

ENCLOSURE 1

NOTICE OF VIOLATION

Virginia Electric and Power Company
North Anna Unit 2

Docket No. 50-339
License No. NPF-7

The following violation was identified during an inspection conducted on October 6 - November 5, 1984. The Severity Level was assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 6.8.1 requires that written procedures be established, implemented, and maintained to control safety-related activity.

Performance test 2-PT-66.3 (Containment Depressurization Actuation Functional Test) specified procedure to test ESF actuation system.

Annunciator Response Procedure 2-AR-10 specified necessary actions to respond to Annunciator E-7 (Recirculation Spray Pump Casing Cooling Tank Level Hi/Low).

Contrary to the above, 2-PT-66.3 was defective and allowed inadvertent opening of MOV-RS-200A, which resulted in draining of the Casing Cooling Tank. Additionally, failure to follow annunciator response procedure 2-AR-10 resulted in 82,000 gallons of water being inadvertently drained to the Reactor Containment Building basement.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: DEC 03 1984

8502060298 850114
PDR ADOCK 05000338
G PDR