

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

85 JAN 22 P 1:55

January 14, 1985

Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission - Region II  
101 Marietta Street - Suite 2900  
Atlanta, Georgia 30323

Subject: McGuire Nuclear Station - Unit 1  
Docket Number 50-370

On December 13, 1984 Diesel Generator (D/G) 1A experienced 3 invalid failures following maintenance, apparently as a result of improper reassembly following maintenance. The investigation of this event is as yet incomplete. A complete report on the Diesel Generator failure will be submitted by February 14, 1985.

Very truly yours,

*H.B. Tucker*

Hal B. Tucker

SAG/mjf

cc: Mr. W. T. Orders  
Senior Resident Inspector  
McGuire Nuclear Station

8502060326 850114  
PDR ADOCK 05000370  
S PDR

OFFICIAL COPY

IE 22

1/0