

CP&L

Carolina Power & Light Company

85 JAN 14 21:05
Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
January 10, 1985

FILE: B09-13510C
SERIAL: BSEP/85-0007

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, GA 30323


BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.3.5.7 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-84-6)

Dear Mr. O'Reilly:

On December 4, 1984, performance of the operability test of the nonsupervised circuitry between the fire detection panels and the Control Room annunciators, PT-35.17, revealed the Control Room annunciator associated with the Unit 1 Reactor Building 117-foot elevation zone 14 fire detection instrument group did not audibly alarm as required. On December 18, 1984, the specified 14-day time frame of the involved LCO for zone 14 fire detection instruments was exceeded.

Troubleshooting revealed a defective logic card in the annunciator panel was preventing the annunciator from audibly alarming. On December 27, 1984, the subject logic card was replaced and the annunciator was satisfactorily tested for operation and returned to service.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/ag/LETAG

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8502060339 850110
PDR ADOCK 05000325
S PDR

OFFICIAL COPY

TE22

1/0