



1650 CALVERT CLIFFS PARKWAY • LUSBY, MARYLAND 20657-1702

GEORGE C. CREEL  
VICE PRESIDENT  
NUCLEAR ENERGY  
(410) 260-4455

July 17, 1992

U. S. Nuclear Regulatory Commission  
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant  
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318  
Report of Steam Generator Tube Plugging

REFERENCE: (a) Calvert Cliffs Unit 1 Technical Specification 4.4.5.5

Gentlemen:

As required by Reference (a), this letter reports the number of tubes plugged in the Calvert Cliffs Unit 1 Steam Generators during the recently completed Inservice Inspection.

Based on recent Eddy Current Examination results of the Unit 1 Steam Generators, we plugged 11 tubes in Steam Generator No. 11 and 7 tubes in Steam Generator No. 12. In addition, a tube (R-93,L-67) in Steam Generator No. 12, which had been erroneously plugged on the cold leg side in 1986 (LER 317/88-03), was plugged on the hot leg side. The total number of tubes plugged in Steam Generator Nos. 11 and 12 are 118 and 77, respectively.

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

GCC/DWM/dwm/bjd

cc: D. A. Brune, Esquire  
J. E. Silberg, Esquire  
R. A. Capra, NRC  
D. G. McDonald, Jr., NRC  
T. T. Martin, NRC  
P. R. Wilson, NRC  
R. I. McLean, DNR  
J. H. Walter, PSC

9207220074 920717  
PDR ADOCK 05000317  
P PDR

Cont No  
P09862342  
A001  
1/0