


Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER

TELEPHONE
(714) 492-7700

January 28, 1985

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

SUBJECT: Docket Nos. 50-361 and 50-362
30-Day Report
Licensee Event Report No. 85-005
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to 10 CFR 50.73(a)(2)(iv), this submittal provides the required 30-day written Licensee Event Report (LER) for two occurrences involving spurious actuations of the Control Room Isolation System (CRIS). Since these events involve components common to Units 2 and 3, a single report is being submitted in accordance with NUREG-1022. The health and safety of plant personnel or the public were not affected by these events.

If you require any additional information, please so advise.

Sincerely,

J.G. Haynes

Enclosure: LER No. 85-005

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)
J. B. Martin (USNRC Regional Administrator, USNRC Region V)
Institute of Nuclear Power Operations (INPO)

8502060401 840128
PDR ADOCK 05000361
S PDR

IE22
1/1