

ENCLOSURE 1

NOTICE OF VIOLATION

South Carolina Electric and Gas Co.
V. C. Summer

Docket No. 50-395
License No. NPF-12

The following violations were identified during an inspection conducted on October 1-31, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 6.8.1 requires that written procedures be established, implemented and maintained for applicable procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978. Appendix A recommends procedures for equipment control (e.g., locking and tagging). Station Special Instruction (SI) 84-05, Locked Valve Control, implements the "locking" portion of this equipment control requirement. SI 84-05 requires that component cooling water heat exchanger inlet valve, XVB 9508B, be "locked open".

Contrary, to the above, on October 29, 1984, valve XVB 9508B was determined to be opened but had its locking device removed.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: NOV 23 1984

8502060504 850109
PDR ADOCK 05000395
Q PDR