

CP&L

Carolina Power & Light Company

P.O. Box 101, New Hill, NC 27562
January 16, 1985

05 JAN 22 P 1: 53

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 2900)
Atlanta, Georgia 30323

NRC-315

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986 - 900,000 KW - UNIT 1
ELECTRICAL SUPPORTS -
INSTALLATION CRITERIA, ITEM 197

Dear Mr. O'Reilly:

On December 20, 1984, CP&L (Mr. F. E. Strehle) notified the NRC (Mr. A. Hardin) of a potentially reportable item per the provisions of 10CFR 50.55(e). The NRC was informed that conduit supports could fail due to the lack of installation criteria concerning the minimum distance conduit fasteners may be installed from the end of B-line strut channels.

The Harris Plant Construction Section, in coordination with the Harris Plant Engineering Section, have assembled worst case conduit support samples for load testing and tests are in progress. In order to complete these tests, analyze test results, and establish design criteria for incorporation into design documents, additional time is required. It is currently projected that a report on the reportability of this item will be issued by March 6, 1985.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons
Project General Manager
Completion Assurance
Shearon Harris Nuclear Power Plant

RMP/rt

cc: Messrs: G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. R. C. DeYoung (NRC)

B502060510 B50116
PDR ADOCK 05000400
S PDR

OFFICIAL COPY

rt-4/1

JEAT 10