

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2						DOCKET NUMBER (2) 0 5 0 0 0 3 6 1 1			PAGE (3) 1 OF 0 1		
--	--	--	--	--	--	--	--	--	----------------------	--	--

TITLE (4)
DELINQUENT IODINE AND PARTICULATE PURGE SAMPLES

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)			
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)		
0 1	0 1	8 5	8 5	0 0 4	0 0	0 1	2 9	8 5	SONGS, UNIT 2	0 5 0 0 0		
										0 5 0 0 0		

OPERATING MODE (9) N

POWER LEVEL (10) 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

20.402(b)	20.405(a)(1)(i)	20.405(a)(1)(ii)	20.405(a)(1)(iii)	20.405(a)(1)(iv)	20.405(a)(1)(v)	20.405(c)	50.36(c)(1)	50.36(c)(2)	50.73(a)(2)(i)	50.73(a)(2)(ii)	50.73(a)(2)(iii)	50.73(a)(2)(iv)	50.73(a)(2)(v)	50.73(a)(2)(vii)	50.73(a)(2)(viii)(A)	50.73(a)(2)(viii)(B)	50.73(a)(2)(X)	73.71(b)	73.71(c)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)
									X											

LICENSEE CONTACT FOR THIS LER (12)

NAME J. G. HAYNES, STATION MANAGER		TELEPHONE NUMBER	
		AREA CODE 7 1 1 4	NUMBER 4 9 2 1 - 7 7 1 0 1 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On December 24, 1984, with Unit 2 defueled, a containment purge was initiated. In accordance with Technical Specification 4.11.2.1.2, Table 4.11-2, which requires that continuous iodine and particulate samples for containment purging be changed at least once per seven days, the weekly particulate and iodine samples were collected on December 25, 1984. During preparation of a new release permit on January 4, 1985, it was discovered that the weekly purge samples, required to be collected on January 1, were not collected. The samples were immediately collected and analyzed. Containment Airborne Radiation Monitor 2RT-7804 (EIIS Component Code RIT) remained operable during this period.


The delinquent sample collection was due to an oversight by the on-shift Chemistry Technician in scheduling the samples to be collected. All Chemistry Foremen and Technicians have been counseled to carefully review all sampling requirements to ensure proper sample scheduling and collection. The scheduling error is considered an isolated occurrence and no further corrective action is planned.

There are no credible circumstances under which this event would have been more severe.

8502060563 850129
PDR ADOCK 05000361
S PDR

IF22
1/1

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER

January 29, 1985

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 85-004
San Onofre Nuclear Generating Station, Unit 2

Pursuant to 10 CFR 50.73(a)(2)(i), this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving delinquent iodine and particulate purge samples. Neither the health and safety of plant personnel nor the public were affected by this event.

If you require any additional information, please so advise.

Sincerely,

Enclosure: LER No. 85-004

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, USNRC Region V)

Institute of Nuclear Power Operations (INPO)

IE22
1/1