NAC Form 348					LIC	CENSEE EVENT REPORT (LER)					U.S. NUCLEAR REGULATORY COMMISSION APPROVED OME NO. 3150-0104 EXPIRES: 8/31/66				
PACILITY	Y NAME (1	1)									DOCKET NUMBER	(2)	PAG	18 13	
BY	RON,	UNIT	1								0 5 0 0	10141514	1 05	a h	
TITLE IA	•											1 - 1 4 13 14	1	IU K	
MI	SSED	SURV	EILL	ANCE FOR	LCOAR										
EVENT DATE (S) LER NUMBER (6)				REPORT DATE IT				OTHER	A FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL	REVISION	MONTH	DAY	YEAR	FACILITY NAMES		MES	DOCKET NUMBERIS			
St. Bur												0 5 0 0	101	11	
					-										
0 1	1 2	8 5	8 5	003	00		2 9	8 5				0 1510 10	101		
	ENITARI		THIS RE	PORT IS SUBMITTE	D PURBUANT 1	THE R	COUIREM	ENTS OF 1	0 CFR 9: /C	heck one or more	of the followings (11	1)			
LONGE OF GLO			20.405(a)(1)(3) 20.405(a)(1)(8) 20.405(a)(1)(8) 20.405(a)(1)(9) 20.405(a)(1)(9)			60.36(a)(1) 60.36(a)(2) 60.73(a)(2)(i) 50.73(a)(2)(ii) 50.73(a)(2)(iii)			90.73(a)(2)(vii) 90.73(a)(2)(viii)(A) 90.73(a)(2)(viii)(B) 90.73(a)(2)(xii)(B)			73.71tel OTHER (Specify in Abstract Setow and in Test, NRC Form 364A)			
						ICENSES	CONTACT	FOR THIS	LER (12)						
DO	ug Kr	uger	, Sys	stem Test	Enginee	r, E	xt. 3	14			8 1 5	2 3 4 -	15 14	4 1	
				COMPLETE	ONE LINE FOR	EACH CO	OMPONEN	T FAILURE	DESCRIBE	O IN THIS REPOR	AT (13)				
CAUSE	SYSTEM	COMPC	DNENT	MANUFAC	REPORTABLE TO NPROS			CAUSE	SYSTEM	COMPONENT	MANUFAC- TURER	MEPORTABLE TO NPROS			
A	E B	B	KIR	W 1 2 0	N					111	111				
				111						111					
SUPPLEMENTAL REPORT EXPECTED (14)								EXPECTED MONTH DAY YE		YEAR					
7	1 //f vm. co	omerem f	XPECTED	SUBMISSION DATE	,	-	7 00				SUBMISSIO	ON			

A Technical Specification Action statement time interval was exceeded. One of the reserve offsite transmission circuits was not available, and the required periodic surveillance of the remaining offsite transmission circuits was not performed when due. The requirement for timely processing of surveillances is being reiterated with shift personnel through required reading.

8502080050 850129 PDR ADOCK 05000454 PDR

ABSTRACT (Limit to 1400 spaces, i.e. approximetally fifteen single-space typewritten lineal (16)

1 E2 ?

LICENSEE E	EVENT REPORT (LER) TEXT CONTINU	APPROVED O	U.S. NUCLEAR REQULATORY COMMISSION APPROVED DMB NO. 3150-0104 EXPIRES: 8/31:95				
FACILITY NAME (1)	DOCKET NUMBER (2)		LER NUMBER (8)	PAGE (3)			
		YEAR	SEQUENTIAL MEVISION				
BYRON, UNIT 1	0 5 0 0 0 4 5 4	8 5	_0р13 _0р	0 2 0 0 0 2			

On 1/11/85, at 1850 CST, during Mode 3 operation, a Technical Specification surveillance was due but was not performed. An LCO action statement had been entered when one of the reserve offsite transmission circuits was made unavailable due to relay testing. The action statement required determination of operability of the remaining offsite transmission circuits every eight hours. The required surveillance was performed at 2356 hours on 1/11/85 and was performed late again at 1215 hours on 1/12/85. The reserve offsite transmission circuit was restored at 1842 hours on 1/12/85.

There was no impact on plant or public safety because it was not necessary to revert to the reserve offsite circuit for plant operation.

The station has issued required reading for operating shift personnel regarding the timely processing of surveillances.

Previous similar occurrences: None.

January 29, 1985

LTR:

BYRON 85-0154

U. S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Dear Sir:

The enclosed Licensee Event Report from Byron Generating Station is being transmitted to you in accordance with the requirements of 10CFR 50.73 (a) (2) (i) (B) which requires a 30 day written report.

This report is number 85-03-00, Docket No. 50-454.

Very truly yours,

R. E. Querio

Station Superintendent

Byron Nuclear Power Station

Enclosure: Licensee Event Report No. 85-03-00.

cc:

J. G. Keppler, NRC Region III Administrator

J. Hinds, NRC Resident Inspector

INPO Record Center CECO Distribution List

1E22