
Individual Plant Examination

of the

Perry Nuclear Power Plant

July 1992

Cleveland Electric Illuminating Company



Abstract

A Level 2 probabilistic risk assessment of the Perry Nuclear Power Plant has been performed in response to the NRC Generic Letter No. 88-20 dated November 23, 1988 requesting an Individual Plant Examination for Severe Accident Vulnerabilities - 10CFR50.54(f).

The primary results are a delineation of the likely frequency of core damage as the result of internal initiating events including internal flooding and the expected frequency and magnitude of fission product release as the result of the containment response following core damage. In addition the specific contribution of decay heat removal failure to core damage has been assessed.

The total core damage frequency is approximately 1.3 X 10⁻⁵ per year. anticipated transients without scram and loss of offsite power are the major contributors to core damage. Containment failure as the result of steam over pressure is the dominant contributor to offsite releases.

Acknowledgments

The Perry Individual Plant Examination was performed by a team of personnel from Cleveland Electric Illuminating Company, Halliburton NUS Environmental Corporation, Gilbert Commonwealth, and Gabor Kenton and Associates. The project has benefited from advice and review from RAPA in the case of the Level 1 portion of the study and ERIN in the case of the Level 2.

The provision of information and performance of review by the operational and engineering s "f at Perry was a key factor in ensuring the accuracy of the final plant model.

Project Team

CEI

T	.A.	Lentz
S.	. P.	Meyer
W	. J.	Colvir
K	.A.	Javor
J	.R.	Spano

Halliburton NUS

M.G.K. Evans G.W. Parry K. Jamali E. Jorgenson R.R. Sherry² M. Cheok P. Guymer B. Lydell F. Zikria

1. Now Department of Energy 2. Now Gabor Kenton Assoc.

at store wateres storesteres repaires

Gilbert Commonwealth

R. Schmehl M.A. Capiotis R.L. Mauchline S.N. Maruvada J.J. Nyeste L.M. Englert M.M. Waselus J.A. Stoudt

Table of Contents

Page

1.0	EXECUTIVE SUMMARY	11
	1.1 Background and Objectives	1-1
	1.2 Plant Familiarization	1-2
	1.3 Overall Methodology	1-2
	1.4 Summary of Major Findings	1-4
	1.4.1 Summary of Core Damage Frequency for Internal Events	1-4
	1.4.2 Summary of Core Damag. Frequency from Internal Flooding	1-8
	1.4.3 Summary of Containment Evaluation	1-9
	1.4.4 Comparison of Results With Other Studies	1-11
	1.4.5 Decay Heat Removal Evaluation - Issue A-45	1-13
	1.4.6 Potential Improvements	1-15
	1.4.7 Conclusions	1-17
2.0	EXAMINATION DESCRIPTION	2-1
	2.1 Introduction	2-1
	2.2 Conformance with Generic Letter and Supporting Material	2-1
	2.2.1 Examination Process	2-1
	2.2.2 External Events	2-1
	2.2.3 Methods of Examination	22
	2.2.4 Resolution of Unresolved Safety Issue A-45	2-2
	2.2.5 Severe Accident Sequence Selection	2-2
	2.2.6 Documentation of Examination Results	2-2
	2.3 General Methodology	2-3
	2.3.1 Initiating Events And Success Criteria	2-4
	2.3.2 Accident Sequence Development	2-4
	2.3.3 Data Base	2-5



	2.3.4	Dependent Failures and Interaction	2-5
	2.3.5	System Modeling	2-6
	2.3.6	Human Interaction Analysis	2-6
	2.3.7	Aucident Sequence Quantification	27
	2.3.8	Plant Damage State Analysis	2-7
	2.3.9	Containment Evaluation	27
	2.3.10	Risk Contribution Evaluation	28
	2.4	Information Assembly	2-8
.0	FRONT H	IND ANALYSIS	
	3.1	Accident Delineation	3-1
	3.1.1	Initiating Events	3-1
	3.1.2	Frontline Event Trees	3-10
	3.1.3	Special Event Trees	3-23
	3.1.4	Sequence Grouping and Back End Interface	3-43
	3.2	System Analysis	3-48
	3.2.1	RPV Depresurization System, B21	3-48
	3.2.2	Standby Liquid Control, C41	3-50
	3.2.3	Residual Heat Removal, E12	3-51
	3.2.4	Low Pressure Core Spray, E21	3-54
	3.2.5	High Pressure Core Spray, E22	3-55
	3.2.6	Reactor Core Isolation Cooling, E51	3-57
	3.2.7	Emergency Closed Cooling, P42	3-58
	3.2.8	Emergency Service Water, P45	3-60
	3.2.9	Service/Instrument Air Systems, P52/P52	3-61
	3.2.10	Safety Related Instrument Air System, P57	3-62
	3.2.11	Fire Protection, P54	364
	2 2 1 2	D.C. Electrical System, B42	3-65

iv

3.2.13 AC Power, Standby Diesel Generator System, R43 High Pressure Core Spray Diesel Generator System, E22B	3-66
3.2.14 Suppression Pool Make-Up, G43 Drywell Vacuum Relief, M16	3-67
3.2.15 Diesel Generator Building Ventilation	3-71
3.2.16 Condensate Transfer System	3-72
3.2.17 Containment Venting (FPCC)	3-73
3.2.18 Containment Venting (RHR)	374
3.3 Sequence Quantification	376
3.3.1 List of Generic Data	3+76
3.3.2 Plant Specific Data and Analysis	3-76
3.3.3 Human Failure Data (Generic and Perry)	3-76
3.3.4 Common Cause Failure Data	3-79
3.3.5 Quantification of Unavailabilities of Systems and Functions	3-80
3.3.6 Quantification of Sequence Frequencies	3-81
3.3.7 Internal Flooding	3-83
3.4 Results and Screening Process	3-91
3.4.1 Application of Generic Letter Screening Data	3-91
3.4.2 Vulnerability Screening	3-107
3.4.3 Decay Heat Removal Evaluation - Issue A-45	3-109
0 BACK-END ANALYSIS	
4.1 Plant Data	4-1
4.1.1 Mark III Plant Features	4-1
4.1.2 Sources for Data	4-1
4.2 Plant Models and Methods for Physical Processes	42
4.2.1 MAAP Analysis Assumptions (Model Parameters)	4-2
4 3 Bins and Plant Damage States	4-2

	4.3.1	Plant Damage State Grouping Parameters	42
	4.3.2	PDS Grouping Logic and PDS Characteristics	4-5
	4.3.3	PDS Frequencies and Dominant Sequences	4-11
	4.4	Containment and Drywell Failure Characteristics	4-12
	4.4.1	Containment Failure Modes	4-12
	4.4.2	Drywell Failure Modes	4-13
	4.4.5	Containment Overpressure Fragility	414
	4.4.4	Containment Overpressure Failure Impact on RPV Injection	4-15
	4.4.5	Drywell Overpressure Fragility	4-16
	4.5	Containment Event Trees	4-17
	4.5.1	Containment Severe Accident Analysis	4-17
	4.5.2	Summary of Event Tree Structure	4-18
	4.5.3	APET Quantification	4-42
	4.6	Accident Progression	445
	4.6.1	Summary of Sequences Analyzed	4-45
	4.6.2	APET Sensitivity Analysis	4-45
	4.6.3	Containment Performance Improvement Sensitivity Analysis	4-48
	4.7	Radionuclide Release Characterization	4-51
	4.7.1	Release Category Grouping Parameters and Grouping Logic	4-51
	4.7.2	Release Category Grouping Logic Tree and Release Category Characteristics	4-55
	4.7.3	Release Category Source Term Characteristics	456
	4.7.4	Release Category Point Estimate Frequencies and Sequences	Dominan 4–57
0	UTIL	TY PARTICIPATION AND INDEPENDENT REVIEW TEAM	
	5.1	IPE Organization	5-1
	5,2	Independent Review	51
	5.3	Areas of Review and Major Comments	5-2

1.1

	υ		80			
1	Ð	Ø.				
4		64				
	ч	10		21	æ	
	3	1		9	P.	

(A)

6

	5.3.1	Level 1 Review	5-2
	5.3.2	Level 2 Review	5-3
	5.4	Resolution of Comments	5-3
	5.4.1	Resolution of Comments on Level 1	55
	5.4.2	Resolution of Comments on Level 2	5-6
.0	POTENT	TAL PLANT IMPROVEMENTS AND UNIQUE SAFETY FEATURES	
	6.1	Unique Safety Teatures	6-1
	6.1.1	Core Damage Safety Features	6-1
	6.1.2	Unique and/or Important Containment Festures	6-2
	6.2	Plant Design Considerations	62
	6.2.1	Plant Improvements Made Due to IPE Insights	6-2
	6.2.Z	Design Considerations for Reduction in Core Damage Frequency	6-3
	6.2.3	Design Considerations for Reduction in Containment Failure	6+3
	6.3	Program for Inclusion of Plant Design Changes	6-5
.0	SUMMAR	AND CONCLUSION	
	7.1	Core Damage Frequency	7-1
	7.1.1	Comparison With Grand Gulf Results	7-1
	7.1.2	Severe Accident Closure Issues	7-3
	7.2	Containment Analysis	7-4
	7.2.1	Severe Accident Closure Issues (NUMARC 91-04)	7-4
	7.2.2	Comparison With Grand Gulf Results	75
	7.2.3	Severe Accident Closure Issues	7-1
	7.2.4	Severe Accident Closure Sensitivity Analysis	7-7
	7.3	Conclusions	77



Appendix A	System Fault Trees
Appendix B	Success Criteria
Appendix C	Data Analysis
Appendix D	Human Interaction
Appendix E	Functional Fault Trees
Appendix F	Sequence Quartification
Appendix G	Internal Flooding
Appendix H	Back End Analysis

List of Tables

1-1	Summary of Core Damage Frequency by Initiating Event & Flood Zone
1-2	Sequence Core Damage Frequencies Grouped by Initiator
1-3	Sequences Within the Upper 95% of Total Core Damage
1-4	Importance Ranking of Components (Fussel).Vesely)
1-5	Importance of Basic Events Ranked by Risk Achievement Worth
1-6	Accident Sequence Grouping Criteria and Results
1-7	Containment Performance Comparison of Design Change Considerations
1-8	Comparison of Perry IPE with Kuosheng Cofrantes, & NUREG/CR-4350 Results
1-9	Comparison of Plant Design Features
1-10	Summary of Containment Failure Frequency
2-1	List of Procedures
2-2	Summary of Design Features - Perry
2-3	Significant Insights from Other Studies
24	Comparison of Core Damage Frequency From Various FRAs
3.1.	1-1 PNPP IPE Initiating Event List
3.1.	1-2 EPRI BWR Transient Category Deficitions
3.1.	1-3 Interfacing LOCA Evaluation
3.1	.1-4 LOCA Bypassing Containment Evaluation
3.1	.1-5 EPRI Events Included in the Transient Categories
3.1	.2-1 List of Front Line and Support Systems
3.1	.2-2 Dependency of Front Line Systems on Support Systems
3.1	.2-3 Dependency of Support Systems on Support Systems
3.1	.2-4 Succiss Criteria for Transients with Loss of PCS (T2)
3.1	.2-5 Success Criteria for Transients with PCS Available (T3A)
3.1	.2-6 Success Criteria for Transients with Loss of Feedwater (T3B)
3.1	1.2-7 Success Criteria for Large LOCA (A)
	사람이 많은 것 같은 것

List of Tables (continued)

3.1.2-8	Success Criteria for Intermediate LOCA (S1)
3.1.2-9	Success Criteria for Small LOCA (52)
3.1.3-1	Success Criteria for Loss of Offsite Power (T1)
3.1.3-2	Success Criteria for Station Blackout (B)
3.1.3-3	Success Criteria for IORV Transients (T3C)
3.1.3-4	Success Criteria for ATVS
3.2.1-1	PPV Depressurization System, B21, Dependency Matrix
3.2.2-1	Standby Liquid Control System, C41, Dependency Matrix
3.2.3-1	Residual Heat Removal System, E12, Dependency Matrix
3.2.4-1	Low Pressure Core Spray System, £21, Dependency Matrix
3.2.5-1	High Pressure Core Spray System, E22, Dependency Matrix
3,2.6-1	Reactor Core Isolation Cooling System, ES1, Dependency Matrix
3.2.7-2	Emergency Closed Cooling System, P42, Dependency Matrix
3.2.8-1	Emergency Service Water System, P45, Dependency Matrix
3.2.9-1	Service/Instrument Air System, P51/52, Dependency Matrix
3.2.10-1	Safety Related Instrument Air System, P57, Dependency Matrix
3.2.11-1	Fire Protection System, P54, Dependency Matrix
3.2.12-1	D.C. Electrical System, R42, Dependency Matrix
3.2.13-3	AC Power Standby Diesel Generator System, R43 and High Pressure Core Spray Dierel Generator System, E22B Lependency Matrix
3.2.14-1	1 Suppression Pool Make Up System, G43, Dependency Matrix
3.2.14-	2 Dryvell Vacuum Relief System, M16, Dependency Matrix
3.2.15-	1 Diesel Generator Building Ventilation System, M43, Dependency Matrix
3.2.16-	1 Alternate Injection System, Dependency Matrix
3.2.17-	1 Containment Venting System, D23, Dependency Matrix
3.3.2-1	Basic Event Database
3.3.3-1	Human Interaction Database

х

List of Tables (continued)

- 3.3.4-1 CCF Probabilities for Various CCF Events
- 3.3.5-1 Function Unavailabilities
- 3.3.7-1 Flooding Screening Analysis Results
- 3.3.7-2 Flooding Conditional Core Damage Probabilities
- 3.3.7-3 Detailed Flooding Results
- 3.4.1-1 Summary of Core Damage Grouped by Initiating Event
- 3.4.1-2 Summary of Core Damage Sequences Grouped by Initiating Event
- 3.4.1-3 Sequences Contributing 95% to the Core Damage Frequency
- 3.4.1-4 Sequences Leading to Containment Failure Prior to Core Damage
- 3.4.1-5 Sequences Below 10" Because of Human Interaction Reliability
- 3.4.1-6 Contribution to Core Damage by Internal Events Initiator
- 3.4.1-7 Importance Ranking of Components (Pussell-Vesely)
- 3.4.1-8 Importance Ranking of Components (Risk Achievement)
- 3.4.1-9 Contribution of Functional Failure to Core Damage
- 3.4.1-10 APET Containment Performance Base Case Results
- 3.4.1-11 Dominant Containment Failure Plant Damage States
- 3.4.1-12 Recovery Actions Included in the Model
- 3.4.1-13 Impact of Recovery Actions on Core Damage Frequency
- 3.4.1-14 Sensitivity Analysis Results
- 3.4.1-15 Core Damage Frequency Based on Revised Initiating Event Frequencies
- 3.4.2-1 Accident Sequence Grouping Criteria
- 3.4.2-2 Individual Core Damage Sequence Group d by Accident Class
- 4.1.1-1 Comparison of Mark III Containment Design Characteristics
- 4.3.3-1 Dominant Plant Danage States
- 4.4.1-1 Ultimate Containment Failure Modes
- 4.4.1-2 Expected Type of Containment Failure
- 4.4.2-1 Ultimate Drywell Failure Modes

List of Tables (continued)

Perry IPE Accident Progression Event Tree Questions 4.5.1-1 4.5.3-1 APET Base Case Results APET Containment Performance Base Case Results for Dominant PDS 4.5.3-2 Groups Dominant Containment Failure Plant Damage States 4.5.3-3 Impact of Design Changes on Containment Failure Frequency 4.6.3-1 Impact of Design Changes on Containment Failure Frequency Using 4.6.3-2 Updated Initiator Frequency Containment Performance Comparison of Design Change Considerations 4.6.3-3 Representative Sequences for Release Fraction Analysis 4.7.3-1 Time of Occurrence for Important Events in Release Cat ory Cases 4.7.3-2 Composite Source Term Category Release Fractions 4.7.3-3 Recommendations for Release Fractions for Unanalyzed Source Term 4.7.3-4 Categoriea MAAP Fission Product Species 4.7.3-5 Dominant Source Term Categories 4.7.4-1 Importance of Plant Damage States to Release Categories 4.7.4-2 Impact of Design Changes on Core Damage Frequency 6-1 Impact of Design Changes on Containment Failure Frequency 6-2 Impact of Design Changes on Containment Failure Frequency 6.3 Lawing Updated Initiator Frequency Summary of Core Damage Frequency by Initiating Event & Flood Zone 7-1 Comparison of Perry IPE with Kuosheng, Cofrentes, & NUREG/CR-4550 7-2 Results Accident Sequence Grouping Criteria 7-3 Primary IPE Core Damage Evaluation Process 7-4 Containment Performance of Design Change Considerations 7-5 IPE Containment Bypass Evaluation Frocess 7-6 Impact of Design Changes on Containment Failure Frequency Using Updated 7-7 Initiator Frequency xi'

List of Figures

1-1 Cu	mulative Distribution
1-2 Co	ntributors of Accident Initiation to CDF
1-3 Do	minant Basic Events Banked by Fussel-Vesely Importance
1-4 Co	ntributors of Each Flood Zone to Core Damage
2+1 P+	oject Organization
2-2 Ov	erview of Level 1 Methodology
2-3 Ov	erview of Level 2 Methodology
3.1.2-1	Transient With Loss of PCS Event Tree
3.1.2-2	Transient With PCS Available Event Tree
3.1.2-3	Transient With Loss of Feedvater
3.1.2-4	Large LOCA Event Tree
3.1.2-5	Intermediate LOCA Event Tree
3.1.2-6	Small LOCA Event Tree
3.1.3-1	Loss of Offsite Power Event Tree
3.1.3-2	Station Blackout Event Tree
3.1.3-3	Transient With Inadvertent Open Relief Valvo Event Tree
3.1.3-4	Loss of Instrument Air Event Tree
3.1.3-5	Loss of Service Water Event Tree
3.1.3-6	Loss of Control Complex Chilled Water Event Tree
3.1.3-7	Loss of Offsite Power - ATWS Event Tree
3.1.3-8	Transient With Loss of PCS - ATWS Event Tree
3.1.3-9	Transient With PCS Available - ATWS Event Tree
3.1.3-10	Transient With Loss of Feedwater - ATWS Event Tree
3.1.3-11	Transient With Inadvertent Open Relief Valve - ATWS Even
3.1.3-12	Loss of Instrument Air - ATWS Event Tree
3.1.4-1	Loss of PCS - PDS Event Tree (T2)

Event Tree

- 3.1.4-2 PCS Available PDS Event Tree (T3A)
- 3.1.4-3 Loss of Feedvator PDS Event Tree (T3B)
- 3.1.4-4 Large LOCA PDS Event Tree (A)
- 3.1.4-5 Intermediate LOCA PDS Event Tree (S1)
- 3.1.4-6 Small LOCA PDS Event Tree
- 3.1.4-7 Loss of Offsite Power PDS Event Tree (T1)
- 3.1.4-8 Station Blackout PDS Event Tree
- 3.1.4-9 Inadvertent open Relief Valve PDS Event Tree (T3C)
- 3.1.4-10 Loss of Instrument Air PDS Event Tree (TIA)
- 3.1.4-11 Loss of Service Air PDS Event Tree (TSW)
- 3.1.4-12 Loss of CCCW PDS Event Tree (TCW)
- 3.1.4-13 ATVS and LOOP PDS Event Tree (T1-C)
- 3.1.4-14 ATVS and Loss of PCS PDS Event Tree
- 3.1.4-15 ATWS With PCS Available PDS Event Tree
- 3.1.4-16 ATWS With Loss of Feedwater IOS Event Tree
- 3.1.4-17 ATWS With IOV PDS Event Tree
- 3.1.4-18 ATWS With Loss of Instrument Air PDS Event Tree
- 3.1.4-19 Plant Damage State Grouping Logic
- 3.2.1-1 RPV Depressurization System Drawing (ADS/SRV Orientation)
- 3.2.1-2 RPV Depressurization System Drawing (Air Supply)
- 3.2.2-1 Standby Liquid Control System Draving
- 3.2.3-1 RHR Low Press Clnt Injection Train A System Draving
- 3.2.3-2 RHR Low Press Clnt Injection Train B System Drawing
- 3.2.3-3 RHR Low Press Clnt Injection Train C System Drawing
- 3.2.3-4 RHR Containment Spray Train A System Draving
- 3.2.3-5 RHR Containment Spray Train B System Drawing
- 3.2.3-6 RHR Suppression Pool Cooling Train A System Drawing

xiv

3.2.3-7	RHR - Suppression Pool Cooling Train B System Draving
3.2.4-1	Low Pressure Core Spray System Draving
3.2.5-1	High Pressure Core Spray System Drawing
3.2.6-1	Reactor Core Isolation Cooling System (E51) System Drawing
3.2.7-1	Emergency Closed Cooling Train A System Drawing
3.2.7-2	Emergency Closed Cooling Train B System Draving
3.2.8-1	Emergency Service Water System Drawing
3.2.9-1	Service/Instrument Air System (P51/P52) System Draving
3.2.10-1	Safety Related Instrument Air System Draving
3.2.11-1	Fire Protection (RPV Injection) System Draving
3.2.12-1	DC Power (Div 1) System Drawing
3.2.12-2	DC Power (Div 2) System Drawing
3.2.12-3	DC Power (Div 3) System Drawing
3.2.13-1	AC Power System Drawing
3.2.14-1	Suppression Pool Make Up Trains A & B System Draving
3.2.14-2	Dryvell Vacuum Relief System Draving
3.2.15-1	Diesel Generator Room Ventilation System Drawing
3.2.16-1	Condensate Transfer Alternate Injection System Drawing
3.2.17-1	Containment Venting Fuel Pool Clng & Cleanup System Drawing
3.2.18-1	Containment Venting RHR Containment Spray - Train A System Draving
3.2.18-2	Containment Venting RHR Containment Spray - Train B System Drawing
3.3.7-1	Pie Chart Showing Core Damage by Flood Zone
3.4.1-1	Cumulative Distribution Function for Core Damage Frequency
3.4.1-2	Contribution of Internal Initiators to Core Damage Frequency
3.4.1-3	Plant Damage State Grouping Logic
4.1.1-1	PNPP Mark III Containment
4.3.2-1	Plant Damage State Grouping Logic
	XV



Containment Overprossure Fragility 4.4.3-1 Fast Overpressure Conditional Probability of Anchorage Failure 4.4.3-2 Quantification of Cv, Core Not Vulnerable to Damage, for HPCS 4.4.4-1 Quantification of Cv, Core Not Vulnerable to Damage, for LP ECCS 4.4.4-2 Quantification of Cv, Core Not Vulnerable to Damage, for Fdwtr Inj 4.4.4-3 Quant of Cv, Core Not Vulnerable to Damage, for Inj Outside AB 4.4.4-4 Drywell External Overpressure Fragility 4.4.5-1 Summary Containment Event Tree 4.5.2.1-1 Debris Cooled In-Vessel Decomposition Event Tree (DET) 4.5.2.2.1-1 Mode of Containment Failure Before RPV Failure DET 4.5.2.2.2-1 4.5.2.2.3-1 Injection & Spray Failure Due to Containment Failure Before **RPV** Failure DET 4.5.2.2.4-1 Dryvell Failure At/Near RPV Failure DET 4.5.2.2.5-1 Hode of Containment Failure At/Near RFV Failure DET 4.5.2.2.6-1 Fool Bypass Before/Near RPV Failure DET Injection & Spray Failure Due to Containment Failure 4.5.2.2.7-1 At/Near RPV Failure DET 4.5.2.2.8-1 Pedestal Failure Due to Core Debris Concrete Interaction DET 4.5.2.2.9-1 Mode of Late Burn & Overpressure Containment Failure DET 4.5.2.2.10-1 Pool Bypass Late DET 4.7.1-1 Source Term Category Grouping Logic 5.1-1 Project Organization Chart 5.1-2 Project Organization 6.2.2-1 Containment Performance: Base Case 6.2.2-2 Containment Performance: Passive Vent 6.2.2-3 Untmnt Performance: Auto ADS Inhibit & Alt Shutdown 6.2.2-4 Containment Performance: Hydrogen Ignition System Backup Power 6.2.2-5 Cntmt Performance: Passive Vent & ATWS Mods

- 6.2.2-6 Cntmt Performance: Vent, ATVS Mods & HIS Power
- 7-1 Contribution to Core Damage by Initiating Event
- 7-2 Contribution to CDF by Initiator
- 7-3 Core Damage By Flood Zone
- 7-4 Functional Accident Sequence Groups

TABLE OF ACRONYMS

- A Large LOCA
- AC Alternating Current
- ADS Automatic Depressurization System
- APET Accident Progression Event Tree
- ARI Alternate Rod Insertion or Alarm Response Instructions
- ASEP Accident Sequence Evaluation Program
- ATWS Anticipated Transient Without Scram
- BOP Balance of Plant
- BWR Boiling Water Reactor
- CCCV Control Complex Chilled Water System
- CCI Core Concrete Interaction
- CD Core Damage
- CDF Core Damage Frequency
- CET Containment Event Tree
- CM Mechanical Failure of Control Rods (Basic Event)
- CRD Control Rod Drive
- CS Containment Spray
- CST Condensate Storage Tank
- CTS Condensate Transfer System
- Cv Core Vulnerable
- DAM Disalloved Maintenance
- DC Direct Current
- DET Decomposition Event Tree
- D/G Diesel Generator
- ECC Emergency Closed Cooling System
- ECCS Emergency Core Cooling System
- EOP Emergency Operating Procedure

TABLE OF ACRONYMS

EPG	Emergency Procedure Guideline
EPRI	Electric Pover Research Institute
ERIN	ERIN Engineering and Research, Inc.
ESF	Engineered Safety Feature
ESV	Emergency Service Water System
EVNTR	E Event Progression Analysis Progre-
FMEA	Failure Modes and Effects Analysis
FPCC	Fuel Pool Cooling and Clean-up System
FV	Feedwater
G/C	Gilbert/Commonwealth, Inc.
HEP	Human Error Probability
HI	Human Interaction
HPCS	High Pressure Core Spray
HRA	Human Reliability Analysis
HVAC	Heating Ventilation and Air Conditioning
IA	Instrument Air
INPO	Institute of Nuclear Power Operations
IOI	Integrated Operating Instruction
IORV	Inadvertent Open Relief Valve
IREP	Interim Reliability Evaluation Program
LER	Licensee Event Report
LOCA	Loss of Coolant Accident
LOOP	Loss of Offsite Power
LPCI	Low Pressure Crolant Injection
LPCS	Low Pressure Cc e Spray
MAAP	Modular Accident Analysis Program
MCC	Motor Control Center

8

TAJLE OF ACEONYMS

- MFP Motor Feed Pump
- MOV Mctor Operated Valve
- MSIV Main Steam Isolation Valve
- NCC Nuclear Closed Cooling System
- NPRDS Nuclear Plant Reliability Data System
- NPSH Net Positive Suction Head
- NRC Nuclear Regulatory Commission
- NSSS Nuclear Steam Supply System
- NSSSS Nuclear Steam Supply Shutoff System
- NUCAP NUS Containment Accident Processes Vorkstation
- NUPRA NUS Probabilistic Risk Assessment Workstation
- NUS Haliburton NUS Corporation
- P&ID Piping and Instrumentation Drawing
- PCS Power Conversion System
- PDS Plant Damage State
- PEI Plant Emergency Instructions
- PRA Probabilistic Risk Assessment
- RAPA Reliability and Performance Associates
- RCIC Reactor Core Isolation Cooling
- RFBP Reactor Feed Booster Pump
- RHR Residual Heat Removal
- RPS Reactor Protection System
- RPT Recirculation Pump Trip
- RPV Reactor Pressure Vessel
- RSSMAF Reactor Safety Judy Methodology Application Program
- S1 Intermediate LOCA
- S2 Small LOCA

TABLE OF ACRONTHS

- SA Service Air
- SBO Station Blackout
- SIA Safety Related Instrument Air
- SLC Standby Liquid Control System
- SOI System Operating Instruction
- SPC Suppression Pool Cooling
- SPMU Suppression Pool Make-
- SRV Safety Relief Valve
- SW Service Water
- T1 Loss of Offsite Power Transient
- T2 Transient with loss of PCS
- T3A Transient with PCS initially available
- T3B Transient caused loss of Feedvater
- T3C Transient caused by IORV
- TAF Top of Antive Fuel
- TCW Transient caused by loss of CCCW
- TIA Transient caused by loss of Instrument Air
- TSW Transient caused by loss of Service Water
- USAR Updated Final Safety Analysis Report

1.0 EXECUTIVE SUMMARY

This document presents the results of the Level 2 Probabilistic Risk Assessment (PRA) performed in response to the NRC Generic Letter (NRC, 1988) which requested each licensee to perform a plant examination of each of their nuclear power plants to search for vulnerabilities to severe accidents and propose cost effective safety improvements that reduce or eliminate the important vulnerabilities. The content and format of this report is in accordance with the NRC submittal guidance document (NRC, 1989) and provides sufficient information to show how the results were obtained and how they can be reproduced.

This summary includes a discussion on the background and objectives (1.1), the plant familiarization activities (1.2), the overall methodology (1.3), and a summary of the major findings of the study (1.4).

1.1 BACKGROUND AND OBJECTIVES

The Commission issued a policy statement in 1985 to the effect that, based on available information, existing plants pose no undue risk to the public heal 1 and safety and that there is no present basis for immediate action on generic rulemaking or other regulatory requirements for these plants. However it was decided that a systematic evaluation of each plant would be beneficial in that it would provide information on any plant-specific vulnerabilities to accidents and, through their resolution, enhance safety. In addition to identifying each vulnerability it was Jecided that unlike many earlier PRAs, the IPE should be performed by a team in which utility personnel played a major part as recommended in the generic letter. Thus the IPE would ensure that utility personnel also achieved the following:

1. The development of an appreciation of severe accident behavior.

- An understanding of the most likely severe accident sequences that could occur at the plant.
- 3. The gaining of a more quantit, ive understanding of the overall probabilities of core damage a: J fission product release.
- 4. If necessary, the reduction of the overall frequency of core dumage and fission product release by notification, where appropriate, of hardware or procedures that would likely prevent or mitigate severe accidents.

It was considered that these objectives, and the additional CEI objective of having a fring PRA, would best be achieved by performing a PRA. The advantage of having a living PRA is that it could be used in the future for some or all of the following uses:

- To compare the costs and benefits of various proposed equipment modifications.
- To establish what, if any, improvements should be made to procedures.

- To identify which accident sequences should be used for operator retraining.
- 4. To determine the variations in risk for a range of maintenance options for a given plant state.
- 5. To evaluate proposed changes to Technical Specifications or limiting conditions of operation.

It should be emphasized that the involvement of CEI personnel in all aspects of the analysis and the development of the plant models and appropriate support documentation has ensured that the PRA represents the risk posed by the Perry Plant as accurately as possible, and therefore enables the above objectives to be met.

1.2 PLANT FAMILIARIZATION

The project team consisted of five CEI engineers (3 full time and 2 part time) and a number of engineers from Halliburton NUS Environmental Corporation, Gilbert Commonwealth and Associates and Gabor Kenton and Associates. One of the CEI personnel had over seven years experience in the operations department at Perry, where he served as Operations Engineering Human Factors Unit Lead Engineer, and played a major part in developing the emergency operating procedures, as a member of the BWR Owners Group Emergency Operating Procedures Committee. A second member of the group was also SRO certified. The other CEI engineers had considerable plant experience as members of either the Independent Safety Engineering Group or Mechanical Design Section on site at the Perry Plant.

As the study was performed on site at Perry, visits were made to the unit whenever plant-specific information concerning the layout of components, maintenance practices, or specific operational information was required. In addition, there was ready access to the latest drawings, operational and training experience, and the appropriate design, licensing and maintenance engineers. All work products were reviewed by CEI personnel directly involved in plant operation and design as well as by independent review teams.

1.3 OVERALL METHODOLOGY

The methodology used to perform the IPE for Perry is the performance of a Level 2 PRA. The specific approach used is very similar to that used in the recent Sandia PRA of Grand Gulf for the NRC (NUREG/CR-4550, Drouin, 1989). Fundamentally this is based on the use of event trees to develop the sequence of events following a plant transient or loss of coolant accident and fault trees to model the potential system failures at each phase of the sequence of events. Each individual core damage sequence following a transient or loss of coolant accident is quantified by linking together the fault trees for the potential system and support system failures. The results of the quantification define the combination of component or other failures that will lead to inadequate cooling of the core and failures of the containment systems designed to prevent or mitigate the release of fission products. The fission product source term resulting from core damage is determined by extending the analysis of events through the phases of core damage, vessel failure, containment failure, and, ultimately, release of fission products. In order that this process may be represented in a logical manner, an Accident Progression Event Tree [similar to that used in the Grand Gulf study reported in NUREG/CR-4551, (Brown, 1990)] is developed to represent the range of possible events associated with containment loading mechanisms such as steam generation, hydrogen generation and combustion and the subsequent variations in pressure and temperature within containment. In order to investigate these events the MAAP code was used to model core meltdown, vessel failure, hydrogen generation and burning, and the corresponding variations in containment pressure. A containment capacity analysis was performed to determine the various failure modes and ultimate capacity. The comparison of the pressure transients and their frequency with the results of containment ultimate strength analysis enables the frequency of the containment failure in the different modes to be determined.

Finally the source terms for the various containment failure scenarios identified above were estimated based on the work done by Sandia National Laboratories for the evaluation of severe risks (Brown, 1990) and the use of new MAAP analyses for dominant sequences in each release category.

The methodology used to perform the analysis is corribed in more detail in Chapter 2. As the PRA aimed at identifying specific strengths and weaknesses of the design and operation at Perry, particular emphasis was placed on ensuring that the information used to perform the study (P&ID, operating procedures, maintenance experiences) represented the current condition of the plant (January 1990).

Particular attention was paid to the relationship between system failures following a plant trip and the actions that the operators would take in accordance with the Plant Emergency Instructions (PEI). In this way the PEIs were integrated into the system and sequence analysis so that not only individual operator actions could be assessed but also combinations of operator action required to prevent development or continuation of a sequence of failures that would lead to core damage. The evaluation was based on a careful review of the PEIs related to each scenario. Training and operational staff were interviewed to enhance the qualitative understanding of the way in which the operators use the procedures in the course of a sequence, and to assist in quantifying the failure probabilities of key actions. Measurements were made of the time taken to perform a number of actions outside the control room in order to ensure that proper credit was given for the operators performance following various system failures.

Plant-specific data were collected and analyzed for system maintenance outages and initiating event frequencies.

One very important feature of the methodology is that the entire Level 1 analysis including the internal flooding was performed on the NUPRA workstation (Fulford, 1989). The Level 2 analysis is captured on the NUCAP+ (Fulford and Sherry, 1991) and the NUREG-1150 EVNTRE software, which enabled the project team to develop a completely integrated model from initiating event to source term release, for use on a personal computer. This is essential for the establishment of a living PRA, i.e., one which can be easily maintained and modified as changes are made in design and operation of the plant. The workstation model is fully supported by a comprehensive set of analysis files (engineering calculations), which detail the assumptions and information sources used at each stage of model development.

A formal Project Plan was developed for the project to ensure the appropriate level of review and documentation. The work products were reviewed at each stage, both initially by project team members and externally by engineering and operations personnel at Perry. In addition an independent review was performed to ensure consistency within the overall methodology. All comments received have been addressed and retained within the appropriate analysis files.

An independent verification program as defined by our quality assurance program and engineering criterion for technical practices will be implemented to allow utilization of the PRA as an approved methodology for review and analysis by the Perry staff.

1.4 SUMMARY OF MAJOR FINDINGS

1.4.1 Summary of Core Damage Frequency for Internal Events

In order to differentiate between core damage and fission product release the various accident sequences were developed for two sets of bounding conditions. The first set of conditional event trees were developed to determine the frequency of accident sequences in which an initiating event and subsequent system failures would lead to core damage. Core damage is defined as failure to maintain the water level in the vessel above the Minimum Zero Injection 7ater Level Ar, in the case of ATWS, failure to maintain the maximum cladding temperatures below 2,200°F, with no possibility of recovery of injection in the short term. This set of event trees were defined as the core damage event trees.

A second set of plant damage state event trees were developed for the plant damage states, and in this case consideration was given to recovery of in-vessel cooling to prevent vessel failure, and to operator actions that affect the accident progression, containment loading, and fission product behavior. This second set of event trees gives the frequency of the contribution to the various fission product releases or source terms. In the case of the loss of offsite power and station blackout events these vere developed to accurately model the various reages at which offsite power recovery would enable recovery of late injection either before vessel or containment failure.

The point estimate frequency of core damage from internal events excluding flooding is approximately 1.2×10^{-9} per reactor year. This was composed of 21 core damage frequencies with an annual frequency of greater than 10^{-7} and which contributed 86% of the overall core damage frequency, and an additional 89 sequences with a point estimate frequency of greater than $10^{-1.9}$ /yr which contributed the remaining 14%. The accident grouping by initiating event is shown in Table 1-1. The quantification is described in detail in section 3.4.1.1.

The cumulative distribution function for the core damage frequency is shown in Figure 1-1. The significant parameters of the uncertainty analysis frequency distibution function are as follows.

Mean	1.4 2	(10 5
Standard Deviation		¢ 10 ⁻⁵
95th Percentile	2.5 2	(10-5
Median	1.1 3	(1(**
Sth Percentile	6.2 3	(10 *

The dominant accident initiating event type is anticipated transient without scram (ATWS) at 40.7 percent. Transients contribute 25.0 percent, station blackout 19.3 percent, and loss of offsite power 12.4 percent. As a complete class, LOCAs contribute 2.6 percent. The individual sequences contributing to each initiator are shown in Table 1-2 and those contributing to 95 percent of the core damage frequency in Table 1-3.

An event importance analysis was performed on the overall core damage model. In this analysis the relative importance of each basic event was calculated with respect to three different measures. The three measures are Fussell-Vesely, risk reduction, and risk achievement.

The dominant basic events ranked in order by Fussell-Vesely and risk reduction measures are shown in Table 1-4. The Fussell-Vesely importance is a measure of the contribution of the given component to the overall core damage frequency by comparing the sum of all cutsets in which that basic event occurs with the sum of all cutsets. The risk reduction measure shows the ratio of the original core damage frequency to the reduced core damage frequency if the component was perfect or its failure probability is zero.

It should noted that the ranking of events by the Fussell-Vesely measure and the risk reduction measure are identical so the highest ranked items for these two measure are discussed in the following paragraphs.

The most important basic event for risk reduction is the mechanical failure of the control rods (CM) preventing insertion into the core given a signal to shut down the reactor. This is the single event following any transient initiator which will lead to the ATWS scenarios which in turn contribute 40.7 percent to the core damage frequency.

The second important basic event for risk reduction is the loss of offsite power (T1). This initiator leads to station blackout sequences (19.3 percent) and loss of offsite power sequences (12.4 percent). Core damage sequences following the loss of offsite power initiator thus contribute 31.7 percent to the core damage f squency. The Fussell-Vesely importance is 0.32 with a risk reduction of 1.47.

Failure of the operator to maintain availability of the power conversion system (PCS) (NSHICPEC5-2-L1T3) for an ATWS resulting from a transient with PCS initially available or loss of feedwater transient, is the third most important basic event. It has been assessed that the feedwater runback leading to loss of RPV level will result in closure of the MSIV in all cases. This basic event was set to 1.0 and occurs in the dominant sequences of the

First Time Fussell-Vesely importance is 0.27 with a risk reduction of 1.38. Fo initiating event transient with PCS available (T3A) is the fourth most is portant basic event. This event contributes to the dominant ATWS sequences and has a Fussell-Vesely importance of 0.25 with a risk reduction of 1.34.

Failure of the operator to re-open the motor feed pump control valves or manually depressurize the RPV (FWHICPEL-2-FDW-V) during an ATWS event following a transient with a loss of PCS is the fifth most important basic event with a Fussell-Vesely importance of 0.25 with a risk reduction of 1.33.

The initiating event transient with PCS not available (T2) is the sixth most important basic event. This event contributes to the dominant ATWS sequences and has a Fussell-Vesely importance of 0.23 with a risk reduction of 1.30.

The seventh important basic event is the failure of the operator to inhibit ADS (ADHICPC5-1-ALS-O) for ATWS scenarios where the feedwater system has failed. The Fussell-Vesely importance of this basic event is 0.22 with a risk reduction of 1.28. The failure to inhibit ADS in other sequences is modeled by different basic events as they have different values. The sensitivity of the results to this event is discussed in section 3.4.1.6.

The failure of the containment anchorage (CV05) is the eighth most important basic event. This is included in any sequence in which RPV injection is successful but long-term containment heat removal fails. The Fussell-Vesely importance is 0.15 with a risk reduction of 1.17.

Non-recovery of offsite power in 3 hours (R15) leads to sequences in LOOP and station blackout contributing 12.8 percent to the core damage frequency. The Fissell-Vessly importance is 0.13 with a risk reduction of 1.15.

The failure of the 4,160 VAC bus EH12 can fail all equipment which requires division 2 power. The Fussell-Vesely importance is 0.12 with a risk reduction of 1.13. Failure of this bus will prevent the opening of the valve in the vent path inside containment and therefore result directly in failure of the ability to vent containment. Failure of the division 1 power to the outboard valve can be overcome by manual opening of the valve, thus failure of division 1 power has a much lower importance value.

Of the next six basic events in importance, four are failures of either the Division 1 and 2 dieuel generators to supply power or the non-recovery of offsite power. These basic events contribute to both LOOP and station blackout sequences.

Two of the next eight basic events are failures to provide alternate injection to the RPV via the fire protection system. The fire protection system may be used when other alternate injection systems are unavailable due to non-recovery of offsite power.

Similar information was generated for risk achievement worth. Risk achievement worth is derived by calculating the core damage frequency with a given event failure probability set equal to 1.0. This is equivalent to determining the core damage frequency if the component is failed at the time of the initiating event. The dominant basic events ranked in order by risk achievement worth are shown in Table 1-5. The dominant basic event as measured by risk achievement is the mechanical failure of the control rods to insert into the core (CM). In this case, the probability that the control rods fail leading to an ATWS following all initiating events is 1.0 and shutdown is only achieved by use of the standby liquid control system.

The next basic event is the common cause failure of the ECCS pump room coolers (EPFACCEPRCS). These coolers provide heat removal from the pump rooms. The common cause failure was assessed to be low enough such that setting it to 1.0 would significantly increase its contribution to core damage frequency.

The third basic event in importance as ranked by risk achievement is the failure of the Division 2 4,160 VAC bus, EH12, (DGBALC1R22S0006). Failure of this bus would cause a loss of all equipment powered from Division 2 including low pressure coolant injection, heat removal equipment, and containment venting equipment.

Common cause failure of the batteries (DCBTCC) is the fourth most important basic event. As DC power is required for all systems and the batteries are required for any station blackout event, the common cause failure of the batteries is relatively important.

The next three basic events are common cause failures of diesel building ventilation fans, dampers and louvers (DBMFCC, DBMDCC, and DBLVCC). These components support the operation of the diesel generators and are required following a loss of offsite power.

The initiating event for a Large LOCA (A) is the eighth basic event in risk achievement importance.

Of the next ten ranked basic events, six are common cause basic events. Common cause is very high in risk achievement worth because the redundant components are failed at the same time. Setting the common cause basic events to 1.0 therefore significantly increases the core damage frequency.

1.4.1.1 Vulnerability Screening

A concise definition of vulnerability has not been given in either the documentation associated with the performance of reporting of the IPE or at a number of gatherings held to discuss the performance of the IPE. In the response to questions in Appendix C to the Subsitial Guidance Document (NRC, 1989), mention is made of examining sequences that are above the screening criteria in order to determine if a weakness exists. Thus the word weakness replaces the word vulverability but, neither is defined in numerical or comparative terms. In another response it is suggested that a vulnerability is an outlier. The NUMARC Severe Accident Issues Closure Guidelines (NUMARC, 1992) proposes a set of guidelines based on a combination of the core damage frequency for a group of sequences and the individual contribution from a sequence group. If the contribution from a given initiator or system failure is greater than 50 percent to the total core damage frequency it is interpreted as a significant vulnerability, if it contributes 20-50% it is interpreted as a potential vulnerability to be investigated. Similarly,



contributions from sequence groups between a core damage frequency of 10⁻⁵ to 10⁻⁴ should be reviewed to determine if there is an effective plant procedure or hardware change which would reduce the frequency of the sequences.

The functional accident sequence groups, the definition of each group and the frequency of sequences in each group are shown in Table 1-6. It can be seen from this table that there are no significant vulnerabilities as defined in the previous section as all the accident sequence groups have a frequency below 10⁻⁵ and no group contributes more than 50% to the overall core damage frequency. However there are two groups of accident sequences that contribute between 20 and 50 percent. Group 4 which is made up of accident sequences involving anticipated transients without scram leading to core damage, containment failure and subsequent loss of inventory, and Group 2 which is made up of accident sequences involving loss of containment heat removal leading to containment failure and subsequent failure of coolant inventory make-up.

Group 4

The contribution to core damage from sequences in this group comes primarily from ATWS sequences in which the motor feed pump has failed to inject water and ADS has not been inhibited resulting in rapid depressurization of the RPV and injection of low pressure ECCS. This leads to a series of reactivity oscillations resulting in generation of large quantities of steam and ultimately containment failure and core damage. In these sequences, the potential vulnerability is the failure to inhibit ADS. However, the sensitivity analysis that uses the plant operating data for cycles 2 and 3 will reduce the frequency of the initiators which contribute to this group and consequently directly reduces the contribution to core damage frequency of these sequences from 34% to approximately 15%, which is no longer a potential vulnerability in terms of the NUMARC criteria.

Group 2

The contribution to core damage from sequences in this group comes from a failure of containment heat removal leading to containment failure and subsequent loss of injection. One of the reasons that this is a significant contributor is that the containment design at Perry is such that approximately 15% of containment failures lead to injection failure. One potential modification considered, a passive vent, if fitted would reduce the containment failure frequency, with the core damage frequency also being reduced. This would also have an impact on source term magnitude and is further discussed in the containment evaluation in section 1.4.3.2.

1.4.2 SUMMARY OF CORE DAMAGE FREQUENCY FROM INTERNAL FLOODING

The contribution to core damage from floods is 1.5×10^{-6} per reactor year which is approximately 12 percent of the overall core damage frequency. The contribution from each flood area is shown in Table 1-1 and Figure 1-4.

The most significant contribution is from floods in Zone 13 in the control complex at elevation 576 ft. The total contribution from floods in this area is 8.8×10^{-7} per year or 7 percent of the total core damage frequency which is approximately the same as the contribution from loss of instrument air.

In the event of a flood in this zone, the majority of the damage is done to the support systems (control complex chilled water, emergency closed cooling pumps, and instrument and service air).

The second highest contributor is flooding in Zone 17 in the control complex at the 599' level with a frequency of 3.2 X 10⁻⁷ per year (2.4%). Floods in this area will flow through doors and down to Zone 13, which then has the same impact on the support equipment as a flood in Zone 13. The results of the flooding analysis are discussed in section 3.3.7.

1.4.2.1 Flooding Core Damage Vulnerabilities

There are no vulnerabilities associated with internal flooding following the NUMARC definition. The total contribution to core damage frequency is 12 percent from all floods, and flooding in the most significant area, Zone 13, only contributes 7 percent to the overall core damage frequency. This sequence is based on conservative assumptions assuming the availability of injection systems and therefore the current procedures for maintaining vessel injection will ensure that optimum use will be made of the systems, and the potential core damage frequency minimized.

1.4.3 SUMMARY OF CONTAINMENT EVALUATION

The containment evaluation was conducted in two phases. In the first phase, the strength of the containment was determined and in the second, the accident progression and fission product release following core damage were evaluated.

The results of the containment analysis performed by the Perry plant architect that designed the containment indicate that the median pressure capacity is 64.3 psig compared with the design pressure of 15 psig. The potential failure modes under severe accident conditions will vary according to the accident progression, and may also affect the accident progression. The two failure modes of concern are penetration failures resulting in steam release from the shield building to the auxiliary building through the penetration seals, and anchorage failure which would result in loss of the suppression pool as the water is expelled to the shield building and adjacent buildings. The latter event would also result in drywell bypass. Additionally, anchorage rupture can result in a direct radiological release to the environment. Penetration failures would commence with a small leakage area and increase with containment pressure. Concrete and steel anchorage failure would result in gross failure of the containment vessel from the mat foundation.

The level one analysis identified a number of sequences in which gradual steam overpressurization would occur as the result of failure of containment heat removal, but successful injection of water to the vessel. In this case it is necessary to identify what proportion of the containment failure will lead to failure of the injection systems and therefore core damage in a failed containment. This analysis resulted in the identification of a function designated Cv in the level one analysis. The exact value of this function is dependent upon the injection system operating at the time of containment failure as well as the containment failure mode. The total contribution to core damage resulting from internal event sequences in which a gradual steam overpressurization results in containment failure is 2.6 x 10⁻⁶/per year or 22 per cent of the core damage frequency. These sequences are included in Group 2 in Table 1-6. In the importance analysis in Table 3.4.1-7 it can be seen that the highest ranked function is CV05 (eighth) and that functions CV01 and CV03 are ranked 31st and 38th respectively. As discussed in section 1.4.1.1, a means of mitigating excessive containment pressure buildup such as the fitting of a passive vent, could reduce the frequency of containment failure and the frequency of failure of the injection system, and the frequency of core damage within a failed containment.

The leval two analysis plant damage state grouping also shows that Critical (non-shutdown) ATW3 results in a failed containment before core damage with a frequency of 5.6×10^{-7} which represents 4.4% of the total core damage frequency.

For those sequences where the containment is intact at the time of core damage, the progression of the accident was evaluated by use of the Modular Accident Analysis Program (MAAP) and the construction of an Accident Frogression Event Tree in order to account for the uncertainties surrounding events during the course of the accident. Particular attention was paid to the generation of hydrogen and the impact of hydrogen burns, the potential for pedestal overpressurization, and pedestal core concrete interactions.

The plant damage state profile from the level 1/2 interface is: 0% containment bypass; 77% containment intact at core damage (9% - Station Blackout, and 68% - transients and other event types with AC power available), 23% - containment failed at core damage (4.4% - critical (not shutdown) ATWS sequences, 4.3% - Loss Of Offsite Power and Station Blackout, and 14% - other events).

The Accident Progression Event Tree summary results for containment performance are: no containment failure - represents a 39% conditional probability given core damage and a frequency of 5.0 x 10^{-6} , containment venting - represents a 29% conditional probability and a frequency of 3.7 x 10^{-6} , and containment structural failure - represents a 32% conditional probability and a frequency of 4.0 x 10^{-6} . The conditional probability estimates of the detailed containment failure modes evaluation are: 50.8% in-vessel cooling and no RPV failure; and the balance of the sequences with RPV failure (49.2%) is composed of: 12.4% - no containment failure, 10% venting with a damaged core; 7.4% - late containment failure; 3.4% - early containment failure with no pool bypass; and 16.1% containment failure with pool bypass. These results are shown in Table 1-7.

As in the case of the other BWR/6 plants with Mark III containments, the hydrogen ignitors are AC powered. Consequently Station Blackout sequences result in loss of the ignitors. However, as the total contribution to core damage from Station Blackout sequences is only 9% and the contribution to containment structure failure as a result of hydrogen burns is less than 5 percent, the addition of a backup power supply would not significantly impact the source term release given the other contributions to containment failure at the present time.

1.4.4 COMPARISON OF RESULTS WITH OTHER STUDIES

1.4.4.1 Core Damage Frequency

The major purpose of this study was to ensure that the PRA model developed by the project team was understood by the CEI staff at Perry and represented the as-built as-operated condition at Perry as far as possible. Guidance for performing the IPE indicated that heavy reliance could be placed on the results of previous studies for similar plants, in this case the Grand Gulf study performed as part of the NRC program in 1987 and reported in NUREG/CR-4550 and NUREG/CR-4551. However it was decided that if the completed PRA was to be used as a living PRA the success criteria and plant models would have to be developed for the as-built condition of the Perry plant and incorporate the latest understanding, as presented by the BWR Owners Group, of the required response by the operations to ATWS events, and the thermal hydraulic performance of the core when the water level is below the top of active fuel.

In addition, a plant-specific human reliability analysis was performed so that the impact of the current emergency operating procedures on the operator's response to the initiating events would be correctly incorporated in the event and fault trees.

It can be seen in Table 1-8 that as the result of incorporating the plant-specific insights into the models and developing a completely new set of event and fault trees, the core damage frequency from internal events at Perry is approximately 1.2 $\times 10^{-5}$ compared with 4.0 $\times 10^{-5}$ at Grand Gulf (NUREG/CR-4550). The design features are compared in Table 1-9. The results from the analysis of BWR/6s in Taiwan (Kuosheng) and Spain (Cofrentes) are also included in Table 1-8 for comparison purposes. It was not possible to compare the results with the IPEs for Grand Gulf, Clinton or River Bend as the IPE submissions were not available at the time of production of this report.

The only significant differences between Perry and NUREG/CR-4550 (Drouin, 1989) are in the results for anticipated transient without scram, transients without the power conversion system available and loss of instrument air. Some of the reasons for these differences are discussed in the following paragraphs.

It can be seen from the table that there is a wide variation in the assessment of core damage frequency following an ATWS in the four studies, ranging from less than 10⁻⁷ to 2.6 x 10⁻⁵, a factor of over 250. The specific reasons for the differences between the NUREG/CR-4550 core damage frequency and the Perry frequency are the result of different success criteria being used in the two studies. In the Perry study the latest information from the BWR/6 Mark III Issues Committee of the BWR Owners Group that the High Pressure Core Spray can not be used to maintain vessel level has been incorporated. In the NUREG/CR-4550 study it was assumed that if HPCS started, successful injection would be achieved. When it is assumed that HPCS can not be used for high pressure injection the feedwater system becomes important. At Perry runback occurs following ATWS requiring the operator to take control to restore feedwater injection and maintain level. The net effect is to place dependence on the operator to achieve the required

plant status. The quantification of the operator actions based on a detailed evaluation of the PEI combined with the system failures resulted in the ATWS core damage frequency of 4.74×10^{-6} .

The only other two initiators for which there is a significant difference between the Perry and NUREG/CR-4550 studies are the Transient with loss of PCS (1.7 x 10^{-6} at Perry compared with 1.3 x 10^{-6} in NUREG/CR-4550), and loss of Instrument Air (1.0 x 10^{-6} compared with less than 10^{-7}). In the case of loss of PCS the failure of recovery of PCS in the NUREG/CR-4550 study is two orders of magnitude lower than at Perry. This is not in line with the generally applied value which has been used in the Perry study. Similarly in the loss of instrument air it is considered that non-conservative recovery actions have been used for the NUREG/CR-4550 study.

1.4.4.2 Containment Evaluation

The Perry IPE level 2 containment analysis uses the same Event Progression Analysis (EVNTRE) code applied in the Grand Gulf NUREG/CR-4551 study (Brown, 1990) to transpose the severe accident analysis phenomenological framework of the template Mark III reference study and to model the many dependencies associated with containment loading mechanisms such as steam generation, hydrogen generation and combustion, and the subsequent variations in pressure and temperature within the containment. The Perry IPE Accident Progression Event Tree consists of 68 questions which address the four general time frames of accident progression: initial, early, intermediate and late. The more extensive NUREG/CR-4551 Grand Gulf evaluation consisted of 125 questions.

To evaluate the impact of interruption of power to the hydrogen ignitors, the Perry APET addresses the hydrogen combustion phenomena in a similar manner to the NUREG/CR-4551 Grand Gulf APET. The Perry APET models the recovery of offsite power before RPV failure as well as after RPV failure, and possible variations in hydrogen concentration at the time of power restoration are evaluated including the possibility of detonable concentrations.

The Perry IFE use of the same event progression analysis code as the NUREG/CR-4551 template study enables a good transfer of phenomenological modeling as well as of the quantification bases. The Perry APET routinely references the NUREG/CR-4551 template study and transfers many of the event models, such as the bounding model of alpha mode steam explosions. However, the primary reference for modeling phenomenological parameters is the EPRI maintained MAAP code 3.0B.

One parameter was found to be important when performing the sensitivity analysis of the Accident Progression Event Tree. That was large in-vessel steam explosions leading to bottom head failure. These phenomena are not modeled in the MAAP code nor addressed in the EPRI Recommended Sensitivity Analyses discussed above in section 7.2. The probabilities applied in the NUREG/CR-4551 template plant study appear to over estimate the risk and are reduced by a factor of 10 in the base case. However, if the NUREG/CR-4551 values for large in-vessel steam explosion failure are used, the base case all sequence estimate of 51% for in-vessel cooling and no RPV failure is reduced to 21%, a 58% reduction.

2.0 X 10⁻⁶ t. 4.2 X 10⁻⁷.

The contribution from individual maintenance activities is not large and contribution to planned maintenance for the HPCS and RCIC has already been reduced. The maintenance activities for the HPCS and RCIC were revised as a result of the schedule optimization prior to the third operating cycle. There is a more extensive Systematic Maintenance Optimization (SMO) in progress which will result in the optimization of maintenance for all ECCS systems. Currently preventive maintenance of the HPCS system is only performed during an outage. Thus, this component of the maintenance outage is now zero.

It is considered, in view of the low frequency of the contribution to core damage of the failure of the decay heat function, that no immediate action is required to modify the plant design and that this analysis satisfies the requirements for resolution of unresolved safety issue A-45. The ongoing systematic maintenance optimization program will ensure that the reliability of the ECCS system will be maintained at least above that assumed in the performance of the IPE.

1.4.6 POTENTIAL IMPROVEMENTS

The A-45 evaluation discussed in the previous section and the vulnerability analysis described in section 3.4.2 shows that there are no vulnerabilities associated with core damage. However two items are discussed which would lead to a reduction in the core damage frequency. The improvements and impact on core damage frequency are summarized in Table 1-10.

Similarly the containment analysis discussed in section 4 identified the contributors to containment failure and a number of changes which would reduce the likelihood of containment failures, given core damage. The impact on containment failure frequency is shown in Table 1-7.

The potential plant improvements considered are discussed in the following sections.

1.4.6.1 Potential Plant Improvements to Prevent Core Damage

Passive Containment Vent Path

One of the sensitivity analyses performed was on the impact of containment failure to loss of RPV injection and subsequent core damage. The addition of means of mitigating slow excessive containment pressure buildup, such as a passive containment vent path that does not depend on AC power, would reduce the core damage frequency for the non-ATWS sequences in which loss of decay heat removal leads to containment failure and results in an overall reduction of approximately 19% from approximately 1.3 $\times 10^{-5}$ to 1.1 $\times 10^{-5}$ (includes flooding events).

Automatic ADS Inhibit for ATWS



One of the contributors to core damage frequency for ATWS is manually inhibiting ADS. By installing an automatic inhibit of ADS, those ATWS sequences in which manual inhibit fails would drop out. The overall core damage frequency is reduced by 21 percent from approximately 1.3×10^{-5} to 1×10^{-5} . As the sequences resulting from this failure result in an uncontrolled flow to the vessel from the low pressure injection systems with subsequent core damage and containment failure, the installation of the auto inhibit would reduce the frequency of this set of sequences.

Maintenance

Performing maintenance on systems and components is important from two aspects. First, maintenance is needed to provide assurance that the systems can perform their function when called upon. Sccond, because systems are out of service while maintenance is being performed, maintenance can also have a detrimental impact on core damage frequency. Current practice is such that HPCS preventive maintenance is now only scheduled during plant outage. A Systematic Maintenance Optimization (SMO) for all ECCS systems is now in progress, and it is expected that this will result in changes in planned maintenance activities which will reduce the core damage frequency.

1.4.6.2 Design Consideration for Reduction in Containment Failure

The containment bypass as the result of an unisolated breach of the primary system outside the containment was determined to be less than 10^{-6} as reported in the Grand Gulf study and therefore does not require any action at Perry.

Supplement No. 3 of Generic Letter 88-20 identified that Mark III containment owners were expected to evaluate the vulnerability to interruption of power to the hydrogen ignitors. The modification of the electrical supply to the hydrogen ignitors to ensure availability during station blackout would remove the possibility of high containment loads from hydrogen deflagrations and detonations. The overall impact of this change on the base case assessment is very minor: 1) the containment failure with early/late pool bypass frequency changes from 2.04 \times 10⁻⁶ to 2.00 \times 10⁻⁶ (-2% change), 2) the containment structural failure frequency changes from 4.03 \times 10⁻⁶ to 3.76 \times 10⁻⁶ (-6.7% change). Thus, a hardware upgrade to provide uninterrupted electrical supply to the hydrogen ignitors is not warranted.

In the base case analysis the frequency of RPV Failure and Early Containment Failure with Pool Bypass is 2.0×10^{-6} or 16 per cent of the core damage frequency. In section 1.4.6.1 two modifications were identified which would lower the core damage frequency. The implementation of the two modifications would also reduce the frequency of core damage with early containment failure. The implementation of a passive vent would reduce the contribution to RFV failure and early containment failure with pool bypass from 2.0 $\times 10^{-6}$ to 4.5 $\times 10^{-7}$ which is a 78% reduction. The inclusion of an automatic ADS inhibit in the event of an ATWS would reduce the RFV failure and early containment failure with pool bypass from 2.0 $\times 10^{-6}$ to 1.8 $\times 10^{-6}$, an approximately 15% reduction. The combined effect of performing both modifications would be to reduce the contribution to RFV failure and early containment failure with pool bypass from 2.0 $\times 10^{-6}$ to 1.6 $\times 10^{-7}$ a 92% reduction.

It should also be noted that if frequencies of scrams at Perry based on operating cycles 2 and 3 is used, the contribution to RPV failure and early

The results of the Perry IPE containment performance analysis cannot be directly compared to the NUREG/CR-4551 Grand Gulf study, due to differences in containment failure modes, plant damage state group frequencies, and phenomenological modeling assumptions. The NUREG/CR-4551 study was dominated by Station Blackout (97% plant damage state frequency) and determined that hydrogen combustion was the dominate cause of containment failure. The Perry IPE is dominated by shutdown ATWS sequences (ATWS with successful SLC) and other transients with Station Blackout accounting for 9% of the plant damage state frequency. The modeling for debris cooled in-vessel is similar, with the one variance noted above regarding the estimated value for large in-vessel steam explosions. When the Perry APET event for large in-vessel steam explosion is set to the NUREG/CR-4551 value, the estimated results for No REV Failure compare closely, with 21% for the Perry APET and 18% for the Grand Gulf APET. The Perry APET estimates for the conditional probability of Containment Performance are shown below with the NUREG/CR-4551 Grand Gulf APET estimates:

	Perry	NUREG/CR-4551 Grand Gulf
No RPV Failure	51%	18%
RPV Failure and No Containment Failure	12%	5%
RPV Failure and Venting	10%	43
RFV Failure and Late Containment Failure	7%	28%
RPV Failure and Early Containment Failure With No Pool Bypass	3 %	2,2%
RPV Failure and Early Containment Failure With Pool Bypass	16%	21%

1.4.5 DECAY HEAT REMOVAL EVALUATION - ISSUE A-45

The objectives of Task Action Plan A-45 are to evaluate the safety adequacy of Decay Heat Removal (DHR) Systems in existing light water reactor nuclear power plants and to assess the value and impact (benefit/cost) of alternative measures for improving the overall reliability of the DHR function if required.

Some potential accidents which could result in core melt were excluded from the A-45 studies performed by Sandia National Laboratories (S.W. Hatch, 1987). Since the purpose of the program is to study the adequacy of shutdown decay heat removal systems, large LOCAs, reactor vessel ruptures, interfacing system LOCAs and anticipated transients without scram (ATWS) are excluded. The study focused on events occurring from power or in hot standby.

The delineation of the accident sequences, system analysis, core damage and sequence quantification are fully described in sections 3.1 through 3.4.1. The concern in issue A-45 is to identify the specific vulnerabilities associated with sequences identified as potentially leading to core damage if all injection to the vessel and decay heat removal are lost.

The breakdown of functional contribution to core damage is shown in Table 1-6. The three groups which result in failure of decay heat removal as the result of failure of injection contribute 22 percent to core damage, with individual contributions as follows:

Group	Description	Percentage
1B 1E 1A	Loss of offsite power and make-up Loss of coolant inventory make-up at low pressure Loss of high pressure make-up and failure to	13 8
	depressurize	1.1

The contribution to core damage frequencies as the result of loss of decay heat removal from containment leading to containment failure and consequential loss of injection (class 2) is 22 percent of the overall core damage frequency. Thus 44 percent of the contribution to core damage is the direct result of failure of decay heat removal either from the vessel or containment. Although the overall frequency is not high (5.1×10^{-6}) it is of interest to identify any potential improvements which, if they could be addressed cost effectively, would reduce the contribution of decay heat removal failures to the overall core damage frequency.

The importance analysis discussed in section 1.4.1 and listed in Table 1-4 identified the individual components whose improvement would make the greatest contribution to the reduction in core damage frequency. The highest ranked component in terms of decay heat removal is the event representing failure of injection as the result of containment failure (CV05). This indicates that the mode of containment failure following overpressurization is more significant than any individual containment heat removal system failure. Therefore an alternative means to prevent containment failure will have the largest impact in reducing the core damage frequency.

The contributions from the remaining individual components is small. Therefore the improvement of an individual component will not make a significant difference to the core damage frequency.

1.4.5.1 Summary of A-45 Evaluation

The core damage frequency resulting from failure of decay hews removal systems is 5.1×10^{-6} per year representing 44 percent of the contribution to core damage from internal events. This frequency is below 10^{-6} and therefore not a significant vulnerability in frequency terms. However a review of the contributions to this failure identified one event which contributed more than any other to the core damage frequency and for which a possible modification could be considered. The mode of containment failure results in a significant probability of injection failure following containment failure and subsequent core melt in a failed containment, with consequent increase in offsite release. The addition of means of mitigating slow excessive containment pressure buildup, such as a passive containment vent path, would reduce the frequency of core damage frequency, excluding flooding, would be reduced from approximately 1.2×10^{-6} to 9.0×10^{-6} and the frequency of core damage frequency and the frequency of core damage sequences with containment failed at core damage is reduced from

containment failure with pool bypass is reduced from 2.0 x 10^{-6} to 1.0 x 10^{-6} and with the fitting of the passive vent to 2.0 x 10^{-7} .

There results are summarized in Tables 1-7 and 1-10.

1.4.7 CONCLUSIONS

The performance of the level 2 PRA in response to the NRC's request in Generic Letter 88-20 for an Individual Plant Examination of the Perry plant has resulted in the CEI gaining a number of insights into the contribution to risk at the plant. The outcome was the performance of the following improvements during the course of the study.

Loss of Offsite Power Instructions

- Retention of RCIC isolation bypass for high steam tunnel temperature
- Enhanced process for crosstieing Unit 1 and 2 batteries
- Enhanced process for offsite power recovery to HPCS and alternate injection system bus bars.

Flooding Instructions

- Enhanced alarm response instructions to flooding scenarios.

In addition the following improvements are expected to be made in the near future.

- Implementation of automatic RPV depressurization for non-ATWS events (requires industry Emergency Procedures Group and UNSRC reviews and approvals prior to design and implementation)
- "Fast Firewater" tie between Fire Protection and HPCS
- Permanent Division 3 to Division 2 "guick" connect
- Reduction of Out of Service Time for certain critical components (already achieved fcr HPCS and RCIC)

The result of the improvements is an overall core damage frequency for the internal and internal flooding events of 1.3 x 10° per year and an RPV failure with early containment failure with pool bypass frequency of 2.0 x 10° per year. In the event automatic RPV depressurization is not implemented, core dmuge frequency will not increase as plant specific operating data when incorporated will more than compensate. Beyond the base case, a number of additional enhancements discussed in the previous faction have been identified and are being evaluated further. However, careful analysis is required before any further improvements beyond those identified above are made.

When performing a major analysis of this type, it is necessary to fix the date for collection of design and operational information, in this case January 1, 1990. At this time Perry had only completed one full cycle of operation and therefore little or no operational data was available. Si e that time, it has been possible to include data for maintenance outages or a small number of components. It is clear from the experience in operating cycles 2 and 3 that the initiating event frequencies are significantly lower than the generic values used in the NRC Grand Gulf study and therefore in the

Perry study. Therefore, hefore any further decisions are made concerning plant improvements the first step will be to update the living PRA to include this data, and any design changes made since the freeze date of January 1, 1990. In the case of the latter a brief review of the work performed during the first two cycles indicate that there have been no major design changes to the ECCS.

The enhancements discussed earlier improve the decay heat removal capabilities following an initiating event. It is considered that the current core damage frequency, as the result of decay heat removal failures, is within the current guidelines and therefore the results of this study represent satisfactory resolution of Unresolved Safety Issue A-45 for the Perry Nuclear Power Plant.

There were no specific vulnerabilities identified with regard to containment performance in the Perry IPE. The Perry backend containment analysis indicates that the Perry containment response to severe core damage accidents is generally similar to that for other BWR/6 Mark III plants [e.g., NUREG-1150 Grand Gulf (NRC, 1989a)].

The containment performance sommary results for the Perry Mark III containment were: no containment failure - represents a 39% conditional probability given core damage and a frequency of 5.0 x 10°, containment venting - represents a 29% conditional probability and a frequency of 3.7 x 10°, and containment structural failure - represents a 32% conditional probability and a frequency of 4.0 x 10°. The conditional probability of RPV failure and early containment failure with pool bypass given core damage was estimated to be 0.16 in the Perry IPE (compared to 0.21 for Grand Gulf in NUREG-1150). The differences in these results between the Perry IPE and NUREG-1150 mainly result from significant differences in the type of sequence contributing to core damage, from different containment failure modes, and from the phenomenological assumption made in the Perry IPE regarding the probability of steam explosions failing the lower RPV head.

References

- Brown, T.D. et al 1990. Evaluation of Severe Accident Risks: Grand Gulf, Unit 1, NUREG/CR-4551 Vol 6 Rev 1 Parts 1 and 2, Sandia National Laboratories, Altuquerque, NM.
- Drouin, M.T. 1989 et al Analysis of Core Damage Frequency. Grand Gulf Unit 1 NUREG/CR-4550 Vol 1 Rev 1, Sandia National Laboratories, Albuquerque, NM.
- Fulford, P.J. 1989 NUPRA Users Manual NUS 5218, Halliburton NUS Corporation, Gaithersburg, MD.
- Fulford, P.J. and R.R. Sherry, 1991 NUCAP Plus Level 2 PRA Workstation Users Manual, NUS-5282, Halliburton NUS Corporation, Gaithersburg, MD.
- Hatch, S.W. et al 1987, Shutdown Decay Heat Removal Analysis of a General Electric BWR4/Mark I, NUREG/CR-4767, Sandia National Laboratories, Albuquerque, NM.
- Hickman, J.W. 1983 "PRA Procedures Guide: A Guide to the Performance of Probabilistic Risk Assessments for Nuclear Power Plants" American Nuclear Society and Institute of Electrical and Electronic Engineers, NULJG/CR-2300 Vol 1-2
- NRC, 1988 Individual Plant Examination for Severe Accident Vulnerabilities -10CFR50.54(f), Generic Letter No. 88-20 USNRC Washington, D.C.
- NRC, 1989 Individual Plant Examination: Submittal Guidance NUREG-1335, USNRC Washington, D.C.
- NRC, 1989a Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants NUREG-1150 Vol 1 & 2 (Second Draft), USNRC Washington, D.C.
- NUMARC. 1992 Severe Accident Issue Closure Guidelines, NUMARC 91-04, Nuclear Management and Resources Council, Inc., Washington, D.C.

 14 Ber 1		 	
 a D.	2.4	 2	

Summary of Core Damage Frequency by Initiating Event & Flood Zone

	Core Damage Freq	Percent of	CDF
Loss of Offsite Po	VCT		
ŤJ R	1.80 X 10 ⁻⁷ 7.19 X 10 ⁻⁷	1.5	(Loss of Offsite Power) (Loss of Offsite Power and No Offsite Power
U	$4.1^{-7} \times 10^{-7}$	3.6	Recovery at 3 hrs) (Loss of Offsite Power
TIPI	7,62 X 10 ⁻⁸	0.7	w/no HPCS or RCIC (Loss of Offsite Power and 1 SORV)
TIPLU	1.53 X 10 ⁻⁸	0.1	(Loss of Offsite Power and 1 SORV w/no HPCS or RC1C)
T1P2	3.89 X 10 ⁻⁶	0,3	(Loss of Offsite Power and 2 SORVs)
Total	1.44 × 10 ⁻⁶	12.4	
Station Blackout			
B BF1	2.11 X 10 ⁻⁶ 8.36 X 10 ⁻⁸	18.1 0.7	(Station blackout) (Station blackout 1 SORV)
BP2	5.92 X 10 ⁻⁸	0.5	(Station blackout and 2 SORVs)
Total	2.25 X 10 ⁻⁶	19.5	
Transients			
T3A T3AF1 T3AF2 T3B T3C T2 T2P1 T2P2 TIA T1AP1	< 10^{-8} < 10^{-8} < 10^{-8} < 10^{-8} 1.38 X 10^{-7} 1.64 X 10^{-6} 2.47 X 10^{-8} < 10^{-8} 1.01 X 10^{-6} < 10^{-8}	0.0 0.0 0.1 0.0 1.2 14.1 0.2 0.0 8.7 0.1	<pre>(Transient w/ PCS) (Loss of feedwater) (Inadvertent open 3RV) (Transient w/o PCS) (Loss of instrument air)</pre>
TIAP2 TSW TSWP1 TSWP2	< 10 ⁻⁸ 6.68 X 10 ⁻⁰ < 10 ⁻⁸ < 10 ⁻⁸	0.0 0.6 0.0 0.0	(Loss of service water)
Total	2.90 X 10 ⁻⁶	25.0	





Table	1-1	conti	mued

	Core Damage Freq	Percent of C	DF
LOCAS			
A S1 S2	2.11 X 10 ⁻⁷ 6.18 X 10 ⁻⁸ 3.34 X 10 ⁻⁸	1.8 0.5 0.3	(Large LOCA) (Intermediate LOCA) (Small LOCA)
Total	3.06 × 10-7	2.6	
ATWS			
T1-C T3A-C T3B-C T3-C T3-C TIAC	3.61 x 10 ⁻⁸ < 10 ⁻⁸ 5.42 x 10 ⁻⁷ 9.38 x 10 ⁻⁸ 4.02 x 10 ⁻⁶ 4.33 x 10 ⁻⁸	0.3 0.1 4.6 0.8 34.5 0.4	
Total	4.74 7 10"6	40.7	

Total Core Damage Frequency (internal initiators) 1.17 X 10-5 (88%)

Flooding

Zone	13	8.94 × 10 ⁻⁷	57
zone	17	3.22 × 10 ⁻⁷	21
TPC		8.70 x 10 ⁻⁸	6
zone	1	1.93 × 10 ⁻⁷	12
Zone	AL	< 10 ⁻⁸	< 1
Zone	8	2.80 X 10"*	2
Zone	16	1.10 X 10 ⁻⁸	1

Total Core Damage Frequency (flooding) 1.54 X 10-6 (12%)

Total Core Damage Frequency (internal initiators & flooding) 1.32 X 10⁻⁵

Sequence Core Damage Frequencies Grouped by Initiator

T2-C Sum = 4.02E-006 34.5% T2-CS30 2.27E-005 19.5% T2-C-U3-X' T2-CS20 6.25E-007 5.4% T2-C-Lc-C1 T2-CS28 3.12E-007 2.7% 12-C-U3-X 2.5% T2-C-C1 "2-CS11 2.90E-007 2.0% T2-C-X' 12-CS12 2.37E-007 1.4% T2-C-V T2-CS06 1.58E-007 T2-CS05 1.25E-007 1.1% T2-C-V' Sum = 2.11E-006 18.1% B 7.71E-007 6.6% B-U1-Va-R BS24 5.26E-007 4.5% B-U1-U2-R-Val BS34 2.9% B-U1-R BS17 3.368-007 BS07 1.60E-007 1.4% B-R-Y-CV 0.9% B-HI-R BS12 1.04E-007 BS12 1.048 000 0.5% B-U1-Va-V BS22 5.96E-008 0.5% B-U1-Va-V BS35 5.15E-008 0.4% B-U1-U2-R-X BS33 5.11E-008 0.4% B-U1-U2-R-Y-CV BS35 5.11E-006 0.4% B-0.-02-R-1-BS29 3.37E-008 0.3% B-01-02-Val 1.81E-008 0.2% B-U1-U2-X B\$30 T2 Sum = 1.64E-006 14.19 72504 1.62E-006 13.9% T2-W-Y-CV 1.90E-008 0.2% T2-U3-U2-W-Y-CV 12.509 T2518 9.56E-009 0.1% T2-U3-U2-U1-V-Va TIA Sum = 1.01E-006 8.7% TIAS14 7.335-007 6.5% TIA-U2-U1-V-Va TIASC5 2.57E-007 2.28 TIA-U2-W-Y-CV R SIM # 7.198-007 6.2% R520 6.04E-00) 5.23 R-Ws-V-Va 8.735-008 0.7% R-WE-V-CV RS19 2.75E-009 0.28 R-KS-W-Y-CV RS1.0 13B-C Sun = 5,428-007 4.6% C.B-C529 2.76E-007 2.4% T3B-C-U3-X' 13B-CS19 7.60E-008 0.7% T3B-C-Q-Lc-C1 1713-CS09 5.32E-008 0.5% T3B-C-O-X T3B-CS27 3.80E-009 0.3% T3B-C-U3-X .3B-CS10 3.45E-008 0.3% T3B-C-Q-C1 T3B-CS11 2.98E-008 0.2% T3B-C-C-X' T3B-CE08 1.78E-008 0.29 T38-C-Q-V T3B-CS07 1.52E-008 0.1% T3B-C-Q-V' 11 Sum = 4 148-007 3 64

NF	En. Party and	1 2 10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	10 1 10 10 10	
	US29	3.34E-007	2.9%	U-R1-V-Va
	US12	5.998-008	0.58	U-V-Va
	US28	1.£3E-008	0.18	10-R.+-W-Y-CV



	Table 1-2 continued
A Sum = 2.11E-007	1.8%
A Sum = 2.11E-007 AS09 2.10E-007	1.8% A-UL-V
AS09 2.105-007	**06 W.07-4
T1 Sum = 1.80E-007	1.5%
T1S08 1.47E-007	1.3% T1-R2-W-Y-CV
T1S04 1.94E-008	0.2% T1-W-Y-CV
T1833 1.33E-008	0.1% T1-U1-Ws-V-Va
T3C Sum = 1.38E-007	1.2%
T3CS04 1.38E-007	1.2% T3C-W-Y-CV
T3C-C Sum = 9.38E-008	
T3C-CS27 5.49E-008	
T3C-CS17 1.40E-008	
T3C-CS07 9.81E-009	0.1% T3CCX
	0.70
BP1 Sum = 8.36E-003	
BP1827 4.855-008	
BP1517 1.69E-008	
BP1526 1.13E-008	0.16 DLT-DT-AG-U
TIPL Sum = 7.62E-008	0.7%
T1P1S31 7.24E-008	
******** ******	
TSW Sum = 6.68E-008	0.6%
TSWS10 5.49E-008	
TSW514 1.00E-006	0.1% TSW-C
51 Sum = 6.18E-008	
\$1\$13 5.85E-008	0.5% S1-U1-V-Va
BP2 Sum * 5.91E-008	0.58
BF2S13 5.91E-008	
Brasts 5.516-000	0.08 012-02
TIAC Sum = 4.33E-008	0.4%
TIACS09 3.31E-008	
T1P2 Sum = 3.89E-008	
T1P2S11 2.39E-008	0.2% T1P2-U1-V
T1P2504 1.49E-008	0.1% T1P2-W-Y-CV
	0.25
T1-C Sum = 3.61E-008 T1-CS09 2.19E-008	0.36
TI-CS09 2.19E-008	0.1% T1-C-C1
T1-CS08 8.44E-009	A. 74 17-0-01
52 St- # 3.24E-008	0.3%
\$2,520 3.00E-008	0.3% S2-C
T2P1 Sum = 2.47E-008	0.2%
T2P1504 2.46E-008	
T1P1U Sum = 1.53E-008	0.1%
T1P1US22 1.37E-008	0.1% TIPLU-R1-V



Sequence within the Upper 95% of Total Core Damage

T2-CS30	2.27E-006	19.5%	T2-C-U3-X'
T2S04		13.9%	T2-W-Y-CV
BS24	7.71E-007	6.6%	B-U1-Va-R
TIAS14	7.53E-007	6.5%	TIA-U2-U1-V-Va
T2-CS20	6.25E-007	5.4%	T3-C-LC-C1
RS20	6.04E-007	5.2%	R-Ws-V-Va
BS34	5.26E-007	4.58	B-U1-U2-R-Va1
BS17	3.36E-007	2.98	B-U1-R
US29	3.34E-007	2.9%	U-R1-V-Va
T2-CS28	3.12E-007	2.7%	T2-C-U3-X
T2-CS11	2.90E-007	2.5%	T2-C-C1
T3B-C529	2.76E-007	2.48	T3B-C-U3-X'
TIAS05	2.57E-007	2.2%	TIA-U2-W-Y-CV
T2-CS12	2.37E-007	2.0%	T2-C-X'
A\$09	2.10E-007	1.8%	A-U1-V
BS07	1.60E-007	1.48	B-R-Y-CV
T2-CS06	1.58E-007	1.4%	T2-C-V
T1508	1.47E-007	1.3%	T1-R2-W-Y-CV
T3CS04	1.38E-007	1.2%	T3C-W-Y-CV
T2-CS05	1.25E-007	1.1%	T2-C-V'
BS12	1.04E-007	0.9%	B-HI-R
RS19	8.73E-008	0.7%	R-WS-V-CV
T3B-CS19	7.60E-008	0.78	T35-C-Q-LC-C1
T1P1S31	7.24E-008	0.6%	T1P1-U1-WS-V
US12	5.99E-008	0.5%	U-V-Va
BS22	5.96E-008	0.5%	B-U1-Va-V
BP2513	5.91E-008	0.5%	BP2-U1
S1S13	5.85E-008	0.5%	S1-U1-V-Va
TSWS10	5.49E-008	0.5%	TSW-U2U1-V
	5.49E-008	0.5%	T3C-C-U3-X'
T3B-CS09	5.32E-008	0.5%	T3B-C-Q-X
B935	5.15E-008	0.4%	B-U1-U2-R-X
BS33	5.11E-008	0.4%	B-U1-U2-R-Y-CV
BP1.527	4.85E-008	0.4%	BP1-U1-U2
T3B-CS27	3.80E-008	0.3%	T3B-C-U3-X
T3B-CS10		0.3%	T3B-C-Q-C1
BS29	3.37E-008	0.3%	B-U1-U2-Va1
TIACS09			TIAC-X'
S2S20	3.00E-008		\$2-C
T3B-CS11			T3B-C-Q-X'
RS10	2.75E-008		R-WS-W-Y-CV

(13)

Importance Ranking of Basic Events (Fussell-Vesely)

Rank	Event Name CM T1 NSHICPEC5-2-L1T3 T3A FWHICPEL-2-FDW-V T2 ADHICPC5-1-ADS-O CV05 R15 DGBALC1R22S0006 DHDGFS1E22S0001 U207B FPOFFSITEPUMPER DGDGFS1R43S0001B TIA DGDGFS1R43S0001A R36 FPDFFR0P54C0001 LCLCUMA U202B LCLCUMRHRALPRC FWHICPSN27-4:1IA SPHICPPS4:5SPCU FWHICPEC5-3:2 SLHICPEQ-6-SLCX MESC133 T3B MESA133 MESB133 R39 CV01 FPHICPPS4:2RCIC1 DGDGFR1R43S0001B ESMPCC CVHICPEPC-FPCC CVHICPEPC-COM	Point Est	F-V Imp	Risk Ach	Risk Red
1	CM	1.000E-005	4.110E-001	41100.41	1.698
2	71	6.090E-002	3.202E-001	5.94	1.471
3	NSHICPEC5-2-L1T3	1.000E+000	2.735E-001	1.00	1.377
4	T3A	4.510E+000	2.530E-001	0.80	1.339
5	FWHICPEL-2-FDW-V	5.003E-003	2.472E-001	50.17	1.328
6	12	1.620E+000	2.314E-001	0.91	1.301
7	ADHICPCS-1-ADS-0	7,200E+000	2.165E-001	0.81	1.276
8	CV05	1.400E-001	1.468E-001	1.90	1.172
0	R15	8.230E-002	1.279E-001	2.43	1.147
10	DOBALC182250006	9,6002-005	1.171E-001	1220.42	1.133
11	DHDGF51E22S0001	3,000E-002	1.164E-001	4.76	1.132
12	112078	8.752E-001	1.028E-001	1.01	1.115
12	FROPPS I TEPI MPER	6.000E-001	1.003E-001	1.07	1.112
14	TXXXXIFS1R4350001B	3.000E-002	9.750E-002	4.15	1.108
16	TTA	9.200E-002	9.134E-002	1.90	1.101
16	A100025124350001A	3.000E-002	8.504E-002	3.75	1.093
17	D26	5.290E-001	8.427E-002	1.08	1,092
10	FPDPFP0P54C0001	1.7458-001	7.8905-002	1.37	1.086
10	T PT PT BAL	1.030E-002	7.724E-002	4.92	1.084
20	112020	7.823E-001	6.915E-002	1.02	1.074
21	1 CT CIMPLIENT DEC	9.2205-003	6.623E-002	8.12	1,071
22	PURITOPENIOTALITA	1 1966-001	6.408E-002	1.47	1.068
33	COUT ODDCA . SCDOIL	1.0005+000	6.344E-002	1.00	1.068
40	BERIT COPCE 2.0	1.000E-002	6.151E-002	7.09	1,066
20	CTUT CONCELET CV	1.0005+000	6.128E-002	1,00	1.065
20	WEEG132	7.7608-003	5.075E-002	7.49	1.053
412	Piliper 2.3	7.6008-003	4.707E-002	1.01	1.049
50	130	7.7608-002	4.F03E-002	6.89	1.048
20	MEGRA 33	7 7608-003	4.3868-002	6.61	1.046
20	MESBIJJ	1.2205-002	A 2587-002	4.42	1.044
30	R39	1.2306-002	A 132E-002	1.05	1.043
31	GVUL (STOTAL	3.0000-001	2 0135-002	1.09	1.040
34	PPHICPP34:2RCICI	2.3305-003	3 6278-002	5 58	1.038
33	MADGY KING SSUCOLD	2 4175-004	3 5052-002	103.55	1.036
39	CVHICPEPC-FPCC	1.000E-001	3.482E-002	1.31	1.036
35	CVHICPEPC-COM	1.001E-003	3.482E-002	35.76	1.036
36	FPHICPPS4:2RCIC4	1.0015-003	3.424E-002	1.31	1.035
37		4.000E-002			
38		1.980E-002			1.034
39		1.770E-002			1.033
40					1.032
41		1.890E-002			1.032
42		7.327E-001			1.031
43		1.980E-002			1.030
44	ESESUMB	1.890E-002			1.030
45			2.927E-002		1.030
46					1.03
47		1.000E-002			1.03
48	RCHICPS51-LDTRIP	4.999E-002	2.859E-002	1,54	4-1-4-2



enc.	- 10-	N	×2 .	
11.5	81.1		2.1	×.
	cara-i	121.4	 e.,	97.

Importance Ranking of Basic Events (Risk Achievement Worth)

tank	Event Name	Point Est	F-V Imp	Risk Ach	Risk Red
1	CM	1.000E-005	4.110E-001	41100.41	1, 198
2	EDEACCEPRCS	3 750E-006	6.664E-003	1778.20	1. 1. 1. 1.
3	DGBALC1R22S0006 DCBTCC DBMFCC	9,600E-005	1.171E-001	1220,42	1.125
4	DCBTCC	1.370E-0J5	5,433E-003	397.55	1,005
5	DBMFCC	2,930E-005	8.087E-003	277.00	1.008
6	DENTROC	2.9305-005	8.0876-003	277.00	1.008
7	DELUCC	2.9305-005	8.0875-003	277.00	1.008
8	DDDVCC	1.0005-004	1.8148-002	182.34	1.018
9	PEMDAA	3.417E-004	3.505E-002	103.55	1.036
10	Endine schol	0 2505-005	7 2845-003	70 72	1.007
11	EDMYCC EDM	9.2500-005 0.000-006	5 0245-004	75 1.0	1 001
11	ADSRCUADS	1 1000-005	7 6068-004	64 02	1 001
12	ECMPLC	1.1305-002	F 0528 003	63 01	1,001
13	DBMFCC DBNDCC DBLVCC A ESMPCC ESMVCC ADSRCCADS ECMPCC DGBALC1R22S0007 FWH1CPEL-2-FDW-V ECMVCC CVH1CPEPC-COM DGDGCC S1 DCBTLC1R42S0002 CVMVN01G41F0140 SCMVNC1E12F0048A LCLCUMRHRALPRC MESC133 SLH1CPEQ-6-SLC1	9.0005-005	0.9030-003	50.17	1,720
14	FWHICPEL-Z-FDW-V	5,003E-003	2.4725-001	20.17	1.340
15	ECMVCC	9.2506-005	9.238E-002	40.81	1.004
16	CVHICPEPC-COM	1.001E-003	3.4826-002	35.70	1,035
17	DGDGCC	3.675E-004	8.743E-003	24.78	1.009
18	51	3.000E-004	5.280E-003	18,60	1.005
19	DCBTLC1R42S0002	1.367E-003	1.071E-002	8.83	1.011
20	CVMVN01G41F0140	2.930E-003	2.212E-002	8.53	1.023
21	SCMVNC1E12F0048A	2,930E-003	2.210E-002	8.52	1.023
22	LCLCUMRHRALPRC	9.220E-003	6.623E-002	8,12	1.071
23	MESC133	7.760E-003	5.075E-002	7.49	1.053
24	SLHICPEQ-6-SLC1	1.251E-003	7.903E-003	7.31	1.008
25					
26	SLEVCC	2.930E-004	1.826E-003	7.23	1.002
27	SLMPCC	2.930E-004	1.826E-003	7.23	1.002
28	ADHICPC5-1-ADS-A	3.793E-003	2.346E-002	7.16	1.024
29	HTHTCPEC5-3:2-F	1.001E-003	6.127E-003	7.12	1,006
30	HIHICPEC5-5-CRIT SLEVCC SLMPCC ADHICPC5-1-ADS-A HIHICPEC5-3:2-F FWHICPEC5-3:2 SLMVCC1G33 SLMVCC SLCVNO1C41F0007 SLCVNO1C41F0007	1.000E-002	6.151E-002	7.09	1.066
31	SLMUCCIG33	9.250E-005	5.577E-004	7.03	1,001
32	CT MUCC	9.250E-005	5.577E-004	7.03	1.001
33	SIGNO1CA1E0007	1.000E-004	5.0%8E-004	7.03	1.001
34	SLCVNO1C41F0006	1.0002-004	6.028E-004	7.03	1.001
35		4.499E-005	2.659E-004	6.91	1.000
		7.760E-003	4.603E-002	6.89	1.048
36		1.000E-003	5.731E-003		1.006
37					
38		2.930E-004	1.677E-003		
39		1.600E-003	9.113E-003	6.69	
40		7.760E-003	4.386E-002	6.61	1.046
41			1.464E-002		
42			1.454E-002		1.015
43			1.453E-002		1.015
44		2,930E-003	1,453E-002		1.015
45	HPMVNO1E22F0012	2.930E-003	1.453E-002		1.015
46	Tl	6.090E-002	3.202E-601		1.471
47	LCLCUMLPCIALPCS	5.290E-003	2.622E-002	5.93	1.027
48			9.627E-003	5.69	1.010



Table 1-6

Functional	Accident Sequence Grouping Criteria and Results						
Sequence	Definition	CDF	Percent CDP				
1A	Accident Sequences Involving Loss of Coolant Inventory Makeup in Which Reactor Pressure Remains High.	7.0E-8	< 1				
18	Accident Sequence Involving a Loss of AC Power and Loss of Coolant Inventory Makeup.	1.58-6	13				
1C	Accident Sequence Involving a Loss of All AC Power and No Recovery of AC Power.	1.2E-5	10				
1D	Accident Sequences Involving a Loss of Coolant Inventory Makeup and ATWS.	4.48-7	4				
15	Accident Sequence Involving a Loss of Coolant Inventory Makeup in which Reactor Pressure has been successfully reduced.	9.4E-7	8				
2	Accident Sequences Involving Loss of Containment Heat Removal Leading to Con'ainment Failures and Subsequent Loss of Coolant Inventory Makeup.	2.58-6	22				
3A	Vessel Rupture Leading beyond makeup capability.	< 1.08-7	< 1				
38	Accident Sequence Initiated or resulting in a small or medium LOCA for which reactor cannot be depressurized and inventory makeup is inadequate.	< 1.0E-7	< 1				
3C	Accident sequences initiated or resulting in medium or large LOCA for which the reactor is at low pressure and inadequate coolant inventory makeup is available.	3.9E-7	3				
3D	Accident sequences which are initiated by a LOCA or failure for which vapor suppression is inadequate.	< 1.E-7	< 1				
4	Accident sequences involving an ATWS leading to containment failure due to high pressure and subsequent loss of inventory.	4.0E-6	34				
5	Unisolated LOCA outside containment leading to loss of effective coolant inventory makeup.	< 1E-7	< 1				

TABLE 1-7

CONTRAINMENT PERFORMANCE CONDUCTION OF DESIGN CHANGE CONSIDERATIONS

GENERIC INITIATING EVENT FREQUENCY UPDATED INITIATING EVENT FREQUENCY

Bypess_	Cote Damage	Containment Structural Failure	RPV Failure And Early Containment Failure With Fool Bypess	Core Damage	Containment Structural Failure	RFV Feilure And Early Containment Failure With Fool
Bane Case	1.38-5	4.05-6	2.02-6	0.16+6	2.68-6	1.08-6
Passive Vent	1.08-5 (-16% CHQ)	9,92+7 (-75% CHG)	4.5E-7 (~78% CHG)	6.78-6 (-17% CHG)	5,38-7 (-80% CHG)	2.08-7 (~81% CHG)
ATWS Mods: Alt Shutdown 4 ADS Inhibit	1.08-5 (-19% CHG)	2.58~6 (~15% CNG)	1,05-6 (-16% CHG)	7.38-6 (- 9% CNG)	2.58+6 (- 5% CHG)	9.58-7 (~ 7% CHG)
Passive Vent <u>4 ATWS Mods</u>	8.0E-6 (-37% CHG)	4.6E~7 (-89% CHG)	1.6E-7 (-92% CH0)	5.96-6 (-26% CHO)	4.05-7 (~05% CHO)	1.2E-7 (-89% CH
Passive Vent, ATWE Mods & Ignitor Power	8.0E-6 (-37% CHG)	1.8E-7 (-96% CHG)	1.18-7 (-94% CHG)	5.9E-6 (-26% CHG)	1.25-7 (-964 CH _a)	7.2E-8 (-93% CNG)

NOTE: These results are based on an analysis of the core damage sequences included in the plant (ismage state trees. Thus there are small differences in the impuct of changes reported in this table compared with those reported for internal event core damage sequences in section 3.4. These differences do not change the overall conclusions.





OTher.	6.3	100	AL	65
Ta	D1	e	1.00	-85
10.000	-		1.00	- 16

Comparison of Perry IPE with Kuosheng, Cofrentes, & NUREG/CR-4550 Results

Initiating Event	Petry	Kuosheng	Cofrentes	NUREG/CR-4550
Loss of Offsite Power	1.4 X 10 ⁻⁶	1.0 x 10 ⁻⁶	l l	
Station Blackout	2.2 X 10 ⁻⁶	3.3 X 10-6	1.7 X 10	3.9 X 10 ⁻⁶
Transient w/ PCS (T3A)	< 10 ⁻⁸	1.1 X 10 ⁻⁶		< 10 ⁻⁷
Loss of feedwater (TAB)	< 10 ⁻⁸	3.0 X 10-1	7	< 10 ⁻⁷
Inadvertent open SRV (T3C)	1.4 x 10 ⁻⁷	3.0 x 10 ⁻⁸		< 10 ⁻⁷
Tranvient w/o PCS (T2)	1.7 X 10 ⁻⁶	1.3 X 10 ⁻⁸		1.3 X 10 ⁻⁸
Loss of instrument air (TIA)	1.0 X 10 ⁻⁶	-NA	< 10 ⁻⁷	< 10 ⁻⁷
Loss of service water (TSW)	6.7 X 10 ⁻⁸	NA		-NA-
Large LOCA (A)	2.1 X 10 ⁻⁷	< 1 ^{n 7}	1	< 10 ⁻⁷
Intermediate LOCA (S1)	6.2 X 10 ⁻⁸	4.1 X 10 ⁻¹	< 10 ⁻⁷	< 10 ⁻⁷
Small LOCA (S2)	3.3 X 10 ⁻⁸	< 10 ⁻⁷	생활님이	< 10 ⁻⁷
ATWS	4.7 x 10 ⁻⁶	2.5 x 10 ⁻⁵	< 10 ⁻⁷	1.1 X 10 ⁻⁷
Versel Rupture	< 10 ⁻⁷	2.7 X 10 ⁻⁷	< 10 ⁻⁷	< 10 ⁻⁷
Total Core Damage Freq	1.2 X 10 ⁻⁵	3.4 x 10 ⁺⁵	2.6 X 10 ⁻⁷	4.0 X 10 ⁻⁶
Internal Flooding CDF	1.5 x 10 ⁻⁶	5.7 × 10 ⁻¹	-NA-	-NA

* Total CDF does not include flooding.

Table 1-9	
Table 1-9	

Compar	ison of Plant Design I	reatures		I
Plant Feature/Parameter	GGNS	Clinton	Perry	River Bend
Rated Power, Mwt	3833	2894	3579	2894
AE	Bechtel	S&L	GILBERT/ COMMONWEALTH	SWEC
ECCS Systems (number x gpm) LPCS LPCI	1 x 7115 3 x 7450	1 x 5010 3 x 5050	1 % 6000 3 % 6500	1 x 5010 3 x 5050
HPCS RCTC	1 X 1650 1 X 800	1 x 1400 1 x 600	1 x 1550 1 x 700	1 x 1400 1 x 600
ADS Valves/Non-ADS	8 ≠ 12	7/9	8 / 11	7/9
CONDENSATE/FEEDWATER Turbine-driven Pumps Motor-driven Pumps Feed Booster Condensate Pumps Cond Booster Pumps	2 0 0 3 3	2 1 0 4 4	2 1 4 3 3	0 3 0 3 0
Turbine Bypass Capacity (%)	35	35	35	1.
Service Water Safety Related Non-safety Related	3 independent 1 loop/8 pumps	3 independent 1 loop	3 independent 1 loop/4 pumps	4 pumps/2 loops 1 loop
AC Power Offsite Power Circuits ESF Buses Standby Diesels	3 3 3	4 3 3	4 3 3	6 3 3
DC Power Safety Related Batteries Non-Safety Related Batteries Design Battery Life (hours)	3 4 4(Div 1&2) 2(Div 3)	4 2 4	3+3(Unit 1&2) 7 22(x-tie & shedding)	3 3 4(Div 1&2) 2(Div 3)


mparison of Plant Design Features


TABLE 1-10

SUMMARY OF CONTAINMENT FAILURE FREQUENCY

	GENERIC	UPDATED	UPDATED
	INITIATINO	INITIATING	INITIATING
	EVENT	EVENT	EVENT
	FREQUENCY	PREQUENCY	FREQUENCY
	BARE CASE	BASE CASE	PASSIVE VENT
No RPV Failure: No Containment Failurr	3,39E-6	1.22E-6	1.22E-6
	(26,7%)	(15.2%)	(18.3%)
Vent	2.458-6	2.36E-6	2.825-6
	(19.3%)	(29.4%)	(42.3%)
Containment Failure	6.188-7	4.70%-7	6.74E-8
	(4.9%)	(5.8%)	(1.0%)
Subtotal No RPV Failure Core Damage Frequency:	6.468-6	4.065-6	4.112-6
	(50.8%)	(50.3%)	(61.6%)
RPV Feilure: No Containment Failure	1.58E+6	6.22E-7	6.22E-7
	(12.4%)	(7.7%)	(9.3%)
Vent	1.270-6	1.23E-6	1.47E-5
	(10.0%)	(15.3%)	(22.1%)
Lata Containment Failure	9.388-7	9.25E-7	2.45E-7
	(7.4%)	(11.5%)	(3.7%)
Early CF: No Pool Bypass	4.30±-7 (3.4%)	1.885-7	2.00E-8 (0.3%)
Late Pool Bypass	1.54E-6	7.51E-7	8.40E-8
	(12.1%)	(9.3%)	(1.3%)
Early PB, Spray	6.12E+8	2.828-8	2.78E-8
	(0.5%)	(0.3%)	(0.4%)
Early PB, No Spray	4.451-7	2.49E-7	8.76E~8
	(3.5%)	(3.1%)	(1.3%)
Subtotal RPV Failure Core Damage Frequency:	6.278-6	4.00E-6	2.56E-6
	(49.2%)	(49.7%)	(38.4%)
YOTAL CORE DAMAGE PREQUENCY.	1.27E-5	8.05E-6	6.67E6
	(100%)	(100%)	(100%)
Subtotal Containment Venting Frequency:	3.72£-6	3.59F-6	4:29E-6
	(29.2%)	(44.7%)	(59:4%)
Subtotal Cntmt Structural Failure Frequency:	4.03E-6	2.61E-6	5.34£-7
	(31.7%)	(32.5%)	(8.0%)
TOTAL CONTAINMENT FAILURE & VELLING FREQUENCY:	7.762-6	6.21E+6	4.83E-6
	(60.9%)	(77.13)	(72.4%)
RFV FAILURE & EARLY CONTAINMENT FAILURE	2.04E~6	1.03E-6	1.99%-7
WITH POOL BYPASS FPEQUENCY:	(16.1%)	(12.3%)	(3.04)


CORE DAMAGE FREQ DISTRIB FIGURE 1-1






DOMINANT BASIC EVENIS BY FUSSELL-VESELY IMPORTANCE

re 1-3



×

1E-001



2.0 EXAMINATION DESCRIPTION

2.1 INTRODUCTION

The Perry IPE project is aimed at meeting two objectives, satisfying the NRC requirements for an individual plant examination and providing plant models for use in assisting in maintaining the safe operation of the Perry Nuclear Power Plant. In this section it is demonstrated that the project conforms with the NRC requirements. The general methodology and the information used in the course of the study are also described.

2.2 CONFORMANCE WITH GENERIC LETTER AND SUPPORTING MATERIAL

Generic Letter 88-20 and its supplements identify a number of requirements in the areas of the examination process, methodology, treatment of unresolved safety issues and reporting. This IPE conforms with the requirements laid out in the generic letter and uses the current supporting material appropriate to the analysis of a BWR/6 Mark III. The software used in the Level 1 and Level 2 sections of the analysis has been developed in accordance with NRC or EPRI QA requirements and is in general use in the industry. Conformance within each of the specific areas is discussed in the following sections.

2.2.1 Examination Process

It is the belief of the NRC as stated in the generic letter that the quality and comprehensiveness of the results derived from the IFE depend on the vigor with which the utility applies the method of examination and on their commitment to the intent of the IFE. It can be seen from the project organization shown in Figure 2-1 that the CEI personnel were involved in the performance of all tasks. In fact the majority of the Level 1 and 2 analyses was performed by Perry personnel with assistance from a number of consultants in key areas such as performance of the containment ultimate strength analysis and the core melt phenomenology.

In house review of systems analysis was performed by Perry staff conversant with system design, maintenance and operation. In addition to the in house review further review of the examination process and the results were performed by independent consultants.

The combination of experienced consultants, Perry personnel and independent review in the performance of the analysis has ensured that the quality and comprehensiveness of the Perry IPE results meet the highest standards and will be usable in the future as a living PRA and for the development of accident management strategies.

2.2.2 External Events

The current study includes only core damage and fission product release assessment following an internal initiating event or internal flood. A number of plant walkdowns have been conducted for the flooding analysis and for the investigation of common cause failures. The information gained from these walkdowns has been included in the appropriate analysis files and will be available when performing external event analyses.

2.2.3 Methods of Examination

The approach used to satisfy the IPE was to perform a Level II PRA based on the procedures in NUREG/CR-2300 (Hickman 1953) and information provided in NUREG/CR-4550 (Drouin, 1989) for the Grand Gulf analysis. In order to ensure that methods used for the human reliability and common cause analysis represent the current state of the art in these areas the latest information from either EPRI or the NRC was used to perform the analysis. As the PRA was performed at the Perry site the latest design information (January 1990) was used in the performance of the study. As the quality assurance for the development of the plant model has required full recording of all documentation used, it will be a straightforward process to update the model as design change packages are complete. The methodology is fully described in Section 2.3.

Details of the approach to the Containment Structural Analysis are given in Section 4 of this report.

2.2.4 Resolution of Unresolved Safety Issue A-45

The PRA specifically addresses the performance of the shutdown decay heat removal systems following transients from high power or loss of coolant accidents. The overall contribution to core damage is assessed and any individual system vulnerabilities identified.

2.2.5 Severe Accident Sequence Selection

The results of the analysis which are reported in Sections 3.4 and 4.7 have been based on the screening analysis defined in Appendix 2 of the generic letter and amplified in the guidance document (NRC, 1989). Any identified vulnerabilities, unique safety features, and potential improvements are discussed in Section 6.

2.2.6 Documentation of Examination Results

As it is intended that the IPE shall be videly used within CFI in the future, considerable care has been taken in developing the documentation for the study. The documentation of the completed study has three components. The first is this report which summarizes the results and findings of the PRA given the current plant status. The second is the Perry plant model which exists in the PC software NUPRA/NUCAP+/EVNTRE. This model can be updated as and when changes in design or procedures are made. The third is the set of analysis files which document all the assumptions, boundary conditions and documents used in developing the plant model on the PC. It is these documents which form the basis for the living PRA in that they provide the basis of comparison of new designs, data, operational procedures, training, testing, etc with that used for the base scone study, and thus enable the changes that need to be made to the model to be identified.

One of the key items in this third tier of documentation is the listing of all the documents (such as the Updated Safety Analysis Report (USAR), P&IDs, etc.) used and reports produced in the study.

2.3 GENERAL METHODOLOGY

The methodology used to perform the analysis for the Individual Plant Examination is designed to answer the following questions.

- What events at the plant will result in a reactor trip or the necessity for the reactor to trip?
- What requirements for reactivity control, pressure control or level control will arise?
- 3. How can decay heat be removed following reactor trip?
- 4. How often (with what frequency) will core damage occur as the result of failure to remove decay heat?
- 5. How likely is containment failure to occur following core damage?
- 6. What fission product release is likely to occur and how often?
- 7. What are the significant contributors to the frequency of core damage, containment failure, and fission product release?

The answers to the above questions are determined by carrying out the following basic steps shown in the flow diagrams in Figures 2-2 and 2-3.

- Identifying the causes and frequency of plant trips (Initiating Events).
- Developing a model which represents the many different ways in which decay heat removal can fail following the various initiating events (event trees and fault trees) taking into account the reactivity, pressure and level control requirements to achieve decay heat removal.
- Assembling data for the component failures, maintenance unavailabilities, operator actions, etc. included in the event and fault tree models. (Data and common cause failures)
- Quantifying the core damage frequency and performing importance analysis to identify the dominant contributors to core damage (quantification, importance analysis).
- Performing a containment building strength analysis to determine the likelihood of failure over a range of pressures and temperatures.
- 6. Determine the range of pressures and temperatures in the containment building for a range of possible core damage scenarios. Each scenario is identified by a specific set of conditions at the time of core damage known as the plant damage state. (containment analysis)

 Combine 5 and 6 to determine the likelihood of containment building failure and the magnitude of the fission product release.

The way in which each of these steps is performed is discussed in the following paragraphs. In order to ensure that the analysis was as complete as possible and that all the interfaces between the various sub-tasks of the PRA were clearly recognized, the first step in performing the analysis was to develop a set of comprehensive procedures to identify the way in which the analysis in each sub-task was to be performed. The procedures used are listed in Table 2-1.

2.3.1 Initiating Events and Success Criteria

Initiating event information was derived from the plant operating experience for the past two years, from past studies of BVRs and the NRC study of Grand Gulf. Particular attention was paid to the Failure Mode and Effects analysis of support systems which would result in possible initiating events associated with the loss of switchgear room cooling, loss of service water, loss of alternating current (AC) and direct current (DC) bus bars and loss of instrument air.

The safety functions required in response to each of the initiation events were defined and the systems which could perform these functions were identified. The success criteria were determined by reviewing earlier analyses, the USAR, General Electric analyses and by performing thermal hydraulic analyses using the MAAP code to confirm the requirements and to obtain estimates of timing. These are discussed in section 3.1.1.

Following the identification of the success criteria for each initiating event, it was possible to group together events which had similar system success criteria in order to reduce the number of event trees to be developed.

2.3.2 Accident Sequence Development

An event tree was developed for each initiating event or event group using the information developed for the system success criteria and including the operator actions identified in the various emergency procedures (section 3.1.2). An individual path through each event tree (an accident sequence) then specifies the combination of system failures and successes and operator actions which will lead either to successful core cooling or to core damage through lack of cooling. As the Perry IPE is effectively a Level 2 PRA, this analysis also considered the impact that the containment building systems could have on the potential for core damage. In order to clearly define the boundary conditions in terms of timing for each sequence, it was necessary to perform a number of MAAF analyses. The results of these analyses enabled the timing of actuation signals and the time available for operators to perform back up or recovery actions to be identified. The development of the plant damage states is described in Section 2.3.8.



2.3.3 Data Base

Plant-specific data has been used to determine the maintenance unavailability for all front line and important support systems, and for the frequency of transients initiating events for comparison with the generic transient initiating event frequencies. Generic data has been used for all other items.

2.3.4 Dependent Failures and Interaction

In addition to the failures directly associated with the components in the system performing the safety function, it is necessary to model the dependent failures. Direct functional dependencies (i.e. electric power, pump bearing cooling, initiating signals, etc.) are modeled by developing a dependency matrix for each system and including these dependencies in the system fault tree. The system performance is then evaluated by linking the fault trees for the supporting systems into the appropriate points of the system fault tree. These dependencies are summarized in section 3.2 and shown in detail in the fault trees in Appendix A.

Multiple failures of some components may occur as the result of influences which it is neither possible to identify nor explicitly model in the system fault tree of the individual equipment failures. In addition, there may also be interactions between systems as the result of location or the fluid being pumped by the system. An attempt has been made to model such failures by including common cause events in the fault trees for components which are assessed to be subject to such common failures, for example diesel generators, motor-driven pumps, motor-operated valves, and check valves. The quantification of these events has been based on a review of both plant design and industry data. The evaluation and quantification of these dependencies is described in section 3.3.4 and Appendix C.

The dependency of systems on environmental conditions has been included in the analysis. For each system the running time and room temperature have been evaluated, over the range of accident scenarios, to determine if room cooling is required. The impact of suppression pool water temperature on the systems which take suction from the suppression pool has been taken into account. This information is included in the system analysis supporting documentation and summarized in section 3.2.

The dependencies between initiating events and systems required to prevent core damage or the release of fission products are modeled in the event and fault trees. Similarly, the dependency of a function in an event tree on the success or failure of a previous function is the basis for the construction of the event trees. The dependency between function and initiating events is represented in the system fault trees by the use of house events. These events are then set to one or zero depending on the system being modeled and the initiating event. The setting of these events for each of the sequences are given in Appendix E.



2.3.5 System Modeling

As insufficient data exist for determining the probability of failure of each system directly, it is necessary to model each system in a logical way, breaking it down to individual components for which failure data are available or can be estimated. The basic model used in this study, as is in other PRAs, is the fault tree.

The systems for which fault tree models are required are defined in the development of the success criteria and event trees. In addition to the front line systems, the list includes the support systems such as electric power, cooling water, control air, and instrumentation and control. For each system a fault tree has been developed either to the component level or, if it is not important relative to core damage frequency, to a lesser level of detail, but always including the dependency on supporting systems. (Section 3.2 and Appendix A)

2.3.6 Human Interaction Analysis

System and safety function failures may result from the operators' failure to perform certain actions or the performance of incorrect actions. Therefore operator actions are included in the event and fault trees. Two types of actions are identified.

- Errors occurring prior to the plant trip which result in equipment (e.g. valves) left in the wrong position at the time of the demand on the system or result in miscalibration of instruments such that a system is not initiated.
- Post trip errors which result in the operator failing to take the correct action in response to the plant state either to start a system or failure to perform a backup action if auto initiation should fail.

The second group can in fact be broken down into the following three subgroups: failing to take the correct action in accordance with procedure, taking the incorrect action, and failing to take appropriate recovery actions following system failures.

A systematic approach based on the work performed at the Electric Power Research Institute (EPR1) was used to perform the analysis. There are three essential steps in this method. The first is identification by the event and fault tree analyst of the human interactions that can occur which will impact the operation of the system either before or after the plant trip. This is achieved by a detailed review of test, maintenance, and operating procedures.

The second step is to evaluate each action in terms of how the action would be performed for various combinations of prior system failures, how long the operator has to perform the action, what cues he has to indicate the necessities to perform the action, and how it relates to the procedures. At this stage it may be necessary to modify the event or fault tree in order to more accurately model the human interaction. It is also necessary to examine the combinations of human actions that occur in a given sequence of events in order to determine the relationship between success and failure of one action to the success and/or failure of the second and/or subsequent actions in the combination.

The third and final stage is the quantification of each of the actions ultimately modeled in the event and fault trees. The quantification of each of the important actions was based either on THERP or methods based on those developed as a result of the Operator Reliability Experiments (ORE) program performed by EPRI. Quantification of the less important actions was based on estimates used in NUREG/CR-4550 (Drouin, 1989) for the Grand Gulf PRA for similar actions. (Section 3.3.3)

2.3.7 Accident Sequence Quantification

In this step the information gathered in the preceding steps is used to quantify the individual core damage sequences. In the NUPRA code the first step is to develop linked and quantified fault trees for all the functions in the event tree. Care is taken to ensure that for each function the system fault tree used reflects the boundary conditions in terms of initiating event and actuation conditions appropriate to the sequence in which the function appears. Each sequence is then quantified by combining the results from the quantification of the linked fault trees taking care to ensure that both success and failure paths are accounted for in each core damage sequence. The final result is entered into a data base which stores the frequency of each sequence, the various functional failures and successes, and a list of the combinations of basic event failures contributing to the sequence frequency. (Section 3.3.5 and 3.3.6)

2.3.8 Plant Damage State Analysis

The interface between Level 1 and Level 2 is the set of plant damage states which reflect the operability of plant systems and containment building systems, as well as the Reactor Pressure Vessel state at the onset of core damage. In order to group the individual core damage sequences into the various plant damage states, two requirements have to be met. The first is to define the grouping criteria. The criteria have been developed based on those aspects of plant and containment building systems or reactor state at the onset of core damage which have a significant impact on the accident progression and ultimate fission product release. (Section 3.1.4)

The second is to develop a set of event trees which include all the information necessary to apply the grouping logic developed above. This requires extending the core damage event trees to include not only functions which can prevent core damage, but also functions which will prevent containment building failure or significantly impact fission product release.

2.3.9 Containment Evaluation

The Perry IPE containment evaluation is performed using an Accident Progression Event Tree (APET) similar to that used in the Grand Gulf NUREG/CR-4551 analysis (Brown, 1990). The initial accident progression analysis begins by grouping the functional characteristics determined in the plant damage state analysis into plant damage state groups. Each Plant Damage State contains Front-End sequences with sufficient similarity of the system functional characteristics that the containment accident progression for all sequences in the group can be considered to lead to the same thermal hydraulic transient containment response. The APET is then extended into early, intermediate and late time periods to determine: the coolability of the core debris in-vessel, the mode of containment failure and the mode of suppression pool bypass. Containment performance and source term category groups are determined using a binner function with a specified grouping logic. Source term category grouping logic selects those sequence characteristics important to source term assessment. Release category source terms are estimated based on the results of Modular Accident Analysis Program (MAAP) computer runs.

2.3.10 Risk Contribution Evaluation

The results of both the core damage quantification and the source term releases have been analyzed to identify the dominant contributors to each in terms of initiating events, system and component failures, operator actions, containment capacity, and phenomenological sensitivity. This has been achieved by performing three sets of analyses: sensitivity, importance, and uncertainty. The use of importance analysis leads to the identification of the dominant contributors to the frequency of core damage and the frequency of a given source term. The identification of vulnerabilities in this way (dominant or significant contributors that are initiating events, component failures, operator actions, maintenance items, or containment building failure modes) enables the areas in which improvements would have the most impact to be identified. The important contributions to decay heat removal failure and the evaluation of these vulnerabilities is addressed in the risk contribution evaluation task.

2.4 INFORMATION ASSEMBLY

The first step in the performance of the IPE was the assembly and review of the documentation necessary to perform this study. This consisted of the USAR, the PRA performed for Grand Gulf (Drouin, 1989), the piping and instrumentation diagrams, normal and emergency operating procedures, control room logs, maintenance records, and selected thermal hydraulic analyses performed by General Electric and the architect/engincer Gilbert/ Commonwealth. In addition, the PRA studies performed for the BWR/6s at Kuosheng in Taiwan (ROC, 1985) and Cofrentes in Spain, (Hydroelectrica, 1991) were made available to the project team.

The members of the project team from CEI were all very familiar with the Perry plant. The members of the project team from Gilbert/Commonwealth were also very familiar with the Perry plant, having been involved in the construction and startup of the plant. All the Halliburton NUS personnel had previously performed a PRA for the BWR/6 at Kuosheng and were therefore familiar with the plant layout and performance. Visits were made by personnel during the course of the study to acquire specific information relating to the flooding analysis and to system performance. One of the major concerns when developing a living IPE/PRA model is that it represents the as-built as operated plant. In order to ensure that the Perry model described in this report meets this requirement, the following specific actions were taken:

- The study was performed by the Independent Safety Engineering Section at the Perry site so that design documentation was directly available.
- 2. Analysis files were set up for each phase of the model development to ensure that the documents used and decisions made on the basis of information in a given document were recorded. This ensures that comparison between the model and subsequent design change packages can be made in a controlled manner.
- The design engineers reviewed all the system models for correctness of assumptions concerning design, alignment and operation.
- 4. Operations reviewed all the event trees.
- 5. The current set of operating procedures were used in performing the human reliability analysis and many of the actions were discussed with training and operations personnel.
- Maintenance data was acquired directly from plant operating experience.
- A significant number of visits were made to the plant to walkdown systems which would lead to flooding and trace potential flood propagation pathways.
- The Containment Building Strength Evaluation and portions of the internal flooding analysis were performed by Gilbert/Commonwealth, the architect/engineer (A/E) for the Perry Nuclear Power Plant.
- 9. In addition to reviews of each of the system analyses by the appropriate design engineers, intermediate reviews of the work products and the draft report were performed by key personnel from the operations, training, and engineering departments.

2.4.1 Plant Layout and Containment Building Information

The Perry Nuclear Power Plant is a two unit site on which only Unit 1 has been completed and is operating. Unit 2 was approximately 40% complete when all work was stopped. The site is therefore a single unit site as tar as interactions are concerned. The unit is a General Electric BVR/6 with a Mark III containment. The balance of plant systems were engineered by Gilbert/Commonwealth. The unit started commercial operation in 1987. Some important design features of the Perry plant are described in Table 2-2. The applicability of the unique features associated with Mark III containment design to the progression of an accident are discussed in Section 4.1 of the report.

2.4.2 Review of PRA Studies of Plants Similar to Perry

Three BWR/6 Mark III plants have been the subject of previously published PRAS. These are the Kuosheng Nuclear Pover Plant (ROCAEC, 1985), Grand Gulf (Druin, 1989) and Cofrentes (Hydroelectrica, 1991). The NRC has also published a document summarizing generic risk insights for General Electric Boiling Water Reactors (Travis, 1991). Other studies reviewed for information pertaining to either internal events, internal flooding or containment evaluation analysis were GESSAR II (General Electric, 1982), the EPRI document recommending sensitivity analysis to be performed when using the MAAP code (Kenton, 1991) and the evaluation of severe accident risk performed for Grand Gulf reported in NUREG/CR-4551 (Brown, 1990).

For the Level 1 analysis, the above studies were reviewed to identify the dominant contributions to core damage and any plant-specific vulnerabilities associated with equipment or systems similar to equipment or systems at Perry. In particular, careful attention was paid to the Grand Gulf st dy to determine what assumptions had been made with regard to room cooling requirements, the availability and modeling of support systems and the evaluation of the emergency operating procedures and recovery actions. The results of this study are compared with the results of the NUREG/CR-4550 and other BWR/6 PRA results in sections 1.4.4 and 3.4. Important insights from some of these studies are listed in Table 2-3 and the core damage frequencies for a number of plants in Table 2-4.

For the Level 2 analysis the above studies were reviewed to identify 1) Plant systems and components important to accident progression and mitigation, 2) Phenomenological events and processes which are important to drywell and containment failure and source term definition, and potential containment loading and failure mechanisms and modes. These studies were also reviewed to determine the criteria and parameters used in the definition of plant damage states and the physical processes, system operation, operator actions, etc., which were considered of sufficient importance to containment accident progression to be included as a containment event tree heading in the analysis. The results from the containment analysis are compared with the results from the analysis performed for Grand Gulf in sections 1.4.4 and 4.7.4.

2.4.3 Walkthrough Activities

In order to ensure that all members of the project team were familiar with the Perry Plant, a plant familiarization tark was included in the work scope. This consisted of reviewing the system descriptions and making a plant visit at the beginning of this study so that analysts could familiarize themselves with the general information and layout of the plant.

As the study was conducted at the Perry site visits were made to the unit as and when the need arose. The areas of analysis which resulted in such visits are discussed in the following sections.

2.4.3.1 Human Reliability Analysis

Throughout the human interaction modeling task, communication was maintained with the Operations Procedure Unit personnel in order to thoroughly perform the plant logic model construction. Particularly, close communication was maintained with the Plant Emergency Instruction Coordinator to clearly understand the Plant Emergency Instruction Flow Charts. Several Plant Emergency Instructions relating to alternate injection and containment venting were walked down in the plant. The assessment of human interaction timing was determined from interviews with the Operator Training Unit, as well as plant operator walkdown.

2.4.3.2 Data Analysis

Because of the short operating history of the plant generic failure data was used for component failure rates. For unavailability due to maintenance for the HPCS and RCIC systems, Perry-specific data from the third operating cycle was used as the core damage frequency was most sensitive to the maintenance unavailability of these systems. Earlier operating cycle data was used for other systems. The maintenance data was taken from the Unit Log, Active LCO Tracking sheets and the Fire Protection Log for the periods of time when the unit was at power. Maintenance data for the Motor Feed Pump was taken from Work Orders. These documents were obtained from Document Control at the site.

2.4.3.3 System Modeling

As part of the system modeling task plant walkdowns were performed. These walkdowns are documented in the analysis files of the system modeling task. Walkdowns were done on an area by area basis without trying to trace a system from beginning to end. General location of components, external crud buildup, rust, leaks, and general cleanliness were all examined as part of the walkdown process. A team of two individuals performed all system modeling walkdowns.

2.4.3.4 Dependencies and Common Cause

Included in the walkdowns performed for the system modeling task were examinations of potential dependencies such as the proximity of systems and components to high energy pipes and sources of water damage, sources of heat or enclosed areas subject to heat buildup. Multiple systems located in a given vicinity were noted. This is documented in the system modeling analysic files.

2.4.3.5 Internal Flooding

Several walkdowns were performed by a team of two persons covering the general plant areas with emphasis on the critical identified zones. Direction of door opening, penetrations, and equipment heights were investigated. In addition numerous one man walkdowns took place. These typically involved checking the gaps under doors, measuring critical heights on skid and panel mounted equipment, and various other concerns such as counting pipe welds where this factor was needed for input to the flood initiation frequency.

2.4.3.6 Containment Evaluation

The containment evaluation walkdown focused on modeling the modes of containment failure impact on RPV injection and on suppression pool loss. Containment walkdowns were made to Unit 1 to provide general familiarization of detail. When the containment anchorage failure mode was identified, the walkdowns were extended to the Unit 2 containment (now under construction) to better examine the containment construction within the open shield building annulus.

References

- Brown, T.D. et al 1990 <u>Evaluation of Severe Accident Risks: Grand Gulf Unit 1</u> NUREG/CR-4551 Vol 6 Rev 1 parts 1 and 2, Sandia National Laboratories, Albuquerque, NM.
- Drouin, M.T. et al, 1989 <u>Analysis of Core Damage Frequency: Grand Gulf, Unit</u> <u>1, Internal Events</u> NUREG/CR-6550, Sandia National Laboratories, Albuquerque, NE.
- General Electric, 1962 GESSAR II BV9/6 Standard Plant Probabilistic Risk Assessment, General Electric Company, San Jose, CA
- Rickman, J.W., 1983, <u>PRA Frocedures Guide: A Gride to the Performance of</u> <u>Probabilitic Risk Assessments for Nuclear Power Plants</u>", <u>NUREG/CR-2300 Vol 1 and 2. American Nuclear Society and Institute</u> of Electrical and Electronic Engineers
- Hydroelectrica Espanola S.A., 1991 <u>Central Nuclear de Cofrentes Analysis</u> Probabilista de Seguridad Doc. No. K90-S-35-7 Madrid, Spain.
- Kenton, M.A. and J.P. Gabor, 1991. Recommended Sensitivity Analysis for an Individual Plant Examination using MAAP 3.08. Electric Power Research Institute, Palo Alto, CA
- NEC, 1989, Individual Plant Examination: Submittal Guidance, NUREG-1335, USNRC Washington, D.C.
- ROC AEC, (Republic of China, Atomic Energy Council) 1985 "Probabilistic Risk Assessment Kuosheng Nuclear Power Plant Unit 1", Executive Yuan, Taipei, Taiwan.
- Travis, R. et al, 1991. <u>Generic Risk Insights for General Electric Boiling</u> <u>Water Reactors</u> NUREG/CR-5692, Brookhaven National Laboratory, Upton, NY

Table 2-1

List of Procedures

Description Number IPE Project Plan -NA-IPE Technical Assignment Plan 80793 Initiating Event/Accident Sequence Task Plan 80744/80745 System Modeling Task Plan 80746 Dependent Failure Task Plan 80747 Data Base Task Plan 80748 Euman Interaction Task Plan 80749 Risk Contribution Evaluation Task Plan 807.50 Internal Flooding Task Plan 80751 Containment Evaluation Task Plan 80752 Final Report Task Plan 80755





Table 2-2

Summary of Design Features - Perry

1. High Pressure Injection Systems

- a. High pressure core spray; diesel backed motor driven pump.
- b. Reactor core isolation cooling; turbine driven pump.
- c. Condensate/Feedwater system; turbine and motor driven pumps.

2. Low Pressure Injection Systems

- a. Low pressure coolant injection system; three independent trains.
- b. Low pressure core spray system; one train.
- c. Condensate transfer alternate injection system.
- d. Fire Protection system; diesel driven pump.
- . wepressurization System
 - a. Automatic depressurization system 8 relief valves
 - b. Manual depressurization using ADS or non-ADS valves 19 relief valves.
- 4. Decay Heat Removal
 - a. Power conversion system.
 - b. Two trains of RNR with one heat exchanger in each train which can be used in the following modes:

Suppression pool cooling mode; Containment spray mode.

D. Emergency Service Water

Two trains of emergency service water with one pump in each train which provides cooling to the RER heat exchangers. One train provides an alternative injection path to the RER train B.

- 6. Electrical Design
 - a. Number of offsite circuits = 4
 - b. Number of auxiliary power circuits = 4 1 unit auxiliary transformer; 1 startup transformer (per unit).



Table 2-7 continued

- c. Number of preferred power circuits of ESF buses = 2.
- d. Number of ESF buses per unit = 3.
- e. Number of standby AC p ver sources per unit = 3 (1/ESF bus).
- f. Number of 125VDC systems = 6 (2/ESF bus).
- g. Sharing of standby power supplies and interconnection between safety buses - Division 3 D/G (HPCS) can be connected to ESF Bus 2.

7. Containment Structure

- a. Type: Mark III, steel containment with pressure suppression, enclosed by reinforced concrete shield building. Containment enclosed drywell and suppression pool.
- b. Construction: Steel shell enclosed by reinforced concrete cylindrical structure with hemispherical head. The internal design temperature is 185°F, the design pressure 15 psig and the free volume 1.165×10^6 ft⁻³.
- c. Drywell: Reinforced concrete; basically cylindrical with a flat concrete roof with a steel refueling head. The internal design temperature is 330°F and design pressure is 30 psi. The external design pressure is 21 psi. The free volume is 277,700 ft³.
- d. Suppression Pool: Reinforced concrete, steel lined; basically annualr. The minimum water volume is 115,612 ft³.

Table 2-3

Significant Insights From Other Studies

NUREG/CR-4550 Grand Gulf IT. (1989)

 Station Blackout Sequences are the dominant contributor to ">re damage (97%).

Significant contributions are: Operator failure to recover AC power RCIC turbine driven pump failure Failure to recover diesel generators Diesel generator hardvare failures Battery common cause failure

 ATWS sequences contribute 3%, all other sequences are at cr below a core damage frequency of 1.02-8/yr.

Ruosheng Study (AEC, 1985)

- 1. ATWS sequences are the dominant contributor to core damage (76%).
 - Significant contributions are: Failure of the standby liquid control systems (SLC) Failure of the operator to initiate SLC Failure of RCIC pumps
- Loss of offsite power and station blackout contributes 13% and all other transients 8%. Loss of coolant accidents contribute 3%.

Cofrentes Study (Hydroelectrica, 1991)

 Loss of offsite power and station blackout accidents are the dominant contributors to core melt (66.5%).

Significant contributions:

Failure of the RCIC turbing driven pump Common cause failure to operate the diesel generators A and B Operator failure to depressurize following a station blackout Common cause failure of Div I and II essential service water pump discharge valve to open

 Loss of coolant accidents contribute 15.5% and transients resulting in isolation of the reactor, loss of feedwater, loss of instrument air and loss of service water contribute 16%. ATWS sequences only contribute 2%.

Table 2-3 continued

Generic Risk Insights for BWRs (NUREG/CR-5692, 1991)

This study summarizes the results from seven studies.

- For 3 plants loss of offsite power and station blackout are the dominant sequences.
- For 3 plants transients or small LOCA with failure of high pressure injection and a failure to depressurize are dominant.
- For one plant transients or LOCA followed by loss of containment heat removal is dominant.
- For one plant the maximum contribution from failure to scram is 43%. For all the other plants it is 12% or less.

	2	

Comparison	Of Core	Damaryo	The more services and a	Warman Area	and the second
comparison	and an in the last	articles and the	tredneuch	FION Va	LICUIS FRAC

Plant PRA	Mean Core Damage Frequency for Internal Events
Cofrentes	2.0 E -7
Grand Gulf	4.0 E6
Perry	1.2 E -5
Kupsheng	3.4 E -5
Surrey	7.4 E -5
Oconee	1.4 E -4
Seabrook	1.7 E -4
Three Mile Island	4.4 E -4








Figure 2-1 Project Organization









FIGURE 2-2 OVERVIEW OF LEVEL 1 PRA METHODOLOGY





FIGURE 2-3 OVERVIEW OF LEVEL 2 PRA METHODOLOGY



..

3.0 FRONT END ANALYSIS

3.1 ACCIDENT DELINEATION

The reporting of the accident delineation process is divided into four sections. In the first section the selection and grouping of the initiating events is described. The event trees as ociated with such initiating event group and its success criteria are developed in sections 3.1.2 and 3.1.3 for the Front Line and Special event trees respectively. Finally the sequence grouping into the various plant damage states in order to achieve the Level 1/Level 2 interface is described in section 3.1.4.

3.1.1 Initiating Events

For the purpose of this analysis, initiating events are defined as those plant occurrences, during normal plant operation, which cause a rapid shutdown of the plant (automatic scram), or an immediate need to manually trip the plant (manual scram), so as to challenge the capability of the plant systems to bring the reactor to a safe shutdown condition. Manual orderly shutdowns of the plant for outages or administrative reasons (i.e. Technical Specifications) are not considered. Events during plant startup, shutdown or below 12% power are additionally excluded from the scope of this study. The decision to define events at power as those above 12% is that this is the point at which the mode switch is placed to RUN.

This section discusses the identification of the initiating events which are analyzed in the Perry IPE, and the grouping of these events into classes. The list of Perry IPE initiating events is identified in Table 3.1.1-1. This list provides input for the event true task. Event trees, which define the p?ant response to the given initiator, are developed for each initiator.

The scope of this analysis includes internally initiated events only. That is, those abnormal occurrences within the plant systems which have the potential to cause a plant challenge. This includes internal flooding, which is discussed in the report of the flooding analysis in Section 3.3.7.

3.1.1.1 Initiating Events - Identification

The significant issue in the development of the list of initiating events is completeness. To minimize the possibility of omitting a significant initiator, the task of identifying initiating events is subdivided into three categories.

A. TransientsB. LOCAsC. Special Initiators

Each task is defined and discussed in the following subsections.

3.1.1.1.1 Transients

For this analysis a transient is defined as any event which requires or results in a reactor scram. The first step involved with identifying a list of PNPP specific transient events is to prepare a list of all transients which have occurred in other BVRs. NUREG/CR 3862 (NRC, 1985a) provides a summary and categorization of all industry transient events and is used as a basis for this analysis. NUREG/CR-3862 updates and validates the transient categorizations (dentified in EPRI NF-2230 (McClymont, 1982). Thirty-seven BVR Transient Category Definitions were defined in the EPRI report. The same categorization was used in NUREG/CR-3862.

All PNPP post scram restart reports from plant startup through scram 1-90-01 were reviewed to determine the basic cause of scram, plant response following scram and to identify any unique features of the PNPP design. These events were then classified using the EPRI BWR Transient Category Definitions to verify the completeness and applicability of the transient definitions to Perry.

The transient categorization used in NUREG/CR-4550 (Drouin, 1989) for the Grand Gulf analysis was also reviewed to ensure that no unique transient categories were identified for a plant of similar design configuration.

The EPRI BVR Transient Category Definitions as described by NUREG/CR-3862 are listed in Table 3.1.1-2. The review of all Perry scram reports verified that all the transient events which have occurred at Perry were represented by the industry operating experience described by the EPRI BVP Transient Categories. Also, the review determined that the Grand Gulf Initiating Events Identification as described by NUREG/CR-4550 referenced the EPRI BVR Transient Categories as a summary of transient initiating events, and did not identify any additional transient categories.

During the review of the Perry scrams, it was noted that the thirty-seven EPRI BVR Transient Categories provide only three associated with startup and shutdown operation: Low Feedwater Flow During Startup, High Feedwater Flow During Startup or Shutdown, and High Flux Due to Rod Withdrawal at Startup. The Perry IPE analysis considers that a more refined transient categorization would include the classification of reactor power level for each applicable category. The transfer from startup or shutdown operation to power operation was selected to be at 12% reactor power. 12% reactor power corresponds to the limiting reactor power level when the reactor mode switch is placed in "run" during startup operation. As the IPE specifically excludes consideration of initiating events other than those which occur at power, no further investigation was made of events below 12% power.

3.1.1.1.2 LOCAS

Loss of Coolant Accidents (LOCAs) comprise one major class of initiating events. LOCAs are examined because they would cause a plant trip and could require emergency core cooling systems to operate.

A review was made of Probabilistic Risk Assessments (PRAs) performed for the Kuosheng Nuclear Power Station (AEC, 1985), Grand Gulf Nuclear Station (Drouin, 1989), and the General Electric 238 Nuclear Island (GESSAR II, GE, 1988). Kuosheng is a BWR/6-218 and Grand Gulf is a BWR/6-251.

Each of the studies examined at least three different break size ranges defined as Large LOCA, Intermediate LOCA, and Small LOCA. Vessel rupture was also included in each of the studies. LOCAs bypassing the containment were

addressed by the General Electric and Kuosheng PRAs. System interfacing LOCAs wore addressed by the Grand Gulf PRA (NUREG/CR-4550) and Kuosheng PRA. Grand Gulf included one LOCA not addressed in the other studies reviewed. A leak from the Recirculation pump seals was termed a Small-Small LOCA.

LOCA break sizes are determined by success criteria for the LOCA definitions provided below. The break sizes used by Kuosheng were determined through the use of General Electric (GE) NEDJ-24708A (GE, 198C) based on BWR/6-218 plants and calculations made by the computer code MARCH. The Grand Gulf break sizes were scaled up based on GE NEDO-24708A. GESSAR II used the GE licensing codes incorporating best estimate decay heat and modeling of core heat up to account for the steam cooling effects following core uncovery.

WE RE LOCA

arge LOCA (Type A) is defined as a break large enough such that the reactor vessel will depressurize and allow the low pressure injection systems to inject into the reactor vessel.

The Kuosheng study defined this as a break of greater than or equal to 0.3 sqft for both liquid and steam breaks as determined from GE NEDO-24708A and MARCH code calculations.

The Grand Gulf study took the data from the same GE report as Kuosheng but scaled the break size up based on a reactor vessel diameter of 251 inches. A break size of greater than or equal to 0.4 sqft was used by Grand Gulf for both liquid and steam breaks.

In the GESSAR II PRA, GE calculated the break sizes to be greater than or equal to 0.5 sqft for a liquid break and greater than or equal to 0.3 sqft for a steam break. This study was based on BWR/6-238 plants.

Since Perry is a BWR/6-238 model plant, break sizes of greater than or equal to 0.5 sqft for a liquid break and greater than or equal to 0.3 sqft for a steam break taken from the GESSAR II PRA will be used for a large LOCA.

Intermediate LOCA

An Intermediate LOCA (Type S1) is defined as a break large enough such that the Reactor Core Isolation Cooling system alone is not sufficient to mitigate the accident and not large enough to depressurize the reactor vessel to where the low pressure ECCS would inject into the reactor vessel.

The Ruosheng PRA used break sizer of between 0.005 and 0.3 sqft for liquid breaks and 0.1 to 0.3 sqft for steam breaks with an assumed Reactor Core Isolation Cooling (RCIC) system flow rate of 600 gpm.

The Grand Gulf study used data from the NEDO-24708A and scaled the break size up based on a reactor vessel diameter of 251 inches. Break sizes of between 0.007 to 0.4 sqf⁺ for liquid breaks and 0.13 to 0.4 sqft for steam breaks were used by Grand Gulf with an assumed RCIC flow rate of 825 gpm.

In the CESSAR II PRA, GE calculated the break sizes to between 0.01 to 0.5 sqft for a liquid break and 0.1 to 0.3 sqft for a steam break with an assumed

RCIC flow rate of 700 gpm.

Since Perr, is a BWR/6-238 model plant and has the same RCIC flow rate as that used in the GESSAR II PRA, break sizes of 0.01 to 0.5 sqft for a liquid break and 0.1 to 0.3 sqft for a steam break will be used for an intermediate LOCA.

Small LOCA

A Small LOCA (Type S2) is defined as a break small enough such that the Reactor Core Isolation Cooling system alone can maintain the core covered.

The Kuosheng PRA used break sizes of less than or equal to 0.005 sqft for liquid breaks and less than or equal to 0.1 sqft for steam breaks.

The Grand Gulf study used data from the NEDO-24708A and scaled the break size up based on a rector vessel diameter of 251 inches. Break sizes of less than or equal to 0.007 sqft for liquid breaks and less than or equal to 0.13 sqft for steam breaks were used by Grand Guif.

In the GESSAR II PRA, GC calculated the break sizes to be less than or equal to 0.01 sqft for a liquid break and less than or equal to 0.1 sqft for a steam break.

Since Perry is a BWR/6-238 model plant and has the same RCIC flow rate as that used in the GESSAR II PRA, break sizes of less than or equal to 0.01 sqft for a liquid break and less than or equal to 0.1 sqft for a steam break will be used for a small LOCA. The lower bound for a small LOCA will be taken to be the Technical Specification leakage from the reactor coolant system.

Small - Small LOCA

The Grand Gulf study considered a Small-Small LOCA (Type S3) defined as a recirculation pump seal leak. Although this type of LOCA is easily detected and isolated, because of its higher frequency, it was addressed. Leaks on the order of 50 to 100 gpm could occur on a per pump basis.

At Perry the recirculation pump seals are well instrumented and a seal leak would easily be detected. Applicable PNPP operating instructions list the recirculation pump seals as possible leakage sources. Operating instructions direct operators to trip and isolate the recirculation pump given a seal leak.

It is not expected that the Reactor Protection System would be activated due to the capability of the feedwater system to make up the leakage and the length of time it would take for the Drywell to pressurize sufficiently to reach the reactor scram setpoint.

From NUREG/CR-4550, Table 4.9-26, the mean probability of a Small-Small LOCA occurring is 3.0E-2. Table 4.9-25 provides a probability of failing to detect and isolate the leakage as 1.0E-2. Therefore, the probability that a Small-Small LOCA would exist and not le detected and isolated is 3.0E-4. The probability of a Small LOCA is given by Table 4.9-26 as 3.0E-3. Since the

Small-Small LOCA event is an order of magnitude less than the Small LOCA with the same outcome, event type S3 as defined by NUREG/CR-4550 will not be considered further.

Interfacing System LOCA

An Interfacing System LOCA (Type V) is defined as a break of a high pressure to low prensure interface with the primary system.

The Kuosheng PRA identified the following lines as susceptible to an interfacing LOCA: Low Pressure Core Spray injection line, Shutdown Cooling discharge line (A and B), Shutdown Cooling suction line, Low Pressure Coolant Injection lines (A, B, and C), and the Residual Heat Removal Head Spray line.

The Grand Gulf study identified the Emergency Core Cooling Systems' (ECCS) injection lings and the Reactor Water Cleanup system.

The GESSAR II PRA did not explicitly address the interfacing system LOCA event.

Perry will use the exclusion criteria described in NUREG/CR-5124 (Chu, 1989) as the basis for determining the lines susceptible to interfacing LOCAs. A review of the Perry design was performed with the following lines identified as potentially susceptible to interfacing LOCAs; MSIV Leakage Control lines (A, B, C, and D), RHR Head Spray line, Reactor Core Isolation Cooling suction line, RHR Steam Condensing suction lines, RHR Shutdown Cooling suction line, RHR Shutdown Cooling return lines (A and B), RHR Low Pressure Coolant Injection lines (A, B, and C), Low Pressure Core Spray injection line, Reactor Water Cleanup suction line, Standby Liquid control suction lines, and Feedwater pump suction lines.

Table 3.1.1-3 provides a list of values which must fail. Each of these values either receives a closure signal on line break, is normally closed or is a check value. the closure of any one of the values in each pathway will prevent high pressure fluid from challenging low pressure piping, thus preventing an interfacing LOCA. The frequency of these failures is evaluated in the data section.

Containment Eypass LOCAs

Containment Bypass LOCAs (Type 0) are all LOCAs occurring in high pressure portions of systems that result in the discharge of reactor coolant outside of the containment.

The Kuosheng PRA identified the following lines as potentially susceptible to initiating a LOCA that bypasses the Containment: Main Steam lines (A, B, C, and D), Feedwater lines (A and B), High Pressure Core Spray injection line, Main Steam to RCIC and RHR, and the Reactor Water Cleanup pump suction.

The Grand Gulf study did not explicitly model LOCAs bypassing the Containment as a separate group from Interfacing LOCAs. Several of the ECCS injection lines fall into the category defined by LOCA Bypassing Containment. A review of the Peiry design was made with the following lines identified as

being potentially susceptible to a LOCA that bypasses the containment: Main

Steam lines (A, B. C, and D), Main Steam Drain lines (A, b, C, and D), MSIV Leakage Control lines (A, B, C, and D), RCIC injection line, Main Steam to RCIC and RHR, Reactor Water Cleanup suction lines (A and B), Reactor Water Cleanup return lines (A and B), High Pressure Core Spray injection line, Standby Liquid Control injection lines (A and B), and Feedwater lines (A and B).

Table 3.1.1-4 identifies the valves which must fail. Each of these valves either receives a closure signal on line break, is normally closed or is a check valve. The closure of any one of the valves in each line up vill isolate a LOCA that bypasses containment.

Reactor Vessel Rupture

LOCAs from Reactor Vessel ruptures (Type R) can be divided into two categories. In the first category, the Reactor Vessel ruptures are of a size and in a location such that they are essentially equivalent to a large, intermediate, or small pipe break. This type is covered in the large, intermediate, and small LOCA initiators. In the second category the Reactor Vessel ruptures are greater than the size of a double-ended recirculation line break or are located in the region below the core shroud.

The above definition comes from the Grand Gulf study The Kuosheng and GESSAR II PRAs simply postulate a random Reactor Vessel rupture that exceeds the capability of the ECCS systems.

Perry will use the Grand Gulf definition with the location being top of the jet pump instead of below the core shroud. This provides a reflood of 2/3 core height capability.

3.1.1.1.3 Special Initiators

In addition to the evaluation of transient and LOCA initiator categories, a failure modes and effects analysis (FMEA), of support systems was conducted. The purpose of the FMEA was to identify special initiators unique to the PNPP design. A special initiator is defined as any internal initiating event which will:

 Cause a reactor scram.
 Is additionally capable of degrading an accident mitigation system required in response to the initiator.

The FMEA was divided into five categories addressing the loss of both safety and non-safety support systems. The scope of each category is defined below:

- Electrical Systems: (Safety and Non-safety)

13.8 KV Buses
4.16 KV Buses
480 VAC Buses
120 VAC Buses
125 VDC Buses
Air Systems: (Safety and Non-safety)

Page 3-6

- Instrument Air System (P52)
- Service Air System (P51)
- Safety Related Instrument Air System (P57)
- Water Systems: (Safety and Non-safety)
 - Service Water System (P41)
 - Emergency Service Water System (P45)
 - Nuclear Closed Cooling System (P43)
 - Emergency Closed Cooling System (P42)
 - Turbine Closed Cooling system (P44)
 - Turbine Building Chilled Water System (P46)
 - Control Complex Chilled Water System (F47)
 - Containment Vessel Chilled Water (P50)

- HVAC Systems: (Safety and Non-safety)

- Containment Vessel Cooling System (M11)
- Dryvell Cooling System (M13)
- ~ Controlled Access and Misc. Equip. Area HVAC (M21)
- MCC, Switchgear and Misc. Elec. Areas HVAC (M23)
- Battery Room Exhaust (M24)
- Control Room HVAC and Recirculation System (M25/M26)
- Computer Room HVAC (M27)
- Emergency (losed Cooling Pump Area Cooling (M28)
- ECCS Pump Poom Cooling system (M39)
- Steam Tunnel Cooling System (M47)
- Turbine Pover Complex Ventilation System (M42)
- Control Cabinets

Plant design information from the PNPF Off-normal Instructions (ONIs), System Operating Instructions (SOIs), Alarm Response Instructions (ARIs), P&IDs, Electrical One-line Diagrams, post scram reports, Licensee Event Reports (LERs) design calculations, System Description Manuals (SDMs), walkdowns and discussion with operations support personnel provided the basis for the evaluation. The evaluation process assumed the complete loss of each of subject support system. Plant response was characterized from the references described above.

Special Initiators Identified:

From this review the following special initiators were retained for further analysis:

- Loss of Instrument Air - Loss of Service Water

Loss of Instrument Air

Loss of Instrument Air would cause a plant scram through the dependency of multiple plant systems upon instrument air. A reactor scram would be expected due to the MSIV closure caused by loss of air, or on high water

level in the scram discharge volume (SDV) caused by drifting of the scram valves and the closure of the vent and drain valves.

The MSIVs will close on decreasing of pressure causing a loss of the Pover Conversion System (PCS). Loss of the Steam Jet Air Ejectors will also lead to a loss of the PCS. Due to various system dependencies the loss of instrument air will also lead to the loss of make-up air to the non-ADS SRVs, probable loss of feedwater flow, loss of the RHR steam condensing mode and loss of CRD as an alternate flow injection source.

For the non-ADS SRVs immediate operability will not be affected due to the accumulators which provide a source of backup air. The MSIVs are also backed up by accumulators. Feedwater flow is expected to be lost due to the lockup of the Hot Surge Tank level control valves, the failing open of the feedwater and feedwater booster pump recirculation valves and the lockup of the Motor Feedpump flow control valve. The CRD flow control valve will fail closed on loss of air causing a decrease in the drive water flow to the CRDs.

Based on the dependencies described above, the loss of instrument air meets the criteria to be considered as a special initiator.

Loss of Service Water

The loss of Service Water event will lead to the loss of Steam Tunnel Cooling event since Service Water provides the ultimate cooling source for the Steam Tunnel Cooling System. This results in a reactor scram on high steam tunnel temperature and MSIV closure. In addition RCIC isolation would occur after a delay of 30 minutes. A reactor scram would also be expected due to the loss of stator cooling water (turbine trip) or on a high drywell temperature due to loss of Drywell Cooling. A loss of feedwater and CRD flow would also be expected as both systems would be required to be manually shutdown due to loss of component motor bearing and/or lube oil cooling. The Service Air/Instrument Air compressors would also be expected to trip on high temperature. This event is treated as a special initiator.

Special Initiators Eliminated by Screening:

Through the process of the failure modes and effects (FMEA) analysis, several initiators which may have been considered for analysis in other PRAs or which may have initially appeared significant were eliminated. Such considerations are addressed below.

The review of plant electrical systems did not identify any bus loss which would meet the criteria established in this study for a special initiator. Electrical loads are distinctly separated between safety and non-safety loads. No single loss of a safety bus was identified which would cause a reactor scram. Additionally, loss of a safety bus would not cause more than the loss of one division of plant safety systems. Several non-safety buses were identified that would cause a reactor scram due to variety of plant responses. In fact some are documented by actual plant scrams. However, none were identified which would cause a loss of an accident mitigation system other than feedwater or the PCS. Each of these events are already identified as transient initiating events (T2 and T3B). The loss of Safety Related Instrument Air is not a special initiator. The only loads provided by this system are the ADS accumulators and one non-ADS SRV. Loss would not result in a reactor scram or the immediate loss of any accident mitigation system.

The loss of the various plant water systems identified only the loss of Service Water (P41) as a special initiator. Loss of the safety related service water systems, including Emergency Service Water (P45) and Emergency Closed Cooling (P42), were not included as special initiators as neither would cause a reactor scram upon system loss.


The HVAC systems were reviewed for special initiators. None vere retained. The loss of Control Room HVAC was reviewed, however it met neither of the two vriteria for special initiators. A review of engineering calculations dicated that under realistic analysis criteria (1.e., credit for heat sinks, realistic heat loads) that the control room heatup would remain below the control room qualification temperature of 120 degrees Fahrenheit, thus not challenging the capability of control room equipment. Additionally, the remote shutdown room, cooled by a separate HVAC system would be available to provide control capability to achieve safe shutdown.

The loss of the MCC, Switchgear and Miscellaneous Electrical Equipment Area HVAC was reviewed. Two redundant, divisionally separate loops, each with redundant fans, are available to individeally provide 100% room cooling. Assuming the loss of all cooling, no interaction was identified which would cause a reactor scram or requirement for immediate shutdown. Additionally, engineering calculations indicated a very long time lag (>24 hrs)prior to any exceedance of equipment temperature qualification limits. It is assumed that corrective action could be taken prior to any potentially significant equipment loss.

The loss of Control Complex Chilled Vater (CCCW) does not meet the specific criteria of a special initiator since no immediate automatic or m rul scram is expected or required. However, due to a Technical Specification requirement for plant shutdo a within six hours upon the loss of Control Room HVAC (which is a load supplied by CCCW) this event will lead to reactor shutdown. However recent analysis has confirmed that the Switchgear room heatup will not lead to loss of functioning equipment, therefore all ECCS will be available and this event does not need to be treated as a special initiator.

The failure modes and effects analysis (FMEA), included a limited look at control cabinets to identify any potential special initiators. The review scope and criteria included the following:

- -Only Control Room cabinets were reviewed, excluding the "horseshoe control panels.
- -Each cabinet was reviewed to ensure that each cabinet was either divisionally separated or that it controlled only one plant "function". Examples of plant functions include, RPV level control, RPV Pressure control, HVAC, etc.



dravings.

The results of this analysis indicated that all cabinets were either divisionally or functionally separated. No special initiators were identified.

3.1.1.2 Initiating Events - Grouping

The process for transient identification was described in section 3.1.1.1 and the results are provided in Table 3.1.1-5. Each of these transients were reviewed and grouped according to plant response. This grouping reduces the total number of events which must be individually analyzed, while retaining the detail of the individual events. Table 3.1.1-5 identifies the criteria and rationale for grouping each of the transient events identified in Table 3.1.1-2 into the final initiating event group.

By comparison to NUREG/CR-4550, several of the transients which for Grand Gulf were categorized as transients with loss of PCS (T2), were recategorized as loss of feedwater transients (T3B) for Perry. This is due to the Perry specific design which causes a trip of the RFP turbines on a high RPV water level (L8).

By their definition LOCA, special initiators and internal flooding each has a unique plant response. No grouping of time initiators is required or possible.

3.1.2 FRONTLINE EVENT TREES

This section discusses the development of event trees for each initiating event as identified in section 3.1.1 of this report (see Table 3.1.1-1) and the acceptance criteria used to define success or failure in a given function to prevent core damage following an initiating event and the front line and support systems which will perform those functions.

3.1.2.1 Acceptance Criteria

Fuel Boundaries

In the IPE we are concerned with two levels of modeling, the identification of core damage, and the risk posed by the release of fission products following core degradation and melting. For the core damage analysis the conditions defined are very similar to that defined in the Grand Gulf study (NUREG/CR-4550). For Perry, core damage is defined as exceedance of any of the fuel boundary criteria in the USAR or an occurrence of significant core uncovery such that the water level talls below -112 inches and there is no expectation of imminent reflooding of the core. As the bottom of the active fuel is at -150 inches this is slightly higher that that defined in the Grand Gulf study (24 inches above its bottom of the active fuel). However the timing difference between reaching the level of -112 compared with -126 is so small that this will make negligible difference to the assessed core damage frequency. The result in both cases is prolonged uncovery of the core which leads to damaged fue? and an expected release of fission products.

Reactor Coolant Boundary

The acceptance criteria for maintaining integrity of the reactor coolant boundary is based on not exceeding the corresponding American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code Level C service limit stress criterion during any transient. The number of safety relief valves required to open for a given event is based on this criterion.

Containment Building Integrity

Analysis performed by Gilbert Commonwealth (G/C, 1992) showed that the Containment Capacity Threshold Limit (i.e. a 1 percent probability of containment failue) for the Perry containment is 50 psig. This has been taken as the basis for the timing of the requirement of long term containment heat removal.

System Acceptance Criteria

Besides the above overall acceptance criteria, there are also specific acceptance criteria for components and systems. Two of them which have an influence on the construction of the event and fault trees and the development of the success criteria are:

- 1. Pumped fluid temperatures for pumps connected to the suppression pool.
- 2. Maximum ambient temperature for all safety equipment.

The first of these is addressed in developing the various event trees for initiating events which are going to result in injection systems taking suction from the suppression pool and the second in evaluating the performance of each system in response to the various initiating events.

3.1.2.2 Front Line and Support Systems

The basic requirements for prevention of core damage and prevention or mitigation of the release of fission products can be divided into the following four functions.

- 1. Reactivity Control
- 2. Reactor Coolant System Overpressure Protection
- 3. Emergency Core Cooling
- 4. Containment Overpressure Protection and Fission Product Control.

For a given accident initiating event the systems that directly perform one or more of these functions are defined as front line systems. Support systems are those that affect the course of the sequence only by means of their effect on the operation of a front line system. The list of front line and support systems is given in Table 3.1.2-1 and the dependency between them in Table 3.1.2-2. The dependency of some support systems on other support systems is shown in Table 3.1.2-1. The level of support varies from dependency to dependency. For example, cooling dependency is continuous. But power may only be required for a very short period of time when system initiation is required. Room cooling may only be required when a system is operating and the system may be able to operate for an extended period of time without room cooling. These requirements are identified in the development of the event and fault trees.

3.1.2.3 Event Tree Development

The event tree model is the central analytical tool used in the determination of the frequency of core damage, and the various ways in which it can occur. As the principles of its development are well documented in the PRA Procedures Guide (NRC, 1983), and the Interim Reliability Evaluation Program Procedures Guide (NRC, 1982a), they are not described in detail in this report. Some discussion is, however, provided on those aspects of the development of the event trees that are specific to the present study.

The initiating event task defined the LOCA and transient initiating events, grouped according to the major functions required to prevent core damage.

The first task in the development of the event tree is to define the frontline system requirement to meet the acceptance criteria for each of the functions defined in section 3.1.2.2. The second task is to identify the impact of the initiating event on the frontline or support systems required to perform each of the functions.

The most important aspect of developing the event trees from the above information is to reflect the inherent functional and physical dependencies between each phase of the sequence, and at the same time, the interaction between operators and systems as the sequence unfolds. Thus the event tree is developed by first considering those functions (reactivity control, overpressure protection) that are required early, and then those which are required in the long term. In this way, it is relatively straight forward to model dependencies between functions. For example, in the case of a large LOCA, injection is required immediately. If injection fails, it will not be necessary to consider long term containment heat removal in the context of core damage, although it will be considered later in terms of the impact of its loss on long term containment integrity. This is discuted in section 3.1.4.

Operator interactions, such as cooling down and depressurizing the RPV when called for in the emergency procedures, by use of the ADS either in the automatic or manual mode, are specifically identified, so that the relationship between the success or failure of the operators interaction can be clearly identified.

Finally, it will be noted that for initiating events that are not related to loss of a support system, the event tree addresses only systems which perform the functions identified in Section 3.1.2.2. The dependency of each of these systems on the various support systems is developed in the analysis of individual systems. In the case of loss of a support system, such as loss of offsite power, recovery of the support system is included in the event trees. The results of this phase of the study are the identification of the individual core damage sequences, and the detailed analysis requirements for determining the timing and progression of each accident sequence. The timing is required in order to evaluate the impact of the operator actions, and the time of occurrence of the automatic systems initiation signals. The front line event trees described in this section are for the following initiating events.

Transients involving loss of feedwater, but with the Power Conversion System initially availabl Large Loss of Coolant Accident Intermediate Loss of Coolant Accident Small Loss of Coolant Accident	able	T3A T3B A S1 S2	
---	------	-----------------------------	--

3.1.2.4 TRANSIENT WITH A LOSS OF PCS EVENT TREE

3.1.2.4.1 General Description

Transients with a loss of the Power Conversion System (PCS) are defined as class T2 transients, consistent with the nomenclature utilized in NUREG/CR-4550.

The T2 transient is characterized by the occurrence of an event or action which causes a loss of the PCS. A plant scram due to a MSIV isolation or a loss of condenser vacuum are examples of such a transient.

Table 3.1.1-5 identifies the EPRI classified transients which comprise this transient category.

For the purpose of this analysis, the PCS is defined as the main steam system, the turbine bypass system, the main condenser and its primary supporting systems, (i.e., Circulating Water System, the Steam Jet Air Ejectors, etc.).

3.1.2.4.2 Success Criteria

Success criteria for the loss of PCS transient is listed in Table 3.1.2-4. The incorporation of these success criteria into the event tree is discussed in the following section.

3.1.2.4.3 Event Tree

The event tree for this transient is provided on Figure 3.1.2-1 sheets 1-3. Heading definitions are provided below in the approximate chronological order that would be expected following a transient with a loss of PCS.

- T2 A less of PCS transient occurs which disrupts the normal operation of the ant and requires mitigation.
- C Success or failure of RFV reactivity control with RPS automatic or manual scram or ARI. Success implies that a sufficient number of control rods have inserted into the core to provide a shutdown rod pattern. Thus, a successful reactor scram has occurred. Failure implies the rods have not inserted to a subcritical rod configuration. Failure sequences transfer to the ATWS event tree.

Success or failure of RFV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, one failed to reclose. Failure sequences are developed in a transfer event tree. The sizing of the SRVs is such that one open SRV results in leakage and depressurization of the RPV at the same rate as in the small LOCA. The success criteria is the same as the small loCA and the event tree (Sheet 2) is developed accordingly.

P1

X

- P2 Success or failure of RPV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, two failed to reclose. Failure sequences are developed in a transfer event tree. The sizing of the SRVs is such that two open SRVs results in leakage and depressurization of the RFV at the same rate as the intermediate LOCA. The success criteria is the same as for an intermediate LOCA and the event tree (Sheet 3) is developed accordingly.
- U3 Success or failure of RPV level control with the Motor Feedpump. Success implies that the Motor Feedpump (MFP) is manually initiated by the plant operators and adequate RPV level control is maintained. Failure implies that the Motor Feedpump could not be, or was not started such that RPV level control cannot be maintained with the MFP.
- U2 Success or failure of RPV level control with the RCIC system. Success implies that either RCIC automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. It further implies that long-term containment heat removal with RHR in Suppression Pool Cooling mode successfully maintains containment conditions for long-term operability of RCIC. Failure implies that RCIC is not maintaining RPV level control or that long-term containment heat removal is not maintained, resulting in the loss of RCIC.
- UI Success or failure of RPV level control with the HPCS system. Success implies that either HPCS automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS.
 - Success or failure of emergency RPV depressurization. Success implies that the ADS was automatically or manually initiated or that the operator manually depressurized the vessel with at least 4 SRVs. Failure implies that ADS failed and that the operator failed to manually emergency depressurize with the required number of SRVs causing the reactor vessel to remain at a higher pressure than that required by the PNPP Plant Emergency Instructions (PEIs) for successful RPV level control with low pressure injection.
- V Success of failure of RPV level control with the ECCS low pressure make-up systems. Success implies that, at a minimum, LPCS or one loop of LPCI either auromatically initiated or was manually placed in service and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained by an ECCS low pressure injection system.

Success or failure of RPV level control with the Condensate Transfer Alternate Injection alignment. Success implies, that the CTS alternate injection alignment was manually started by the plant operators and that the alignment successfully provided RPV level control. Failure implies that CTS alternate injection was not aligned or that it was unable to maintain RPV level control.

Success or failure of long-term containment heat removal with RHR to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that long-term heat removal can be achieved by at least one of the following modes of RHR. Failure implies that no long-term containment heat removal mode of RHR was aligned or that pressure caurot be maintained below the Containment Capacity Threshold Limit.

U One RHR train in Suppression Fooling Cooling mode.

o One RHR train in the Containment Spray mode.

Success or failure of long-term containment heat removal by venting of the containment. Success implies that one of the below listed venting paths were aligned, per the PEIs, prior to containment pressure exceeding the Containment Capacity Threshold Limit of 50 psig and that the aligned path maintains pressure below that limit. Failure implies that no path was successfully aligned or that the Containment Capacity Threshold Limit was exceeded.

- o Fuel Pool Cooling and Cleanup System. Manual alignment of vent path through the fuel pool skimmers into the Fuel Handling Building.
- o RHR Containment Spray Loop / or B. Manual alignment of vent path through the containment spray header into the Fuel Handling Building.

Defines the susceptibility of the core to damage, dependent upon containment conditions. Success implies that given containment failure, the core is still maintained in a safe configuration. Failure implies that the containment failure has led to a degradation of plant systems such that the core is susceptible to damage. The evaluation of this function is discussed in Section 4.4.

The development of the functional fault tree for each of these functions with the appropriate system boundary conditions defined by the initiating event is described in Appendix E.

3.1.2.5 TRANSIENT WITH PCS AVAILABLE EVENT TREE

3.1.2.5.1 General Description

Transients with the Power Conversion system (PCS) available are defined as class T3A transients, consistent with the nomenclature utilized in NUREG/CR-4550.

For the purpose of this analysis, the PCS is defined as the main steam system, the turbine bypass system, the main condenser and its primary



Y

CV

Va

supporting systems. (i.e., Circulating Water System, the Steam Jet Air Ejectors, etc.)

The T3A transient is characterized as a "typical" plant scram (i.e., all systems and functions are potentially available to respond to the transient, including the feedwater system and the PCS).

Table 3.1.1-5 identifies the EPRI classified transients which comprise this transient class. Plant scrams due to a turbine trip or manual scram are examples of such a transient.

3.1.2.5.2 Success Criteria

Success criteria for the PCS available transient (T3A) is listed in Table 3.1.2-5. The incorporation of these success criteria into the event tree is discussed in the following section.

3.1.2.5.3 Event Tree

The event tree for this transient is provided on Figure 3.1.2-2 Sheets 1-3. Heading definitions are provided below.

- T3A A transient with PCS available occurs which disrupts the normal operation of the plant and requires mitigation.
- Q success or failure of the PCS to remain available. Success implies that the PCS is available to provide RPV pressure control and to remove decay heat from the RFV for 24 hours following the initiation of the transient. Failure implies that it is not available. This transfers to the transient with loss of PCS event tree.
- U3 Success or failure of RPV level control with the Feedwater system. Success implies that one of two Reactor Feedpumps (RFFs) or one Motor Feedpump (MFP) started or continued to run and provided successful RPV level control. Failure implies that the feedwater system could not maintain RPV level control.
- Ul Success or failure of RPV level control with the HPCS system. Success implies that either HPCS automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS. As PCS is available, no containment heat removal is required following successful HPCS operation.

The remaining functions C, P1, P2, U2, X, V, Va, V, Y, and Cv are as described above in the previous section for the T2 transient. The development of the functional fault trees for each of the functions with the appropriate boundary conditions is described in Appendix E.

3.1.2.6 LOSS OF FEEDWATER TRANSIENT LVENT TREE

3.1.2.6.1 General Description

Transients with a loss of feedwate: are defined as class T3B transients,

consistent with the nomenclature of NUREG/CR-4550.

The T3B transient is characterized as a transient with the Power Conversion System (PCS) available, further characterized by the loss of the feedwater system.

For the purpose of this analysis, the loss of feedwater is defined as loss of the two normally operating Reactor Feedpumps (RFPs). The Motor Feedpump (MFP) is assumed to be able to be recovered by operator action. The Reactor Feedwater Booster Pumps and the condensate system are assumed available to support Mir operation for this transient.

The complete loss of feedwater (including the loss of the MFP) is modeled in the T3B event tree path in which recovery with the MFP has failed. (Failure of function U3, discussed below).

The PCS is defined as being available for this transient. The PCS is defined as the main steam system, the turbine bypass system, the main condenser and its primary supporting systems, (i.e., Circulating Water System, the Steam Jet Air Ejectors, etc.)

Table 3.1.1-5 identifies the EPRI classified transients which comprise this transient class.

3.1.2.6.2 Success Criteria

Success criteria for the loss of feedvater transient (T3B) is listed in Table 3.1.2-6.

3.1.2.6.3 Event Tree

The event tree for this transient is provided in Figure 3.1.2-3. Heading definitions are provided below. As by definition the PCS remains available the SRVs are not challenged, therefore events P1, P2, are excluded from the tree.

- T3B A loss of feedwater transient occurs which disrupts the normal operation of the plant and requires mitigation.
- Q Success or failure of the PCS to remain available. Success implies that the PCS is available to provide RPV pressure control and to remove decay heat from the RPV for 24 hours following the initiation of the transient. Failure implies that it is not available.
- U3 Success or failure of RPV level control with the Motor Feedpump (MFP). Success implies that the MFP is manually initiated by the plant operators and adequate RPV level control is maintained. Failure implies that the Motor Feedpump could not be, or was not started such that RPV level control cannot be maintained with the MFP. As PCS is available, no containment heat removal is required following successful MFP recovery.
- U1 Success or failure of RPV level control with the HPCS system. Success implies that either HPCS automatically actuated at RPV level 2 or that





it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS. As PCS is available, no containment heat removal is required following successful HPCS operation.

The remaining functions C, U2, X, V, Va, V, Y and Cv are the same as those described in the T2 event tree in section 3.1.2.4. The development of the functional fault tree for each of these functions with the appropriate system boundary conditions defined by the initiating event is described in Appendix E.

3.1.2.7 LARGE LOCA EVENT TREE

3.1.2.7.1 General Description

The Large LOCA event is defined as a class A event, consistent with the nomenclature utilized in NUREG/CR-4550.

A large LOCA is defined as a break large enough such that the reactor pressure vessel (RPV) will depressurize without the assistance of Automatic Depressurization System (ADS) or the Safety Relief Valves (SRVs) and permit the low pressure injection systems to inject into the reactor vessel.

This event is expected to result in a rapid loss of RPV water inventory, resulting in a trip of the reactor and the main turbine generator (RPV level 3) and the loss of the power conversion system (PCS) due to closure of the Main Steam Isolation Valves (MSIVs), (KPV level 1).

Only Emergency Core Cooling Systems (ECCS) are in-diately available for injection of water into the RPV. The Reactor Core Isolation Cooling System (RCIC) is not available due to the absence of steam pressure to drive the RCIC turbine.

3.1.2.7.2 Success Criteria

The success criteria for a large lOCA is provided in Table 3.1.2-7.

Depressurization of the reactor vessel and closure of the MSIVs eliminates use of the turbine driven feedwater pumps as a source of water to the reactor vessel.

3.1.2.7.3 Event Tree

The event tree for this event is provided on figure 3.1.2-4. Heading definitions are provided below.

- A A large LOCA occurs which disrupts the normal operation of the plant and requires mitigation.
- C Success or failure of RPV reactivity control with RPS automatic or manual scram or ARI. Success implies that a sufficient number of control rods have inserted into the core to provide shutdown rod pattern. Thus, a successful reactor scram has occurred. Failure implies the rods have not inserted to a subcritical rod configuration.

Failure sequences transfer to the ATVS event tree.

Success or failure of RPV level control with the HPCS system. Success implies that either HPCS automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS.

Success or failure of RPV level control with the ECCS low pressure make-up systems. Success implies that, at a minimum, LPCS or one loop of LPCI either automatically initiated or was manually placed in service and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained by an ECCS low pressure injection system.

Success or failure of long-term containment heat removal with RHM to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that long-term heat removal can be achieved by at least one of the following modes of RHR. Failure implies that no long-term containment heat removal mode of RHR was aligned or that pressure cannot be maintained below the Containment Capacity Threshold Limit.

o One RHR train in Suppression "ool Cooling mode.

o One RHR train in the Containment Spray mode.

Success or failure of long-term containment heat removal by venting of the containment. Success implies that one of the below listed venting paths were aligned, per the PEIs, prior to containment pressure exceeding the Containment Capacity Threshold Limit of 50 psig and that the aligned path maintains pressure below that limit. Failure implies that no path was successfully aligned or that the containment limit was exceeded.

- o Fuel Pool Cooling and Cleanup System. Manual alignment of vent path through the fuel pool skimme s into the Fuel Handling Building.
- o P.HR Containment Spray Loop A or B. Manual alignment of vent path through the containment spray header into the Fuel Handling Building.
- Cv Defines the susceptibility of the core to damage, dependent upon containment conditions. Success implies that given containment failure, the core is still maintained in a safe configuration. Failure implies that the containment failure has led to a degradation of plant systems such that the core is susceptible to damage.

The vacuum breakers are normally closed motor operated values so as in the case of the Grand Gulf study the potential for suppression pool bypass was omitted from the event.

Calculations were performed to determine if suppression pool make up was required to provide vapor suppression, i.e. to maintain the containment pressure below the containment failure pressure. It was established that

01

V

cuppression pool make-up is not required either to maintain pump NPSH or prevent vortex limits to be exceeded. It was also shown that containment design pressure would not be exceeded. These analyses are reported in the analysis files developed for this task.

The development of the functional fault trees for each of the functions with the approximate system boundary conditions defined by the initiating event and subsequent system successes or failures is described in Appendix E.

3.1.2.8 INTERMEDIATE LOCA EVENT TREE

3.1.2.8.1 General Description

The intermediate LOCA event is defined as a class S1 event, consistent with the nomenclature utilized in NUREG/CR 4550.

An intermediate LOCA is defined as a break large enough such that the Reactor Core Isolation Cooling (RCIC) alone is not sufficient enough to mitigate the accident and not large enough to depressurize the reactor vessel to where the low pressure ECCS would inject into the RPV.

This event is expected to result in a rapid loss of RPV water inventory, resulting in a trip of the reactor and the main turbine generator (RPV level 3) and the loss of the PCS due to closure of the Main Steam Isolation Valves (MSIVs), (RPV level 1).

Only Emergency Core Cooling Systems (ECCS) are immediately available for injection of water into the RPV. RCIC capacity is defined as insufficient for the event.

3.1.2.8.2 System Success Criteria

System Success Criteria for an Intermediate LOCA are listed in Table 3.1.2.8.

During an Intermediate LOCA the condensate/feedwater systems would attempt to maintain water level in the reactor vessel but would be unable to do so prior to a reactor scram. Eventually a trip of the reactor and the main turbine generator would be received and the loss of PCS due to a closure of the Main Steam Isolation Valves would be experienced. Depressurization of the reactor vessel by means of the Main Steam Safety Relief Valves is necessary for the operation of the low pressure systems to mitigate the accident. Alternate injection from Condensate Transfer Alternate Injection alignment will provide adequate low pressure injection.

3.1.2.8.3 Event Tree Heading Definition

The event tree for this event is provided on Figure 3.1.2-5. Heading definitions are provided below.

- S1 An intermediate LOCA occurs which disrupts the normal operation of the plant and requires mitigation.
- X Success or failure of emergency RPV depressurization. Success implies that the ADS was automatically or manually initiated or that the

operator manually depressurized the vessel with at least 2 SRVs. Failure implies that ADS failed and that the operator failed to "nually emergency depressurize with the required number of SRV causing the reactor vessel to remain at a higher pressure than that required by the PNPF Flant Emergency Instructions (PEIs) for successful RPV level control with low pressure injection.

Va Success or failure of RPV level control with the Condensate Transfer Alternate Injection alignment. Success implies, that the CTS alternate injection alignment was manually started by the plant operators and that the alignment successfully provided RPV level control. Failure implies that CTS alternate injection was not aligned or that it was unable to main ain RPV level control or that the ESW cross tie was not used.

The remaining functions C, U1, V, V, 1, and Cv are the same as those described in the previous section for the type A event tree.

The vapor suppression function is not modeled as calculations performed to determine if it was necessary showed that suppression pool make-up would not be required. This is summarized in the analysis files for this task.

The development of the functional fault trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating event and preceding function success or failures is described in Appendix E.

3.1.2.9 SMALL LOCA EVENT TREE

3.1.2.9.1 General Description

The small LOCA event is defined as a class S2 event, consistent with the nomenclature utilized in MUREG/CR-4550.

The small LOCA event is defined as a break small enough such that the RCIC system alone can maintain the core covered. However, the break is defined as larger in size than that which would be handled in an orderly plant shutdown. A small LOCA will not depressurize the reactor vessel fast enough, without the assistance of the SRVs, to prevent uncovery of the zore before the low pressure systems inject into the vessel.

The event is expected to cause only minor perturbation to the RPV water level. The capacity of feedwater system is more than sufficient to make-up the intervention ory loss due to the break. However, automatic reactor scram is explose to a high dryvell pressure or due to low RPV water level 13), if feedwater fails to provide level control.

3.1.2.1 System Success Criteria

System success criteria for a Small LOCA are listed in Table 3.1.2.9.

During a Small LOCA the condensate/feedwater systems can maintain water level in the reactor essel prior to a reactor scram. Eventually a trip of the reactor and test ain turbine generator would be received and the loss of PCS due to a received of the Main Steam Isolation valves would be experienced. RCIC and HPCS inject into the vessel to recover reactor vessel level. Depressurization of the reactor vessel by means of the Main Steam Safety Relief Valves is necessary for operation of the low pressure systems to mitigate the accident. An alternate source of water is the Condensate Transfer Alternate Injection.

3.1.2.?.3 Event .ree

The event tree for this event is provided on Figure 3.1.2-6. Heading definitions are provided below.

- S2 A small LOCA occurs which discupts the normal operation of the plast and requires mitigation.
- U3 Success or failure of RPV level control with the feedwater system. Success implies that one of two Reactor Feedpumps (RFPs) or one Motor Feedpump (MFP) starts or continues to run and provide successful RPV level control. Failure implies that the feedwater system cannot maintain RPV level control.
- U2 Success or failure of RPV level control with the RCIC system. Success implies that either RCIC automatically actuates at RPV level 2 or that it is manually actuated and is providing adequate RPV level control. It further implies that long-term containment heat removal with RHR in Suppression Pool Cooling mode successfully maintains containment conditions for long-term operability of RCIC. Failure implies that RCIC is not maintaining RPV level control or that long-term containment heat removal is not maintained, resulting in the loss of RCIC.
- X Success or failure of emergency RPV depressurization. Success implies that the ADS was automatically or manually initiated or that the operator manually depressurized the vessel with at least 3 SRVs. Failure implies that ADS failed and that the operator failed to manually emergency depressurize with the required number of SRV causing the reactor vessel to remain at a higher pressure than that required by the FNPP Plant Emergency Instructions (PEIs) for successful RPV level control with low pressure injection.
- Va Success or failure of RPV level control with the Condensate Transfer Alternate Injection alignment. Success implies, that the CTS alternate injection alignment was manually started by the plant operators and that the alignment successfully provided RPV level control. Failure implies that CTS alternate injection was not aligned or that it was unable to maintain RPV level control or the ESW cross tie.

The remaining functions C, U1, V, V, Y and Cv are the same as those described in the type A event tree in section 3.1.2.7.

For the small LOCA, failure of the Vapor Suppression stem was considered to be a very low frequency event and therefore not included in the event tree. With a small LOCA, the RPV will not immediately depressurize and only a high pressure system would be operating. Flow would be "imited by the break size. Drawdown of the suppression pool would not occur quickly and even if all high pressure systems fail multiple low pressure systems are available to provide

water from external sources.

The development of the functional sult trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating event and proceeding function success or failures is described in Appendix E.

3.1.3 SPECIAL EVENT TREES

The definition of the Acceptance Criteria and methodology for developing the event trees is described in section 3.1.2.3. The same criteria and methodology is used to develop the event trees for the following special initiating events.

Loss of Offsite Pover and Station Blackout	(T1/B)
Transient with Inadvertent Open Relief Valve	(T3C)
Loss of Instrument Air	(TIA)
Loss of Service Air	(TSV)
Anticipated Transient Without Scram	(ATWS)

No event trees have been developed for initiating events

Interfacing Containment Vessel Ruptu	Bypass	Pressure	System)	LOCA	(V) (0)
					(K)

Each of these events for which a tree has been developed are discussed in the following section.

3.1.3.1 LOSS OF OFFSITE POWER EVENT TREE

3.1.3.1.1 General Description

loss of offsite power transients are defined as class T1 transients, onsistent with the nomenclature utilized in NUREG/CR-4550.

Offsite AC power is normally supplied from the 345 kV grid. The onsite emergency diesel generators are designed to supply AC power to the Engineered-Safety-Features (ESF) systems in the case of failure of all offsite power.

A loss of offsite power causes a trip of the reactor and the main turbine generator and the loss of the PCS due to the closure of the main steam isolation valves. Only Emergency Core Cooling Systems (ECCS) and the Reactor Core Isolation Cooling (RCIC) System are immediately available for injection. Alternate injection can be provided by the diesel driven fire pump prior to restoration of offsite power. Other alternate injection alignments can be provided from additional systems only then the offsite power is restored.

The Perry plant has three electrical divisions. Division 1 provides power for the LPCS system and to Loop A of the RHR system, and is essential for long-term power to the DC power system, which provides control power for RCIC. Division 2 provides power for the remaining two loops of the RHR system, and Division 3 is dedicated to the HPCS system. If the Division 1 and 2 diesel generators fail to start or fail while running before offsite

power is restored, station blackout occurs.

3.1.2.1.2 Success Criteria

Success criteria for Loss of Offsite Power is listed in Table 3.1.3-1.

The condensate/feedvater pumps have not been included in the Emergency Core Cooling success criteria upon power recovery, due to water hammer concerns on system restart. For a Hotwell pump start, the discharge valve is required to be manually throttled down. After the initial recovery portion of the event, the operators would be reluctant to start a Reactor Feedwater Booster Fump due to the potential for voiding in the feedwater header.

3.1.2.1.3 Event Tree

The event tree for this transient is provided on Figure 3.1.3-1 Sheets 1-6. Heading definitions are provided below.

- T1 A loss of offsite power transient occurs which disrupts the normal operation of the plant and requires mitigation.
- C Success or failure of RPV reactivity control with RPS automatic or manual scram or ARL. Success implies that a sufficient number of control is have inserted into the core to provide shutdown rod pattern. Thus, a successful reactor scram has occurred. Failure implies the rods have not inserted to a subcritical rod configuration. Failure sequences transfer to the ATWS event tree.
- P1 Success or failure of RPV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, one failed to reclose. This is equivalent to a small LOCA and is developed on Sheet 4.
- P2 Success or failure of RFV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, one failed to reclose. This is equivalent to an intermediate LOCA event and is developed on Sheet 6.
- B1 Success or failure of onsite emergency power to either the division 1 or division 2 buses. Success implies that one or both buses are available and supplying power to their respective loads. Failure implies that both buses fail and that power is not being supplied to division 1 and division 2 loads. This transfers to the station blackout event tree.
- Ul Success or failure of RPV level control with the HPCS system. Success implies that either HPCS automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS.
- U2 Success or failure of RPV level control with the RCIC system. Success implies that either kCIC automatically actuated at RPV level 2 or that

it "as manually actuated and is providing adequate RPV level control. It further implies that long-term containment heat removal with RHR in Suppression Pool Cooling mode successfully maintains containment conditions for long-term operability of RCIC. Failure implies that RCIC is not maintaining RPV level control or that long-term containment heat removal is not maintained, resulting in the loss of RCIC. έđ

Recovery or nonrecovery of offsite power. Recovery of offsite power implies that offsite power was recovered and all safety related and non-safety related buses have power. Nonrecovery implies that offsite power was not recovered.

Upon failure of HPCS ad success of RCIC, R1 is based on recovery in 3.3 hours. Upon failure of both HPCS and RCIC, R1 is based on recovery in 0.4 hours. For failure of both HPCS and RCIC and one stuck open relief value, R1 is based on recovery in 0.26 hours.

- Vs Success or failure of maintaining the suppression pool less than 185°F. Success implies that at least one train of RHR is in operation in the suppression pool cooling mode. Failure implies that the suppression pool could not be maintained below 185°F.
- X Success or failure of emergency RPV depressurization. Success implies that the ADS was automatically or manually initiated or that the operator manually depressurized the vessel with at least 4 SRVs. Failure implies that ADS failed and that the operator failed to manually emergency depressurize with the required number of SRV causing the reactor vessel to remain at a higher pressure than that required by the PNPP Plant Emergency Instructions (PEIs) for successful RPV level control with low pressure injection.
 - Success or failure of RPV level control with the ECCS low pressure make-up systems. Success implies that, at a minimum, LPCS or one loop of LPCI either automatically initiated or was manually placed in service and is providing adequate RPV level control. Failure implies that RFV level control cannot be maintained by an ECCS low pressure injection system.
- Hv Initial analysis indicated that switchgear room cooling was required to prevent breaker failure. Recent analysis showed that this was not the case. The function is still in the event tree but the probability of failure is set to zero and success to one.
- R2 Success or failure of the ability to recover offsite power. Success implies offsite power is recovered. Failure implies that offsite power was not recovered within the following time frames.

With success of HPCS, R2 is based on failure to recover in 12 hours. Following failure of EPCS, F2 is based on failure to recover in 4 hours.

X2 Success or failure of e. : enc: RPV depressurization. Success implies that the ADS was au smaller or manually initiated or that the operator manually depressurized the vessel with at least 4 SRVs.

R1

V.

Failure implies that ADS failed and that the operator failed to manually emergency depressurize with the required number of SRV causing the reactor vessel to remain at a higher pressure than that required by the PNFP Plant Emergency Instructions (PEIs) for successful RPV level control with low pressure injection. This event occurs much later than X above as it follows failure of high pressure injection after failure of the room cooling (Hv).

Success or tailure of RPV level control with the alternate low pressure injection systems. Success implies that either the alternate injection mode of the condensate transfer system or the fire protection system crosstie to ESW B and RHR B was manually placed in service and is maintaining RPV level control. If offsite power is not available the only alternate injection system modeled is the fire protection system. Failure implies that RPV level control cannot be maintained by either the condensate transfer system or the fire protection system.

Success or failure of long-term containment heat removal with RHR to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that long-term heat removal can be achieved by at least one of the following modes of RHR. Failure implies that no long-term containment heat removal mode of RHR was aligned or that pressure cannot be maintained below the Containment limit.

o One RHR train in Suppression Pool cooling mode.

o One RHR in the Containment Spray mode.

Va

v

Y

Success or failure of long-term containment heat removal by venting of the containment. Success implies that one of the below listed venting paths were aligned, per the PEIs, prior to containment pressure exceeding the Containment Capacity Threshold Limit of 50 psig and that the aligned path maintains pressure below that limit. Failure implies that no path was successfully aligned or that the containment limit was exceeded.

- o Fuel Pool Cooling and Cleanup System. Manual alignment of vent path through the fuel pool skimmers into the Fuel Handling Building.
- o RHR Containment Spray Loop A or B. Manual alignment of vent path through the containment spray header into the Fuel Handling Building.
- Cv Defines the susceptibility of the core to damage, dependent upon containment conditions. Success implies that given containment failure, the core is still maintained in a safe configuration. Failure implies that the containment failure has led to a degradation of plant systems such that the core is susceptible to damage.

The development of the functional ault trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating event and preceding success or failures is described in Appendix E.

3.1.3.2 STATION BLACKOUT EVENT TREE

3.1.3.2.1 General Description

The loss of offsite power transients which are further compounded by the failure of both emergency AC Divisions 1 and 2 which supply electric power to the safe shutdown RHR sys.ems are defined as station blackout (SBO). sequences.

Station Blackout sequences are defined as "B" sequences, consistent with the nomenclature utilized in NUREG/CR-4550.

Multiple plant instructions address the station blackout event at Perry. In addition to the BWR Owners Group EPG Revision 4 based Perry Plant Emergency Instructions (PEIs), off-normal instruction, ONI-R10, Loss of AC Power provides scenario specific plant ins...uctions.

A station blackout event is initiated by the occurrence of r loss of offsite power and the subsequent less of both Division 1 and Division 2 diesel generators. The Power Conversion System (PCS), is lost due to the closure of the Main Steam Isolation Valves (MSIVs). All ECCS systems are immediately lost, with the exception of the Division 3 diesel generator backed High Pressure Core Spray (HECS) System and the AC independent Reactor Core Isolation Cooling (RCIC) System. Alternate injection with the diesel driven Fire Water pump is also available.

Upon the loss of motive power caused by a Station Blackout, the containment AC motor-operated isolation valves will remain in the normal plant lineup. in most capes this is insignificant as the open penetrations lead to closed systems outside containment. The upper containment fuel pool return line penetration is not automatically isolated under 530 conditions and thus provides a containment vent path. however the operators are procedurally directed to close this penetration.

The containment 'r operated isolation valves generally reposition in the closed position ollowing the loss of power: however, air-operated inboard MSIV before seat normal 3rain valve, 1813-F033, does not close and provides a pathway from the reactor vessel to the low pressure condenser through a one inch line. This line is isolated by the operators during a station blackout by closing 1B21-F019. The front end analysis will assume that this manual isolation is always completed.

3.1.3.2.2 Success Criteria

The success criteria for station blackout is listed in Table 3.1.3-2.

3.1.3.2.3 Event Tree

The event tree for the station blackout event is provided on Figure 3.1.3-2 Sheets 1-3. Heading definitions are provided below.

A loss of offsite power transient occurs with a subsequent failure of onsite Division 1 and 2 power (Station Blackout) such that no AC power is available. Initial mitigation is only possible with HPCS and RCIC.



8

- BP1 A loss of offsite power transient occurs with a subsequent failure of onsite Division 1 and 2 power (Station Blackout) such that no AC power is available. In addition, one SRV is stuck open. Initial mitigation is only possible with HPCS and RCIC. Failure of HPCS and RCIC is assumed to lead to core damage.
- BP2 A loss of offsite power transient occurs with a subsec ont failure of onsite Division 1 and 2 power (Station Blackout) such t no AC power is available. In addition, two SRVs are stuck open. Initial mitigation is only possible with HPCS. Failure of HPCS is assumed to lead to core damage.
- Ul Success or failure of the HPCS system. Success implies that either FTCS automatically actuated at level 2 or that it was manually actuated and is maintaining coolant make-up into the reactor vessel. Failure implies that HPCS is not maintaining cool nt make-up.
- HI Success or failure of operator to take action to extend HPCS operation. Success implies that the operators crossile the Unit 1 and Unit 2 L batteries enabling HPCS to provide injection for the complete mission time. Failure implies that this was not successfully completed and that HPCS injection fails.
- U2 Success or failure of the RCIC system. Success implies that either RCIC automatically actuated at Level 2 or that it was manually actuated and is maintaining coolant make-up into the reactor vessel until its limiting system parameter is reached. Failure implies that RCIC is not maintaining coolant make-up for its defined mission time.
- Va Success or failure of the diesel-driven fire water pump. With success of RCIC upon the suppression pool temperature reaching 185°F the operators are instructed to depressurize the RPV. Given a failure to depressurize, RCIC will continue to operate. Therefore, success of the diesel Priven fire pump implies that the RPV was depressurized causing a loss of RCIC and that the fire pump is injecting to the RPV and will continue to run until limiting system parameters are reached. Failure implies that the fire pump intensity of the reached of the system parameters are reached.

With BPCS success and successful operator actions to extend HPCS operation, P is based on recovery in 13 hours. If the operator action to extend BPCS operation fails, R is based on recovery in 11 hours. With failure of BPCS and success of RCIC and alternate injection with the fire pump, ... is based on recovery in 13 hours. If the fire pump fails, only 3 hours is available for recovery. If both HPCS and RCIC fail, R is based on recovery in 0.4 hours.



With one stuck open relief valve the above recovery times are slightly more restrictive. With HPCS success and successful operator action, R is based on recovery in 11 hours. If the operator action fails, R remains based on recovery in 11 hours. With failure of HPCS and success of RCIC and alternate injection with the fire pump, R is based on 11 hours. If the fire pump fails, only 2 hours is available for recovery.

The times with two stuck open relief valves are the same as with one stuck open relief valve.

Success or failure of emergency depressurization (automatic or manual) following the recovery of divisional power supplies. Success implies that the RPV is depressurized using the appropriate number of SRVs for the sequence (4, 3 or 2). Failure implies that the reactor has not been depressurized and no ECCS system will be capable to provide injection into the vessel.

X

12

Y

Success or fail_re of low pressure make-up. Success implies that a low pressure ECCS system is providing adequate make-up into the RPV. Failure implies no low pressure ECCS is capable of providing RPV coolant make-up.

Val Success or failure of condensate transfer alternate injection or fire protection alternate injection crossfied to the HPCS injection line. Success implies that the transfer systems were aligned to the RPV and are providing injection. Failure implies that the systems could not provide coolant makeup.

Success or failure of long-cerm containment heat removal by RHR supp.sision pool cooling or containment spray, to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that heat removal can be demonstrated after power restoration by operation of at least one heat exchanger. Failure implies that heat removal by RHR is not maintaining containment pressure below the limit.

Success or failure of containment heat removal by venting to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that steady-state heat removal can be demonstrated after the power restoration time by a venting operation performed either manually of with motor-operated valves. Failure implies that heat removal by venting is not maintaining containment pressure below the limit.

 Venting with the Fuel Pool Cooling and Cleanup system requires the manual alignment of vent path through the fuel pool skimmers into the Fuel Handling Building.

o Venting with the RHR Containment Spray Loop A or B requires the manual alignment of vent path through the applicable containment spray header into the Fuel Handling Building. Operation of the containment motor operated valves requires AC power.

Page 3-29

Following failure of offsite AC power restoration success of venting implies that the division 3 but has been crosstied to the division 2 bus and the inboard FPCC isolution vavle was successfully opened and that the operators manually opened the Fuel Pool Cooling and Cleanup (FPCC) outboard isolation valve. Failure implies that the FPCC line is isolated.

Cv Success or failure of operating injection systems following loss of containment integrity. Success implies that adequate core cooling can be maintained by the operating injection system. Failure implies that the reactor core was vulnerable to damage as a result of the failure of an operating injection system coincident with loss of containment integrity.

The development of the functional fault trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating event and preceding success or failures is described in Appendix E.

3.1.3.3 TRANSIENT WITH INADVERTENT OPEN RELIEF VALVE

3.1.3.3.1 General Description

The inadvertent open relief valve (IORV), event is defined as a class T3C transient, consistent with the nomenclature utilized in NUREG/CR-4550.

The IORV transient is defined as the spurious or inadvertent opening, during normal plant operation, of an SRV that then sticks in the full open position. With an inadvertent open relief valve, reactor steam is discharged directly into the suppression pool. Alarms, temperature monitors and plant response will readily indicate the existence of an IORV. The FNPP procedure for an IORV calls for attempts by the operators to close the valve. PNPP Technical Specifications call for an immediate plant shutdown if the valve cannot be closed prior to the suppression pool exceeding 110°F.

A MAAP analysis indicates that it will take approximately 8 minutes for the pool temperature to increase from 90 to 110°F.

For an IORV transient, it is assumed that the Power Conversion System (PCS) is initially available to eliminate any challenge to the SRVs for RPV pressure control.

RCIC is capable of providing injection for the IORV event. Additionally, an IORV is assumed to not depressurize the reactor versel fast enough, without the assistance of additional open SRVs or the ADS system, to prevent uncovery of the core before the low pressure systems inject into the vessel.

The event is expected to cause only minor perturbation to the RPV water level. The capacity of the feedwater system is sufficient to make-up the inventory lost due to the IORV.

No automatic scram is assumed to occur until the suppression pool heatup causes an increase in the dryvell pressure and a resultant automatic reactor scram.

This event is treated separately from the transient induced stuck open relief valve (SORV), since for the IORV, plant shutdown will not occur until suppression pool temperature approaches 110°F. For the SORV, a plant scram will have occurred prior to the open SRV. Thus, there is more critical demand upon the containment heat removal systems for the IORV than for the SORV.

3.1.3.3.2 Success Criteria

The success criteria for a transient with an inadvertent open relief valve is listed in Table 3.1.3-3.

3.1.3.3.3 Event Tree

The event tree for this event is provided on Figure 3.1.3-3. Heading definitions are provided below.

- T3C An IORV transient occurs which disrupts the normal operation of the plant and requires mitigation.
- C Success or failure of RPV reactivity control with RPS automatic or manual scram or ARI. Success implies that a sufficient number of control rods have inserted into the core to provide a shutdown rod pattern. Thus, a successful reactor scram has occurred. Failure implie: the rods have not inserted to a subcritical rod configuration. Failur: sequences transfer to the ATWS event tree.
- U3 Success or failure of RPV level control with the feedwater system. Success implies that one of two Reactor Feedpumps (RFPs) or one Motor Feedpump (MFP) starts or continues to run and provides successful RPV level control. Failure implies that the feedwater system cannot maintain RPV level control.
- U2 Success or failure of RPV level control with the RCIC system. Success implies that either RCIC automatically actuates at RPV level 2 or that it is manually actuated and is providing adequate RPV level control. It further implies that long-term containment heat removal with RNR in Suppression Pool Cooling mode successfully maintains containment conditions for long-term operability of RCIC. Failure implies that kcIC is not maintaining RPV level control or that long-term containment heat removal is not maintained, resulting in the loss of RCIC.
- U1 Success or failure of RFV level control with the HPCS system. Success implies that HPCS automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS.
- X Success or failure of emergency RPV depressurization. Success implies that the ADS was automatically or manually initiated or that the operator manually depressurized the vessel with at least 4 SRVs. Failure implies that ADS failed and that the operator failed to manually emergency depressurize with the required number of SRV causing the reactor vessel to remain at a higher pressure than that required by the PNPP Plant Emergency Instructions (PEIs) for successful RPV level

control with low pressure injection.

V

Y

- Success or failure of RPV level control with the ECCS low pressure make-up systems. Success implies that, at a minimum, LPCS or one loop of LPCI either automatically initiated or was manually placed in service and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained by an ECCS low pressure injection system.
- Va Success or failure of RPV level control with the Condensate Transfer Alternate Injection alignment. Success implies, that the CTS alternate injection alignment was manually started by the plant operators and that the alignment successfully provided RPV level control. Failure implies that CTS alternate injection was not aligned or that it was unable to maintain RPV level control.
- Success or failure of long-term containment heat removal with RHR to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that long-term heat removal can be achieved by at least one of the following modes of RHR. Failure implies that no long-term containment heat removal mode of RHR was aligned or that pressure cannot be maintained below the limit.

o One RHR train in Suppression Pool Cooling mode.

o One RHR in the Containment Splay mode.

- Success or failure of long-term containment heat removal by venting of the containment. Success implies that one of the below listed venting paths were aligned, per the PEIs, prior to containment pressure exceeding the Containment Capacity Threshold Limit and that the aligned path maintains pressure below that limit. Failure implies that no path was successfully aligned or that the limit was exceeded.
 - o Fuel Pool Cooling and Cleanup system. Manual alignment of vent path through the fuel pool skimmers into the Fuel Handling Building.
 - RHR Containment Spray Loop A or B. Manual alignment of vent path through the containment spray header into the Fuel Handling Building.
- Cv Defines the susceptibility of the core to damage, dependent upon containment conditions. Success implies that given containment failure, the core is still maintained in a safe configuration. Failure implies that the containment failure has led to a degradation of plant systems such that the core is susceptible to damage.

The development of the functional fault trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating event and preceding success or failures is described in Appendix E.

3.1.3.4 LOSS OF INSTRUMENT AIR EVENT TREE

3.1.3.4.1 General Description

The loss of instrument air transient is defined as the TIA transient. It is a special initiator.

The loss of instrument air event is defined as the complete unrecoverable loss of instrument air during normal plant operation. The loss of instrument air event is similar to a loss of PCS transient (T2). It is developed as a special initiator as it will lead to the potential loss of some additional accident mitigating systems.

The loss of instrument air event is considered a subset of the loss of Service Water event which is expected to fail both Turbine Building Closed Cooling and Nuclear Closed Cooling (and thus instrument air).

Upon the complete unrecoverable loss of instrument air, plant operators are directed to perform a fast reactor shutdown. However, if no immediate operator action is taken, it is expected that a plant scram will occur due to a variety of plant conditions. The worst case initiator is assumed to be a MSIV isolation caused by either the loss of instrument air to the MSIV accumulators (and the subsequent drifting closed of the MSIVs) or due to a low condenser vacuum isolation signal caused by the loss of the Steam Jet Air Ejectors.

A plant scram could also occur due to turbine trip (caused by loss of air to the main turbine front standard), or loss of condenser vacuum (caused by the loss of the Steam Jet Air Ejectors) or due to a high scram discharge volume (caused by drifting of the scram valves and closure of the SDV vent and drain valves).

Feedwater is lost for this transient due to the loss of steam to the Reactor Feedpumps (RFPs), resulting from the MSIV isolation caused by a loss of condenser vacuum. The Motor Feedpump (MFP), is unable to be started due to the lockup of the MFP Flow Control Valve (1N27-F0010) in its normally closed position.

Additionally, the Not Surge Tank level control valves will fail as is and the feedwater and feedwater booster pump recirculation valves will fail open. these failures are assumed to inhibit recovery of the feedwater system.

CRD pumps will also be unavailable for the transient as the loss of instrument air will cause the closure of the flow control valve, resulting in a decreased drive water and cooling water flow to the CRDs.

Long-term air supply to the non-ADS SRVs (excepting F0051D), is lost with the loss of instrument air. Accumulators provide an immediate air supply for short term SRV operability.

3.1.3.4.2 Success Criteria

The success criteria for loss of instrument air are the same as for the loss of PCS transient listed in Table 3.1.2-4.

3.1.3.4.3 Event Tree

V

The event tree for this transient is provided on Figure 3.1.3-4 sheets 1-3. Heading definitions are provided below.

- TIA A loss of instrument air transient occurs which disrupts the normal operation of the plant and requires mitigation.
- C Success or failure of RFV reactivity control with RPS automatic or manual scram or ARI. Success implies that a sufficient number of control rods have inserted into the core to provide a shutdown rod pattern. Thus, a successful reactor scram has occurred. Failure implies the rods have not inserted to a subcritical rod configuration. Failure sequences transfer to the ATWS event tree.
- F1 Success or failure of RPV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, one failed to reclose. The event tree for the equivalent small LOCA is developed on Sheet 2.
- P2 Success or failure of RPV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, two failed to reclose. The event tree for the equivalent intermediate LOCA event is developed on Sheet 3.
- U2 Success or failure of RPV level control with the RCIC system. Success implies that either RCIC automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level 2 or that It further implies that long-term containment heat removal with RHR in Suppression Pool Cooling mode successfully maintains containment conditions for long-term operability of RCIC. Failure implies that RCIC is not maintaining RPV level control or that long-term containment heat removal is not maintained, resulting in the loss of RCIC.
- Ul Success or failure of RPV level control with the HPCS system. Success implies that either HPCS automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS.
- X Success or failure of emergency RPV depressurization. Success implies that the ADS was automatically or manually initiated or that the operator manually depressurized the vessel with at least 4 SRVs. Failure implies that ADS failed and that the operator failed to manually emergency depressurize with the required number of SRV causing the reactor vessel to remain at a higher pressure than that required by the PNPP Plant Emergency Instructions (PEIs) for successful RPV level control with low pressure injection.
 - Success or failure of RPV level control with the ECCS low pressure make-up systems. Success implies that, at a minimum, LPCS or one loop of LPCI either automatically initiated or was manually placed in

service and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained by an ECCS low pressure injection system.

- Va Success or failure of reactor feed booster pump alternate injection. Success implies that at least one reactor feed booster pumps is manually aligned and provides injection to the RPV. Failure implies that the reactor feed booster pumps were not aligned or that the pumps are unable to maintain RPV level control.
- Success or failure of long-term containment heat removal with RHR to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that long-term heat removal can be achieved by at least one of the following modes of RHR. Failure implies that no long-term containment heat removal mode of RHR was aligned or that pressure cannot be maintained below the limit.

o One RHR train in Suppression Pool Cooling mode.

o One RHR train in the Containment Spray mode.

- Success or failure of long-term containment heat removal by venting of the containment. Success implies that one of the below listed venting paths were aligned, per the PEIs, prior to containment pressure exceeding the Containment Capacity Threshold Limit and that the aligned path maintains pressure below that limit. Failure implies that no path was successfully aligned or that the limit was exceeded.
 - o Fuel Pool Cooling and Cleanup System. Manual alignment of vent path through the fuel pool skimmers into the Fuel Handling Building.
 - o RHR Containment Spray Loop A or B. Manual alignment of vent path through the containment suray header into the Fuel Handling Building.
- Cv Defines the susceptibility of the core to damage, dependent upon containment conditions. Success implies that given containment failure, the core is still maintained in a safe configuration. Failure implies that the containment failure has led to a degradation of plant systems such that the core is susceptible to damage.

The development of the functional fault trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating event and preceding success or failures is described in Appendix E.

3.1.3.5 LOSS OF SERVICE VATER EVENT THEE

3.1.2 5.1 General Description

Y

The loss of service water transient is defined as the TSW transient. It is a special initiator.

The loss of Service Water event is defined as the complete loss of Service Water during normal plunt operation. It is assumed that the loss of Service

Water will lead to the additional loss of the Nuclear Closed Cooling System, the Turbine Closed Cooling System and the systems which are supported by these systems (including Instrument Air).

The loss of Service Water event is similar to a loss of PCS transient (T2). It is developed as a special initiator as a loss of Service Water will lead to the potential loss of additional accident mitigating systems. The loss of Service Water event is expected to bound other similar initiators, such as loss of Turbine Building Closed Cooling and Nuclear Closed Cooling. Failure of these systems is conservatively included in the loss of Service Water initiator Water event.

Upon loss of Service Water, plant operators are directed to perform a fast reactor shutdown in anticipation of the loss of cooling to the various plant loads. If no immediate operator action is taken, it is expected that a plant scram will occur due to a variety of plant conditions.

The worst case initiator for the 15% transient is assumed to be a MSIV isolation. The isolation can be initiated form various mechanisms, including an isolation signal on high steam tunnel temperature (loss of steam tunnel cooling) or on low condenser vacuum (loss of Steam Jet Air Ejectors) or by a loss of Instrument Air to the MSIVs and their subsequent isolation.

A plant scram is also postulated due to high drywell pressure (loss of drywell cooling), a turbine trip (due to loss of Stator Water Cooling), high scram discharge volume (due to drifting of the scram valves and closure of the SDV vent and drain valves).

Feedwater is assumed lost for this transient due to a loss of component motor bearing or lube oil cooling. Compounding the loss of feedwater would be the loss of Instrument Air which would cause a lockup of the Hot Surge Tank level control valves, the failing open of the feedwater and feedwater booster pump recirculation valves and the lockup of the Motor Feedpump flow control valve. Loss of the MSIVs would also isolate the steam supply to the Reactor Feedpumps (RFPs). The Motor Feedpump (MFP) is assumed to be unable to be started due to the lockup of the MFP flow control valve.

The Power Conversion System (PCS) is assumed lost for this transient. The Steam Jet Air Ejectors (SJAE) will be lost upon loss of Instrument Air or due to tripping of the Off-Gas compressons, which would require SJAE shutdown. While ONI-P41 directs the operators to start the mechanical vacuum pumps, these will also be lost due to loss of an ultimate heat sink for the TBCC system which cools the vacuum pumps.

The Service Air and Instrument Air compressors will trip on high temperature resulting from the loss of Nuclear Closed Cooling. Actual loss of instrument air is not expected to occur until the system is bled down by leakage or component usage.

CRD pumps are assumed to be lost due to loss of component cooling. Loss of Instrument Air will lead also to the closure of the CRD flow control valve.

RCIC isolation may also occur if the RCIC isolation signal on high steam tunnel temperature is not overridden by the plant operators prior to the

thirty minute timer timing out.

Long-term air supply to the non-ADS SAVs (excepting F0051D), is lost with the loss of Instrument Air. Accumulators provide an immediate air supply for short term SRV operability.

3.1.3.5.2 Juccess Criteria

The success criteria for loss of service water are the same as for the loss of PCS transient with the addition identified above and are in Table 3.1.2-4.

3.1.3.5.3 Event Tree

The event tree for this transient is provided in Figure 3.1.3-5 sheets 1-3.

- TSW A loss of service water transient occurs which disrupts the normal operation of the plant and requires mitigation.
- C Success or failure of RPV reactivity control with RPS automatic or manual scram or ARI. Success implies that a sufficient number of control rods have inserted into the core to provide a shutdown rod pattern. Thus, a successful reactor scram has occurred. Failure implies the rods have not inserted to a subcritical rod configuration. Failure sequences transfer to the ATVS event tree.
- P1 Success or failure of RPV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, one failed to close. The event tree for the equivalent small LOCA is developed on Sheet 2.
- P2 Success or failure of RPV pressure control with the SRVs opening and reclosing. Success implies that the required SRVs opened and reclosed. Failure implies that of the SRVs which successfully opened, two failed to reclose. The event tree for the equivalent intermediate LOCA is developed on sheet 3.
- U2 Success or failure of RPV level control with the RCIC system. Success implies that either RCIC automatically actuated at RPV level 2 or that it was manually actuated and is providing adequa. RPV level control. It further implies that long-term containment heat removal with RHR in Suppression Pool Cooling mode successfully maintains containment conditions for long-term operability of RCIC. Failure implies that RCIC is not maintaining RPV level control or that long-term containment heat removal is not maintained, resulting in the loss of RCIC.
- Ul Success or failure of RPV level control with the HPCS system. Success implies that neither HPCS automatically actuated at RPV level 2 or that it was manually actuated and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained with HPCS.
- X Success or failure of emergency RPV depressurization. Success implies that the ADS was automatically or manually initiated or that the operator manually depressurized the vessel with at least 4 SRVs.





Failure implies that ADS failed and that the operator failed to manually emergency depressurize with the required number of SRV causing the reactor vessel to remain at a higher pressure than that required by the PNFP Plant Emergency Instructions (PEIs) for successful RPV level control with low pressure injection.

- Success or failure of RPV level control with the ECCS low pressure make-up systems. Success implies that, at a minimum, LPCS or one loop of LPCI either automatically initiated or was manually placed in service and is providing adequate RPV level control. Failure implies that RPV level control cannot be maintained by an ECCS low pressure injection system.
- Success or failure of long-term containment heat removal with RHR to maintain containment pressure below the Containment Capacity Threshold Limit of 50 psig. Success implies that long-term heat removal can be achieved by at least one of the following modes of RHR. Failure implies that no long-term containment heat removal mode of RHR was aligned or that pressure cannot be maintained below the limit.

o One RHR train in Suppression "ool Cooling mode.

o One RHR train in the Containment Spray mode.

- Success or failure of long-term containment heat removal by venting the containment. Success implies that one of the below listed venting paths were aligned, per the PEIs, prior to containment pressure exceeding the Containment Capacity Threshold Limit and that the aligned path maintains pressure below that limit. Failure implies that no path was successfully aligned or that the limit was exceeded.
- o Fuel Pool Cooling and Cleanup System. Manual alignment of vent path through the fuel pool skimmers into the Fuel Handling Building.
- RHR Containment Spray Loop A or B. Manual alignment of vent path through the containment spray header into the Fuel Handling Building.
- Cv Defines the susceptibility of the core to damage, dependent upon containment conditions. Success implies that given containment failure, the core is still maintained in a safe configuration. Failure implies that the containment failure has led to a degradation of plant systems such that the core is susceptible to damage.

The development of the functional fault trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating event and preceding success or failures is described in Appendix E.

3.1.3.6 INTERFACE LOCA EVENT TREE

3.1.3.6.1 General Description

V

Y

No event tree was developed for the interface LOCA event. An evaluation was performed on the potential paths of an interface LOCA. The paths noted in

section 4.4.15 of NUREG/CR-4550 were identified as the dominant paths contributing to interface LOCA for the Perry plant. The Grand Gulf and Perry designs are identical for these paths. Using the data in NUREG/CR-4550 the core damage frequency for an interfacing LOCA event is less than 10^{-8} /yr.

3.1.3.7 CONTAINMENT BYPASS LOCA EVENT TREE

3.1.3.7.1 General Description

No event tree was developed for the containment bypass LOCA event. An evaluation was performed on the potential paths for containment bypass LOCAs. The potential for an unisolable break in these lines was much less than for an interface LOCA event. Therefore, the core damage frequency for a containment bypass LOCA event is also less than 10⁻⁸/yr.

3.1.3.8 VESSEL RUPTURE

3.1.3.8.1 General Description

No event tree will be developed for this event. All occurrences of this event are assumed to result in core damage. Using the data in NUREG/CR-4550, the frequency of a vessel rupture is less than 10[°]8/yr.

3.1.3.9 INTERNAL FLOODING

3.1.3.9.1 General Description

This event is being treated as a separate task in the IPE and is fully described in section 3.3.7.

3.1.3.10 ANTICIPATED TRANSIENT WITHOUT SCRAM (ATWS) EVENT TREE

3.1.3.10.1 General Description

Transients with a failure of automatic scram are defined as ATWS events and are further defined as type "C" events, consistent with the nomenclature utilized in NUREG/CR-4550.

When a transient initiating event is followed by failure of reactivity control to provide rod insertion by automatic/manual Reactor Protection System scram and by automatic/manual Redundant Reactivity Control System Alternate Rod Insertion, the operators will attemp. shutdown of the reactor by manually inserting rods and/or initiating the two Standby Liquid Control System (SLC) pumps. The progression of an anticipated transient without automatic scram (ATWS) depends on the initiating events and the subsequent success in the operation of plant systems and in the success of human interactions.

ATWS events can result during the development of all initiators analyzed. Six ATWS event trees (Loss of Offsite Power, Transient Without PCS, Transient With PCS Available, Transient With Loss of Feedwater, Inadvertent Stuck Open Relief Valve, and Loss of Instrument Air) transfer from the initiating trees and bound all ATWS events. These ATWS event trees detail the accident progression for ATWS events due to mechanical failure of control rods to insert. Electrical failure of the reactivity control systems without mechanical failure is considered to be negligible and is not developed.

3.1.3.10.2 Success Criteria

The success criteria are given in Table 3.1.3-4.

Additional key assumptions upon which this analysis is based include the following:

- For the bounding ATWS condition of all control rods out, the reactor power was modeled with an adjusted Chexal-Layman Correlation (to account for the allowable 120% rod line). At the rated RPV pressure of 1,039 psia, the adjusted Chexal-Layman Correlation calculates 21% rated reactor power with the downcomer water level at the TAF when the decay heat power is 2.5%.
- HPCS is not utilized as a high pressure injection source in the ATWS event trees, since the BWR Owners Group EPG Rev 4 does not direct the operation of inside the shroud injection systems until all other injection sources have been exhausted.
- 3. Exceeding the suppression pool heat capacity design temperature limit does not lead immediately to a loss of containment integrity, and will not lead to core damage provided containment heat removal is initiated following shutdown by injectica of borated water (SLC).
- Reactor power remains constant until hot shutdown is achieved which is approximately 44 minutes for 1 pump SLC injection.
- 5. Containment integrity is not threatened until the Containment Car city Threshold Limit (approximately 50 psig) is reached.
- No credit is taken for manually inserting individual rods.

3.1.3.10.3 Event Tree

Reactivity control is provided by multiple, redundant design features and systems. Following the occurrence of a transient which disrupts normal plant operation the front line reactivity control systems are challenged to insert all the control rods into the core to at least position 02 or to a shutdown pattern. The frontline reactivity control capabilities addressed in the transient event trees include Reactor Protection System (RPS), Redundant Reactivity Control System (Alternate Rod Insertion - ARI) and manual scram. Success of any of these control functions implies that the reactor has been successfully shutdown and continues the accident sequence progression through the transient tree. Failure of all these functions implies that the reactivity control electrical portion is not capable of shutting down the reactor. With recent design improvements this frequency is projected to be negligible.

A fraction of reactivity control failures can be attributed to mechanical failures associated with the reactivity control systems. Mechanical failure would eliminate the capability to insert the control rods by any alternate

means. The mechanical failure of control rod insertion systems is explicitly addressed in the ATWS event trees. Failure of this event assumes that all of the rods remain in the withdrawn position.

For ATWS scenarios due to mechanical failure, tripping of the recirculation pumps is assumed to have occurred. The trip will occur automatically due to Recirculation Pump Trip (RPT), manual operator action, mechanical overspeed or due to cavitation/flow induced failures when RPV level falls towards the Top of Active Fuel (TAF). For some transients (i.e., loss of offsite power) plant conditions will cause the pump trip. Success implies that the RPT has functioned resulting in a natural circulation reactor power of approximately 50% at the bounding 120% rod line. ATWS scenarios with a failure of the RPT are not developed further in this analysis.

Six events are analyzed in this ATWS analysis. As noted above, the transients are characterized by the occurrence of the transient, the mechanical failure of reactivity control such that no control rods are inserted into the core and the occurrence of the Recirculation Pump Trip (RPT). The six events analyzed include Loss of Offsite Power, Transient without PCS, Transient with PCS Available, Transient with Loss of Feedwater, Inadvertent Stuck Open Relief Valve and Loss of Instrument Air. The associated ATWS event tree is similar. Heading definitions are provided below:

- Txxx-C A transient initiating event has occurred which disrupted normal operation. A mechanical failurs of the front line reactivity control systems (Reactor Protection System and Kedundant Reactivity Control) has occurred such that a failure to insert all control rods into the core to at least position 02 or to a shutdown pattern has occurred. Recirculation Pump Trip (RPT) has occurred resulting in a natural circulation reactor power of approximately 50% at the bounding 120% rod line.
- M Success or failure of the safety relief values (SRVs) to relieve RFV pressure. Success implies that all SRVs have opened against the spring preventing a rupture of the RFV due to overpressurization. Failure implies that at least one SRV failed to open.
- RPT Success or failure of the recirculation pump trip. Success implies that the recirculation pumps have received a trip signal and tripped. Failure implies that the recirculation pumps have not tripped and are still operating.
- Q Success or failure of the Power Conversion System (PCS) to remain available. Success implies that the Main Steam Isolation Valves have remained open. Success is contingent on the operators defeating the MSIV Low RPV Level Isolation by repositioning four back panel switches before the rector water level Decreases to Level 1. Failure implies the MSIVs did not remain open which results in a loss of PCS and steam to the Turbine Driven Feed Pumps (TDFPs).
- U3 Success or failure of RPV level control with at least one pump in the feedwater system. Success implies that either the Motor Feed Pump

(MFP) or one of the two Turbine Driven Feed Pumps operate until hot shutdown and the RPV water level is maintained at or neat the Top of Active Fuel (TAF) per the PNFP Flant Emergency Instructions (PEIs). Failure implies all feedwater pumps failed to function.

- Lc Success or failure of RPV level control. Success implies that the operators control the RPV water level at TAF to control RPV power. Failure implies that that level is not deliberately lowered.
- X' ADS successfully or not successfully inhibited. Success implies that the operators have bypassed the automatic depressurization system to prevent rapid RPV overfill with cold water from the low pressure injection systems. Failure implies that the ADS is not inhibited and the RPV will depressurize on the automatic initiation of the ADS system allowing a cold water reactivity transient with the potential for core damage and increased containment threat from high reactor power.
- Cl Success or failure of Standby Liquid Control (SLC) system injection with one of two pumps. Success implies that the operators have initiated the SLC system such that hot shutdown is achieved with 1 SLC pump injecting 43 gpm of sodium pentaborate into the reactor before containment integrity is threatened. Failure implies the operators did not initiate SLC soon enough or that both SLC pumps failed to operate such that SLC could not inject to avoid threatening containment integrity.
- X Success or failure of emergency RFV depressurization. Success implies that the operator manually depressurized the vessel with at least 4 SRVs. Failure implies that the operator failed to manually emergency depressurize with the required number of SRVs causing the reactor vessel to remain at a higher pressure than that required for successful core recovery with low pressure injection.
- V Success or failure of adequate core reflood with a low pressure system. Success implies that at least one of the following ECCS systems was successfully aligned and slowly throttled to avoid a large power excursion which might result in core damage, and yet initiated in time to recover the core before the fuel clad temperature becomes excessive. Failure implies that these ECCS pumps were not properly aligned or controlled per the the PEIs.

o Low Pressure Coolant Injection Train A

o Low Pressure Coolant Injection Train B

o Low Pressure Core Spray

V' Success or failure of not overfilling the vessel after shutdown. Success implies the operator slowly increases vessel level to the normal water level control band. Failure implies the operator overfills the vessel and flushes out the boron and returns the vessel to a critical conditions.

Success or failure of long-term containment heat removal with one loop

of RHR to maintain containment pressure below the Containment Capacity Threshold Limit. Success implies that long-term heat removal can be achieved during 24 hours by at least one of the following modes. Failure implies that long-term heat removal by RHR is not maintaining containment pressure below the limit.

o One RHR train in Suppression Pool Cooling.

O Che RHR train in Containment Spray.

Success or failure of long-term containment heat removal by venting to maintain containment pressure below the Containment Capacity Threshold Limit. Success implies that long-term heat removal can be achieved during 24 hours by at least one of the following modes. Failure implies that long-term heat removal by venting is not maintaining containment pressure below the limit.

o Containment Venting by Fuel Pool Cooling and Cleanup

o Containment Venting with RHR Containment Spray Headers

CV

Y

Defines the susceptibility of the core to damage, dependent upon nontainment conditions. Success implies that given containment failure, the core is still maintained in a safe configuration. Failure implies that the containment failure has led to a degradation of plant systems such that the core is susceptible to damage.

The development of the functional fault trees for each of the event tree functions with the appropriate boundary conditions defined by the initiating events and preceding success or failures is described in Appendix E.

3.1.4 SEQUENCE GROUPING AND BACK END INTERFACE

3.1.4.1 Plant Damage State Grouping Criteria

The interface between the Level 1 Systems Analysis and the Level 2 Containment Analysis is defined by the plant damage state at the time of core melt. In order to avoid performing a full analysis of the phenomenology of each core melt sequence to determine the potential release of fission products the individual core damage sequences are assigned to one of the plant damage state (PDS) groups. Each group is defined by a set of functional characteristics for system operation which are important in terms of the accident progression, containment failure and source term definition. Each PDS contains Level 1 sequences with sufficient similarity in system functional characteristics such that the containment accident progression for all sequences in the group can be considered essentially the same.

The important functional characteristics for each PDS are developed in section 4.3. These characteristics are interpreted in terms of success or failure of the various systems used to prevent core damage and mitigate the release of the fission products. Therefore the core damage event trees are extended to include all systems which will impact fission product release. The sequence characteristics which are important to the progression of the accident in the order in which they are asked in the grouping process are shown in Figure 3.1.4-19 and are as follows.

- 1. Not a containment bypass sequence.
- 2. Containment status at core damage.
- 3. Event Type:

3.1 For Containment Intact At Core Damage Station Blackout (SBO) LOOP With No HVAC Other Types than above
3.2 For Containment Failed At Core Damage Critical (Non-Shutdown) ATWS Loss of Offsite Power and Station Blackout Others than above

 Initial Containment Heat Removal With Suppression Pool Cooling (only for LCOP With No HVAC)

5. Containment Vent Isolated at RPV Failure (only for SBO)

6. RPV Injection Failure Time

7. Offsite Power Recovery Time

- 8. Containment Heat Removal With RHR Spray Loop
- 9. Containment Heat Removal With Vent
- 10. Late In-Vessel Injection and Pedestal Cavity Supply
- 11. RFV depressurized during core damage

Each of the above grouping criteria, the plant damage state characteristics and the binning results are fully described in section 4.3.

An examination of the above criteria shows that the event trees discussed in section 3.1.2 and 3.1.3 which are based on the success criteria for the prevention of the onset of core damage, do not include all the functions necessary to group them into the various plant damage states. For example where core damage is the result of failure of injection containment heat removal is not included. Similarly, following loss of offsite power only recovery to prevent core damage has been considered in the core damage event trees. It is necessary to modify the initial core damage event trees to include the functioning of the containment systems for all sequences. As the majority of the function in the plant damage state trees are those that lead to core damage only those functions which have been added in order to enable the PDS grouping to be performed are described in detail in this section. The additional containment systems added to the earlier event trees to give the new PDS trees are modeled in exactly the same way as the earlier functions. Fault trees are developed for each of the containment functions and all functions are linked to give combinations of failures leading to a given sequence of events. This will ensure that any dependencies between



the system preventing core damage and those preventing containment failure will be correctly modeled.

3.1.4.2 Plant Damage State Event Trees

The amended event trees for all initiating events are shown in Figures 3.1.4-1 through 3.1.4-18. There are a number of basic functions which have been included in all the trees and a further group of functions only applicable to the loss of offsite power and station blackout trees. The functions applicable to all trees are associated with decay heat removal, depressurization and late injection and are discussed first, followed by a discussion of events only applicable to loss of offsite power and station blackout scenarios.

Containment Heat Removal (Wc, Ws)

The containment heat removal function has been divided into two in order to differentiate between sequences where containment heat removal is achieved through the containment spray system and those where the containment spray system is not operational but containment heat removal is achieved through suppression pool cooling.

We is defined as failure of containment heat removal as the result of failure of the containment spray mode of RHR or supporting systems.

Ws is defined as failure of containment heat removal as the result of failure of the suppression pool cooling mode of RHR or supporting systems following the failure of Wc.

Reactor Pressure Vessel Depressurization (X3)

In a number of sequences it is postulated that core damage will occur at high pressure as the result of failures associated with the containment or as the result of the failure of the operator to depressurize in time for low pressure injection systems to inject and prevent core damage. Late depressurization, after core damage, but before vessel failure will have a significant impact on fission product release so this function has been added to all high pressure core damage sequences.

Late Vessel Injection (Li)

If late depressurization is successful then it is possible to inject using low pressure systems with the potential for achieving in vessel debris cooling. In some cases late injection into the containment is also significant. This function has therefore been added to the event tree for all success branches of the function X3.

It has also been added as a special event in the Large and Intermediate LOCA event trees to reflect the fact that alternative low pressure systems which are not available in the short term to prevent core damage could be aligned later to provide invessel cooling of the debris.

Loss of Offsite Power and Station Blackout

In the event of a loss of offsite power or station blackout actions in addition to those discussed can be taken to mitigate the release of fission products. Probably the most important of these is the recovery of offsite (cr onsite) power before vessel or containment failure. Each of the functions is discussed in the following paragraphs.

- R3 Recovery offsite power prior to vessel failure. The time available for the recovery of power is dependent upon the specific sequence. The timing for this function is sequence dependent - See Appendix E.
- R4 Recovery of offsite power prior to containment failure. The time available to recover offsite power prior to containment failure is considerably longer than that available prior to vessel failure. Recovery will enable containment systems to be restarted and therefore reduce the frequency of containment failure. The time available for recovery is sequence dependent and discussed in Appendix E.
- Y2 Long term containment heat removal with venting. As this has not been asked earlier in some sequences it is necessary to include it in the trees. In order to avoid having the venting function appear twice with the same identifier, the second time it is used it is given the designator Y2. The functional requirements are the same as for Y.
- Wt Long term containment heat removal with suppression pool cooling. This is the same function as Ws, but again is required at a different time for certain sequences, thus, as in the case of the function Y a different designator is used.
- I Isolation of the containment. If power is lost initiation of the Fuel Pool Closed Cooling can only be achieved by the operator or restoration of electrical power. This function models failure to achieve this following a station blackout.
- Val Alternate Low Pressure makeup. This is the same function as Va but as in the case of Y and Ws above requires to be modeled at a different position in the development of the sequences.

3.1.4.3 Plant Damage State Sequences

A review of the plant damage state event tree will reveal that not all the core damage sequences in the core damage event trees have been included in the PDS trees. In order to avoid analysis of sequences which do not contribute significantly to the core damage or offsite release all sequences below 1.0 x 0° were excluded from the PDS evaluation. In order to ensure that any sequence omitted did not pose a risk to the containment significantly different from those included the characteristics of all excluded sequences were reviewed and compared with those which were included. The resulting PDS trees contain sequences which contribute 99.9% to the overall core damage frequency.

The plant damage state to which a sequence contributes is shown in the status column on the event tree and the grouping logic used to define the plant

damage states is shown in Figure 3.14-19. The characteristics of the individual plant damage states and the deriviation of the grouping logic is discussed fully in section 4.3. The contribution of each sequence to a specific plant damage state is also discussed in this section and in the summay of the quantification is section 3.4.

3.2 SYSTEM ANALYSIS

The Perry IPE was performed using the "small event tree - large fault tree" approach, as described in NUREG/CR-2300 (Hickman, 1983) In using this type of method, the fault tree analysis of the plant systems becomes the major underlying task of the Level 1 analysis.

The analysis of the initiating events and the required plant response, to maintain decay heat removal and containment integrity, result in the identification of the safety functions required to achieve these aims. Each of the safety functions can be achieved by either automatic operation of a system or a combination of system operation and operator actions. By analyzing the system requirements in response to each of the groups of initiating events it is possible to identify the response required from each individual system. To summarize, the accident sequence analysis results in identification of the functional requirements which in turn are the translated into individual system requirements. Each individual system requirement is then the starting point for the fault tree development for that system. In the majority of cases the success criteria do not specifically identify the requirements for the support systems, that is electric power, room cooling, motor cooling, instrument air, etc. The top event for the fault tiees for these systems, are determined by the requirements identified in the development of the frontline system fault trees.

The system analysis was conducted in accordance with the task plan which provided specific guidance on the modeling of components and the general assumptions to be made when developing a fault tree. This included specifying component boundaries, level of detail of modeling, guidelines for restoration errors, test and maintenance unavailability, etc. The task procedure was developed to meet all the applicable requirements of NUREG-1335 (NRC, 1989) and NUREG/CR-2300 for fault tree analysis.

Each system is briefly described in this section with details of the success criteria, the functions performed and the dependency matrix. The detailed analysis of each system is recorded in a series of analysis files specifically developed for the project. The fault trees are shown in Appendix A.

The quantification of individual fault trees has not been included in this section. The contribution of individual component and function failures to the overall core damage frequency is discussed in section 3.4.

3.2.1 RPV DEPRESSURIZATION SYSTEM, B21

The Automatic Depressurization System (ADS) is part of the Emergency Core Cooling System (ECCS) and its function is to reduce the pressure in the reactor pressure vessel in the event that the high pressure injection systems fail to perform their function. If the high pressure injection systems cannot maintain adequate core cooling, then ADS reduces the RPV pressure to a point at which the Low Pressure Core Spray (E21) and the Low Pressure Coolant Injection (E12) systems can be used to provide inventory make-up. The non-ADS safety relief values can also be used to reduce the RPV pressure by opening each of the values individually. Simplified diagrams for the system are shown in Figures 3.2.1-1 and 3.2.1-2.

3.2.1.1 System Description

Eight of the nineteen installed safety relief valves (SRVs) on the main steam lines are used for the ADS function. There are two ADS valves in each of the main steam lines A through D. These valves are mechanically self actuating under conditions of high reactor steam pressure (to prevent overpressure in the vessel), or are electrically actuated either manually or by relay logic circuits to provide pressure relief (low-low set or relief mode) or depressurization if the low pressure injection systems are required for inventory make-up.

The eleven installed SRVs not used for ADS are also mechanically self actuating under conditions of high reactor steam pressure or may be electrically actuated either manually or by relay logic circuits to provide pressure relief (low-low set or relief mode).

ADS operation is achieved by actuation of one of two solenoid veries which will allow air from the safety related instrument air system (P57) into the pneumatic operating cylinder of the ADS valve, thus opening the ADS valve. There are two accumulators associated with each ADS SRV. These accumulators ensure an adequate air supply in the event of a safety related instrument air system failure. The accumulator capacity is sufficient to provide two valve actuations during accident conditions.

The discharge from each of the ADS and non-ADS valves is piped to the suppression pool, with the discharge line exhaust submerged to ensure steam condensation within the suppression pool whenever a valve operates.

3.2.1.2 System Operation

Automatic initiation of ADS will occur if the following conditions occur: a) low reactor water level, Level 3: b) low reactor water level, Level 1: c) time delay of 105 seconds after low level is reached - this timer can be reset manually and is automatically reset every time level is raised above Level 1: and d) availability of the LPCS or LPCI pumps. Automatic operation can be overridden if required.

ADS logic can be started manually by placing the manual initiation switch collars in the armed position and depressing the switches. This manual initiation signal bypasses both the level requirements for initiation and the 105 second timer. A LPCI/LPCS pupp must still be running in order to open the ADS valves. Both the ADS and non-ADS sets of valves can be individually opened by the operators from the control room.

3.2.1.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.1-1.

The ADS depends on the safety related Instrument Air System for opening the valves and on DC buses ED-1-A and ED-1-B for valve operation and control.

The non-ADS SRVs depend on the Instrument Air system for valve operation and on the ED-1-4 and ED-1-B buses for valve operation and control.

3.2.1.4 Success Criteria

Success of the ADS implies that at least four of the eight ADS valves open when all the present conditions are satisfied. Valves can be opened either by automatic or manual initiation. Given failure of the above, credit will be taken for the manual opening of at least four of the remaining 11 non-ADS Safety Relief Valves. The fault trees developed for this system are one of the inputs to the failure to the depressurize function in the event trees (X, X2, X3). The exact relationship is shown in the development of the function fault trees i. Appendix E.

3.2.2 STANDBY LIQUID CONTROL, C41

The standby liquid control system shuts down the reactor by pumping a neutron absorbing solution (sodium pentaborate) into the reactor pressure vessel in sufficient concentration and quantity to provide the required reactor shutdown margin without control rod movement and to overcome the maximum positive reactivity resulting from cooldown and xenon decay. A simplified diagram for the system is shown in Figure 3.2.2-1.

3.2.2.1 System Description

The standby liquid control system takes suction from a storage tank containing a highly concentrated solution of sodium pentaborate. Two parallel positive displacement pumps rated at 43 gpm are available to inject the solution into the reactor pressure vessel. Each pump suction contains a normally closed motor operated valve. The pump suctions are crosstied downstream of the motor operated valves to ensure suction to both pumps in the event that one of the suction valves fails closed. Two parallel explosive valves are downstream of the pump discharge. The pump discharges are also crosstied upstream of the explosive valves to ensure a flow path to both pumps in the event that one of the explosive valves fails. Downstream of the explosive valves, the A and B trains combine to provide a single injection line to the reactor pressure vessel.

Reactor water cleanup receives an isolation signal upon initiation of the standby liquid control system to prevent depletion of the boron solution in the reactor, following injection.

3.2.2.2 System Operation

There is no automatic actuation of the standby liquid control system. However, the storage tank outlet valves open, the pumps start, and the explosive valves fire by moving the keylock switches for each train to "ON".

3.2.2.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.2-1.

The storage tank outlet valves and the SLC pumps are dependent on the associated diesel backed 480 VAC buses (EF-1-A and EF-1-8). The explosive

valves receive 120 VAC power from both divisions 1 and 2. A loss of a single division therefore would not fail either of the explosive valves.

Standby liquid control is dependent upon the isolation of reactor water cleanup. If left operating, the reactor water cleanup system would deplete the boron concentration in the reactor pressure vessel after injection.

In addition to AC power, the standby liquid control system is dependent on the heat tracing and antifreeze protection system to maintain adequate temperature in the SLC pump suction lines and the storage tank. The two-bed demineralized water system provides a keep fill function for the standby liquid control system. The instrument air system provides air for mixing during the addition of chemicals into the storage tank. None of these systems were considered necessary for the injection of sodium pentaborate into the reactor pressure vessel and were not incorporated into the logic model.

3.2.2.4 Success Criteria

A single pump with a suction flow path from the storage tank and a discharge flowpath to the reactor pressure vessel is sufficient to shutdown the reactor. The reactor water cleanup valves must also be closed for success. The fault tree developed for this system is one of the inputs to the failure of the standby liquid control function in the event trees (C1). The exact relationship is shown in the functional fault trees in appendix E.

3.2.3 RESIDUAL HEAT REMOVAL, E12

The functions of the Residual Heat Removal (RHR) system are to remove heat from the reactor vessel and suppression pool under normal and accident conditions, to automatically restore and maintain the desired water level in the reactor vessel following a loss of coolant accident (LOCA), and to control or reduce pressure in the reactor and the containment following a LOCA. Simplified diagrams of the system are showp in Figures 3.2.3-1 through 3.2.3-7.

3.2.3.1 System Description

RHR is a 3 train system consisting of motor operated valves and motor driven pumps. The 3 pumps are rated at 7,260 gpm at 125 psi. Trains A and B each have 2 heat exchangers in series downstream of the pumps. Cooling water to the heat exchangers is not required for the Low Pressure Coolant Injection (LPCI) mode of operation. Train C has no heat exchangers and is dedicated to the LPCI mode of operation. The RER pumps take suction from the suppression pool for the low pressure coolant injection, suppression pool cooling and containment spray modes of operation.

Flow through the pump minimum flow lines is limited to 1,650 gpm by valves F0018A/B/C.

3.2.3.2 System Operation

The following modes of operation are considered in preventing core damage following a plant trip from power.







Low Pressure Coolant Injection

LPCI involves restoration of the water level in the reactor vessel to a height sufficient to provide adequate core cooling after a LOCA. LPCI is a low pressure, high flow system which automatically starts giving flow from all 3 pumps to the reactor vessel when the vessel water level decreases to Level 1 or the drywell pressure increases to 1.68 psi. One pump is sufficient to maintain the integrity of the fuel cladding.

During LPCI operation all 3 pumps draw water from the suppression pool. The bypass valves around the heat exchangers open and may not be closed for 10 minutes because heat rejection is not required during the time it takes to flood the reactor. Water flows to the reactor vessel through the LPCI injection valves.

Containment Spray

The containment spray mode is used to remove heat from the containment following a LOCA. This mode uses either train A or B pumps to pump water from the suppression pool through the heat exchangers and out of the nozzles in the ring spray headers in the dome of the containment. The spray condenses any steam that may exist in the containment thus reducing containment pressure. The water returns to the suppression pool through drainage.

The containment spray mode is actuated automatically 10 minutes after LPCI initiation if the drywell pressure is 1.68 psig (setpoint) and the containment pressure is 22.42 psia (setpoint). Operating procedures, however, instruct the operators to bypass automatic actuation and manually initiate containment spray as required. Injection to the reactor vessel is isolated for the train in the containment spray mode of operation.

Suppression Pool Cooling

The suppression pool cooling mode is used to maintain the suppression pool less than 90°F during normal plant operation to ensure adequate condensation of the steam in the event of a LOCA. It may also be used to reduce suppression pool temperature following Reactor Core Isolation Cooling (RCIC) or Main Steam Safety Relief Valve (SRV) operation and following a LOCA.

Either train A or B may be used for this mode. The flow path is from the suppression pool to the pump through the heat exchangers and back to the suppression pool through the test return valve.

Operator action is required to place RHR into suppression pool cooling mode of operation.

RHR Loop B Containment Flooding

This mode of operation may be used to flood the containment with water from the Emergency Service Water (ESW) system. Two manual ESW inter-tie valves are opened with handwheels to admit ESW water to RHR loop B downstream of heat exchanger outlet valve. The water then flows to the reactor vessel



through the LPCI injection line and out of the break thereby flooding the containment.

The systems can be manually aligned to the three principle modes as follows:

LPCI - The RHR system may be manually aligned to the LPCI mode of operation by arming and depressing push-buttern 1221-S9 for train A or 1E12A-S21 for trains B and C.

Containment Spray - The RHP system may be manually aligned to the containment spray mode of operation by arming and depressing push-button 1E12A-S63A for train A or 1E12A-S63B for train B. Manual actuation of containment spray bypasses the time delay.

Suppression Pool Cooling - The RHR system must be manually aligned to the suppression pool cooling mode of operation by closing valves FOO4P /B and FOO27A/B and opening valve FOO24A/B.

3.2.3.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.3-1.

The major system dependencies are DC control power for actuation. AC power for operating the pumps and valves, cooling to the pumps, and pump room cooling. AC and DC power is divisionally separated with train A being dependent on Division 1 and trains B and C being dependent on Division 2.

In addition to the dependencies common to all the modes of operation, the train A LPCI actuation sensors are shared with the Lov pressure Core Spray system. Trains B and C share LPCI actuation sensors and instrumentation.

Although the containment spray mode of operation is normally manually initiated, the system is designed to be automatically initiated by high containment and drywell pressures with a 10 minute time delay. At the end of 10 minutes if the high pressures still exist, the LPCI injection valve, FO042A will be closed and the containment spray valves FO028A and F0537A will be opened. The train B valves will operate 35 seconds after the train A valves.

The suppression pooling cooling mode is manually initiated. If either a LPCI injection or a containment spray signal is generated after initiation of the suppression pool cooling mode of operation, the system will automatically realign to the respective mode of operation demanded by the signal.

3.2.3.4 Success Criteria

Low Pressure Coolant Injection

Injection to the reactor pressure vessel from anyone of loops A, B or C tith the flow path through the heat exchangers or the heat exchanger bypass valve is considered a success. The fault trees developed for each train form the primary input to function V as shown in Appendix E.

Containment Spray

Flow to the containment spray headers from either loop A or B with the flow path through the heat exchangers is considered a success. The fault trees developed for each train form one of the primary inputs to function W as shown in Appendix E.

Suppression Pool Cooling

Flow to the suppression pool from either loop A or B with the flow path through the heat exchangers is considered a success. The fault trees developed for each train form one of the primary inputs to function W as shown in Appendix E.

3.2.4 LOV PRESSURE CORE SPRAY, E21

The purpose of the Low Pressure Core Spray (LPCS) system is to automatically provide coolant to the reactor pressure vessel during accidents when the pressure is low. The Automatic Depressurization System (ADS) can be used in conjunction with LPCS to attain a low enough system pressure for injection to occur. A simplified system diagram is shown in Figure 3.2.4-1.

3.2.4.1 System Description

The LPCS system consists of a single train with motor-operated and manual valves and a motor driven pump. Suction is taken from the suppression pool through a suction strainer and injection is through the reactor pressure vessel via a sparger which surrounds the core just inside the core shroud.

The LPCS pump is designed to operate with a maximum discharge head of 520 psig. The pump is designed to deliver rated flow of 6,110 gpm at a discharge head of 128 psig within 40 seconds of an initiation (including diesel generator start and pump start time delay).

3.2.4.2 System Operation

The LPCS system is automatically initiated and controlled. Automatic initiation occurs at a low reactor pressure vessel water level of Level 1 or a high urywell pressure of 1.68 psig. This energizes the pump and aligns the valves.

Normally no operator actions are required for system initiation. However, if automatic initiation fails for any reason, the LPCS system can be manually initiated by depressing a manual initiation push button. This will energize the LOCA relays which will automatically cause the above mentioned automatic actions to occur.

3.2.4.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.4.-1.

The LPCS system major dependencies are DC control power for initiating the actuation relay logic and LPCS pump breaker, AC power for operating the LPCS pump and valves, and LPCS pump room cooling.



The DC power is provided by Division 1 125VDC bus ED-1-A. Power for the LPCS pump is provided by Division 1 4,160VAC Bus EH-11, and power for the valves and room cooler is provided by Division 3 480VAC bus EF-1-A.

LPCS room cooling is provided by the ECCS Pump Room Cooling System, M39. Room cooling is not required for the initiation of the system. However, long term LPCS operation is dependent upon the room cooling system to maintain the environmental conditions within the qualified limits.

3.2.4.4 Success Criteria

Success of the LPCS system implies that either LPCS was automatically actuated at Level 1 or that it was manually actuated, and that coolant make-up to the reactor pressure vessel is being carrial out at the rated flow. The fault tree developed for this system is one of the inputs to the failure of the low pressure injection system function in the event trees (V). The exact relationship is shown in the functional fault trees in Appendix E.

3.2.5 HIGH PRESSURE CORE SPRAY, E22

The purpose of the High Pressure Core Spray (HPCS) system is to automatically provide coolant to the reactor vessel during accidents when the pressure remains high. Sufficient water inventory is maintained until the reactor is depressurized to a level where the Low Pressure Core Spray and Low Pressure Coolant Injection systems can be placed into operation. The HPCS system is also capable of performing the functions of the Reactor Core Isolation Cooling (RCIC) system in the event of KCIC system failure. A simplified diagram of the system is shown in Figure 3.2.5-1.

3.2.5.1 System Description

The HPCS system consists of a single train with motor-operated valves and a motor driven pump. Suction is taken from two possible water sources. The Condensate Storage Tank (CST) is the preferred source. When a low level in the CST or a high level in the suppression pool is sensed, suction is automatically aligned to the suppression pool. Injection to the reactor vessel is via a sparger which surrounds the core just inside the core shroud.

The HPCS system is designed to pump water into the reactor vessel over a wide range of pressures. When the system is started, initial flow rate is established by primary system pressure. For reactor pressures of 1,177 psid (differential pressure between the reactor vessel and the succion source), the minimum rated flow is 517 gpm. As vessel pressure decreases flow will increase. When vessel pressure reaches 200 psid the system rated core spray flow is 6,110 gpm. A restricting orifice in the pump discharge limits flow to a maximum designed runout flow of 7,800 gpm with reactor depressurized. The HPCS pump and motor are capable of delivering rated flow at full reactor pressure within 27 seconds of an initiation. This includes the time for the D.vision 3 diesel generator to start and supply power to bus EH-13 if necessary.



3.2.5.2 System Operation

The HPCS system is initiated automatically if a low reactor vessel water level of Level 2 or a high dryvels pressure of 1.68 psig is sensed. This energizes the pump, starts the HPCS diesel generator, and aligns the valves.

Since the CST is designed to be the initial suction sour for the HPCS system, the CST suction valve, F001, is normally open and F0015, the suppression pool suction valve, is closed. Suction is automatically switched to the suppression pool upon either low CST level or high suppression pool level. The CST suction valve closes when the suppression pool suction valve is fully open.

The HPCS system is automatically isolated when the reactor water level reaches Level 8. At this pint, the HPCS injection valve closes and the minimum flow valve to the suppression pool opens. The HPCS pump continues to run. A Level 3 signal will reopen the valve.

3.2.5.3 System Interf ' e and Dependencies

The system interfaces and dependencies are shown in Table 3.2.5-1.

The HPCS system major dependencies are DC control power for initiating the actuation relay logic and HPCS pump breaker, AC power for operating the HPCS pump and valves, and HPCS pump room cooling.

The DC power is provided by Division 3 125VDC bus ED-1-C. Power for the HPCS pump is provided by Division 3 4,160VAC Bus EH-13, and power for the valves and room cooler is provided by Division 3 480VAC bus EF-1-E. It should be noted that Division 3 electric power (AC and DC) is dedicated to HPCS and its supporting systems.

HPCS room cooling is provided by the ECCS Pump Room Cooling System, M39. The system is not required for the initiation of the system. However, long term operation is dependent upon the room cooling system to maintain the environmental conditions within the qualified limits.

The HPCS and RCIC systems share a common CST suction valve F0518. This is a normally open manual valve. Failure of this valve will fail the CST as a suction source to both HPCS and RCIC.

3.2.5.4 Success Criteria

Success of the HPCS system implies that either HPCS was automatically actuated at Level 2 or that it was manually actuated, and that coolant make-up to the reactor vessel is being carried out at the rated flow. It also implies that switchover from CST suction to suppression pool suction is carried out when CST level is low. The fault tree developed for this system is one of the inputs to the failure of the high pressure core spray function in the event trees (U1). The exact relationship is shown in the functional fault tree in Appendix E.

3.2.6 REACTOR CORE ISOLATION COOLING, E51

The purpose of the Reactor Core Isolation cooling (RCIC) System is to ensure that sufficient reactor water inventory is maintained in the reactor vessel during vessel isolation conditions to permit adequate core cooling to take place.

During accident conditions, the RCIC system is capable of providing coolant injection into the RPV for high pressure accident scenarios. A simplified diagram for the system is shown in Figure 3.2.6-1.

3.2.6.1 System Description

The RCIC system is a single train system which consists of a steam-driven turbine, an appointed pump assembly, valve, and instrumentation. Suction is taken from either the condensate storage tank (CST), or the suppression pool. The RCIC pump discharges the water through a spray nozzle inside the reactor pressure vessel (RPV) head.

The RCIC pump is capable of providing a constant 725 gpm flow rate, for RPV pressures ranging between 1,192 psia and 165 psia. MAAP (Modular Accident Analysis Program) assumes RCIC operation down to 20 psig. 25 gpm of the system flow is recirculated to the RCIC pump lube oil cooler, providing 700 gpm injection into the RPV.

3.2.6.2 System Operation

During normal reactor operation, the RCIC system is in standby configuration. The system can be activated and shutdown manually or automatically. Automatic initiation occurs on a low reactor water level (Level 2). Automatic initiation of the RCIC system causes a trip of the main turbine and the Reactor Feed Pump Turbines. In addition, automatic alignment of required RCIC components will occur. Required cooling systems will receive concurrent automatic initiation signals on low reactor water level.

The RCIC system can be manually initiated by plant operators by arming and depressing the RCIC manual initiation switch. Plant and system response will be the same as for automatic initiation.

The RCIC suction supply can be manually transferred between the CST and the suppression pool.

The operators are directed to override the RCIC suction shift from the CST to the suppression pool for a Station Blackout. If the transfer has occurred, they are directed to return the suction configuration to the CST. The above manual actions are noted as they are specifically modeled in the RCIC fault tree.

3.2.6.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.6-1.

The major RCIC dependency is upon DC power. By design, RCI is ca,able of initiation and operation independent of AC power, plant service air, and any

external cooling water systems. All components and control systems necessary for the initiation of the KCIC system are powered from the plant emergency DC electrical system.

Other system components are supplied from emergency and non-emergency backed AC power supplies. None of these components are required for system initiation. The emergency backed components are typically associated with isolation requirements. The non-emergency backed components are not required for any safety or reliability based system function.

Instrument Air is provided only to RCIC steam supply and exhaust drain line valves.

RCIC room cooling is provided by the ECCS Pump Room Cooling System, M39. The system is not required for the initiation of the system.

3.2.6.4 Success Criteria

RCIC is assumed to be a success path for the following initiating events:

Small LOCA (S2)
 Loss of FCS Transient (T2)
 PCS Avail(ble Transient (T3A)
 Loss of Feedwater Transient (T3B)
 Loss of Offsite Power (T1)
 Station Blackout (T1-B)

For each of the initiating events in which RCIC is considered a success path, the RCIC system is required to provide full flow (700 gpm) into the reactor vessel for a twenty-four hour accident duration. The fault tree developed for this system is one of the inputs to the failure of the reactor core isolation cooling function in the event trees (U2). The exact relationship is shown in the functional fault tree in Appendix E.

3.2.7 EMERGENCY CLOSED COOLING, P42

The ECC system provides cooling to selected loads for selected modes of normal reactor operation as well as during a loss of coolant accident (LOCA) or a loss of offsite power (LOOP). Motor operated valves automatically align on a LOCA or LOOP signal to provide cooling to the control complex chillers. These chillers normally receive cooling water from the Nuclear Closed Cooling (NCC) system, P43. A simplified diagram of the system is shown in Figures 3.2.7-1 and 3.2.7-2.

3.2.7.1 System Description

The ECC system is divided into two independent loops each consisting of a pump, heat exchanger, surge tank, valves and interconnecting piping. A chemical addition tank is shared by the two loops. The ECC heat exchangers are cooled by the Emergency Service Water system. The pumps and motor operated valves receive power from diesel backed buses.

The ECC is designed to yield a maximum expected equipment cooling water temperature of 95°F.

ECC is designed such that in the event of a single active or passive failure in the system, cooling water can be supplied to either of the Engineered Safeguards Features divisions.

3.2.7.2 System Operation

ECC is required to supply equipment cooling to the Residual Heat Removal pumps and room coolers and the Reactor Core Isolation Cooling room cooler during reactor isolation in hot standby. The initiation of the system for this mode of operation is a remote-manual function.

ECC is required to supply cooling water to support the Residual Seat Removal system in the normal shutdown mode. The initiation of ECC for this mode is a manual operation and is dependent on the specific RHR system requirements for cooling water.

The ECC system provides cooling to selected loads during a loss of coolant accident (LOCA) or a loss of offsite power (LOOP). Motor operated valves automatically align on a LOCA or LOOP signal to provide cooling to the control complex chillers. These chillers normally receive cooling water from the Nuclear Closed Cooling (NCC) system, P43.

ECC is designed such that in the event of a single active or passive failure in the system, cooling water can be supplied to either of the Engineered Safeguards Features divisions.

3.2.7.3 Syst m Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.7-1.

The system is dependent upon the following electrical supplies:

EF-1-A	(A valves)
EF-1-B	(Pump A)
EF-1-C	(B valves)
EF-1-D	(Pump B)

ED-1-A (Pump A controls) ED-1-B (Pump B controls)

The ECC major dependencies are DC control power for initiation logic and control logic, AC power for pumps and valves, and Emergency Service Water. Dependencies on Instrument Air, P52, and Two-Bed Demineralized Water, P21, or Emergency Service Water, P45, for make-up water were not needed for the fault tree models developed. The dependency on Emergency Pump Area Cooling for HVAC was not incorporated into the fault tree model as not being needed for the duration of the event.

DC power for Division 1 control logic and initiation logic is supplied by Bus ED-1-A. Bus ED-1-B supplies DC power to the Division 2 control logic and initiation logic. Because train A ECC is in³⁺³ ted during Reactor Core Isolation Cooling, there is an initiation signa m Division 2 to train A ECC. AC power is supplied from divisionally sepa ced AC 480 volt buses.



3.2.7.4 Success Criteria

ECC is required to supply cooling water for 24 hours following a LOCA or transient. The fault tree developed for this system provides inputs to the frontline systems.

3.2.8 EMERGENCY SERVICE WATER, P45

The Emergency Service Water (ESW) system supplies cooling water to equipment (including RHR, diesel generators, and emergency closed cooling (tube side of heat exchanger)) required for normal and emergency shutdown of the reactor. It can also provide water to Fire Protection, Fuel Pool Cooling and Cleanup, Emergency Closed Cooling (shell side of heat exchanger), Residual Heat Removal (for containment flooding), Standby Liquid Control, and the ESW Screen Wash (for deicing). A simplified diagram of the system is shown in Figure 3.2.8-1.

3.2.8.1 System Description

The source of water for the ESW system is Lake Erie. The ESW system is made up of three independent trains. Each train consists of a motor driven pump, motor operated valves, and heat exchangers. Train C is dedicated to the High Pressure Core S, ray system.

The Loop A and B pumps are designed for 12,900 gpm and are driven by 800 hp 4,160VAC motors powered from EH-11 and EH-12, respectively. The Loop C pump is designed for 960 gpm and is driven by a 75 hp 480VAC motor powered from EF-1-E.

The system is designed to operate with a maximum water temperature of 85°F.

The ESW pumps are all located in the Emergency Service Water Pumphouse. Because of the relative location of the system components, local access to the ESW system would not be affected by either containment venting or failure. Because of the large size of the pumphouse and the presence of louvers on the valls, ample room ventilation was assumed available and a loss of ESW Pumphouse Ventilation, M32, was not considered to fail the pumps.

3.2.8.2 System Operation

ESW loops A and B automatically start within 18.5 seconds following receipt of any of the following signals: Division 1 or 2 diesel starts, or drywell high pressure, or RPV level 1, or loss of offsite power, or (for loop A only) initiation of RCIC.

ESV loop C automatically starts 28 seconds after receipt of any of the following signals: Division 3 diesel start, or high drywell pressure, or RPV level 2.

ESW loop B can be manually aligned to RHR loop B to provide the capability to flood the containment.

ESW loops A and B can be manually aligned to provide an emergency make-up to the ECC surge tanks for the respective loops.

ESV loop B can be manually aligned to provide an emergency make-up to the SLC surge tank for the respective loops.

3.2.8.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.8-1.

The Emergency Service Water system major dependencies are DC control power to the pumps and AC power for operating the valves and pumps. ESW train A receives DC power form ED-1-A, train B from ED-1-B, and train C from ED-1-C. AC power is supplied from divisionally separated sources.

Dependencies on Instrument Air were not needed for the fault trees and not developed. The dependency on ESW Pumphouse Ventilation system was not incorporated into the ESW fault tree model as not being needed for the duration of the events.

3.2.8.4 Success Criteria

ESW must supply water for 24 that there is 1000 g = LOCA or transient. The fault trees developed for this support stem provide inputs to the front line systems and also one of the inputs to the failure of the low pressure injection (ESW crossie) function in the event trees (Va). The exect relationship is shown in the functional fault tree in Appendix E.

3.2.9 SERVICE/INSTRUMENT AIR SYSTEMS, P51/P52

The purpose of the Instrument Air system is to supply clean, dry, oil free air to various control and instrumentation functions throughout the plant. For the IPE, the purpose of the Service Air system in to supply air to the Instrument Air system. A simplified diagram of the service and instrument air systems is shown in Figure 3.2.9-1.

3.2.9.1 System Description

The Service Air and Instrument Air system each consist of two separate trains, one for each Unit. The Service Air trains are interconnected to through two motor operated valves (1P51-F0090 and 2P51-F0090). The Service Air trains are also connected to the Instrument Air trains through check valves (1P51-F0532 and 2P52-F0532) and pneumatic valves (1P52-F0050 and 2P52-F0050). The Instrument Air trains are interconnected through two motor operated valves (1P52-F0210 and 2P52-F0210). Each train of the Service Air and Instrument Air systems consist of an air compressor and a receiver tank. Compressed air flows from the receiver tank through the distribution piping to components in the plant.

3.2.9.2 System Operation

Under normal plant operating conditions, the instrument air for both Units will be supplied by one Service or Instrument Air compressor. Preferred system configuration is to have one compressor running with at least one compressor in standby. The preferred alignment is to have a compressor from the opposite unit in standby to ensure an air supply on a loss of either the Unit 1 or 2 supply bus. Normal system operating pressure range is 120-130 psig.

3.2.9.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.9-1.

The major dependencies of the Service and Instrument Air systems are electrical power and Nuclear Closed Cooling.

Service and Instrument Air systems are non-safety systems and thus are not supplied by diesel backed electrical power. The exception is for the Instrument Air Containmert and Dryvell isolation valves which are safety related.

The Unit 1 Service and Instrument Air Compressors are supplied from 4.6KV BUS H-12. The Unit 2 compressors are supplied from Bus H-22. The 480VAC, 120VAC, and 125VDC supplied Service and Instrument Air components are powered from the corresponding Units 4.16KV Bus.

Component cooling is provided by the Nuclear Closed Cooling System. Room cooling for the systems is provided by the Controlled Access and Miscellaneous Equipment Area HVAC System (M21). Cooling under accident conditions is also provided indirectly by the Emergency Closed Cooling Pump Area Cooling System (M28) due to the proximity of the compressors to the Emergency Closed Cooling System. It is assumed for this analysis that neither room cooling system is required for Instrument and Service Air System success for the accident duration.

3.2.9.4 Success Criteria

The success criteria for Service and Instrument Ai: is not dependent upon plant initiators.

The system is required for long-term successful operation of the non-ADS Safety Relief Valves (SRVs). System success is defined as provided at least one operable compressor and a flow path to the SRV Instrument Air distribution system.

The fault trees developed for the P51/P52 systems are linked to other systemic fault trees as they are support systems.

3.2.10 SAFETY RELATED INSTRUMENT AIR SYSTEM P57

The purpose of the Safety Related Instrument Air (SRIA) System is to supply clean, dry, oil free air to the Automatic Depressurization System (ADS), Safety Relief Valve Accumulators and to the accumulator for one non-ADS SRV (B21-F051D). A simplified diagram of the system is shown in Figure 3.2.10-2.

3.2.10.1 System Description

The Safety Related Instrument Air System consists of an air compressor, air filters, air receiver tanks, two air storage tanks, and two separate air headers for distribution. The "A" header charges the four accumulators

associated with the ADS relief valves and the one non-ADS valve. The "B" header charges the four accumulators associated with the other four ADS valves.

The Safety Related Instrument Ai: System fulfills its normal function without operator action. The ADS Storage Tanks supply make-up air to the ADS accumulators for any leakage from the ADS system. When air pressure decreases to approximately 160 psig, the air compressor will automatically start to recharge the system to approximately 170 psig and will automatically stop.

The ADS Storage Tanks provide a volume of 1.350 cubic feet of compressed air. Extrapolation of an engineering design calculation indicates that up to 336 actuations per train can be achieved. This accounts for system leakage over a seven day period. Pipe fittings are provided for temporary connection of portable air cylinders to each header as a backup source of compressed air. Once connected, these cylinders would be used to restore system pressure and then disconnected.

3.2.10.2 System Operation

In normal operation, the Safety Related Instrument Air System Compressor will be instandby configuration, cycling on and off to maintain system pressure between 160 psig and 170 psig.

In standby configuration, the compressor will auto start when system pressure decreases to approximately 160 psig. The compressor will automatically shutdown when system pressure increases to approximately 170 psig.

3.2.10.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.10-1.

The only major dependency of the Safety Related Instrument Air System is upon the plant electrical system. The containment and drywell isolation valves are su plied by diesel-backed electrical power. 480VAC Bus EF-1-A supplies valves 1P57-F015A and 1P57-F020A. 480VAC Bus EF-1-C supplies valves 1P57-F015B and 1P57-F020B. The compressor is supplied from a non-emergency power supply (Bus F-1-C).

No component cooling system is required for system operation.

Room cooling is provided by the Auxiliary Building HVAC System (M38) and the Intermediate Building Ventilation System (M33). The HVAC systems were not modeled.

3.2.10.4 Success Criteria

System success is defined per individual train of the Safety Related Instrument Air System.

Individual train success requires the operability of a flow path from the air storage tank to the ADS valves for the event duration. However for long term accident scenarios, success criteria will additionally require the operability of the Safety Related Instrument Air Compressor or connection of air cylinders to the air system.

The system is required for successful operation of the ADS valves and the one non-ADS valve.

The fault trees developed for the P57 system are linked to the ADS systemic fault trees as P57 is a support system.

3.2.11 FIRE PROTECTION, P54

For the IPE the purpose of the Fire Protection system is to provide an alternate supply of water to the suppression pool or the reactor pressure vessel in the event that the Emergency Core Cooling systems are unavailable. A simplified diagram for the system is shown in Table 3.2.11-1.

3.2.11.1 System Description

Although the Perry Fire Protection system includes both a motor driven pump and a diesel driven pump, only the diesel driven pump will be included in the model. The Diesel Fire Service Pump with a design capacity of 2,500 gpm at 125 psig is directly coupled to a diesel engine through a right angle coupling with a non-reversing mechanism to prevent backspin of the diesel. The diesel engine is equipped with an electric starter which is supplied by 2 independent battery banks. A battery charger is supplied to automatically maintain the batteries in a fully charged condition. During operation the diesel control and alarm circuitry is powered by a shaft driven alternator.

3.2.11.2 System Operation

For the Perry IPE there are no automatic functions associated with the fire protection system.

The diesel driven fire pump is started and the valves aligned to enable fire water to be pumped into the vessel through the feedwater injection line.

3.2.11.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.11-1.

The portion of the fire protection system modeled for the TPE is not dependent on any of the other support systems within the IPE model. The diesel driven pump has its own battery sets and the shaft driven alternator provides control power. Each of the valves is manipulated by hand.

3.2.11.4 Success Criteria

The diecel driven fire pump starts and injects into the Reactor Pressure Vessel.

The fault trees developed for this system are one of the inputs to the failure of the fire protection function in events trees (Va). The exact relationship is shown in the functional lault trees in Appendix E.



3.2.12 D.C. ELECTRICAL SYSTEM, R42

The purpose of the Class 1E DC power system is to provide continuous 125 VDC power for control and switching of the components in those systems needed for the safe shutdown of the plant.

The emergency DC power system consists of three divisions. These divisions are completely separate and independent with each designed to provide DC power to the respective divisional loads required for safe shutdown of the plant. A simplified diagram for the system is shown in Figure 3.2.12-1, 2, and 3.

3.2.12.1 System Description

Division 1 and 2

Unit 1 Division 1 and 2 buses (ED-1-A and ED-1-B) are each connected to a 60 ceil lead acid 1,200 ampere-hour battery. The batteries at sized to supply the required DC loads for a minimum of 2 hours without any cell voltage decreasing to 1.75 Volts/cell or the total battery voltage decreasing to less than 105VDC.

The Class 1E DC buses are also connected to 400 ampere battery chargers and 400 ampere reserve battery chargers. All Class 1E battery chargers are solid state and are backed by the respective division 1 or 2 diesel generators.

Division 3

The Division 3 bus (ED-1-C) is connected to a 60 cell lead acid battery rated at 100 ampere-hours. ED-1-C is also connected to a 50 ampere battery charger and a 50 ampere reserve battery charger. The battery clargers are backed by the Division 3 diesel generator.

The Unit 2 DC buses, ED-2-A and ED-2-B and ED-2-C, may be manually crossiled to the respective Unit 1 DC buses in the event that the Unit 1 batteries and chargers are not rvailable due to either maintenance (equalizing charge on batteries, charger maintenance, etc.) or random failure. The Unit 2 battery chargers are not diesel backed.

3.2.12.2 System Operation

If the battery chargers and reserve battery chargers become inoperable or if AC power is lost, the batteries will automatically pick up the load.

3.2.12.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.12-1.

The Class 1E DC power system is dependent on the availability of the AC power system for long term operation. Following Station Blackout with manual load shedding and crosstieing Unit 1 and 2 batteries, the batteries have sufficient capacity for 22 hours.



The DC power system is also dependent on the MCC, Switchgear and Miscellaneous Electrical Equipment Areas HVAC, M23, to maintain the ambient temperatures within the design limits. Battery Rooms Enhaust System, W24, is also needed to dissipate the hydrogen generated from the operation of the batteries. These systems were not modeled as being necessary for the duration of the event.

3.2.12.4 Success Criteria

The DC power system (hatteries, chargers and reserve chargers) must supply at least 105VDC for 2 hours following a LOCA or transient other than a Station Blackout.

The batteries must supply at least 105 VDC for 22 hours following a Station Blackout. After 22 hours AC power must be restored. The Unit 1 and Unit 2, Divisions 1 and 2 must also be crosstied and nonessential loads shed for the batteries to last 22 hours.

The fault trees developed for the D.C. electrical system are linked to other systemic fault trees.

3.2.13 AC POWER, STANDBY DIESEL GENERATOR SYSTEM, R43 HIGH PRESSURE CORE SPRAY DIESEL GENERATOR SYSTEM, E22B

The AC power system provides the source of AC power to those systems needed to safely shutdown the plant. A simplified diagram for the system is shown in Figure 3.2.13-1.

3.2.13.1 System Description

The AC power system consists of three 4,160VAC Class 1E buses, their associated stub buses and switchgear, and the diesel generator systems. The Division 1 and 2 buses (EH-11 and EH-12) provide an independent source of AC power to the majority of the engineered safeguard features (ESF) of Perry. The Division 3 bus (EH-13) is dedicated to the High Tressure Core Spray system and its support systems.

The Unit 1 interbus transformer is considered the preferred source of power to the 4,160VAC Class 1E buses with the Unit 2 interbus transformer being the alternate preferred source and the diesels being the emergency source. The interbus transformers receive power from 13.8KV buses L10 and L20 which receive power from the Unit 1 and 2 startup transformers.

3.2.13.2 System Operation

The Division 1 and 2 diesel generators automatically start on an RHR LOCA signal or an undervoltage signal on the associated bus. Large loads are sequenced at approximately 5 second intervals to ensure that large motors will have attained rated speed and that voltage and frequency will have stabilized before succeeding loads are applied.

The Division 1 and 2 stub buses (XH-11 and XH-12) are stripped from buses EH-11 and EH-12 during an automatic diesel generator start due to an RHR LOCA signal. The stub bus tie breaker may be reclosed after placing the LOCA

Bypass Reylock Switch to BYPASS then taking the control switch for the breaker to CLOSE. During a bus undervoltage event without en RHR LOCA signal, the stub buses are not stripped.

The Division 3 diesel generator starts and loads on a HPCS LOCA signal or an undervoltage signal of Bus EH-13.

3.2.13.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.13-1.

Each of the Division 1 and 2 diesel generators depend on 5 systems for its operation: Standby Diesel Generator Starting Air, R44: Standby Diesel Generator Fuel Oil, R45: Standby Diesel Generator Jacket Water Cooling, R46: Standby Diesel Generator Lube Oil, R47; and Standby Diesel Generator Exhaust/Intake Crankcase, R48. The Division 3 diesel generator has these same systems incorporated into its design. All of these systems are treated as part of the diesel generator.

In addition, each of the diesel generators also depend on several other systems for long term operation. Emergency Service Water, P45, transports a large portion of the heat generated during operation of the diesel generators to Lake Erie. Diesel Generator Building Ventilation, M43, dissipates the balance of the heat generated to the atmosphere. Emergency DC Pover, R42, provides control pover to the diesel generators. Each of these systems provides support to the diesel generators by separate divisions. There are no dependencies which are interdivisional.

3.2.13.4 Success Criteria

Emergency AC power system supplies AC power for at least 24 hours following a LOCA or transient other than a Station Blackout.

Following a Station Blackout, AC power must be restored within 22 hours or within the time specified in the sequence.

Given a failure of the automatic initiation, the diesel generators must be manually started in the event of loss of offsite power.

The fault trees developed for this system are input as support systems to frontling systems and one of the inputs to the failure of the AC power function in the loss of offsite power event trees (B1). The exact relationship is shown in the functional fault trees in Appendix E.

3.2.14 SUPPRESSION POOL MAKE-UP, G43 DRYWELL VACUUM RELIEF, M16

The Suppression Pool Make-up System (SPMU) provides a rapid means of gravity feeding the suppression pool from the upper containment pool to compensate for any conservable water loss associated with a Loss-of-Coolant-Accident (LOCA). A simplified diagram for the system is shown in Figure 3.2.14-1.

The Drywell Vacuum Relief System provides a means to limit the buildup of negative pressure in the drywell in order to protect the drywell from

flooding following a small break in the containment. The system also provides for dryvell to containment isolation during LOCF conditions. A simplified diagram for the system is shown in Figure 3.2.14-2.

3.2.14.1 System Description

The Suppression Pool Make-up system is divided into two 100% capacity, independent trains, each consisting of piping and two downstream motor operated isolation valves. Train A is physically separated from Train B. The suppression pool volume, between the normal low vater level (LVL) and minimum post-accident pool level, plus the make-up volume from the upper pool is adequate to supply all possible post-accident entrapment volumes for suppression pool vater. The long term post-accident containment pressure and suppression pool temperature takes credit for the volume added from the upper containment pool.

The system gravity dump time through one of the two redundant lines is less than or equal to the minimum pump time. Fump time is determined by dividing pumping volume (upper pool make-up volume plus volume in the suppression pool stored between LWL and minimum top vent coverage) by the total maximum runout flow rate from all five ECCS pumps.

The Drywell Vacuum Relief System is divided into two independent relief lines. Each line consists of a 10" vent line, a motor-operated drywell vacuum relief valve, and a swing check valve. If a vacuum is sensed in the drywell, the vacuum relief valves (1M16-F010A,B) open. The differential pressure between the drywell and containment will cause air to be drawn into the vent pipe, through the swing check valves (1M16-F020A,B) and the drywell vacuum relief valves (1M16-F010A,B) and into the drywell.

The Drywell Vacuum Relief System is designed to limit a buildup of negative pressure inside the drywell and to prevent suppression pool water from overflowing the suppression pool weir wall which would result in partial flooding of the drywell following a small pipe break in the containment.

The drywell vacuum relief lines are spaced around the drywell to meet space separation requirements so that direct "shine" or "streaming" of radiation from inside the drywell is minimized.

3.2.14.2 System Operation

The opening of the SPMU system values is signaled by a series combination of a Lo-Lo suppression pool level and a LOCA signal. The Lo-Lo level is 18 inches below the normal low water level. Since maximum ECCS pump flow lowers the suppression pool at a rate of approximately .88 feet per minute, there is approximately 1.5 minutes between the start of ECCS flow and generation of a dump initiation signal taking into account only for maximum ECCS system of flow from the suppression pool. The actual time between a LOCA and suppression pool low level signal is actually one to two minutes longer than this because vessel inventory mass is added to the suppression pool during blowdown steam condensation. This built-in delay assures that the Dryvell pressure transient due to vessel blowdown has ended prior to dumping of the upper pool and corresponding increase of vent submergence. The SPMU system dump valves can also be signaled to open by a LOCA signal in series with a 30 minute timer where the timer itself is started by the LOCA signal. This path of initiation logic is independent of sup; ssion pool level and is specifically directed towards insuring that the combined upper pool and suppression pool volumes are available as a heat sink for "small" breaks which do not lower the suppression pool to the Lo-Lo level trip, but continue to dump vessel blowdown energy into the suppression pool. The minimum suppression pool volume, however, is adequate to meet all heat sink requirements without an upper pool dump.

Adequate water can be provided to the suppression pool even if one of the SPMU trains fails to initiate. One line can deliver the entire make-up volume in about 8 minutes and 40 seconds. In the remote possibility that both lines fail to initiate, the Control Room operator can manually initiate the system. This is done by first checking that a LOCA permissive signal is present. The Control Room operator then initiates the system by arming and depressing the Train A and Train B Manual Initiation Switches.

If a drywell vacuum condition is sensed, the isolation valve will automatically open until the vacuum signal is no longer present, then the valve will automatically reshut. If a LOCA signal (BOP isolation - RPV water level 2 or High drywell preusure) is received, the vacuum relief isolation valve will close. The valve will remain closed until either a drywell vacuum signal is received or the operator places the control switch to OPEN. It should be noted that the isolation valve will remain in the OPEN position indefinitely. In order to shut the isolation valve, the vacuum signal must be cleared and the operator must place the control switch to the CLOSE position.

The drywell vacuum relief check valves (M16-F020A,B) have no controls or interlocks associated with their operation. They function on a differential pressure across the valves to open and gravity to close.

3.2.14.3 System Interface and Dependencies

The system interfaces and dependencies for G43 are shown in Table 3.2.14-1. The system interfaces and dependencies for the M16 are shown in Table 3.2.14-2.

Electric Buses (required): for Suppression Pool Makeup	EF-1-A (A valves) EF-1-C (B valves) EK-1-Al (A valve controls) EK-1-Bl (B valve controls)
Electric Buses (required): for Drywell Vacuum Relief	EF-1-B (480 VAC for A isolation value) EF-1-D (480 VAC for B isolation value) EK-1-A1 (120 VAC for indication) EK-1-B1 (120 VAC for indication)

The SPMU dependencies are 120VAC control power for initiation logic and control logic, 480VAC power for the main flow path motor operated valve operation, and the water supply coming from inventory in the upper containment pools.

The AC power for the Division 1 control logic and initiation logic is supplied by Bus EK-1-A1. Bus EK-1-B1 supplies AC power to the Division 2 control logic and the initiation logic. Motor operated valve power is supplied from divisionally separated 480 VAC buses.

The Drywell Vacuum Relief System dependencies are 120VAC control power for isolation valve logic, 480VAC power for the motor operated isolation valve operation, and instrument air for testing of the check valves.

Bus EF-1-B supplies Division 1, 480VAC power to the M16-F001A isolation valve for operation and control. Bus EF-1-D supplies Division 2, 480VAC power to the M16-F0010B isolation valve for operation and control. Three 120 VAC sources (buses EK-1-A1 and EK-1-B1 and distribution panel K-1-H) supply power for indicator lights, ERIS, and check valve testing. Instrument Air, P52, is used to open the relief check valves for periodic exercising so that operability is assured.

3.2.14.4 Success Criteria

SPMU is required to provide a rapid means of gravity feeding the suppression pool from the upper containment pool to compensate for any conceivable water loss associated with a LOCA. This ensures that there is an adequate water volume in the suppression pool to keep the suppression pool vents covered for all break sizes.

The dump valves are required to open for a lo-Lo level in the suppression with a simultaneous LOCA signal. The dump valves are also required to open for a LOCA signal that has been continually present for 30 minutes following its initiation. In this latter case the Lo-Lo level in the suppression is not required. This ensures an adequate long term heat sink is available regardless of the break size.

The fault trees developed for this system are one of the inputs to the failure of the containment venting function (Y) in the ATWS event trees. The exact relationship is shown in the functional fault trees in Appendix E.

The Drywell Vacuum Relief System is required to limit the buildup of negative pressure inside the drywell. This ensures that the suppression pool water will not overflow the suppression pool weir wall which would result in partial flooding of the drywell following a small break in the containment.

Following the blowdown phase of a LOCA, air initially contained in the drywell is full of steam. During this period the ECCS is injecting cooling water from the suppression pool into the reactor pressure vessel. When the reactor pressure vessel is flooded to the level of the break, water begins spilling onto the drywell, condensing the steam and causing rapid depressurization of the drywell, and a possible vacuum condition to be created. The Drywell Vacuum Relief System ensures that the vacuum condition will be mitigated.

The fault trees developed for this system are one of the inputs to the failure of the containment venting function (Y) in the ATWS event trees. The exact relationship is shown in the function fault trees in Appendix E.

3.2.15 DIESEL GENERATOR BUILDING VENTILATION, M43

The Diesel Generator Building Ventilation system functions to provide ventilating air to the diesel generator rooms. This air is provided to dissipate the heat generated by the diesel generators and miscellaneous equipment during operation. A simplified diagram for the M16 system is shown in Figure 3.2.15-1.

3.2.15.1 System Description

The Diesel Generator Building Ventilation system is designed to maintain the Diesel Generator Rooms at 120°F maximum with an outside temperature of 95°F and at 40°F minimum with an outside temperature of -5°F.

The system serves the three diesel generator rooms. Each room is served by two 100% capacity air fans, four 50% capacity motor operated exhaust louvers, outside air and recirculation dampers, and ductwork. One of the four exhaust louvers in the Division 1 and 2 diesel generator rooms is normally open, the other three are normally closed. All of the exhaust louvers in the Division 3 diesel generator room are normally closed. The system for each room is divided into two trains.

Both trains start when the diesel generator in that room starts. The amounts of outside and recirculated return air used for cooling are automatically controlled by outside air and recirculation dampers. Only one ventilation train is normally required to provide adequate room cooling. The other train can be shutdown. Inactive supply fans are automatically isolated by the outside air dampers. For the Division 1 and 2 diesel generator rooms, when neither fan in the rooms operate, the outside air dampers modulate to promote natural recirculation and the suxiliary room cooling fan operates to maintain acceptable room temperatures during standby conditions.

When the carbon dioxide fire suppression system is activated, outside air and exhaust air dampers close, the recirculation air dampers open, and all fans stop.

3.2.15.2 System Operation

Both trains of M43 in a room start when the diesel generator in that room starts. The amounts of outside and recirculated return air used for cooling are automatically controlled by outside air and recirculation dampers.

3.2.15.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.15-1.

The diesel generator building ventilation system is dependent only on the AC power system. There are no room coolers to be supported by a cooling water supply. There is no dependency on DC power.



3.2.15.4 Success Criteria

The diesel generator ventilation system must supply air to the diesel generator rooms within 15 minutes of the start of a diesel generator. Only one train is required to start and run for each division. The fault trees developed for these systems are input as support systems to the diesel generator fault trees.

3.2.16 CONDENSATE TRANSFER SYSTEM

The Plant Emergency Instructions, PEI-B13, provide six alternate methods for the injection of water into the reactor pressure vessel under accident conditions. These systems are utilized after the primary injection systems (i.e., ECCS, Feedwater and RCIC) fail to maintain RFV level above the Top of Active Fuel (TAF). A simplified diagram for the system is shown in Figure 3.2.16-1.

3.2.16.1 System Description

This alignment provides make-up into the RPV using the Condensate Transfer and Storage flush Water Supply to RHR Shutdown cooling to Feedwater Line or LPCI injection line for injection either outside or inside the shroud. This alignment requires one local valve in the AB 620' elevation to be operated. A simplified diagram for the Condensate Transfer Alternate Injection path is shown in Figure 3.2.16-1.

3.2.16.2 System Operation

Suction for this injection path is taken from the Condensate Storage Tank, pumped by Condensate Transfer Pumps, 1P11-COOIA and B and through Feedwater Flush Supply Valve 1E12-F360A or B into the RHR System. From there, flow can be diverted inside or outside the RPV shroud by directing flow through the LPCI injection line or the Shutdown Cooling to feedwater line.

3.2.16.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.16-1.

Electrical power is provided by offsite power.

Instrument Air is supplied to valve 1E12-F0300A/B/C. Failure of Instrument Air will cause the loss of this valve function and thus a loss of the injection path.

No component or room cooling is required for system operation.

The water supply is provided by the Condensate Storage Tank.

3.2.16.4 Success Criteria

For the Condensate Transfer Alternate Injection System, one 1,000 gpm pump is assumed to be required for system success.

The fault trees developed for each injection path form the primary input to function Va as shown in Appendix E.

3.2.17 CONTAINMENT VENTING (FPCC)

Plant Emergency Instruction PEI-D23-2 provides for 2 mechanisms for venting the containment in the event that the containment pressure cannot be maintained below the Containment Pressure Limit. One vent path is through the Fuel Pool Cooling and Cleanup system skimmers and piping. A simplified diagram for the system is shown in Figure 3.2.17-1.

3.2.17.1 System Description

The Fuel Pool and Cleanup system normally removes decay heat generated by spent fuel stored in the Fuel Storage pools and maintains the purity, clarity and level of the water in the upper pools. This system may also be used to vent the containment if the containment pressure cannot be maintained below the Containment Pressure Limit provided in PEI-D23-2.

The FPCC system is aligned to vent the containment through the 11 skimmers in the Fuel Transfer and Storage Poc. the Reactor Well and the Separator Storage Well, to the FPCC Surge Tank and into the fuel Handling Building atmosphere through the 5 skimmers in the Spent fuel Storage Pool.

3.2.17.2 System Operation

Venting of the containment must be manually aligned.

- a. Verify that at least 1 Fuel Handling Building HVAC Exhaust fan (OM40-CO002A, B or C) is in operation.
- b. Open Containment isolation motor operated valve 1G41-F0145.
- c. Open Containment isolation motor operated valve 1G41-F0140.

3.2.17.3 System Interface and Dependencies

The system interfaces and dependencies are shown in Table 3.2.17-1.

The systems are dependent upon the following electrical supplies:

EF-1-A (1G41-F0145) EF-1-B (OM40-C0002A) EF-1-C (1G41-F0140) EF-1-D (OM40-C0002B) EF-2-D (OM40-C0002C)

The dependency for this vent path is on electric power only if a containment isolation should occur prior to the loss of electric power. In this case the normally open inboard isolation valve 1G41-F0140 would be closed with no way for an operator to open it. The Fuel Handling Building Ventilation System exhaust fans, although dependent on electric power are not assumed to be needed for containment venting success.



3.2.17.4 Success Criteria

Any one vent path is considered a success. This system is the major input to function Y. Full details of the development of this function fault tree are given in Appendix E.

3.2.18 CONTAINMENT VENTING (RHR)

Plant Emergency Instruction PEI-D23-2 provides for 2 mechanisms for venting the containment in the event that the containment pressure cannot be maintained below the Containment Pressure Limit. One vent path is through the RHR Containment Spray headers and out through the Spent Fuel Storage Fool. Simplified diagrams are shown in figures 3.2.18-1 and 2.

3.2.18.1 System Description

In addition to providing containment heat removal through the containment spray mode of operation, the RHR containment spray headers can be used to vent the containment as described in PEI-D23-2.

The containment is vented by aligning the RHR containment spray headers by means of the RHR piping to the FPCC Supplement Cooling connection and into the Fuel Handling Building atmusphere through the Spent Fuel Storage Pool.

3.2.18.2 System Operation

Venting of the containment must be manually aligned.

- a. Open the FPCC to RHR Supply manual valve 1G41-F0559A.
- b. Verify that at least 1 Fuel Handling building HVAC Exhaust fan (OM40-C0002A, B or C) is in operation.
- c. Verify RHR valve 1E12-F0027A(B) is open.
- d. If the containment spray mode has not been initiated or if the KHR valves to the spray headers are closed, stop RHR pump A(B) and arm and depress the Containment Spray Manual Initiation push-button, 1E12A-63A(B).

If the loop to be placed in the venting mode is in operation, then depress the Containment Spray Loop A(B) Seal-In Reset push-button, 1E12A-S64A(B) to reset the initiation logic. Then stop RHR pump A(B).

- e. Close the RHR heat exchanger bypass motor operated valve 1E12-F0048A(B).
- f. Close the RHR heat exchanger outlet motor operated valve 1E12-F0003A(B).
- g. Open the RHR FPCC Supplement Cooling discharge manual valve 1E12-F0099A(B).



3.2.18.3 System Interface and Dependencies

The systems are dependent upon the following electrical supplies:

EF-1-A (RHR A valves) EF-1-B (OM40-CO02A) EF-1-D (RHR B valves) (OM40-CO002B) EF-2-D (OM40-C0002C)

3.2.18.4 Success Criteria

Any one vent path is considered a success. This system is the major input to function Y. Full details of the development of this function fault tree are given in Appendix E.





3.3 SEQUENCE QUANTIFICATION

3.3.1 LIST OF GENERIC DATA

NUREG/CR-4550 (Drouin, 198 was adopted as the primary source for generic data. A review of the data _see in this study was made against other sources of data (NUS BWR Generic (NUS, 1982), NUREG/CR-1363 (Miller, 1982), NUREG/CR-1740 (Trojovsky, 1°84), NUREG/CR-3831 (Kahl, 1985), IEEE-500, WASH-1400 (NRC, 1985), GESS-R II (GE, 1982), and Kuosheng PRA, (AEC, 1985)) to establish that NUREG/CR-4550 data are of the same order of magnitude. Since the data contained in NUREG/CR-4550 are a compilation of many sources, a review of the base documents was also made, when possible, to verify the data being used and to assist in establishing component boundaries for use in system modeling. For those components not contained in NUREG/CR-4550, other sources of generic data were used. For a very few components not described elsewhere, assumptions of similarity were made to estimate failure rates.

3.3.2 PLANT SPECIFIC DATA AND ANALYSIS

Because of the short operating history of Perry, insufficient data was available to provide a meaningful statistical sample of failures upon which to build a data base. It was assumed that the greater population base of generic data offered a better estimate of fullure data than the Perry data that was available. Perry failure values that were based on zero or one failure from a small population were not used. Large components such as Emergency Core Cooling Pumps have not experienced failures at Perry to date. Generic failure data was used for these components. The diesel generators do have a failure history for some modes of failure. This bistory was analyzed to estimate a failure rate for the diesels.

Due to the variance of system unavailability from testing and maintenance from plant to plant, Perry Unit 1 documents were used to determine unavailability of the Emergency Core Cooling Systems and the Reactor Core Isolation Cooling system due to testing and maintenance.

A lognormal distribution was assumed for nearly all of the data contained in NUREG/CR-4550 and other documents examined. This distribution was also assumed for the Perry specific unavailabilities and failures used.

Table 3.3.2-1 presents the basic event data used in the Perry IPE. The table is sorted by component.

3.3.3 HUMAN FAILURE DATA (GENERIC AND PERRY)

3.3.3.1 Introduction

The objective of the human reliability analysis (HRA) is to provide estimates of the probabilities of the human interaction basic events included in the Perry Plant IPE logic model. In general, human interactions considered for inclusion in a PRA can be divided into three general classes according to the time phase in which they occur.



Type A HIs arise before an initiating event, when plant personnel can affect availability and safety of the plant by inadvertently leaving equipment disabled following test, maintenance and calibration activities.

Type B HIs are those HIs that result in, or contribute to, initiating events. Examples are: plant trips following mistakes during testing, failures to control feedwater leading to plant trip, etc. Type B events are almost invariably incorporated implicitly in the initiating event frequencies obtained from plant operating experience. No explicit consideration of Type B HIs has been included in this study.

Type C HIs cover a wide range of specific actions following an accident. There are two sub-categories of Type C: (1) operator action performed in response to an Emergency Operating Procedure (EOP), including manual backup on failure of automatic initiation of systems, and (2) recovery actions in response to unavailability of a safety function that failed because of equipment malfunction. Events in the first sub-category (Type CP) can either appear as headings in the event trees, or as basic events in system or functional fault trees, while recovery actions (Type CR) are addressed at the accident sequence cutset level.

The major effort in this study was the analysis of the Type CP events, and this is discussed in Section 3.3.3.3.

3.3.3.2 Pre-Initiating Event Human Interactions

Miscalibration of sensors leave an instrument channel such that it cannot actuate a given system as required. Common cause failure of actuation due to miscalibration was also considered. The potential for common cause miscalibration of multiple sensors of a given type or function due to human interaction was characterized as one tenth of the sensor failure probability.

The potential for incorrect system configuration following maintenance or surveillance was reviewed by verifying that the performance test would reveal an incorrect configuration fault. For the Perry IPE, restoration faults were not postulated for those systems or components with readily available control room indication of inoperability and bypassed indication, with daily position verification, or with administrative control for locked valve position verification. With these Type A guidelines, restoration faults were modeled for only the non-safety systems.

3.3.3.3 Post-Initiating-Event Human Interactions

ine plant logic model, the event trees and fault trees, were constructed to include human interaction basic events. For inclusion in the event or fault trees, these events are adequately defined in terms of the failure mode they represent e.g., operators fail to depressurize the reactor following a loss of high pressure injection. However, in order to quantify these events, i.e., estimate their probabilities, it is essential to define them in greater detail. For example, it is necessary to understand what cues and procedures the operators use to guide them to perform the required function, what they have to do to successfully accomplish that function, the time available, and other factors that might influence their probability of success or failure. These factors all are scenario specific. The first step in the HRA was,



therefore, to define the events as clearly as possible in preparation for the quantification. This was done by studying the scenarios to which the human interaction events contributed, and understand, among other things, the time line of the events.

Another function of this step of the HRA task is an identification of potential dependence between the human interaction events that occur in the model. Functional dependencies of the type. "if event A occurs, event B cannot be successful," are handled in the overall structure of the model, i.e., they are hardwired into the event tree structure. What is principally of concern here is the influence of success or f 'lure in a preceding event on the probability of success or failure of another event. There are a variety of reasons why the events may be probabilistically dependent: one important issue is that the cognitive processes needed to recognize the need for multiple actions may have common elements. To assist in the identification of such cognitively correlated HIs, the following groundrules are adopted:

- (a) If two HI events are associated with responses to the same plant status (e.g, initiate HPCS pump, initiate RCIC on failure of auto initiation at Level 2), the cognitive part of the failure probabilities are considered to be totally dependent.
- (b) As a corollary to this, if, in the chronological development of the scenarios, an HI failure event follow a successful HI, and the procedural instructions for both events are closely related, the cognitive failure probability of the second HI should be very small and can be neglected, since the success in the first event implies a successful recognition of the scenario.
- (c) If human interactions are i) separated by a significant time (i.e., time between cues or required responses is long), or ii) separated chronologically in the sequence by a successful action, or iii) responses to different cues in different parts of the EOPs, they may be regarded as being independent.
- (d) In addition, the easily memorized responses may be regarded as independent from these actions for which the procedures are expected to be providing the direction.

Other types of dependency, such as the fact that performing one function may take resources away from another is also considered by addressing, in the evaluation of the HEPs, the role of crew personnel, both in performing the actions called for, and in recovering from failure to execute correctly.

3.3.3.4 Quantification Approach

The model of human interactions used for the evaluation of a human error probabilities is the simple one that splits the response into two components, a detection, diagnosis and decision (DDD) phase and an execution phase. This is compatible with the ASEP methodology (Svain, 1987), the more recent EPRI proposed methodology (EPRI, 1991), and the HRA Mandbook (Svain, 1983), all of which were used in the quantification. Reference is made to these documents for details.

For the key time-critical human interactions, the time-reliability curve approach of the EPRI metholodgy (EPRI, 1991) was used to estimate the probability of failure in the DDD phase. The alternate approach of the EPRI methodology was used to evaluate the HEPs for those HIs considered dependent on the time critical HI or which are not time critical. A simplified THERP or ASEP approach was used to estimate the HEP for the execution phase. The details can be found in Appendix D. It should be noted that the quantification was performed on a sequence by sequence basis to more completely address the dependency issues.

The HEPs are given in Table 3.3.3-1.

3.3.4 COMMON CAUSE FAILURE DATA

The common cause failure analysis was performed following the general guidelines of NUREG/CR-4780 (Moslah, 1988). Stages 3 and 4 of the analysis rely on the existence of a data base that provides detailed descriptions of historical events related to both single as well as multiple component failures. However since CCFs are rare events, very limited plant specific experience of these failures is expected. Therefore, in this study, as recommended in NUREG/CR-4780, industry experience, as reported in Nuclear Power Experience (Stoller Corporation) has been used to derive common cause data. Since the information in NPE is obtained primarily from LERs, its value as a complete data base, reporting single as well as multiple failure January 1984. Thus, only the data up to 1984 is used in the quantification analysis.

As part of this analysis, the current Halliburton NUS component failure data base, which is based on the summary of information provided by the NPE event reports was modified to account for the Perry design. This data base contains an assessment of the historical events as they occurred at various plants. Due to the level of reporting, it is not always easy to interpret or assess the data objectively hence in some cases events have been subjectively assessed. The approach taken in NUREG/CR-4780, of recording the interpretation in terms of impact vectors, was followed in this study. The results in a pseudo PNPP specific data base. The data analysis is described in more . .1 in Appendix C2.

In order to determine which CCF events contribute significantly to the overall core damage frequency, an importance analysis of the core damage cutsets was performed. The measure of significance adopted was the Fussell-Vesely importance measure and a beta factor of 0.1 was used in the initial modeling of common cause failures. Events where importance measures resulted in a contribution to core damage frequencies of greater than 0.1% were included as significant.

On the basis of the above criteria the following CCFs were analyzed in detail:

ESW motor operated valves (ESMVCC)
 Diesel generators (DGDGCC)



-	ESW	motor	driven	pumps	(ESMPCC)
*	ECC	motor	driven	pumps	(ECMPCC)

The CCF probabilities used for each of the components is shown in Table 3.3.4-1. For all the events not analyzed in detail the screening values were retained in the final analysis.

3.3.5 QUANTIFICATION OF UNAVAILABILITIES OF SYSTEMS AND FUNCTIONS

The Ferry IPE was performed using a linked fault tree approach as described in NUREG/CR-2300 using the NUPRA FRA vorkstation. In performing a PRA in this manner, the functions defined by the event tree headings are the main building blocks of the quantification process. The quantified functions can be used to determine the overall contribution of a given function value, such as decay heat removal, to core damage. Each function is representative of the failure of one or more front line systems and/or human actions. Support systems are linked into the front line systems they support. A given function or combination of systems may be quantified several times to reflect the results of the quantification of each function are summarized in Table 5.3.5-1. The quantification process and the results are presented in detail in Appendix E of this report. The individual systems were quantified in the course of development of the fault trees. The results are reported in the individual system analysis files.

3.3.5.1 Summary of function Quantification Process

The accident sequence analysis task identifies safety functions that must be provided in order to prevent core damage following an initiating event. The function is defined by the systems success criteria, the mission time, important operator actions, and any sequence specific equipment unavailability, environmental, or phenomenological conditions that exist following a specific initiating event. The combination of the above used to develop the functional fault tree for a given initiator are first combined and linked with the appropriate support systems. In order to avoid developing a separate fault tree for each condition in which a system is required to respond, a "switch" known as a "house event" is used to switch in or out various sections of the system fault tree for each condition. A house event Basic Event Data (BED) file is constructed for each initiating event. This defines the status (on or off) of each house event for that initiating event. All the house events and combinations of house events are described in Appendix E.

The functional quantification process is very straight forward. The appropriate fault tree(s) for the function of interest are updated against the house event file appropriate for the initiator of interest. This updating will turn on or off gates as required. The full tree is then solved and quantified using appr priate truncation values. The result is a Boolean equation which is used in the sequence quantification as well as giving a quantified value for that function. Some functions may be single events and would not require this process. A jult descriptions of the quantification of all functions is given in Approxime E.

3.3.5.2 Summary of Function Unavailabilities

The functional unavailabilities are shown in Table 3.3.5-1. This table identifies the function and describes the success criteria. Each function is named after the function identifies in the event tree. For example, the function UI represents failure of High Pressure Core Spray (HPCS). In the event tree is found that HPCS is required for a number of sets of conditions. Thus the functions are identified as 101, U102, U103, etc. The exact function used in each sequence of each event tree is printed on the event tree and developed in Appendix E.

3.3.6 QUANTIFICATION OF SEQUENCE FREQUENCIES

This section will describe how the quantification of sequence frequencies was accomplished. The methodology is discussed and a brief explanation of the complicer code modules used to perform the quantification is given. The full quantification documentation and detailed quantification of an example sequence is given in Appendix F.

Sequence frequency quantification is accomplished by merging the combinations of failures for each function resulting from the quantification of the function unavailabilities (Section 3.3.5) as determined by the event tree structure (Sections 3.1.2 and 3.1.3). The event tree defines core damage sequences, transfer sequences and non-core damage sequences. The NUFRA workstation was used to perform the task of sequence quantification. The non-core damage sequences (Status categorized as OK) are shown on the event trees for convenience, but are not quantified since their results have no application. These non-core damage sequences will not be discussed further.

3.3.6.1 Initial Quantification of Sequence Frequencies

Each core damage sequence is quantified in a number of stages. In the first stage all the combinations of events contributing to each functional failure, and the initiating event, are merged to give a set of combinations of failures (known as minimal cutsets) which will lead to core damage. However, in any given sequence a number of functions may have been successful and, therefore, some of the combinations may not be applicable as the particular piece of equipment may have operated satisfactorily. If, for example, a specific electrical supply appears in both a successful and failed function, it cannot be both failed and successful. In the second stage, the combinations of failures are compared with the successful functions and all the failure combinations which include components which are operational are removed.

In the third stage, the remaining combinations are compared with disalloved combinations of failures. For example, a combination of both Division 1 and Division 2 diesel generator in maintenance is not allowed by the Technical Specifications. These disallowed combinations are removed.

The final list of combinations (cutsets) represent the contributors to core damage, and the sum of the frequencies of all the combinations in a sequence, represents the sequence core damage frequency.



The PRA code NUPRA was used to perform the quantification in the following manner.

The NUPRA Sequence Function Equation Assignment Module was used to automatically generate quantification control (merge) files for each sequence in each page of the event trees based on the event tree construction and function assignment. This file is then used to automatically perform the quantification of all the sequences in the event tree. The cutoff selected for each sequence was a truncation value of 1.0×10^{-10} . The results from system and function quantification used in the quantification of each sequence are in the form of equations containing the minimum combinations of failure cutsets above, typically 1.0×10^{-10} . Then each sequence is quantified automatically by merging the cutsets for each function.

The event tree merge control files perform three processes for each core damage and transfer sequence. The first process is to combine all the function equations for each failed function with the initiating event function equation using Boolean binary conjunction, AND, logic. The second process is to delete the functional successes by comparing the cutset function equation for each function which is a success in the event tree with the combined cutsets for all the failed functions using Boolean binary subtraction of each basic event that is successful. The remaining cutsets then represent the failures which would contribute to the sequence.

The third process is to modify the sequence equation and printout files to take account of Technical Specification limitations, to delete successful function cutsets for the transfer sequences or to correct the value for success branches of event trees when single basic events of the failure branch is greater than 0.1. Each of these actions requires editing of the merge control file for each of the event trees as described in the following paragraphs.

Technical Specification, Limiting Conditions for Operation prohibit certain redundant equipment from being inoperable during power operation. A fault tree, DAM, was created to provide cutsets which represent disallowed maintenance combinations based on Technical Specification. This fault tree was then quantified to give a cut set equation of all the disallowed combinations. The cutset function equation for disallowed maintenance, DAM.EQN, was used to perform Boolean subtraction from every sequence by adding a step in the quantification of each sequence in the event tree merge control files.

Transfer sequences were used as the initiating event frequency for several of the transfer event trees. The sequence equation files were used as input directly to these transfer event trees. For example, the Station Blackout event tree B used Loss of Offsite Power sequence TIS39 as the initiating event frequency. Each of such transfers is shown on the appropriate event tree. All the successful functions from the tree from the sequence is transferred here to be inserted in the merge control file for the transfer time, i.e. all success function sequences TIS319 have to be included for each sequence in event tree B.

When the failure probability of a function is greater than 0.1 then the success branch approximation of 1.0 is no longer valid. NUPRA always uses a

success approximation value of 1.0. To compensate for this approximation all success paths for functions which contain a basic event with a failure probability of greater than 0.1 were multiplied by the complement of the function failure rate.

After this final processing, the sequence equation files and the sequence printout files were then ready to be used to determine total core damage frequency or as input for back end analysis.

The event tree merge control files were named using the corresponding event tree name with OCL as the file name extension. For example, for Large LOCA (event tree A) this would be A.OCL. The output from the quantification consists of two files. One output file is the sequence equation file which contains all of the cutsets which are greater than the truncation file which should be emphasized that this file contains only cutsets and no data or cutset values. A truncation of 1.0 \times 10⁻¹⁰ was used unless the equation resulted in greater than 5,400 cutsets. Then a slightly higher truncation was used which would result in less than 5,400 cutsets.

Another output file is the sequence printont file which contains the desired number of cutsets (usually 50) ranked in order of magnitude using data in the data base at the time of quantification. Appendix F contains the first page from the printout files for every sequence resulting in a core damage frequency greater than 1.0×10^{-7} . The sequence file names are the same as the event tree names in combination with the sequence number. For example, sequence 4 of the Large LOCA event tree would be AS04. The equation files have a file name extension of EQN and the printout files have a file name

The quantification of an example sequence is fully described in Appendix E.

3.3.6.2 Summary of Quantification

The sequence quantification described in the previous section was performed for three sets of event trees: the first to give the core damage frequency from internal initiating events, the second to give the plant damage state frequencies for use in the quantification of the source term release frequencies and the third to give the conditional core damage frequencies for internal flooding initiated events. The location in this report of information on the results and details of the quantification are as follows:

Internal Events	Section 3.4	Appendix F
Plant Damage States	Section 4.3.4	Appendix H
Internal Flooding	Jection 3.3.7	Appendix G

3.3.7 INTERNAL FLOODING

3.3.7.1 Introduction

The objective of the analysis reported here is to estimate the contribution of internal plant flooding to core damage and fission product release category frequencies at PNPP Unit 1.

Internal plant flooding encompasses the effects from the accumulation, spraying or dripping of fluids arising from the rupture, cracking or incorrect operation of components within the plant. In practice major internal floods have occurred in nuclear power plants, for example, from the rupture of pipes, valves and expansion joints as well as from operator errors during plant maintenance activities. All potential internal flood sources and causes are considered in this analysis, including those that result in loss of primary or secondary reactor coclant outside the Containment (i.e., interfacing LOCAs or steam line blocks with failure to isolate).

Internal flocding like other so called "external events" merits consideration as a potentially significant risk contributor because of it's potential for common cause equipment failures and/or human actions which may result in an accident initiating event (e.g., loss of Main Feedwater) and loss of one or more accident mitigating systems. The detailed analysis of such events is very plant specific, since their likelihood of progression and subsequent impact on plant systems is highly dependent on factors such as layout, piping arrangements, drainage as well as the prevailing flood protection features accident sequences the probability of coincident random equipment failures and operator errors must also be taken into account.

In theory at least, the risk from all flood sources anywhere in the plant could be assessed in a detailed realistic marner. However this is impractical due to the large number of potential flood sources, and unnecessary since floods in many areas can be shown to be insignificant contlibutors by simple bounding arguments and analyses. For the sake of efficiency the analysis was performed in two levels of detail. At the conclusion of the screening analysis some plant areas (or particular flood scenarios) are determined not to be significant while others is ingled out intoact of flooding was obtained mainly from the Appendix R safe shutdown submittal PNPF USAR, panel and conduit layout, general arrangement and piping addition information obtained during plant walkdowns and in discussions with plant staff proved invaluable.

The flooding analysis is fully described in Appendix G and a summary of the results presented in this section. The screening analysis described in section 3.3.7.2, the detailed analysis in section 3.3.7.3 and the summary and conclusions given in section 3.3.7.4.

3.3.7.2 Screening Analysis

3.3.7.2.1 Designation of Independent flood Areas

In this sub-task various areas of the plant are designated independent with respect to iternal flooding. An area is termed independent if flooding outside the area cannot intrude into the area without the failure of an enclosing flood barrier. Conversely, in the absence of a flood barrier, flooding in an independent area will not be the direct cause of failures outside the area. The concept is useful because it will allow the analyst to define the extent of common-cause failure citributed to a particular flood, and to assign frequencies to the flood.

The physical layout of the plant buildings together with the location and size of potential flood sources is considered in determining the independence of an area. These areas can be easily identified as independent with respect to internal flooding because they are distinct structures with only a few interconnecting pathways. These interconnections are generally in the form of personnel or equipment access ways or, in some case shared drainage systems. A review of the plant design a performed antify design features (such as watertight doors, check valves in compared in the form and differences in floor elevations between buildings) that tend to inhibit any significant propagation of water from one building to the other. Other factors that may contribute to the independence of an area are physical separation, and equilibrium flood heights compared with the lowest elevation of any opening in a flood barrier.

For plant structures containing safety related equipment the areas of independence were defined as smaller areas within a larger independent area. If possible, these areas were defined such that they contain components pertaining to a particular mitigating system. It should be noted that even non-watertight doors may, under certain circumstances, be regarded as effectively providing independence; for example, a door in a stairwell will funnel virtually all water flowing down the stairwell to a lower elevation. Thus, the elevation to which the door provides access will not be susceptible to significant amounts of water inflow from a higher elevation, even if the stairwell door is not watertight.

In considering the possibility of flood barrier failure, the failure modes will include: perational errors (e.g., watertight doors or hatchways left open) leakage through unsealed doors and door failures due to hydrostatic head. Building gaps (rattle spaces) were also considered.

In general, the collapse of walls or leakage through construction joints were not considered to be important. (Although there have been instances of leakage through wall seams, the leakage rates have been minor and easily accommodated by installed drainage systems.) However portions of the TPC/CDB building will involve collapse of a wallboard stairwell during circ water flooding.

3.3.7.2.2 Evaluation of Bounding Flood Frequencies

For the purpose of screening, flood frequencies are generally determined on the basis of US plant experience from significant incidents reported in Nuclear Power Experience (NPE) (Stoller Power Inc., 1990). However, because of incomplete event descriptions and differences in plant layout and flood sources, this data was applied in a conservative fashion.

Note that this approach is appropriate for screening, since it encompasses all flood sources and no information on flooding rates is required at this stage.

3.3.7.2.3 Identification of Flood Induced Initiating Events and Mitigating System Damage

For each area in which a flood can occur, it is necessary to examine the

flood susceptible equipment to determine which of the initiating events defined in the internal events study may occur and which accident mitigating systems may fail. Generally all electrical equipment is assumed to be susceptible to damage except junction boxes which have a double heat shrink wrap covering and cable raceways. In the screening analysis susceptible equipment is assumed to be damaged given that a flood occurs in an area or propagates to it unless damage can be easily ruled out on the basis of an inadequate maximum flood height and minimal possibility of spraying. Flood propagation is assumed to occur if a given pathway exists, unless it requires the failure of a physical barrier whose failure probability is independent of flood height. In this case propagation will be assumed to occur with a probability equal to the probability of the barrier failure.

In certain areas it ... be possible for floods to cause more than one type of transient (floods are not usually capable of causing LOCAs). Since the objective of the screening analysis is to be conservative the most severe transient is assumed.

3.3.7.2.4 Summary of Screening Analysis

The results of the screening analysis are summarized in Table 3.3.7-1. This table identifies each of the independent areas, the flood frequency and the estimated core damage frequency. Of the 36 areas six areas are identified as requiring detailed analysis. The estimated core damage frequency from each of the other areas is below 10° using the conservative assumption that all equipment in the area is damaged immediately on occurrence of the flood. The six areas selected for detailed analysis are:

Zone Description

1	Turbine Building
13	Lowest Level Control Complex
17	Second Level in Control Complex
8	Auxiliary Building Corridors - lowest level
10 1A	Auxiliary Building Corridors - second level Steam Tunnel

3.3.7.3 Detailed Flooding Analysis of Designated Areas

3.3.7.3,1 Definition of Flood Damage States

Following a flood incident, damage to some equipment in the local vicinity may occur immediately, due to spraying and dripping. However, for a flood area of reasonable size, much of the equipment will not sustain damage until the flood level rises to a critical level (e.g., for switchgear room MCCs this is generally 6" to 1 ft). Likewise flood propagation to an adjacent area may not occur until the flood level rises above a curb for example, and then ac ional time will be required before the level reaches a critical height in that area. Therefore, there is usually a basis for defining a set of distinct flood damage states, each corresponding to a progressively increasing severity equipment loss. Each flood damage state is therefore defined in terms of the time at which it occurs after the initial flooding incident together with a set of accident mitigating systems which are damaged. Subsequent analysis then predicts the frequency of each flood

damage state and the conditional core damage frequency given it does occur.

The growth (or rate of rise) of flood level is then determined by taking into account the flooding rate, the free cross-sectional area of the flood area, and the capability of the drainage mechanisms (floor drains, and leakage pathways to adjacent areas under doorways). In some cases an equilibrium flood height is established when the outgoing flow through the drains or under doors equals the flood rate. Flood growth may be halted at any time either by automatic or operator action leading to isolation of the flood source, or by exhaustion of the flooding source itself. Factors considered in evaluating the probability of suppression include: the means of detecting occurrence of the flood (alarm, area occupancy, etc.); the means of detecting and isolating the specific source of the flood, the time available for the cperator to isolate the flood source before equipment damage occurs and applicable flood procedures and operator training.

3.3.7.3.2 Flood Growth Event Tree

The individual Flood Damage states are determined by developing flood growth ovent trees for each of the floods in each of the flood areas identified in the screening analysis. In order to more accurately estimate the effects of flooding in an individual zone, the flood rate is divided into three groups, severe, moderate, and small. The basis for this is fully described in Appendix G. The trees then consist of the flood initiating event ind frequency) and the various stages of the containment of the flood. The stopping of the flood at a given stage will lead to a flood damage state in which a given set of equipment is damaged and therefore unable to prevent core damage. The defined flood damage states and equipment affected for the floods in each of the above areas is shown in Table 3.3.7-2. Also included is the conditional core damage frequency, that is the probability of the random failure of the remaining ECCS equipment not already failed by the flood.

3.3.7.3.3 Results of Flooding Analysis

The core damage frequency as the result of flooding is estimated to be 1.5 \times 10⁻⁶. The contribution from flooding in each of the most significant zones is shown in Table 3.3.7-3 and Figure 3.3.7-1 and discussed in the following paragraphs.

Zone 13 Control Complex Elevation 576'10"

The core damage frequency from floods in this area is 8.8 X 10⁻⁷ per year which is 57 percent of the total contribution from flooding. This zone consists of a large open area at the lowest level of the control complex. Principle equipment in this area is the control complex chilled water pumps (CCCW), emergency closed cooling pumps (ECC), and the instrument and service air (IA/SA) compressors. Failure of the IA/SA occurs at a flooding level of 1 ft and the ECC and CCCW 22" above the floor defining the two plant damage states.

The severe flood rate was defined at 105,000 gpm based on floods from the service water 30 in and 42 in pipework. The moderate flood was defined as 35,000 gpm and the small flood as 16,000 gpm.

A flood in this area is assumed to lead to loss of instrument air initiating event and eventually failure of the RCIC system, low pressure injection and loss of containment heat removal. The low pressure systems are lost as a result of loss of ECC. As the low pressure systems are not failed immediately, there is time to restore low pressure injection via one of the alternate injection paths. RCIC fails as the result of flow under the door to the Unit 1 auxiliary building and flooding of the RCIC local panel.

The largest contribution comes from the medium flood (29%) followed by a small flood (18%). The frequency of a severe flood is low so the total contribution from this flood is approximately 10%.

Zone 17 Control Complex 599'

The core damage frequency from floods in this area is 3.2 X 10⁻⁷ per year which is 21 per cent of the total contribution from flooding. The source of a severe flood in this zone is the service water piping in the Nuclear Closed Cooling (NCC) heat exchangers. A flood in this area would flow through doors and down to zone 13 with the same consequential damage. The doors to the doors to zone 18. NCC is assumed lost in zone 17 as the result of the loss of SW cooling, NCC equipment and cooling to the instrument air compressor are affected in the course of the flood.

The impact of the flood is the same as that for area 13 however the flood frequencies are lower as the contribution from the moderate, small and severe floods are 11, 6 and 4 percent respectively.

Zone 1 Turbine Building and Turbine Power Complex

The core damage frequency from floods in the turbine building and turbine power complex is 2.8 X 10⁻⁷ per year which is 18 percent of the total contribution from flooding. The major sources of water considered in detail in the turbine building are the circulating and service water systems. All other sources were assumed capable of only causing a small flood and therefore the frequency of such floods was based on general industry this area the major flood sources were broken down into the following subgroups: floods from pipework in the turbine building, floods from the water pipework in the Turbine Power Complex, where it passes through the east and west side rooms.

The three damage states of concern in the turbine building are (1) 3 to 5 ft above the 574'10" floor level which will fail the hotwell and condensate booster pumps (2) the 593'6" level at which the preferred alternate injection pumps (condensate transfer) will fail and (3) the 599' level at which the door to the safety related auxiliary building is located.

Failure at the first and second damage level will only fail equipment in the turbine building and therefore do not make a significant contribution to core damage. For any circulating water flood in the main turbine building the third level cannot be reached with the initial inventory in the system and

basin, therefore a severe flood will not reach level 3. The only possible way for this level to be reached is for a relatively moderate or small circ water flood to slowly "ill the heater bay and turbine power complex while the basin make-up system adds water to the basin. Floods will only reach the third stage following failure of flood logic and very delayed operator action.

In the turbine power complex the CW return header passes through the east and wests side rooms at the second fluor level. An estimated flood rate of 750,000 gpm is postulated if a gross rupture of the pipe occurs. There are no large valves or expansion joints in the area. It has been assessed that a full pipe rupture in the east side room would collapse the wall board stairwell to elevation 568 west room which guickly fills. The double door fails at elevation 568 to the larger west room but the level continues to rise until the level in 593 east rises to the top of the auxiliary building door at elevation 599 at which point the door is assumed to fail. This is estimated to occur 73 sec after the pipe rupture.

For gross rupture in the west side, if the west side elevator door fails inward before 13ft level of water is achieved (top of door to auxiliary building) downward flow of water through the elevator shaft will fill the lower level. Two doors to the turbine building and the elevator door on elevation 577 will open and allow the water into the turbine building where the flood alarm and isolation switches will activate to isolate the flood before the flood causes failure of the door to the auxiliary building at the 599 level.

As the result of the frequencies of the various floods the highest contribution to core damage comes from floods as the result of a small expansion joint failure (11%) followed by floods is either the turbine power complex west or east rooms (3% each). The remaining floods contribute approximately 2% to the overall flooding CDF.

Zone 8 Auxiliary Building Elevation 508'

The core damage frequency from floods in this area is 2.8 X 10⁻⁸ which is approximately 2 per cent of the total contribution from flooding. Floods in the auxiliary building basement level corridors will not directly affect the ECCS systems as each of the 6 rooms is protected by a watertight door. However, all the local panels are mounted in the corridor at the 568 ft level with the exception of the HPCS panel at the 574 ft level. The major flooding sources within the zone are the emergency service water and condensate transfer. Flooding will lead to the loss of the ADS permissive, which can by bypassed by the operator in the control room, and loss of the RCIC due to multiple trips from flooding of the local panel.

If the flood is not isolated then eventually water will build up and flood under the door gap into the control complex zone 13 with consequential damage to equipment in that area. The time available for flood isolation is such that this is not a significant contributor to the overall core damage frequency from flooding.

Zone 16 Auxiliary Building Elevation 599'

The core damage frequency from floods in this area is 1.1×10^{-8} which is less than 1 per cent of the total contribution from flooding. Floods in this area were found to affect equipment on the floor directly below before a critical height for zone 16 equipment would be reached; however water spray could cause failure of the TBCC chillers in the west zone area. Moreover as the flood rates range from 16,000 gpm (severe) to 3000 gpm (small) the time available to isolate the flood and the relatively minor damage early on ensures that floods in this area are not a significant contribution to core damage.

3.3.7.4 Summary and Conclusions

Sequences leading to core damage initiated by internal floods contribute approximately 12% to the overall core damage frequency from internal events and internal floods. The most significant sequence will arise from floods in Zone 13 in the control complex at elevation 576 ft. The total contribution from small, medium and severe floods in this area is 8.8 X 10⁻⁷ on 7 per cent of the total core damage frequency, which is less than the contribution from either ATWS, loss of offsite power or station blackout.

It is concluded that as the highest contribution to flooding in a given area is 8.8×10^{-7} , based on a number of conservative assumptions and the overall contribution from flooding in all areas is 1.5×10^{-6} no specific plant improvements will be considered.

3.4 RESULTS AND SCREENING PROCESS

Core damage for the Perry plant is defined in the USAR as follows:

- 1. The maximum fuel element cladding shall not exceed 2,200°F.
- The calculated total oxidation of the cladding shall nowhere exceed 0.17 times the total cladding thickness before oxidation.
- 3. The calculated total amount of hydrogen generated from the chemical reaction of the cladding with water or steam shall not exceed 0.01 times the hypothetical amount that would be generated if all of the cladding metal in the fuel region of the core were to react.
- 4. Calculated changes in core geometry shall be such that the core remains amenable to cooling.
- 5. After any calculated successful initial operation of the ECCS, the calculated core temperature shall be maintained at an acceptably low value and decay heat shall be removed for the extended period of time required by the long-lived radioactivity remaining in the core.

For the purpose of the Perry IPE non-ATWS sequences, this is translated to define core damage as occurring upon the onset of reactor pressure vessel (RPV) steam cooling, at the Minimum Zero Injection Water Level (MZIWL), given that a high capacity injection system is not immediately available to recover core cooling. For RCIC, injection recovery is assumed to be required by the top of active fuel (TAF) to avoid core damage. The definition of steam cooling is consistent with that defined in the BWR Owners Group Emergency Procedure Guidelines (EPGs). For ATWS sequences, core damage was assumed to occur at fuel clad temperatures of 2,200°F as determined by the MAAP computer code.

Although these criteria are slightly conservative, the analysis shows that the additional time available to recover cooling systems before serious core degradation occurs is small and would not significantly lower the core damage frequency for the dominant sequences. However, in evaluating the frequency of release of fission products, consideration has been given to recovery of systems and re-establishment of decay heat removal capability prior to RPV failure or prior to containment failure. Thus, the slight conservatism in the arbitrary definition of core damage has not been carried over into the frequency of fission product release.

In this section the results and screening process used to identify the core damage frequency are discussed. Results associated with the level 2 analysis, that is contribution of sequences to the containment failure frequency and radionuclide source term category frequencies, are summarized in Sections 4.7 and 7.0.

3.4.1 Application of Generic Letter Screening Data

All of the event trees were constructed with the headings representing functions combining one or more systems and operator actions. The following screening criteria have been used for inclusion of the results in this







section of the report. As many of the functions are effectively single systems the criteria for systemic sequences rather than functional sequences have been used.

- 1. Any sequence that contributes 1 \times 10^{-7} or more per reactor year to core damage has been included in the summary of core damage frequencies by initialing event. (Table 3.4.1-1)
- 2. Any sequence that contributes 1 X 10^{-7} or more to the total core damage frequency, grouped by initiator. (Table 3.4.1-2)
- 3. All sequences that are within the upper 95% of the total core damage frequency. (Table 3.4.1-3)
- 4. Systemic sequences that contribute to a containment bypass frequency in excess of 1.0 x 10⁻⁶ per reactor year. (Table 3.4.1-4)
- 5. Any systemic sequences that are determined from previous applicable PRAs or by engineering judgment to be important contributors to core damage frequency or poor containment performance which are not already included in Tables 3.4.1-1 through 3.4.1-4.
- 6. All systemic sequences greater than 1% within the upper 95% of the total containment failure frequency. (Tables 3.4.1-11)

In order to meet the above screening criteria, the core damage frequency calculations were performed using a truncation of 1.0×10^{-10} for the sequence cutsets. Recovery actions were included after the initial quantification by modifying the event trees. No sequences were cutoff after adding the recovery actions. Therefore, information was retained on all sequences that meet the original screening criteria of 1×10^{-7} .

The submittal guidance requires that all sequences that, but for low human error rates in post operator actions, would have been above the applicable core damage frequency screening criteria be identified. By using an initial cut off three orders of magnitude below the basic screening criteria and not eliminating any sequences after applying recovery action, all such sequences are retained and reported in Table 3.4.1-5.

3.4.1.1 Core Damage Frequency

The internal events portion of the IPE identified 21 core damage sequences with an annual frequency of greater than 1 $\times 10^{-7}$ contributing 86.3 percent of the overall core damage frequency (CDF). An additional 89 sequences with a point estimate frequency of greater than 1 $\times 10^{-10}$ per year contributing the remaining 13.7 percent of the overall core damage frequency. Each initiating event's contribution to the overall CDF is shown in Table 3.4.1-1. The CDF results given, except where stated otherwise are point estimates.

The point estimate frequency of core damage is 1.2×10^{-5} per reactor year. The combined frequency of the 89 sequences below the 1×10^{-7} cut off is less than 1.4×10^{-9} per reactor year. An uncertainty analysis was performed to evaluate the uncertainty on core camage frequency resulting from the uncertainties on the parameter values of the core damage model. The cumulative distribution function for the core damage frequency as shown in Figure 3.4.1-1. some significant parameters of the core damage frequency distribution are as follows:

Mean	1.4 X 10 ⁻⁵
Standard Deviation	3.9 X 10 ⁻⁵
95 th Percentile	2.5 X 10-5
Median	1.1 X 10 ⁻⁵
5 th Percentile	6.2 X 10 ⁻⁶

The difference between the mean value, obtained from the uncertainty analysis, and the point estimate results from the correlation of the samples of the basic event probabilities that are based on the same parametric value distribution. This is called state of knowledge correlation (Apostolakis and Kaplan, 1991).

On review of the cutsets it does not appear that the overall characterization of the safety of the plant in terms of the contributions and their relative importance, would be significantly altered by using the uncertainty analysis for the estimation of core damage frequency. Therefore, the point estimate results are used in the remainder of the discussion and interpretation of results. In further support of this approach, it should be noted that the point estimate values for the parameters have been chosen to be either realistic (when sufficient data are available) or conservative.

The summary of sequences grouped by initiato. is shown in Table 3.4.1-2 and those contributing 95 percent of the core damage frequency in Table 3.4.1-3. The containment bypass sequences are given in Table 3.4.1-4.

The dominant accident initiating event type is anticipated transient without scram (ATWS) at 40.7 percent. Transients contribute 25.0 percent, station blackout 19.3 percent, and loss of offsite power 12.4 percent. As a complete class, LOCAs contribute 2.6 percent. These results are summarized in Table 3.4.1-6 and Figure 3.4.1-2.

An event importance analysis was performed on the overall core damage model. In this analysis the relative importance of each basic event was calculated with respect to three different measures. The three measures are Fussell-Vesely, risk reduction, and risk achievement.

The dominant basic events ranked in order by Fussell-Vesely and risk reduction measures are shown in Table 3.4.1-7. The Fussell-Vesely importance is a measure of the contribution of the given component to the overall core damage figuency by comparing the sum of all cutsets in which that basic event occurs with the sum of all cutsets. The risk reduction measure shows the ratio of the original core damage frequency to the reduced core damage frequency if the component was perfect or its failure probability is zero.

It should noted that the ranking of events by the Pussell-Vesely measure and the risk reduction measure are identical so the highest ranked items for these two measure are discussed in the following paragraphs.

The most important basic event for risk reduction is the mechanical failure of the control rods (CM) preventing insertion into the core given a signal to

shut down the reactor. This is the single event following any transient initiator which will lead to the ATWS scenarios which in turn contribute 40.7 percent to the core damage frequency.

The second important basic event for risk reduction is the loss of offsite power (T1). This initiator leads to station blackout sequences (19.3 percent) and loss of offsite power (12.4 percent). Sequences following the loss of offsite power initiator then contribute 31.7 percent to the core damage frequency. The Fussell-Vesely importance is 0.32 with a risk reduction of 1.47.

Failure of the operator to maintain the power conversion system (PCS) available (NSHICPEC5-2-LIT3) for an ATWS resulting from a transient with PCS initially available or loss of feedwater transient, is the third most important basic event. It has been assessed that the feedwater runback leading to a loss of RPV level will result in closure of the MSIV in all cases. This basic event was set to 1.0 as the operators will not have time to restore feedwater before MSIV closure. It occurs in the dominant sequences of the IPE. This HI effectively becomes the transfer flag for these events to the MSIV closure ATWS tree (T2-C) based on the current feedwater design. The Fussell-Vesely importance is 0.27 with a risk reduction of 1.38.

The initiating event transient with PCS available (T3A) is the fourth most important basic event. This event contributes to the dominant ATWS sequences and has a Fussell-Vesely importance of 0.25 with a risk reduction of 1.34.

Failure of the operator to re-open the motor feed pump control valves or manually depressurize the RPV (FWHICPEL-2-FDW-V) during an ATWS event following a transient with a loss of PCS is the fifth most important basic event with a Fussell-Vesely importance of 0.25 with a risk reduction of 1.33.

The initiating event transient with PCS not available (T2) is the sixth most important basic event. This event contributes to the dominant ATWS sequences and has a Fussell-Vesely importance of 0.23 with a risk reduction of 1.30.

The seventh important basic event is the failure of the operator to inhibit ADS (ADHICPC5-1-ADS-O) for ATWS scenarios where the feedwater system has failed. The Fussell-Vesely importance of this basic event is 0.22 with a risk reduction of 1.28. The failure to inhibit ADS in other sequences is modeled by different basic events as they have different values. The sensitivity of the results to this event is discussed in section 3.4.1.6.

The failure of the containment anchorage (CV05) is the eighth important basic event. This is included in any sequence in which RPV injection is successful but long-term containment heat removal fails. The Fussell-Vesely importance is 0.15 with a risk reduction of 1.17.

Non-recovery of offsite power in 3 hours (R15) is the next basic event. This basic event leads to sequences in LOOP and station blackout contributing 12.8 percent to the core damage frequency. The Fussell-Vesely importance is 0.13 with a risk reduction of 1.15.

The failure of the 4,160 VAC bus EH12 is the next basic event. This basic

event can fail all equipment which requires division 2 power. The Fussell-Vesely importance is 0.12 with a risk reduction of 1.13. This failure results in the failure to vent as the inboard FPCC isolation valve is powered from the Division 2 bus. In the event of failure of the Division 1 bus, the outboard FPCC isolation valve can be locally opened by the operator.

Of the next six basic events in importance, four are failures of either the Division 1 and 2 diesel generators to supply power or the non-recovery of offsite power. These basic events contribute to both LOOP and station blackout sequences.

Two of the next eight basic events are failures to provide alternate injection to the RFV via the fire protection system. The fire protection system may be used when other alternate injection systems are unavailable due to non-recovery of offsite power.

Similar information was generated for risk achievement. Risk achievement is derived by calculating the core damage frequency with a given event failure probability set equal to 1.0. This is equivalent to determining the core damage frequency if the component is failed at the time of the initiating event. The dominant basic events ranked in order by risk achievement measures are shown in Table 3.4.1-8.

The dominant basic event as measured by risk achievement is the mechanical failure of the control rods to insert into the core (CM). Assuming that the control rods fail in an ATWS following all initiating events with reduced systems available for RPV injection and the required reactivity.

The next basic event is the common cause failure of the ECCS pump room coolers (EPFACCEPRCS). These coolers provide heat removal from the pump rooms. The common cause failure was assessed to be low enough such that setting it to 1.0 would significantly increase its contribution to core damage frequency.

The third basic event in importance as ranked by Risk Achievement is the failure of the Division 2 4160 VAC bus (DGBALC1R22S0006). Failure of this bus would cause a loss of all equipment powered from Division 2 including low pressure coolant injection, heat removal equipment, and containment venting equipment.

Common cause failure of the batteries (DCBTCC) is the fourth most important basic event. As DC power is required for all systems and the batteries are required for any station blackout event, the common cause failure of the batteries is relatively important.

The next three basic events are common cause failures of diesel building ventilation fans, dampers and louvers (DBMFCC, DBMDCC, and DBLVCC). These components support the operation of the diesel generators and are required following a loss of offsite power.

The initiating event for a Large LOCA (A) is the eighth basic event in risk achievement importance.

Of the next ten basic events ranked, 5 are common cause basic events. Common

cause is very high in risk achievement because the redundant components are failed at the same time. Setting the common cause basic events to 1.0 therefore significantly increases the core damage frequency.

3.4.1.2 Functional Failure Leading to Core Damage

In order to evaluate the relative contribution of the failure of the various systems or events, other than initiating events, to the overall core damage frequency it is possible to group the core damage sequences by functional failures. The percentage contribution for the following functional failures are shown in Table 3.4.1-9.

Loss of injection (U1, U2, U3, V, V2) Failure of decay heat removal (Q, M) Failure of containment heat removal (W, Y, Ws)

Loss of HVAC (Hv, CC)

Failure to restore offsite AC power (R, R1, R2)

Failure to depressurize (X)

Failure to inhibit ADS (X')

The sum of these events is greater than 100% as a number of the sequences contribute to more than one category of functional failure. For example, some sequences involve both loss of cffsite power and failure of injection.

It can be seen that failure of injection, both high pressure and low pressure, (68%) is the dominant contributor with failure to depressurize in the event of failure of the high pressure injection systems a very small contributor (4%). This implies that the reliability of the ADS and procedures associated with depressurization are satisfactory and little reduction in core damage frequency would be achieved by improving them.

As anticipated transients without scram is the dominant contributor to core damage, failure to inhibit ADS is a significant contributor to core damage (25%).

Failure of containment heat removal or venting will lead to the so called W sequences, that is sequences in which injection is successful but the failure to remove decay heat from containment results in containment failure and consequential failure of injection leading to core damage. Contribution from this function is 28%. The contribution from failure to recover offsite power is 22% which reflects the fact that loss of cffsite power and station blackout events are also a relatively important contribution to core damage. The failure of containment leading to core damage is also significant at 22%.

3.4.1.3 Dominant Accident Sequences

The top 15 dominant accident sequences contributing 81 percent to the core damage frequency are discussed in detail in this section. A complete list of

the sequences which contribute 1 percent or more to the core damage frequency and the dominant cutsets for each sequence is given in Appendix F.

Sequence (T3A + T2)-C-U3-X' (T2-CS30)

Frequency 2.27 X 10⁻⁶ Contribution 19.5%

A transient has occurred. The PCS may be lost either due directly to the transient or due to subsequent conditions which may result in MSIV isolation. The control rods fail to insert into the core and the reactor remains at power. The motor feed pump has failed to inject into the RPV to maintain RPV level control. The operators have failed to inhibit ADS resulting in rapid depressurization of RPV and injection of low pressure ECCS resulting in a reactivity excursion leading to core damage.

The initiating event T3A (transient with PCS available) contributes almost three times as much to the failure of this sequence than does T2 (transient without PCS). This is due to the failure of the operators to maintain PCS available for an ATWS scenario. Following the initiating events T3A and T2 given the mechanical failure of the control rods, the dominant contributors to this sequence are failure of the operators to re-open the motor feed pump control valves and manually depressurize the RPV and inhibit ADS.

Sequence T2-W-Y-CV (T2S04)

Frequency 1.62 X 10⁻⁶ Contribution 13.9%

A loss of PCS transient has occurred with a reactor scram and successful SRV operation to maintain RPV pressure control. The motor feed pump has started and is successfully maintaining high pressure RPV level control. The RHR system and venting have failed to provide long-term containment heat removal. Without containment heat removal the containment ruptures disabling the injection path from the motor feed pump and leading to core damage.

The dominant contributors to the failure of this sequence are failure of the injection path upon failure of the containment and failure of 4,160 VAC Division 2 Bus EH12. The maintenance of RHR train A and the failure of the operators to align a containment vent path also contribute to the frequency of this sequence.

Sequence T1-B1-U1-Va-R (BS24)

Frequency 7.71 X 10" Contribution 6.6%

A loss of offsite power has occurred and the Division 1 and 2 diesel yenerators have failed to provide onsite AC power. HPCS has failed to provide high pressure RPV level control. RCIC has successfully provided high pressure RPV level control for 3 hours at which time the suppression temperature limit of 185°F has been exceeded and RCIC fails. The operators have successfully depressurized the RPV, but the fire protection system has failed to provide adequate low pressure RPV level control and offsite power was not recovered at 3 hours leading to core damage.

The dominant contributors to the failure of this sequence are unavailability

of the fire protection system to provide alternate injection due to failure of the offsite pumper, failure of the diesel fire pump to run, and failure of the operators to align the fire protection system for RPV injection after RCIC is lost.

Sequence TIA-U1-U2-V-Va (TTAS14)

Frequency 7.53 X 10" Contribution 6.5%

A loss of instrument air has occurred with a reactor scram and successful SRV operation to maintain RPV pressure control. RCIC and HPCS have failed to provide adequate RPV level control at high pressure. The RPV has been successfully depressurized. With the RPV depressurized low pressure ECCS make-up and low pressure alternate injection have failed to provide RPV level control leading to core damage.

The dominant contributors to the failure of this sequence are failure of the operators to successfully align the reactor feed booster pumps or suppression pool cleanup for alternate low pressure injection. Common cause failure of Emergency Service Water pumps A and B, and other random failures of Emergency Service Water trains A, B and C also contribute to the core damage frequency for this sequence.

Sequence (T3A + T2)-C-U3-X' (T2-CS20)

Frequency 6.25 X 10⁻⁷ Contribution 5.4%

A transient has occurred. The PCS may be lost either due directly to the transient or due to subsequent conditions which may result in MSIV isolation. The control rods fail to insert into the core and the reactor remains at power. The motor feed pump has successfully injected into the RPV but the operators have failed to control RPV level. The operators have successfully inhibited ADS but have subsequently failed to initiate standby liquid control leading to core damage.

The initiating event T3A (transient with FCS available) contributes almost three times as much to the failure of this sequence than does T2 (transient without PCS). This is due to the failure of the operators to maintain PCS available for an AIWS scenario.

Sequence T1-U1-R1-Ws-V-Va (RS20)

Frequency 6.04 X 10⁻⁷ Contribution 5.2%

A loss of offsite power has occurred with a reactor scram and successful SRV operation to maintain RPV pressure control. HPCS has failed, but RCIC has successfully provided high pressure RPV level control. At 3 hours RCIC failed due to failure of the Suppression Pool Cooling mode of RHR and non-recovery of offsite power. The RPV has been successfully depressurized. Low pressure ECCS make-up and alternate low pressure make-up have failed leading to core damage.

The dominant contributors to the failure of this sequence are the failure of the operators to align fire protection for alternate injection after RCIC

fails and the failure of the Division 3 diesel generator to start. Failure of the Division 1 and 2 diesel generators to start, the failure of the offsite pumper to provide adequate low pressure alternate injection and the failure of the diesel driven fire pump also contribute to the failure of this sequence.

Sequence T1-B1-U1-U2-R-Va (BS34)

Frequency 5.26 X 10 Contribution 4.5 %

A loss of offsite power has occurred and the Division 1 and 2 diesel generators have failed to provide onsite AC power. HPCS and RCIC have failed to provide nigh pressure RPV level control. Offsite power was not recovered at 0.4 hours. The operators successfully depressurized the RPV, but fire protection alternate injection failed to provide adequate RPV level control.

The dominant contributors to the failure of this sequence are the failure of the offsite pumper, failure of the operators to bypass the RCIC isolation on high steam tunnel temperature, running failure of the diesel fire pump, failure of the operators to align fire water in a timely manner, and start failure of the division 3 diesel generator. Start failures of the division 1 and 2 diesel generators also contribute to this sequence.

Sequence T1-B1-U1-R (BS17)

Frequency 3.36 X 10⁻⁷ Contribution 2.9%

A loss of offsite power has occurred and the Division 1 and 2 diesel generators have failed to provide onsite AC power. HPCS has failed to provide high pressure RPV level control. RCIC has successfully provided high pressure RPV level control for 3 hours at which time the operators have successfully depressurized the RPV and aligned fire water as alternate low pressure injection. The batteries fail at 7 hours and offsite power was not recovered by 13 hours. There is no containment heat removal leading to failure of the containment and subsequent failure of RPV injection leading to core damage.

The dominant contributors to the failure of this sequence are maintenance and starting failures of the division 1, 2, and 3 diesel generators.

Sequence T1-U1-U2-R1-V-Va (US29)

Frequency 3.34 X 10" Contribution 2.9%

A loss of offsite power has occurred with a reactor scram and successful SRV operation to maintain RPV pressure control. HPCS and RCIC have failed to provide successful RPV level control at high pressure. Offsite power was not recovered by 0.4 hours, but the RFV has been successfully depressurized. Depressurization may be delayed unti! the M2IWL is reached dependent on the injection system alignment. With the RPV depressurized low pressure ECCS make-up and fire protection alternate injection have failed to provide RPV level control leading to core damage.

The dominant contributors to the failure of this sequence are failure of the

division 3 diesel generator to start and maintenance of residual heat removal train A, LPCS, and RCIC. Failure of the offsite pumper and failure of the operators to align fire water in a timely manner, and failure of the RCIC turbine driven pump also contribute to the core damage frequency for this sequence.

Sequence (T3A + T2)-C-U3-X (T2-CS28)

Frequency 3.12 X 10⁻⁷ Contribution 2.7%

A transient has occurred The PCS may be lost either due directly to the transient or due to subsequent conditions which may result in MSIV isolation. The control rods fail to insert into the core and the reactor remains at power. The motor feed pump was not successfully placed into operation. ADS inhibit and standby liquid control are successful, but depressurization of the RPV by the operators was unsuccessful resulting in core damage.

The dominant contributor to the failure of this sequence is the failure of the operators to re-open the motor feed pump control valves and depressurize the RPV. For the IPE for a transient with PCS available coupled with an ATWS, it was assumed that the MSIV isolation at RPV level was not bypassed. This is also one of the dominant contributors to this sequence.

Sequence (T3A + T2)-C-C1 (T2-CS11)

Frequency 2.90 X 10⁻⁷ Contribution 2.5%

A transient has occurred. The PCS may be lost either due directly to the transient or due to subsequent conditions which may result in MSIV isolation. The control rods fail to insert into the core and the reactor remains at power. The operators successfully controlled RPV level with the motor feed pump. ADS inhibit was successful, but standby liquid control was unsuccessful resulting in core damage.

Given a transient leading to a loss of PCS with an ATWS, the dominant contributor to this sequence is the failure of the operators to initiate standby liquid control.

Sequence T3B-C-U3-X' (T3B-CS29)

Frequency 2.76 X 10" Contribution 2.4 %

A loss of feedwater transient has occurred, the control rods have failed to insert into the core and the reactor remains at power. Recovery of the motor feed pump has failed. The operators have also failed to inhibit ADS resulting in rapid depressurization of the RPV and initiation of low pressure ECCS causing a reactivity excursion leading to core damage.

The dominant contributors to the failure of this sequence are the failure of the operators to inhibit ADS, re-open the motor feed pump control valves and manually depressurize the RPV.

Sequence TIA-U2-W-Y-Cv (TIAS05)

Frequency 2.57 X 107 Contribution 2.2%

A loss of instrument air has occurred with a reactor scram and successful SRV operation to maintain RPV pressure control. RCIC has failed to adequately control RPV level. HPCS has initiated and is successfully maintaining high pressure RPV level control. The RHR system and venting have failed to provide long-term containment heat removal. Without containment heat removal the containment ruptures disabling the injection path from HPCS and leading to core damage.

The dominant contributors to core damage are the failure of the containment and subsequent release of steam into the HPCS pump room resulting in failure of HPCS and failure of the 4,160 VAC bus EH12. Maintenance of RHR train A and the failure of the containment anchorage also contribute to failure of this sequence.

Sequence (T3A + T2)-C-X' (T2-CS12)

Frequency 2.37 X 10"7 Contribution 2.0%

A transient has occurred. The PCS may be lost either due directly to the transient or due to subsequent conditions which may result in MSIV isolation. The control rods fail to insert into the core and the reactor remains at power. The operators successfully controlled RPV level with the motor feed pump, but fail to inhibit ADS resulting in core damage.

The initiating event T3A (transient with PCS available) contributes almost three times as much to the failure of this sequence than does T2 (transient without PCS). This is due to the failure of the operators to maintain PCS available for an ATWS scenario.

Sequence A-U1-V (AS09)

Frequency 2.10 X 10⁻⁷ Contribution 1.8%

A large LOCA has occurred with successful reactor scram. HPCS and low pressure ECCS have failed to injection water into the RPV leading t core damage.

The dominant contributors to this sequence are the failure of trains A and B of Emergency Service Water. The maintenance of trains A and B of Emergency Closed Cooling and trains A and B of Emergency Service Water also contribute to this sequence.

3.4.1.4 Contribution to Containment Failure

The development of the containment response following core damage for the various plant damage states is fully described in Chapter 4. This includes a complete analysis of which sequences and plant damage states contribute to the various containment failure modes, and source terms. The significant sequences most likely to contribute to containment failure are summarized in this section. The frequency of containment structure failure is 7.8 X 10⁻⁶

per year and the frequency of RPV failure and early containment failure with pool bypass is 2.0 X 10⁻⁶ per year. As shown in Figure 3.4.1-3 sequences resulting in containment bypass (from Event V) represent less than 1% of the core damage frequency, and those core damage sequences resulting in containment failure represent 23%. The sequences contributing 95% of the total to each of the failures and, where appropriate, the plant damage states in which the sequences occur, are discussed below.

Containment Failed Prior to Core Damage for Internal Initiators

In the case of failure of containment prior to core damage, denoted in the event tree by function CV, the containment failure can occur at the anchorage, in which case the suppression pool would be lost and the containment bypassed. In section 4.4.4 it is shown that for slow overpressurization sequences the ratio of anchorage failure to other failures is 0.15/0.85. The Level 1 sequences without flooding which contribute to overpressure failure are shown in Table 3.4.1-4. The frequency of the Cv sequences is 2.6×10^{-6} . However the frequency of pool bypass is this frequency multiplied by 0.15. Thus the contribution to the RPV failure and early containment failure with pool bypass frequency is 3.9×10^{-7} , which is approximately 3% of the overall core damage frequency. The dominant contribution to this is the loss of feedwater followed by successful injection but failure of all containment heat removal and venting. The contribution from this sequence is 62%. The next highest sequences associated with loss of instrument air contributes 10%. Event V contributes less than 1%.

Containment Failure

The containment structural failure and venting frequency from all sequences is 7.8 x 10⁻⁶ per reactor year. The containment venting frequency is 3.7 x 10-0 and the contanment structural failure frequency is 4.0 x 10". The breakdown of the containment failure modes for all plant damage state sequences is shown in Table 3.4.1-10. The plant damage state failure frequency from sequences in which containment fails prior to core damage is 2.9×10^{-6} , so the total containment structural failure and venting frequency after core melt is approximatley 4.9×10^{-6} per reactor year, which is approximately 38 percent of the core damage frequency. The contributors to this from venting after core damage is 3.7 x 10" or 77%. Thus the frequency of a containment structural failure without the frequency of the containment failed at core damage is 1.1×10^{-6} which is approximately 9% of the core damage frequency. The frequency of containment structural failure for all station blackout sequences is 6.0 X 10 which represents 4.7 percent of the core damage frequency. The plant damage states which contribute 95% of the containment failure frequency and the sequences which contribute to each of these plant damage states are listed in Table 3.4.1-11. It will be noted that for all plant damage states which contribute 95% of the containment failure frequency there is a 100% probability of containment failure given the conditions identified for that plant damage state. The assessment of containment failure for the 16 plant damage states which contribute 95 percent of containment failure and venting is described in Section 4.5.3.

The plant damage states contributing to containment failure and the dominant sequences (above 1% CDF) in each plant damage state are shown in

Table 3.4.1-11.

3.4.1.5 Comparison of Results With and Without Recovery Actions

The quantification of the core damage sequences was base on inclusion of both the automatic initiation of systems and operator actions specifically called out in the procedures in the fault and event tree models. For example following a loss of feedwater the falling water level in the vessel will result in auto initiation of the HPCS, RCIC, or motor feed pump, and the operator is instructed to confirm that the systems are operating. If the systems have failed, he is instructed to perform a series of operations which will result in depressurization of the vessel and use of the low pressure systems to inject ater into the vessel. The operator actions associated with use of these systems have been included in the base case model as have all the other actions in the procedures which he would be using.

When the initial quantification of the core damage sequences were complete each combination of failures was reviewed to determine if it represented a direct path to core damage or if as a result of following procedures, the operator would use additional systems to prevent core damage. This resulted in the identification of the following recovery actions which are now modeled in the event trees.

Use of Alternative Low Pressure Injection (including fire protection system) following failure of the Low Pressure Coolant Injection and Low Pressure Core Spray. This is included in the event tree as function Va.

The operator takes the necessary actions to cross connect dc power from the Unit 2 batteries following loss of offsite power to extend the HPCS operating time by providing indication of water level (HI) or provides power to maintain the SRVs open and allow the fire protection system to be used for injection.

The operator manually opens the outboard fuel pool cooling and cleanup isolation valve when there is no electric power available or motor operator failure in order to vent the containment (Y).

The operator crossties the division 3 and division 2 AC buses in a station blackout to allow opening of the inboard fuel pool cooling and cleanup isolation valve.

In the plant damage state trees additional recovery actions are included.

The operator depressurizes after core damage and before vessel failure following early failure to depressurize.

Operator initiates both standby liquid control pumps at a later stage following an ATWS, failure of level control, and before containment failure.

The applicable operator actions are listed in Table 3.4.1-12, and the impact of adding each group of actions associated with a given function, on the core damage frequency is given in Table 3.4.1-13. The overall impact of removing the recovery actions would be to increase the core damage frequency from 1.2×10^{-5} to 4.2×10^{-5} a factor of approximately 3.5. The most significant contribution is the use of the alternate low pressure injection sources, in the event of failure of the low pressure coolant injection and low pressure core spray, followed by the use of the Unit 1/Unit 2 dc cross-tie.

It should be emphasized that these recovery actions have been included in the model because the operator has specific procedures which direct him to use the identified systems to perform the specific functions modeled. The two recovery actions which have been included in the plant damage state event trees do not lower the core damage frequency but result in a reduction of the frequency of a number of plant damage states. The late injection will reduce the frequency of plant damage states 63 through 66 (Figure 3.4.1-3) a d hence lead to a significant reduction in the frequency of release from these plant damage states. The late the time of core damage. The transfer of 90% of these sequences to a plant damage state representing low pressure at vessel failure will again have a significant impact on fission product release. A fuller discussion of the impact on fission product release is given in section 4.

3.4.1.6 Sensitivity Analysis

The dominant contribution to core damage comes from sequences associated with ATWS, loss of offsite power and station blackout. The sequences resulting from each of these initiations were reviewed to establish if there were any areas where the success criteria or other assumptions could be construed as either conservative or non conservative. In addition, the human reliability, common cause failure and maintenance contributions to the core damage frequency were reviewed to determine the overall sensitivity of the results to the modeling and data in these areas. One of the reasons this was done was to ensure that sequences which had a low core damage frequency as a result of operator actions were identified. The results of the sensitivity analysis are summarized in Table 3.4.1-14.

Initiating Event Frequency

The initiating event frequency for the initiation is based on the information given in the Grand Gulf study, as, at the beginning of the Perry IPE study information was only available from the first operating cycle. At the time of completion of the study the second and third operating cycles had been completed providing further information on the number of plant trips. In fact in these two operating cycles there was only one inadvertent scram from power, which was the result of a loss of feedwater. Based on this information the initiating event frequencies for the transients T2 (loss of power conversion), T3A (trip with PCS available) and T3B (loss of feedwater) would be lower than those used in the base case. As no T2 or T3A events occurred a value of 0.5/year is assumed for the sensitivity analysis. In the case of T3B one trip occurred in two years; therefore, a frequency of 0.5/year is used. The use of these frequencies reduces the core damage frequency.

It is clear from the experience of the last two operating cycles that the initiating event frequencies at Perry for the above transient categories are

significantly lower than the industry values used in the Grand Gulf study. As the Perry IPE is intended to be a living PRA the plant specific information on the initiating event frequencies (and other applicable data such as maintenance unavailabilities) will be included at the first updating of the model.

Another significant impact of this change in the frequency of the initiating events is the change in the relative contributions to the overall core damage frequency. It can be seen in Table 3.1.4-15 that the dominant contribution is now station blackout at 32% followed by loss of offsite power at 20%. The ATWS contribution is now 16.5%, which is less than the combined transient contribution of approximately 23%. The importance of these results when considering plant improvements is discussed in Chapter 6.

Anticipated Transient Without Scram

The critical function of borated water injection, RFV level control and revention of depressurization all require the intervention of the operator. The core damage frequency following an ATWS event is therefore sensitive to the assumptions made in determining the operator error rates in each of these functions. For example, if the operator failure to inhibit ADS is increased to 1.0 the overall core damage frequency goes from 1.2×10^{-5} to 8.6×10^{-5} . However the ATWS sequences frequency goes from 4.7×10^{-5} to 7.9×10^{-5} , a factor of approximately 17. Similar increases occur if the values of the operator error rate for the other functions are increased.

As stated earlier this dependency arises because of the following assumptions and design features at Perry.

- It is now considered that operation of the HPCS is not an acceptable method of maintaining vessel inventory following failure to insert the control rods.
- 2. The standby liquid control system has to be manually initiated.
- The feedwater runback reduces feedwater injection to zero and therefore manual control is required to restore feedwater.
- 4. It is necessary to inhibit ADS to prevent depressurization and injection of water from the high capacity low pressure systems. This action has to be performed by the operator.

Although the automation of a number of these actions will not make a major reduction in the core damage frequency, it will reduce the dependency on the operator to perform the overt action. For example, the introduction of an automatic ADS inhibit following ATWS would reduce the core damage frequency for 1.2×10^{-5} to 8.8×10^{-5} , approximately 24% but it would also remove any dependency on the operator for the primary response to the particular requirement.

Loss of Offsite Power Sequences

The impact of the assumption that the unit 2 battery can be used to supply dc and that the firewater can be used as an injection source have already been discussed in the previous section (3.4.1.5) on recovery actions. In addition two other assumptions have been made in evaluating the base case core damage frequency.

- 1. The operator will override the RCIC leak detection trip on loss of offsite power.
- 2. Room cooling is not required for the switchgear rooms to prevent failure of ac power from the diesels following loss of offsite power.

For the first assumption if the RCIC trip is not overridden, the overall core damage frequency increases from 1.2×10^{-5} to 1.8×10^{-5} and if switchgear room cooling is required, from 1.2×10^{-5} to 1.5×10^{-5} . The current analysis gives a high degree of confidence in the validity of both the above assumptions.

Impact of Containment Failure

The current containment failure analysis indicates that a proportion of containment failures, as the result of loss of containment heat removal following successful reactor vessel injection, will lead to a loss of injection and thus core damage with a failed containment. As indicated in Table 3.1.4-9, such sequences contribute 22% to the core damage frequency. Thus if a passive vent were fitted, it could be shown that containment failure will not lead to loss of injection and the core damage frequency would be reduced by 22% from 1.2×10^{-6} to 9×10^{-6} . This reduction would eliminate a class of core damage sequences with a failed containment, which result in high fission product release.

Maintenance Contribution to Core Damage

Maintenance of the ECCS and associated support systems results in periods of unavailability of the systems. The data used in the study is based on the plant specific information available at the time of the quantification of the event trees in 1991 and updated for cycle 3 for the HPCS and RCIC systems. A sensitivity study has been performed to determine the contribution of maintenance outages on the core damage frequency.

It can be seen that by putting all maintenance to zero, the core damage frequency is reduced by 45% indicating that this is the maintenance contribution to the core damage frequency. It is significant to note that the contribution from HPCS and RCIC for which the cycle 3 information has been used, is approximately 1%. There is an extensive Systematic Maintenance Optimization (SMO) program at the plant for all ECCS systems. When this is complete the plant specific data can be used to update the values used in the current base case.

Human Reliability Modeling

The inclusion of recovery actions is discussed in section 3.4.1.5 however the sensitivity of the core damage frequency to the other human reliability data is also of interest. This has already been discussed to a limited extent in the early paragraphs on the ATWS sequences.



The current values for all human reliability basic events have been based on a systematic approach to the quantification of the human actions. If it is assumed that there is a bias in this analysis such that all events were assumed to be too low then the core damage frequency would be higher. To assess the overall sensitivity to the human error probabilities the values were increased by a factor of ten if the base value was less than 0.1 and to a value of 1.0 if the base case was between 0.1 and 1.0. The core damage frequency increased from 1.2×10^{-5} to 4.3×10^{-4} , a factor of 28. This indicates that operator actions do play a significant part in determining the core damage frequency and emphasize the importance of the instruction and guidance in the emergency procedures, particularly as they relate to the 41 actions identified in the core damage sequences which contribute to the core damage frequency. Particular emphasis has been placed on the analysis of multiple interdependent actions. This is fully described in Appendix D.

The sequences which but for operator actions would have been above the screening value of 1.0 x 10° are shown in Table 3.4.1-5. The sequences fall into three classes, those associated with ATWS events those associated with failure of decay heat removal and those associated with manual depressurization. In all cases those sequences which are increased to the 10° to 10° range contain operator actions which are currently in sequences above the cut off and for which dependency analysis has been performed. This is particularly so in the case of the ATWS events and the failure to initiate containment heat removal or venting. It is concluded that there are no significant sequences which would be above 10° if a more detailed human reliability analysis was performed. Finally if all the operators performed the required actions perfectly the core damage frequency would be reduced to $3.9 \times 10°$.

Common Cause Failures

If the common cause failures were all increased by a factor of 10, the core damage frequency would increase from 1.2×10^{-5} to 2.2×10^{-5} which is less than a factor of 2. As the result of the major contribution to core damage from the ATWS sequences common cause failures of the cooling and support systems such as the emergency service water or diesel generators do not contribute si ificantly to the overall core damage frequency. However, as described in section 3.3, a detailed analysis has been made of the critical components in these systems.

3.4.2 VULNERABILITY SCREENING

A concise definition of vulnerability is not given in the documentation associated with the performance and reporting of the IPE. In the response to questions in Appendix C to the Submittal Guidance Document (NRC, 1989), mention is made of examining sequences that are above the screening criteria in order to determine if a weakness exists. Thus the word weakness replaces the word vulnerability, neither of which is defined in numerical or comparative terms. In another response it is suggested that a vulnerability is an outlier. The NUMARC Severe Accident Issues Closure Guidelines (NUMARC, 1992) proposes a set of guidelines based on a combination of the core damage frequency for a group of sequences and the individual contribution from a sequence group. If the contribution from a given initiator or system failure



is greater than 50 per cent to the total core damage frequency it is interpreted as a significant vulnerability, if it contributes 20-50% it is interpreted as a potential vulnerability to be investigated. Similarly contribution from sequence groups between a core damage frequency of 10^{-5} to 10^{-4} are reviewed to determine if there is an effective plant procedure or hardware change which would reduce the frequency of the sequences.

In this study Importance and Sensitivity measures have been used to determine the most significant contributions to the core damage frequency, containment system performance, and decay heat removal functions as discussed in section 3.4.1.

3.4.2.1 Internal Event Core Damage Vulnerabilities

The breakdown of core damage by init: ing event is shown in Table 3.4.1-6 and by sequence with function failure in Table 3.4.1-3. However in order to evaluate the vulnerabilities in terms of the criteria proposed by NUMARC, it is appropriate to regroup the sequences into a series of functional accident groups according to the criteria shown in Table 3.4.2-1.

The list of sequences and frequency of each group is shown in Table 3.4.2-2. It can be seen from this table that there are no significant vulnerabilities as defined in the previous section as all the accident sequence groups have a frequency below 1.0×10^{-5} and no group contributes more than 50% to the overall core damage frequency. However there are two groups of accident sequences that contribute between 20 and 50 per cent. Group 4 which is made up of accident sequences involving an ATWS leading to containment failure due to high pressure and subsequent loss of inventory, and Group 2 which is made up of accident sequences involving loss of containment heat removal leading to containment failure and subsequent failure of coolant inventory make-up.

Group 4

The contribution to core damage from sequences in this group comes primarily from ATWS sequences in which the motor feed pump has failed to inject water and ADS has not been inhibited resulting in rapid depressurization of the RPV and injection of low pressure ECCS. This leads to a series of reactivity oscillations resulting in generation of large quantities of steam and ultimately containment failure and core damage. In these sequences the potential vulnerability is the failure to inhibit ADS. However it should be noted from the sensitivity analysis that the use of the plant operating data for cycle 2 and 3 will reduce the frequency of the initiators which contribute to this group and thus the contribution to core damage frequency of these sequences from 33% to approximately 15% which is no longer a potential vulnerability.

Group 2

The contribution to core damage from sequences in this group comes from failure of containment heat removal leading to containment failure and subsequent loss of injection. One of the reasons that this is a significant contributor is that the containment design is such that in approximately 15% of cases containment failure leads to injection failure. Thus if a passive vent was fitted, the core damage frequency of these sequences would be



reduced. This also has an impact on source term magnitude and is further discussed in section 3.4.2.3 under containment vulnerabilities. However it should be emphasized that the overall frequency of this group 2.6 x 10^{-6} is well below 1.0 x 10^{-5} .

3.4.2.2 Flooding Core Damage Vulnerabilities

There are no vulnerabilities associated with internal flooding. the total contribution to core damage frequency is 12 per cent from all floods and flooding in the most significant area, Zone 13 only contributes 7 per cent to the overall core damage frequency. The sensitivity analysis shows that it is important to ensure that the supply valves to the Unit 2 heat exchanger, which is in dry lay-up with the bell ends removed, cannot be opened.

3.4 1.3 Containment Vulverabilities

The Perry containment design pressure is 15 psig. The median containment pressure capacity is estimated to be 64.3 psig. Results from the containment accident progression event tree analysis indicate a containment failure can occur from hydrogen burns and from gradual overpressurization. The systems analysis indicates a relatively high probability of loss of venting capability for LOOP sequences with loss of containment heat removal. The loss of both RHR and venting will eventually result in containment overpressure failure (assuming failure from some other mechanism has not previously occurred).

The Perry Mark III steel containment has failure modes which will have an impact on accident progression. If containment failure should result in penetration failure, then ECCS pump failure may occur due to steam release pathways from the Shield Building to the Auxiliary Building through penetration seals. If containment failure results in anchorage failure, then the ECCS pumps may fail as the result of piping failure and loss of suppression pool. Suppression pool water loss and drywell bypass can occur during anchorage failure when the water inventory is expelled to the Shield Buildings. Additionally, anchorage rupture can result in a direct radiological release to the environment. The containment performance is discussed in more detail in Section 4.

3.4.3 DECAY HEAT REMOVAL EVALUATION - 1 SUE A-45

The objectives of Task Action Plan A-45 are to evaluate the safety edequacy of Decay Heat Removal (DHR) Systems in existing light water reactor nuclear power plants and to assess the value and impact (benefit-cost) of alternative measures for improving the overall reliability of the DHR function if required.

Some potential accidents which could result in core melt were excluded from the A-45 studies performed by Sanlia National Laboratories (S.W. Hatch, 1987). Since the purpose of the program is to study the adequacy of shutdown decay heat removal systems, large LOCAs, reactor vessel ruptures, interfacing system LOCAs and anticipated transients without scram (ATWS) are excluded. The tudy focused on events occurring from power or in hot standby.



a failed containment. with consequent increase in offsite release. The addition of an alternate passive vent path will reduce the frequency of core damage and result in a reduction in offsite release. That is the overall core damage frequency would be reduced from 1.2×10^{-5} to 9.0×10^{-6} but the overall frequency of core damage sequence with the suppression pool bypassed is reduced from 2.0×10^{-6} to 4.5×10^{-7} which will have an impact on the source terms.

It is considered that in view of the low frequency of the core damage sequences resulting from failure of decay heat removal (5.1 x 10⁻⁶ per year) the performance of these systems is adequate and that this analysis provides the necessary information for adequate resolution of unresolved safety issue A-45 for the Perry Nuclear Power Plant.

Reterences continued . . .

McClymount, A.S. and B.W Pohlman, 1982, ATWS: A Reappraisal: Fart 3 Frequency of Anticly ed Transients, EPRI-NP-2230, Electric Power Research Institute, Falo Alto, CA.

- Miller, C. 1982, Data Summaries of Licensee Event Reports of Valves at U.S. Commercial Nuclear Power Plants, NUREG/CR-1363, USNRC Washington, D.C.
- Mosleh, A. et al, 1988, Procedures for Testing Common Cause Failure in Safety and Reliability Studies, NUREG/CR-4780, USNPC Washington, D.C.
- NUMARC, 1992, Severe Accident Issue Closure Guidelines, NUMARC 91-04 NUMARC, Washington, D.C.
- NRC (US Nuclear Regulatory Commission), 1982a, Interim Reliability Evaluation Program Procedures Guide, NUREG/CR-2728, Washington, D.C.
- NRC (US Nuclear Regulatory Commission), 1983, PRA Procedure Guide NUREG/CP 2300, Washington, D.C.
- NRC (US Nuclear Regulatory Commission), 1985a, <u>Development of Transient</u> <u>Initiating Event Frequencies for Use in PRA</u>, NUREG/CR - 3502, Washington, D.C.
- NRC, (US Nuclear Regulatory Commission), 1989, Individual Plant Examination: Submittal Guidance Final Report NUREG-1335, Washington, D.C.
- NUS, 1990, <u>BWR Generic Data Base from NUS</u>, Transmitted in letter PNPP-IPE-019, dated June 18, 1990, Halliburton NUS Environmental Corporation, Gaithersburg, MD.
- Scoller, A.M. Nuclear Power Experience.
- Swain, A.D. and H.E Gutman, 1983, <u>Handbook of Human Reliability Analysis with</u> <u>Emphasis on Nuclear Power Plant Application</u>, NUREG/CR-1278, Sandia National Laboratories, Albuquerque NM.

Swain, Alan D., 1987, <u>Accident Sequence Evaluation Program Human Reliability</u> <u>Analysis Procedure</u>, <u>MUREG/CR-4772</u>, <u>Sandia</u> National Laboratories, <u>Albuquerque</u>, <u>NM</u>.

- Trojowsky, M. and Brown, S.R., 1984, Data Summaries of Licensee Event Reports of Selected Instruments and Control Components at U.S. Commercial Nuclear Power Plants, NUREG/CR-1740.
- WASH-1400 (NUREG-75/014), Reactor Safety Study An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants, October 1975.

The current values for all human reliability basic events have been based on a systematic approach to the quantification of the human actions. If it is assumed that there is a bias in this analysis such that all events were assumed to be too low then the core damage frequency would be higher. To a tess the overall sensitivity to the human error probabilities the values the increased by a factor of ten if the base value was less than 0.1 and to a value of 1.0 if the base case was between 0.1 and 1.0. The core damage frequency increased . $Dm 1.2 \times 10^{-6}$ to 4.3×10^{-6} , a factor of 28. This indicates that operator actions do play a significant part in determining the core damage frequency and emphasize the importance of the instruction and guidance in the emergency procedures, particularly as they relate to the 41 actions identified in the core damage sequences which contribute to the core damage frequency. Particular emphasis has been placed on the analysis of multiple interdependent actions. This is fully described in Appendix D.

The sequences which but for operator actions would have been above the screening value of 1.0 X 10° are shown in Table 3.4.1-5. The sequences fail in three classes, those associated with ATWS events, those associated with failure of decay heat removal and those associated with manual depressurization. In all cases those sequences which are increased to the 10° to 10° range contain operator actions which are currently in sequences above the cut off and for which dependency analysis has been performed. This is particularly so in the case of the ATWS events and the failure to initiate containment heat removal or venting. It is concluded that there are no significant sequences which would be above 10° if a more detailed human reliability analysis was performed. Finally if all the operators performed the required actions perfectly the core damage frequency would be reduced to $3.9 \times 10^{\circ}$.

Commo. use Failures

If the common cause failures were all increased by a factor of 10, the core damage frequency would is the from 1.2×10^{-5} to 2.2×10^{-5} which is less than a factor of 2. As the result of the major contribution to core damage from the ATWS sequences common cause failures of the cooling and support systems such as the emergency service water or diesel generators do not contribute significantly to the overall core damage frequency. However, as described in section 3.3, a detailed analysis has been made of the critical components in these systems.

3.4.2 _____NERABILITY SCREENING

A concise definition of vulnerability is not given in the documentation associated with the performance and reporting of the IPE. In the response to guestions in Appendix C to the Submittal Guidance Document (NRC, 1989), mention is made of examining sequences that are above the screening criteria in order to determine if a weakness exists. Thus the word weakness replaces the word vulnerability, neither of which is defined in numerical or comparative terms. In another response it is suggested that a vulnerability is an outlier. The NUMARC Severe Accident Issues Closure Guidelines (NUMARC, 1992) proposes a set of guidelines based on a combination of the core damage frequency for a group of sequences and the individual contribution from a sequence group. If the contribution from a given initiator or system failure is greater than 50 per cent to the total core damage frequency it is interpreted as a significant vulnerability, if it contributes 20-50% it is interpreted as a potential vulnerability to be investigated. Similarly contribution from sequence groups between a core damage frequency of 10⁻⁵ to 10⁻⁶ are reviewed to determine if there is an effective plant procedure or hardware change which would reduce the frequency of the sequences.

In this study Importance and Sensitivity measures have been used to determine the most significant contributions to the core damage frequency, containment system performance, and decay heat removal functions as discussed in section 3.4.1.

3.4.2.1 Internal Event Core Damage Vulnerabilities

The breakdown of core damage by initiating event is shown in Table 3.4.1-6 and by sequence with function failure in Table 3.4.1-3. However in order to evaluate the vulnerabilities in terms of the criteria proposed by NUMARC, it is appropriate to regroup the sequences into a series of functional accident groups according to the criteria shown in Table 3.4.2-1.

The list of sequences and frequency of each group is shown in Table 3.4.2-2. It can be seen from this table that there are no significant vulnerabilities as defined in the previous section as all the accident sequence groups have a frequency below 1.0 x 10⁻⁵ and no group contributes more than 50% to the overall core damage frequency. Rowever there are two groups of accident sequences that contribute stween 20 and 50 per cent. Group 4 which is made up of accident sequences involving an ATWS leading to containment failure due to high pressure and subsequent loss of inventory, and Group 2 which is made up of accident sequences involving loss of containment heat removal leading to containment failure and subsequent failure of coolant inventory make-up.

Group 4

The contribution to core damage from sequences in this group comes primarily from ATWS sequences in which the motor feed pump has failed to inject water and ADS has not been inhibited resulting in rapid depressurization of the RPV and injection of low pressure ECCS. This leads to a series of reactivity oscillations resulting in generation of large quantities of steam and ultimately containment failure and core damage. In these sequences the potential vulnerability is the failure to inhibit ADS. However it should be noted from the sensitivity analysis that the use of the plant operating data for cycle 2 and 3 will reduce the frequency of the initiators which contribute to this group and thus the contribution to core damage frequency of these sequences from 33% to approximately 15% which is no longer a potential vulnerability.

Group 2

The contribution to core damage from sequences in this group comes from failure of containment heat removal leading to containment failure and subsequent loss of injection. One of the reasons that this is a significant contributor is that the containment design is such that in approximately 15% of cases containment failure leads to injection failure. Thus if a passive vent was fitted, the core damage frequency of these sequences would be

reduced. This also has an impact on source term magnitude and is further discussed in section 3.4.2.3 under containment vulnerabilities. However it should be emphasized that the overall frequency of this group 2.6×10^{-6} is well below 1.0×10^{-5} .

3.4.2.2 Flooding Core Damage Vulnerabilities

There are no vulnerabilities associated with internal flooding. the total contribution to core damage frequency is 12 per cent from all floods and flooding in the most significant area, Zone 13 only contributes 7 per cent to the overall core damage frequency. The sensitivity analysis shows that it is important to ensure that the supply valves to the Unit 2 heat exchanger, which is in dry lay-up with the bell ends removed, cannot be opened.

3.4.2.3 Containment Vulnerabilities

The Perry containment design pressure is 15 psig. The median containment pressure capacity is estimated to be 64.3 psig. Results from the containment accident progression event tree analysis indicate a containment failure can occur from hydrogen burns and from gradual overpressurization. The systems analysis indicates a relationly high probability of loss of venting capability for LOOP sequences with loss of containment heat removal. The loss of both RHR and venting will eventually result in containment overpressure failure (assuming failure from some other mechanism has not previously occurred).

The Ferry Mark III steel containment has failure modes which will have an impact on accident progression. If containment failure should result in penetration failure, then ECCS pump failure may occur due to steam release pathways from the Shield Building to the Auxiliary Building through penetration seals. If containment failure results in anchorage failure, then the ECCS pumps may fail as the result of piping failure and loss of suppression pool. Suppression pool water loss and drywell bypass can occur during anchorage failure when the water inventory is expelled to the Shield Buildings. Additionally, anchorage rupture can result in a direct radiological release to the environment. The containment performance is discussed in more detail in Section 4.

3.4.3 DECAY HEAT REMOV'L EVALUATION - ISSUE A-45

The objectives of Task Action Plan A-45 are to evaluate the safety adequacy of Decay Heat Removal (DHR) Systems in existing light water reactor nuclear power plants and to assess the value and impact (benefit-cost) of alternative measures for improving the overall reliability of the DHR function if required.

Some potential accidents which could result in core melt were excluded from the A-45 studies performed by Sandia National Laboratories (S.W. Hatch, 1987). Since the purpose of the program is to study the adequacy of shutdown decay heat removal systems, large LOCAs, reactor vessel ruptures, interfacing system LOCAs and anticipated transients without scram (ATWS) are excluded. The study focused on events occurring from power or in hot standby.



The delineation of the accident sequences, system analysis and quantifications are fully described in the preceding sections 3.1 through 3.4.1. The identification and ranking of the plant vulnerabilities are described in section 3.4.2. However the concern in issue A-45 is to identify the specific vulnerabilities associated with sequences identified as potentially isocling to core damage if all injection to the vessel and decay heat remova is hist.

The breakdows of functional contribution to core damage is shown in Table 3.4.2-1. From this table it can be seen that failure of decay heat removal as the result of failure of injection contributes 22 percent to core damage with individual function contributions as follows:

Group	Description	Percentage
18 1E	Loss of offsite power and make-up Loss of coolant inventory make-up	13
1A	at low pressure Loss of high pressure make-up and	8
	failure to depressurine	<1

The contribution to core damage frequency as the result of loss of decay heat removal from containment leading to containment failure and consequential loss of injection (class 2) is 22 percent of the overall core damage frequency. Thus 44 per cent of the contribution to core damage is as the direct result of failure of decay heat removal either from the vessel or containment. Although the overall frequency is low (5.1 X 10^{-6}) it is of interest to identify any potential vulnerabilities which, if they could be addressed, in a cost effective manner would reduce the contribution of decay heat removal failure to the overall core damage frequency.

The importance analysis discussed is section 3.4.1.1. od listed in Table 3.4.1-7 identifies the individual components whose improvement would make the greatest contribution to the reduction in core damage frequency. The highest ranked component in terms of decay heat removal is the event representing failure of injection as the result of containment failure (CV05). This indicates that the mode of containment failure following overpressurization is more significant than any individual containment heat removal system failure. Therefore an alternative means to prevent containment failure will have the biggest impact in reducing the core damage frequency.

The contributions from the remaining individual components is small therefore no improvement of an individual component will have a significant impact on the contribution to decay heat removal failure.

3.4.3.1 Summary and Conclusions

The core damage frequency resulting form failure of decay heat removal systems is 5.1 x 10° representing 44 percent of the contribution to core damage form internal events. A review of the contribution to this failure identified one event which contributed twice as much as any others to the core damage frequency for which a possible modification may be considered. The mode of containment failure results in a significant probability of injection failure following containment failures and subsequent core melt in

a failed containment, with consequent increase in offsite release. The addition of an alternate passive vent path will reduce the frequency of core damage and result in a reduction in offsite release. That is the overall core damage frequency would be reduced from 1.2×10^{-5} to 9.0×10^{-6} but the overall frequency of core damage sequence with the suppression pool bypassed is reduced from 2.0×10^{-6} to 4.5×10^{-7} which will have an impact on the

It is considered that in view of the low frequency of the core damage sequences resulting from failure of decay heat removal $(5.1 \times 10^{-6} \text{ per year})$ the performance of these systems is adequate and that this analysis provides the necessary information for adequate resolution of unresolved safety issue A-45 for the Perry Nuclear Power Plant.



References

- AEC (Republic of China Atomic Energy Commission), 1985 Probabilistic Risk Assessment, Kuosheng Nuclear Power Station Unit 1, Executive Yuan, Taipei, Taiwan.
- Chu, T-L, Staymore, and R. Fitzpatrick, 1989, <u>Interfacing System LOCA:</u> Boiling Water Reactors NUREG/CR-5124, Brookhaven National Laboratory, Upton, NY.
- Drouin, M. et. al., 1989, <u>Analysis of Core Damage Frequency:</u> Grand Gulf, <u>Unit 1 Internal Events</u>, Rev. 1, NUREG/CR-4550, Sandia National Laboratories, Albuquerque, NM.
- EPRI, 1991, An Approach to the Analysis of Operator Actions in Probabilistic Risk Assessment, EPRI-TR-100259, Palo Alto CA.
- G/C, (Gilbert Commonwealth), 1992, Cleveland Electric Illuminating Company Perry Nuclear Power Plant Individual Plant Examination, Containment Capacity Analysis, February 17, 1992.
- GE (General Electric Company) 238 Nuclear Island General Electric Standard Safety Analysis Report (GESSAR /I)
- GE (General Electric Company), 1980a Additional Information Required for NRC Staff Generic Report on Boiling Water Reactor, NEDO-24708A Rev 1, San Jose, CA.
- GE (General Electric Company), 1982 EWR/6 Standard Plant Probabilistic Risk Assessment, 22A7007, (GESSAR II).
- Hatch, S.W. et.al., 1987, <u>Shutdown Levay Heat</u> <u>Removal Analysis of a General</u> <u>Electric BWR4/Mark I</u>, NUREG/CR-4767, Sandia National Laboratories, Albuquerque, NM.
- Hickman, J.W., 1983, PRA Procedures Guide: A Guide to Performance of Probabilistic Risk Assessments for Nuclear Power Plants, NUREG/CR-2330 Volumes 1 and 2, American Nuclear Society.
- Kahl, 1985, The In-Plant Reliability Data Base for Nuclear Plant Components: Interim Report - Diesel Generators, Batteries, Chargers and Inverters, NUREG/CR-3831.

References continued . . .

McClymount, A.S. and B.W. Pohlman, 1982, ATWS: A Reappraisal: Part 3 Frequency of Anticipated Transients, EPRI-NF-2230, Electric Power Research Institute, Palo Alto, CA.

- Miller, C. 1982, Data Summaries of Licensee Event Reports of Valves at U.S. Commercial Nuclear Power Plants, NUREG/CR-1363, USNRC Washington, D.C.
- Mosleh, A. et al, 1988, Procedures for Testing Common Cause Failure in Safety and Reliability Studies, NUREG/CR-4780, USNRC Washington, D.C.
- NUMARC, 1992, Severe Accident Issue Closure Guidelines, NUMARC 91-04 NUMARC, Washington, D.C.
- NRC (US Nuclear Regulatory Commission), 1982a, Interim Reliability Evaluation Program Procedures Guide, NUREC CR-2728, Washington, D.C.
- NRC (US Nuclear Regulatory Commission), 1983, PRA Procedure Guide NUREG/CR-2300, Washington, D.C.
- NRC (US Nuclear Regulatory Commission), 1985a, Development of Transient Initiating Event Frequencies for Use in PRA, NUREG/CR - 3862, Washington, D.C.
- NRC, (US Nuclear Regulatory Commission), 1989, Individual Plant Examination: Submittal Guidance Final Report NUREG-1335, Washington, D.C.
- NUS, 1990, BWR Generic Data Base from NUS, Transmitted in letter PNPP-IPE-019, dated June 18, 1990, Halliburton NUS Environmental Corporation, Gaithersburg, MD.
- Stoller, A.M. Nuclear Power Experience.
- Swain, A.D. and H.E Gutman, 1983, Handbook of Human Reliability Analysis with Emphasis on Nuclear Power Plant Application, NUREG/CR-1278, Sandia National Laboratories, Albuquerque NM.
- Swain, Alan D., 1987, Accident Sequence Evaluation Program Human Reliability Analysis Procedure, MJREG/CR-4772, Sandia National Laboratories, Albuquerque, NM.
- Trojowsky, M. and Brown, S.R., 1984, Data Summaries of Licensee Event Reports of Selected Instruments and Control Components at U.S. Commercial Nuclear Power Plants, NUREG/CR-1740.
- WASH-1400 (NUREG-75/914), Reactor Safety Study An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants, October 1975.



Table 3.1.1-1

PNPP IPE Initiating Event List

Designation*	Description	Mean Frequency
Tl	Loss of Offsite Power Transient	6.09 E-2
Τ2	Transients with the loss of the Pover Conversion System (PCS)	1.62
T3A	Transients with PCS initially available	4.51
тзв	Transients involving loss of feedwater, but with the PCS initially available	7.60 E-1
T3C	Transients caused by an Inadvertent Open Relief Valve (IORV) on the RPV	1.40 E-1
AIT	Transient caused by a loss of Instrument Air	9.20 E-2
TSV	Transient caused by a loss of Service Water	1.0 E-3
A	Large Loss of Coolant Accident (LOCA)	1.0 E-4
S1	Intermediate LOCA	3.0 E-4
12	Small LOCA	3.0 E-3
v	Interface Systems LOCA	<1.0 E-8
0	Containment Bypass LOCA	<1.0 E 8
R	Vessel Rupture	1.0 E-7

* The letters used to designate a specific initiating event Group are, where possible, those used in the Grand Gulf Study, and generally in other BWR studies.

Table 3.1.1-2

EPRI BWR Transient Category Definitions

EPRI Catego	ry Title and Definition
1.	Electrical Load Rejection - the electrical load rejection transient occurs when electrical grid disturbances result in significant loss of load on the generator. Also included are intentional generator trips.
2.	Electrical Load Rejection with Turbine Bypass Valve Failure - this transient is identical to No. 1 except that the turbine bypass valves do not open simultaneously with shutdown of the turbine.
3.	Turbine Trip - a turbine trip transient occurs when any one of a number of turbine or nuclear system malfunctions requires the turbine to be shut down. Turbine trips which occur as a by-product of other transients such as loss of condenser vacuum or reactor high level trip are not included. Intentional turbine trips are included.
4.	Turbine Trip with Turbine Bypass Valve Failure - this transient is identical to No. 3 except that the turbine bypass fails to open.
5.	Main Steam Isolation Valve (MSIV) Closure - the MSIV closure transient occurs when any one of various steam line and nuclear system malfunctions require termination of steam flow from the vessel automatically or by operator action.
6.	Inadvertent Closure of One MSIV - only one MSIV closes, the rest remaining open, due to operator or equipment error.
7.	Partial MSIV Closure - partial closure of one or more MSIVs results from a hardware or human error.
8.	Loss of Normal Condenser Vacuum - either a complete loss or decrease in condenser vacuum results from a hardware or human error.
9,	Pressure Regulator Fails Open - either the controlling pressure regulator or backup regulator fails in the open direction. The failure causes a decreasing coolant inventory as the mass flow of water entering the vessel decreases.
10.	Pressure Regulator Fails Closed - either the controlling pressure regulator or backup regulator fails in the closed direction. This failure causes increasing pressure and thus decreasing steam flow from the vessel.
11.	Inadvertent Opening of a Safety/Relief Valve (Stuck) - a safety/relief valve sticks open. Due to an operator error or equipment error a single safety/relief valve can be opened, increasing steam flow from the vessel. If the valve cannot be closed, a scram is initiated. This transient only includes those openings that cannot be subsequently closed before a scram occurs.

Table 3.1.1-2 continued

EPRI BWR Transient Category Definitions

EPRI Categ	ory Title and Definition
12.	Turbine Bypass Fails Open - equipment or operator error results in inadvertent or excessive opening of turbine bypass valves so as to decrease the vessel level.
13.	Turbine Bypass or Control Valves Cause Increased Pressure (closed) - wither operator error or equipment failure causes the turbine bypass or control valves to close, resulting in increased system pressure.
14.	Recirculation Control Failure - Increasing Flow - a failure of a flow controller, either in one loop or the master flow controller, causes an increasing flow in the core.
15.	Recirculation Control Failure - Decreasing Flow - flow controller failure failure causes a decreased flow to the core.
16.	Trip of One Recirculation Pump - one recirculation pump trips due to a hardware or human error.
17.	Trip of All Recirculation Pumps - the simultaneous loss of all recirculation pumps occurs.
18.	Abnormal Startup of Idle Recirculation Pump - an idle recirculation pump is started at an improper power and flow condition. The increased flow could cause a flux spike, or, if the loop has been idle so as to allow coolant in the pump loop to cool, core inlet subcooling.
19.	Recirculation Pump Seizure - the failure of a recirculation pump is such that no coastdown occurs, and a sudden flow decrease is experienced.
20,	Feedwater - Increasing Flow at Power - event causes increasing feedwater flow at power. Excluded (see Category 26) are increasing flow events during startup or shutdown, when manual control is being utilized.
21.	Loss of Feedwater Heater - the loss-of-feedwater heating is such that the reactor vessel receives feedwater cool enough to exceed core scram parameters.
22.	Loss of All Feedwater Flow - the simultaneous loss-of-feedwater flow, excluding that due to the loss-of-offsite power (see Category 31), occurs.
23.	Trip of One Feedwater Pump (or Condensate Pump) - the loss of one feedwater or condensate pump is such that a partial loss of feedwater is experienced.

Table 3.1.1-2 continued

FFRI BWR Transient Category Definitions

EPRI Catego	ry Title and Definition
24,	Feedwater - Low Flow - plant occurrence causes decreasing feedwater flow at power. Excluded are events at low power (see Category 25).
25.	Low Feedwater Flow During Startup - event results in low feedwater flow at essentially zero power; this definition includes only startup or shutdown operations.
26.	High Feedwater Flow During Startup or Shutdown - excessive feedwater flow occurs during startup or shutdown. This reactor is essentially at zero power.
27.	Rod Withdrawal at Power - one or more control rods are withdrawn inadvertently in the power range of plant operation.
28.	High Flux Due to Rod Withdraval at Startup - the inadvertent withdraval of a control rod causes a local power increase.
29.	Inadvertent Insertion of Rod or Rods - malfunction causes an inadvertent insertion of rod or rods during power operation.
30,	Detected Fault in Reactor Protection System - a scram is initiated due to an indicated fault in the reactor protection system. An example is the indication of a high level in the scram discharge volume.
31.	Loss of Offsite Power - all power to the plant from external sources (the grid of dedicated transmission lines to another plant) is lost. This event requires the plant emergency power sources to be available.
32.	Loss of Auxiliary Power (Loss of Auxiliary Transformer) - the loss of incoming power to a plant results from onsite failures such as the loss of an auxiliary transformer.
33.	Inadvertent Startup of HPCI/HPCS - one of the systems supplying high pressure cold water to the vessel inadvertently starts up. In general, a BWR will have either a high pressure coolant injection (HPCI) system or a high pressure core spray (HPCS) system.
34.	Scram Due to Plant Occurrences - an automatic or manual scram is initiated by an occurrence that does not cause an out-of-tolerance condition in the primary system, but requires shutdown. Examples are turbine vibration, off-gas explosion, fire, excess conductivity of reactor coolant, etc.

35. <u>Spurious Trip Via Instrumentation, RPS Fault</u> - a scram resulting from hardware or human error in instrumentation or logic circuits occurs.

Table 3.1.1-2 continued

EPRI BWR Transient Category Definitions

EPRI Category

35

Title and Definition

- 36. <u>Manual Scram No Out-of-Tolerance Condition</u> a manual initiation of a scram, either purposely or by error, occurs and there are no out-of-tolerance conditions.
- 37. Cause Unknown a scram occurs, but the cause was not determinable.

Table 3.1.1-3

Interfacing LOCA Evaluation

System	Valves	Failure Mcde	Valve Type	Initial Position
SIV Leakage Control	1E32-F001	Fails to Remain Closed	NOM	Closed
(discharges to	1E32-F002	Fails to Remain Closed	MOV	Closed
Annulus)	1E32-F003	Fails to Remain Closed	NOM	Closed
(discharges to Aux	1E32-F006	Fails to Remain Closed	MOV	Closed
Building and Annuls)	1E32-F007	Fails to Remain Closed	MOA	Closed
(discharges to	1E32-F008	Fails to Remain Closed	MOV	Closed
Annulus)	1E32-F009	Fails to Remain Closed	MOV	Closed
RCIC (water side)	1E51-F066	Fails to Prevent Backflow	Check.	Closed
(pressurizes RCIC	1E51-F065	Fails to Prevent Backflow	Check	Closed
pump suction)	1E51-F013	Fails to Remain Closed	MOV	Closed
(pressurizes RHR)	1E51-FC56	Fails to Prevent Backflow	Check	Closed
	1E51-F065	Fails to Prevent Backflow	Check	Closed
	1E12-F019	Fails to Prevent Backflow	Check	Closed
	1E12-F023	Fails to Remain Closed	MOM	Closed
(discharges to CST)	1E51-F066	Fails to Prevent Backflow	Check	Closed
	1E51-F065	Fails to Prevent Backflow	Check	Closed
	1E51-F013	Fails to Remain Closed	MOA	Closed
	1E51-F022	Fails to Remain Closed	MOV	Closed
	1E51-F059	Fails to Remain Closed	MOV	Closed
RHR-Steam Condensing		Fails to Close	MOM	Open
(pressurizes RHR)	1E51-F064	Fails to Close	MOA	0pen
	1E12-F052A,B	Fails to Remain Closed	MOV	Closed
	1E12-F087A,B	Fails to Remain Closed	MOV	Closed
	1E12-F055A,B	Fails to Open	RV	Closed

0



Table 3.1.1-3 continued

Interfacing LOCA Evaluation

System	Valves	Failure Mode	Valve Type	Initia' Position
(pressurizes RHR)	1E51-F063	Fails to Close	MOV	Open
	1E51-F064	Fails to Close	Mov	Open
	1E12-F052A,B	Fails to Remain Closed	Mov	Closed
	1E12-F051A,B	Fails to Remain Closed	Puv	Closed
	1E12-F055A,B	Fails to Open	Rv	Closed
RHR-Shutdern Cooling (suction (pressure as RHR)	1E12-F009 1E12-F008	Fails to Remain Closed Fails to Remain Closed	MOA. MOA	Closed Closed
RHR-Shutdown Cooling (return) (pressurizes RHR)	1N27-F559A,B 1B21-F032A,B 1E12-F050A,B 1E12-F053A,B	Fails to Prevent Backflow Fails to Prevent Backflow Fails to Prevent Backflow Fails to Remain Closed	Check Check Check MOV	Closed Closed Closed Closed
RER-LPCI	1E12-F041A,B,C	Fails o Prevent Backflow	Check	Closed
(pressurizes RHR)	1E12-F042A,B,C	Fails to Remain Closed	MOV	Closed
LPCS	1E21-F006	Fails to Prevent Backflow	Cherk	Closed
(pressurizes LPCS)	1E21-F005	Fails to Remain Closed	MOV	Closed
RWCU (suction)	1G33-F001	Fails to Close	MOA	Open
(pressurizes low	1G33-F004	Fails to Close	MOA	Open
pressure side of	1G33-F054	Fails to Close	MOA	Open
RWCU)	1G33-F053	Fails to Close	MOA	Open
RWCU (return) (pressurizes low pressure side of RWCU)	1N27-F559A,B 1B21-F032A,B 1G33-F052A,B 1G33-F03? 1G33-F040	Fails to Prevent Backflow Tails to Prevent Backflow Fails to Prevent Backflow Fails to Close Fails to Close	Check Check Check MOV MOV	Open Open Open Open Open

Table 3.1.1-3 continued

Interfacing LOCA Evaluation

System	Valves	Failure Mode	Valve Type	Initial Position
HPCS	1E22-F005	Fails to Prevent Backflow	Check	Closed
(pressurizes HPCS	1E22-F004	Fails to Remain Closed	MO∛	Closed
pump suction)	1E22-F024	Fails to ' event Backflow	Check	Closed
(discharges to CST)	1E22-F005	Fails to Prevent Backflow	Check.	Closed
	1E22-F004	Fails to Remain Closed	MOV	Closed
	1E22-F010	Fails to Remain Closed	MOV	Closed
	1E22-F011	Fails to Remain Closed	MOV	Closed
Staadby Liquid Control (pressurizes SLC pump suction)	1C41-F007 1C41-F006 1C41-F004A,B 1C41-F033A,B 1C41-F029A,B	Pails to Prevent Backflow Fails to Prevent Backflow Fails to Remain Closed Fails to Prevent Backflow Fails to Remain Closed	Check Check Squib Check RV	Closed Closed Closed Closed Closed
Feedwater	1N27-F559A,B	Fails to Prevent Backflow	Check	Open
(pressurizes FW	1B21-F032A,B	Fails to Prevent Backflow	Check	Open
pump suction)	1N27-F514A,B	Fails to Prevent Backflow	Check	Open

8





Table 3.1.1-4

LOCA Bypassing Containment Evaluation

System	Valves	Failure Mode	Valve Type	Initial Position
Main Steam	1B21-F022A,B,C,D	Fails to Close	MSIV	Open
	1B21-F028A,B,C,D	Fails to Close	MSIV	Open
MSIV Leakage Control	1N22-F016	Fails to Close	MOA	Closed
(inboard drains)	1N22-F019	Fails to Close	MOA	Closed
(outboard drains)	1N22-F067A,B,C,D	Fails to Remain Closed	NOA	Closed
RCIC (water side)	1E51-F066	Fails to Prevent Backflow	Check	Closed
	1E51-F065	Fails to Prevent Backflow	Check	Closed
RCIC (steam side) &	1E51-F063	Fails to Close	MOA	Open
RHR-Steam Condensing	1G33-F004	Fails to Close	MOA	Open
RWCU (suction)	1G33-F001	Fails to Close	MOM	Open
	1G33-F004	Fails to Close	MOM	Open
RWCU (return)	1N27-F559A,B	Fails to Prevent Backflow	Check	Open
	1B21-F032A,B	Fails to Prevent Backflow	Cleck	Open
	1G33-F052A,B	Fails to Prevent Backflow	Check	Open
	1G33-F039	Fails to Close	MOV	Open
	1G33-F040	Fails to Close	MOV	Open
HPCS	1E22-F005	Fails to Prevent Backflow	Check	Closed
	1E22-F004	Fai's to Remain Closed	M0V	Closed
Standby Liquid Control	1C41-F007	Fails to Prevent Backflow	Check	Closed
	1C41-F006	Fails to Prevent Backflow	Check	Closed
Feedwater	1N27-F559A,B	Fails to Prevent Backflow	Check	Open
	1B21-F032A,B	Fails to Prevent Backflow	Check	Open

0

Table 3.1.1-5

	EPRI Events	Included in the Transient Categories
Initiating Event Group	EPRI Transient Category	Rationale For Inclusion
T1 (Transient that causes LOOP)	31	A loss of the offsite grid will result in a reactor scram and loss of normal AC power. The onsite emergency diesel generators are required to start to supply emergency loads. (USAR 15.2.6)
	32	Loss of the auxiliary transformer would result in a reactor scram and a loss of normal AC power. Emergency loads would still be maintained by offsite power, however, it is conservatively assumed that diesel generator start is required to supply emergency loads. (USAR 15.2.6)
T2 (Transient with loss of PCS)	2	Generator load rejection with failure of the turbine bypass valves will result in a fast closure of the turbine control valves which will result in a reactor scram. The failure of the turbine bypass valves to open will result in the loss of the condenser. (USAR 15.2.2)
	4	Turbine trip with failure of the turbine bypass valves. Similar to No. 2 above. Turbine trip causes the reactor scram. A failure of the turbine bypass valves to open will result in the loss of the condenser. (USAR 15.2.3)
	5	An MSIV isolation will result in a reactor scram and loss of the condenser. (USAR 15.2.4)
	6	Inadvertent closure of one MSIV may cause a high steam flow isolation signal resulting in closure of the remaining MSIVs and subsequent loss of the condenser. MSIV Closure will cause a reactor scram. (USAR 15.2.4)
	7	Partial closure of one MSIV. Sequence of events are assumed to be identical to No. 6 above. (USAR 15.2.4)
	8	A loss of normal condenser vacuum will cause both a reactor scram and loss of the condenser. (USAR 15.2.5)



Table 3.1.1-5 continued

EPRI Events Included in the Transient Categories EPR1 Initiating Event Transient Rationale For Inclusion Category -Group 9 A failure of the pressure regulator in the open T2 position will cause the turbine control valves to go wide open, a reactor scram would occur on high (Transient with RPV water level and the MSIVs will close on low loss of PCS) steamline pressure which will cause isolation of the condenser. (USAR 15.1.3) (Continued) A failure of the pressure regulator in the closed 10 position will cause a high neutron flux reactor scram. The turbine control valves will close and the turbine bypass valves will not open causing a loss of the condenser. (USAR 15.2.1) 12 A failure of the turbine bypass valves in the open position will cause a decrease in the main steamline pressure resulting in a closure of the MSIVs, isolating the condenser and causing a reactor scram. (USAR 15.2.4) 13 A failure of the turbine bypass or control valves in the closed position vill isolate the reactor from the condenser. Turbine stop valve closure vill initiate the reactor scram. (USAR 15.2.3) Transients of unknown cause are assumed to result 37 in the loss of the condenser. (No applicable USAR reference) A generator load rejection will cause the fast 1 T3A closure of the turbine control valves which will result in a turbine trip and reactor scram. The (Transient with condenser vill be available. (USAR 15.2.2) PCS available) A turbine trip will cause a reactor scram on the 3 fast closure of the turbine control valves. The condenser will be available. (USAR 15.2.3) A recirculation control failure-increasing flow 14 will result in a high neutron flux reactor scram. The turbine control valves will close on falling turbine pressure. The MSIVs will remain open and the turbine trip will initiate turbine bypass valve operation. (USAR 15.4.5)

Table 3.1.1-5 continued

EPRI Events Included in the Transient Categories

Initiating Event Group	EPRI Transient Category	Rationale For Inclusion
T3A (Transient with PCS available) (Continued)	18	The abnormal startup of an idle recirculation pump is not expected to cause a reactor scram. However, if plant response is exacerbated, the startup could cause a reactor scram on high neutron flux. The MSIVs will remain open and the turbine trip will initiate turbine bypass valve operation. (USAR 15.4.4)
	21	A loss of fee,water heating could result in a high neutron flux reactor scram. The MSIVs will remain open and the turbine trip will initiate turbine bypass valve operation. (USAR 15.1.1)
	27	A rod withdraval at power is not expected to cause a reactor scram due to the rod withdraval limiter function (RVL) of the rod control and limiter system (RC&IS). However, if plant response is exacerbated, it is assumed that the event will cause a reactor scram on high neutron flux. The MSIVs will remain open and the turbine bypass valves will be operable. (USAR 15.4.2)
	29	The inadvertent insertion of a control rod or rods with the assumed failure of the RC&IS will cause a turbine trip on low steam flow. The MSIVs will remain open and the turbine bypass valves will be operable. (No applicable USAR reference)
	30	A detected fault in the reactor protection system can result in a reactor scram. The MSIVs will remain open and the turbine bypass valves will remain open. (No applicable USAR reference)
	34	A scram due to a plant occurrence is not assumed to cause an MSIV isolation or a turbine bypass valve failure. (No applicable USAR reference)
	35	A spurious trip via reactor protection system instrumentation is not assumed to cause an MSIV isolation or the failure of the turbine bypass valves. (No applicable USAR reference)
	36	A manual scram with no out of tolerance conditions is assumed to not cause an MSIV isolation or the failure of the turbine bypass valves. (No applicable USAR reference)

Table 3.1.1-5 continued

EPRI Events Included in the Transient Categories

Initiating Event Group	EPRI Transient Category	Rationale For Inclusion
T3B (Transient with a loss of feedvater)	15	A recirculation control failure-decreasing flow will cause a reactor scram on high RPV water level, resulting in a loss of feedwater. The MSIVs will remain open and the turbine trip will initiate turbine bypass valve operation. (USAR 15.3.2)
	16	The trip of one recirculation pump will not cause a reactor scram. However it is conservatively assumed that the plant response will be similar to the loss of two recirculation pumps. See No. 17 below. (USAR 15.3.1)
	17	The trip of both recirculation pumps will result in a reactor scram on high RPV water level, resulting in a loss of feedwater. The MSIVs will remain open and the turbine trip will initiate turbine bypass valve operation. (USAR 15.3.1)
	19	A recirculation pump seizure would cause a reactor scram on high RPV water level, resulting in the loss of feedwater. The MSIVs will remain open and the turbine trip will initiate turbine bypass valve operation. (USAR 15.3.3)
	20	Increasing feedwater flow at power will cause a reactor scram on high RPV water level, resulting in the loss of feedwater. The MSIVs will remain open and the turbine trip will initiate turbine bypass valve operation. (USAE 15.1.2)
	22	A loss of all feedwater flow will cause a reactor scram on low RPV water level. With no feedwater available the HPCS and RCIC systems will initiate to recover level. It is assumed that the plant operators will take the reactor mode switch to shutdown following the scram thus eliminating the possibility of MSIV closure on low steamline pressure. (USAR 15.2.7)
	23	A trip of one feedwate: (or condensate) pump may not result in a reactor scram if the feedwater control system can compensate. However, it is assumed that such an event would cause a scram on low RPV water level. The MSIVs will remain open and the turbine bypass valves will remain operable. (No USAR ref.)

4

Table 3.1.1-5 Last

EPRI Events Included in the Transient Categories

Initiating Event Group	EPRI Transient Category	Rationale For Inclusion
T3B (Transient with loss of feedwater)	24	A low flow feedwater transient not compensated by the feedwater control system is expected to cause a reactor scram on low RPV water level. The MSIVs will remain open and the turbine bypass valves will remain operable. (No applicable USAR reference)
(Continued)		
	33	The inadvertent startup of HPCS will require the proper compensation by the feedwater control system. Any failure of the control system will potentially result in a reactor scram on either low or high water level. Conservatively, it is assumed to cause a scram on high water level which will result in the loss of feedwater. The MSIVs will remain open and the turbine bypass valves will remain operable. (USAR 15.5.1)
T3C (IORV Transient)	11	An inadvertent opening of a safety/relief valve (stuck) could cause the suppression pool to exceed technical specification limits. A manual scram would be procedurally required. The MSIVs will remain open and the turbine bypass valves will remain operable. (USAR 15.1.4)
N/A	25	A low feedwater flow transient during plant startup or shutdown is not considered within the scope of this study. (See section 3.1.1)
	26	A high feedwater flow transient during plant startup or shutdown is not considered within the scope of this study. (See section 3.1.1)
	28	A high flux due to rod withdrawal at startup is not considered within the scope of this study. (See section 3.1.1)

Table 3.1.2-1

List of Front Line Systems and Support Systems

Frontline Systems

RPV Depressurizaiton

Standby Liquid Control

Residual Heat Removal

Lov Pressure Coolant Injection Mode Containment Spray Mode - Suppression Pool Cooling Mode

Low Pressure Core Spray High Pressure Core Spray Reactor Core Isolation Cooling Condensate/Feedwater Fire Protection Alternate Injection Condensate Transfer Alternate Injection ESV B/RHR B Cross-Tie Alternate Injection Reactor Feed Booster Pump Alternate Injection Containment Venting by Fuel Pool Cooling and Cleanup Containment Venting by RHR Containment Spray

Support Systems

Suppression Pool Make-up Dryw 11 Vacuum Relief ECCS Pump Room Cooling Diesel Generator Room Ventilation Emergency Closed Cooling Nuclear Closed Cooling

Table 3.1.2-1 continued . . .

List of Front Line Systems and Support Systems

Emergency Service Water Safety Related Instrument Air Service/Instrument air Emergency DC Power Emergency AC Power Service Water Turbine Building Ventilation Heater Bay Ventilation Turbine Building Closed Cooling





10

 \boldsymbol{o}



6

Table 3.1.2-2 Support System to Frontline System Dependency Hatrix

Systems	Offsite Power	AC Power	DC Fower A 3 C	DC Power Se	Serv Water A B C	12A 5128 51	Ra 6128 612C 621 622 651	FHB Instr Vent Air	Sfty Hel ECC Inst Air A B	NOC CUTH	Batt Vset
ADS, 821	65		c c						v		
587, 321	8		2 2					c			
MSIV, 871	8							ų			
CREH, CII A	R	Ų						v		æ	c
8	60	v						2			ų
acts, cll	81			¢							
RRCS, C22 Div 1	m		v								
Div 2	8										
SLC, C41 A	a	v									2
40	gi,	e.									s.
11. " S48											
LPCI, E12 A	a	ų	u	8							0
	8	ų	v		ø	÷					u.
v		3	v			2					
LPCS, 821	ņ	¢.1	2				¢				
HPCS, £22	n	v	9				4				
RCIC, ESI	¢0		ç								
FPCC, 541 A	m	4		2	y.					#1	0
a.	A	v		0	Vi						ų
CWC, MIL										40	¢.
Cond, N21	ŧ.							5			v
FW, 1627	8							n			2
789, 332	æ										

ġ

Lagend: A * Interdapender: B = Complete dependence C = Fartial or delayed dependence

e,

a.

Table 3 1.2-3 Support System to Support System Copendency Matrix

Support Systems	Offsite Power	AC Power	DC Power	DC Par	Emergency Serv Water A B C	ESW Pap Ss Vent	FHB Vent	instr Air	Sfty Rel Inst Air			Ares	Cing	CCCW A B	Misc	Batt	DG Vent A B C
Offsite Power																	
SM AC, R43 Div	1		5		A											A	A
Div	2		8		A											A	А.
E22 Div	3		в		A											A	A
1E DC, R42 A	c	c														A	
в	с	c															
c	с	c														A	
Non 18 0C, 842	c													-		A	
ESW, 945 A	в	А				c						 				¢	
в	8	А				с										e	
с	в	A				c										c	
EPRC, M39 E12A	9	с								8						c	
121.28	в	¢								8						<i>c</i>	
E12C	в	с								в						c	
£21	8	c								8						c	
£22	8	c			8											с	
E51	Э	c								8						e	
EPHV, M32 A	В	с														с	
B	8	с														c	
FHBV, M40	5	с														С	
IA, P52	B										B	C	¢			c	
SRIA, P57	8															C	
ECC, P42 A	8	c	с		3							¢	с			с	
в	8	с	2		8							<	c			c	

C =



al or calayed dependence



Table 3.1.2-3 Support System to Support Dependency Matrix (continued)



Support Systems	Offsite Power	Emergency AC Power 1 2 3		DC Pwr	Emergency Serv Water A B C		ESW Pmp Hs Vent	FNB Vent	Instr Air	Sfty Bel Inst Air	ECC A B	NCC C	Area	Cing	CCCW A B	Misc		DG Vent A 8 C
MCC, 943	6	c c	сс			8			ø								c	
CVCH, PS0	8			c					в			в	-		-		-	
EPAC, M28 a	3	c											 					-
B	8	c													Α		C	
CCCW, P47 A	в	c	c								e	8	 		A		<u><u></u></u>	
8	8	с	~										A				a	
c	8			e								8	A				A	
SW, P41	8	c	с	c							cc	8	 A	A.	_	_	A	
MV, M46	8												 			c	¢	
MBV, M23/24	B	c c				-					in in		 -				C	
067, H13 A		A											 		8		A	
	8																c	
		A															e.	
c	6																2	

Legend: A = Interdependent

B = Complete dependence C = Partial or delayed dependence

Table 3.1.2-4

Initiator	RPV Reactivity Control	Ex Coolant System Overpressure Protection	Emergency Core Cooling [a]	Containment Overpressure Protection
TZ	RPS or ARI	SRVs Open & Close	HPCS or RCIC or MFP or ADS (4 SRVs open automatically or manually) and LPCS or 1 of 3 LPCI or Condensate Transfer Alternate Injection [see Note b]	1 of 2 RHR and HX (in SPC or Spray mode) or Containment Venting

Success Criteria for the Loss of PCS Transient (T2)

NOTES:

(a) If emergency depressurization is required, then 4 or more open SRVs are necessary for injection.
 (b) Condensate Transfer Alternate Injection provides 2,000 gpm @ 75 psig using the Condensate Transfer System (CTS) flush connection to the RHR Shutdown Cooling to FDW line. This alignment requires one local valve to be operated in the Auxiliary Building.





.

Table 3.1.2-5

Success Criteria for the Transient with PCS Available (T3A)

Initiator	RP7 Reactivity Control	Rx Coolant System Gverpressure Protection	Emergency Core Cooling [a]	Containment Overpressure Protection
T3A	RPS or ARI	PCS or SRV	HPCS or RCIC or 1 FW or ADS (4 SRV open automatically or manually) and LPCS or 1 of LPCI or Condensate Transfer Alternate Syjection [see Note b]	1 of 2 RHR and HX (in SPC or Spray mode) or PCS or Containment Venting

 (a) If emergency depressurization is required, then 4 or more open SRVs are necessary for success.
 (b) Condensate Transfer Alternate Injection provides 2,000 gpm @ 75 psig using the Condensate Transfer System (CTS) flush connection to the RER Shutdown cooling to FDV line. This alignment requires one local valve to be operated in the Auxiliary Building.

NOTES:

Tab	£	10. 14	 100
1.2433	1.52	5.1	
2.2.2.2.2.	10 m	203	 · · ·

Success Criteria for the Loss of Feedwater Transient (T3B)

Initiator	RPV Reactivity Control	Rx Coolant System Overpressure Protection	Emergency Core Cooling [a]	Containment Overpressure Protection
T3B	RPS or ARI	PCS or SRV	HPCS or RCIC or 1 FW or AD ^C (4 SRV open automatically or manually) and LPCS or 1 of 3 LPCI or Condensate Transfer Alternate Injection [see Note b]	PCS or 1 of 2 RHR and HX (in SPC or Spray Mode) or Containment Venting

NOTES: (a) Condensate Transfer Alternate Injection provides 2,000 gpm @ 75 psig using the Condensate Transfer System (CTS) flush connection to the RHR Shutdown Cooling to FDW line. This alignment requires one local value to be operated in the Auxiliary Building.



No.



0

Table 3.1.2-7

Success Criteria for Large LOCA

1

٠,

Initiator	Reactivity Control	Emergency Core Cooling	Containment Overpressure Protection
Δ	RPS or ARI	EPCS or LPCS or 1 of 3 LPCI	1 of 2 RHR and Hx (in SPC or Spray mode) or Containment Venting

Table 3.1.2-8

Success Criteria for Intermediate LOCA

nitiator	Reactivity Control	Emergency Core Cooling [a]	Containment Overpressure Protection
S1	RPS	HPCS	1 of 2 RHR and Hx
	or	10	(in SPC or Spray mode)
	ARI	Emergency Depressurization	OF
		with 2 SRVs and	Containment Venting
		LPCS or 1 of 3 LPCI	
		or	
		Condensate Transfer Alternate Injection	
		[see Note b]	

NOTES: (a) If emergency depressurization is required, then 2 or more SRVs are necessary for success. For the intermediate LOCA, the break size is assumed equivalent to one open SRV.

(b) Condensate Transfer Alternate Injection provides 2,000 gpm @ 75 psig using the Condensate Transfer system (CTS) flush connection to the RHR Shutdown Cooling to FDW line. This alignment requires one local valve to be operated in the Auxiliary Building.





Table 3.1.2-9

Success Criteria for Small LOCA

Initiator	Reactivity Control	Emergency Core Cooling [a]	Containment Overpressure Protection
52	RPS Or ARI	HPCS or RCIC Jr IFW or Emergency Depressurization with 3 SRVs and LPCS or 1 of 3 LPCI or Condensate Transfer Alternate Injection [see Note b]	l of 2 KHR end Hx (in SPC or Spray mode) or Containment Venting

(a) If emergency depressurization is required, then 3 or more SRVs are necessary for success. NOTES:

(b) Condensate Transfer Alternate Injection provides 2,000 gpm @ 75 psig using the Condensate Transfer system (CTS) flush connection to the RHR Shutdown Cooling to FDW line. This alignment requires one local valve to be operated in the Auxiliary Building.

Table 3.1.3-1

Initiator	RP7 Reactivity Control	Rx Coolant System Overpressure Protection	Emergency Core Cooling [a]	Contaisment Overpressure Protection
Tl	RPS or ARI	SRVs open & close [see Note a]	HPCS or RCIC or Emergency depressurization with 4 or more SRVs and LPCS or 1 of 3 LPCI or Fire Water Cross-tie [see Note b]	1 of 2 RHR and HX (in SPC or Spray Mcde) or Containment Venting

Success Criteria for the Loss of Offsite Pover

NOTES:

(a) If Emergency Depressurization is required then 4 or more open SRVs are necessary for success.

(b) The Fire Water Cross-tie provides 100 gpm @ 120 psig using the ESW cross-tie into the RHR B Shutdown Cooling to Feedwater line. The alignment requires several local valves to be operated.







Table 3.1.3-2

Success Criteria for Station Blackout

8	
ARI [see Note a] Or (in RCIC	Protection 1 of 2 RHR and HX a SPC or Spray Mode) or Containment Venting [see note c]

NOTES:

(a) If Emergency Depressurization is required then 4 or more open SRVs are necessary for success.

(b) Available only upon restoration of either offsite or division 1/2 cosite power.

(c) Fuel Pool Cooling & Cleanup Venting may be performed manually; RHR Containment Spray venting is available only upon restoration of either offsite or division 3 to division 2 cross

(d) The Fire Water Cross-tie provides 800 gpm @ 20 psig using the ESW cross-tie into the RER B Shutdown Cooling to Feedwater line. The alignment requires several local valves to be operated. Fire water can also be crosstied to the HPCS injection line.

Table 3.1.3-3


Success Criteria for IORV Transient (T3C)

Initiator	RPV Reactivity Control	Rx Coolant System Overpressure Protection	Emergency Core Cooling [a]	Containment Overpressure Protection
T3C	RPS or ARI	PCS [see Note b]	HPCS or RCIC or 1FW or Emergency depressurization and LPCS or 1 of 3 LPCI or Condensate Transfer Alternate Injection [see Note c]	l of 2 RHR and HX (in SPC or Spray Mode) or Containment Venting

- NOTES: (a) If emergency depressurization is required, then 3 or more open SRVs are required for success. Open SRVs, due to the transient are included in the required number of open valves.
 - (b) for the IORV transient, it is assumed that the PCS is initially available to r tigate the initial pressure transient upon reactor scram. With the PCS available, the SRVs are required to lift to relieve RPV pressure.
 - (c) Condensate Transfer Alternate Injection provides 2,000 gpm @ 75 psig using the Condensate Transfer System (CTS) flush connection to the RHR Shutdown Cooling to FDV line. This alignment requires one local value to be operated in the Auxiliary Building.



NOTES:



Success Criteria for ATWS

Initiator	RPV Reactivity Control	Rx Coolant System Overpressure Protection	Emergency Core Cooling [a]	Containment Overpressure Protection
T1-C T2-C T3A-C or T3B-C T3C-C T1A-C [see Note a & b]	RPT + 1 of 2 SLC	SRVs open & close [see Note b]	MFP or 1 of 2 TDFPs [see Note d] or 1 of 2 LPCI A/B [see Note f] or LPCS	l of 2 RHR and HX (in SPC or Spray Mode) PCS [see Note e] or Containment Venting

(a) The ATWS initiators are direct transfers from the Initiating Event Trees.

(b) Transfer from TSW is not shown, since it is not significant. Transfers from A, S1 and S2 (i.e., LOCAs) are not developed, as not significant.

- (c) SRVs are required to cycle as necessary in each transient to prevent RPV overpressurization. If Emergency Depressurization is required then conservat vely eight open SRVs are necessary for success. Emergency Depressurization is required for depressurization is based on a conservative estimate that at TAF The eight SRVs assumed required for depressurization is based on a conservative estimate that at TAF with RPT, power level is approximately 20%. 20% power correlates to the capacity of four open SRVs. An additional four SRVs are assumed required to depressurize. Eight SRVs equals the number of ADS valves.
- (d) The Turbine Driven Feed Pumps are potentially available, if offsite AC power and PCS are available and the MSIVs are open. The MFP is available if offsite AC power is available. For this base case ATWS analysis no credit is taken for the Reactor Feedwater Booster Pumps following RPV depressurization.
- (e) The main turbine bypass portion of the PCS can accommodate 35% of reactor thermal power.
- (f) LPCI flow is directed through the Feedwater Return throttle valve to inject outside the shroud.

Table 3.2.1-1

RPV Depressurization System, B21 Dependency Matrix

	ADS Valves (8 Total)	Non-ADS Valves (11 Total)
Class 1E A	*	*
В	*	*
DC Pover C		
Safety Related		
Inst Air, P57	*	
Inst Air P52		*

Table 3.2.2-1

Standby Liquid Control System, C41 Dependency Matrix

Train "A" SLC Train "B" SLC

 *

*

Emergency 1 2 AC Power 3

Tatle 3.2.3-1

Residual Heat Removal System, E12 Dependency Matrix

	Train A	Train B	Train C
Emergency 1	*		*
AC Pover 3			
Class 1E A	*		
B DC Power C		*	*
Emergency A Service B Water C	*	*	*
ECCS Pump			
Room Cooling M39	*	*	*
Emergency A Closed B Cooling P42	*	*	k

Table 3.2.4-1

Low Freesure Core Spray System, E21 Dependency Katrix

LPCS injection

Emergency 1 2	*
AC Pover 3	
Class 1E A B DC Power C	*
Emergency A Closed B Cooling P42	*
ECCS Pump Room Cooling M39	*

Table 3.2.5-1

High Pressure Core Spray System, E22 Dependency Matrix

High Pressure Core Spray Operation

		A DESCRIPTION OF A
	The definited of the strategy of a strategy of the strategy of	
Emergency	1	
	2	
AC Power	3	*
Class IE	Å	
	В	
DC Power	0	*
Emeigency	Α	
Service	В	
Water P45		*
ECCS Pump Room Cool M39	ing	*



Table 3.2.6-1

Reactor Core Isolation Cooling System, E51 Dependency Matrix

RCIC System Operation

×

Class 1E A B DC Pover C

Table 3.2.7-1

Emergency Closed Cooling System, P42 Dependency Matrix

Unit 1 TRAIN A 1 ECC TRAIN B 2 ECC

	the second	A rest of the second	and any or plant is the second providence. The presidence will be available or the million of the state of the second s
Emergency 1 2 Ac Power 3		*	*
Class 1E A B DC Power C		*	*
Emergency Service P45	A B	*	*

Table 3.2.8-1

Emergency Service Water System, P45 Dependency Matrix

No Dependencies Modeled

Table 3.2.9-1

Service/Instrument Air System, P51/52 Dependency Matrix

P51/52			
Offsite Power	*		
Nulcear Closed Cooling P43	*		

Table 3.2.10-1

Safety Related Instrument Air System, P57 Dependency Matrix

	P57	
Emergency 1	*	
AC Power 3	*	
Offsite		
Pover	*	

Table 3.2.11-1

Fire Protection System, P54 Dependency Matrix

Diesel Driven Fire Pump Injection to RPV

Residual Heat Removal E12 Note: (Various E12 Manual Valves Are Only Required)

ESV P45 Note: (Various P45 Manual Valves Are Only Required)

Table 3.2.12-1

5

D.C. Electrical System, R42 Dependency Matrix

	Division I	Division II	Division III
	125 VDC	125 VDC	125 VDC (HECS)
Emergency 1 2 AC Power 3	*	*	*





Table 3.2.13-1

AC Power Standby Diesel Generator System, R43 High Pressure Core Spray Diesel Generator System, E22B Dependency Matrix

		Division 1 Diesel Generator	Division 2 Diesel Generator	Division 3 KPCS Diesel
Class 1E	A	*		
DC Pover	B C		*	*
Emergency Service	i. B	*	*	
Water P45				*

Table 3.2.14-1

Suppression Pool Make Up System, G43 Dependency Matrix

	Train A	Train B	
Emergency 1 2 AC Power 3	*	*	

Table 3.2.14-2

Orywell Vacuum Relief System, M16 Dependency Matrix

Motor Operated Valves Sving Check Valves

Emergency 1 * 2 * AC Power 3

Table 3.2.15-1

8 8

> Diesel Generator Building Ventilation System, M43 Dependency Matrix

> > DGBV Div 1 DGBV Div 2 DGBV Div 3

Laergency 1	*	
AC Power 3		*

Table 3.2.16-1

Alternate Injection System Dependency Matrix

Condensate Transfer Alternate Injection			
Offsite Power	*		
Emergency 1 2 AC Power 3	* (This is an RHR system * dependency)		
Inst Air P52	*		

Table 3.2.17-1

Containment Venting System, D23 Dependency Matrix

Fuel Pool Cooling and Cleanup Venting RHR Containment Spray Venting

Emergency 1	*	*	
AC Power 3	*		

Event	Point Est	Description
A	1.00E-004	LARGE LOSS OF COOLANT ACCIDENT (LARGE LOCA)
ADADUMA	2.04E-003	DIVISION 1 ADS UNAVAILABLE DUE TO TEST & MAINTENANCE
ADADUMS	2.04E-003	DIVISION 2 ADS UNAVAILABLE DUE TO TEST & MAINTENANCE
ADCLDECHNLALOGIC	1.60E-003	DIVISION 1 ACTUATION LOGIC FAILS
ADCLDECHNLBLOGIC	1.60E-003	DIVISION 2 ACTUATION LOGIC FAILS
ADCVCCADSNC	1.00E-005	1B21-F0039 VALVES COMMON CAUSE FAIL TO CLOSE
ADCVCCNONADSNC	1.00E-005	1B21-F036 VALVES COMMON CAUSE FAIL TO CLOSE
ADCVN01B21F0032A	1.00E-004	1821-F0032A CHECK VALVE NC - FAILS TO OPEN
ADCVN01B21F0032B	1.00E-004	1B21-F0032B CHECK VALVE NC - FAILS TO OPEN
ADHICPC5-1-ADS-A	3.79E-003	OPERATOR FAILS TO INHIBIT ADS ATWS W/ FEEDWATER
ADHICPC5-1-ADS-I	3.60E-000	OPERATOR FAILS TO INHIBIT ADS ATWS W/O FDW & IORV
ADHICPC5-1-ADS-L	3.60E-002	OPERATOR FAILS TO INHIBIT ADS ATWS W/ LOOP
ADHICPC5-1-ADS-0	7.20E+000	OPERATOR FAILS TO INHIBIT ADS ATWS V/O FEEDWATER
ADHICPEC2-ADS-LR	9.99E-005	FAILS TO RECOVER FROM RPV DEPRESS CD FAILURE
ADHICPEC2-ADS-R	1.00E-001	FAILS TO RECOVER FROM RPV DEPRESS CD FAILURE
ADHICPEC2-ADS-T	1.00E-003	FAILS TO EMERGENCY RPV DEPRESS TRANSIENT
ADHICPEC5-ADS-FL	7.00E-003	FAILS TO EMERGENCY RPV DEPRESS - ATVS W/FDW & LVL CNTRL
ADHICPEC5-ADS-FX	1.40E-002	FAILS TO EMERGENCY RPV DEPRESS - ATWS W/FDW & NO LVL CNT
ADSRCCADS	8.00E-006	ADS VALVES COMMON CAUSE FAILURE
	1.00E+000	NON-ADS VALVES COMMON CAUSE FAILURE
ADSRN01B2170041A	1.00E-002	1B21-FOO41A SAFETY RELIEF VALVE NC - FAILS TO OPEN
ADSRN01B21F0041B	1.00E-002	1B21-F0041B SAFETY RELIEF VALVE NC - FAILS TO OPEN
ADSRN01B21F0041E	1.008-002	1B21-F0041E SAFETY RELIEF VALVE NC - FAILS TO OPEN
ADSRN01B21F0041F	1.00E-002	1B21-F0041F SAFETY RELIEF VALVE NC - FAILS TO OPEN
ADSRN01B21F0047D	1.00E-002	1821-PO047D SAFETY RELIEF VALVE NC - FAILS TO OPEN
ADSRN01B21F0047H	1.00E-002	1821-FOO47H SAFETY RELIEF VALVE NC - FAILS TO OPEN
ADSRN01B21F0051C	1.00E-002	1821-F0051C SAFETY RELIEF VALVE NC - FAILS TO OPEN 1821-F0051G SAFETY RELIEF VALVE NC - FAILS TO OPEN
ADSRN01B21F0051G ARI	1.00E-002 1.00E-002	ALTERNATE ROD INSERTION FAILS
ASABLFOP61B0001A	5.00E-002	OP61-B0001A AUXILIARY BOILER FAILS TO FUNCTION
ASABLFOP61B00018	5.00E-002	OP61-BOOOIB AUXILIARY BOILER FAILS TO FUNCTION
C	1.00E-005	REACTOR SCRAM CONTROL RODS IN
C108B	0.00E+000	COMPLEMENT TO C108
	1.00E-003	OPERATORS FAIL TO SHIFT CONDENSER AIR REMOVAL TO VP 5 AB
CAVPFR1N62C0001A		1N62-COOO1A VACUUM PUMP FAILS TO RUN
CAVPFR1N62C0001B	7.20E-004	1N62-COOO1B VACUUM PUMP FAILS TO RUN
CAVPFS1N62C0001A	2.93E-003	1N62-CO001A VACUUM PUMP FAILS TO START
CAVFFS1N62C0001B	2.93E-003	1N62-COOO1B VACUUM PUMP FAILS TO START
CBMVFC1M17F0015	2.40E-006	1M17-F0015 MOTOR VALVE NO - FAILS CLOSED
CBMVFC1M17F0025	2.40E-006	1M17-F0025 MOTOR VALVE NO - FAILS CLOSED
CBMVFC1M17F0035	2.40E-006	1M17-F0035 MOTOR VALVE NO - FAILS CLOSED
CBMVFC1M17F0045	2.40E-006	1M17-F0045 MOTOR VALVE NO - FAILS CLOSED
CBVBCC	3.44E-004	M17 VACUUM BREAKERS COMMON CAUSE FAILURES
CRVBF01M17F0010	3.44E-003	1M17-F0010 VACUUM BREAKER NC - FAILS TO OPEN
CBVBF01M17F0020	3.44E-003	1M17-PO020 VACUUM BREAKER NC - FAILS TO OPEN
CBVBF01M17F0030	3.44E-003	1M17-F0030 VACUUM BREAKER NC - FAILS TO OPEN
CBVBF01M17F0040	3.44E-003	1M17-F0040 VACUUM BREAKER NC - FAILS TO OPEN
CCCCLFA	0.00E+000	CONTROL COMPLEX CHILLED WATER TRAIN A TRIPS
CCCCUMA	0.00E+000	CCCW TRAIN A UNAVAILABLE DUE TO MAINTENANCE
CCCCUMB	0.00E+000	CCCW TRAIN B UNAVAILABLE DUE TO MAINTENANCE



	Event	Point Est	Description
	ссссинс	0.002+000	CCCV TRAIN C UNAVAILABLE TUE TO MAINTENANCE
	CCCRCC	0.00E+000	CHILLERS COMMON CAUSE FAILURE
	CCCHFROP47B0001A	0.00E+000	JP4J-BOOOIA CHILLER FAILS TO RUN
	CCCEFROP47800018	0.00E+000	OP47-BOOO1B CHILLER FAILS TO RUN
	CCCHFR0F47B0001C	0.00E+000	0P47-B0001C CHILLER FAILS TO RUN
	CCCHFSOP47B0001A	0.00E+000	OP47-BOOOIA CHILLER FAILS TO START
	CCCHFSOP47B0001B	0.00E+000	OP47-BOOO1B CHILLER FAILS TO START
	CCCHFSOP47B0001C	0.00E+000	0P47-B0001C CHILLER FAILS TO START
	CCHICP	0.00E+000	OPERATOR FAILS TO BYPASS LUCA SIGNAL IN 4.5 HOURS
	CCHICPSP47-5:4	0.00E+000	OPERATOR FAILS TO REALIGN CCCV LOOP C IN 4.5 HOURS
	CCMPCC	0.00E+000	CCCV MOTOR PIMP COMMON CAUSE FAILURES
	CCMPFROP47C0001A	3.00E-011	OP47-COOO1A JTOR FUMP FAILS TO RUN
	CCMPFROP47C0001B	3.00E-011	OP47-COOO1B MOTOR PUMP FAILS TO RUN
	CCMPFR0P47C0001C	3.00E-011	Gr47-CO001C MOTOR PUMP FAILS TO RUN
	CCMPFSOP47C0001A	2.93E-003	OP47-COOO1A MOTOR FUMP FAILS TO START
	CCMPFS0P47C0001B	2.93E-003	OP47-COOO1B MOTOR PUMP FAILS TO START
	CCMPFS0P47C0001C	2.93E-003	OP47-COOOIC MOTOR PUMP FAILS TO START
	CCMVNCOP47F0550	2.93E-003	OF47-F0550 MOTOR VALVE FAILS TO CLOSE - NO
	CCMVNCOP47F0551	2.93E-003	OP47-F0551 MOTOR VALVE FAILS TO CLOSE - NO
	CCTRNARECOVERED4	0.00E+000	CCCW TRAIN A RECOVERED IN 4 HOURS
	CDHICPPS2:1-XH11	1.00E-001	OPERATOR FAILS TO BYPASS THE RHR LOCA SIGNAL - XH11
融	CDHICPPS2:1-XH12	1.00E-001	OPERATOR FAILS TO BYPASS THE RHR LOCA SIGNAL - XH12
37	CDHICPPS2:1-XH1X	1.00E-003	OPERATOR FAILS TO BYPASS THE RHR LOCA SIGNAL - XHIX
	CE	2.00E-005	ELECTRICAL FAILURE ROD INSERTION SIGNAL
	CF	1.00E+000	CONTAINMENT FAILS DUE TO EXTERNAL PRESSURE
	CICLDEISOLOGIC	1.60E-003	FLOOD PROTECTION ACTUATION LOGIC
	CICLLF1N71F0020A	1.25E-004	1N71-F0020A CONTROL LOGIC FAILS TO FUNCTION
	CICLLF1N71F0020B	1.25E-004	1N71-F0020B CONTROL LOGIC FAILS TO FUNCTION
	CICLLF1N71F0020C	1.25E-004	1N71-F0020C CONTROL LOGIC FAILS TO FUNCTION
	CICLLF1N71F0030C	1.25E-004	1N71-F0030C CONTROL LOGIC FAILS TO FUNCTION
	CICLLF1N71F0030D	1.25E-004	1N71-F0030D CONTROL LOGIC FAILS TO FUNCTION
	CICLLF1N71F0140A	1.25E-004	1N71-F0140A CONTROL LOGIC FAILS TO FUNCTION
	CICLLF1N71F0140B		1N71-F0140B CONTROL LOGIC FAILS TO FUNCTION
	CICLLF1N71F0140C	1.25E-004	1N71-F0140C CONTROL LOGIC FAILS TO FUNCTION
	CICLLFIN71.0140D	1.25E-004	1N71-F0140D CONTROL LOGIC FAILS TO FUNCTION
	CIMVLF1N71F0030A	5.00E-001	1N71-F0030A VALVE FAILS DUE TO PIPE BREAK
	CIMVLF1N71F0030B	2.50E-001	1N71-F0030B VALVE FAILS DUE TO PIPE BREAK
	CIMVNC1N71F0020A	2.93E-003	1N71-F0020A MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNC1N71F0020B	2.93E-003	1N71-F0020B MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNC1N71F0020C	2.93E-003	1N71-F0020C MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNC1N71F0030C	2.93E-003	1N71-F0030C MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNC1N71F0030D	2.938-003	1N71-F0030D MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNCIN/IF0140A	2.93E-003	1N71-F0140A MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNC1N71F0140B	2.93E-003	1N71-F0140B MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNC1N71F0140C	2.935-003	1N71-F0140C MOTOR VALVE FAILS TO CLOSE - NO
	CIMVNCIN71F01400	2.93E-003	1W71-F0140D MOTOR VALVE FAILS TO CLOSE - NO
100	CM	1.00E-005	MECHANICAL FAILURE CONTROL RODS
1	CNAVF01N21F0220	2.40E-006	1N21-F0220 AIR VALVE NC - FAILS OPEN
1349	CNAVF01N27F0305	2.40E-006	1N27-F0305 PNEUMATIC VALVE NC - FAILS OPEN
	CNAVNC1N21F0230	2.00E-003	1N21-F0230 PNEUMATIC VALVE NO - FAILS TO CLOSE
	Summer and a second	#100#-00J	and a very analytical marker of a first to the off

Event	Point Est	Description
CNMVN01N27F0200	2.93E-003	1N27-F0200 MOTOR VALVE NC - FAILS TO OPEN
CNXVN01N27F0508	1.00E-004	1N27-F0508 MANUAL VALVE NC - FAILS TO OPEN
CNXVN01P81F0553	1.00E-004	1P81-F0553 MANUAL VALVE NC - FAILS TO OPEN
CSCLDEA	1.60E-003	TRN & CNTNMNT SPRAY ACTUATION LOGIC HARDWARE FAILURE
CSCLDEB	1.60E-003	TRN B CNTNMNT SPRAY ACTUATION LOGIC HARDWARE FAILURE
CSHICPET-2:P-1	1.702-002	OPERATOR FAILS TO INITIATE RHR CONTAINMENT SPRAY
CSHICPET-2:P-1-A	1.70E-002	OPERATOR FALS TO INITIATE TEN A RHR CONTAINMENT SPRAY
CSHICPET-2:P-1-B	1.70E-002	OPERATOR FAILS TO INITIATE TRN B RHR CONTAINMENT SPRAY
CSMVCC	9.252-005	CNTNMNT SPRAY VLVS COMMON CAUSE FAILURE
CSMVNC1E12F0042A	2.93E-003	1E12-FOO42A MOTOR VALVE NO - FAILS TO CLOSE
CSMVNC1F12F0042B	2.93E-003	1E12-F0042B MOTOR VALVE NO - FAILS TO CLOSE
CSMVN01E12F0028A	2.93E-003	1E12-FOO28A MOTOR VALVE NC - FAILS TO OPEN
CSMVN01E12F0028B	2.93E-003	1E12-FOO28B MOTOR VALVE NC - FAILS TO OPEN
CSMVN01E12F0537A	2.93E-003	1E12-F0537A MOTOR VALVE NC - FAILS TO OPEN
CSMVN01E12F0537B	2.93E-003	1E12-F0537B MOTOR VALVE NC - FAILS TO OPEN
CSPXCCCNT	9.59E-006	CONTAINMENT PRESS COMMON CAUSE MISCALIBRATION
CSPXDE1E12N0662A	9.59E-005	1E12-NO662A CNT PRS PRESSURE INSTRUMENT FAILS TO FUNCTION
CSPXDE1E12N0662B	9.59E-005	1E12-NO662B CNT PRS PRESSURE INSTRUMENT FALLS TO FUNCTION
CSPXDE1E12N0662C	9.59E-005	1E12-NO66?C CNT PRS PRESSURE INSTRUMENT FAILS TO FUNCTION
CSPXDE1112N0662D	9.59E-005	1E12-NO662D CNT PRS PRESSURE INSTRUMENT FAILS TO FUNCTION
CSTILF1E12K93A	2.93E-004	1E12-F93A TIME DELAY RELAY FAILS TO FUNCTION
CSTILF1E12K93B	2.93E-004	1E12-K93B TIME DELAY RELAY FAILS TO "UNCTION 1E12-F0300A AIR VALVE NO - FAILS TO OPEN
CTAVNO1E12F0300A	2.00E-003	1E12-F0300B AIR VALVE NC - FAILS TO OPEN
CTAVNO1E12F0300B	2.00E-003	1P11-COOOIA CONTROL LOGIC FAILS TO FUNCTION
CTCLLF1F11C0001A	1.25E-004 1.25E-004	1P11-COOO1B CONTROL LOGIC FAILS TO FUNCTION
CTCLLF1P11C0001B	-5.00E-002	CTS PUMP 1P11-COO1A UNAVAILABLE DUE TO MAINTENANCE
CTCTUM1P11COOCIA	5.00 -002	CTS PUMP 1P11-COOID UNAVAILABLE DUE TO MAINTENANCE
CTCTUM1P11C00 B CTCVN01E12F0063A	1.00E-004	1E12-FOO63A CHECK VALVE NC - FAILS TO OPEN
CTCVN01E12F0063B	1.00E-004	1E12-FOO63B CHECK VALVE NC - FAILS TO OPEN
CTHICPPS4:4-ALT	1.00E-001	OPERATOR FAILS TO ALIGN CONDENSATE XFER ALT INJECTION
CTT CPPS4:4-ALT6	1.00E-003	OPERATOR FAILS TO ALIGN CONDENSATE TRANSFER IN 6 HOURS
ClaiCTPS4:4-ALTC	3.00E-001	OPERATOR FAILS TO ALICN CONDENSATE XFER ALT INJECTION
CTMFCC	2.93E-004	CTS PUMP COMMON DAUSE FAILURE
CTMPFR1P11C0001A		
CTMPFR1P11C0001B	7.20E-004	1P11-COOO15 MOTOR PUN'P FAILS TO RUN
CTMPFS1P11C0001A	2.93E-003	1P17-COOT A MOTOR FUMP FAILS TO START
CTMPFS1P11C0001B	2.93E-003	1P11-COOO1B MOTOR PUMP FAILS TO START
CTSVLC1E12F0301A	2.40E-006	1E12-F0301A SOLENOID VALVE FAILS TO FUNCTION
CTSVLC1E12F0301B	2.40E-006	1E12-F0301B SOLENOID VALVE FAILS TO FUNCTION
CTSVLF: E12F0301A	2.00E-003	1E12-F0301A SOLENOID VALVE FAILS TO FUNCTION
CTSVLF1E12F0301B	2.00E-003	1E12-F0301B SOLENOID VA!VE FAILS TO FUNCTION
CV01	4.30E-001	CORE VULNERABLE HERS OF RATING
CVO2	2.60E-001	CORE VULNERABLE LOW PRESS INJ OPER
CV03	4.00E-002	CORE VULMERABLE FDV OPERATING
CVO4	0.00E+000	COTE VULNERABLE INJ OUTSITE AB
CV05	1.40E-001	E VULNERABLE ANCHORATE FAILURE CONTAINMENT SPRAY A CONTROL LOGIC SEAL-IN RESET FAILS
CVCLLF1E12S64A	15E-004	
CVCLLF1E12S64B	1.25E-004	
CVCLLF1G41F0140	1.25E-004	1C41-F0140 CONTROL LOGIC FAILS

Ev	ent	Point Est	Description
		1.25E-004	1G41-F0145 CONTROL LOGIC FAILS
	HICPEPC-COM		FAILS TO INITIATE CNTNMNT PRESS CNTRL RHR AND VENT
	HICPEPC-FPCC		FAILS TO INITIATE CNTNMNT PRESS CNTRL VENTING
	HICPEPC-RHR		FAILS TO INITIATE CNTNMNT PRESS CNTRL RHR
	HICPEPC-RHR-E		FAILS TO INITIATE CNTNMNT PRESS CNTRL RHR - S.P. CLNG
	KICPPS7-RHR		OPERATOR FAILS TO INITIATE RHR CONTAINMENT VENTING
	HICPPS7:1 P T		OPERATOR FAILS TO PREPARE FOR RHR CNTNMNT VENT - TRAN
	HICPPS712. T		OPERATOR FAILS TO ALIGN FPCC FOR CNTNMNT VENT - TRAN
	HICPPS7:4E12-T		OPERATOR FAILS TO ALIGN RER FOR CNTNMNT VENT - TRAN
	HICRPS7:3G41-T		OPERATOR IS UNABLE TO LOCALLY OPEN 1G41-F0145
	/MV1G41F0140FC		
			FRACTION OF TIME IN SBO THAT D. DID NOT STAFT
			1E12-FOOO3A MOTOR VALVE NO -FAILS TO CLOSE
			1E12-FOOO3B MOTOR VALVE NO - FAILS TO CLOSE
CV	/MVN01G41F0140	2.93E-003	1G41-F0140 MOTOR VALVE FAILS TO OPEN
CV	/MVN01G41F0145	2.93E-003	1G41-F0145 MOTOR VALVE FAILS TO OPEN
	BCLLF1M43C0001A		1M43-COOO1A CONTROL LOGIC FAILS TO FUNCTION
	BCLLF1M43C0001B		1M43-COOO1B CONTROL LOGIC FAILS TO FUNCTION
	BCLLF1M43C0001C		1M43-CO001C CONTROL LOGIC FAILS TO FUNCTION
	SCLLF1M43COOC2B		1M43-COOO2B CONTROL LOGIC FAILS TO FUNCTION
	BCLLF1M43C0002C		1M43-COOO2C CONTROL LOGIC FAILS TO FUNCTION
	BCLLFDIVITRAIN1		DG BLOG VENT DIV 1 CONTROL LOGIC TRN 1 FAILS TO FUNC
		1.25E-004	DG BLDG VENT DIV 1 CONTROL LOGIC TRN 2 FAILS TO FUNC
	BCLLFDIV2TRAIN1	1.25E-004	DG BLDG VENT DIV 2 CONTROL LOGIC TRN 1 FAILS TO FUNC
		1.25E-904	DG BLDG VENT DIV 2 CONTROL LOGIC TRN 2 FAILS TO FUNC
		1.25E-004	DG BLDG VENT DIV 3 CONTROL LOGIC TRN 1 FAILS TO FUNC
		1.25E-004	DG BLDG VENT DIV 3 CONTROL LOGIC TRN 2 FAILS TO FUNC
	BLVCC	2,93E-005	DG BLDG VENT LOUVER COMMON CAUSE FAILURE
	BLVFC1M43F0771A	2.40E-006	1M43-F0071A LOUVER NO - FAILS CLOSED
	BLVFC1M43F0071B	2.40%-006	1M43-FOO71B LOUVER NO - FAILS CLOSED
	BLVN01M43F0070A	2.93E-003	1M43-FOO70A LOUVER NC - FAILS TO OPEN
	BLVNC1M43F0070B	2.93E-003	1M43-F0070B LOUVER NC - FAILS TO OPEN
	BLVN01M43F0070C	2.93E-003	1M43-F0070C LOUVER NC - FAILS TO OPEN
	BLVN01M43F0071C	2.93E-003	1M43-F0071C LCUVER NO - FAILS CLOSED
	BLVN01M43F00B0A	2.93E-003	1M43-FOO80A LOUVER NC - FAILS TO OPEN
	BLVN01M43F0080B	2.93E-003	1M43-FOO80B LOUVER NC - FAILS TO OPEN
	BLVN01M63F0080C	2.93E-003	1M43-FOOBOC LOUVER NC - FAILS TO OPEN
	BLVN01M43F00B1A	2.93E-003	1M43 FOO81A LOUVER NC - FAILS TO OPEN
	BLVN01M43F0081D	2.93E-003	1M43-FOO81B LOUVER NC - FAILS TO OPEN
	BLVN01M43F0081C	2.93E-003	1M43-F0081C LOUVER NC - FAILS TO OPEN
	BMDCC	2.93E-005	DG BLDG VENT COMMON CAUSE MOTOR DAMPER FAILS
	BMDFC1M43F0020A	2.40E-006	1M43-F0020A MOTOR DAMPER FAILS CLOSED
	BMDFC1M43F0020B	2.402-006	1M43-F0020B MOTOR DAMPER FAILS CLOSED
	BMDFC1M43F0020C	2.40E-006	1N43-FOO2OC MOTOR DAMPER FAILS CLOSED
	BMDFC1M43F0030A	2.40E-006	1M43-F0030A MOTOR DAMFER FAILS CLOSED
	BMDFC1M43F0030B	2.40E-006	1M43-F0030B MOTOR DAMPER FAILS CLOSED
	BMDFC1M43F0030C	2.40E-006	1M43-F0030C MOTOR DAMPER FAILS CLOSED
	BMDFC1M43FGO31A	2.40E-006	1M43-F0031A MOTOR DAMPER FAILS CLOSED
	BMDFC1M-3F0031B	2.40E-006	1H43-F0031B MOTOR DAMPER FAILS CLOSEL
DI	BMDFC1M43F0031C	2.40E-006	1M43-F0031C MOTOR DAMPER FAILS CLOS

....

A)

h

Event	Point Est	Description
And the second s	2.40E-006	1M43-F0220A MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0220A	2.408-006	1M43-F0220B MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0220B	2.40E-006	1M43-F0220C MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0220C	2.40E-006	1843-F0230A MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0230A	2.40E-006	1M43-F0230B MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0230B	2.40E-006	1M43-F0230C MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0230C	2.408-006	1M43-F0231A MOTOR DAMPER FAILS CLOSED
DBMDFC1M43FC231A	2.40E-006	1MA3-F0231B MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0231B	2.40E-006	1M43-F0231C MOTOR DAMPER FAILS CLOSED
DBMDFC1M43F0231C	2.93E-005	DG BLDG VENT MOTOR FAN COMMON MODE FAILURE
DBMFCC	1.20E-004	1843-COODIA MOTOR FAN FAILS TO RUN
DBMFFR1M43C0001A	1.20E-004	1M43-COOO1B MOTOR FAN FAILS TO RUN
UBMFFR1M43C0001B	1.20E-004	1M43-COUDIC MOTOR FAN FAILS TO RUN
DBMFFR1M43C0001C	1.20E-004	1M43-COOU2A MOTOR FAN FAILS TO RUN
DBMFFR1M43C0002A	1.20E-004	1M43-COOO2B MOTOR FAN FAILS TO RUN
DBMFFR1M43C0002B	1.208-004	1M43-COOO2C MOTOR FAN FAILS TO RUN
DBMFFR1M43C0002C	2.93E-003	1M43-COOO1A MOTOR FAN FAILS TO START
DBMFFS1M43C0001A	2.93E-003	1M43-COOO1B MOTOR FAN FAILS TO START
DBMFFS1M43C0601B	2.938-003	1M43-COOPIC MOTOR FAN FAILS TO START
DBMFFS1M43C0001C	2.93E-003	1M43-COOOZA MOTOR FAN FAILS TO START
DBMFFS1M43C0002A	2.93E-003	1M43-COOO2E MOTOR FAN FAILS TO START
DBMFFS1M43C00023		1M43-COOO2C MOTOR FAN FAILS TO START
DBMFFS1M43C0002C	2.93E-003	1M43-COO1A & COO2A UNAVAILABLE D'IE TO MAINTENANCE
DPMFUMDIV1	1.36E-003	1M43-COOIB & COO2B UNAVAILABLE DUE TO MAINTENANCE
DIMFUMUIV2	1.36E-603	1M43-COOIC & COO2C UNAVAILABLE DUE TO MAINTENANCE
DBMFUMDIV3	1.36E-003	EFDIC BATTERY CHARGER HARDWARE FAILURE
DCBCLC1E22S0006	2.40E-005	EFDIA BATTERY CHARGER HARDWARE FAILURE
DCBCLC1R42S0006	2.40E-005	ED12A RES BATTERY CHARGER HARDWARE FAILURE
DCBCUC1R42S0007	2.40E-005	EFDIB BATTERY CHARGER HARDWARE FAILURE
DCBCLC1R42S0008	2.40E-005	EDF12B RES BATTERY CHARGER HARDWARE FAILURE
DCBCLC1R42S0009	2.40E-005	EDF12C RES BATTERY CHARGER DARDWARE FAILURE
DCBCLC1R42S0011	2.40E-005	EDF120 RATTERY CHARGER HARDWARE FAILURE
DCBCLC2R42S0006	2.40E-005	EFD2B BATTERY CHARGER HARDWARE FAILURE
DCBCLC2R42SOOC	2.40E-005	ED-1-A 125 V DC BUS HARDWARE FAILURE
DCB1 LC1R42S0024	3.12E-006	ED-1-B 125 V DC JUS HARDWARE FAILURE
DCBD_C1R42S0025	3.12E-005	ED-1-C 125 V DC BUS HARDVARE FAILURE
DCBELC1R42S0037	3.12E-006	ED-2-A 125 V DC BUS LARDWARE FAILURE
DCBD-C2R42S0024	3.12E-006	ED-2-8 125 V DC BUS HARDWARE FAILURE
DCBD. C2R42 50025	3.12E-006	BATTERY COMMON CAUSE FAILURE
DCBTCC	1.37E-005	
DCBTLC1E22SU005	1.37E-0C3	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
DCBTLC1R42S0002	1.37E-003	The second
DCBTLC1R42S0003	1.37E-003	A DECK OF THE PARTY OF THE PART
DCBTLC2E22S0005	1.37E-003	The second
DCBTLC2R42S0002	1.37E-003	A DESCRIPTION OF DESCRIPTION OF A DESCRI
DCBTLC2R42S0003	1.37E-003	DATTERN 1E22_SOOOS UNAVAILABLE DUE TO MAINTENANCE
DCBTUM1E22S0005	4.38E-004	THE TO BOOKS INTATIANTE DIE FUIR TO MAINTENANCE
DCBTUM1R42S0002	4.38E-004	A DECK AND A AND A AND A DECK
DCBTUM1RA2S0003		
DCBTUM2R42S0002		
DCBTUM2R42S0003	4,38E-004	i DVIIDUI ELAT-DOLOD GUILLITURDO CON LA



Event	Point Est	Description
DGBALC1R2250006	9.605-005	EH12 4160 V AC BUS HARDWARE FAILURE
DGBALC1R2250007	9.60E-005	EH11 4160 V AC BUS HARDWARF FAILURE
DGBALC1R23S0009	9.60E-005	EF-1-A 480 V AC BUS HARDWARE FAILURE
DGBALC1R23S0010	9.60E-005	EF-1-B 480 V AC BUS HARDWARE FAILURE
DGBALC1R23S0011	9.60E-005	EF-1-C 480 V AC BUS HARDVARE FAILURE
DGBALC1R23S0012		EF-1-D 480 V AC BUS HARDWARE FAILURE
DGBALC1R24S0029	9.60E-005	EFIE MCC HARDVARE FAILURE
DGBALC2R23S0010	9.60E-005	EF-2-B 480 V AC BUS HARDWARE FAILURE
DGBALC2R23S0012	9.60E-005	EF-2-D 480 V AC BUS HARDWARE FAILURE
DGCUDE1R43S0001A	1.60E-003	DIV 1 D/G ACTUATION LOGIC FAILURE
DGCLDE1R43S0001B	1.60E-903	DIV 2 D/G ACTUATION LOGIC FAILURE
DGDGCC	3.67E-004	DIESEL GENERATOR COMMON MODE FAILURE
DGDGFR1R43S0001A	7.86E-003	DIVISION 1 DIESEL GENERATOR FAILS TO RUN
DGDGFR1R43S0001B	7.86E-003	DIVISION 2 DIESEL GENERATOR FAILS TO RUN
DGDGFS1R43S0001A	3.00E-002	DIVISION 1 DIESEL GENERATOR FAILS TO START
DGDGFS1R43S0001B	3.00E-002	DIVISION 2 DIESEL GENERATOR FAILS TO START
DGDGUM1R43S0001A	3.08E-002	DIV 1 D/G UNAVAILABLE DUE TO MAINTENANCE
DGDGUM1R43S0001B	3.08E-002	DIV 2 D/G UNAVAILABLE DUE TO MAINTENANCE
DGHICPOS11-2:5	1.25E-003	OPERATOR FAILS TO INITIATE DIESEL GENERATORS
DGHICPOS11-2:5:A	1.25E-003	OPERATOR FAILS TO INITIATE DIV 1 D/G
DGHICPOS11-2:5:B	1.25E-003	OPERATOR FAILS TO INITIATE DIV 2 D/G
DGHIMASR43-4:1:A	0.00E+000	FAILURE TO RESTORE FOLLOWING MAINTENANCE
DGHIMASR43-4:1:B	0.002+000	FAILURE TO RESTORE FOLLOWING MAINTENANCE
DGHXFL1R46B0002A	2.05E-003	1R46-B0002A HEAT EXCHANGER PLUGS
DGHXPL1R46B0002B	2.05E-003	1R46-B0002B HEAT EXCHANGER PLUGS
DHBALC1R22S0009	9.602-005	EH13 4160 V AC BUS HARDWARE FAILURE
DHCLDE1E22S0001	1.60E-003	DIV 3 D/G ACTUATION LOGIC FAILURE
DHDGFR1E22S0001		DIVISION 3 DIESEL GENERATOR FAILS TO RUN
DHDGFS1E22S0001		DIVISION 3 DIESEL GENERATOR FAILS TO START
DHDGUM1E22SOG01		DIV 3 D/G UNAVAILABLE DUE TO MAINTENANCE
	1.25E-003	OPERATOR FAILS TO INITIATE DIV 3 D/G
DHHIMASE22B-4:1	0.09E+000	FAILURE TO RESTORE FOLLOWING MAINTENANCE
DHHXPL1E22S0001	2.05E-003	1E22-SOOO1 HEAT EXCHANGER PLUGS
DMCLLF1M43C0002A	1.25E-004	1M43-COOO2A CONTROL LOGIC FAILS TO FUNCTION
DVMVCC	9.55E-005	M16 VACUUM BREAKERS COMMON CAUSE FAILURES
DVMVN01M16F0010A	2.93E-003	1M16-FOOIDA MOTOR VALVE NC - FAILS TO OPEN
DVMVN01M16F0010B	2.93E-003	1M16-FOO10B MOTOR VALVE NC - FAILS TO OPEN
DVVBN01M16F0020A	1.00E-004	1M16-FOO2OA VACUUM BREAKER NC - FAILS TO OPEN
DVVBN01M16F0020B	1.00E-004	1M16-FOO2OB VACUUM BREAKER NC AILS TO OFEN
E1DGACEH1112	2.00E-001	FAILURE TO RESTORE DIV 1 DIESEL GEN IN 12 MOURS
E1DGACEH1124	2.00E-001	FAILURE TO RESTORE DIV 1 DIESEL GEN IN 24 HOURS
E1DGACEH116	6.00E-001	FAILURE TO RESTORE DIV 1 DIESEL GEN IN 6 HOURS
E1DGACEH118	5.0CE-001	FAILURE TO RESTORE DIV 1 DIESEL GEN IN 8 HOURS
E2DGACEH1212	2.00E-001	FAILURE TO RESTORE DIV 2 DIESEL GEN IN 12 HOURS
E2DGACEH1224	2.00E-001	FAILURE TO RESTORE DIV 2 DIESEL GEN IN 24 HOURS
E2DGACEH126	6.00E-001	FAILURE TO RESTORE DIV 2 DIESEL GEN IN 6 HOURS
E2DGACEH128	5.00E-001	FAILURE TO RESTORE DIV 2 DIESEL GEN IN & HOURS
ECCLLF1P42/0001A	1.25E-004	1P42-COOOIA CONTROL LOGIC FAILS TO FUNCTION
ECCLLF1, 42C0001B	1.25E-004	1P42-COOO1B CONTROL LOGIC FAILS TO FUNCTION
ECCVN01P42F0519A	1.00E-004	1P42-F0519A CHECK VALVE NC - FAILS TO OPEN

W

APRIL 5

Event	Point Est	Description
		ANA POLICE CURCH MALUE NO. PATTO TO OPEN
ECCVN01P42F0519B	1.00E-004	1F42-F0519B CHECK VALVE NC - FAILS TO OPEN ECC TRAIN A UNAVAILABLE DUE TO MAINTENANCE
ECECUMA	1.98E-002	ECC TRAIN & UNAVAILABLE DUE TO MAINTENANCE
ECECUMB	1.98E-002	OPERATOR FAILS TO CLOSE VALVE OP42-F0150A(B)
ECHICPSP42-4:2	5.00E-002 5.00E-002	OPERATOR FAILS TO CLOSE VALVE OF42-F0150A(B)
ECHICPSP42-412A	5.008-002	OPERATOR FAILS TO CLOSE VALVE OF42-F0150B
ECHICPSP42-4:2B		OPERATOR FAILS TO INITIATE PUMP 1P42-COOO1A(B)
ECHICPSP42-4PMP ECHICPSP42-4PMPA	5.00E-002	OPERATOR FAILS TO INITIATE PUMP 1P42-COOOIA
ECHICPSP42-4PMPB	5.00E-002	OPERATOR FAILS TO INITIATE PUMP 1P42-COOO1B
ECHIMASP42-4:1A	0.00E+000	ECC TRAIN A NOT RESTORED FOLLOWING MAINTENANCE
ECHIMASP42-4:1B	0.00E+000	ECC TRAIN B NOT RESTORED FOLLOWING MAINTENANCE
ECHXPL1P42B0001A	2.05E-0C3	1P42-B0001A HEAT EXCHANGER PLUGS
ECHXPL1P42B0001B	2.05E-003	1P42-BOOO1B HEAT EXCHANGER PLUGS
ECMPCC	1.19E-005	ECC MOTOR PUMP COMMON CAUSE FAILURE
ECMPFR1P42C0001A	7.20E-004	1P42-COOO1A MOTOR PUMP FAILS TO RUN
ECMPFR1P42C0001B	7.20E-004	1P42-COOO1B MOTOR PUMP FAILS TO RUN
ECMPFS1F42C0001A	2.93E-003	1P42-COOO1A MOTOR PUMP FAILS TO START
ECMPFS1P42C0001B	2.93E-003	1P42-COOO1B MOTOR PUMP FAILS TO START
ECMVCC	9 25E-005	ECC MOTOR VALVE COMMON CAUSE FAILURE
ECMVNCOP42F0150A	2.93E~003	OP42-F0150A MOTOR VALVE NO - FAILS TO CLOSE
ECMVNCOP42F0150B	2.93E-003	OP42-F0150B MOTOR VALVE NO - FAILS TO CLOSE
ECXVPL1P42F0515A	4.50E-005	1P42-F0515A MANUAL VALVE PLUGS
ECXVPL1P42F0515B	4.50E-005	1P42-F0515B MANUAL VALVE PLUGS
ECXVPL1P42F0520A	4.50E-005	1F42-F0520A MANUAL VALVE PLUGS
ECXVPL1P42F0520B	4.50E-005	1P42-F0520B MANUAL VALVE PLUGS
ECXVPL1P42F0527A	4.50E-005	1P42-F0527A MANUAL VALVE PLUGS
ECXVPL1P42F0527B	4.50E-005	1P42-F0527B MANUAL VALVE PLUGS
ECXVPL1P42P0555A	4.50E-005	1P42-F0555A MANUAL VALVE PLUGS
ECXVPL1P42F0555B	4.50E-005	1P42-F0555B MANUAL VALVE PLUGS
ECXVPL1P42F0555C	4.50E-005	1P42-F0555C MANUAL VALVE PLUGS
ECXVPL1P42F0558A	4.50E-005	1P42-F0558A MANUAL VALVE PLUGS 1P42-F0558B MANUAL VALVE PLUGS
ECXVPL1P42F0558B	4.50E-005	1P42-F0558C MANUAL VALVE FLUGS
ECXVPL1P42F0558C	4.50E-005 1.25E-004	1M39-BOOOIA CONTROL LOGIC FAILS TO FUNCTION
EPCLLF1M39B0001A		
EPCLLF1M39BG001B	1.25E-004	1M39-BOOOD CONTROL LOGIC FAILS TO FUNCTION
EPCLLF1M39B0002 EPCLLF1M39B0003	1.25E-004	1M39-BOOO3 CONTROL LOGIC FAILS TO FUNCTION
EPCLLF1M39B0004	1.25E-004	1M39-BOOO4 CONTROL LOGIC FAILS TO FUNCTION
EPCLLF1M39B0006	1.25E-004	1M39-BOOO6 CONTROL LOGIC FAILS TO FUNCTION
EPEPUMHPCS	1.63E-003	ECCS PMP RM CLNG FOR HPCS UNAVAIL DUE TO MAINTENANCE
EPEPUMLPCIA	1.63E-003	ECCS PMP RM CLNG FOR LPCI A UNAVAIL DUE TO MAINTENANCE
EPEPUMLPCIB	1.63E-003	ECCS PMP RM CLNG FOR LPCI B UNAVAIL DUE TO MAINTENANCE
EPEPUMLPCIC	1.63E-003	ECCS PMP RM CLNG FOR LPCI C UNAVAIL DUE TO MAINTENANCE
EPEPUMLPCS	1.63E-003	ECCS PMP RM CLNG FOR LPCS UNAVAIL DUE TO MAINTENANCE
EPEPUMRCIC	1.63E-003	ECCS PMP RM CLNG FOR RCIC UNAVAIL DUE TO MAINTENANCE
EPFACCEPRCS	3.75E-006	ECCS PMP RM CLNG COMMON MODE COOLER FAILURE
EPFAFR1M39B0001A	3.00E-004	1M39-BOOOIA FAN FAILS TO RUN
EPFAFR1M39B0001B	3.00E-004	1M39-BOOO1B FAN FAILS TO RUN
EPFAFR1M39B0002	3.00E-004	1M39-BOOO2 FAN FAILS TO RUN
EPFAFR1M39B0003	3.00E-004	1M39-B0003 FAN FAILS TO RUN

0.

	Event	Point Est	Description
	EPFAFR1M39B0004	3,00E-004	1M39-B0004 FAN FAILS TO RUN
	EPFAFR1M39B0006	3.00E-004	1H39-BOOOG FAN FAILS TO RUN
	EPFAFS1M39B0001A	3.75E-004	1M39-BOODIA FAN FAILS TO START
	EPFAFS1M39B0001B	3.75E-004	1M39-BOOO1B FAN FAILS TO START
	EPFAFS1M39B0002	3.75E-004	1M39-B0002 FAN FAILS TO START
	EPFAFS1M39B0003	3.75E-004	1M39-B0003 FAN FAILS TO START
	EPFAFS1M39B0004	3.75E-004	1M39-BOOO4 FAN FAILS TO START
	EPFAFS1M39B0006	3.75E-004	1M39-BOOCS FAN FAILS TO START
	EPXVPL1P42F0537	4.50E-005	1P42-F0537 MANUAL VALVE PLUGS
	EPXVPL1P42F0541	4.50E-005	1P42-F0541 MANUAL VALVE PLUGS
	EPXVPL1P42F0563A	4.50E-005	1P42-F0563A MANUAL VALVE PLUGS
	EPXVPL1P42F0563B	4.50E-005	1F42-F0563B MANUAL VALVE PLUGS
	EPXVPL1P42P' 563C	4.50E-005	1P42-F0563C MANUAL VALVE PLUGS
	EPXVPL1P42F0567A	4.50E-005	1P42-F0567A MANUAL VALVE PLUGS
	EPXVPL1P42F0567B	4.50E-005	1P42-F0567B MANUAL VALVE PLUGS
	EPXVPL1P42F0567C	4.50E-005	1P42-F0567C MANUAL VALVE PLUGS
	EPXVPL1F42F0568	4.50E-005	1P42-F0568 MANUAL VALVE PLUGS
	EPXVPL1P42F0572	4,50E-005	1P42-F0572 MANUAL VALVE PLUGS
	EPXVPL1P45F0514	4.50E-005	1P45-F0514 MANUAL VALVE PLUGS
	EPXVPL1P45F0518	4.50E-005	1P45-F0518 MANUAL VALVE PLUGS
	ERCVN01P45F0575	1.00E-004	1P45-F0575 CHECK VALVE NC - FAILS TO OPEN
	ERHICPPS4:2-ESV	1.00E-002	OPERATORS FAIL TO ALIGN 11 VLVS FOR RPV INJECTION
	ERXVN01P45F0572	1.00E-004	1P45-F0572 MANUAL VALVE NC - FAILS TO C' N
1	ERXVN01P45F0573	1.00E-004	1P45-F0573 MANUAL VALVE NC - FAILS TO OPEN
	ESCLLF1P45C0001A	1.25E-004	1P45-COOOIA CONTROL LOGIC FAILS
	ESCLLF1P45C0001B	1.25E-004	1P45-COOO1B CONTROL LOGIC FAILS
	ESCLLF1P45C0002	1.25E-004	1P45-COOO2 CONTROL LOGIC FAILS
	ESCVN01P45P0501A	1.00E-004	1P45-F0501A CHECK VALVE NC - FAILS TO OPEN
	ESCVN01P45F0501B	1.00E-004	1P45-F0501B CHECK VALVE NC - FAILS TO OPEN
	ESCVN01P45F0552	1.00E-004	1P45-F0552 CHECK VALVE NC - FAILS TO OPEN
	ESESUMA	1.89E-002	ESV TRAIN A UNAVAILABLE DUE TO MAINTENANCE
	ESESUMB	1.89E-002	ESV TRAIN B UNAVAILABLE DUE TO MAINTENANCE
	FSESUMC	9.37E-003	ESV TRAIN C UNAVAILABLE DUE TO MAINTENANCE
	ESFLPL1P45D0002A	9.60E-004	1P45-D0002A STRAINER PLUGS
	ESFLPL1P45D0002B	9.60E-004	1P45-D0002B STRAINER PLUGS
	ESFLPL1P45D0003	9.60E-004	1P45-D0003 STRAINER PLUGS
	ESHIMASP45-4:1A	0.00E+000	ESV TRAIN A NOT RESTORED FOLLOWING MAINTENANCE
	ESHIMASP45-4:18	0.00E+000	ESW TRAIN B NOT RESTORED FOLLOWING MAINTENANCE
	ESHIMASP45-4:1C	0,00E+000	ESW TRAIN C NOT RESTORED FOLLOWING MAINTENANCE
	ESMPCC	3.42E-004	ESV PUMP COMMON MODE FAILURE
	ESMPFR1P45C0001A	7.20E-004	1P45-COOOIA MOTOP PHMP FAILS TO RUN
	ESMPFR1P45C0001B	7.20E-004	1P45-CO001B MOTON PUMP FAILS TO RUN
	ESMPFR1P45C0002	7.20E-004	1P45-COOO2 MOTOR PUMP FAILS TO RUN
	ESMPFS1P45C0001A	2.93E-003	1945-COOOLA MOTOR PUMP FAILS TO START
	ESMPFS1P45C0001B	2.93E-003	1P45-COOO1B MOTOR PUMP FAILS TO START
	ESMPFS1P45C0002	2.93E-003	1P45-COOO2 MOTOR PUMP FAILS TO START
10	ESMVCC	9.25E-005	ESV MOTOR VALVE COMMON CAUSE FAILURE
	ESMVFC1P45F0014A		THE REPORT OF THE PARTY AND ADDRESS AND ADDRESS ADDRES
	ESMVFC1P45F0014B		THE REPORT OF A DESCRIPTION OF A DESCRIP
	ESMVFC1P45F0068A	2.40E-006	1P45-F0068A MOTOR VALVE NO - FAILS CLOSED

 $p_{\rm c} = 1$

රා

ŭ

•0

Event	Point Est	Description
ESMVFC1P45F0068B	2.408-006	1P45-F0068B MOTOR VALVE NO - FAILS CLOSED
ESMVN01P45F0130A	2.93E-003	1P45-F0130A MOTOR VALVE NC - FAILS TO OPEN
ESMVN01P45F0130B	2.93E-003	1P45-F0130B MOTOR VALVE NC - FAILS TO OPER
ESMVN01P45F0140	2.938-003	1P45-F0140 MOTOR VALVE NC - FAILS TO OPEN
ESMVPL1P45F0014A	4.50E-005	1P45-FOO14A MOTOR VALVE PLUGS
ESMVPL1P45F0014B	4.50E-005	1P45-FOO14B MOTOR VALVE PLUGS
ESMVPL1P45F0068A	4.50E-005	1P45-F0068A MOTOR VALVE PLUGS
ESMVPL1P45F0068B	4.50E-005	1P45-F0068B MOTOR VALVE PLUGS
ESMVPL1P45F0130A	4.5CE-005	1P45-F0130A MOTOR VALVE PLUGS
ESMVPL1P45F0130B	4.50E-005	1P45-FG130B MOTOR VALVE PLUGS
ESMVPL1P45F0140	4.50E-005	1P45-F0140 MOTOR VALVE PLUGS
ESSCPL1P49D0001A	9.60E-004	1P49-D0001A TRAVELING SCREEN PLUGS
ESSCPL1P49D0001B	9.60E-004	1P49-DOOO1B TRAVELING SCREEN PLUGS
ESXVPL1P45F0519	4.50E-005	1P45-F0519 MANUAL VALVE PLUGS
ESXVPL1P45F0523	4.50E-005	1P45-F0523 MANUAL VALVE PLUGS
ESXVPL1P45F0530A	4.50E-005	1P45-F0530A MANUAL VALVE PLUGS 1P45-F0530B MANUAL VALVE PLUGS
ESXVPL1P45F0530B	4.50E-005 4.50E-005	1P45-F0534A MANUAL VALVE PLUGS
ESXVPL1P45F0534A ESXVPL1P45F0534B	4.50E-005	1P45-P0534B MANUAL VALVE PLUGS
ESXVPL1P45F0536A	4.50E-005	1P45-F0536A MANUAL VALVE FLUGS
ESXV. L1P45F0536B	4.50E-005	1P45-F0536B MANUAL VALVE PLUGS
ESXVPL1P45F0541A	4.50E-005	1P45-F0541A MANUAL VALVE PLUGS
ESXVPL1P45F0541B	4.50E-005	1P45-F0541B MANUAL VALVE PLUGS
ESXVPL1P45F0550A	4.50E-005	1P45-F0550A MANUAL VALVE FLUGS
ESXVPL1P45F0550B	4.50E-005	1P45-P055CB MANUAL VALVE PLUGS
FPDPFR0P54C0001	1.75E-001	OP54-CO001 DIESEL PUNP FAILS TO RUN
FFDPFSCF54C0001	3.00E-002	OP54-COOO1 DIESEL PUMP FAILS TO START
FPDPUM	2.14E-002	DIESEL DRIVEN FIRE FUMP UNAVAILABLE DUE TO MAITNEMANCE
FPHICPPS4:2-DD-0	3.00E-002	OPERATORS FAIL TO MAINTAIN FUEL CIL FOR DIESEL FIRE PMP
FPHICPPS4:2FF-LE	5.00E-002	OPERATOR FAILS TO ALIGN VLVS FOR LATE FP ALT INJ < 3 HRS
FPHICPPS4:2FP-LL	5.00E-003	OPERATOP FAILS TO ALIGN VLVS FOR LATE FP ALT INJ > 3 HRS
FPHICPPS4 · 2RCIC1	3.00E-001	FAIL TO ALIGN FP AFTER RCIC FAILS DUE SUPP POOL TEMP
FPHICPPS4:2RCIC2	1.00E-001	FAIL TO ALIGN FP AFTER RHR FAILS DUE TO MCC TEMP
FPHICPPS4:2RCIC3	1.00E-002	FAIL TO ALIGN FP AFTER HPCS FAILS DUE TO MCC TEMP
FPHICPPS4:2RCIC4	1.00E-001	FAIL TO ALIGN FAST FIRE PROTECTION ALTERNATE INJECTION
FPOFFSITEPUMPER	6,00E-001	OFFSITE PUMPER FAILS TO ARRIVE & PROVIDE WATER
FPXVNC1E12F0027B	1.00E-004	1E12-F0027B MANUAL VALVE NO FAILS TO CLOSE
FPXVNC1P45F0014B	1.00E-004	1P45-F0014B MANUAL VALVE NO FAILS TO CLOSE
FPXVNC1P45F0530B	1.00E-004	1P45 F0530B MANUAL VALVE FROZEN OPEN
FPXVNC1P45F0536B	1.00E-004	1P43-F0536B MANUAL VALVE NO FAILS TO CLOSE
FPXVNC1P45F0578	1.00E-004	1P45-F0578 MANUAL VALVE NO FAILS TO CLOSE
FPXVN01E12F0024B	1.00E-004	1E12-F0024B HANUAL VALVE NC FAILS TO OPEN
FPXVN01E12F0053B	1.00E-004	1E12-F0053B MANUAL VALVE NC FAILS TO OPEN 1P45-F0572 MANUAL VALVE PLUGGED
FPXVPL1P45F0572	8.21E-004	1P45-F0573 MANUAL VALVE PLUGGED
FPXVPL1P45F0573	8.21E-004 8.21E-004	1P45F0589 MANUAL VALVE PLUGGED
FPXVPL1P45F0589 FPXVPL1P45F0593	8.21E-004 8.21E-004	1P45-F0593 MANUAL VALVE PLUGGED
FPXVPL1P45F0631	8.21E-004	1r45-F0631 MANUAL VALVE PLUGGED
FPXVPL1P45F0632	8.216-004	1P45-F0632 MANUAL VALVE PLUGGED
FWAVFC1N21F0230	2.40E-006	1N21-FC230 AIR VALVE NO - FAILS CLOSED
TRULL OTHETLOS 20	21400-000	ALLER THE WALL THE TO ALLER THE PROPERTY

	Event	Point Est	Description
	Adding adjustment of the state of the second	and the second second	1N21-F0220 AIR VAL'E NC - FAILS OPEN
	FVAVNO1N21F0220		1N27-COOO4 ACTUATION LOGIC FAILS OPEN
	FWCLDE1N27C0004	1.605-003	1N21-COOOL CONTROL LOGIC FAILS TO FUNCTION
	FVCLLF1N21C0001C	1.25E-004	1N27-COOOLD CONTROL LOGIC FAILS TO FUNCTION
	FVCLLF1N27C0001D	1.25E-004	1N27-COOO4 CONTROL LOGIC FAILS TO FUNCTION
	FWCLLF1N27C0004	1.25E-004	1N27-F0559A CHECK VALVE NC - FAILS TO OPEN
	FVCVN01N27F0559A	1.00E-004	1N27-F05598 CHECK VALVE NC - FAILS TO OPEN
	FWCVN01N27F0559B	1.00E-004	OPER FAILS TO CNTRL RPV LEVEL AT TAF W/ FW DURING IORV
	FVHICPEC5-2:3LCS	1.00E-002	OPER FAILS TO CONTROL RPV LEVEL AT TAF
	FWHICPEC5-3:2	1.00E-002	OPER FAILS TO CONTROL REV LEVEL AT TAP OPERATOR FAILS TO REOPEN MFP CONTROL VALVES FOR T3C-C
	FWHICPEL-2-FDV-L	1.00E-002	OPER FAILS TO REOPEN MEP CONTROL VALVES OR DEPRESSURIZE REV
	FVHICPEL-2-FDV-V	5,00E-003	OPER FAILS TO CNTRL EX FEED BOOSTER FMP DURING LOSS OF IA
	FWHICPSN27-4:1IA	1.20E-001	OPER FAILS TO CNIRL RX FEED BOOSTER PMP DORING LOSS OF TA
	FWHICPSN27-4:11L	5.00E-003	
	PWMPFR1N21C0001A	7.20E-004	1N21-COOO1A MOTOR PUMP FAILS TO RUN
	FVMPFR1N21C0001B	7.20E-004	1N21-COOO1B MOTOR PUMP FAILS TO RUN
	FVMPFR1N21C0001C	7.20E-004	1N21-COOO1C MOTOR PUMP FAILS TO RUN 1N27-COOO1A MOTOR PUMP FAILS TO RUN
	FWMPFR1N27C0001A	7.20E-004	
	FVMPFR1N27C0001B	7.20E-004	1N27-COOO1B MOTOR PUMP FAILS TO RUN
	FVMPFR1N27C0001C	7.20E-004	1N27-COOO1C MOTOR PUMP FAILS TO RUN 1N27-COOO1D WOTOR PUMP FAILS TO RUN
	FWMPFR1N27C0001D	7.20E-004	
	FWMPFR1N27C0004	7.20E-004	1N27-COOO4 MOTOR PUMP FAILS TO RUN
Ø	FWMPFS1N21C0001C	2.93L-003	1N21-COOOLC MOTOR PUMP FAILS TO START
	FVMPFS1N27C0001D	2.93E-003	1N27-COOOID MOTOR PUMP FAILS TO START
	FWMPFS1N27C0004	2.93E-003	1N27-COOO4 MOTOR PUMP FAILS TO START
	FVMPUM1N21COOD1C	5.00E-001	1N21-COOOLC MOTOR PUMP UNAVAIL DUE TO MAINT
	FVMPUM1N27C0001D	5.00E-001	1N27-COOOID MOTOR PUMP UNAVAIL DUE TO MAINTENANCE
	FVMPUM1N27C0004	5.00E-003	1N27-COOO4 MOTOR PUMP UNAVAIL DUE TO MAINTENANCE
	FVMVN01N27F0200	2.93E-003	1N.7-FO200 MOTOR VALVE FAILS TO OPEN - NC
	FWTPFR1N27C0002A	1.13E-001	1N27-COOO2A TURBINE PUMP FAILS TO RUN
	FWTPFR1N27C0002B	1.13E-001	1N27-COOO2B TURBINE PUMP FAILS TO RUN
	FWXVFL1N27F0560A	4.50E-005	1N27-FOSEOA MANUAL VALVE PLUGS
	FWXVPL1N27F0560B	4.50E-005	1N27-F0560B MANUAL VALVE PLUGS
	HIHICPEC5-3:2-F	1.00E-003	FAILS TO RESTR RHR A/B/LPCS AND CONTRL AT TAF W/ FDW FAILS TO RESTR RHR A/B/LPCS AND CNTRL AT TAF W/O FDW
	HIHICPEC5-3:2-S	1.00E-003	OPER FAILS TO CNTRL RPV LEVEL AND FLUSHES BORON
	HIHICPEC5-5-CRIT	2.00E-003	OPERATOR FAILS TO CLOSE FFCC OUTBOARD VALVE 1G41-F0145
	HIHICPOR10-4:0-I	5.00E-002	OPER FAILS TO X-TIE UNIT 1 AND 2 BATT AND LOAD SHED
	FIHICPOR10-4:3-B	1.00E-002	OPER FAILS TO OPEN DIV 3 SWITCHGEAR ROOM DOORS
	HIHICPOR10-4:3-D	2.00E-003	OPERATOR FAILS TO CROSSTIE DIV 3 BUS TO DIV 2 BUS
	HIHICPORIO-XTIE	5.00E-003	CST LOW LEVEL ACTUATION LOGIC HARDWARE FAILURE
	HPCLDECST	1.60E-003	HPCS ACTUATION LOGIC FAILURE
	HPCLDEL2	1.60E-003	MIN, FLOW MOV ACTUATION LOGIC FAILURE
	HPCLDEMINFLOW	1,60E-003	MIN, FLOW MOV ACTURITOR LOGIC FAILS TO ENERGIPE
	HPCLLF1E22C0001	1.25E-004	1E22-COOO1 CONTROL LOGIC FAILS TO ENERGIZE 1E22-F0002 CHECK VALVE NC - FAILS TO OPEN
	HPCVF01E22F0002	3.44E-003	1E22-FOOD2 CHECK VALVE NC - FAILS TO OPEN 1E22-FOOD2 CST SUCTION LINE CHK VL NC - FAILS TO OPEN
	HPCVN01E22F0002	1.00E-004	1522-FUUUZ USI SUCTION LINE ORK VE NC - FRIDS TO UPEN
	HPCVN01E22F0005	1.00E-004	1E22-FOOD5 CHECK VALVE NC - FAILS TO OPEN
1	HPCVN01E22FC016	1.00E-004	1E22-FOO16 CHECK VALVE NC - FAILS TO OPEN
P	HPCVN01E22F0024	1.00E-004	1E22-F0024 PUMP DISC CHECK VALVE NC - FAILS TO OPEN
	HPHICPEL-1	1.25E-003	OPERATOR FAILS TO INITIATE HIGH PRESSURE INJECTION
	HPHICPSE22-5:0	5.COE-002	OPERATOR FAILS TO CONTROL MIN FLOW VALVE 1E22-F0012

Event	Point Est	Description
HPHICPSE22-5:2	5.00E-002	OPER FAILS TO XFER TO SUPR POOL WITH 1E22-F015
HPHIMASE22-4:1	0.00E+000	FAILURE TO RESTORE HPCS AFTER MAINTENANCE
HPHPUM	2.68E-003	HPCS UNAVAILABLE DUE TO MAINTENANCE
HPLXDL1E22N0654C	0.58E-004	1E22-N0654C LEVEL INSTRUMENT FAILS TO FUNCTION
HPLXDE1E22N0654G	9.58E-004	1E22-NO654G LEVEL INSTRUMENT FAILS TO FUNCTION
HPMPFF1522C0001	7.20E-004	1E22-COOO1 EFCS MOTOR DRIVEN FUMP FAILS TO RUN
HPMPFS1E22C0001	2.93E-003	1E22-CODO1 HPCS MOTOR DRIVEN PUMP FAILS TO START
HPMVNC1E22F0001	2.93E-003	1E22-F0001 MOTOR VALVE NO - FAILS TO CLOSE
HPMVN01522F0004	2.93E-003	1E22-F0004 MOTOR VALVE NC - FAILS TO OPEN
HPMVN01E22F0012	2.93E-005	1E22-F0012 MOTOR VALVE NC - FAILS TO OPEN
EPMVN01E22F0015	2.93E-003	1E22-F0015 MOTOR VALVE NC - FAILS TO OPEN
HFXVPL1k22F0036	4.50E-005	1E22-F0036 MANUAL VALVE PLUGS
HPXVPL1E22F0518	4.50E-005	1E22-F0516 CST SUCTION MANUAL VLV PLUGS
HVFAFR1M41C0001A	3.00E-004	1M41-COOO1A FAN FAI'S TO RUN
HVFAFR1M41C0001B	3.00E-004	1M41-COOO1B FAN FAILS TO RUN
HVFAFR1M41C0002A	3.00E-004	1M41-CO002A FAN FAILS TO RUN
HVFAFR1M41C0002B	3.00E-004	1M41-COOO2B FAN FAILS TO RUN
IAACLF	0.00E+000	SA/IA AIR RECEIVER TANKS DO NOT HAVE SUFFICIENT AIR
IAAVFC1P52F0050	2.40E-005	1P52-F0050 PNEUMATIC VALVE NO - FAILS CLOSED
IAAVFC1P52F0210	2.40E-006	1P52-F0210 AIR VALVE NO - FAILS CLOSED
IAAVFC2P52F0050	2.40E-006	2P52-F0050 AIR VALVE NO - FAILS CLOSED
IAAVFC2P52F0210	2.40E-006	2P52-F0210 AIR VALVE NO - FAILS CLOSED
IAAVNC1P52F0050	2.00E-003	1P52-F0050 PNEUMATIC VALVE NO - FAILS TO CLOSE
IAAVNC2P52F0050	2.00E-003	2P52-F0050 PNEUMATIC VALVE NO - FAILS TO CLOSE
IACLLF1P52C0001	1,25E-004	1P52-CO001 CONTROL LOGIC HARDWARE FAILURE
IACLLF2P52C0001	1.25E-004	2P52-CODO1 CONTROL LOGIC HARDWARE FAILURE
IACMCC	8.25E-003	IA/SA COMPRESSORS COMMON CAUSE FAILURES
IACMFR1P52C0001	3.83E-003	1P52-COOC1 COMPRESSOR FAILS TO RUN
IACMFR2P52C0001	3.83E-003	2P52-CO001 COMPRESSOR FAILS TO RUN
IACMFS1P52C0001	8.25E-002	1P52-COOO1 COMPRESSOR FAILS TO START
1ACMFS2P52C0001	8.25E-002	2P52-C0001 COMPRESSOR FAILS TO START
IACMUM2P51C0001	5.00E-001	2P51-COOO1 UNAVAILABLE DUE TO MAINTENANCE
IACMUM2F52C0001	5.00E-001	2P52-COCO1 UNAVAILABLE DUE TO MAINTENANCE
1ACVN01P52F0532	1.00E-004	1P52-F0532 CHECK VALVE NC - FAILS TO OPEN
IACVN01P52F0550	1.00E-004	1P52-F0550 CHECK VALVE NC - FAILS TO OPEN
IACVN01P52F0639	1.00E-004	1P52-F0639 CHECK VALVE NC - FAILS TO OPEN
1ACVN01P52F1004	1.00E-004	1P52-F1004 CHECK VALVE NC - FAILS TO OPEN
IACVN02P52F0532	1.00E-004	2P52-F0532 CHECK VALVE NC - FAILS TO OPEN
IACVN02P52F1004	1.00E-004	2P52-P1004 CHECK VALVE NC - FAILS TO OPEN
IAHICPSP51-4:2	5.00E-002	OPERATOR FAILS TO REPOSITION NCC LUBE OIL CLR OUTLET VLV
IAHICRSP52.7:2	1.00E-001	OPERATOR FAILS TO OVERRIDE ISOLATION SIGNAL
IAHIMASP51-4:1:2	1.00E-003	FAILURE TO RESTORE FOLLOWING MAINTENANCE
IAMVFC1P52F0200	2.40E-006	1P52-F0200 MOTOR VALVE NO - FAILS CLOSED
IAMVFC1P52F0646	2.40E-006	1P52-F0646 MOTOR VALVE NO - FAILS CLOSED
IAPLLR1P52	2.71E-003	IA & SA FAIL DUE TO LINE BREAK
IAPXDE1P52N0060	9.59E-005	1P52-N0060 PRESSURE SENSOR FAILS TO FUNCTION
IAPXDE1P52N0185	9.59E-005	1P52-M0185 PRESSURE SENSOR FAILS TO FUNCTION
IAPXDE2P52N0060	9.59E-005	2P52-N0060 PRESSURE SENSOR FAILS TO FUNCTION
IAPXDE2P52N0185	9.59E-005	2P52-N0185 PRESSURE SENSOR FAILS TO FUNCTION
	1,00E+000	INTERNAL FLOODING



õ

Event	Point Est	Description
LCCLDE	1.60E-003	LPCI B AUTOMATIC ACTUATION LOGIC MARDWARE FAILURE
LCCLDEMINFLOW	1.60E-003	MINIMUM FLOW MOV ACTUATION LOGIC FAILURE
LCCLDEMINFLOVA	1.60E-003	MINIMUM FLOW MOV ACTUATION LOGIC FAILURE
LCCLDEMINFLOVE	1.60E-003	KINIMUM FLOW MOV ACTUATION LOGIC FAILURE
LCCLDEMINFLOVC	1.00E-003	MINIMUM FLOW MOV ACTUATION LOGIC FAILURE
LCCLLF1E12C0002A	1.25E-004	1E12-COOO2A CONTROL LOGIC FAILS TO FUNCTION
LCCLLF1E12C0002B	1.25E-004	1F12-COOC2B CONTROL LOGIC FAILS TO FUNCTION
LCCLLF1E12C0002C	1.25E-004	1E12_CO002C CONTROL LOGIC FAILS TO FUNCTION
LCCVN01E12F0031A	1.00E-004	1E12-FOO31A CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F00319	1.00E-004	1E12-F0031B CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0031C	1.00E-004	1£12-FOO31C CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0041A	1.00E-004	1E12-FOO41A CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0041B	1.00E-004	1E12-F0041B CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0041C	1.00E-004	1E12-F0041C CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0046A	1.00E-004	1E12-F0046A CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0046B	1.00E-004	1E12-FOO46B CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0046C	1.00E-004	1E12-FOO46C CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0050A	1.00E-004	1E12-FOO5OA CHECK VALVE NC - FAILS TO OPEN
LCCVN01E12F0050B	1.00E-004	1E12-FOOSOB CHECK VALVE NC - FAILS TO OPEN
LCHICPEL-1-LPC1	1.00E-003	OPERATOR FAILS TO INITIATE LPCI B
LCHICPSE12-5:1	5.00E-002	OPERATOR FAILS TO CONTROL MIN FLOW VALVE 1E12-F0064A
LCHIMASE12-4:1A	0.00E+000	FAILURE TO RESTORE TRAIN A LPCI FOLLOWING MAINT
LCHIMASE12-4:18	0.00E+000	FAILURE TO RESTORE TRAIN & LPCI FOLLOWING MAINT
LCHIMASE12-4:1C	0.00E+000	FAILURE TO RESTORE TRAIN C LPCI FOLLOWING MAINT
LCHXPL1212B0001A	2.05E-003	1E12-BOOOIA HEAT EXCHANGER PLUGS
LCHXPL1E12B0001B	2.05E-003	1E12-BOOU1B HEAT EXCHANGER PLUGS
LCHXPLIE12B00020	2.05E-003	1E12-ROOO1C HEAT EXCHANGER PLUGS
LCHEPLIE 12B0001D	2.05E-003	1E12-BOOO1D HEAT EXCHANGER PLUGS
1 CT CTIMA	1.93E-002	LPCI TRAIN A UNAVAILABLE DUE TO MAINTENANCE
1.C1.C11MB	1.81E-002	LPCI TRAIN B UNAVAILABLE DUE TO MAINTENANCE
LCLCUMC	1.03E-002	LPCI TRAIN C UNAVAILABLE DUE TO MAINTENANCE
LCLCUMLPCIALPCS	5.29E-003	LPCI A AND LPCS BOTH UNAVAILABLE DUE TO MAINT
LCLCUMLPCIBLPCIC	1.77E-002	LPCI B AND LPCI C BOTH UNAVAILABLE DUE TO MAINT
LCLCUMRHRALPRC		LPCI A, LPCS & RCIC ALL UNAVAILABLE DUE TO MAINTENANCE
LCMPCC	2.93E-004	LPCI PUMP COMMON MODE FAILURE
LCMPFRIE12C0002A	7.20E-004	1E12-CO002A MOTOR PUMP FAILS TO RUN
LCMPFR1E12C0002B	7.20E-004	1E12-COOO2B MOTOR PUMP FAILS TO RUN
LCMPFR1E12C0002C	7.20E-004	1E12-CO002C MOTOR PUMP FAILS TO RUN
LCMPFS1E12C0002A	2.93E-003	1E12-COOO2A MOTOR FUMP FAILS TO START
LCMPFS1E12C0002B	2.93E-003	1E12-COOO2B MOTOR PUMP FAILS TO STA3T
LCMPFS1E12C0002C	2.93E-003	1E12-COOO2C MOTOR PUMF FAILS TO START
LCMVCC	9.25E-005	INJECTION VALVE COMMON MODE FAILURE
LCMVFC1E12F0003A	2.405-006	1E12-F0003A MOTOR VALVE NO - FAILS CLOSED
LCMVFC1E12F0003B	2.40E-006	
LCHVFC1E12F0004A	2.40E-006	
LCMVFC1E12F0004B	2.40E-006	
LCMVFC1E12F0027A	2.40E-006	
LCMVFC1E12F0027B		1E12-F0027B MOTOR VALVE NO - FAILS CLOSED
LCMVFC1E12F0047A		1E12-F0047A MOTOR VALVE NO - FAILS CLOSED
LCMVFC1E12F0047B		1E12-FOO47B MOTOR VALVE NO - FAILS CLOSED

Event	Point Est	Description
LCMVFC1E12F0048A	2.40E-00€	1E12-F0048A MOTOR VALVE NO - FAILS CLOSED
LCHVFC1E12F0043B	2.40E-006	1E12-FOO48B HOTOR VALVE NO - FAILS CLOSED
LCMVFC1E12F0105	2.40E 006	1E12-F0105 MOTOR VALVE NO - FAILS CLOSED
LCMVP01E12F0021	1.20E-005	1E12-F0021 MOTOR VALVE NC - FAILS OPEN
LCMVF01E12F0024A	1. 005	1E12-FOOZ4A MUTOR VALVE NC - FAILS OFEN
LCMVF01E12F0024F	1.20E-005	1E12-F0024B MOTOR VALVE NC - FAILS OPEN
LCHVF01E12F0028A	1.208-005	1E12-FO028A MOTOR VALVE NC - FAILS OPEN
LCMVF01E12F0028B	1.20E-005	1E12-FOO28B MOTOR VALVE NC - FAILS OPEN
LCMVF01E12F0537A	1.20E-005	1E12-F0537A MOTOR VALVE NC - FAILS OPEN
LCMVF01E12F0537B	1.20E-005	1E12-F0537B MOTOR VALVE NC - FAILS OPEN
LCMVNC1E12F0021	2.93E-003	1E12-F0021 MUTOR VALVE FAILS TO CLOSE
LCMVN01E12F0042A	2.93E-003	1E12-F0042A MOTOR VALVE NC - FAILS TO OPEN
LCMVN01E12F0042B	2.93E-003	1E12-FOO42B MOTOR VALVE NC - FAILS TO OPEN
LCMVN01E12F0042C	2.93E-003	1E12-F0041C MOTOR VALVE NC - FAILS TO OPEN
LCMVN01E12F0064A	2.93E-003	1E12-FOO64A MOTOR VALVE NC - FAILS TO OPEN
LCMVN01E12F0064B	2.93E-003	1E12-F0064B MOTOR VALVE NC - FAILS TO OPEN
LCMVN01E12F0064C	2.93E-003	1E12-F0064C MOTOR VALVE NC - FAILS TO OPEN
LCMVN01E12F0105	2.93E-003	1E12-F0105 MUTOR VALVE FAILS TO OPEN
LCMVPL1E12F0003A	4.50E-005	1E12-FOOO3A MOTOR VALVE PLUGS
LCMVCL1E12F0003B	4.50E-005	1E12-F0003B MOTOR VALVE PLUGS
LCMVFL1E12F0004A	4.50E-005	1E12-FOOO4A MOTOK VALVE FLUGS
LCMVPL1E12F0004B	4.50E-005	1E12-FOO04B MOTOR VALVE PLUGS
LCMVPL1E12F0027A	4.50E-005	1E12-F0027A MOTOR VALVE PLUGS
LCMVPL1E12F0027B	4.50E-005	1E12-F0027B MOTOR VALVE PLUGS
LCMVPL1E12F0047A	4.50E-005	1E12-FO047A MOTOR VALVE PLUGS
LCMVPL1E12F0047B	4.50E-005	1E12-FOO47B MOTOR VALVE PLUGS
LCMVPL1E12F0048A	4.50E-005	1E12-FOO48A MOTOR VALVE PLUGS
LCMVPL1E12F0048B	4.50E-005	1E12-FC048B MOTOR VALVE PLUGS
LCMVPL1E12F0105	4.50E-005	1E12-F0105 HOTOR VALVE PLUGS
LCPXCCLPCI	9.598-006	LPCI PMP PERMISSIVE COMMON MODE FAILURE
LCPXDE1E12N0655A	9.59E-005	1E12-N0655A PRESSURE INSTRUMENT FAILS TO FUNCTION
LCPXDE1E12N0655B	9.59E-005	1212-N0655B PRESSURE INSTRUMENT FAILS TO FUNCTION
LCPXDE1E12N0655C	9.59E-005	1E12-N0655C PRESSURE INSTRUMENT FAILS TO FUNCTION
LCPXDE1E12N0656A	9.59E-005	1E12-NO656A PRESSURE INSTRUMENT FAILS TO FUNCTION
LCFXDE1E12N0656B	9.59E-005	1E12-NO656B PRESSURE INSTRUMENT FAILS TO FUNCTION
LCPXDE1E12N0656C	9.59E-005	1E12-N0656C PRESSURE INSTRUMENT FAILS TO FUNCTION
LCFVPL1E12F0018A	4.50E-005	1E12-FOO18A MANUAL VALVE PLUGS
LCXVPL1E12F0018B	4.50E-005	1E12-FOO18B MANUAL VALVE PLUGS
LCXVCL1E12F0018C	4.50E-005	1E12-F0018C MANUAL VALVE PLUGS
LCXVPL1E12F0029A	4.50E-005	1E12-F0029A MANUAL VALVE PLUGS
LCXVPL1E12F0029B	4.50E-005	1E12-FOO29B MANUAL VALVE PLUGS
LCXVPL1E12F0029C	4.50E-005	1E12-FOO29C MANUAL VALVE PLUGS
LCXVPL1E12F0039A	4.50E-005	1E12-F0039A MANUAL VALVE PLUGS
LCXVPL1E12F0039B	4.50E-005	1E12-F0039B MANUAL VALVE PLUGS
LCXVPL1E12F0939C	4.50E-005	1E12-F0039C MANUAL VALVE PLUGS
LI19B	7.65E-001	COMPLEMENT TO LI19
LI26B	7.20E-001	COMPLEMENT TO LI26
LPCLDE	1.60E-003	LPCS AUTOMATIC ACTUATION LOGIC HARDWARE FAILURE
LPCLDEMINFLOW	1.60E-003	MIN. FLOW MOV ACTUATION LOGIC FAILURE
LPCLLF1L21C0001	1.25E-004	1E21-COOCI CONTROL LOGIC FAILS TO ENERGIZE

	Event	Foint Est	Description
	LPCVN01E21F0003	1.008-004	1E21-FOO03 CHECK VALVE NC - FAILS TO OPEN
	LPCVN01E21F0006		1E21-F0006 CHECK VALVE NC - FAILS TO OPEN
	LPCVN01E21F0501	1.008-004	1E21-F0501 CHECK VALVE NC - FAILS TO OPEN
	LPHICPEL-1	1.00E-003	OPERATOR FAILS TO INITIATE LOW PRESSURE INJECTION
	LPHICPEL-1-LPCS	1.00E-003	OPERATOR FAILS TO INI/IATE LPCS
	LPHICPSE21-5:1	5.00E-002	OPERATOR FAILS TO CONTROL MIN FLOW VALVE 1E21-F0011
	LPHIMASE21-4:1	0.00E+000	FAILURE TO RESTORE LPCS AFTER MAINTENANCE
	LPLPUM	2.03E-002	LPCS UNAVAILABLE DUE TO MAINTENANCE
		7.20E-004	1E21-COOO1 LPCS MOTOR PUMP FAILS TO RUN
		2.93E-003	1E21-COOO1 LPCS MOTOR PUMP FAILS TO START
		2.93E-003	1E21-FOO11 MOTOR VALVE FAILS TO CLOSE
	LPMVN01E21F0005		1E21-FOOD5 MOTOR VALVE NC - FAILS TO OPEN
		2.93E-003	1E21-FOO11 MOTOR VALVE FAILS TO OPEN
		4.50E-005	1E21-F0001 MOTOR VALVE PLUGS
	LPPXDE1E21N0650		1E21-N0650 RX PRESS PRESSURE INSTRUMENT FAILS TO FUNCTION
	LPPXDE1E21N0652		1E21-N0652 PRESSURE INSTRUMENT FAILS TO FUNCTION
	LPPXDE1E21N0653	9.59E-005	1E21-N0653 PRESSURE INSTRUMENT FAILS TO FUNCTION
	LFXVPL1E21F0007	4.50E-005	1E21-FOO07 MANUAL VALVE PLUGS
	м	1.00E-004	AT LEAST ONE SRV FAILS TO OPEN AGAINST SPRING
	MCHICRRECVRD4	0.006-000	MCC, SWTCEGR, & MISC FLECT AREAS RECVRD IN 4 HOURS
	MCHICRRECVRD9	0.00E-000	MCC, SWICHGR, & MISC ELECT AREAS RECVRD IN 9 HOURS
A	MCMFFR1M23C0001A	3.00E-011	1M23-CO001A HOTOR FAN FAILS TO RUN
P	MCMFFR1M23C0001B	3.00E-011	1M23-COOOlB MOTOR FAN FAILS TO RUN
	MCMFFR1M23C0002A	3.00E-011	1M23-COOD2A MOTOR RETURN FAN FAILS TO RUN
	MCMFFR1M23C0002B	3.00E-011	1M23-COOO2B MOTOR RETURN FAN FAILS TO RUN
		2.93E-003	1M23-COOO1B MOTOR FAN FAILS TO START
	MCMFFS1M23C0002B	2.93E-003	1M23-CO002B MOTOR RETURN FAN FAILS TO START
	MESA133	7.76E-003	NO FLOW TO ESW TRAIN A HEAT EXCHANGERS
	MESB133	7.76E-003	NO FLOW TO ESW TRAIN B HEAT EXCHANGERS
	MESC133	7.76E-003	NO FLOW TO ESW TRAIN C HEAT EXCHANGERS
	MIAA174	1.05E-004	UNIT 2 F1004 AND F0210 VALVES FAIL CLOSED
	MIAA241	8.66E-002	1P52-COOO1 COMPRESSOR FAILS
	MIAA331	8.66E-002	
	MIAA353	1.05E-004	UNIT 1 F1004 AND F0210 VALVES FAIL CLOSED
	MIAA431	8.66E-002	2P51-COGO1 COMPRESSOR FAILS
	MIAA584	3.77E-003	1P43-COOO1C MOTOR PUMP FAILS
	MIAA884	3.77E-003	1P41-COOID MOTOR PUMP FAILS
	MLHICPE32	1.00E-002	
	MLMFFR1E32C0001	5.03E-003	1E32-COOO1 MOTOR FAN FAILS TO RUN
	MLMFFS1E32C0001	2.93E-003	1E32-COOO1 MOTOR FAN FAILS TO START
	MLMLUMA	1.00E-002	INBOARD MSIV LEAKGE CONTROL UNAVAILABLE DUE TO MAINTENANCE
	MLMV1E32F0003ANC	2.93E-004	1E32-F0003A FAILS TO CLOSE AFTER BEING OPENED
	MLMV1E32F0003ENC	2.93E-004	1132-F0003E FAILS TO CLOSE AFTER BEING OPENED
	MLMV1E32F0003JNC	2.93E-004	1E32-F0003J FAILS TO CLOSE AFTER BEING OPENED
	MLMV1E32F0003NUC	2.93E-004	1E32-F0003N FAILS TO CLOSE AFTER BEING OPENED
53	MLMVCC	9.25E-005	1E32 MOTOR VALVE COMMON CAUSE FAILURES
T	MLHUNO1E32F0001A	2.93E-003	1E32-FOOUIA MOTOR VALVE NC - FAILS TO OPEN
-	MLMVN01E32F0001E		1E32-FOOO1E MOTOR VALVE NC - FAILS TO OPEN
	MLMVN01E32F0001J	2.93E-003	1E32-FOO01J MOTOR VALVE NC - FAILS TO OPEN
	MLMVN01E32F0001N	2.93E-003	1E32-FOODIN MOTOR VALVE NC - FAILS TO OPEN

т

Event	Foint Est	Description
MLMVN01E32F0002A	2.93E-003	1E32-FC002A MOTON VALVE NC - FAILS TO OPEN
MLMVN01E32F0002E	2.93E-003	1E32-FOOD2E MOTOR VALVE NC - FAILS TO OPEN
MLMVN01E32F0002J	2.93E-003	1E32-F0002J MOTOR VALVE NC - FAILS TO OPEN
MLMVN01E32F0002N	2.93E-003	1E32-F0002N MOTOR VALVE NC - FAILS TO OPEN
MLMVN01E32F0003A	2.93E-003	1E32-FOOO3A MOTOR VALVE NC - FAILS TO OPEN
MLMUN01E32F0003E	2.93E-003	1E32-F0003E MOTOR VALVE NC - FAILS TO OPEN
MLMVN01E32F0003J	2.93E-003	1E32-F0003J MOTOR VALVE NC - FAILS TO OPEN
MLMVN01E32F0003N	2.93E-003	1E32-FOOD3N MOTOR VALVE NC - FAILS TO OPEN
NBLYCCL1	9.59E-005	RPV LEVEL 1 COMMON MODE MISCALIBRATION
NBLXCCL2	9.59E-005	RPV LEVEL 2 COMMON MODE MISCALIBRATION
NBLXCCL3	9.59E-005	RPV LEVEL 3 COMMON MODE MISCALIBRATION
NBLXDZ1B21N0667C	9.58E-004	1B21-NO667C LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0667G	9.58E-004	1B21-NO6673 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0667L	9.58E-004	1B21-N0667L LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0667R	9.58E-004	1B21-N0667R LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0673C	9.58E-004	1821-NO673C RPV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0673G	9.58E-004	1B21-NO673G RPV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21M0673L	9.58E-004	1821-N06731 RFV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0673R	9.38E-004	1B21-N0673R RPV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0691A	9.58E-004	1821-NO691A RPV L1 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0691B	9.58E-004	1B21-N0691B RPV L1 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0691E	9.58E-004	1B21-N0691E RPV L1 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0691F	9.58E-004	1821-N0691F RPV L1 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0692A	9.582-004	1821-N0692A RFV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0692B	9.58E-004	1821-N06928 RPV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0692E	9.58E-004	1821-N0692E RPV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0692F	9,58E-004	1B21-N0692F RPV L2 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0695A	9.58E-004	1B21-N0695A LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1B21N0695B	9.58E-004	1B21-N0695B LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1C34N0004A	9.58E-004	1C34-NOOO4A RPV L8 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1C34N0004B	9.555-004	1C34-NO004B RPV L8 LEVEL INSTRUMENT FAILS TO FUNCTION
NBLXDE1C34N0004C	9.58E-004	1C34-NOOO4C RPV L8 LEVEL INSTRUMENT FAILS TO FUNCTION
NBPXCCDV	9.59E-006	DRYWELL PRESSURE COMMON MODE MISCALIBRATION
NBPXDE1B21N0667C	9.59E-005	1821-NO667C PRESSURE INSTRUMENT FAILS TO FUNCTION
NBPXDE1B21N0667G NBPXDE1B21N0667L	9.59E-005 9.59E-005	1B21-N0667G PRESSURE INSTRUMENT FAILS TO FUNCTION 1B21-N0667L PRESSURE INSTRUMENT FAILS TO FUNCTION
NBPXDE1B21N0667R	9.59E-005	1821-NO667R PRESSURE INSTRUMENT FAILS TO FUNCTION
NBPXDE1B21N0694A	9.59E-005	1B21-N0694A DW PRES PRESSURE INSTRUMENT FAILS TO FUNCTION
NBFXDE1B21N0694B	9.598-005	1B21-N06948 DW PRES PRESSURE INSTRUMENT FAILS TO FUNCTION
NBPXDE1B21N0694E	9.598-005	1821-NG694E DW FRES FRESSURE INSTRUMENT FAILS TO FUNCTION
NBPXDE1821N0694F	9.59E-005	1B21-N0694F DV PRES PRESSURE INSTRUMENT FAILS TO FUNCTION
NBTICCADS	2.93E-005	ADS TIMER RELAY COMMON MODE FAILURE
NBTILF1B21K5A	2.93E-004	1821-K5A TIME DELAY RELAY FAILS TO FUNCTION
NBTILF1B21K5B	2.93E-004	1821-K58 TIME DELAY RELAY FAILS TO FUNCTION
NCCLLF1P43C0001C	1.25E-004	1P43-CO001C CONTROL LOGIC FAILS
NCMPFR1P43C0001A	7.20E-004	1P43-COOOIA MOTOR PUMP FAILS TO RUN
NCMPFR1P43C0001B	7.20E-004	1043, COOOLS MOTOR PUMP PATTS TO BUN
NCMPFR1P43C0001C	7.20E-004	1P43-COOOLC MOTOR FUMP FAILS TO RUN
NCMPFS1P43C0001C	2.93E-003	1P43-CO001C MOTOR PUMP FAILS TO START
NCMPUM1P43C0001C	5.00E-001	NCC STANDBY PUMP UNAVAILABLE DUE TO MAINTENANCE

Event	Point Est	Description
and the second s		
NSAVAC1821F0022A	2.00E-003	1821-FO022A (MSIV) AIR VALVE NO - FAILS TO CLOSE
NSAVNC1B21F0022B	2.00E-003	
NSAVNC1B21F0022C	2.00E-003	1B21-F0022C (MSIV) AIR VALVE NO - FAILS TO CLOSE
NSAVNC1B21F0022D	2.008-003	1B21-F0022D (MSIV) AIR VALVE NO - FAILS TO CLOSE
NSAVNC1B21F0028A	2.00E-003	1821-F0028A (MSIV) AIR VALVE NO - FAILS TO CLOSE
NSAVNC1B21F0028B	2.00E-003	1821-FOO288 (MSIV) AIR VALVE NO - FAILS TO CLOSE
NSAVNC1B21F0028C	2.00E-003	1821-F00253 (MSIV) AIR VALVE NO - FAILS TO CLOSE
NSAVNC1B21F0028D	2.00E-003	1821-FOO28D (MSIV) AIR VALVE NO - FAILS TO CLOSE
NSHICPEC5-2-L1	1.00E-001	OPERATOR FAILS TO BYPASS MSIV LEVEL 1 ISOLATION FOR T3C-C
NSHICLEC5-2-L1T3	1.00E+000	OPERATOR FAILS TO BYP MSIV LVL 1 ISOL FOR T3A-C OR T3B-C
NSNSCC	2.00E-004	MSIV COMMON CAUSE FAILURES
ONE	1.00E+000	BASIC EVENT SET TO 1.0
P1	1.60E-002	ONE SRV FAILS TO OPEN AND RECLOSE
P2	1.60E-003	TWO SRVS FAIL TO OPEN AND RECLOSE
FX	1.00E+000	PROBABILITY THAT SRV'S WILL OPEN FOR A GIVEN TRANSIENT
R1	5.73E-002	NONRECOVERY OF OFFSITE AC POWER IN 6 HOURS
R10	6.27E-001	OFFSITE AC PWR NOT RESTRD IN 12 HOURS IF NO FWR AT 10 HRS
R11	6.57E-002	NUNRECOVERY OF OFFSITE AC POWER IN 5 HOURS
R12	3.24E-002	NONRECOVERY OF OFFSITE AC POWER IN 9 HOURS
R13	2.66E-001	NONRECOVERY OF OFFSITE AC POWER IN 1 HOUR
R13B	7.34E-001	RECOVERY OF OFFSITE AC POWER IN 1 HOUR
R14	1.74E-001	NONRECOVERY OF OFFSITE AC POWER IN 2 HOURS
R14B	8.26E-001	RECOVERY OF OFFSITE AC POWER IN 2 HOURS
R15	8.23E-002	NONRECOVERY OF OFFSITE AC POWER IN 3 HOURS
R15B	9.18E-001	RECOVERY OF OFFSITE AC POWER IN 3 HOURS
R16	5.73E-001	NONRECOVERY OF OFFSITE AC POWER IN 0.3 HOURS
R16B	4.27E-001	RECOVERY OF OFFSITE AC POWER IN 0.3 HOURS
R17	1.29E-001	OFFSITE AC PWR NOT RESTRD IN 4 HOURS IF NO PWR AT 0.3 HR
R17B	8.71E-001	OFFSITE AC PWR RESTRD IN 4 HOURS IF NO PWR AT 0.3 HR
R18	4.25E-001	OFFSITE AC PWR NOT RESTRD IN 4 HOURS IF NO PWR AT 2 HRS
R18B	5.75E-001	OFFSITE AC PWR RESTRD IN 4 HOURS IF NO PWR AT 2 HRS
R19	9.855-003	NONRECOVERY OF OFFSITE AC POVER IN 14 HOURS
R2	4.07E-002	NONRECOVERY OF OFFSITE AC POWER IN 8 HOURS
R20	5.75E-003	NONRECOVERY OF OFFSITE AC POWER IN 17 HOURS
R23	3.81E-001	OFFSITE AC PWR NOT RESTRD IN 17 HOURS IF NO PWR AT 12 HRS
R23B	6.19E-001	OFFSITE AC PWR RESTRD IN 17 HOURS IF NO PWR AT 12 HRS OFFSITE AC PWR NOT RESTRD IN 5 HOURS IF NO PWR AT 2 HRS
R24	3.78E-001	OFFSITE AC PWR NOT RESIRD IN 2 HOURS IF NO PWR AT 2 HRS
R24B	6.22E-001	OFFSITE AC PWR RESTRD IN 5 HOURS IF NO PWR AT 2 HRS
R25	1.96E-002	NONRECOVERY OF OFFSITE AC POWER IN 11 HOURS OFFSITE AC PWR NOT RESTRD IN 14 LOURS IF NO PWR AT 11 HRS
R26	5.03E-001	OFFSITE AC PWR NOT RESTRO IN 14 HOURS IF NO PWR AT 11 HRS
R26B	4.97E-001	OFFSITE AC PWK RESIRD IN 14 DOURS IT NO FRE AL IL HAS
R27	1.31E-003	NONRECOVERY OF OFFSITE AC POWER IN 24 HOURS NONRECOVERY OF OFFSITE AC POWER IN 15 HOURS
R28	8.21E-003	OFFSITE AC PWR NOT RESTRD IN 24 HOURS IF NO PWR AT 15 HRS
R29	1.60E-001	OFFSITE AC FWR RESTRD IN 24 HOURS IF NO FWR AT 15 HRS
R29B	8.40E-001	NONRECOVERY OF OFFSITE AC POWER IN 12 HOURS
R3	1.51E-002	OFFSITE AC PWR NOT RESTRD IN 24 HOURS IF NO FWR AT 7 HRS
R30	2.67E-002	NONRECOVERY OF OFFSITE AC POWER IN 7 HOURS
R31	4.91E-002	OFFSITE AC PWR NOT RESTRD IN 7 HOURS IF NO PWR AT 3 HRS
R32	5.97E-001	OFFSITE AC PWR RESTRD IN 7 HOURS IF NO PWR AT 3 HRS
- R32B	4.03E-001	OLIDITE NO LAN VEDITO TU LUOUNO IL NO LEU NE O NEO

Event	Foint Est	Description
R33	2.02E-001	NONRECOVERY OF OFFSITE AC POWER IN 1.7 HOURS
R33B	7,98E-001	RECOVERY OF OFFSITE AC POWER IN 1.7 HOURS
R34	6.49E-003	OFFSITE AC PVR NOT RESIRD IN 24 HOURS IF NO PVR AT 1.7 HR
R35	3.53E-001	OFFSITE AC PWR NOT RESTRD IN 1.7 HRS IF NO PWR AT 0.3 HR
R3	6.47E-001	OFFSITE AC PVR RESTRD IN 1.7 HOURS IF NO PVR AT 0.3 HR
R	5.29E-001	NONRECOVERY OF OFFSITE AC POWER IN 0.4 HOURS
R3	4.71E-001	RECUVERY OF OFFSITE AC FOVER IN 0.4 HOURS
R	1.40E-001	OFFSITE AC PVR NOT RESTRD IN 4 HOURS IF NO PVR AT 0.4 HR
R3	8.60E-001	OFFSITE AC PWR RESTED IN 4 HOURS IF NO PWR AT 0.4 HR
R	8.985-001	OFFSITE AC PWR NOT RESTRD IN 4 HOURS IF NO PWR AT 3 HRS
R3	1.028-001	OFFSITE AC PWK RESTRD IN 4 HOURS IF NO PWR AT 3 HRS
R	1.23E-002	NONRECOVERY OF OFFSITE AC POVER IN 13 HOURS
R4	2.04E-001	OFFSITE AC PWR NOT RESTRD IN 12 HOURS IF NO PWR AT 4 HRS
R40	6.16F-001	NONRECOVERY OF OFFSITE AC POWER IN 0.26 HOURS
R40B	3.848-001	RECOVERY OF OFFSITE AC POWER IN 0.26 HOURS
R41	1.20E-CO1	OFFSITE AC PWR NOT RESTRD IN 4 HOURS IF NO PWR AT 0.26HR
R418	8,80E-001	OFFSITE AC PWR RESTRD IN 4 HOURS IF NO PWR AT 0.26HR
R42	4.60E-003	NONRECOVERY OF OFFSITE AC POWER IN 18 HOURS
R43	6.22E-002	OFFSITE AC PWR NOT RESTRD IN 18 HOURS IF NO PWR AT 4 HRS
R44	5.44E-001	OFFSITE AC PWR NOT RESTRD IN 15 HOURS IF NO PWR AT 12 HRS
R44B	4.56E-001	OFFSITE AC PWR RESTRD IN 15 HOURS IF NO PWR AT 12 HRS
R45	5.59E-002	OFFSITE AC PWR NOT RESTRD IN 18 HOURS IF NO PWR AT 3 HRS
R46	2.29E-001	NONRECOVERY OF OFFSITE AC FOWER IN 1.4 HOURS
R46B	7.71E-001	NONRECOVERY OF OFFSITE AC POWER IN 1 4 HOURS
R47	4.33E-001	OFFSITE AC PWR NOT RESTRD IN 1.4 HRS IF NO PWR AT .4 HRS
R47B	5.57E-001	OFFSITE AC FWR NOT RESTRD IN 1.4 HRS IF NO PWR AT .4 HEC
R48	4.32E-001	OFFSITE AC PWR NOT RESTRD IN 1 HOUR IF NO PWR AT .26 HR
R48B	5.68E-001	OFFSITE AC PWR RESTRD IN 1 HOUR IF NO PWR AT .26 HR
R49	2.46E-003	NONRECOVERY OF OFFTITE AC POWER IN 21 HOURS
R4B	7.96E-001	OFFSITE AC PWR RESTRD IN 12 HOURS IF NO PWR AT 4 HRS
R5	7.39E-001	NONRECOVERY OF OFFSITE AC POWER IN 4 HOURS
R50	2.00E-001	OFFSITE AC PWR NOT RESTRD IN 21 HOURS IF NO PWR AT 13 HRS
R508	8.00E-001	OFFSITE AC FWR RESTRD IN 21 HOURS IF NO FWR AT 13 HRS
R51	4.19E-001	OFFSITE AC PWR NOT RESTRD IN 15 HOURS IF NO PWR AT 11 HRS
R51B	5.81E-001	
R52	4.67E-001	OFFSITE AC FWR NOT RESTRD IN 17 HOURS IF NO PWR AT 13 HRS
R52B	5.33E-001	OFFSITE AC PWR RESTRD IN 17 HOURS IF NO PWR AT 13 HR3
R53	6.96E-001	OFFSITE AC PWR NOT RESTRD IN 6 HOURS IF NO PWR AT 3 HRS
R53B	3.04E-001	OFFSITE AC PWR RESTRD IN 6 HOURS IF NO PWR AT 3 HRS
R54	2.29E-002	OFFSITE AC PWR NOT RESTRD IN 24 HOURS IF NO PWR AT 6 HRS
R55	2.38E-001	NONRECOVERY OF OFFSITE AC POWER IN 1.3 HOURS
R55B	7.62E-001	RECOVERY OF OFFSITE AC POWER IN 1.3 HOURS
R56	5.50E-003	OFFSITE AC PWR NOT RESTRD IN 24 HOURS IF NO PWR AT 1.3 HR
R57	4.50E-001	OFFSITE AC PWR NOT PESTRD IN 1.3 HRS IF NO PWR AT 0.4 HR
R57B	5.50E-001	OFFSITE AC PWR RESTRD IN 1.3 HOURS IF NO PWR AT 0.4 HR
R58	1.648-003	NONRECOVERY OF OFFSITE AC POWER IN 23 HOURS
R59	8.37E-002	OFFSITE AC PWR NOT RESTORED IN 23 HRS IF NO PWR AT 11 HRS
R6	2.41E-002	NONDROUTERY OF OFFETTE AC DOUTE IN 10 HOURS
R60	3.29E-001	OFFSITE AC PWR NOT RESTORED IN 6 HOURS IF NO PWR AT 2 HRS
R60B	6.71E-001	OFFSITE AC PWR RESTORED IN 6 HOURS IF NO PWR AT 2 HRS
ROUD	0.711-001	ALLERTE DA LED PROTABED TH A HARDE TI HA LED UT & DUD

Event	Point Est	Description
R61	4.92E-003	OFFSITE AC PWR NOT RESTORED IN 24 HRS IT NO PWR AT 1 HOUR
R62	1.09E-002	OFFSITE AC PWR NOT RESTORED IN 17 HRS IF NO PWR AT 0.4 HR
R7	7.75E-001	OFFSITE AC TWR NOT RESTRD IN 6 HOURS IF NO TWR AT 4 HR
R7B	2.25E-001	OFFSITE AC PWR RESTRD IN 6 HOURS IF NO PWR AT 4 HR
R8	3.26E-001	OFFSITE AC PWR NOT RESTRD IN 10 HOURS IF NO PWR AT 4 HR
R8B	6.74E-001	OFFSITE AC PVR RESTRD IN 10 HOURS IF NO PVR AF 4 HR
R9	3.11E-002	OFFSITE AC PWR NOT RESTRD IN 10 HOURS IF NO PWR AT 6 HR
RCCLDECST	1.60E-003	CST LOW LEVEL ACTUATION LOGIC HARDWARE FAILURE
RCCLDEL2	1.60E-003	RCIC AUTOMATIC L2 ACTUATION LOGIC HARDWARE FAILURE
	1.60E-003	RCIC LEVEL 8 ACTUATION LOGIC HARDWARE FAILURE
RCCLDEL8		MIN FLOW ACTUATION LOGIC HARDWARE FAILURE
RCCLDEMINFLOW		1E51-COOO1 CONTROL LOGIC FAILS TO FUNCTION
RCCLLF1E51C0001		1E51-FOO11 CHECK VALVE NC - FAILS TO OPEN
RCCVN01E51F0011		1E51-FOC21 CHECK VALVE NC - FAILS TO OPEN
RCCVN01E51F0021		1E51-F0030 CHECK VALVE NC - FAILS TO OPEN
RCCVN01E51F0030	1.00F-004	1E51-F0040 CHECK VALVE NC - FAILS TO OPEN
RCCVN01E51F0040	1.00E-004	
RCCVN01E51F0065	1.002-004	1E51-FOO65 CHECK VALVE NC - FAILS TO OPEN
RCCVN01E51F0066	1.00E-004	1651-FOOG6 CHECK VALVE NC - FAILS TO OPEN
RCCVN01E51F0577		1E51-F0577 CHECK VALVE NC - FAILS TO OPEN
RCHICPEL-2-CST-S	5.00E-002	OPERATOR FAILS TO PREVENT SUCTION SHIFT TO SUPP POOL
RCHICPS51-LDTRIP		FAILURE TO RECOVER ISOL SIGNAL ON HIGH STEAM TUPNEL TEMP
RCHICPSE51-5:1	5.00E-002	OFERATOR FAILS TO PERFORM RCIC SUCTION SHIFT
RCHIMASE51-4:1	0.00E+000	FAILURE TO KESTORE RCIC FOLLOWING MAIN"ENANCE
RCLXCCCSTLOW	9.59E-005	CST LOW LEVEL INSTR COMMON CAUSE MISCALIBRATION
RCLXDE1E51N0035A	9.58E-004	1E51-NO035A CST LEVEL INSTRUMENT FAILS TO FUNCTION
RCLXDE1E51N0035E	9.58E-004	1E51-NOO35E CST LEVEL INSTRUMENT FAILS TO FUNCTION
RCMVFC1E51F0010	2.40E-006	1E51-FOO10 MOTOR VALVE FAILS TO REMAIN OPN
RCNVFC1E51F0063	2.40F-006	1E51-FOO63 MOTOR VALVE FAILS TO REMAIN OPN
RCMV CIE51F0064	2.40E-006	1E51-F0064 MOTOR VALVE FAILS TO REMAIN OPN
RCMVFC1E51F0068	2.40E-006	1851-FOO68 MOTOR VALVE FAILS TO REMAIN OPN
RCMVNC1F51F0045	2.93E-003	1E51-F0045 MOTOR VALVE NO - FAILS TO CLOSE
RCMVN01E51F0013	2.93E-003	1E51-F0013 MOTOR VALVE NC - FAILS TO OPEN
RCMVN01E51F0019	2,93E-003	1E51-FOO19 MOTOR VALVE NC - FAILS TO OPEN
RCMVN01E51F0031	2.93E-003	1E51-F0031 MOTOR VALVE NC - FAILS TO OPEN
RCMVN01E51F0045	2.93E-003	1E51F0045 MOTOR VALVE NC - FAILS TO OPEN
RCMVN01E51F0046	2.93E-003	1E51-TO046 MOTO' VALVE NC - FAILS TO OPEN
RCPRN01E51F0015	1.00E-003	1E51-FOO15 FRES JIRE REGULATOR FAILS TO OPEN
RCRCUM	1.81E-002	RCIC UNAVAILABLE DUE TO MAINTENANCE
RCTPFR1E51C0001	1.138-001	1E51-CO001 TURBINE PUMP FAILS TO RUN
RCTPPR1E51C001	1.38E-002	1E51-COOO1 TURBINE PUMP FAILS TO RUN
RCTPFS1E51C0001	2.93E-003	1E51-COOO1 TURBINE PUMP FAILS TO START
RCXVPL1E51F0501	1.37E-004	1E51-F0501 MANUAL VALVE PLUGGED
RCXVPL1E51F0502	1.37E-004	1E51-F0502 MANUAL VALVE PLUGGED
RPHICPERC-1:0-2	1.00E-004	OPERATOR FAILS TO SCRAM REACTOR
RPT	1.00E-004	. RECIRC PUMP FAILS TO TRIP
RPVLEVEL8TRIP	1.00E-001	PROB THAT RFF WILL NOT BE AVAIL DUE TO RPV LEVEL 8 TRIP
51	3.008-004	INTERMEDIATE LOSS OF COOLANT ACCIDENT (INTERMEDIATE LOCA)
52	3.008-003	SMALL LOSS OF COOLANT ACCIDNET (SMALL LOCA)
SACLLF2P51C0001	1.252-004	2P51-COOO1 CONTROL LOGIC HARDVARE FAILURE
SACMFR1P51C0001	3.83E-003	
and the second se		

Event	Point Est	Description
SACMFR2P51COOL.		2P51 COOO1 COMPRESSOR FAILS TO RUN
SACMFS2P51C0001		2P51-C0001 COMPRESSOR FAILS TO START
SAHICPSP51-4:2	5.00E-002	OPERATOR FAILS TO REPOSITION NCC LUBE OIL CLR OUTLET VLV
SAHIMASP51-4:1:2	1.00E-003	FAILURE TO RESTORE FOLLOWING MAINTENANCE
SAPXDE2P51N0185	9.59E-005	2P51-N0185 PRESSURE SENSOR FAILS TO FUNCTION
SCHICPSE12-5:3	1.09E-004	OPERATOR FAILS TO ALIGN RHR TO SUPP POOL COOLING
SCHICPSE12-5:3A	1.09E-004	OPERATOR FAILS TO ALIGN RHR TRAIN A TO SUPP POOL CLNG OPERATOR FAILS TO ALIGN RHR TRAIN B TO SUPP POOL CLNG
SCHICPSE12-5:3B	1.09E-004	SUPP POOL RTRN VLVS COMMON CAUSE FAILURE
SCMVCC SCMVF01E12F0053A	9.25E-005 1.20E-005	1E12-F0053A MOTOR VALVE NC - FAILS OPEN
SCHVF01E12F00538 SCHVF01E12F00538	1.20E-005	1E12-F0053B MOTOR VALVE NC - FAILS OPEN
SCHVP01E12F0033B	2.93E-003	1E12-F0027A MOTOR VALVE NO - FAILS TO CLOSE
SCHVNC1E12F0027B	2.93E-003	1E12-FOO27B MOTOR VALVE NO - FAILS TO CLOSE
SCHVNC1E12F0048A	2.93E-003	1E12-FOO4BA MOTOR VALVE NO - FAILS TO CLOSE
SCMVNC1E12F0048B	2.93E-003	1E12-FO048B MOTOR VALVE NO - FAILS TO CLOSE
SCMVN01E12F0024A	2,93E-003	1E12-FO024A MOTOR VALVE NC - FAILS TO OPEN
SCMVN01E12F0024B	2.93E-003	1E12-F0024B MOTOR VALVE NC - FAILS TO OPEN
SICMFR1P57C0001	3.83E-003	1P57-CO001 COMPRESSOR FAILS TO RUN
SICVF01P57F0555A	3.44E-003	1P57-F0555A CHECK VALVE FAILS OPEN
SICVF01P57F0555B	3.44E-003	1P57-F0555B CHECK VALVE FAILS OPEN
SICVF01P57F0556A	3.44E-003	1P57-F0556A CHECK VALVE FAILS OPEN
SICVF01P57F0556B	3.44E-003	1P57-F0556B CHECK VALVE FAILS OPEN
SILVNO1P57F0524A	1.00E-004	1P57-F0524A CHECK VALVE NC - FAILS TO OPEN
SICVN01P57F0524B	1.00E-0(14	1P57-F0524B CHECK VALVE NC - FAILS TO OPEN
SIHICPSP57-7:1	5.00E-002	OPERATORS FAIL TO CONNECT AIR CYLINDERS
SIHICPSP57-7:1:A	5.00E-003	OPERATORS FAIL TO CONNECT AIR CYLINDERS
SIHICPSP57-7:1:B	5.00E-003	OPERATORS FAIL TO CONNECT AIR CYLINDERS
SIHIMASP57-4:0:A	0.00E+000	FAILURE TO RESTORE FOLLOVING MAINTENANCE
SIHIMASP57-4:0:B	0.00E+000	FAILURE TO RESTORE FOLLOWING MAINTENANCE
SIMVFC1P57F0015A	2.40.7-006	1P57-FOO15A MOTOR VALVE NO - FAILS CLOSED
SIMVFC1F57F0015B	2.40E-006	1P57-F0015B MOTOR VALVE NO - FAILS CLOSED
SIMVFC1P57F0020A	2.40E-006	1P57-F0020A MOTOR VALVE NO - FAILS CLOSED 1P57-F0020B MOTOR VALVE NO - FAILS CLOSED
SIMVFC1P57F0020B	2.40L-006 1.00E-004	1C41-FOOD6 CHECK VALVE NC - FAILS TO OPEN
SLCVN01C41F0006 SLCVN01C41F0007	1.00E-004	1C41-FOOOT CHECK VALVE NC - FAILS TO OPEN
SLCVN01C41F0033A	1.00E-004	1C41-F0033A CHECK VALVE NC - FAILS TO OPEN
SLCVN01C41F0033B	1.002-004	1C41-F0033B CHECK VALVE NC - FAILS TO OPEN
SLEVCC	2.93E-004	SLC EXPLOSIVE VALVE COMMON MODE FAILURE
SLEVN01C41F0004A	2.93E-003	1C41-FC004A EXPLOSIVE VALVE NC - FAILS TO OPEN
SLEVNO1C41F0004B	2.93E-003	1C41-F0004B EXPLOSIVE VALVE NC - FAILS TO OPEN
SLHICPEQ-6-RPVLC	5.00E-002	OPER FAILS TO CNTRL RPV LVL & MAINTAIN BORON INVENTORY
SLH1CPEQ-6-SLC1		OPERATOR FAILS TO INITIATE SLC 1 PUMP INJECTION
SLHICPEQ-6-SLCX	1.00E+000	OPERATOR FAILS TO INITIATE SLC LEVEL CONTROL FAILS
SLHICREQ-6-SLCR	1.00E-001	OPER FAILS TO INITIATE SLC GIVEN CORE DAMAGE
SLHIMA	0.00E+000	FAILURE TO RESTORE SLC FOLLOWING MAINTENANCE/TEST
SLMPCC	2.93E-004	SLC MOTOR PUMPS COMMON CAUSE FAILURE
SLMPFR1C41C0001A	1.20E-004	1C41-COOOIA MOTU" PUMP FAILS TO RUN
SLMPFR1C41C0001B	1.20E-004	1C41-COOU1B MOTOR PUMP FAILS TO RUN
SLMPFS1C41C0001A		1C41-COOCIA MOTOR PUMP FAILS TO START
SLMPFS1C41C0001B	2.93E-003	1C41-COOOLB MOTOR PUMP FAILS TO START

۴.			
	Event	Point Est	Description
	SLMPUM1C41C0001A	1.65E-002	1C41-CO001A UNAVAILABLE DUE TO MAINTENANCE
	SLMPUM1C41C0001B	1.65E-002	1C41-CO001B UNAVAILABLE DUE TO MAINTENANCE
	SLMVCC	9.25E-005	SLC MOTOR VALVES COMMON CAUSE FAILURE
	SLMVCC1G33	9.25E-005	RVCU VALVES COMMON CAUSE FAILURE
	SLMVNC1G33F0001		1G33-FOOD1 MOTOR LVE NO - FAILS TO CLOSE
	SLMVNC1G33F0004	2.93E-003	1G33-F0004 MOTOR VALVE NO - FAILS TO CLOSE
	SLMVN01C41F0001A	2.93E-003	1C41-FO001A MOTOR VALVE NC - FAILS TO OPEN
	SLM/NO1C41F0001B	2.93E-003	1C41-F0001B MOTOR VALVE NC - FAILS TO OPEN
	SLMVUM1C41F0001A	1.08E-002	1C41-F0001A UNAVAILABLE DUE TO MAINTENANCE
	SLMVUM1C41F0001B	1.08E-002	1C41-F0001B UNAVAILABLE DUE TO MAINTENANCE
	SLRVF01C41F0029A	1.60E-005	1C41-F0029A RELIEF VALVE NC - FAILS OPEN
	SLRVF01C41F0029B	1.60E-005	1C41-F0029B RELIEF VALVE NC - FAILS OPEN
	SLXVPL1C41F0002A	4.50E-005	1C41-F0002A MANUAL VALVE PLUGS
	SLXVPL1C41F0002B	4.50E-005	1C41-F00D2B MANUAL VALVE PLUGS
	SLXVPL1C41F0003A	4.50E-005	1C41-F0003A MANUAL VALVE PLUGS
	SLXVPL1C41F0003B	4.50E-005	1C41-F0003B LANUAL VALVE PLUGS
	SLXVPL1C41F0036	4.50E-605	1C41-F0036 MANUAL VALVE PLUGS
	SLXVPL1C41F0057A	4.508-005	1C41-F0037A MANUAL VALVE PLUGS
	SLXVPL1C41F0037B	4.50E-005	1C41-F0037P MANUAL VALVE NC - FAILS TO OPEN
	SMCLLF1G43A	1.25E-004	SPMU TRAIN A CONTROL LOGIC FAILS
	SMCLLF1G43B	1.25E-004	SPMU TRAIN B CONTROL LOGIC FAILS
4	SMMVCC	9.25E-005	SPMU MOTOR VALVE COMMON CAUSE FAILURE
,	CMMVN01G43F0030A	2.93E-003	1G43-F0030A MOTOR VALVE FAILS TO OPEN
	SMMVN01G43F0030B	2.93E-903	1G43-F0030B MOTOR VALVE FAILS YO OPEN
	SMMVN01G43F004/JA	2.93E-003	1G43-F0040A MOTOR VALVE FAILS TO OPEN
	SMMVN01G43F0040B	2.93E-003	1G43-F004CB MOTOR VALVE FAILS TO OPEN
	SMRANDOM-SRVTPLL	5.00E-001	SMALL LOCA RANDOM SPMU DUMP LIFTS 5P INTO UNSAFE ZONE
	SPHICPPS4: 5SPCU	1.00E+000	OPERATORS FAIL TO ALIGN SUPP POOL C/U ALTERNATE INJECTION
	SPHICPPS4:5SPCUL	5.00E-002	OPERATORS FAIL TO ALIGN SUP POOL C/U ALT INJECTION(LATE)
	SPMPFR'G42C0001		1G42-COOO1 MOTOR PUMP FAILS TO RUN
	SPMPFS1G42C0001		1G42-COOO1 MOTOR PUMP FAILS TO FIART
		2.93E-003	1G42-F0010 MOTOR VALV. NC - FAILS TO OPEN
		2.93E-003	1G42-F0020 MOTOR VALVE NC - FAILS TO OPEN
	SVCLLF1P41C001D	1.25E-004	1P41-COOID CONTROL LOGIC FAILS TO FUNCTION
	SVMPFR1P41C001A	7.20E-004	1P41-COOIA MOTOR PUMP FAILS TO RUN
	SVMPFR1P41C001B	7.20E-004	1P41-COOIB MOTOR PUMP FAILS TO RUN
	SVMPFR1P41C001C	7,20E-004	1P41-COOIC MOTOR PUMP FAILS TO RUN
	SWMPFR1P41C001D	7.20E-004	1P41-COOID MOTOR PUMP FAILS TO RUN
	SVMPFS1P41C001D	2.93E-003	1P41-COOID KOTOR PUMP FAILS TO START
	SVMPUM1P41C001D	5.00E-001	STANDBY SERV . WATER PUMP UNAVAIL DUE TO MAINTENANCE
	T1	6.07E-002	LOSS OF OFFSILE POVER TRANSIENT (LCOP)
	T2	1.62E+000	TRANSIENT WITH LOSS OF POWER CONVERSION SYSTE!
	T3A	4,51E+000	TRANSIENTS WITH PCS INITIALLY AVAILABLE
	T38	7.60E-001	TRANSIENT W/ LOSS OF FEEDWATER BUT W/ PCS INITIALLY AVAIL
	T3C	1,40E-001	TRANSIENT CAUSED BY INADVERTENT OPEN RELIEF VALVE ON REV
	7BFAFR1M35C0001A	3.00E-004	1M35-CC001A FAN FAILS TO RUN
4	TBFAFR1M35C0001B	3.00E-004	1M35-COOO1B FAN FAILS TO RUN
1	TBFAFR1M35C0001C	3.00E-004	1M35-COOOLC FAN FAILS TO RUN
	TBFAFS1M35C0001C	3.75E-004	1M35-COOO1C FAN FAILS TO START OPERATOR FAILS TO START STANDBY FAN
	TBHICPSM35	5.00E-002	ULDRAIUN FAILD IU DEART DIARDDI FAR

TCV8.51E-002LOSS OF CONTROL COMPLEX CHILTIA0.20E-002LOSS OF INSTRUMENT AIRTSW1.00E-003LOSS OF SERVICE WATER	LLED WATER
TIA 0.20E-002 LOSS OF INSTRUMENT AIR	
TWCLLF1P44C0001C 1.25E-004 1P44-C0001C CUNTROL LOGIC FA	LILS TO START
TWMPFR1P44C0001A 7.20E-004 1P44-C0001A MOTOR PUMP FAILS	S TO RUN
TWMPFR1P44C0001P 7.20E-004 1P44-C0001B MOTOR PUMP FAILS	S TO RUN
TWMPFR1P44C0001C 7.20E-004 1P44-C0001C MOTOR PUMP FAILS	S TO RUN
TWMPFS1P44C0001C 2.93E-003 1P44-C0001C MOTOR PUMP FAILS	S TO START
TWMPUM1P44C0001C 5.00E-001 1P44-C0001C MOTOR PUMP UNAV	AIL DUE TO MAINTENANCE
U109B 8.955-001 COMPLEMENT TO U109	
U111B R.96E-001 COMPLEMENT TO U111	
U202B 7.82E-001 COMPLEMENT TO U202	
U207B 8.75E-001 COMPLEMENT TO U207	
U210B 8.34E-001 COMPLEMENT TO U210	
VAO3B 8.38E-001 COMPLEMENT TO VAO3	
VA04B 7.33E-001 COMPLEMENT TO VA04	
VA05B 8.76E-001 COMPLEMENT TO VA05	
VAO8B 7.19E-001 COMPLEMENT TO VAO8	
VA09B 5.33E-001 COMPLEMENT TO VA09	
VA10B 8.23E-001 COMPLEMENT TO VA10	
VA15B 5.44E-001 COMPLEMENT TO VA15	
VA16B 7.29E 001 COMPLEMENT TO VA16	
VA18B 8.01E-001 COMPLEMENT TO VA18	
VA20B 7.44E-001 COMPLEMENT TO VA20	
X26B 1.00E+000 COMPLEMENT TO X26	
X33B 9.00E-001 COMPLEMENT TO X33	
XHOS-LO-IW-PRESS 0.00F.000 DW PRESSURE TOO LOW TO CAUS	
XHOSACPOWER1 0.00E+000 RECOVERY OF AC PWR IN 1 HOU	
XHOSACPOWER10 0.00E+000 RECOVERY OF AC PUR IN 10 HO	URS 10 = 1
XHOSACPOVER10:4 0.00E+000 RECOVERY OF AC PWR IN 10 HO	
XHOSACPOWER10:6 C.OOE+000 RECOVERY OF AC PWR IN 10 HO	
· · · · · · · · · · · · · · · · · · ·	URS 11 YOURS = 1
	URS 1 HOURS = 1
XHOSACPOWER12:10 0.00E+000 RECOVERY OF A CPWR IN 12 HR	
XHOSACPOWER12:4 0.00E+000 RECOVERY OF AC PWR IN 12 HO	
XHOSACPOWER13 0.00E+000 RECOVERY OF AC PWR IN 13 HO	
XHOSACPOVER14 C.OOE+000 RECOVERY OF AC PWR IN 14 HO	
XHOSACPOWER14:11 0.00%+000 RECOVERY OF AC PWR IN 14 GI	
XHOSACPOWER15 0.00E+000 RECOVERY OF AC PWR IN 15 HO	
XHOSACPOWER15:11 0.00E+000 RECOVERY OF AC PWR IN 15 GI	
XFOSACPOWER15.12 0.00E+000 RECOVERY OF AC PWR IN 15 GI	
XHOSACPOWER17 0.00E+000 RECOVERY OF AC PWR IN 17 HO	
XHOSACPOWER17:12 0.00E+000 RECOVERY OF AC PWR IN 17 HR	
XHOSACPOWER17:13 0.00E+000 RECOVERY OF AC FWR IN 17 HR	
XHOSACPOVER17:P4 0.00E+000 RECOVERY OF AC PWR IN 17 GI	
XHOSACPOVER18 0.00E+000 RECOVERY OF AC PWR IN 18 HO	
XHOSACPOWER18:3 0.00E+000 RECOVERY OF AC PWR IN 18 GI	VEN 3 HOURS 18:3 = 1
XHOSACPOWER18:4 0.00E+000 RECOVERY OF AC PWR IN 18 GI	VEN 4 HOURS $18:4 = 1$
XHOSACPOWER1: P26 0.00E+000 RECOVERY OF AC PWR IN 1 HOU	
XHOSACPOWER1P3 0.00E+000 RECOVERY OF AC PWR IN 1.3 H	HOURS 1.3 HOURS = 1

Event	Point Est	Description
XHOSACPOWER1P3P4	0.00E+000	RECOVERY OF AC PWR IN 1.3 GIVEN 0.4 HR 1.3:0.4 = 1
XHOSACPOVEF1P4	0.00E+000	RECOVERY OF AC FVR IN 1.4 HOURS 1.4 HOURS = 1
XHOSACPOVER1P4P4	0.00E+000	RECOVERY OF AC PWR IN 1.4 GIVEN 0.4 HR 1.4:0.4 = 1
XHOSACPOVER1P7	0.005+000	RECOVERY OF AC PWR IN 1.7 HOURS 1.7 HOURS # 1
XHOSACPOVER1P7P3	0.00E+000	RECOVERY OF AC PWR IN 1.7 GIVEN 0.3 HR 1.7:0.3 = 1
XHOSACPOVER2	0.00E+000	RECOVERY OF AC FWR IN 2 HOURS 2 HOURS = 1
XHOSACPOVER21	0.00E+000	RECOVERY OF AC PWR IN 21 HOURS 21 HOURS = 1
XHOSACPOVER21:13	0.00E+000	RECOVERY OF AC PVR IN 21 GIVEN 13 HRS 21:13 # 1
XHOSACPOVER23	0.00E+000	RECOVERY OF AC PWR IN 23 HOURS 23 HOURS = 1
XHOSACPOVER23:11	0.00E+000	RECOVERY OF AC PWR IN 23 GIVEN 11 HRS 23:11 = 1
XHOSACPOVER24	0.00E+000	RECOVERY OF AC PWF. IN 24 HOURS 24 HOURS # 1
XHOSACPOVER241P3	0.00E+000	RECOVERY OF AC PWR IN 24 GIVEN 1.3 HRS 24:1.3 = 1
XHOSACPOVER241P7	0.00E+000	RECOVERY OF AC PWR IN 24 GIVEN 1.7 HRS 24:1.7 = 1
XHOSACPOWER24:1	0.00E+000	RECOVERY OF AC PVR IN 24 GIVEN 1 HOUR 24:1 = 1
XHOSACPOVER24:15	0.00E+000	RECOVERY OF AC PWR IN 24 GIVEN 15 HRS 24:15 = 1
XHOSACPOVER24:6	0.00E+000	RECOVERY OF AC PWR IN 24 GIVEN 6 HOURS 24:6 = 1
XHOSACPOVER24:7	0.00E+000	RECOVERY OF AC PWR IN 24 GIVEN 7 HRS 24:7 - 1
XHOSACPOVER3	0.005+000	RECOVERY OF AC PWR IN 3 HOURS 3 HOURS = 1
XHOSACPOVER4	0.00E+000	RECOVERY OF AC PWR IN 4 HOURS 4 HOURS = 1
XHOSACPOVER4:2	0.00E+000	RECOVERY OF AC PWR IN 4 HOURS GIVEN 2 4:2 = 1
XHOSACPOWER4:3	0.00E+000	RECOVERY OF AC PWR IN 4 HOURS GIVEN 3 4:3 = 1
XHOSACPOVER4: P26	0.00E+000	RECOVERY OF AC PWR IN 4 HOURS GVN 0.26 4:P26 = 1
XHOSACPOVER4: P3	0.0CE+000	RECOVERY OF AC FWR IN 4 HOURS GIVEN .3 4:P3 = 1
XHOSACPOVER4: P4	0.00E+000	RECOVEL OF AC PWR IN 4 HOURS GIVEN .4 4:P4 = 1
XHOSACPOWER5	0.0(E+000	RECOVERY OF AC PWR IN 5 HOURS 5 HOURS = 1
XHOSACPOWER5:2	0.001+000	RECOVERY OF AC PWR IN 5 HOURS GIVEN 2 5:2 = 1
XHOSACPOVER6	0.00E+000	RECOVERY OF AC PWR IN 6 HOURS 6 HOURS = 1
XHOSACPOVER6:2	0.00E+600	RECOVERY OF AC PWR IN 6 GIVEN 2 HOURS 6:2 = 1
XHOSACPOVER6:3	0.00+000.0	RECOVERY OF AC PVR IN 6 GIVEN 3 HOURS 6:3 = 1
XHOSACPOVER6:4	0.00E 000	RECOVERY OF AC PWR IN 6 HOURS GIVEN 4 6:4 = 1
XHOSACPOVER7	0.00E+000	RECOVERY OF AC PWR IN 7 HOURS 7 HOURS = 1
XHOSACPOVER7:3	0.00E+000	RECOVERY OF AC PWR IN 7 GIVEN 3 HOURS 7:3 = 1
KHOSACPOVER8	C.OOE-000	RECOVERY OF AC PWR IN 8 HOURS 8 HOURS = 1
XHOSACPOVER9	0.00E+000	RECOVERY OF AC PWR IN 9 HOURS 9 HOURS = 1
XHOSACPOVERP26	0.00E+000	RECOVERY OF AC PWR IN 0.26 HOURS 0.26 HOURS * 1
XHOSACPOWERF3	0.00E+000	RECOVERY OF AC FWR IN 0.3 HOURS 0.3 HOURS = 1
XHOSACPOWERP4	0.00+300.0	RECOVERY OF AC PWR IN 0.4 HOURS 0.4 HOURS = 1
XHOSADSAC	0.00E+000	ADS ACCUMULATORS NOT CONSIDERED A SUCCESS
XHOSCNTNMNTSPRAY		CONTAINMENT SPRAY SIGNAL PRESENT CS = 1; NO CS = 0
XHOSFPTTRIPSCNAL		FEED PUMP TURBINE TRIP SIGNAL TRIP SIGNAL = 1
XHOSHIGHDRYWELL	1,00E+000	HIGH DRYWELL PRESSURE SIGNAL HDP = 1
XHOSLONGTERMEVNT		LONG TERM EVENT LTE = 1
XHOSLOOP	1,00E+000	LOSS OF OFFSITE POVER
XHOSMFPSTARTSGNL		MOTOR FEED PUMP START SIGNAL NO START SIGNAL = 1
XHOSNOAUTOADS	0.00E+000	ADS INHIBITED AUTO ADS = 1 NO AUTO ADS = 0
XHOSNOLOOP	0.00E+000	NO LOSS OF OFFSITE POWER
XHOSNONADSAC	0.00E+000	NON-ADS ACCUMUL NOT CONSIDERED A SUCCESS
XHOSNOSBO	0.00E+000	NO STATION BLACKOUT SBO = 0 NO SBO = 1
XHOSNOSTEAM	1,00E+000	POWER CONVERSION SYSTEM IS NOT AVAILABLE
XHOSRCICISOL	0.00E+000	STEAM SUPPLY FAILS DUE TO ISOLATION SIGNAL

Event	Point Est	Description
XHOSRCICROOMCLNG	0.00E+000	RCIC RM CLNG RORD NO COOLING = 0 COOLING = 1
XHOSRFVL1	1.00E+000	PRV LOW WATER LEVEL 1 SIGNAL LEVEL 1 = 1
XHOSSBO	1.00E+000	STATION BLACKOUT SEO = 1 NO SEO = 0
Y17B	9.21E-001	COMPLEMENT TO Y17
ZERO	0.00E+000	BASIC EVENT SET TO 0.0

Table 3.3.3-1 Human Interaction Basic Events

Basic Event Id Point Est Description

-	CONTRACTOR OF A CONTRACTOR OF A CONTRACT OF		
	ADHTOPOS-1-ADS-A	3.79E-003 OPERATOR FAILS TO INHIBIT ADS ATWS W/ FEEDWATER	
	ADHICPCS-1-ADS-I	3.60E+000 OPERATOR FAILS TO INHIBIT ADS ATWS W/O FDW & IPRV	
		3.60E-002 OPERATOR FAILS TO INHIBIT ADS ATWS W/ LOOP	
		7.20E+000 OPERATOR FAILS TO INHIBIT ADS ATWS W/O FEEDWATER	
		9.99E-OUS FAILS TO RECOVER FROM RPV DEPRESS CD FAILURE	
	AURICIEUZ-AUS-LA	1.00E-001 FAILS TO RECOVER FROM RPV DEPRESS CD FAILURE	
	ADHICPECZ-ADS-1	1.00E-003 FAILS TO EMERGENCY REV DEPRESS TRANSIENT	
	ADHICPECS-ADS-FL	7.00E-003 FAILS TO EMERGENCY RPV DEPRESS - ATWS W/ FDW & LVL CNTKL	
	ADHICPEC5-ADS-FX	1.40E-002 FAILS TO EMERGENCY RPV DEPRESS - ATWS W/ FDW & NO LVL CNT	
	CAHICPIOO8 -4:2	1.00E-003 OPERATORS FAIL TO SHIFT CONDENSER AIR REMOVAL TO VP & AB	
	CCHICP	0.00E+000 OPERATOR FAILS TO BYPASS LOCA SIGNAL IN 4.5 HOURS	
	CCHICPSP47-5:4	0.00E+000 OPERATOR FAILS TO REALIGN CCCW LOOF C IN 4.5 HOURS	
	CDHICPPS2:1-XH11	1.00E-001 OPERATOR FAILS TO BYPASS THE RHR LOCA SIGNAL - XH11	
		1.00E-CO1 OPERATOR FAILS TO BYFASS THE RUR LOCA SIGNAL - XH12	
	CDHICPPS2:1-XH17	1.00E-003 OPERATOR FAILS TO BYPASS THE RHR LOCA SIGNAL - XH1X	
	CSHICPET-2:P-1	1.70E-002 OPERATOR FAILS TO INITIATE RHR CONTAINMENT SPRAY	
	CSHICPET-2:P-1-A	1.70E-002 OPERATOR FAILS TO INITIATE TRN A RHR CONTAINMENT SPRAY	
	CSHICPET-2:P-1-B	1.70E-002 OPERATOR FAILS TO INITIATE TRN B F.HR CONTAINMENT SPRAY	
	CTHICPPS4:4. ALT	1.00E-001 OPERATOR FAILS TO ALIGN CONDENSATE XFER ALT INJECTION	
	CTHICPPS4:4-ALT6	1.00E-003 OPERATOR FAILS TO ALIGN CONDENSATE TRANSFER IN 6 HOURS	
	CTRICPPS4:4-ALTC	3.00E-001 OPERATOR FAILS TO ALIGN CONDENSATE XFER ALT INJECTION	
	CVHICPEPC-COM	1.00E-003 FAILS TO INITIATE CNTNMNT PRESS CNTRL RHR AND VENT	
	CVHICPEPC-FPCC	1.00E-001 FAILS TO INITIATE CNTNMNT PRESS CNTRL VENTING	
	CVHICPEPC-RHR	1. DE-002 FAILS TO INITIATE CNTNMNT PRESS CNTRL RHP.	
	CVHICPEPC-RHR-E	1.00E-001 FAILS TO INITIATE CNTNMNT PRESS CNTRL RHR - S.P. CLNG	
	CVHICPPS7RHR	1.00E-005 OPERATOR FAILS TO INITIATE RHR CONTAINMENT VENTING	
	CVHICPPS7:1-P-T	1.00E-010 OPERATOR FAILS TO PREPARE FOR RHR CNTNMNT VENT - TRAN	
	CVHICPPS7:3G41-T	9.99E-005 OPERATOR FAILS TO ALIGN FPCC FOR CNTNMNT VENT - TRAN	
	CVHICPPS7:4E12-T	9.99E-005 OPERATOR FAILS TO ALIGN RHR FOR CNTNMNT VENT - TRAN	
	CVHICRPS7:3G41-T	5.00E-002 OPERATOR IS UNABLE TO LOCALLY OPEN 1G41-F0145	
	DGHICPOS11-2:5	1.25E-003 OPERATOR FAILS TO INITIATE DIESEL GENERATORS	
		1.25E-003 OPERATOR FAILS TO INITIATE DIV 1 D/G	
		1.25E-003 OPERATOR FAILS TO INITIATE DIV 2 D/G	
		0.00E+000 FAILURE TO RESTORE FOLLOWING MAINTENANCE	
	DGHIMASR43-4:1:E	9.00E+00C FAILURE TO RESTORE FOLLOWING MAINTENANCE	
	DHHICPOS11-2:5:C	1.25E-003 OPERATOR FAILS TO INITIATE DIV 3 D/G	
	DHHIMASE22B-4:1	0.00E+000 FAILURE TO RESTORE FOLLOVING MAINTENANCE	
	ECHICPSP42-412	5.00E-002 OPERATOR FAILS TO CLOSE VALVE OP42-F0150A(B)	
	ECHICPSP42-4:2A	5.00E-002 OPERATOR FAILS TO CLOSE VALVE OP42-F0150A	
	ECHICPSP42-4:2B	5.00E-002 OPERATOR FAILS TO CLOSE VALVE OP42-F0150B	
	ECHICPSP42-4PMP	5.00E-002 OPERATOR FAILS TO INITIATE PUMP 1P42-CO001A(B)	
	ECHICPSP42-4PMPA	5.00E-002 OPERATOR FAILS TO INITIATE PUMP 1P42-CO001A	
	ECHICPSP42-4PMPB	5.00E-002 OPERATOR FAILS TO INITIATE PUMP 1P42-C9001B	
	ECHIMASP42-4:1A	0.00E+000 ECC TRAIN A NOT RESTORED FOLLOWING MAINTENANCE	
	ECHIMASP42-4:1B	0.00E+000 ECC TRAIN B NOT RESTORED FOLLOWING MAINTENANCE	
	ERHICPPS4:2-ESW	1.00E-002 OPERATORS FAIL TO ALIGN 11 VLVS FOR RPV INJECTION	
	ESHIMASP45-4.1A	0.00E+000 ESV TRAIN A NOT RESTORED FOLLOWING MAINTENANCE	
	ESHIMASP45-4:1B	0.00E+000 ESW TRAIN B NOT RESTORED FOLLOWING MAINTENANCE	
1	PSHIMASP45-4:1C	0.00E+000 ESV TRAIN C NOT RESTORED FOLLOWING MAINTENANCE	
	FPHICPPS4:2-DD-0	3.00E-002 OPERATORS FAIL TO MAINTAIN FUEL OIL FOR DIESEL FIRE PMP	
	the second second		

Table 3.3.3-1 Human Interaction Basic Svents (continued)

Basic Event Id Point Est

Description FPHICPPS412FP-LE 5.00E-002 OPERATOR FAILS TO ALIGN VLVS FOR LATE FP ALT INJ < 3 HRS FPHICPPS4:2FP-LL 5.00E-003 OPERATOR FAILS TO ALIGN VLVS FOR LATE FP ALT INJ > 3 HRS PPHICPPS4:2RCIC1 3.00E-001 FAIL TO ALIGN FP AFTER RCIC FAILS DUE SUPP POOL TEMP FPHICPPS4: 2RCIC2 1.00E-001 FAIL TO ALIGN FP ATTER RHR FAILS DUE TO MCC TEMP FPHICPPS4: 2RCIC3 1.00E-002 FAIL TO ALIGN FP AFTER HPCS FAILS DUE TO MCC TEMP FFRICPFS4:2RCIC4 1.00E-001 FAIL TO ALIGN FAST FIRE PROTECTION ALTERNATE INJECTION FVHICPEC5-2:3LCS 1.00E-002 OPER FAILS TO CNTRL RPV LEVEL AT TAF W/ FW DURING IORV 1.00E-002 OPER FAILS TO CONTROL RPV LEVEL AT TAF FWHICPECS-3:2 FWHICPEL-2-FDW-L 1.0CE-002 OPERATOR FAILS TO REOFEN MFP CONTROL VALVES FOR T3C-C FWHICPEL-2-FDW-V 5.00E-003 OPER FAILS TO REOPN MFP CNTRL VALVES OR DEPRESSURIZE RPV FVHICPSN27-4:11A 1.20E-001 OPER FAILS TO CNTRL RX FEED BOOSTER PMP DURING LOSS OF 1A FWHICPSN27-4:111 5.00E-003 OPER FAILS TO CNTRL RX FEED BOOSTER PMP LOSS OF IA > 2 HRS FIRICPEC5-3:2-F 1.00E-003 FAILS TO RESTR RHR A/B/LPCS AND CONTRL AT TAF W/ FDW HIHICPEC5-3:2-S 1.00E-003 FAI'S TO RESTR RHR A/B/LPCS AND CNTRL AT TAF V/O FDW HIHICPEC5-5-CRIT 2.00E-003 OPER FAILS TO CNTRL RPV LEVEL AND FLUSHES BORON HIHICPOR10-4:0-1 5.00E-002 OPERATOR FAILS TO CLOSE FPCC OUTBOARD VALVE 1G41-F0145 HIHICPOR10-4:3-B 1.00E-002 OPER FAILS TO X-TIE UNIT 1 AND 2 BATT AND LOAD SHED HIHICPOR10-4:3-D 2.00E-003 OPER FAILS TO OPEN DIV 3 SWITCHGEAR KOOM DOORS HIHICPORIO-XTIE 5.00E-003 OPERATOR FAILS "O CROSSTIE DIV 3 BUS TO DIV 2 BUS HPHICPEL-1 1.25E-003 OPERATOR FAILS TO INITIATE HIGH PRESSURE INJECTION HPHICPSE22-5:0 5.00E-002 OPERATOR FAILS TO CONTROL MIN FLOW VALVE 1E22-F0012 HPHICPSE22-5:2 5.00E-002 OPER FAILS TO XFER TO SUPR POOL WITH 1E22-F015 HPHIMASE22-4:1 0.00E+000 FAILURE TO RESTORE HPCS AFTER MAINTENANCE IAHICPSP51-4:2 5.00E-002 OPERATOR FAILS TO REPOSITION NCC LUBE OIL CLR OUTLET VLV IAHICRSP52-7:2 1.00E-001 OPERATOR FAILS TO OVERRIDE ISOLATION SIGNA! IAEIMASP51-4:1:2 1.00E-003 FAILURE TO RESTORE FOLLOWING MAINTENANCE LCHICPEL-1-LPCI 1.00E-003 OPERATOR FAILS TO INITIATE LPCI B LCHICPSE12-5:1 5.00E-002 OPERATOR FAILS TO CONTROL MIN FLOW VALVE 1E12-F0064A LCHIMASE12-4:1A 0.00E+000 FAILURE TO RESTORE TRAIN & LPCI FOLLOWING MAINT LCHIMASE12-4:1B 0.00E+000 FAILURE TO RESTORE TRAIN B LPCI FOLLOWING MAINT LCHIMASE12-4:1C 0.00E+000 FAILURE TO RESTORE TRAIN C LPCI FOLLOWING MAINT 1.002-003 OPERATOR FAILS TO INITIATE LOW PRESSURE INJECTION LPHICPEL-1 LPHICPEL-1-LPCS 1.00E-003 OPERATOR FAILS TO INITIATE LPCS 5.00E-002 OPERATOR FAILS TO CONTROL MIN FLOW VALVE 1E21-F0011 LPRICPSE21-5:1 0.00E+000 FAILURE TO 1 ORE LPCS AFTER MAINTENANCE LPHIMASE21-4:1 MCHICRRECVRD4 0.00E+000 MCC, SVTCHGR, & MISC ELECT AREAS RECVRD IN 4 HOURS MCHICRRECVRD9 0.00E+000 MCC, SWICHGR, & MISC ELECT AREAS RECVRD IN 9 HOURS 1.00E-002 OPERATOR FAILS TO INITIATE MSIV LEAKAGE CONTROL MLHICPE32 1.00E-001 OPERATOR FAILS TO BYPASS MSIV LEVEL 1 ISOLATION FOR T3C-C NSHTCPEC5-2-L1 NSHICPEC5-2-LIT3 1.00E+000 OPERATOR FAILS TO BYP MSIV LVL 1 ISOL FOR T3A-C OR T3B-C RCHICPEL-2-CST-S 5.00E-002 OPERATOR FAILS TO "REVENT SUCTION SHIFT TO SUPP POOL RCHICPSS1-LDTRIP 5.00E-002 FAILURE TO RECOVER ISOL SIGNAL ON HIGH STEAM TUNNEL TEMP RCHICPSE51-5:1 5.00E-002 OPERATOR FAILS TO PERFORM RCIC SUCTION SHIFT 0.00E+000 FAILURE TO RESTORE RCIC FOLLOWING MAINTENANCE RCHIMASE51-4:1 RPHICPERC-1:Q-2 1.00E-00% OFERATOR FAILS TO SCRAM REACTOR 5.00E-002 OPERATOR FAILS TO REPOSITION NCC LUBE OIL CLR OUTLET VLV SAHICPSP51-4:2 SAHIMASP51-4:1:2 1.00E-003 FAILURE TO RESTORE FOLLOWING MAINTENANCE SCHICPSE12-5:3 1.09E-CO4 OPERATOR FAILS TO ALIGN RHR TO SUPP POOL COOLING SCHICPSE12-5:3A 1.09E-004 OPERATOR FAILS TO ALIGN RHF TRAIN A TO SUPP POOL CLNG SCHICPSE12-5:38 1.09E-004 OPERATOR FAILS TO ALIGH RHR TRAIN B TO SUPP POOL CLNG





Table 3.3.3-1 Human Interaction Basic Events (continued)

Basic Event Id	Point Est	Description
SIHICPSP57-7:1	5.00E-002	OPERATORS FAIL TO CONNECT AIR CYLINDERS
SIHICPSP57-7:1:A	5.00E-003	OPERATORS FAIL TO CONNECT AIR CYLINDERS
SIHICPSP57-7:1:B	5.00E-003	OPERATORS FAIL TO CONNECT AIR CYLINDERS
SIHIMASP57-4:0:A	0.00E+000	FAILURE TO RESTORE FOLLOWING MAINTENANCE
SIHIMASP57-4:0:B	0.00E+000	FAILURE TO RESTORE FOLLOWING MAINTENANCE
SLHICPEQ-6-RPVLC	5.00E-002	OPER FAILS TO CNTRL RPV LVL & MAINTAIN BORON INVENTORY
SLHICPEQ-6-SLC1	1.25E-003	OPERATOR FAILS TO INITIATE SLC 1 FUMP INJECTION
SLHICPEQ-6-SLCX	1.00E+000	OPERATOR FAILS TO INITIATE SLC LEVEL CONTROL FAILS
SLHICREQ-6-SLCR	1.00E-001	OPER FAILS TO INITIATE SLC GIVEN CORE DAMAGE
SLHIMA	0.00E+000	FAILURE TO RESTORE SLC FOLLOWING MAINTENANCE/TEST
SPHICPPS4:5SPCU	1.00E+000	OPERATORS FAIL TO ALIGN SUPP POOL C/U ALTERNATE INJECTION
SPHICPPS4: 5SPCUL	5.00E-002	OPERATORS FAIL TO ALIGN SUP POOL C/U ALT INJECTION(LATE)
TBHICPSM35	5.00E-002	OPERATOR FAILS TO START STANDEY FAN





1944	A	100 100	
10.04	A 1 85	- 12 - 14	.4-1
	U.A.82	1.20 1 1 1	a the second
		100.00.00	

CCF From	abilit.	100 FAN	Varians	13199	Westmines in the
CCF Frot	CALLA A.A.L.	ves rot	suor rev	UUF	Events

Component	Means	5	EF	Madian	95%
MOVs	9.234 X 10 ⁻⁵	1.82	20	1.762 X 10 ⁻⁵	3.524 × 10 ⁻⁴
ESW Puerps	3.413 X 10 ⁻⁴	0.81	3.8	2.458 x 10 ⁻⁴	9.340 X 10 ⁻⁴
ECC Pumps	1.291 X 10 ⁻⁴	1.15	6.6	6.664 x 10 ⁻⁵	7.664 X 10 ⁻⁴
DGs	3.670 X 10 ⁻⁴	1.05	21	6.629 X 10 ⁻⁵	1.392 x 10 ⁻³



Table 3.3.5-1

Function Equation	Function Description	Function Probability
A	Large LOCA	1.00 × 10 ⁻⁴
B101	Div 1 and 2 D/G fail	8.36 X 10 ⁻³
C01	Rx scram - control rods in	1.00 X 10 ⁻⁵
C101	SLC injects with 1 of 2 pumps - LOOP	2.35 X 10 ⁻²
C105	SLC injects with 1 of 2 pumps	4.78 X 10 ⁻³
C107	SLC injects with 1 of 2 pumps	4.78 X 10 ⁻³
C108	SLC injects with 1 of 2 pumps	1.00
C109	SLC injects with 1 of 2 pumps	4.52 x 10 ⁻²
C110	SLC injects with 1 of 2 pumps	1.03 X 10 ⁻¹
C111	SLC injects with 1 of 2 pumps	4.52 x 10 ⁻³
C112	SLC injects with 1 of 2 pumps - LOOP	7.25 X 10 ⁻²
C114	SLC injects with 1 of 2 pumps	5.46 X 10 ⁻²
CC01	Control Complex Chilled Water recovery	0.00
CV01	Core not vulnerable to damage - HPCS	5.70 x 10 ⁻¹
CV02	Core not vulnerable to damage - Low Press ECCS	4.00 X 10 ⁻¹
CA03	Core not vulnerable to damage - Feedwater	1.80 X 10 ⁻¹



Function Equation	Function Description	Function Probability
CVC4	Core not vulnerable to damage - Injctn outside aux blang	1.40 X 10 ⁻¹
HIO1	Operator actions taken to extend HPCS operation SBO	1.30 x 10 ⁻²
HV01	MCC, Swtchgr, & Misc Elect Areas HVAC - LOOP	0.00
HV02	MCC, Swtchgr, & Misc Elect Areas HVAC - LCOP	0.00
HV03	MCC, Swtchgr, & Misc Elect Areas HVAC - LOOP	0.00
HV04	MCC, Swichgr, & Mirc Elect Areas HVACDOP	0.00
101	FPCC isolation shut by operator or diesel	3.44 x 10 ⁻²
LC02	Level Control ATWS	1.00 x 10 ⁻²
LIOI	Late injection	1.40 x 10 ⁻¹
LI02	Late injection	2.85 x 10 ⁻⁵
L103	Late injection	2.85 X 10 ⁻⁵
LI04	Late injection	1.40 x 10 ⁻⁵
LI09	Late injection	1.60 x 10 ⁻¹
LIIO	Late injection	1.44 x 10 ⁻¹
LI12	Late injection	1.95 × 10 ⁻²
LI14	Late injection	1.99 x 10 ⁻¹
LI15	Late injection	5.43 x 10 ⁻¹
LII6	Late injection	1.60 x 10 ⁻¹
LI17	Late injection	1.12 x 10 ⁻¹

Function Equation	Function Description	Function Probability
L119	Late injection	2.36 X 10 ⁻¹
LI21	Late injection	2.13 × 10 ⁻²
LI22	Late injection	2.41 × 10-4
LI23	Late injection	2.88 ~ 10 ⁻⁴
L124	Late injection	7.04 × 10 ⁻¹
LI25	Late injection	1.57 x 10 ⁻¹
LI26	Late injection	2.81 × 10 ⁻¹
1.127	Late injection	1.27 x 10 ⁻¹
LI 29	Late injection	3.28 X 10 ⁻³
LI30	Late injection	3.76 x 10 ⁻¹
LIJI	Late injection	1.41 × 10 ⁻¹
LI 32	Late injection	1.06 x 10 ⁻¹
L133	tate injection	1.14 X 10 ⁻¹
LI34	Late injection	1.06 x 10 ⁻¹
LI35	Late injection	2.41 × 10 ⁻¹
LI 36	Late Injection	6.54 x 10 ⁻³
LT37	Late injection	2.16 x 10 ⁻²
L138	Late injection	7.94 X 10 ⁻²
LI39	Late injection	1.84 x 10 ⁻¹
LI40	Late injection	1.52 x 10 ⁻¹
LIQI	Late injection	4.14 x 10-1
LI 42	Late Injection	4.65 X 10 ⁻¹
LI43	Late injection	2.07 x 10 ⁻¹
LI 48	Late injection	1.80 x 10 ⁻¹

Function Unavailabilities

Punction Equation	Function Description	Function Probability
LI49	Late injection	2.04 x 10 ⁻¹
L150	Late injection	4.40 X 10 ⁻¹
MO1	SRVs open	1.00 × 10-4
P101	One SRV opens and recloses	1.60 × 10 ⁻²
P102	One SRV opens and recloses w/ PCS avail	1.60 X 10 ⁻²
P201	Two SRVs open and reclose	1.60 X 10 ⁻³
P202	'Two SRVs open and reclose w/PCS avail	1.60 X 10 ⁻³
Q01	Power conversion system remains available	3.51 X 10 ⁻³
Q03	Power conversion system remains available	1.00
Q04	Power conversion system remains available	1.00
Q05	Power conversion system remains available	1.00 X 10 ⁻¹
R01	Restonation of AC power before core damage	1.23 X 10 ⁻²
R02	Restoration of AC power befors core damage	1.96 X 10 ⁻²
103	Restoration of AC power before core damage	1.23 X 10 ⁻²
R04	Restoration of AC power before core damage	8.23 x 1.0-2
R05	Restoration of AC power before core damage	1.96 X 10 ⁻²
R07	Restoration of AC power before core damage	5.29 X 10 ⁻¹

) I

Function Equation	Function Description	Function Probability
RC8	Restoration of AC power before core damage	1.96 7 10-2
R09	Restoration of AC power before core damage	1.74 X 10 ⁻¹
R101	Restoration of AC power before consideringe	8.23 X 10 ⁻²
R102	Rontorat. 1 AC power Lefore core damage	5.29 X 10 ⁻¹
R103	Restoration of AC power before core damage	6.16 X 10 ⁻¹
R201	Restoration of AC power before core damage	1.51 X 10 ⁻²
R202	Restoration of AC power before core damage	8.98 X 10 ⁻¹
R203	Restoration of AC power before core damage	1.40 X 10 ⁻¹
R204	Restoration of AC power before core damage	1.20 X 10 ⁻¹
R301	Restoration of ac power before RFV failure	3.81 X 10 ⁻¹
R302	Restoration of ac power before RFV failure	3.26 X 10 ⁻¹
R303	Restoration of ac power before RPV failure	5.97 X 10 ⁻¹
R304	Restoration of ac power before RPV failure	4.19 X 10 ⁻¹
R305	Restoration of ac power before RPV failure	4.33 X 10 ⁻¹
R306	Restoration of ac power before RPV failure	2.56 X 10 ⁻¹
R307	Restoration of ac power before RPV failure	6.96 X 10 ⁻¹

Function Equation	Punction Description	Function Probability
R308	Restoration of an power before RPV failure	4.50 X 10 ⁻¹
R309	Restoration of ac power before RPV failure	5.75 X 10 ⁻³
R310	Restoration of ac power before RFV failure	2.66 X 10 ⁻¹
R311	Restoration of ac power before RFV failure	2.00 x 10 ⁻¹
R312	Restoration of ac power before RPV failure	2.66 X 10 ⁻¹
R313	Restoration of ac power before RPV failure	2.66 X 10 ⁻¹
P.314	Restoration of ac power before RPV failure	4.19 × 10 ⁻¹
R315	Restoration of ac power before RPV Jailure	5.03 X 10 ⁻¹
R316	Restoration of ac power before RPV failure	5.44 X 10 ⁻¹
R317	Restoration of ac power before RFV failure	8.37 X 10 ⁻²
R318	Restoration of ac power before RPV failure	3.29 X 10 ⁻¹
R319	Restoration of ac power before RPV failure	6.22 x 10 ⁻²
R320	Restoration of ac power before RPV failurs	1.09 X 10 ⁻²
R321	Restoration of ac power before RPV failure	5.59 X 10 ⁻²
R323	Restoration of ac power before RPV failure	5.97 X 10 ⁻¹
R324	Restoration of ac power before RFV failure	4.32 X 10 ⁻¹

Punction Equation	Function Description	Function Probability
R326	Restoration of ac power before RPV failure	4.67 X 10 ⁻¹
R329	Restoration of ac power before RPV failure	2.04 X 10 ⁻¹
R401	Restoration of ac power before cntnmnt failure	2.29 X 10 ⁻²
R402	Restoration of ac power before cntnmrt failure	5.50 X 10 ⁻³
R403	Restoration of ac power before cntnmnt failure	1.60 X 10 ⁻¹
R404	Restoration of ac power before cntnmnt failure	2.29 X 10 ⁻²
R405	Restoration of ac power before cntnmnt failure	4.92 X 10 ⁻³
RPT01	Recirculation pump trip	1.00 X 10 ⁻⁴
S1	Intermediate LOCA	3.00 X 10 ⁻⁴
S2	Small LOCA	3.00 x 10 ⁻³
Tl	Loss of Offiste Power	6.09 X 10 ⁻²
T?	Transient with loss of PCS	1.62
T3A	Transient with PCS available	4.51
T3B	Loss of feedwater	7.60 x 10 `
'T3C	Inadvertent open relief valve	1.40 X 10 ⁻¹
TCW	Loss of CCCV	8.51 X 10 ⁻²
TIA	Loss of instrument	9.20 X 10 ⁻²
TSW	Loss of Service Water	1.00 X 10 ⁻³

ŝ

Function Equation	Function	Punction Probability
U101	High Pressure Core Spray	3.94 × 10 ⁻²
U102	High Pressure Core Spray	3.91 x 10 ⁻¹
U104	High Pressure Core Spray	3.73 X 10 ⁻²
U105	High Pressure Core Spray	3.73 X 10 ⁻²
U106	High Pressure Core Opray	3.73 x 10 ⁻²
U109	High Pressure Core Spray - SBO	1.05 x 10 ⁻¹
U110	High Pressure Core Spray	3.91 X 10 ⁻²
U111	High Pressure Core Spray - LOOP & MCC HVAC not modeled	1.04 X 10 ⁻¹
U112	High Pressure Core Spray - TCW	3.73 X 10 ⁻²
U113	High Pressure Core Spray - TCW	3.73 X 10 ⁻²
Ull4	High Pressure Core Spray - Flooding	3.73 X 10 ⁻²
U202	Reactor Core Isolation Cooling - LOOP	2.18 x 10 ⁻¹
U203	Reactor Core Isolation Cooling	1.74 x 10 ⁻¹
U204	Reactor Core Isolation Cooling	1.74×10^{-1}
U205	Reactor Core Isolation Cooling	1.74 × 10 ⁻¹

Function Unavailabilities

Punction Equation	Function Description	Function Probability
U207	Reactor Core Isolation Cooling - SBO	1.25 x 10 ⁻¹
U208	Reactor Core Isolation Cooling - Loss of SW	2.24 x 10 ⁻¹
U209	Reactor Core Isolation Cooling - Small LOCA	6.74 × 10 ⁻¹
U210	Reactor Core Isolation Cooling - Flooding	1.66 x 10 ⁻¹
U301	Condensate Feedwater	1.46 x 10 ⁻³
U302	Condensate Feedwater	9.53 X 10 ⁻³
U303	Condensate Feedwater	1.82 X 10 ⁻³
U304	Condensate freedwater	9.53 X 10 ⁻³
¹³⁰⁵	Condensate Feedwater	9.45 x 10 ⁻⁴
U306	Condensate Feedwater ATWS	1.45 X 10 ⁻²
U307	Condensate Fredwater AIWS	5.95 x 10 ⁻³
U308	Condensate Feedwater ATWS	1.09 X 10 ⁻²
U309	Condensate Teedwater Loss of Instrument Air	1.45 X 10 ⁻²
U310	Condensate Feedwater w/ MFP & RPV level 8 trip	9.53 X 10 ⁻³
V01	Low Pressure Makeup	5 3 X 10 ⁻³
V0.3	Low Pressure Makeup	2.93 X 10 ⁻³
V04	Low Pressure Makeup ATWS - LOOP	1.85 X 10 ⁻²
V05	Low Pressure Makeup A.MS w/Feedwater	5.06 x 10 ⁻³



8

Function Equation	Function Description	Function Probability
V06	Low Pressure Makeup ATWS w/Feedwater	5.06 x 10 ⁻³
V07	Low Pressure Makeup ATWS w/o Feedwater	5.06 x 10 ⁻³
V08	Low Pressure Makeup AIWS w/o Feedwater	5.06 X 10 ⁻³
V11	Low Pressure Makeup Station Blackout	8.55 X 10 ⁻²
V12	Low Pressure Makeup Station Blackout	2.28 x 10 ⁻²
V13	Low Pressure Makeup Station Blackout	1.77 X 10 ⁻¹
V15	Low Pressure Makeup LOOP & MCC HVAC not modeled	1.48×10^{-2}
V2 7	Low Pressure Makeup SBO & MCC HVAC not modeled	8.53 x 1.0 ⁻²
VA01	Alternate Low Pressure Makeup	1.10 x 10 ⁻¹
VA02	Alternate Low Pressure Makeup	3.10 x 10 ⁻¹
VA03	Alternate Low Pressure Makeup	1.11 X 10 ⁻¹
VA04	Alternate Low Pressure Makeup - Fire Water	2.65 X 10 ⁻¹
VA05	Alternate Low Pressure Makeup - Rx Feed Bstr Pmps	1.24 x 10 ⁻¹
VA06	Alternate low pressure makeup - after HPCS success	1.58 X 10 ⁻²
V507	Alternate low pressure makeup - SBO	8.54 x 10 ⁻²
VA08	Alternate low pressure Makeup - LAYOP	2.67 X 10 ⁻¹

Punction Equation	Function Description	Function Probability
VA09	Alternate low pressure makeup - LOOP	4.67 X 10 ⁻¹
VAIO	Alternate low pressure makeup - SBO	6.45 X 10 ⁻¹
VP11	Alternate low pressure makeup - LOOP	2.67 x 10 ⁻¹
VA12	Alternate low pressure makeup - LOOP	2.08 X 10 ⁻²
VA13	Alternate low pressure makeup	7.31 X 10 ⁻²
VA14	Alternate low pressure makeup	4.96 X 10 ⁻⁴
VA15	Alternate low pressure makeup	4.56 X 10 ⁻¹
VA16	Alternate low pressure makeup	2.58 X 10 ⁻¹
VA17	Alternate low pressure makeup	6.40 X 10 ⁻¹
VA18	Alternate low pressure makeup	7.32 X 10 ⁻¹
VA19	Alternate low pressure makeup	1.10 x 10 ⁻¹
VA20	Alternate low pressure makeup	2.56 X 10 ⁻¹
VP01	Provent vessel overfill ATWS	2.00 X 10 ⁻³
MOT	Long Term Containment Heat Removal w/RHR	6,94 X 10 ⁻³
ECW	Long Term Containment Heat Removal w/RHP Loss of offsite power	2.30 X 10 ⁻²

Function Equation	Function Description	Function Probability
W04	Long Term Containment Heat Removal w/RHR Loss of offsits power	2.37 X 10 ⁻²
W05	Long Term Cortainment Heat Removal : RHR	6.53 X 10 ⁻³
W06	Long Term Containment Heat Removal w/RHR	6.94 x 10 ⁻³
W07	Long Term Containment Heat Removal w/RHR	6.93 X 10 ⁻³
WC8	Long Term Containment Heat Removal w/RHR LOOP/ATWS	2.57 X 10 ⁻²
WIO	Long Term Containment Heat Removal w/RHR ATWS	7.17 X 10 ⁻³
W11	Long Term Containment Neat Removal w/RHR ATWS	7.17 × 10 ⁻³
W12	Long Term Containment Heat Removal w/RHR Station Blackout	1.96 x 10 ⁻²
W13	Long Term Containment Heat Removal w/RHR Station Elackout	8.96 X 10 ⁻²
W14	Long Term Containment Heat Removal w/RMR Station Blackout	2.69 x 10 ⁻²
W15	Long Term Containment Heat Removal w/RHR Station Blackout	1.96 X 10 ⁻²
W18	Long Term Containment Heat Removal with RHR	6.38 X 10 ⁻³
W19	Long Term Containment Heat Removal with RHR Station Blackout	2.69 X 10 ⁻²



Function Equation	Function	Function Probability
W20	Long Term Containment Heat Removal with RHR Station Blackout	2.69 X 10 ⁻²
W21	Long Term Containment Heat Removal with RHR Station Blackout	1.81 X 10 ⁻¹
W23	Long Term Containment Heat Removal with RHR SBO & MCC HTYC not modeled	2.18 x 10 ⁻²
%24	Long Term Containment Heat Removal with RHR SBO & MCC HVAC not modeled	8.94 X 10 ⁻²
W25	Long Term Containment Heat Removal with RHR SBO & MCC HVAC not modeled	9.05 X 10 ⁻¹
W26	Long Term Containment Heat Removal with RHR SBO & MCC HVAC not modeled	5.36 X 10 ⁻¹
W27	Long Term Contairment Heat Removal with RHR SBO & MCC HVAC not modeled	1.47 X 10 ⁻¹
W28	Long Term Containment Heat Removal with RKR Station Blackout	5.36 X 10 ⁻¹
W40	Long Term Containment Heat Removal with RHR Station Blackout	5.23 X 10 ⁻¹
W41	Long Term Containment Neat Removal with RHR SBO & MCC HVAC not modeled	1.27 X 10 ⁻¹
WC03	Containment Spray	4.23 X 10 ⁻²
WC04	Containment Spray	3.37 × 10 ⁻²
WC05	Containment spray	1.27 X 10 ⁻¹
WC06	Containment Spray	1.32 X 10 ⁻²

Function Equation	Function Description	Function Probability
WC07	Containment Spray	1.27 X 10 ⁻²
WC08	Containment Spray	4.60 X 10 ⁻²
WC10	Containment Spray	2.52 X 10 ⁻²
WC11	Containment Spray	2.62 x 10 ⁻²
WC13	Containment Spray	1.09 X 10 ⁻¹
WC16	Containment Spray	2.58 X 10 ⁻²
WC18	Containment Spray	1.27 X 10 ⁻²
WC20	Containment Spray	4.60 X 10 ⁻³
WC23	Containment Spray	2.81 X 10 ⁻²
WC24	Containment Spray	9.58 X 10 ⁻²
WC26	Containment Spray	5.55 x 10 ⁻¹
WC28	Containment Spray	5.55 X 10 ⁻¹
WC30	Containment Spray	4.45 X 10 ⁻¹
WC31	Containment Spray	7.22 X 10 ⁻¹
WC32	Containment Spray	4.93 X 10 ⁻²
WC33	Containment Spray	4.76 X 10 ⁻¹
WC34	Containment Spray	3.19 x 10 ⁻²
WC35	Containment Spray	2.92 X 10 ⁻¹
WC36	Containment Spray	2.92 X 10 ⁻¹
WC37	Containment Spray	4.93 X 10 ⁻¹
WC38	Containment Spray	5.29 X 10 ⁻¹
WC39	Containment Spray	1.09 x 10 ⁻¹
WC40	Containment Spray	6.42 x 10 ⁻¹
WC42	Containment Spray	3.55 X 10 ⁻¹

Function Equation	Function Description	Function Probability
WC43	Containment Sprav	4.07×10^{-1}
WC44	Containment Spray	5.70 x 10 ⁻¹
WC45	Containment Spray	8.85 X 10 ⁻²
WC46	Containment Spray	2.30 x 10 ⁻¹
WC47	Containment Spray	4.50 x 10 ⁻¹
WC48	Containment Spray	4.58 X 10 ⁻¹
WC49	Containment Spray	3.07 X 10 ⁻²
WC50	Containment Spray	1.32 x 10 ⁻²
WC51	Containment Spray	3.16 x 10 ⁻²
WC52	Containment Spray	3.67 X 10 ⁻²
WC53	Containment Spray	2.92 X 10 ⁻¹
WS01	Suppression Pool Cocling SBO & MCC HVAC not modeled	9.10 X 10 ⁻²
WS02	Suppression Pool Cooling LOOP & MCC HVAC not modeled	2.50 X 10 ⁻²
17503	Suppression Pool Cooling	2.53 X 10 ⁻²
WS04	Suppression Pool Cooling	2.60 X 10 ⁻²
WS05	Suppression Pool Cooling	7.88 X 10 ⁻³
WS06	Suppression Pool Ccoling	8.31 X 10 ⁻³
WS07	Suppression Pool Cooling	7.88 X 10 ⁻³
WS18	Suppression Pool Cooling	7.88 X 10 ⁻³
WS23	Suppression Pool Cooling	2.32 X 10 ⁻²
WS29	Suppression Por! Cooling	2.44 X 10 ⁻²
WS50	Suppression Pool Cooling	8.31 X 10 ⁻³



Punction	Function	Function
Equation	Description	Probability
X01	Emergency RPV	8.22 x 10 ⁻⁶
	Depressurization	0102 A 10
X02	Emergency RPV	2.39 X 10 ⁻⁵
	Depressurization	4123 X TU
X03	Emergency RPV	8.22 x 10 ⁻⁶
	Depressurization	
X05	Emergency R2V	5.03 x 10 ⁻³
	Depressurization - Aiws	0100 11 10
X06	Emergency RPV	7.01×10^{-3}
	Depressurization - ATWS	7.01 × 10
X07	Emergency RFV	1.40×10^{-2}
	Depressurization - ATWS	T'40 X TU
x08	Emergency FP:	7.01×10^{-3}
	Depressurization - ATWS	1.01 × 20
X09	Emergency RPV	1.40×10^{-2}
	Depressurization - ATWS	***** ** 20
X10	Emergency REV	2.52 x 10 ⁻⁵
	Depressurization - SBO	e.ve A 20
X13	Emergency RPV	2.52 X 10 ⁻⁵
	Depressurization - SBO	0100 A 40
X14	Emergency ROV	5.01 x 10 ⁻³
	Depressurization - ATWS	0.01 A 10
X15	Emergency REV	8.22 x 10 ⁻⁶
	Depressurization	0.000 A 40
	Loss of Inst Air	
X16	Emergency RPV	5.01×10^{-3}
	Depressurization - ATWS	
	Loss of Inst Air	
718	Emergency PFV	2.52 x 10 ⁻⁵
	Depressurization	
X19	Emergency RPV	2.52 x 10 ⁻⁵
	Depressurization - SBO	

Function Equation	Function	Function Probability
X20	Emergency RPV Depressurization - LOOP	2.39 X 10 ⁻⁵
X21	Emergency RPV Depressurization - SBO	2.52 X 10 ⁻⁵
X22	Emergency RFV Depressurization - LOOP	1.00 X 10 ⁻²
X23	Emergency RMV Depressurization - SBO	2.52 x 10 ⁻⁵
X24	Emergency RPV Depressurization - SBO	1.00 X 10 ⁻²
x25	Emergency R9V Depressurization - SBO	2.37 X 10 ⁻⁵
7.26	Emergency RPV Depressurization - SBO	5.26 X 10 ⁻⁵
X27	Emergency RPV Depressurization - ATWS	1.40×10^{-2}
X29	Emergency RPV Depressurization - SBO	1.03 X 10 ⁻³
X 30	Emergency RPV Depressurization ~ SBO	2.52 X 10 ⁻⁵
X31	Emergency RPV Depressurization - SBO	1.02 X 10 ⁻³
X32	Emergency RPV Depressurization - SBO	1.00 X 10 ⁻²
X33	Emergency ROV Dupressurization - SBO	1.00 × 10 ⁻¹
X34	Emergency RIV Depressurization - SBO	J.24 X 10 ⁻⁴
XP01	ADS inhibit - ATWS	3.60 x 10 ⁻²
XP02	ADS inhibit - ATWS	3.64 X 10 ⁻²
XP03	ADS inhibit - ATWS	3.79 X 10 ⁻³



Function Unavailabil ties

Function Equation	Function	1 notion Probability
XP04	ADS inhibit - ATWS	3.64 × 10 ⁻²
XP05	ADS inhibit - ATWS	3.60
Y01	Long Term Containment Heat Removal w, Venting	1.08 × 10 ⁻⁴
¥03	Long Term Containment Heat Removal w/Venting LOOP	1.36 × 10 ⁻³
¥04	Long Term Containment Heat Removal w/Venting LOCF	1.36 X 10 ⁻³
205	Long Term Containment Heat Removal w/Venting	1.08 x 10 ⁻⁴
¥06	Long Term Containment Heat Removal w/Venting	1.08 X 10 ⁻⁴
¥07	Long Term Containment Heat Removal w/Venting	1.08 x 10 ⁻⁴
XOU	Long Term Containment Heat Removal w/Venting ATWS	1.82 x 10 ⁻²
¥10	Long Term Containment Heat Removal w/Venting ATWS	6.27 x 10 ⁻⁴
¥11	Long Term Containment Heat Removal w/Venting AIWS	6.27 × 10 ⁻⁴
¥12	Long Term Containment Heat Removal w/Venting ATW3	6.27 x 10 ⁻⁴
¥13	'ong Term Containment neat Removal w/Venting Station Blackout	1.24 x 10 ⁻²
¥14	Long Term Containment Heat Removal w/Venting Station Blackout	8.24 x 10 ⁻²
¥15	Long Term Containment Heat Removal w/Venting Station Blackout	1.96 X 10 ⁻²

Function Unavailabilities

Punction Equation	Function Description	Function Probability
¥16	Long Term Containment Heat Remova! w/Venting Station Blackout	1.23 X 10 ⁻²
¥17	Long Term Containment Heat Removal w/Venting Station Blackout	7.83 x 2.0 ⁻²
Y18	Long Term Containment Heat Removal w/Venting Station Blackout	1.96 X 10 ⁻²
¥19	Long Term Containment Heat Removal w/Venting	7.70 × 10 ⁻⁵
¥20	Long Term Containment Heat Removal w/Vonting Station Blackout	1.97 x 10 ²
¥21	Long Term containment Feat Removal w/venting Station Blackout	1.74 x 10 ⁻¹
¥22	Long Term Containment Heat Removal w/Venting SBO	1.51 x 10 ⁻⁷
¥23	Long Term Containment Heat Removal w/Venting SBO	8.23 X 10 ⁻²
¥24	Long Term Contairment Heat Ramoval w/Venting SBO	8.58 X 10 ⁻¹
¥25	Long Term Containment Heat Removal w/Venting SBO	5.29 x 10 ⁻¹
*	Long Term Contairment Heat Removal w/Venting SBO	1.40 x 10 ⁻¹
¥27	Long Term Containment Heat Removal w/Vonting SBO	5.29 x 10 ⁻¹
¥28	Long term Cuntainment Heat Reroval w Venting SBO	4.19 X 10 ⁻¹
б.Л	Long Term Containment Heat Removal w/Venting SBO	6.96 X 10 ⁻¹

Function Unavailabilities

Function Equation	Function Description	Function Probability
Х30	Long Term Containment Heat Pemoval v/Venting SBO	2.30 x 10 ⁻²
¥31	Long term Containment Heat Removal w/Venting SBO	4.50 X 10 ⁻¹
¥32	Long Term Containment Heat Removal w/Venting SBO	5.60 X 10 ⁻³
¥34	Long Term Containment Heat Removal w/Venting SBO	2.66 X 10 ⁻¹
¥35	Long Term Containment Heat Removal w/Venting SBO	2.66 X 10 ⁻¹
¥36	Long Term Containment Heat Removal w/Venting SBO	4.6. 10-2
¥37	Long Term Containment Neat Removal w/Venting SBO	5.03 x 10 ⁻¹
¥38	Long Term Containment Heat Removal w/Venting SBO	8.38 X 10 ⁻³
¥39	Long Term Containment Heat Removal w/Venting SBO	6.16 X 10 ⁻¹
¥40	Long term Containment Heat Removal w/Venting SBO	1.20 X 10 ⁻¹
¥41	Long term Containment Heat Removal w/Venting	3.29 X 10 ⁻¹
¥42	Long term Containment Heat Removal w/Venting	3.81 X 10 ⁻¹
¥43	Long term Containment Heat Removal w/Venting	5.44 x 10 ⁻¹
¥46	Long term Containment Heat Removal w/Venting	6.23 X 10 ⁻²
¥47	Long term Containment Heat Removel w/Venting	2.04 % 10 ⁻¹
¥48	Long term Containment Neat Removal W/Venting	5.02 X 10 ⁻³

Function Univailabilities

Function Equation	Function Description	Function Probability
¥49	Long term Containment Heat Removal w/Venting	5.97 X 10 ⁻¹
¥51	Long term Containment Heat Removal w/Venting	1.10 X 10 ⁻²
¥52	Long term Containment Heat Removal w/Venting	4.33 X 10 ⁻¹
¥53	Long term Containment Heat Removal w/Venting	4.32 X 10 ⁻¹
¥54	Long term Containment Heat Removal w/Venting	5.85 X 10 ⁻³
¥56	Long term Containment Heat Removal w/Venting	2.66 X 10 ⁻¹

Table 3.3.7-1


Flood Zone	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Frequency (1/yr)	Conditional Core Damage Probability	Core Damage Frequency (1/yr)	Discussion/Comments
1	Turbine Building, Heater Bay, Turbine Power Complex	Feedwater recovery with motor feedwater pump, condensate transfer system	Automatic 3CRAM	T2 - Loss of PCS	6E-3	3.86-03	2E-5	Result is greater than 3E-07/yr; more detailed evaluation required
1A	Steam Tunnel	Feedwater recovery with motor feedwater pump, RCIC	Automatic SCRAM	T2 - Loss of PCS	6E-4	5.66-03	3E-6	Result is greater than 3E-07/yr; more detailed evaluation required
2	Aux. Bldg. HPCS Room	HECS	Manual SCR4M	T3A - PCS Available	1.4E-3	9.78-05	1E-7	Result is less than 3E-07/yr; no further evaluation required
3	Aux. Bldg. RHR B Room	RHR train B; train C supply for low pressure makeup	Manual SCRAM	T3A - PCS Available	1.48-3	1.62-05	2E-8	Result is less than 3E-07/yr; no further evaluation required
4	Aux. Bldg. RHR C Room	RHR train C supply for low pressure makeup	Automatic SCRAM	T3A - PCS Available	1.4E-3	1.68-05	2E-8	Result is less than 3E-07/yr; no further evaluation required

RESULTS OF INTERNAL FLOODING LEVEL ONE ANALYSIS FOR PERRY NUCLEAR POWER PLANT









RESULTS OF INTERNAL FLOODING LEVEL ONE ANALYSIS FOR PERRY NUCLEAR FORER PLANT

Flood Zone	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Frequency (1/yr)	Conditional Core Danage Probability	Core Damage Frequency (1/yr)	Discussion/Comments
5	Aux, Bldg. RCIC Room	RCIC	Manual SCRAM	T3A - PCS Available	1.4E-3	1.7E-05	2E-8	Result is less than 3E-07/yr; no further evaluation required
6	Aux. Bldg. RHR A Room	RCIC, LPCI train A, condensate transfer train A, RHR train A supply to suppression pool cooling and containment spray, and RHR train A supply for long term containment heat removal	Maratal SCRAM	T3A - PCS Available	1.48-3	1.7E-05	22-8	Result is less than 32-07/yr; no further evaluation required
7	Aux. Bldg. LPCS Room	LPCS	Marrell SCRAM	T3A - PCS Available	1.4E-3	1.42-05	2E-8	Result is less than 3E-07/yr; no further evaluation required
8	Aux. Bldg. Corridors	RCIC, HPCS, LPCS, RHR A, RHR B, RHR C, suppres- sion pool cooling and containment spcmy	Manual SCRAM	T3A - PCS Available	1.1E-3	2.1E-03	2E-6	Result is greater than 3E-07/yr; more detailed evaluation required

.

Accorned Initiating Screening Conditional Core Flood Zone Accident Mitigating Initial "looding Damage Discussion/Comments Flood Event Core Systems Disabled 7one Description Plant Type Frequency Damage Frequency (1/yr) Probability (1/yr) Response 9 Intermediate None Maratal T3A - PCS 1.12-3 1.08-05 1E-8 Regult is less Building Available than 3E-07/yr; no SCRAM Elevation 574.8 further evaluation required Result is less 10 Intermediate Nono Automatic T3A - PCS TE-b 1.08-05 7E-9 Building Available than 3E-07/yr: no SCRAM further evaluation CRD Pumo Room Elevation 574.8 required Drvwell. Design features 11 None preclude losses 12 Design features None Containment preclude losses 13 Control Complex HPCS lost after 10 2.6E-3 3.02-01 RE-4 Result is greater Automatic TIA - LCTT than E-07/yr; more Elevation 574.8 hours; low pressure SCRAM of Inst. Air detailed evaluation makeup, PHR train A and P supply for long term required containment heat removal

RESILTS OF INTERNAL FLOODING LEVEL OFS ANALYSIS FOR PERRY NUCLEAR POWER PLANT











RESULTS OF INTERNAL FLOODING LEVEL ONE ANALYSIS FOR PERRY NGCLEAR POWER PLANT

Flood Zime	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Frequency (1/yr)	Conditional Core Damage Probability	Core Damage Frequency (1/yr)	Discussion/Comments
13 Alter- nate Run	Control Complex Elevation 574.8	Same as for above except suppression pool cooling also unavailable	Automatic SCRAM	TIA - Loss of Inst. Air	2.62-3	1.06+00	32−3	Further evaluation is required to determine the like- lihood for failure of suppression pool cooling due to floods in zone 13
14	Radwaste Building	None	-		-		-	No further consid- eration required except that zone 14 may serve as a propagation pathway between flood zones
15	Intermediate Building Elevation 599	Train A of instrument air supply for ADS unavailable	Automatic SCRAM	TIA - Loss of PCS	7.5E-4	6.58-05	5£-8	Result is less than 3E-07/yr; no further evaluation required

RESULTS OF INTERNAL FLOODING LEVEL ONE ANALYSIS FOR PERRY NUCLEAR POWER FLANT

Flood Zone	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Frequency (1/yr)	Conditional Core Damage Probability	Core Damage Frequency (1/yr)	Discussion/Comments
15 to 22	Intermediate Building Elevation 599 and 620.5	Train A of instrument air supply for ADS unavailable; FPCC vent path for long term containment beat removal with vent	Automatic SCRAM	T2 - Loss of PCS	7.56-4	6.5E-05	SE-8	Result is less than 32-07/yr; no further evaluation required
16	Aux. Bldg. Corridors Elevation 599	RCIC, low pressure makeup, RHR train A and B supply for long term containment heat removal and long term contain- ment heat removal with vent	Automatic SORAM	T2 - Loss of F/S	7.5E-4	6.4E-03	SE-6	Result is greater than 3F 07/yr; more detailed evaluation required
17	Control Complex Elevation 599	FPOC path for long term containment heat removal with vent, HPCS lost after 10 hours	Automatic SCRAM	TIA - Loss of Inst. Air	1.2E-3	1.86-02	2E-5	Result is greater than 32-07/yr; more detailed evaluation required



RESULTS OF INTERNAL FLOODING LEVEL ONE ANALYSIS FOR PERRY NUCLEAR POWER PLANT

Ficod Zone	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Prequency (1/yr)	Conditional Core Damage Probability	Core Damage Frequency (1/yr)	Discussion/Comments
18, 19, 20	Diesel Generator Buildings	Emergency diesel generators	Controlled Shutdown					Flooding of the diesel generator buildings results in no other dis- abling of accident mitigation systems; loss of only the diesel generators results in a con- trolled shutdown and is therefore not considered further; the like- lihood of a flood occurring in the diesel generator buildings (and loss of all emergency diesel power) with a coincident loss of offsite power (and therefore station blackout) is insignificant

RESULTS OF INTERNAL PLOODING LEVEL ONE ANALYSIS FOR FERRY MICLEAR POWER PLANT

Flood Zone	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Tritial Plant Response	Initiating Event Type	Screening Flooding Prequency (1/yr)	Conditional Core Damage Probability	Core Damage Frequency (1/yr)	Discussion/Connents
21	Control Complex Switchges: Rooms Elevation 620.5	Emergency Switchgwar	Automatic SCRAM	T3A - PCS Available	1E-5/yr (divisions 1 and 2); SE-6/yr (divisions 1, 2 & 3)			
22	Intermediate Building West Side Elevation 620.5	FPOC vent path for long term containment heat removal with vent	Automatic SCRAM	13A - PCS Available	6E-4	1./E-05	6E-Y	Result is less than 3E-07/yr; no further evaluation required
23	Aux. Bldg. Corridors West Side Elevation 620.5	HPCS	Automatic SCRAM	T3A - PCS Available	3E-4	1.0E-04	3E-8	Result is less than 3E-07/yr; no further evaluation required
23 to 22	Aux. Bldg. Corridor West Side to Intermediate Building West Side Elevation 620.5	HPCS; FPCC vent path for long term contain- ment heat removal with vent	Automatic SCR.M	T3A - PCS Available	3E-4	1.0E-04	38-8	Result is less than 3E-07/yr; no further evaluation required



RESULTS OF INTERNAL FLOODING LEVEL ONE MULYSIS FOR PERRY NUCLEAR POWER PLANT

Flood Z <i>o</i> ne	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Frequency (1/yr)	Conditional Core Damage Probability	Core Damage Frequency (1/yr)	Discussion/Comments
24	Aux. Bldg. Corridors East Side Elevation 620.5	B train of P57 lost for emergency RPV depressurization	Automatic SCRAM	T3A - RS Available	3E-4	1.06-05	38-9	Result is less than 3E-07/yr; no further evaluation required
25	Intermediate Building East Side Fuel Bandling Area Elevation 620.5	None	Maratal SCRAM	T3A - PCS Available	3E-4	1.06-05	36-9	Result is less than 3E-07/yr; no further evaluation required
26	Intermediate Building Elevation 654.5	None	Manual SCRAM	T2 - Loss of PCS	1.1E-4	6.62-05	7E-9	Result is less than 3E-07/yr; no further evaluation required
27, 28, 29	Control Complex Unit 1, Div. 1/2 Battery Room/switchgear and cable spreading room Elevation 638.5	dc power supplied to division 1 and 2 switchgear	SCRAM					More detailed evaluation required

Flood Zone	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Prequency (1/yr)	Conditional Core Damage Probability	Core Demage Frequency (1/yr)	Discussion/Comments
30, 30A, 31, 31A	Control Complex Unit 1 Control Boom, control complex corridor, Unit 1 and Unit 2 HVAC rooms Elevation 679.5 and 654.5	Control room and potentially control complex HVAC	SCRAM					More detailed evaluation required
32	Intermediate Building Elevation 682.5	None		-	-		-	No further evaluation required
33	Emergency Service Water Pumphouse	Emergency Service Water System	Manual SCRAM	T3A - PCS Available	5E-3 (assumed)	1.7E-05	95-8	The result is less than the 3E-07/yr screening criterion and therefore no further evaluation is 1. Tuired

RESERTS OF INTERNAL PLOOD'NG LEVEL OFE ANALYSIS FOR PERFY NUCLEAR POWER PLANT





RESELTS OF INTERNAL PLOCEDING LEVEL ONE ANALYSIS FOR PERRY NUCLEAR POWER PLANT

Flood Zone	Flood Zone Description	Accident Mitigating Systems Disabled	Assumed Initial Plant Response	Initiating Event Type	Screening Flooding Frequency (1/yr)	Conditional Core Damage Probability	Core Demage Frequency (1/yr)	Discussion/Comments
33 Alter- nate Run	Emergency Service Water Pumphouse	Emergency Service Water System and RMS trains A, B, and C	' nal XRAM	T3A - RCS Available	SE-3 (.issumed)	2.58-05	1E-7	The result is less than the 3E-07/yr screening criterion and therefore no further evaluation is required
34	Service Water Pumphouse	Service water system	Automatic SCRAM	TSW Loss of Service Water	SE-3 (assumed)	6.0£-03	38-5	Result is greater than 3E-07/yr; more detailed evaluation required
35	Off-G Building	None						No further consideration required except that zone 35 may serve as a propagation pathway between flood zones

1

Table 3.3.7-2

Perry Internal Flooding Analysis Conditional Core Damage Probabilities

Flood State	Zones/ Areas Affected	Accident Sequence Assumed	Disabled	onditional Core Damage ability
13B	Zone 13 or Zone 13 & 17	TIA (modified for fldng)	Low pressure make-up, RHR long term cntnmnt heat removal, instrument air	1.5E-3
16A	Zone 16	ТЗА	RCIC	2.6E-9
168	Zone 16	т2	RCIC	6.7E-7
16C	Zones 16 & 8	T3A	RCIC, Low pressure make-up	8.8E-6
16D	Zones 16 & 8	т2	RCIC, ' pressure make-up	3.7E-5
16E	Zones 16, 8 & RHR pmp rm A	АЕТ	RCIC, Low pressure make-up, & Cntnmnt Spray A	2.1E-5
16F	Zones 16, 8 & RHR pmp rm A	T2	RCIC, Low pressure make-up, & Cninmnt Spray A	8.6E-5
16G	Zones 16, 8, 13 & RHR pmp rm A	T2	RCIC, Low pressure make-up, RHR long term cntnmnt heat removal, instrument air, & cntnmnt &pray A	8.6E-5
* 5H	Zone 16	T2	RCIC, Low pressure make-up	3.7E-5
161	Zone 16	T2	RCIC, Low pressure make-up	8.8E-6
144	Zone 1A	T2	RCIC	6.7E-7
1AB	Zone 1A	Т2	Peedwater recovery w/ motor feed pump	4.9E-:
1AC	Zone 1	T2	RCIC and Cndnst Transfer	3.4E-5
FIA	Zone 1	Τ2	Cndnst Transfer, feedwater recovery w/ motor feed pmp	5.7E-5
F1B	Zone 1	T2	Feedvaler recovery w/ motor feed pump. cndnst transfer, RCIC, low pressure make-up, & RHR long term cntnmnt hea removal	3.7E-2 t

Perry Internal Flooding Analysis Conditional Core Damage Probabilities

Flood State	Areas	Accident Sequence Assumed	Disabled C Da	itional ore mage ability
FIC	Zone 1	T2	Feedwater recover w/ motor feed pump	4.9E-6
F1D	Zone 1	Τ2	Feedwater recover w/ motor feed pump, RCIC, Low pressure make-up, & RHR long term cntnmnt heat removal	4.3E-3
F1E	Zone 1	<u>*2</u>	Feedwater recover w/ motor feed pump 2 RCIC	5.6E-6
F8A	Zone 8	A61	RCIC, Low pressure make-up alternate low pressure make-up	6.8E-5
F8B	Zone 8	TL.	RCIC & Low pressure make-up	9.2E-3
T2F	T2 accident seq induced by internal flood		None	1.0E-6
T3A	T3A only	T3A	None	1.0E-9
TIAF	Loss of inst air only	AIT	None	1.0F-5

Table 3.3.7-3

Results of Detailed Flooding Analysis

Flood zone & Flood magnitude	Core Damage Frequency	Zone Percent	Sub-Total
13 mod	4.5E-7	29	
13 small	2.7E-7	18	
13 severe	1.6E-7	10	57
17 mod	1.6E-7	10	
17 small	1.0E-7	6	
17 severe	5.6E-8	4	20
TPC N71E	4.4E-8	3	
TPC N71W	4.4E-8	3	6
1 mod	1.1E8	1	
1 severe	7.2E-9	< 1	< 1
1 small	8.0E-12	< 1	< 1
1 Exp Joint Sev Leak	9.9E-9	1	1
1 Exp Joint Smell Lea	k 1.6E-7	10	10
1A	1.0E-9	10	10
В	3.0E-8	2	2
16	1.2E-8	1	1
Total	1.5E-6		

Summary of Core Damage Frequency 1 Initiating Event

	Core Dersse Freq	Percent of (CDF
Loss of Offei	te Fover		
T1 R	1.80 X 10 ⁻⁷ 7.19 X 10 ⁻⁷	1.5	(Loss of Offsite Power) (Loss of Offsite Power and no Offsite Power Recovery at 3 hr)
U	4.14 X 10 ⁻⁷	3.6	(Loss of Offsite Power w/no
T1P1	7.62 X 10 ⁻⁸	0.7	HPCS or RCIC) (Loss of Offsite Pover and 1 SORV)
TIPIU	1.53 X 10 ⁻⁸	0.1	(Loss of Offsite Power and 1
T1P2	3.89 X 10 ⁻⁸	0.3	SORV w/no HPCS or RCIC) (Loss of Offsite Power and 2 SORVs)
Total	1.44×10^{-6}	12.4	
Station Black	<u>cout</u>		
B BP1 BP2	$\begin{array}{c} 2.11 \times 10^{-6} \\ 8.36 \times 10^{-8} \\ 5.91 \times 10^{-8} \end{array}$	18.1 0.7 0.5	(Station Blackout) (Station Blackout and 1 SORV) (Station Blackout and 2 SORVs)
Total	2.25 X 10 ⁻⁶	19.3	
fransients			
T3A T3AP1 T3AP2 T3B T3C T2 T2P1 T2P2 T1A T1AP1 T1AP1 T1AP2 T3W TSWP1 TSWP2	$< 10^{-8}$ $< 10^{-8}$ $< 10^{-8}$ $< 10^{-8}$ $< 10^{-8}$ $< 10^{-8}$ 1.38×10^{-7} 1.64×10^{-6} 2.47×10^{-8} $< 10^{-8}$ <	$\begin{array}{c} 0.0\\ 0.0\\ 0.1\\ 0.0\\ 1.2\\ 14.1\\ 0.2\\ 0.0\\ 0.0\\ 0.0\\ 0.6\\ 0.0\\ 0.0\\ 0.0\\ 0.0$	<pre>(Transient w/ PCS) (Loss of feedvater) (Inadvertent open SRV) (Transient w/o PCS) (Loss of instrument air) (Loss of service vater)</pre>
Total	2.90 X 10 ⁻⁶	25.0	

6

Table	3.4.	1-1	cont	:tnu	led

	Core Damage Freq	Percent of CDF	
LOCAS			
A \$1 \$2	2.11 X 10 ⁻⁷ 6.18 X 10 ⁻⁸ 3.34 X 10 ⁻⁸	1.8 (Large LOCA) 0.5 (Intermediate LOC 0.3 (Small LOCA)	A)
Total	3.06 × 10 ⁻⁷	2.6	
ATVS			
T1-C T3A-C T3B-C T3C-C T2-C TIAC	$\begin{array}{c} 3.61 \times 10^{-8} \\ < 10^{-8} \\ 5.42 \times 10^{-7} \\ 9.38 \times 10^{-8} \\ 4.02 \times 10^{-6} \\ 4.33 \times 10^{-8} \end{array}$	0.3 0.1 4.6 0.8 34.5 0.4	
Total	4.74 X 10 ⁻⁶	40.7	

Total Core Damage Frequency (internal initiators) 1.17 X 10^{-5}

Sequence Core Damage Frequencies Grouped by Initiator

T	-C Sum =	4.02E-006	34.5%	
	T2-CS30	2.27E-006	19.5%	T2-C-U3-X'
	T2-CS20	6.25E-007	5.4%	T2-C-Lc-C1
	T2-C528	3.12E-007	2.7%	T2-C-U3-X
	T2-CS11	2.90E-007	2.5%	T2-C-C1
	T2-CS12	2.37E-007	2.0%	T2-C-X'
			1.4%	T2-C-V
	T2-CS06	1.585-007		
	T2-CS05	1.25E-007	1.1%	T'2-C-V'
в	Sum .	2.11E-006	18.1%	
10	B\$24	7.71E-007	6.6%	B-U1-Va-R
	BS34	5.26E-007	4.5%	B-U1-U2-R-Va1
	BS17	3.362-007	2.9%	B-U1-R
	BSO7	1.60E-007	1.4%	B-R-Y-CV
	BS12	1.04E-007	0.9%	B-HI-R
	BS22	5.962-008	0.5%	B-U1-1'a-V
	B\$35	5.15E-008	0.4%	B-U1-U2-R-X
	BS33	5.11E-008	0.4%	B-U1-U2-R-Y-CV
	BS29	3.37E-008	0.3%	BU1U2Va1
	BS30	1.81E-008	0.2%	B-U1-U2-X
T2		1.64E-005	14.1%	
	T2S04	1.62E-006	13.9%	T2-W-Y-CV
	T2S09	1.90E-008	0.2%	T2-U3-U2-W-Y-CV
	T2S18	9.56E-009	0.1%	T2-U3-U2-U1-V-V
-	A Sum -	1.01E-006	8.7%	
2.4		7.53E-007	6.5%	TIA-U2-U1-V-Va
		2.57E-007	2.2%	TIA-U2-W-Y-CV
	TIAS05	2+2/6-00/	de o de la	12A-02-W-1-0V
R	Sum =	7.19E-007	6.2%	
	R\$20	6.04E-007	5.2%	R-Ws-V-Va
	RS19	8.73E-008	0.7%	R-Ws-V-Cv
	RS10	2.75E-008	0.2%	R-Ws-W-Y-Cv
	ROID	E1120-000		
T3	B-C Sum -=	5.42E-007	4.6%	
	T3B-CS29	2.76E-007	2.4%	T3B-C-U3-X'
	T3B-CS19	7.60E-008	0.7%	T3B-C-Q-Lc-C1
	T3B-CS09	5.32E-008	0.5%	T3B-C-Q-X
	T3B-C527	3.80E-008	0.3%	T3B-C-U3-X
	T3B-CS10	3.452-008	0.3%	T3B-C-Q-C1
			0.2%	T3B-C-Q-X'
	T3B-CS11	2.88E-008		T3B-C-Q-V
	T3B-C508	1.78E-008	0.2%	and the second se
	T3B-CS07	1.52E-008	0.1%	T3B-C-Q-V'
U	Sum =	4.14E-007	3.6%	
2	US29	3.34E-007	2.9%	U-R1-V-Va
		5.99E-008	0.5%	U-V-Va
	US12			U-R1-V-W-Y-Cv
	US28	1.63E-008	0.1%	D = W T = A = R = T = D A



alla

Table 3.4.1-2 continued

A Sum =	2.11E-007	1.8%	
			2 112 12
ASU9	2.10E-007	1.8%	A-U1-V
T1 Sum =	1.80E-007	1.5%	
T1508	1.47E-007	1.3%	T1-R2-V-Y-Cv
T1S04	1.94E-008	0.2%	TI-W-Y-CV
T1535	1.33E-008	0.1%	T1-U1-Ws-V-Va
11000	1.235-000	U. LA	77-07-89-4-48
T3C Sum M	1.38E-007	1.2%	
T3C504	1.38E-007	1.2%	T3C-W-Y-CV
100004	11000-001	3.1.6.70	100-4-1-01
T3C-C Sum #	9.38E-008	0.8%	
T3C-C527	5.49E-008	0.5%	'T3C-C-U3-X'
T3C-CS17		0.1%	T3C-C-Lc-C1
T3C-CS07	9.81E-009	0.12	T3C-C-X
	n n/n 000	0.74	
BP1 Sum =		0.7%	
BP1527	4.85E-008	0.4%	BP1-UA-U2
BP1S17	1.69E-008	0.1%	BP1-U1-V
BP1526	1.13E-008	0.1%	BP1-U1-Va-R
T1P1 Sum .	7.628-008	0.7%	
			105 855 115 11- 17
T1P1531	7.24E-008	0.6%	T1P1-U1-Ws-V
TSV Sum =	6.68E-008	0.6%	
			MARY 110 111 14
TSWS10	5.49E-008	0.5%	TSW-U2-U1-V
TSVS14	1.002-008	0.1%	TSW-C
P1 0	2 10P (10P	0.54	
S1 Sum m		0.5%	
S1S13	5.85E-008	0.5%	S1-U1-V-Va
BP2 Sum =	5.91E-008	0.5%	
BP2S13	5.91E-003	0.5%	BP2-U1
TIAC Sum =	4 338 000	0.4%	
			and a set
TIACS09	3.31E-008	0.3%	TIAC-X'
T1P2 Sum =	3 807 000	0.3%	
T1P2S11	2.39E-008	0.2%	T1P2-U1-V
T1P2\$04	1.49E-008	0.1%	T1P2-W-Y-CV
-			
T1-C Sum =	3.61E-008	0.3%	
T1-CS09	2.19E-008	0.2%	T1-C-X'
	8.44E-009		
11-0500	0.445-009	0.14	11-0-01
S2 Sum =	3.24E-008	0.3%	
	3.00E-008	0.3%	\$2-C
52520	3.005-008	0.24	32-4
T2P1 Sum =	2.47E-008	0.2%	
	2.46E-008	0.2%	T2P1-V-Y-CV
1211504	2:405-000	0.64	ITLY-M-I-CA
TIPIU Sum .	1.53E-008	0.1%	
TIPIU Sum *		0.1%	T1D111 P1 V
	1.53E-008 1 37E-008	0.1%	T1P1U-R1-V



Sequence within the Upper 95% of Total Core Damage

T2-CS30	2.278-006	19.5%	T2-C-U3-X'
T2504	1.62E-006	13.9%	T2-W-Y-CV
BS24	7.71E-007	6.6%	D-U1-Va-R
TIAS14	7.53E-007	6.5%	TIA-U2-U1-V-Va
T2-CS20	6.25E-007	5.4%	T2-C-Le-C1
R\$20	6.048-007	5.22	R-Ws-V-Va
BS34	5.26E-007	4.5%	B-U1-U2-R-Val
8S17		2.9%	B-U1-R
US2.9	3.34E-007	2.9%	UR1Va
T2-CS28	3.12E-007	2.7%	T2-C-U3-X
T2-CS11	2.90E-007	2.5%	T2-C-C1
T3B-C529	2.765-007	2.4%	T3B-C-U3-X'
TIASOS	2.57E-007	2.2%	TIA-U2-V-Y-CV
T2-CS12	2.37E-007	2.0%	T2-C-X'
AS09	2.10E-007	1.8%	A-111-V
BS07	1.60E-007		B-R-Y-CV
		1.6%	T2-C-V
T1508	1.47E-007	1.3%	T1-R2-V-Y-CV
T3CSU4	and the loss of the second second	and the second	T3C-W-Y-CV
T2-CS05	1.25E-007	1.1%	T2-C-V'
BS12	1.04E-007	0.9%	B-HI-R
R519		0.7%	R-WS-V-CV
T3B-C519		0.7%	T3B-C-Q-Lc-C1
T1P1S31	7.248-008	0.6%	71P1-U1-Vs-V
US12	5.998-008	0.5%	U-V-Va
		0.5%	B-U1-Va-V
and the second second		0.5%	BP2-U1
31513	5.85E-008	0.5%	S1-U1-V-Va
TSVS10	5.49E-008	0.5%	TSV-U2-U1-V
T3CCS27	5.49E-008	0.5%	T3C-C-U3-X'
		0.5%	T3B-C-Q-X
BS35	5.15E-008	0.4%	B-U1-U2-R-X
BS33	5.11E-008	0.4%	B-U1-U2-R-Y-CV
BP1527	4.85E-008	0.4%	BP1-U1-U2
T3B-C527		0.3%	T3B-C-U3-X
T3B-CS10		0.3%	T3B-C-0-C1
BS29		0.3%	B-U1-U2-Va1
TIACS09	3.31E-008	0.3%	TIAC-X'
\$2\$20	3.31E-008 3.00E-008	0.3%	\$2-C
	2.88E-008	0.2%	
RS10		0.2%	
110 2 0	WAY WAY - WORK	A	

Sequenc	es Leading	to Cont	ainment Failure	Prior to	Core	Damage
T2S04 TIAS05 BS07 T1S08 T3CS04 RS19 BS33 RS10 T2P1S04 T1S04 T1S04 T2S09 US28 T1P2S04 Event V	1.62E-006 2.57E-007 1.605-007 1.47E-007 1.38E-007 8.73E-008 5.11E-008 2.75E-008 2.46E-008 1.94E-008 1.94E-008 1.63E-008 1.49E-008 2.10E-008	$13.9\% \\ 2.2\% \\ 1.4\% \\ 1.3\% \\ 1.2\% \\ 0.7\% \\ 0.4\% \\ 0.2\% \\ 0.2\% \\ 0.2\% \\ 0.1\% \\$	$\begin{array}{c} T2 = V - Y - Cv \\ TIA - U2 = V - Y - Cv \\ B - R - Y - Cv \\ T1 - R2 - V - Y - Cv \\ T3C - V - Y - Cv \\ R - vs - V - Cv \\ B - U1 - U2 - R - Y - Cv \\ R - Vs - V - Cv \\ T2P1 - V - Y - Cv \\ T1 - V - Y - V - V - V - V \\ T1 - V - Y - V - V \\ T1 - V - Y - V - V - V \\ T1 - V - Y - V - V - V \\ T1 - V - Y - V - V - V - V - V \\ T1 - V - Y - V - V - V - V \\ T1 - V - V - V - V - V - V \\ T1 - V - V - V - V - V - V - V \\ T1 - V - V - V - V - V - V - V - V \\ T1 - V - V - V - V - V - V - V - V \\ T1 - V - V - V - V - V - V - V - V - V - $			
Total	2.58E-006	22%				

Sequences Below 10⁻⁷ Because of Human Interaction Reliability

	Base Case	HI value rasied to 1.0
T3BCS19	7.60E-8	7.60E-6
US12	6.00E-8	3.50E-7
BS22	6.00E-8	3.20E-7
\$1513	5.85E-B	8.15E7
TJC-CS27	5.49E-8	
T3B-CS09	E 35m 0	1.40E-6
	D. 32E-0	7.60E-6
BS33	5.11E-8	1.200-0
BP1S27	4.055-8	5.09E-7
T3B-CS27	3.80E8	7.00E-0
T3B-CS10	3.45E-8	7.63E-6
BS29	3.37E-8	5.52E-6
TIACS09	3.31E8	9.205-7
T3B-CS11	2.88E-8	7.60E-6
RS10	2.75E-8	1.28E-6 5.09E-7 7.60E-6 7.63E-6 5.52E-6 9.20E-7 7.60E-6 3.72E-8 4.67E-3
T2P1S04	2.46E-8	19 x 10 / 20 ^m 0
T1-CS09	2.75E-8 2.46E-8 2.19E-8	NAVPN 1
T3B-CS08	1.78E-8	7.61E-6
US28	1.63E-8	2.02E-8
T3BCS07	1.52E-8	7.60E-6
T1P2S04	2.46E-8 2.19E-8 1.78E-8 1.63E-8 1.52E-8 1.49E-8 1.40E-8 1.33E-8	2.49E-8
T3CCS17	1.40E-8	1.40E-6
T1S35	1.33E-8	5.67E-7
BP1S26	1.13E-8	6.11E-8
T3C-CS07	9.81E-9	1.40E-6
T2S18	9.56E-9	9.56E8
T1CS08	8.44E-9	6.17E-7
T3AP2S04	6.28E-9	1.30E-3
T3C-CS09	5.31E-9	1.40E-6
T3C-CS08	4.69E-9	1.40E-6
		9.20E-7
T3BS12	4 48E-9	4.48E-8
TIAP1S14	4.01E-9	3.35E-8
US30	4.60E-9 4.48E-9 4.01E-9 3.37E-9	2.09E-8
TI-CS07	3.05E-9	6.09E-7
	2.80E-9	1.40E-6
T3CCS05	2.67E-9	2.67E-9
T2-CS04		9.21E-7
TIACS08	2.56E-9	5.40E-4
\$2\$04	2.35E-9	C 13E-5
T2-CS21	2.32E-9	
BP1S07	2.02E-9	03E-8
T2P2S04	1.94E-9	4.675-4
T3C-CS06	1.89E-9	1.40E-6
TIACS05	1.84E-9	9.20E-7
T1P1US10	1.66E-9	7.74E-6



Table 3.4.1-5 continued

	Hase Case	HI value rasied to 1.0
TI-CS06 T1P1S52 T1-CS05 T1ACS06 T2-CS29 T2-CS26 US13 BP1S24 BP1S12	1.43E-9 1.31E-9 1.22E-9 1.18E-9 9.32E-10 8.78E-10 8.46E-10 8.44E-10 6.63E-10	6.10E-7 3.57E-9 6.09E-7 9.20E-7 6.17E-5 4.39E-7 2.89E-9 4.55E-9 6.64E-8





P#1 1		- AL	14 C		
Ta	 n. (· · · ·	24		6.
3.621	 		S8	A	e1.
	 	we		100	5.0

Summary of Core Damage Fre	quency by Internal 1	Events Initiator
Internal Events Initiator	Frequency	Percentage
ATVS	4.74E ⁻⁶	40.7
Transients	2.90E ⁻⁶	25.0
Station Blackout	2.25E ⁻⁶	19.3
Loss of Offsite Power	1.44E ⁻⁶	12.4
LOCAS	3.06E ⁻⁷	2.6

lank	Event Name	Point Est	F-V Imp	Risk Ach	Risk Red
1	CM	1.000E-005	4.110E-001	41100.41	1.698
	T1	6.090E-002	3.202E-001	5.94	1.471
3	NSHICPEC5-2-L1T3	1.000E+000	2.735E-001	1.00	1.377
	T.3A	4.510E+000	2.530E-001	0.80	1.339
5	FWHICPEL-2-FDW-V	5.003E-003	2.472E-001	50.17	1.328
	T2		2.314E-001		
7		7.200E+000	2.165E-001	0.81	1.276
3	CV05	1.400E-001	1.468E-001	1.90	1.172
9	CV05 R15 DGBALC1R22S0006	8.230E-002	1.279E-001	2.43	1.147
10	DGBALC1R22S0006	9.600E-005	1.171E-001	1220.42	1.133
11	DHDGFS1E22S0001	3.000E-002	1.164E-001	4.76	1.132
12	U2078	8.752E-001	1.028E-001	1.01	1.115
13	U2078 FPOFFSITFPUMPER	6.000E-001	1.003E-001	1.07	1.112
14	DGDGFS1R43S0001B	3.000E-002	9,750E-002	4,15	1,108
15	TIA DGDGFS1R43S0001A	9.200E-002	9.134E-002	1.90	1.101
16	DGPGFS1R43S0001A	3.000E-002	8.504E-002	3.75	1.093
17	R36	5.290E-001	8.427E-002	1.08	1.092
18	FPDPFR0%54C6001	1.745E-001	7.890E-002	1.37	1.086
19	LCLCUMA U202B	.930E-002	7.724E-0C2	4.92	1.084
20	U202B	7.823E-001	6.915E-002	1.02	1.074
21	LCLCUMRHRALPRC	9.220E-003	6.623E-002	8.12	1.071
22	FWHICPSN27-4:1IA	1.196E-001	6.408E-002	1.47	1.068
23	SPHICPPS4:5SPCU	1.000E+000	6.344E-002	1 00	1.068
24	FWHICPEC5-3:2	1.000E-002	€.151E-002	7.09	1.066
2.5	SLHICPEQ-6-SLCX	1.0002+000	6.128E-002	1.00	1.065
26	MESC133	7.760E-003	5.075E-002	7.49	1.053
27	T3B	7.600E-001	4.707E-062	1.01	1.049
28	MESA133	7.760E-003	4.603E-002	6.89	1.048
29	MESB133	7.760E-003	4.386E-002	6.61	1.046
30	R39	1.230E-002	4.258E-002	4.42	1.044
31	CV01	4.300E-001	4.132E-002	1.05	1.043
32	FPHICPPS4:2RCIC1	2.998E-001	3.813E-002	1.09	1.040
3.3	DGDGFR1R43S0001B	7.864E-003	3.627E-002	5.58	1.038
34	LCLCUMRHRALPRC FWHICPSN27-4:1IA SPHICPPS4:5SFCU FWHICPEC5-3:2 SLHICPEQ-6-SLCX MESC133 T3B MESA133 MESB133 R39 CV01 FPHICPPS4:2RCIC1 DGDGFR1R43S0001B ESM°CC CVH1CPEPC-FPCC	3.417E-004	3.505E-002	103.55	1,036
35	CVH1CPEPC-FPCC	1.000E-001	3.482E-002	1.31	1.036
	CVHICPEPC-COM	1.001E-003	3.482E-002	35.76	1.036
37	FPHIC: 284:2RCIC4	1.000E-001	3.424E-002	1.31	1.035
	CV03	4.000E-002	3.337E-002	1.80	1.035
	ECECUMA	1.980E-002	3.322E-002	2.64	1.034
	LCLCUMLPCIBLPCIC	1.770E-002	3.1998-002	2.78	1.033
	ESESUMA	1.890E-002	3.131E-002	2.63	1.032
	VAO4B	7.327E-001	3.056E-002	1.01	1.732
	ECECUMB	1.980E-002	3.023E-002	2.50	1.031
	ESESUMB	1.890E-002	2.929E-002	2.52	1.030
	FPHICFPS4:2RCIC2	1.000E-001	2.927E-002	1.26	1.030
	DGDGUM1R43S0001B	3.030E-002	2.900E-002	1.91	1.030
	CVHICPEPC-RHR	1.0006-002	2.879E-002	3.85	1.030
48	RCHICPS51-LDTRIP	4.999E-002	2.859E-002	1.54	1.029

Imp :tance Ranking of Components (Fussell-Vesely)



Table 3.4.1-7 continued

Rank	Event Name	Point Est	P-V Imp	Risk Ach	Risk Red
49	DGDGUM1R43S0001A	3.080E-002	2.745E-002	1.86	1.028
	LCLCUMLPCIALPCS		2.622E-002	5.93	
	DHDGFR1E22S0001			4.10	
	ADHICPC5-1-ADS-A			7.16	
	DHDGUM1E2250001				1.024
	U109B			1.00	1.023
55	CVMVN01G41F0140	2.930E-003			1.023
	SCMVNC1E12F0048A			8.52	
	T3C				
	CVHICEPS7.3G41-T		2.037E-002	1.39	
				2.98	
	DGDGFR1R43S0001A	7.864E-003	1.837E-002	3.32	1.019
61	A	1.0008-004	1.814E-002	182.34	1.018
62	A P1	1.600E-002	1.772E-002	2.09	1.018
63	U111B	8.956E-001	1.574E-002	1.00	1.016
64	ECMPFS1P42C0001A	2.930E-003	1.464E-002	5.98	1.015
6.6	HPMVN01E22F0015	2.5308-003	1.454E-002	5.95	1.015
66	HPMPFS1E22C0001	2.9308-003	1.4538-002	5.95	1,015
	HPMVN01E22F0012			5.95	
	HPMVN01E22F0004			5.95	
60	ECMPFS1P42CO001B	2.9308-003			
	ECMVNCOP42F0150B		1.338E-002	5.55	1.016
	R3			1.83	
	HIHICPECS-5-CRIT				1.013
	R15B		1.245E-002	1.00	1.013
10	RCTPFR1E51C0001	9.1006-001	1 1020 002	1.09	
14	SCHVNC1E12F0048B	2 0008 003	1 1/72 002	4.90	
	LCLCUMB	1.810E-002	1.098E-002	1.60	
	DCBTLC1R42S0002		1.071E-002	0.00	1.011
11	CTHICFPS4:4-ALT	1.30/8-003	0 0040 003	1.09	1.010
78	HIHICPOR10-4:3-B	1.0005-007	9.0000-003	1.98	1.010
19	R36B	1.000E-902	9.6321-003	1.01	1.010
80	ECHXPL1F42B0001A	4./IUE-001	9.0318-003	5.60	1.010
		2.049E-003	9.0.176-003	1.47	1.010
82	R25	1.960E-002	9.473E-003	1.97	1,000
	ECMVNCOP42F015.			4.12	1.009
84	P7.		9.113E-003	6.69 5.30	1.009
	ECHXPL1P42B0001B	Z.049E-003	8.8286-203	0,30	1.009
	DGDGCC	3.675E-004	8.743E-005	26.78	
87	RCTPFR1E51C001	1.980E-002	8.740E-003	1.43	1.009
	FPHICPPS4:2-DD-0		8.276E-003	1.27	1.008
	FPDPFSOP54C0001		8.276E-003	1.27	1.008
	DBMFCC		8.087E-003	277.60	1.008
	DBLVCC	2.9308-005	8.087E-003	277.00	1.003
			8.087E-003	277.00	1.008
93			7.9032-003	7.31	1.008
94	VA09B	and the second se	7.4898-003	1.01	1.008
95	ESMVCC	9.250E-005	7.284E-003	79.73	1.007
96			7.179E-003	1.39	1.007
	HFCLDEL2		6.987E-003	5.37	1.007
98	ADHICPC5-1-ADS-L	3.600E-002	3.726E-003	1.18	1.007



Importance Ranking of Components (Risk Achievement Worth)

 Rank	Event Name	Point Est	F-V Imp	Risk Ach	Risk Red
1	СМ	1.000E-005	4.110E-001	41100.41	1.698
	E?FACCEPRCS	3.750E-006	6.664E-003	1778.20	1.007
3	DGBA' C1R22S0006	9.600E-005	1.171E-001	1220.42	1.133
4	DCB. JC	1.370E-005	5.433E-003	397.55	1.005
	DBMFCC	2,9305-005	8.087E-003	277.00	1.008
6	DBMDCC	2.930E 005	8.087E-903	277.00	1.008
7	DBLVCC	2.930E-005	8.087E-003	277.00	1.008
8	A	1.000E-004	1.814E-002	182.34	1.018
9	ESMPCC	3.417E-004	3.505E-002	103.55	1.036
10	ESMVCC	9.250E-005	7.284E-003	79.73	1.007
11	ADSRCCADS	8.000E-006	5.934E-004	75.18	1.001
12	ECMPCC	1.190E-005	7.606E-004	64.92	1.001
13	DGBALC1R22S0007	9.600E-005	5.953E-003	63.01	1.006
1.4	FWHICPEL-2-FDW-V	5.00CE-003	2.472E-001	50,17	1.328
15	ECMVCC	9.250E-005	4.238E-003	46.81	1.004
16	CVHICPEPC-COM	1.001E-003	3.482E-002	35.76	1.036
17	DGDCCC S1	3.675E-004	8.743E-003	24.78	1.009
18	\$1	3.000E-004	5.280E-003	18.60	1.005
19	DCBTLC1R42SC002		1.071E-002	8.83	1.011
20	CVMVN01G41F0140	2.930E-003	2.212E-002	8.53	1.023
21	SCMVNC1E12F0048A		2.210E-002	8.52	1.023
22	LCLCUMRHRALPRC	9.220E-003	6.623E-002	8.12	1.071
23	MESC133	7.760F-003	5.075E-002	7.49	1.053
24	SLHICFEQ-6-SLC1	1.251E-003	7.903E-003	7.31	1.608
2.5	HIHICPEC5-5-CRIT		1.259E-002	7.28	1.013
26	SLEVCC	2.930E-004	1.826E-003	7.23	1.002
27	SLMPCC	2.930E-004	1.826E-003	7.23	1.002
28	ADHICPC5-1-ADS-A		2.346E-002	7.16	1.024
29	HIHICPEC5-3:2-F		6.127E-003	7.12	1.006
30		1.000E-002	6.151E-002	7.09	1.066
31	SLMVCC1G33		5.577E-004	7.03	1.001
32		9.250E-005	5.577E-004	7.03	1.001
33			6.028E-004	7.03	1 001
34	SLCVN01C41F0006	1.000E-004	6.028E-004	7.03	1.001
35	SLXVPL1C41F0036	4.499E-005	2.659E-004	6.91	1.000
	MESA133	7.760E-003	4.6036-002	6.89	1.048
37	TSW	1.000E-003	5.731E-003	6.73	1.006
.38	LCMPCC	2.930E-004	1.677E-003	6.72	1.002
	P2	1.600E-003	9.113E-003	6.69	1.009
40	MESB133	7.760E-003	4.386E-002	6.61	1.046
	ECMPFS1P4 20001A	2.930E-003	1,4642-002	5.98	1.015
	HPMVN01E22F0015	2.930E-003	1.4 E-002	5.95	1.015
	HPMVN01E22F0004	2.930E-003	1.453E-002	5.95	1.015
	HPMPFS1E22C0001	2.930E-003	1.453E-002	5.95	1.015
45	HPMVN01E22F0012	2.930E-003	1.453E-002	5.95	1.015
	T1	6.090E-002	3.202E-001	5.94	1.471
	LCLCUMLPCIALPCS	5.290E-003	2.622E-002	5.93	1.027
48	ECHXPL1F42B0001A	2.049E-003	9.627E-003	5.69	1.010





Table 5.4.1-8 continued

Rank	Event Name	Point Est	F-V Imp	Risk Ach	Risk Red
49	н	1.000E-004	4.640E-004	5.64	1.000
	RPT	1.000E-004		5.64	1.000
	DGDGFR1R43S0001B			5.58	1.038
	ECMPFS1P42C0001B				1.014
	ECMVNCOP42F0150B				1.014
		1.598E-003			1.007
	ECHXPL1P42B0001B		8.828E-003	5.30	1.009
	LCLCUMA		7.724E-002	4.92	1.084
	SCMVNC1E12F0048B		1.147E-002	4.90	1.012
	DHDGF5172250001		1.164E-001	4.76	1.132
	ECMPFR1P42C0001A		2.626E-003	4.65	1.003
	R39	1.230E-002	4.256E-002	4.42	1.044
		7.195E-004	2.362E-003		1.002
	HPMPFR1E22C0001		2.347E-003	4.26	1.002
		3.000E-002	9.750E-002	4.15	1,108
	ECMVNCOP42F0150A	2.930E-003	9.157B-003	4.12	1.009
	DHDGFR1E22S0001	7.864E-003	2.4532-002	4.10	1.025
	CVHICPEPC-RHR	1.00UE-002	2.879E-002		1.030
	DGDGFS1R43S0001A	3.000E-002	8.504E-('01		
	EPFAFS1M39B0003	3.750E-004	9.4/65-004		1.001
	EPFAFR1M39B0003		7.2635-004	3.42	1.001
	DGDGFR1R43S0001A		1.837E-002	3.32	1.019
	SMNVCC	9.250E-005	2.102E-004		1.000
	DHHXPL1E22S0001		4.633E-003	3.26	1.005
	ESESUMC	9.370E-003		2.98	
	DCBTLC1E22S0005		2.607E-003		1.003
		1.367E-003	2.505E-003	2.83	1.003
		1.770E-002	3.1995-002	2.78	1.033
	ECECUMA	1.980E-002	3.322E-002	2.64	1.034
	ESESUMA	1.890E-002	3.131E-002		
	DGHXPL1R45B0002B		3.131E-003		
	ESESUMB	1.8906-002	2.929E-002		1.030
		1.980E-002			1.031
	DGHXPL1R46B0002A		2.976E-003	2.45	1.002
	R15				1.147
	HPHPUM		3.611E-003	2.34	1.004
			1.527E-004	2.22	1,000
	the state of the second s		1.167E-003	2.2.	1.001
	the second		1.167E-003	2.22	1.001
	EPEPUMHPCS		1.953E-003	2.20	1.002
	HPCLLF1E22C0001		1.382E-004	2.11	1.000
	EPCLLF1M39B0003	1.250E-004	1.382E-0C4	2.11	1.000
91		1.600E-002	1.772E-002	2.09	1.018
	ECCLLF1P42C0001B	1.250E-004	1.278E-004	2.02	1.000
	DHBALC1R2250009		9.778E-005	2.02	1.000
	12CVN01E22F0002		1.018E-004	2.02	1.000
	EPCVN01E22F0002	1.000E-004	1.018E-004	2.02	1.000
	BPCVN01E22F0016	1.000E-004	1.018E-004	2.02	1.000
	HPCVN01E22F0028 HPCVN01E22F0005	1.000E-004	1.018E-004	2.02	1.000
		1.000E-002	9.852E-003	1.98	1.010
98	HIHICPOR10-4:3-B	1.0005-002	210000×000	3.1.70	A COMP



Functional Failure	Contribution to CDF (%)
Loss of Injection (U1, U2, U3, V, VA)	68
Failure of Decay Heat Removal (Q, M)	2
Failure of Containment Heat Removal (W, Ws,	Y) 28
Failure to Recover Offsite Pover (R, R1, R2) 22
Failure to Depressurize (X, X2)	4
Containment Failure (Cv)	22
Failure to inhibit ADS following ATWS (X')	25

Contribution of Functional Failures to Core Damage

	FREQUENCY	FRACTION OF CDF
No RPV Fail: No Containment Failure	3.39E-6	32.6%
Vent	2.45E-6	19.3%
Containment Failure	6.18E-7	4.9%
Subtotal No RPV Failure Core Damage Frequency:	6.46E-6	50.8%
RPV Fail: No Containment Failure	1.58E-6	12.4%
Vent	1.27E-6	10.0%
Late Containment Failure	9.38E-7	7.4%
Early CF: No Pool Bypass	4.3CE-7	3.4%
Late Pl Bypass	1.54E-6	12.1%
Early PB, Spray	6.12E-8	0.5%
Early ⁿ B, No Spray	4.45E-7	3.5%
Subtotal RPV Failure Core Damage Frequency:	6.27E-6	49.2%
TOTAL CORE DAMAGE FREQUENCY:	1.27E-5	100.0%
Subtotal Containment Venting Frequency:	3.72E-6	29.2%
Subtotal Cntmt Structural Failure Frequency:	4.03E-6	31.7%
TOTAL CONTAINMENT FAILURE & VENTING FREQUENCY:	7.76E-6	60.9%

RPV FAILURE AND EARLY CONTAINMENT FAILURE 2.04E-6 16.1% WITH POOL BYPASS FREQUENCY:

TABLE 3.4.1-11 DOMINANT CONTAINMENT FAILURE PLANT DAMAGE STATES

Rank	PDS CLASS	FREQUENCY	CNTMT FAILURE PERCENT	CDF PERCENT	DOMINANT SEQUENCES	CDF%
1	56	3.40E-6	43.9%	34.0%	13B-U1-U2-Va1 TIA-U2-U1-V-Va-Wr-Ws B6-V-Wc F1D-U3-U2-U1-V-Va A-U1-V-Wc-Ws T15-Va	8.9% 5.9% 3.0% 1.8% 1.6%
2	73	1.22E-6	15.8%	9.6%	T2-Wc-Ws-Y-Cv-Li	8.2%
3	61	6.23E-7	8.0%	4.9%	T15-Va-R3 UR-V-Va-R3	2.6% 1.9%
4	71	5.59E-7	7.2%	4.4%	T2-Wc-Ws-Y-Cv TIA-U2-Wc-Ws-Y-Cv	2.2% 1.5%
5	65	2.93E-7	3.8%	2.3%	T2-CA-C1-Vc	1.1%
6	67	2.65E-7	3.4%	2.1%		
7	69	2.56E-7	3.3%	2.0%		
8	63	1.69E-7	2.1%	1.3%	T2-CA	1.2%
9	25	2.09E-7	1.8%	1.6%		
10	36	1.02E-7	1.3%	0.8%		
11	66	1.00E-7	1.3%	0.8%		
12	9	9.73E-8	0.8%	0.8%		
13	58	6.15E-8	0.8%	0.5%		
14	62	5.02E-8	0.7%	0.4%		
15	53	4.44E-f	0.6%	34,9%		
16	70	3.235-8	0.4%	0.3%		



Recovery Actions Included in the Model

Identification	Description	Function /System
HIHRCPORID-4:3-B	Operator fails to X-tie Unit 1 and Unit 2 batteries	ΗI
CTHICPPS4:4-ALT	Operator fails to align condensate transfer alternate injection	Va
FPHICPPS4:2RCIC1	Operator fails to align fire protection after RCIC fails due to suppression pool temperature	Va
FPHICPPS4:2RCIC2	Operator fails to align fire protection after RHR fails due to MCC HVAC failure	Va
FPHICPPS4:2RCIC3	Operator fails to align fire protection After HPCS fails	Va
FPHICPPS4:2RCIC4	Operator fails to align fast fire protection alternate injection	Va
FWHICPSN27-4:LIA	Operator fails to control reactor feed booster pump during a loss of instrument air transient	Va
FWHICPSN27-4:1IA	Operator fails to control the reactor feed booster pump following loss of Instrument Air in a time frame greater than 2 hrs.	Va
SPHICPPS4:5SPCU(L)	Operator fails to align suppression pool clean up alternateinjection (late injection)	Va (Va,Li)
CVHICRPS7:3G41T	Operator fails to locally open 1G41-F0145	Ŷ
ADHICREC2-ADS-R	Operator fails to depressurize after core damage having failed to depressurize early	Х3
SLHICREQ-6-SLCR	Operator fails to initial SLC given early failure to initiate	C1′

Tat	9		1 14	1.00	Sec. 1
T 23 P.	5 45	4	Sec. 19		28
A 68 L	A.A.C	3 4 9	e a 12.		3.

Recovery Action		Core Damage Frequencies	
		With Recovery	Vithout Recovery
1.	Use of Alternate Low Press Injection	1.2E-5	2.6E-5
Ζ.	Cross connect DC supplies from Unit 2 to Unit 1	1.28-5	2.3E-5
з.	Operator fails to open 1G41-F0145	1.2E-5	1.6E-5
4.	All the above actions	1.2E-5	4.2E-5

Inmpact of Recovery Actions on Core Damage Frequency





Sensitivity Analysis Results

Base Case CDF 1.2E-5*

	Assumption	CDF	% Change
1.	Initiating event frequencies based on Perry experience (with lower limit of 0.5)	7.0E-6	-40%
2.	Automatic ADS Inhibit following ATWS	8.8E~6	-23%
3.	Operator does not override RCIC leak detection temp trip	1.8E-5	+54%
4.	Switchgear room cooling is requited	1.5E-5	+25%
ε.	Containment failure does not lead to loss of injection or passive vent to prevent containment failure	9.0E-6	+22%
6.	Contribution of maintenance to core damage reduced to zero	6.0E-6	-45%
7.	Human reliability data increased by a factor of 10 or to a maximum of 1.0	4.3E-4	+3,584%
8.	Perfect operator performance	3.9E6	-66%
9.	Manual initiation of ADS following loss of all high pressure injection	1.3E-5	+13%
10.	Increase common cause by a factor of 10	2.2E-5	+91%
11.	Passive vent	9.1E-6	-22%

* Excludes flooding

0.0


Table 3.4.1-15

Core Damage Frequency Based on Revised Initiating Event Frequencies

Station Blackout		
B BP1 BP2	2.11E-6 8.36E-8 5.91E-8	30.2% 1.2 0.8
Loss of Offsite Power		
R U T1 T1P1/P2	7.19E-7 4.19E-7 1.80E-7 1.15E-7	10.3 5.9 2.6 1.7
ATWS		
T2-C T3B-C T3C-C T1-C	7.07E-7 3.56E-7 9.38E-8 3.61E-8	10.1 5.1 1.3 0.6
Transients		
TLA T2 T3C TSW	1.01E-6 5.05E-7 1.38E-7 6.68E-8	14.5 7.2 2.0 1.0
LOCA's		
A S1 S2	2.11E-7 6.18E-8 3.24E-8	3.0 0.9 0.5
Total	6.99E-6	









<1

13

10

4

8

22

<1

<1

3

<1

34

Percent CDF

Punctio Acciden		ia
Sequenci	2 Definition	CDF
IA	Accident Sequences Involving Loss of Coolant Inventory Makeup in Which Reactor Pressure Remains High.	7.0E-8
18	Accident Sequence Involving a Loss of AC Power and Loss of Coolant Inventory Makeup.	1.5E-6
1C	Accident Sequence Involving a Loss of All AC Power and No Recovery of AC Power.	1.22-6
1D	Accident Sequences Involving a Loss of Coolant Inventory Makeup and ATWS.	4.4E-7
lE	Accident Sequence Involving a Loss of Coolant Inventory Makeup in which Reactor Pressure has been successfully reduced.	9.7E-7
22	Accident Sequences Involving Loss of Containment Beat Removal Leading to Containment Failures and Subsequent Loss of Coolant Inventory Makeup.	2.58-6
3A	Vessel Rupture Leading beyond makeup capability.	<1.0E-7
3B	Accident Sequence Initiatied or resulting in a small or medium LOCA for which reactor cannot be depressurized and inventory makeup is inadequate.	<1.0E-7
3C	Accident sequences initiatied or resulting in medium or large LOCA for which the reactor is at low pressure and inadequate coolant inventory makeup is available.	3.9E-7
3D	Accident sequences which are initiated by a LOCA or failure for which vapour suppression is inadequate.	<1.E-7
4	Accident sequences involving an ATWS leading to containment failure due to high pressure and subsequent loss of inventory.	4.08-6
5	Ibicolated for entit	


5 Unisolated LOCA outside containment leading to loss of <1E-7 effective coolant inventory makeup. <1

	In vidual Core Dama	age Sequences Grouped	by Accident Class
Group	Seguences	Frequency	Percent CDF
1A	BS35	5.15E-8	
	BS30	1.01E-8	
		6.96E-8	< 1
1B	BS34	5.265-7	
	US29	3.34E-7	
	US12	5.99E-8	
	T1535	1.23E-8	
	RS20	6.04E-7	
		1.54E-6	13
1C	BS24	7 71	
	BS17	7.712-7	
	BS12	3.365-7	
	BP1526	1,04E-7	
	DE1050	1.13E-8	
		1.22E-6	10
10	~2-C\$28	3.12E-7	
	T3B-CSC9	5.32E-8	
	T3B-CS27	3.80E-8	
	T3E-CS08	1.78E-8	
	PS30	1.81E-8	
		4. 19E-7	4
1E	TIAS14	7,53E-7	
	US12	5.99E-8	
	BS22	5.96E-8	
	TSWS10	5.496-8	
	T1S35	1.336-8	
		9.41E-7	8
2	T2S04	1.62E-6	
	BS07	1.60E-7	
	TLAS05	2.57E-7	
	T1308	1.47E-7	
	T3CS04	1.38E-7	
	1.119	8.38-8	
	R\$33	3	
	RS10	2.736-2	
	T1S04		
	T7509	1.94E-8	
	US?8	1.90E-3	
	W.QU	1.63E-8 2.54E-6	33
		\$ · OHE-0	22

Table 3.4.2-2

Table 3.4.2-2 continued


AS09 S1S13 T1P1S31 T1P2S11 BP1S17 T1P1US22	2.10E-7 5.85E-8 7.24E-8 2.39E-8 1.69E-8 1.37E-8 3.95E-7	
T2-CS30 T2-CS20 T3B-CS29 T2-CS11 T2-CS12 T3C-CS27 T3B-CS19 T3B-CS10 TIACS09 T3B-CS11 T1-CS09 T36-CS17	2.275-6 6.25E-7 2.76E-7 2.90E-7 2.37E-7 5.49E-8 7.60E-8 3.45E-8 3.31E-8 2.88E-8 2.19E-8 1.40E-8 3.9CE-6	34



F PE GLE NC V				40-304					51. IC				D0E + CIS	Norse as			0 906-00	001-100	00E+300	
0.62.05.46	n ann an a	8	8	8	8	X	8	8	8	8	8	K.	9. 11.	8	ß	8	0 22	8	8	
SE DUE HOE	142	-1021	101.41	1201-14-1-12+	50-1421	26-00-1401	# 201-002-1421	1-#-61-00-5481	1241-03-00-00-0-0x	10-20-20-142-	* 10,20,E, 1021	4-4-50-20-50-5021	*3-+++-10-20-60-14Z1	A 10-20-50-1423	12011-113-102-011-1-1-W	4-14-10-00-00-3021	1 N N 10 00 20 3421	#a-a-10-00-20-1.00	519 1261-03-03-01-x	PEFREY NUCLEAR POWER PLANT UNIT T THOTWIDURE PLANT EXAMINATION FIGURE 2 1 2-3 SWEET 2 OF 3 LOSS OF PCS 4 OWE STECK OPEN SOW
00 W W W	361	205	8	3	8	Suc	3	205	8	ELS -		1915	247	514	StS	216	1	100 M	81.5 5	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
C3100 way with a set to a set of the set to a set of the set to a set of the				£043					1043				204				C'WD-M			FIRTY NUCLE INCIVIDUA FIGURE 3
LUMG-TERK COLFAINGENE ARA ARA REPORT -Y			-05					*05								SUA				9
L DIAC TEAN CONTALWARN' DENORAL WITH DOG -N												*DE								
ell'i 18 Reversione 101 - Eneles 2021/2021 101 101 101 101 101 101 101 101 101																		412		
No. 1. UNK															A const	Eda				
12.411000 -12.41100 -12.41100																			K C K	
put 53000 (DBS Syntax																1004				
2001 811 986 91 2001 811 986 91 96 801 96 -072							James an				EDRA									
BECONDER BECONDER NOTOR SEEQNAUE -UG3								2051												
reversity with and the states and the states areas and the states areas					1252															

0/001/11/12/12/01/2016 641 0-01-05 12/2017 01/2017 50 621 009


a




0.058841/E1/1585 EAL 4 10.0004 2 ...65 MP.444 5 3 CEI












.

-




GRADIFICTED DATA 0-01-85 1-25 KEAN LOIN CHL + 0 586-008 D / BEUMAL/EL/12MB3 CAL 1-23 309% 2-01-85 WEBUM 5-0 CEL





0 / bc@dil/Ci/k EAL 1 05 550m 0-01-35 WDBM 5 0 (EI 0 / bc@dil/Ci/k EAL 1 05 550m 0-01-35 WDBM 5 0 (EI



8

R

•1. The #1


1


ALCONCE TH

ų










1

.




· · · · · · ·

-

1

a 🙏



2 .


0

9

1.00

1 4. 1

1. 2. 6



^{0./56841/61/10/6}A1 3.52/88# 8-01-85 WDBU# 5.0 261 0./56841/61/10/6A1 3.52/88# 8-01-85 WDBU# 5.0 261

TREE

Lini] T

T'N POMER PLANT

PERRY NUCL

41-10-


25.0

198 df 11 313d 30 3501 /# NU08

ID SHO W/ + SH' DPEN (RP1)

10-10-

INCIVIUUAL PLANT EXAMINATION FIGURE 3 3 3-9 SMEET & DF 6 LOOP AND DWE SYUCK DPEN SRV EVENT REVIJION 3 (12/05/99)




Caller.


F INE OLIE NET V				-10E -0E	00 × 300				tSE-10	DBE+DS	396 2.0	001: + 00	8 196-07		
L O 4 +	ă	ă	ă	8	8	X	ă	ă	1	8	8	e B	8 11 1		
SEGUENCE DE SURIS FIGR	245	N - 545 -	n # 2d1	1 102 - M - V - C.e.	1,12, 14	10-644	202 1193-01-W	506 T1P2-U1-W-Y	1192-01-8-1-04	~H-10-2011	* 10-241	1382-01-X	513 1292-81	PERRY NUCLEAR POWER PLANT (MIT 3 INDIVIDUAL FLANT EXAMINATION	FIGURE 3 1 3-1 SHEET 6 DF 6 LODP & 40 TWO STUCK OPEN SDV* REVISION 2 (31/05/24)
0.00.00	\$0.8 20.8	502	£73	50.4	\$85	208	201	308	805	15	3	3	1015	AR POW	1 3-1 11 2 0 4 1 0 1 2
CDRF NCT VULINE 2481- 6 10 DAMAGE -C.W				CVD1					C VD 2					PERRY NUCLE INDIVIDUA	FIGURE 3 1 100P A4D 7mC
1,006-7ENw For a Posterior National Readow Well 196			E04					104							
(1016-17504 1014-17504 10541 10541 10541 10541 1015 -18			#03					#D#							anna era ta ad
Sartes Sartes 6. arst 6. arst 6. arst -54 -54					1044					10 M					
N- artistati Art											K15				
contraction v Berty Copressos - X												20	1248) 83		
PRESSURE CISRE SPRAX			0115B								1111		10 580 W/ 2 SPAS DF14 (8P2)		
4 00101 618 10 618 1 018 2 -813													10.58		
Annual Spectra County and Section							-		-						

F REGUENCY				005-00			6007				005+00	136-07					00+300	355-07				005+300	966-62	005+00	20-3**				005-00	73E-DB	80-318			116-08	266-93	15608			T	
и. С. С. (Л. Ф.	a	ă	8	C0 3 01	X	ă	CO 1 60	eine -	ă	ă		-	-		5 2	-	0	m	ă	8	ă.	Sie	1.1	-Re-	CD 7 14	×	ä	×	C. 0 00	EL PL GD	CD 1 81	×	ð	CC 5 111	C0 5 26	10				1
SE DUENCE DE SCR1P10R	8	8-8	B-#-4	B-W-Y-Lw	8-n	6-R-1	A-N-r-C+	B-at	10-113-M	A-M-[H-B	*3-*-8-14-8	в-иј-в					-10	8-11-10		B-()1-Wa-M		B-(J] - V3 - W - V - C +	8-01-Va-V	8-01-9e-X	B-03-Ma-0	8-01-02	8-01-02-W	8-01-02-8-1	B-UI-U2-N-L-C*	8-01-02-VM1	8-01-105-X	8-01-02-R	8-01-02-8-1	8-01-02-8-x-C+	B-Ut-U2-R-wat	535 B-C1-02-8-8		MUDLEAR POWER PLANT UML PLANT EXAMINATION	FIGURE 3.1 3-2 SHEET 1 OF 3	REVISION BLACKOUL
	S01	502	503	20.4	1 SOL	- SDE	507	508 B	509 8	S10 8	110				(second second	Scottering Street	vice in a	1517 B		510 8	81.025	523	E 225	523 8	52.4 B	525 8	Collection and the	527 8	10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	52938	530 3	535	532 8	533 8	E FES	535 8		PLAN	2.5	8
NUTINE TABLE NUTINE TABLE TO DAMAGE -CY				EWDI			5401				C#01					C V 0.2						C.ANG		-					[CA05]					CYDA			and the second se	PERRY MUC	1 6 3d001	ATTA TO TA TA
CORFACIONENT NEAT RENOVAL 8/ YEN/ING			V.16			5										£13					1434							121 121					1 1 1							
CONTAJNAGENT (E.M.) NEMOVAL W/ RIGR								and the second second		MON					613					#13							#28										and a			
-VB1																														APT /					VA20					
4/1-33x8w 3-01155.38b/ #021														Second Second																										
Letter the second of the secon																															×10					EINI	Contraction of the local distance			
01 POMER 10 1 DA 2011 1 DA 2												802		A second s			403					8048		9	×0				RC7B						H97	2				
14,0657,084 411 H 016561,084 081 VEN 5926 -Va															unitar.	AMUNS.							wa0.4																	
1500.4710M 1500.4710M 0.000.1M0 -U2																				No. 10												207								
and the second second										103										1																	and the second second			
IH- POLINE AND CINEND AND COMPANY COMP				L			-																																	
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1				L			01096																																	


F RE GUE NC Y					0.056+000				2 026-08				005+00	7 306-30				006+00	6.96-08	C.00	127-09				00+300		006+00	136-08	85E - 08		
600		ă	ð	2				ă	13	8	ă	ž	E0 0	3	ă	ð	ă	8	5	8	5	ă	ă	×	9 8	60	0 02	ce Ce	8		
SEGUENCE DC3CR1P10R		501 BP1	90.1-M	50 T RD1 - M- +	8P1-4-1-C-	n-1,48			*3-2-8-648	- J-H]	M-214-1,68	4-8-28-548	43-1-3-2H-1d0	512 BP1-H-R	87.5-141	#+171-1 dB	x-#-12-1d8	801-01- 8 -2-C*	801-111-W	8-10-128	513 Br1-U-P	8863-111-148	W-87-10-148	80-1-11-MN-M-1-1-1-8	*2-x-#-#A-10-1d8	N-22-01-58	BPT-UL-WA-X	21-N-1-1-1-1-15	527 861-01-102	FERRY NUCLEAR DUWER PLANT	FIGURE 3 1 3-2 SHEET 2 DF 3 STATION BLACKOUT WITH DAR SDAV
0000	-	504	202	50.7	204	S05		205	- 207	204	503	\$10	1115	512	1413	\$15	Sta 1	St6	1212	518	513	025	125	ies	6.23	125	525	526	255	CLEAR	1 3-2 CKOUT
CORE NOT VER NERARILE 70 CAINAGE	-04				E WD 1								[CND]					Exda							10,402					FERRY NU	FIGURE 3
LENG-TERM ECNTATHENT HEAT REMOVAL WITH VENT	N				*18			111				×15					-25							×23							UN I
LING-TERM CONTAINMENT HEAL REMOVAL WITH RHE	-R			(#12							114																				
PRESSIME	A																		W3.4							¥13					
1.000 FILE FILE FILE FILE FILE FILE FILE FILE	X															- Annora							Sec. 12				(K)1				
01 POWER 10 01 POWER 10 01 POEE 1 DE 2	H						40%							105							Pile				A0.95			808			
INJECTION MITH 015561 DistVEN FJSE Puep	. ea-																		AKDAR.								80Y				
1501, 196 1000, 196	OF C											and the second se											120.78								
ACTIONS FAXEN TO EATEND NEVES OPERATION												PA101																			
1015 3994 3803 3902								01098																		0,00					
BLACEDUT WITH Det SRV 510CK 09EB 3D1																	101555														

0.7668811/E1081.0918 8-01-35 5.03 5898 10187 58 - 8 285-01 0.9011111081.091 641 5.03 5868 10187 59 561







(B)



-



^{0./}PERRY/LEN/10018 6-04-92 8:14 2008 0-04-92 NUME 2:0 CEI 0.01111100100018 0-04-92 8:14 2008 00 CEI




- - - O

2

は次して

Directory.cliniters Ext. 4 (5 3644 6-04-92 MiRMA 2:0 CEL


Sector drives




and in the st

いた

· · · · ·



DAMONTATION 2019 2-01-85 8 03 5348 10145 045 4 0 205-003 0 reterrition 2019 2-01-85 8 03 4098 2-01-35 40658 5 0 261



Sec. 4. W. St. 4.

A. 12 P. 4

-6394

_

11 States V

1.


•

F PC DUE NC Y				0 205 × 20	1 225-09	60-36# I	aq- 350	80-3## B	2 196 - 08	
1 D 10 *	ă	ă	8	e B		8	8	6	8	namaa
SE QUENCE DESCRIPTOR	504 L + - C	4-1-14	19-0-41	11-C-18- V-C+	.A-3-11 [305	506 11-C-V	13-12-16	1 - C - C 3	x-3-11 005	<pre>/ Rev NICLEAR PONER PLANT UNT 1 /// PISURE 3 1 3-7 ATMS AND LOOP EVENT PLCE REVISION 3 (05/13/94)</pre>
n w 🛪 🖌	19	202	503	-	505	905	íg.	208	605	PLAP
1006 1007 100 100 100 100 100 100 100 100 10				200						P RY NUCLEA NUTVIDUAL FIG
COVIA 198620 COVIA 198620 REACYAL K/ VCM1346 -Y			80,							
COMPANIES CONTRACTOR			80.8							
-A., NB ACA NB A					NPG1					
A df-320% 30555106						a ça				
Net and							çdx			
suc suc								191		
abs Taari 81 T X ¹									×107	

France					80-345 e	15-342 +	1 585-01				0.005+00	16-306 2	10-31E C				00+300 0	00+3kJ C	0.006+00	006+300	10- XX 9	80-325 z				0 001-00	01-382 B	2 SMC-10	3 325-07	9 35E-3C	30-34¢ \$		
6 (3 (A)	-	8	ă	8	8	Co.	2	ð	ă	8	8	83	3	ă	8	8	8	B	8	8	8	69	ž	8	8	8	8	8	83	23	8	-	
SE GUENCE DE SCHIPTOR		12-C	#-3-21	1.5.5 4.4	12-2-10-1-La	A-2-24	12-E-W	12-C-K	\$08 12+C-X-#	56.4 12-4-8-7	12-C-K-M-1-1+	12-5-51	12-C-K	513 T2-C-57	#21-3-21 #45	2-8-23-3-8	12-C-UC-B-4-C*	12-5-5-51	12-C-10-A	Tart-Leve	12-0-02	x-17-1-51	68-3-24	12-C-03-W	¥2=(U3-#-×	12-C-03-#-C-C*	A-07-2-21	4-60-3-81	12-0-03-1	528 72-2-03-01	530 T2-C-08-z	DERRY NUCLEAR POWER FLANT UNIT INDIVIDUAL PLANT EXAMINATION	FISURE 3 : 3-B ATMS AND LOSS DF PCS EVENT TREE
6 W G	11	105	202	605	204	12.5	1506	105-	508	50.4	510	-	515	513	514	245	535	242	815	015	25	125	525	No.	1224	523	865	125	526	25	8	PLAN	SS OF
CONE NOT NOT 10 10	-[v				CNDS						6343						01:02							1		CA35						INDIVIDUAL	FIS AND LO
LONG-TERM 20M1AJIMENT HEAT REMOVAL	4			161						***						101									101							id.	
LONG A THE TARGET				(m)		and the second se													ALC: NOT THE REAL PROPERTY OF														
DREVENT REV DVERTILL	· ^ ·					2001												10dA									1044						
ACE DUATE (DRE (CDRE RETLODD AT (CDA AT (CDA	A-						ADE												80%									WDT					
ENERGENEY NDV DEPRESS- CALIZAFICN	×-								X06											50%									¥3.4				
SLC INJECTION	-61											10107							1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		C108									12 182			
1 THILHNI SON	-X.												6248									(Cdax									xP04		
LEVEL CONTROL	-10																				1.CDe												
HIGTOR FEED PUMP INJECTION	-03																													305			
411 10 10 10 10 10 10 10 10 10 10 10 10 1	12-C																						1201666										

-

_



0.400041/E1/134-0 EA1 8-41 (### 1-01-35 MD64# 5.0 026-003 0.7000041/E1/134-0 EA1 8-41 (### 1-01-35 MD64# 5.0 026-003


F DE GOENCY			000+000				1 831-20	1 526-DB	1 296-296	5 326-08	5 #5E-08	2 886-08				0.006+00	006+20	006+00	0.000+00	7 506-95	211-362				006+00	206-200	001-100	801-96	001+300	10-392	606-309	80E-10		
000		A	8	ð	8	ă	8	8	8	8	8	8	8	ă	8	8	8	8	8	8	8	8	8	ð.	8	10	8	8	5	8	8	8		
SE QUENCE DE SCRIPTOR		138-C	138-0-04	T38-C-G	138-C-D-M	7.30-2-3-8-1	*3-X-#-0-3-861	A-0-3-061	138-C-D-A	1.38 E-0-3	10-C-D-C1	138-5-0-3	138-1-2-1 ¹	1月11日 - ロービビーキー	A-#-37-0: 1-861	*2-x-#-31-0-3-861	4-27-0-2-8EJ	138-C-D-C-A	138-5-0-14-1	13-11-0-2-951	139-0-0-161	138-C-03	738-C-US-*	1.38-1.0-2.381	138-C-33-8-1-C+	# -ED-3-8E1	4-60-3-861	x-50-3-864	138-C-03-C1	738-C-U3-X	138-C-901	1.28 C *	PESBY NUCLEAB POWERPLANT UNIT 2 THOUTTOOL DUART EVANTUMITIC	1.1.3-30 0F FEFDWATED
ស្សន	in the	201	Su2	SOS	F05	505	508	- 307	805	200	510	SAT.	015	- 513	514	315	Sit	217	1518	10.10	2500	ā	202	523	10.	525	No.	222	528	555	DES	i E E	Dd by	E 380
C.096 121 VULNETABLE 10 Lawror	-Cv						CWD2									Craz									10 M Dis								PY NUCLE	FIGURE FIGURE
LONG-TERM CNTNMGT HEAT REMOVAL WEATVIE	A-																							111									12 12	
L.DNG-TERM CNTNMKT NEAT NEAT REWOWAL	*					#11																												
1015 WT NT 1010 1011 TU TU TU	3.4-							1044									1044						Ī			12.64								
CDRE CDRE REFLPDD AT LON Particulor	A-		-						P.16									×05									#0.1							
Ewe RIGENC + RPW DE PRIZ 55- URT 2 AT 1 (04	-×-									108									808									114						
SLC INJECTION	-C3		C111					Sec.			5107						-	C17980		0.108														
A THE LINESS I SCOW	-X-											ED03									60.00							Ī		*0.0X				
LEWEL COMPADI	-1.6										T	20								102									Ī					
PCS REMATARS AVAILARLE	0-	D0.4B													254																NOT DEVELOUS			
ARCOMENT DS MOTOR FEED Plant	-13																												0.309			MDT DEVELOPED		
	-464								-																							C LON		
SPR46																																		
LING MITH LOSS 24 FEEDMATER	138-C																											0				¥)		

100-31# 2 * 3K3 1W101 #422 /0 # 28-#0-9 #180 0011#31/118000 130 0 2 Wedra 26-10-1 #829 25 8 1A3 3-861/13/1480.8/0

F RE DUE NC Y					G05€ + 0.0	2 806-00	1 805 - UD	9 BIE-09	60-369	5 316-00				0 004-00	005+00	00+300 g	0.006+00	1 #05-08	0 006-90				001+00	0. 00f+25	006+300	01-358	006+00	#21-108	*05-01	ADE-10	406-10	-	
	0	ă	X	8	8	8	00	8	(2)	8	8	x	8	8	8	8	8	8	8	X	8	8	-	50	9	8	00	2	15.20	8	8		1
SE ONENCE DE SCRIPTOR		13E-E	136-C-W	1.3C-C-#-1	13C-C-W-V-Ce	1.HCW	13C-C-W	X-C-C-X	136-5-61	30-C-X	THE-E-LA	130-0-0e-w	T3C-LL-M-3	13C-C-15C-36-3-2E+	4-31-3-361	4-171-3-3E1	13C-C-13-3K	THE-E-EX-EX	130-0-0-rs-jc	196-0-01	#-60-2-364	A-#-60-3-364	13C-C-03-#-1/C+	132-6-03-9	A-60-0-361	180-0-03-X	13-61-3-361	130-10-209-10	24-2-36	7.3(0,-307	#-5-364	POWER PLANT UNIT 5	3 5 3-15 RV EVENT TREE
ທພອ	· · · · · ·	195	205	503	504	505	205	507	905	509	520	213	515	513	53.4	515	516	597	518	455	525	102	252	523	100	525	528	1.05	Sea.	22.0	8	A DOW	E JE
CORE NOT NUT NETABLE 10 DamaSE	-Cv		and the second second		2043									C#02									1455									DEBUY NUCLEAD	ATMUTATOURS 3 3-11 ATMS WITH TORY EVENT SEVERICH T DAATOU
L (JIMC- T E RM CNT NAMUT HE KT RE N(JVML M/ VENT	A												#10									*10										10 Jac	
LCHE-TERM CNTRANKT HCAT REMOVAL R/ RHC	N			#10									410									01.0											
5 3						10dA									10.44									10da								-	
ACK GUATE CORE REFLODD AT LOW AT LOW	4-						×05									N05									W.A				112-51				
5.46.945.945.46.4 8894 06.996.55- 06.24.71.04	×-							×04.									×0.7									127			255 DF PES				
SLE TNUEETION	-01								10105							21036		108									\$105		10 ATMS W/ LOSS OF PCS 112-CI				
a05 1 m1 81 f	. ×-									xPD3									1003									KP03	10	DPED			
LEVEL	-Lc																	102												NOT DEVELOPED			
PCS PERALINS PERALINS AVAILABLE REMAINS AVAILABLE AVAILABLE AVAILABLE AVAILABLE	-03																										27,2018				NDT DEVELOPED		
PCS PEMAINS AVAILABLE MSIVA DPEN	0-																												205		ND1 DE		
	1 db-																													SPT01			
N3:00 N3:00	-N																														104		
ATAS MITH 105V	T3C-C																												136,526				


0.0468443/E1/130-C E41 10.08 5544 3-01-95 40504 5.0 CE1 0.0404111(1541:00.0844 8 4.10.08 5544 5.0 CE1 -


FREDUENCY				o kot-ta	1 Bef -09	1 100-00	201-08	2609	315-08	
0.01.4	8	ă	ð	9	8	8	8	9 []	8	****
SERVENCE DESCALPTOR	×.	*1AC-M	503 1340 m- 1		12.4C - 6	Taxo-w	N - 14 E A	11.965-F2	190-X	PE DEF NUCLEAR DOWERPLANT UNIT 3 INCIVIDUAL PLANT EXAMINATION fileude 3 13-12 AIMS AND LOSS DF INSTRUMENT AIS DEVISION 2 FOX/02/201
	Sol Take	195	E S S S S S S S S S S S S S S S S S S S	- 20×	SS 1	505	<u>g</u>			PLANT PLANT PLANT PLANT PLANT
CORE NOT NOT NOT 10 DAMAGE -C.Y				C M C M						PERRY NUCLE INCLUDIAL FIDUAL FIDUAL FIDUAL AND LO RUJSIC
LOR-TEAM COFALORENT AEAT AEAT AEAT AEAT ACAT			Arrowski Aro							
L CONT AN INVESTIGATION CONT AND INVESTIGATION CONT AND INVESTIGATION (CONT AND INVESTIGATION CONT AND INVESTIGATI AND INVESTICATION CONT AND INVESTICATION CONT AND INVESTICATION CONT			40 20							
PREVENT STLL					a di da					
ACE DUATE CORE REFEEDOR AT LON PACSUME -V						40.2				
 K.M. BAR, N.V. BAR, M.M. BAR, S.S. C.B. PARE, S.S. C.M. S.M. S. S.							9 E			
Suffition C1								(10)		
ADS 1641817 ~X^									100	
ALLAC								85.58	88	



F RE DUE NC +					100 St 1	80-395 1 211	5 #6 0 006 -100	
a co in a	ă	ð	8	ð	5 2 2	е 12- 13 11- 14- 14- 14- 14- 14- 14- 14- 14- 14-	0 9 7	
SEGUENCE DE SCR1 P1 DR	(BB)	- 1001 - 1 0	1201-W-W	1201-46-48-1	*1 *818	1201-10-1-10-111	()-+C-+NW-140	PERRY NUCLORP POWER PLANT UNIT 1 INDIVIDUAL PLANT EXAMINATION F15008 3 1 4 - 5 5462 2 0F 2 L555 0F 2 + 005 54647 TAGE REVISION 1 (1122/02010
ตพละ	-	53	2	7.54	52	908	E.	D P D M
1418 196: VESSEL 196: CT3DM L3						194		PERRY NUCCON PERRY NUCCON
EX- NGT (NT (190 -US 206-20 Add 3,197)							59	
INJECTION NOT NEEREE FOLCHTHANS FOLCHTHANS FOLCHTHANS FOLCHTHANS -CV						8 (D. K. 1)		
1000 1500 1000 1500 1800 180 180 180 180 180 180 180				-	405			
LONG, TEOR CONTATIANNENT REPORAL NET ODAL				405 ×				
LOGATERM CONTAITWAT REMOVAL REMOVAL R/ C S -MC			se as					
LLOSS OF PCS TRANSLENT AND DHE STUCK STA STA T2P3		₹E dŽ						

0.4602/E1/1561 EA1 5.38 4804 8-10-85 40187 E44 + 5.00E-00





ALC: N

-

(1)

^{000-300 0 * 343 7412 8425 1* 2 26-81-9 3180 0011231113800} 0 /602/11/12865 1* 2 41 240 8 6-12-35 MOBUY 5 0 261

F REDUE No.					005 + 00	00-100	006+00	00E = 00	50E+00	006+300	001+300	cot - p0	004-200	001-00	52-328	95 - 363 - 363		
4 10 10 14	ă	ă	ĸ	8	127 0	129	0.925	129 0	9 R	10 28	132	133	0 52 p	0 8 6	Ct d AL		-	
SE OUENCE DE SCRIPTOR	8.	136-03	20-60-661	138-13-12-111	x-10-00-00-00-	136-113-122-01-1-1-1	£3-X-12-25-21-X-K3	17-61-1-01-01-01-001	1 38-13-112-112-11-K-WC	13- W-10-10-10-67	EX-38-X-10-01-60-86.	1. 38-10, 00, 00, 101-1, 10-10		28 - 2 - 1 - 2 - 2 - 5 - 98 1	138-0	2.40	DE DOV MUCLEA O DOMEN D'ANT DALT 5 IMUTVICUEL OL ANT EXAMINATION INDIVICUEL OL ANT EXAMINATION	LOSS OF FEEDWATER - FOS EVENT THEE REVISION 2 TO3/20/921
	16d	236	2	NO.	900 8	200	je .	NO.	P03	0.10		214	5.4.5	19 10 10	2 1 10	3-486 1 196 a	AL AN	4319
1.41E 5N-9E52EL 5N_6ET10N -4.3						101		2024		101			1167				NDIVIOUAL	DF FEEDWA
EX- 100121120 -25236030 -25236030											124			10 K			1912 1	1035
L (JAGE - TE RIA (JAT) Application AGE AT AGE AT AG													sis.				-	
LONG-TERM CHTNMHT HEAT HEADVAL W/ CS -MC												100	ana si ta					
ALL TERMANTE LLOW PREESSURE WARTE 120 - VA							Annalis and											
LD# PRCS2.b0 36422.10																		
E ME TIGGE NE V RIDA DE PROFESS LOTT 2 A 11 ON - X									EBz									
HIGH PRESSURE CORE CORE CORE CORE															(12)			
ACTE AND ENTRANT HEAT READVAL -UZ					5020										TD LOSS OF PCS (12)			
FEEDwelfer MEEDweler werten MEEDpuwe U3			1924												10.10	TWS [T38-0]		
REMATING AVATLABLE 															101	SMLW CL		
REACTOR SCRAW CONTRIX ROOS IT: -C																10		
and the second se									Sec									


F RE GUE NO V			005+200 Ø	40- 10d	WQ+ 3005	905 + 990	10-301 0 011	100-310 E CEL	193 D 100E +0E	005+00	1 100-03	
	ă	8	5	120	5 470	8	2	de l		n SR:		
SE GUÊNC E DE SCRIPTOR		in w	A-10-4	17-a-10-a	- 01- A 40	1 () - N - N - 1 () - N	4-2(1-3)-4(2-30)	8-01-9-W Mc We Li	3 - NH - 28 - A - 10 - W	4-11-4-46-46-4-1-1	¥	PERRY NUCLEAR DOMER DLANT UNIT : INDIVIOUAL PLANT EXAMINATION FIGURE 3 :
N W @ *	ŝ	roa	eda	*5 _d	şû	90a	188	48 00 0	50g	010	i.	A PO+
1.475 319-465551, 314-4657504 -4,1				104		1.101		N102		1.191		PERRY NUCLEA INCIVICIAL FIE LARGE LOCI
CORE NOT NOT ADD. I TO DAMAGE -C.Y												
L DNG - TE RM (ST SMMT (ST SMM) (SE MDWAL (W/ VE NT - V									ā			
CONS. TEOM DELATION DELATION NY SUC -NS -NS								C(1)*				
LUNG-TEAM CUTOMICI ACAT ACAT ACAT ACAT							wC50					
A- driawe Bersshed					401							
MIGH PRESSURE SPRAR 101				101								
104 104 100 10 10 10 10 10 10											F 0	
LIDCA LIDCA Å												

OUNDIFICENTION DELS P-19-35 WEBUN S.D. CEL 0./602/EL/N EAL S.02.38.30 P-19-35 WEBUN S.D. CEL

e

D FREDUENCY		ä	ă	ă	127 5 506+05	122 0 505+00	1.0m 0 00E+00	005-00	130 5 8% - 08	80-359 8 811	133 0 000-00	135 0 00£+00	127 0 005+00	50 00E-00	Due 0 50E+00	DUM D 00E-00	Drue D DOE+DD	00+305 0 400	130 0. 205+00	132 0 005+00	00% 0 005+00	00+300 0 EE3	135 0.00E+00	Dum 0 005+00	50mm 13 2015-028		
SE DUÉNICE DE SCRIPTOR			55-128	a-10-35	51-01-A-Wa	1.1.1.1.4.4.4.10.12	51-111-9-98-90	-11- V-Va-W (-1,1	01-9-9a-90-9a	11-88-38 KA-A-10	1-01-V-9a-ac-4a-Y	5 1 A - 48 - 26 - 9A - A - 10-	51-01-1	01-4-10	01-8-85	51-01-x-m	-01-34-8-10	EX-28-X-50	01-1-10-10	11-8#-2# 8-11-	01-3-46-48-33	1-14-14-14-1	51-01-0-w-w-1-0-0	51 01 1 mc mm + 13 D	3-15	I I PERRY NUCLEAR POWER PLANT DALT I INDIVIOUAL PLANT EXEMINATION	FIGURE 3 3 4-5 INTERMEDIATE LOCA - POS EVENT TREE DEFICION D INCODIDATE
	t	15 i Qel	5 204	5 500	2 = Q =	5 50%	P.06. 5	P07 52	15 804	15 80a	540 S	F11 51	P12 5	12 214	15 110	15 S1 d	P18 51	P17 51	018 51	13 610	020	-15 (25	15 120	15 520	15 124	R POWE	LOCA -
* 17		ł		1																				1		NUCLEA IVIOUAL	FISLOR EDIATE LD
LATE IN-VESSEL INJECTION					-	1,154		2017	L	1.102	L	16101	-	FIDE	124	L	101	KR	L	103	120	L	5118	924		V RR 34	I NI ERM
NOT VULUE RABLE 70 COMMON																											
CMT NMENT HE AD WAL W/ YENT											10												×01				
CONTATIONCIN. NEAT NE NEWAL N. SPIC										N2.16												#258	A				
CDNTA) SIMENT HEAT REMOVAL N/ CS									WC 1 B										*650								
NC) 3012233099 3012223099							WAG 1																				
CD- Jack																											
RPW DEPRE 55- UR12A1104																	×0.1										
A Wind S 3 and 3 MUC 3											1000																
SCRAW CONTROL RODS IN																									C01 -		
INTERMEDIATE LOCA																	-										

0/602/E1/21 EA1 5 51 240# 2-10-35 5 51 480# 101#7 0#6 + 0 856-008 0/602/E1/21 EA1 5 51 240# 0-10-35 MOB## 5 0 0.E1



F DE DUENCY		448 S 455-05	EQ-325	10-365	386-06	90-395	004 + 00	215-04	40-398	#0-380	246-05	eG-3e1	16.00 (P. 006-07	
004		a u u	N E E	a du	r. Bu	8 0 5	135 0	10 13 14	9 8 5	45 18 35	10 11 11	0 11 12	u H H	
SEGUENCE C^GCR1P109		1+D	110-01	169-101-81	150-UI-83-W	A-58-18-18-511	1 10 - 01 - 01 - 40 - X	110-01-02	120-01-02-01	10 41	112-122	1 (0-D1	2-12 1-20-C	PERRY NUCLEAR POWER PLANT UNIT I INDIVIDUAL PLANT EXAMINATION FIBURE 3 1 4-7 SHEET 3 OF 15 FIBURE 3 1 4-7 SHEET 3 OF 15
	•	+6a	63d	E du	#Ga	Soa	BO8	100	956	804	6 6		a a	Pr. 45
offi-3.000 3.6753.306 #GT	A-					SIA			(Int) pwd					ERRY NUCLES
MG11W71180 -\$5385430 Ada	×						×20	DF RCIC (UL	08 OFFSITE					4
SUPPRESSION POOL COOLJMS	₩.					#305		10 100P #/ 1055 DF PCIE 101	TO LOOP W/ NO ACIC OR DEFSITE PWA (UR)					
N PONER	-R1		81018		R103			R5028 T.D. L.	8192 TO LOO					
CODI 146	21-			Baban					a Nas		(2444)			
AWaus 3e000 3sensisada	-01	01 8 1 B				U313				(8) (8)	(2451) N340 S. AUS			
AC POMER ND DIV I DK DIV 3	-81									6103 I.O.	10 1000 #/ 2	DPEN (1103		
SHAN (2008 MAC TWO 590% FAIL TO SCIPACE	-P2										1024	10 1.009 #/ 1 SRV 09EN (1191)		
AND CONTRACTOR	-P3											P101 10 11	TD ATMS (T1-C)	
SCRAM CONTROL	AD05 1X												CD1 1D ATMS	
LOSS DF DFFS11E POMER	130													

F DE DUE NC Y					80-39F	60-354 •	054-300					115-311	40-320	126-10		004 - 900	
0.0.0.	ă	8	8	ð	10	18.3	0 3	ă	8	ă	×	Ŷ	1000 - 10000 - 10000 - 1000 - 1000 - 1000 - 1000 - 1000 - 1000 - 1000 -	3	×	6) 11 15	
SE DUÉ NCE DE SCRIPTOR	tet	113 Mc		11.00.00.0	111-mi-38-1-CA	11-10-10-10-10-111	Development of the	đu-514	38-20-11	11-12-12	a 18 - 28 - 28 - 51 j	111-112-180-180-1-17	1-1-2-1-80-80-1-Ch-1	0.1-1-1-10-10-11		a	PERROY NUCLEAR POWER PLANT UNTT 1 PERROY NUCLEAR POWER PLANT UNTT 1 PLANT EXAMINATION TIGNER 3 1 4-7 SWEET 2 DF 15 LOSS DF DFFSITE POWER PDS EVENT THEE
0000	104	205	E04	PUT	Stille	808	ţ,	DC:B	500	010	-1 -1 -1 -1 -1 -1 -1 -1 -1 -1 -1 -1 -1 -	() 0	El a	8 1 B	10 10 0	u n	PLAN PLAN
LATE PA-VESSEL INJECTTON						1,115							109				PERPV NUCLEAR ENDIVIDUAL P FIGURE 3 1 4
LATE RPV DRIIATION -X3 -X3							629							192			PER E
EB- BRLDWCL3R DFLDWCL3R DFLDWCL3R BRLDWC																	
INJECTION NOT NOLINEARLE TO ENTRHIE ALLUE -CV						E 4013							Cweit				
LONG-TERM CONTATIONENT SEADONL N, VENT -Y					- 23						he was as	-63					
C.DMG-TERM C.DMG-TERM HEAT REAT REPAIL M/ S P E -WS				1223							605 *						
L (MGC-15 RM CONT A 21946 MT REAT READAR W/ C S -MC			E2.33							#C03							
AL TERNATE V.CM PRESSURE WAKE-UP																	
6 46 968 40° 5 80 (1 81 2 40 1 200 98 2 40 1 2 40 1 200 - X2																	
509PP465551014 P006 C000.1945																	
DFFS11E ac POWER BECOVEAN E WEC HVAC -S22									8201								
MCC SMGR E W150 ELE RUBUTH ELE RUBUTH MVAC -H14															i dave		
LDOP T11										1040							


20090111120100 2018 0-10-05 5 52 20180 10191 200 - 1 356-001 0 /602/01/111 0A1 5 52 20180 0-10-05 40500 5 0 021

S FREGUENCY			144 D DDE+DD	111 0 006+00	95+300 8 54+	110 0 005+00	113 0 005+00	117 D DOK+00	121 0 005+50	125 0 500+00	111 0 00E+00	æ	0.1	115.00 000+000						144 D 001+00	78 0 001+00	s 0 006-00	Rees	Ø.,	5	2	a not the		B.	0 006+00	3 50 005-00	a po anc-uto	1 10 10E+00	5 0 D06+00			
	8	ð		-					es-	-					-			8	<u>8</u>	<u>.</u>		ä	24			100 PA-100-1			181	300	- ME _ 12	EB 01-18-1	10	8	144] T 3	NUT I	- A BARES & OF 3D
SEDUENCE DESCRIPTOR	THR	7.6.5 8 ~ 4	1128-4-63	1398-148	7.1.151-89-982	1110-99-86-12	1110-98-011	11120-08-0.1-80	711R-V8-L1-ML	1110-94-03	12420-32		53 30 - K2 - K2 - K2		TRUE STOL 1-ME	1188-22-23	1110-12-03	1130-46	1110-81-1	71134-BE-P-Co	1158-88-94	79-44-28-0111	1.3.50-MI-WH-MC-	1139-40-40-111	÷.:	「一日日」「日本」「日本」「日本」		11111-111-111	1111-10-10-10-10-12	13-88-98-8115	7310-81-52-51-86	7259-81-32-12-13	EX-2X-28-0111	1110-91-12-03	POWER PLANT UNIT	PLANI EXAMINATION	SHITLY N D
	104	505	End	104	554	904	204	P.08	0.04	51a	111		Contraction of the		0 976	1000000	lo Primer.			124	- acal	824	523	Sea		-	1000			26.4	e.e.a	124	Sta	96.4	a pūs	DAL PLAS	
CONTRACTOR CONTRACTOR ACAT SCHOORL W/ 95N1 Y2			Second Se			122			582						ra3								284						6#1			743			PERRY NUCLEAR	INUTATIONS -	a D'S Republic a
CDM0-1E10M CDM1A11646.51 36.807948. 87.507948. •/C.5				and the second second	w.c.13			68.38				NG41			mi 212							WC A3			ece3						10 T				d		
I.A.15 IN-WEDSEL IRORETISUME								1.1.40						139										Gella							1139						
EX- Addr 3.87													x26.0			×26													x268				×25				
LP 1 SLTE MC POME R RECOVERED RIPY F ALLUDGE						83018				#30 F					adie		9336						8/0/8			11.200 F					03188			21EB			
I ALE L'I DA HOT NUM AR PARALE TO ENTRANT TATLURE -CV			CVD.4																	Evoa																	
LONG-TERM CDNTAJTMARAT NEAT REMOVAL W/ VENT Y		1																																			
AL TE RNA TE LOM PDR 55,00E MARE - LP								¥452																	WAST												
E WE RISE NE # RIPW DE PRES- URU TATTON -X2																×22																					
51:379:46 5.53.0H 7900, 0.003:156 Mt																											#529										
LOOP -UN SUCC -UN SUCC -UN FAIL -US FAIL																			1P16																		

0 /H02/E1/11/8 EA1 5 51 100W 2+914 H088W 5 0 021








F REGUENCY				006 - 00	006+900	006 + 00	bûf opp	004 + 00	005-300	006+00	00+300	00E+03	0014-000	00E - 500	006+00	00-300			
	ð	ð	ă	1	0	0 	0.00	0 (i) ¥	1.44	0 22	180	0 EE	2 2 2 2	9 £	0	0			54
SE DOFINCE DE SURIPY DR	8+1	m († 1	73.3 - Har - R2	113 m 62 Ce	11.5. con -0.2. (n - Mc	$\sum_{i=1}^{n} -\frac{1}{2} \sum_{i=1}^{n} -\frac{1}{2} \sum_{i=1}^{n} \sum_{i=1}^{n$	11-43-09-MH 614	713-Hu-R2-C+-L1-X2	13 Here 102 - Con-103	113-14-12-48	13 10 15 No 4	2)-28-44-20-44-E1	11-22-32-22-11	DA-YO-WA-DD-AN-ETJ	E2-84-23-84-E1	113-00-02-03	PER. + HUCLEAR POWER PLANT UNIT :	INDIVISION, PLANT EVANIMATION CTOUDE 2 + +	3384 AMBAB SUG NBARS J 4- 1 2 AMBIN 30 SSG1
		202	Ego	Wilu	Spa	906	1.0.3	90.0	600	61 a	lig	2.4	1.1.1	1 1 1 1	<u>9</u> 14	91.0	R PCM	PLAN.	
KUMMO-TETAR (TANT ATAMENT READWAL W/ VENT -YZ						SA'S		Bez				187		147			R. + NUCLER	INDIVIDUR.	S OF OFFSITE
LONG-TERM CONTATINGNY REACHAL M/C 5 -MC					4.65						wC 45						E.		1.051
LATE IN-VESSEL IN-VESSEL IN-VESSEL IN-LAT							2142						0.00				L	1	
1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1																			
ER- 1000000000000000000000000000000000000									01Eu			11296			6356		-		
14,60,710A NG7 VIC VIC 46,8480,6 10,0,0,12495 F,0,11,2495 -0,0							Page												
AL TERMATE LON LON PRESSUME MARE-UP -VB					28.102									CT CT					
E we alcelve v apry ()(E proc Sys- ()(E 2 x 1) (SR																124			
AC YARAD ST DECONSTRUCT STATES													R202						
MEC Sell TCHGE AR Sell TCHGE AR HYAC							10.00										-		
100% 10% 10% 10% 113 113 113 113				110003															

D.405/E1/13 EW1 0.28 4296 0-16-82 WINGA 2.0 CE1 0.405/E1/1281/EW1 0414 0-18-82 2.83 3898 101AL CME = 0.008-805




GR.

dillo.

F RE DUE NC		3 9 THE-DB	10-300 S 051	3 0 005-50	132 0 30E+00	00+300 % %£1	135 3 34E-07		10 00E+00	0 007+05	a co£+00	0 505+50	0 006+00	C1+300 0		
	<u>ă</u>	Lan .		683	E		£5	8	R.	8	5	.3	61	<u></u>	1 1 1	15 1 1066
SE DUENCE DE SCRIPTURA		5		21-24	15-94-11	21-11-88	115-48-83	1	3	84 - No	C1 - 44 - 41	11-44-44	CA-17-6A-40	50 M M	PLANT UN	ET 7 DF PDS EVEN /08/92)
	Set L Villed	- 12-C+	en-571 E04	ega ris-wa	511 50d	\$11 90a -	P07 115	Sit Bod	\$11 BD4	511 Sid	-511 1.62	-511 Z14	P13 115-	-541 + La	PLANT E	E POMES N J 104
CONTAL INSERT				61.		cr.					(a)		8×-		PERRY NUCLES	FIGURE 3 1 4-7 546ET 7 DF 15 LOSS DF 0FFSITE POMER PDS EVENT TREE REVISION 3 (04/08/92)
1.41E 34-0155EL 344EEE110M																
EX- Addy D1 Ing [BH DAMH 334 2 I D1440 21 D1440 21 D1440 21 D1440							EOEs				900 00 00 00 00 00 00 00 00 00 00 00 00			626.8		(
PACE TON ACT NO. ACT NO. ACT NO. CALENCE FALLENC -CV		CVD4							CvDa							
ACTORNAL CONTRACTORNAL CONTRAC	AAG98					AAD3			BBOWA				¥AD9			
kerserense kerserense Erospinken kerse Hyre											10					
1000 -01 100 -02 2000 -02 2000 -02 2000 -110 -110							05				.đ.)					

F RE DUE NC Y			1 345-07	4 935-08	23 00E+00	120 2 881-08	25 SHE-10	5 ID DOE+-00	90+309 g	530 2 9er-50	133 A. DDE+00.	122 10 101 102	152 10 507 - 90	10 DOT-20	01-325 c	0 000-200	in olt-sis	90+300 d	. 00E + 200	0 301-50	
8. D 19 8	8	K.	122	ŝ,			132	132	1.24	190	66.1	681	Q.	135	128	101	3	673	81	1983	
SEGUENCE DESCRIPTOR	3	***	*****	11 - A MC	21-28-85-5-15	0.4.4×-1.1	D-W-da-Lo-M-	24-38-17-8A-8-5		19-X-10	24-38-4-5		34-51-8-0	0-X-(1-M2)	Ex-x-0	U-X-X3-MC	21-1-12-12-1-1-1	43-84-K-0	0-10-01-0	21-34-51-53-6-0	I I I PERAP MUCLERA POWER PLANT UNIT 1 INDIVIDUAL PLANE EXAMINATION FIGURE 3 1 a-7 SPEET 8 OF 35 FOR DEFETT OF POWER POWER OF 35 FOR DEFETT OF POWER OF A FOR 36 FOR 36 FOR THE STATE OF A FOR 36 FOR 36 FOR THE STATE OF A FOR 36 FOR 36 FOR 36 FOR 36 FOR 36 FOR 36 FOR 36 FOR 36 FOR 36 FOR 36 FOR
0 W B +	10d	204	£64	100	\$04	904	4.64	BO4	80d	910	164	21.4	514	14 14	510	214	613		51	20.0	EAR PD MAL PLA
LCO66-7E5M CD914,73M0ENT AGAT REMOMEL W/ MINT - Y2					42			122			0			12							CIAIONI CIAIONI STATONI
L (UHG) - TE RAM CDUAT A UHB UNT H FE AD YAR M / C S - MC				w.cas			#C29			NOR			*CR			9C36			*0.16		
LAPE JAN VESSEL JALJECTION -L.1							-114B						[1] #B						140		
uate sev organere. -X3 ou -X3											K208						×26				
N: TEDAWTE N: LDM PRESSIFY MARE -UP -YA					WA20																
V- Salati Anixe V-																					
E RE BOSE MC V SE PORESS - OH 7 ZA T LON														121							
-00% 								110907													

0/990/11119/100 091% 2-12-35 5 24 130% 101% CME x 1 896-001 0 /802/61/0 641 5 34 140% 2-12-35 4064% 5 0 (61




10. 0

and the state of the second

1

.

						Laberto Stratter Martine One Store Stratter Martine Ma
	8105					-81 -81 -81 -81 -81 -81 -81 -81 -81 -81
	10 580 W/ 1 504W					Pail: Scuel Cone Spream -UT
	103 e(3)	- Server		100		-02- 201-2000 2010-2000 2000
		R383 TU LOOM 5 3	e1039 (0 1 009 1 1			HT Parate Baratan Antobara
		SCRV W/ ND REEC DR	SCHA MY LOSS OF			Suppression (CON) Me MeS
		DH POWER (P311H)	ACIE (PIN)			-X Chang 2 (con Chang 2 2
PENARY HUGLEAR PONER PLANT UNIT 1 INUIVIOLAL PLANT EXAMINATION FIGURE 3 1 4-7 SHEET 10 OF 15 LOSS OF DEFSITE POMER PUS EVENT TREE REVISION 1 (03/13/92)						A
R POMER PL PLANT EXA A-7 SHEET E POMER PU N 1 (03/2)	- 6 8 1 8 - 10 - 481	1904 1990 1990 1990 1990	0) IN BEALL (196-	20-01 1 1 0 10-01	31 et 1	e e seo
3/92) 3/0/1/1/1/1/2/2/2/2/2/2/2/2/2/2/2/2/2/2/2		1910-01-0Q-93	ŝ			SEQUENTE
m	17 R 19 R 146 - 05	50-305 s	164 B 235-36	1794 7 3886 - 135	1999 1997 1997 1997 1997	⇒ FREQUENCY







		P12 Evf 2 33 on Date 6-1							2040541					-StdSt2	1149 10-1240
					1034									COOL TWO	Suppose Station
	8 19													K MOLAN (190	And
								1 H						AA M-12994	1.0#
					2.04A										1000 SCLOBE
			COM-											ELEE AREAS HYAE -HY	Swill TCrelie and
														-83	SEPRES-
		112				1.312								INJECTION	LATE IN-WESSEL
						<u>x</u>								-#C N/ C 2 N/ X/Mat	CONTACT MEAT
PERRY NUCLI INDIVIDU FIGURE 3 LOSS DF DFFS REVIS		B	110 1901 1909		823			123						16 MOWAL #/ 46 NT - Y2	CENT AT MAENT
L PLAN L PLAN L PLAN	10 10 10		1	01.6	1. 60a	1 803	20.7	PU6 1	503	EQ.4	5 E Dat	- Sda	1991	* 57	
FIGURE 3 1 4-7 SHEET 12 OF 15 ACCOL FLANT EXAMINATION FIGURE 3 1 4-7 SHEET 12 OF 15 ACCOL FLANT EXAMINATION FIGURE 3 1 4-7 SHEET 12 OF 15 ACCOL FLANT EXAMINATION FIGURE 3 1 4-7 SHEET 12 OF 15 ACCOL FLANT EXAMINATION	x-38-21411	11012-00-V-V-10-1.1	75912-85-9-88-19-1	44-86-6-56-21-21	38-11-68-6-69(d)1	20 17 84 8 48 17 18	TIPIZ WA V VALLS	11910-WW-Y-WB-WC-Y2	Jan RA - A - RA - ET 452	11012-05-9-98	11012 WM V	11012-W	21411	DESCRIPTOR	I SUENCE
3381	67	2 C 8 2 9	-¥2 0 0	52 0	e- 19335 0	R 132 0	0.561	133 0	130 0	127	ŷ	¥	Ŗ	• vi	0
	6 60E+66	0 00E+00	0.00E+00	2 00E × 00	1 COE+00	00+300	006 + 00	00E+00	130 0 005+00	127 0 004+00				C PEL MARK THE	F DE GUENCY









1.4.




























M









0

-1

a







			102				1			
		<u>(, 1) ()</u>								
				8					A.	
1 v 15 1 Ju 1 state 1		N/J			N I			1420		
H ALO	a 010	24-17-EX-EN-E3-08 864	PQ8 807.3-83-13-11	1-EX-EN-ELdB COA	PA-EV-EN-EIdE 904	EX-Ex-E1-00 Silve	Le-Etals F0e	2.5 - 34 - E 1 e00 2 Ded	an creat Abe	E LUB
PERRY NUCLEAR POWER PLANT UNIT I INDIVIDUAL PLANT EXAMINATION FIGURE 1 1 4-8 SHEET 11 DF 15 STATION BLACKDUT PDS EVENT THEE STATION BLACKDUT PDS EVENT THEE HEVISION I (33/*8/92)	1-11-28-68-6348	43-13-11	5-13-CI	43-1	3-42	64				

D UNDELETURATE EVI 10 22 4044 7-DI-62 NUMBLE 2 0 CEI DURATIFICATION DELS 6-16-92 2 16 DLos TDIAL CHF + 0 DOE+DOD

980 4/ 1 5049 -01 9405 -01 9405 -01 9405 -01 9405

EB-Sector 18 Annual Sector 18 Annual Band 20 Sector Sector 28 Annual Band 20 Sector Sector 20 Sector

--X3

LATE JN-NESSEL JNLELTION -L1


DAFESTEE AC HOMES ABECOMENT HADIGA ED CHENNENT FAIL HAA

L DAG - TERA CONT & TNAG (41 NG MOVAL #/ C S #/ C S


-, AS NENI NEWSWI NEWSWI TON, KTOR, MOD

DESCRIPTOR

FREDREND








1


.


A


.
















A


_


-

100b































ar.

è








188		
10231		
1000		

1.12	-	1	
-20		8.	κ.
			84
			85
			व्याः
16		22	•
. 7	-	•	

100
- 65
10.0
16
-0.8
1.000
1.52
1.457
Æ
all.
DATA
DATA
DATA
DATA
Date
Data -
Date
Dalta
Data
2 . Dal
2 . Dal
2 . Dal
1a0
1-92 Dat
1-92 Dat
04-92 Dal
-04-92 Dal
-04-92 Dal
04-92 Dal
-04-92 Dal
7-04-92 041
7-04-92 041
7-04-92 041
7-04-92 041
7-04-92 041
7-04-92 041
-04-92 Dal
PDD 7-04-92 Dat
7-04-92 041
PDD 7-04-92 Dat
PDD 7-04-92 Dat
PDD 7-04-92 Dat
13 PD0 7-04-92 Dat
13 PD0 7-04-92 Dat
13 PD0 7-04-92 Dat
13 PD0 7-04-92 Dat
13 PD0 7-04-92 Dat
13 PD0 7-04-92 Dat
13 PD0 7-04-92 Dat
13 PD0 7-04-92 Dat
PDD 7-04-92 Dat
PNDP 1 3 P00- 7-04-92 Dat
PNDP 1 3 P00- 7-04-92 Dat
N PNPP_J_3 PD0 7-04-92 Dat
UN PNDP_1_3 PDD 7-04-92 Dat
14M PNPP _ 3 P00 7-04-92 041
14M PNPP _ 3 P00 7-04-92 041
UN PNDP_1_3 PDD 7-04-92 Dat

ENTRY FROM FRONT-END GARAGE	NOT A CN1W7 BY//KGS	DATH BIATUS 41	EVENT TYPE FOR ENTRY INTACT/FAIL)	INTER ENTRY HEAT BENDER	(NTH) YEN7 1903-87E0	MPs INLEITION	DELET I PORTE	SUTHY OCAT REPORTS	DITN' HEAT READYAL	10 .200 10 .2550.	2014 C211412 (\$16041.711)	4 0	
STATE BEDLENCE	SELUCENCE.	DORK DARADI	A.1 CERE LIA WARE	HITH GURN POND COOLING	AT BEV TATLORE	7.611,080 71.68	HELINICAH INI T	4() For (600) 52902 ((100)	-82 In 92307	Section & PECESTAL CAVITY SUMME	ELMENS CONT DAMAGE	10	FR
TERIA-	CNT_BYP	CNT FAL	EVENT_IY	P SUPA_PL	CNT_ISOL	NJ_F_TI	MPWR_A_TI	SPRAY	VENT	LAT_INJ	AX_PRES	-	
								APALITON-					3 541 1 392
						PRIM REY FAL				765 (3 100 10	16	न्न आम्	
							A STATE AND AND A STATE AND A		ALC: INC. IN	1 12 12 12 12	1.158 -06	1.	3 761
								1 17 11 - 14		in and	- al Asterit		1 24
									W vieros-	111	Asterior		
								Antal Brits		113 100 100 100 100 100 100	155		4.996
						1-415-	(111)-18/7 (111)-01			1 7711-34			19 734 1 796
								1111-14		145 KKH (14	15.5 [a] 1080154 1080154		1 5.75
										100 - 12 - 13 - 13 - 14 - 14 - 14 - 14 - 14 - 14	12.4		8, 891
								HA'LHE H	115	CHAR OF THE OWNER		1 1.48	
									TTHE H	180 	ALL BIR OF	18	7.855
							WA STREET	Marriera	1.		Alwarm		0 055 1 474
									in which a		Ta Wares		0 000
										Time.	953	10.00	0.000
								And Sec. at		101 101 101 101 101 101		20	7.554 0.000
							1 362 - 18		Wine w	1 1 1 1 1 1 1 1 1		20	1.550
					100.140	1		151 - 1517 - 15	Tall State Cher-	19 Milean			6 040 0 000
						1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		$ \frac{ \frac{100347}{60} }{1000100} $. 15	111	1.00	2 010
						a tour a	1.2481-02	1 1011-08					5.504
									17 8807 76	153 15 15 15 15 15 15 15 15 15 15 15 15 15	79.0	21	0.000 2 9481
							THE METERS	- MG		165 1 2 2 2 6 2 7 2 7	76.5		6 000
									(ed 233,4-19	10 - 10 - 10 - 10	$\frac{\frac{18.4}{[m_{1}^{2}]}}{\frac{1}{r_{1,2}^{2}}}\frac{18764+56}{78764+56}$		
								1 PART 17		10.1	11, 2213, 148		1 3.45
							PRIDE BRA PAL		25x1 1 361C-00	distantes distan		122	1 200
			MRC 1 1506-06					1.3616-16	INC BORY 735	ी संग्र तर	314		
						1.1.1.11			* 1981 (199	112		1	1.011
									1181		3 3195 -38		
							tra scener			195 IAR 54	3. 134 - 13		1 (8.94) 5 (2.35)
							1.864.42			Plana an	17 1864 788	10	2.786
									187 9151-16		ANR 15		8. 85E 9.88E
										180 5 5851-00	1 100 EE 161		0 000
										The service	113 H 38		5 336
		TRIAT INTACT			T ALL DR		NO RESOLUTION	- 10			10 8685-11 169 8685-11		5 964 1 894
							1 441 7441 144			101) TEAT 101	1 8125-532	10.	0.000
				MUT AVAILABLE		1	1 MD1, 36 YELEM						
			1.000 MD WEAT	4 2054-00		5 5256 105	1.807.0174109						
				12411 ps con.11	×	1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	1. HET. DEVELOP						
						0.9401-00					(Print in		0 700 4 #48
								APRE -		Thra er	3 19 at 12 M	24	3 .498
			Areas Taske							2147-05	111 111 101 101 10		1. 399 3. 404
	1 2736-35		\$ \$74C-25				California California		1541 1 X/87-00	15 HR-0	The fail and		1. 611
										190 3192 100			
								CHEERS	1	1 N W 1	100 M - 10 00 M - 10		5 584 8 000
									(a) ARL'S	100 6 7 142 - 17	THE-ST	1.1	6.295
								Sec. 1		6 (140 (C))	1 2182-28		1.078 1.098
			1011111 ATM					1 1082-07			1 8436 (07 (5) 3462-04		1 405
			* \$458-67					1 0340-07			150 1 8141 (b)		2 330
-35											10 10 10 10 10 10 10 10 10 10 10 10 10 1		1 295 7 657
		04141 (A1530) 2 \$002-08	1.907 3 580					42		Pisaar	100 100	杨祥	1.581
		a av0a -0.6	a waak -a -							1 NOT 157	C MARTIN		0 56E
											11 12 12 12 12		9:296 5 541
			atog ph	and the second				40		TO NEW TO T	1992 Bull VII	12	
			1 1846-95							1901 1 1 2 3 6 - 1 8	JAN A		1. 226
	EVENT V/MSL BE 0 COORVOO					-				1 601 08101091	E INSTER		
	in the second				in the second second	- protect second	MARGENERATE	Dean		LANT UNIT		-	153192
						1				EXARIMATI			
									IGUAE 3				
								A T DAMA	BE STATE	GROUPING			





ADS/SRV Orientation Figure 3.2.1-1 
















































































.

























5


- 1


•

5-













CONTRIBUTION TO CORE CAMAGE BY FLOOD ZONE




 \mathbf{k}^{*}

0

CORE DAMAGE FREQ DISTRIB FIGURE 3.4.1-1





		21001 945,000	* 5 BB(10									
	No. No.		CE INVIA TO		Contractor internation	and the second second						
			כרביא הריא		-							
	21	TRAFTIC TRAFTICE				a second seco				the of the family of a	an dir Male	
	ϕ_{1}	REPORT REPORT									and shere failed	
98-387 E			and and an other states of the						AL ADALA			
9977 E		18. M.M	£.									
80-812 8												
		ALL STREET, SPACE										
11-984 1. 15-864 P	10								10.1.001	a standar tiefe		
VIC- NOT 1	24.1	A.S. 2910										
19-365 2	59.	AL MA D							-unanta			
20-368 3	1								3811 3611102			
45-375 2			(11) and 12									
11-161 1	12		A LINE CL.									
17-305-11												
15-301 1	10.	\$31 EL MES.										
80-1/5-1	14	11-21 10 10 - 41 H I	Jan and the									
81-201-2	95	NI-3010 C1 50-7611							出行法		ARTCH. DA	
相一册(1) 40-19(1)	14	82-3141 4										
10.816 1												
000 4					100910-00110-0	- BARA		wender States				
-000 18 - 000 18	16				1100 3×31 108 1			arran 1917)ar	- arma			
505 -0	11				VERTICAL SER T							
600 6	-				CARTER OF STREET			206.0464.08				
		AL REAL TO AL MAR.										
80-258 1 01-306 6	20.3	11-1010	an entry provident		The Sustainty of					-1.7114		
1. 316 0.0	10											
b idd	14											
55-259 B	1	10.0 - BOAR B	#1:351#									
49-362-2	10	-Middley -			1.11.11.11							
80-202-62	24	AD - 2010 (A)			······································							
80-318-3 8- 34- a	1	N. R. T										
14-920.1						12.041						
000 0			1						AL. 2161			
00.0 0		The Reference	10 At 2121		in the Bill				781			
	in a	SHE STREET			101.144.50165							
		A REPORT OF A R										
0.000		THE REAL PROPERTY										
11 200		105 52-8080 24										
and i		217 - 10-2004	Contraction of the second second									
R0- 202 - 5		A CONTRACTOR OF A CONTRACTOR	Berner 1831		- ALANSER							
27 986 93	51		strice g	25-2881 I		81.5.5.8.8						
0/0 0		elli peratori										
* 121-53		A Contraction of the second second	10 10 10 10 10 10 10 10 10 10 10 10 10 1		TAL AND DES							
	12 -	10.855	James and an and an	- 81-3185 i								
		AD A										
610.0	11	43-200 (4) 11-3018	M									
10-126-1	23.4				-Billing							
	51		a		Contractor and							
13-210 4		BE BELL PL. REALING										
10 10 1		84.0401 (P)										
	11	E. MILL	(R)	- nisten s								
10-261 #					Mahala	- append						
12:351 8	5	AP 2144	Section and the section of the	A	1.141-181902							
11. 100 - 10	1			0.000								
000 000	1	an and Philadele	a de									
1-302 1	1		Same Bridger									
K1 - 344 - 2	11	AL-MAC (MILLAN)			ALC: NALL							
H - HH - 2 10 - 351 - 1	1	1211 NO. 3407 C										
	14	······································										
15. 115 .2					and the set of the set of the	All and and include the	in the second second second					
15.315.2		SAUE XE CNI IVI	INSA	AWHOR	HILE SM.	HIL TONS	1051 INC	Tel Hellis	AFAL LARA	TV JUNT	DAE INCA	-WINGIT
	# 55	804 XB ("N1"1V1 8040 6 11405 4114 857 14158 3	the sub-traction in the last super-	AVUdS 2007 FRAS 200	MITEEN.	#11 <u>377N1</u> #11	CAL "1801" Ministra All All All	Tel tidfis	NEAL INSAS	THE STAND	STATE BAD	

4.0 BACK-END ANALYSIS

4.1 PLANT DATA

4.1.1 Mark III Plant Features

The Ferry Nuclear Power Plant (PNPP) Unit 1 has a General Electric BVR/6 reactor rated at 3579 MVt and a Mark III free standing steel containment. The Mark III containment system is designed to minimize the release of fission products to the environment by containing and suppressing a radioactive steam release caused by an accident.

The PNPP Mark III containment shown in Figure 4.1.1-1 consists of a concrete dr ell structure that contains the reactor vessel and the connected piping systems. The drywell is enclosed within a steel containment vessel. A suppression pool is at the bottom of the containment. The suppression pool is made common to both the containment and the drywell air volumes by three rows of horizontal vents which are installed in the drywell wall below the normal level of the suppression pool. The suppression pool water volume serves to dissipate the energy released from opened reactor safety relief valves or from a line break in the drywell. A concrete shield building surrounds the containment vessel and forms an annulus which is maintained at a slight negative pressure.

The design pressure of the Perry Nuclear Power 1'ant containment is 15 psig, and the total containment volume is comparable with a large FVR containment (1.44 million cubic feet).

Containment heat is removed with the two trains of the Residual Heat Removal (RHR) system in either the suppression pool cooling mode or containment spray mode. In the event that the RHR system fails to suppress the pressure in the containment, the containment can be vented.

To reduce the potential of a severe hydrogen combustion event during an accident, the containment has a Hydrogen Ignition System (HIS). This system is designed to prevent the bold-up of large quantities of hydrogen inside the containment. Igniters are located throughout the containment and drywell volumes.

A general comportison of design information for the Mark III containments at Perry and Grand Gulf (the NUREG-1150 plant) is presented in Table 4.1.1-1.

A detailed description of the Perry containment is provided in section 2.0 of Appendix H.1, PNPP IPE Containment Analysis.

4.1.2 Sources for Data

The Perry plant and containment specifications pertinent to the IPE Back-End analysis are included in the Modular Accident Analysis Program (MAAP) Parameter File. The entire PNPP IPE MAAP Parameter File is contained in Appendix H.5. The MAAP Parameter file includes plant and containment modeling information sections which are described in the MAAP Users Guide (EPRI 1991).

4.2 PLANT MODELS AND METHODS FOR PHYSICAL PROCESSES

The Electric Power Research Institute (EPRI) maintains a deterministic containment evaluation software code called the Modular Accident Analysis Program (MAAP). MAAP is used for the Perry Nuclear Power Plant IPE containment evaluation for the accident progression analysis, to assist in quantifying the Accident Progression Event Tree (APET), and for estimating source terms.

MAAP 3.0B BWR Version 7.02 is the basis for the Perry analysis. Two minor modifications were added to the code with the direction of Fauske and Associate, Inc. (FAI), the MAAP Maintenance Contractor to correct identified coding problems. The Perry MAAP code was validated to the FAI test cases.

4.2.1 MAAP Analysis Assumptions (Model Parameters)

The MAAP model parameters generally represent inputs to phenomenological models in which significant uncertainties exist. Variations in the values of these parameters can be made to assess the impact of uncertainties in important physical models. The best estimate values used in the Perry IPE are provided in the Model Parameters section of the PNPP IPE MAAP Parameter File, provided as Appendix H.5. These best estimate values were taken directly from the "Recommended Sensitivity Analyses For An Individual Plant Examination Using MAAP 3.0B" (EPRI 1990).

4.3 BINS AND PLANT DAMAGE STATES

4.3.1 Plant Damage State Grouping Parameters

The interface between the Front-End Analysis and the Back-End Analysis consists of a set of plant damage states (PDS). The plant damage states define a set of functional characteristics for system operation which are important to accident progression, containment failure and source term definition. Each Plant Damage State contains Front-End sequences with sufficient similarity of system functional characteristics that the containment accident progression for all sequences in the group can be considered to behave similarly in the period after core damage has begun. Each Plant Damage State defines a unique set of conditions regarding the state of the plant and containment systems, the physical state of the core, the primary coolant system, and the containment boundary at the time of core damage. The important functional characteristics for each Plant Damage State were dotermined by defining the critical parameters or system functions which impact key results. The sequence characteristics which are important are defined by the requirements of the containment accident progression analysis. These include the type of accident initiator, the operability of important systems, and the value of important state variables (e.g., reactor pressure) which are defined by system operation.

4.3.1.1 Identification of Important PDS Functional Characteristics

The accident initiators, plant systems and various possible states of the reactor system and containment (at the time of core damage), and plant operating instructions were reviewed to determine the potential impact on containment accident progression. The most important functional characteristics are listed below within functional categories.

Page 4-2



Containment Status At Core Damage Containment Intact Containment Isolated Containment Bypassed Containment Failed

Event Type At Core DAmage SBO LOOP With No HVAC ATWS Other

Power Recovery For SBO Core Lamage Sequences Before Reactor Vessel Failure Before Containment Vessel Failure No Recovery

Containment Mitigation Features Containment Heat Removal Containment Sprays Containment Venting * Pedestal Cavity Water Supply

- * Hydrogen Igniters
- * Annulus Exhaust Gas Treatment System

Reactor Pressure Vessel Status Prior To Vessel Failure Late In-Vessel Injection Available RPV Pressure

In the Perry IPE Plant Damage Stage Grouping Logic the Containment Heat Removal and Containment Spray functions were combined into one function, "Containment Heat Removal with RHR Spray Loop."

IPE preliminary evaluation of the core damage sequences indicated that a significant fraction of LOOP sequences involved the initial availability of the safe shutdown division 1 and 2 diesel generators, which later become unavailable due to the loss of MCC, Switchgear And Miscellaneous Electrical Equipment Area HVAC. Loss of HVAC sequences are conservatively modeled in the containment evaluation analysis as failing the HVAC system at time zero. The impact of tripping the thermal overload protection on Division 1 & 2 and 3 MCCs in 4.7 and 10 hours, respectively, is the loss of diesel ventilation and the postulated immediate loss of the associated diesel generator. LOOP with no HVAC sequences are similar to Station Blackout sequences (the Hydrogen Ignition System is unavailable). However, the Plant Damage State Logic Grouping distinguishes LOOP with No HVAC sequences, since the accident progression timing is substantially different. Preliminary accident progression analysis of LOOP with No HVAC sequences identified that timing of RPV Failure and Containment Failure were sensitive to whether suppression pool cooling was available for the first 4.7 hours. So, Initial Containment Heat Removal With Suppression Pool Cooling was added as a Plant Damage State functional characteristic. However, subsequent IPE examination of MCC thermal overload heating determined that this was not a contributor to core damage. Consequently, the LOOF with No HVAC core damage sequences have been deleted from the analysis. Therefore, these functional characteristics were initially modeled but are not currently used: LOOP with No

HVAC, and Initial Suppression Pool Cooling.

An examination of the above Plant Damage State functional characteristics list indicates that the following characteristics (designated above with an asterisk) were not explicitly required in the plant damage state grouping logic: (1) Pedestal Cavity Water Supply - since this is essentially the same as the Late In-Vessel Injection, except for suppression pool overflow into the drywell and pedestal; (2) Hydrogen Igniter availability, as well as (3; innulus Exhaust Gas Treatment System availability which are dependent on AC power availability.

4.3.1.2 Identification of Key Event Timing

The timing of key events such as system failure and recovery, core cooling recovery, fuel damage, and operator actions was reviewed with MAAP computer runs and discussions with plant operators.

While both the NUREG/CR-4551 Grand Gulf report (Brown 1990) and the EPRI Generic Framework for Individual Plant Examination Backend Analysis (EPRI 1990) included one time related parameter in the plant damage state grouping criteria (core melt timing), the Perry IPE c ntainment evaluation considered this information was more pertinent for use in offsite consequence analyses. Therefore, core melt timing is not included in the PE iv Plant Damage State grouping criteria.

The timing related characteristics in the plant damage state grouping logic are: Vessel Injection Failure Time, and Offsite Power Recovery Time.

The Vessel Injection Failure Time windows for SBO are:

(1) 0 - 2.8 hours	Initial loss of all RPV injection
(2) 2.8 - 4.2	Short term RCIC injection loss
(3) > 4.2	HPCS and Firewater pump injection loss

The Vessel Injection Failure Time windows for LOOP with No HVAC And With Suppression Pool Cooling Not Available are:

(1)	0 - 3 hours	Initial loss of all RPV injection
(2)	3 - 4.5	Short term RCIC injection loss
(3)	> 4.5	HPCS and Firewater pump injection loss

The Vessel Injection Failure Time windows for LOOP with No HVAC & With Suppression Pool Cooling Available are:

(1)	0 - 9.5 hours	Short term RCIC injection loss
	> 9.5	HPCS and Firevater pump injection loss

Offsite Power Recovery Time during SBO sequences with no injection and with delayed RCIC injection loss is modeled with the three following time windows:

- (1) After core damage and prior to RPV failure,
- (2) After RPV failure and prior to slow overpressurization containment failure, and
- (3) No power recovery.

Offsite Power Recovery Time during SBO sequences with delayed HPCS '-

Firewater) injection loss is modeled with the two following time windows, since the time of RPV failure is near the time of containment failure (if containment heat removal has failed):

- (1) After core damage and prior to RPV failure, and
- (2) No power recovery.

4.3.2 PDS Grouping Logic and PDS Characteristics

The Plant Damage State Grouping Logic is shown in Figure 4.3.2-1. The Plant Damage State Grouping Logic defines 75 plant damage states which distinguish the important combinations of system states that can result in distinctly different accident progress pathways; and therefore, different containment failure and source term characteristics. This logic was developed using the important functional characteristics identified above in section 4.3.1.1.

The PDS logic tree was developed with the following guidelines:

- The characteristics judged to be the most important, or on which subsequent decisions are dependent, are placed early (or left-most) in the diagram.
- Decision points toward the end of the diagram are eliminated, where possible, based on preliminary information on sequence frequencies and consideration of whether a decision branch actually results in sufficient differences in system functional states to warrant differentiation.

4.3.2.1 PDS Grouping Logic Heading Definitions

The following PDS Grouping Logic Headings are used in Figure 4.3.2-1.

CNT BYP Not A Containment Bypass Sequence

A containment bypass sequence with core damage results in a radiological release to the environment. Potential bypass sequences include the traditional Event V, Interfacing System LOCAs, and Main Steam Line Breaks.

CNT FAL Containment Status At Core Damage

The success of containment at core damage maintains the radiological boundary. The failure of containment at, or before, core damage allows an early radiological release. The failure of the containment may result in the loss of RPV injection due to the physical interaction between the containment structure and the injection - tems.

EVENT TYP Event Type: For Containment Intact Or Failed At Core Damage

If the Containment is Intact At Core Damage, the event type is classified into one of the following: SBO, LOOP No HVAC, and OTHER TYPES. If the Containment is Not Intact At Core Damage, the event type is classified as: CRITICAL ATWS, LOOP & SBO, or OTHERS. Note that for SBO initiated core damage sequences where offsite power is recovered in the Plant Damage State event tree before core uncovery, the PDS grouping for the event type at core damage would be OTHER TYPES or OTHERS, as appropriate. Also, note that Critical ATWS defines ATWS sequences in which the core is not shut down by the standby liquid control system initially in the front-end event trees or after core damage by operator recovery action in the plant damage state event trees. Therefore, all the ATWS core damage sequences which are shutdown by early boron injection are classified as OTHERS.

SUPR PL Initial Containment Heat Removal With Suppression Pool Cooling

LOOP With No HVAC sequences are subdivided into into those with initial containment heat removal and those without as: NOT AVAILABLE, and INIT SP COOLING. Initial Suppression Pool Cooling can impact the timing of RCIC failure, as well as the magnitude of the expected peak burn pressure if hydrogen generation or core concrete interaction subsequently occurs.

CNT ISOL Containment Vent Isolated At RPV Failure

Containment isolation prior to fission product release maintains containment integrity and prevents the release of fission products following core damage. Failure of the containment isolation valves to isolate and maintain containment integrity is a function of the containment penetration valve isolation reliability, as well as of the sequence type.

At the onset of a SBO sequence the AC motor operated containment isolation valves may fail "as is", if the diesel generators do not load to the divisional safety buses. At Perry the only normally open system penetrating the containment boundary and interfacing with the containment atmosphere is the Fuel Pool Cooling and Cleanup discharge penetration. All other systems with motor operated containment isolation valves either have normally closed isolation valves or are closed systems which do not interface with the containment atmosphere in the normal operating lineup. The 9.5 inch equivalent diameter Containment Pools Return line provides a release path from the upper pool skimmers to the spent fuel pool skimmers and the fuel pool cooling surge tank vent. The backup hydrogen purge line is another containment penetration which may be open about half of the time during power operation. The 2 inch diameter backup hydrogen purge line routes drywell air from the drywell to the Annulus Exhaust Gas Treatment System in the intermediate building. Following a Loss of AC Power event. these open isolation valves will be manually closed locally in accordance with the off-normal instruction. When AC power is restored, the inboard and outboard isolation valves associated with each open penetration will close with high reliability with the re-energization of the safety related division 1 and 2 buses.

For SBO sequences where the containment is intact at core damage, the isolation status of the Fuel Pool Cooling and Cleanup penetration is modeled as ISOLATED or NOT ISOLATED. For the Not Isolated status, the containment is modeled as open throughout the remainder of the sequence.

0

For Non-SBO sequences when the containment is intact at core damage, the containment isolation valves are modeled as always isolated since the relative containment isolation failure probability is much lover than for SBO sequences. For Non-SBO sequences, AC power is available and the nuclear steam supply shutoff system is available to automatically isolate the containment. If an automatic isolation signal should fail to position the associated valve closed, the ERIS computer would alert the control room (as well as the Technical Support Center) of this abnormal alignment, and manual closure would occur.

For those sequences where the containment is not intact at core damage, the functional characteristic of Containment Isolation is not pertinent to the analysis and this is not used in the grouping logic.

INJ F TIM Reactor Pressure Vessel Injection Failure Time

If the core damage sequence Event Type is SBO or LOOP With No HVAC, the RPV Injection Failure Time is classified into the following time windows.

- 1) Initial Loss of All RPV Injection
- 2) Delayed RCIC Injection Loss
- 3) Delayed HPCS (or Firevater) Injection Loss

Time windows 1), 2) and 3) are utilized for SBO, and LOOP With No HVAC sequences.

Delayed loss of RCIC injection occurs when the suppression pool temperature approaches the Heat Capacity Temperature Limit - the RPV is depressurized and the RCIC turbine becomes unavailable due to low supply steam pressure. RCIC operation time varies for each sequence type.

SBO2.8 - 4.2 hoursLOOP No HVAC - No Initial Supr Pl Clg3.0 - 4.5 hoursLOOP No HVAC - Initial Supr Pool Clg0 - 9.5 hours

PWR R TIM Offsite Power Recovery Time

Power restoration to either the division 1 or 2 safety-related bus from offsite power after core damage is classified into the following time windows.

- 1) PRIOR RPV FAIL After core damage and prior to RPV failure.
- CNTHT LIMIT After RPV failure and prior to a containment capacity overpressure threshold.
- NO RECOVERY No power recovery after core damage.

Generally recovery windows 1), 2) and 3) are utilized for the SBO sequences with the loss of all injection, and delayed RCIC injection failure sequences. Recovery windows 1) and 3) are used for SBO sequences with delayed HPCS (or Firewater) injection failure. If power is recovered before reactor vessel failure, then the AC powered injection systems can cool the core debris in-vessel and may prevent RPV failure. If power is recovered before containment failure due a gradual pressurization, then the RHR containment heat removal or venting motor-operated valves can be utilized to prevent containment failure.

SPRAY

Containment Heat Removal With RHR Spray Loop

Containment heat removal ensures that the containment pressure will be maintained below the containment capacity overpressure threshold. Containment heat removal is accomplished with a RHR heat exchanger. Containment Sprays also remove aerosols and mitigate hydrogen combustion effects.

The Containment Heat Removal With RHR Spray Loop functional characteristic is included in the logic model whenever AC power is available or recovered at some time during the later part of the sequence progression. For those sequences where the containment is not intact or the containment is never isolated, this functional characteristic is not pertinent to the analysis and is not used in the grouping logic. In these cases the conservative assumption that RHR sprays are not available is made.

VENT

Containment Heat Removal With Vent

Containment venting is accomplished with the Fuel Pool Cooling and Cleanup or Containment Spray Header vent pathways which can maintain containment pressure below the containment capacity threshold limit of 50 psig.

The Containment Vent functional characteristic is included in the logic model whenever Containment Heat Removal With Sprays is not successful and the containment is intact (and isolated) at core damage.

LAT INJ

Late In-Vessel Injection & Pedestal Cavity Supply

Successful late in-vessel injection can arrest core damage and can prevent RPV failure. In the Perry IPE Late In-vessel Injection is defined as those injection systems or alternate injection systems that are available and capable of injection when the RPV pressure is low and that initiate prior to core plate failure and continue to operate afterwards.

Conservatively those systems which be recovered after core plate failure are not considered in this analysis. Also it is postulated that if core damage occurs and the RPV is not depressurized, then late in-vessel injection is not successful. (However, these low pressure in-vessel injection systems may still be available to inject



water into the RPV and into to the pedestal cavity through the breached vessel.) For the slow overpressure containment failure sequences in the PDS event trees, the late injection function includes the impact of containment failure when determining late injection system availability.

For those sequences where offsite power is recovered, Late In-Vessel Injection is modeled with the following systems: ECCS, Condensate Transfer Alternate Injection, Emergency Service Water Cross-Tie, the electric motor-driven firewater pump, the diesel-driven firewater pump and the Perry Township Fire Department Pumper.

For sequences where all AC power is lost, and offsite power is not recovered, Late In-Vessel Injection is modeled with the following systems: the diesel-driven firewater pump, and the Perry Township Fire Department Pumper.

For sequences where all AC power is available, Late In-Vessel Injection is modeled with the following systems: Condensate Transfer Alternate Injection, Emergency Service Water Cross-Tie, electric motor-driven firewater pump, diesel-driven firewater pump, and the Perry Township Fire Department Pumper.

RX PRES RPV Depressurized During Core Damage

RPV depressurization during core damage and at the time of vessel failure effects in-vessel steam explosion phenomena and direct containment heating phenomena at vessel breach.

The RPV Depressurized During Core Damage functional characteristic is included on all Plant Damage State Grouping Logic branches.

4.3.2.3 Comparison With NUREG/CR-4551

The Perry IPE Plant Damage State grouping provides 11 questions regarding conditions prior to the initiation of core damage. The NUREG/CR-4551 Grand Gulf (Brown 1990) Accident Progression Event Tree includes 22 questions to describe conditions at the beginning of the accident. These include plant damage state grouping, evaluation of containment and drywell structural capabilities, whether the ignitors are operating and whether the containment is vented before core damage.

The Perry PDS grouping does not explicitly include a question about the availability of DC power, since this included in the PDS event tree for successful RPV Depressurization.

The Perry PDS grouping does not include a question on the number of SRVs which have failed to reclose, since core damage sequences with one or two open SRVs contribute about 3.3% of the total CDF. The Grand Gulf APET asks one question to determine if one or more SRVs fail to reclose.

The Perry PDS & uping provides one question for late in vessel injection and pedestal cavity water supply, whereas the Grand Gulf APET includes seven questions regarding the status of injection systems and alternate injection

systems.

The Perry PDS grouping provides one question regarding containment heat removal with an RHR spray loop that includes successful performance of the RHR heat exchanger. The Grand Gulf APET provides two questions: 1) Does RHR fail (heat exchangers not available), and 2) Are the containment sprays failed?

Both the Perry PDS grouping and the Grand Gulf APET include a question regarding the status of vessel depressurization.

The Perry PDS grouping indirectly includes the time of core damage for Station Blackout events events where the containment is intact at core damage by modeling the time of injection loss, and for those PDS groups for which the containment is failed at core damage; however this is not included to those PDS groups for which the containment intact at core damage and AC power is available. The Grand Gulf APET asks if core damage occurs in the short term (approximately 1 hour) or in the long term (approximately 12 hours).

The Perry PDS grouping includes a question to evaluate the isolation of the containment vent during Station Blackout sequences; if the vent is not isolated, then containment is modeled as not capable of pressurizing. The Grand Gulf APET includes two questions: 1) What is the level of pre-existing leakage of isolation failure, and 2) Is the containment not vented before core damage?

The Perry PDS grouping does not include the Grand Gulf APET question regarding the level of pre-existing suppression pool bypass through the dryvell personnel hatch.

The Perry PDS grouping does not include the condition regarding the operator actuation of the Hydrogen Ignition System before core damage, but this action in included in the Accident Progression Event Tree logic structure as event 16 which is discussed in section 4.5.2.2.

4.3.2.4 Plant Damage State Event Trees

Plant Damage State Event Trees were developed by extending the Level 1 core damage event trees with the additional PDS functional characteristics defined above to fully evaluate all the "CD" core damage sequences, and pruning the "OK" no core damage branches. The Plant Damage Event Trees developed for Level 1/2 interface are included as Figures 3.1.4-1 through 19.

The Plant Damage State Event Trees for all initiating events include the following PDS functional headings: Containment Heat Removal With RHR Spray Loop, Containment Heat Removal With RHR Suppression Pool Cooling, Containment Heat Removal With Vent, Late RPV Depressurization, and Late In-Vessel Injection & Pedestal Cavity Supply. Late RPV Depressurization during core damage (and before RPV failure) is modeled on core damage sequences where this function has not been previously applied, and also applies a human interaction recovery to those sequences where the initial depressurization attempt has failed. The Late In-Vessel Injection function includes the dependency of containment failure on ECCS and alternate injection for those sequences where both RHR and venting containment heat removal fail which can result in failure of the operating injection system.

The Station Blackout Plant Damage State Event Trees include the following unique functional characteristics: Offsite AC Power Recovery Prior To RPV Failure, Offsite AC Power Recovery Prior To Containment Failure, and FPCC Isolation Shut By Operator Or By Diesel Operation. The time of RPV failure is determined by MAAP analysis when the core plate failure occurs. Similarly, the time of containment failure is determined by MAAP analysis when the containment pressure reaches the containment overpressure threshold limit of 50 psig. Offsite power is modeled as being restored to the plant by adjusting the RPV failure and containment failure times by the time required to align the electrical system from the control room, and to align the RPV injection or RHR containment heat removal system.

The ATWS Plant Damage State Event Trees include the human interaction recovery Late SLC Injection After Core Damage to account for successful reactor shutdown after nominal core damage has occurred when RPV injection is available.

4.3.3 PDS Frequencies and Dominant Sequences

Seventy five plant damage states are used to group the Level 1 (Plant Damage State) sequences. The Level 1 plant damage state event tree sequences were assigned to plant damage states using the Plant Damage State Grouping Logic diagram (Figure 4.3.2-1). Plant damage states with frequencies less than 10° were eliminated from the back-end containment analysis. The total back-end core damage frequency is 1.27 x 10° . The back-end core damage frequency 97.2% of the front-end core damage frequency of 1.31 x 10° due to binning cutoffs.

The Dominant Plant Damage States are listed in Table 4.3.3-1, by frequency with the individual sequences contributing above 1% listed. Fifteen PDS groups represent 95% of the core damage frequency. The most dominant PDS groups are 53, 56 and 73 which represent 71% of the core damage. A general discussion of these three PDS groups is provided below.

PDS group 53, represents Non-SBO sequences with the Containment Intact At Core Damage and successful Containment Heat Removal with the RHR Spray Loop, Late In-Vessel Injection, and RPV Depressurization During Core Damage. PDS group 53 has a core damage frequency of 4.44 x 10⁻⁶ (35%). This group has 7 dominant sequences above 1% of the core damage frequency. The most dominant sequence (18%) is an ATWS (successfully shutdown with the Standby Liquid Control) Loss of Power Conversion System, failure of the Motor Feedpump, and failure to inhibit ADS. This group also includes four other (shutdown) ATWS with Loss of PCS sequences with each contributing from 1 to 5%. A (shutdown) ATWS with Loss of Feedwater and failure to inhibit ADS contributes 2%. The other dominant sequence is a LOOP with loss of all injection which contributes 1%.

PDS group 56, represents Non-SBO sequences with Containment Intact At Core Damage and successful Containment Heat Removal with the Vent, Late Injection, and RPV Depressurization During Core Damage. PDS group 56 has a core damage frequency of 3.40 x 10⁻⁶ (27%). This group has 6 dominant sequences above 1% of the core damage frequency. The most dominant sequence (9%) is a Flood in Zone 13B with failure of all injection. The second sequence (6%) is a Loss Of Instrument Air with Loss of all injection. The third sequence (3%) is a Station Blackout sequence with successful recovery of offsite power before core uncovery and subsequent loss of all injection. The fourth sequence (2%) is a Flood in Zone FlD with loss of all injection. The remaining two sequences (1.6% each)

are a Large LOCA and LOOP with failure of injection.

PDS group 73, represents sequences other than critical ATWS or LOOP & SBO with Containment Failed At Core Damage, unsuccessful Late Injection, and successful RPV Depressurization During Core Damage. PDS group 56 has a frequency of 1.22 x 10^{-6} (10%) This PDS has just 1 dominant sequence (8%), Loss of PCS and failure of containment heat removal with subsequent failure of all late injection.

7 of the 15 dominant PDS groups (63, 65, 66, 67, 69, 71 and 73) represent Containment Failed Before Core Damage sequences with a frequency of 2.86 x10⁻⁶ (22.5%). All the PDS groups associated with Containment Failed Before Core Damage contribute to a frequency of 2.90 x 10⁻⁶ (22.8%). This 22.8% Containment Failed Before Core Damage is comprised of: Critical ATWS (4.4%) with dominant PDS groups 63, 65 and 66, LOOP & SBO (4.3%) with dominant PDS groups 67 and, and OTHERS (14%) with dominant PDS groups 71 and 73.

5 of the 15 dominant PDS groups (1, 25, 32, 36 and 9) represent Station Blackout core damage sequences. The total core damage frequency in these five SBO PDS groups is 5.57×10^{-7} (4.4%). All the SBO PDS groups (1 through 47) comprise 9% of the core damage frequency.

4.4 CONTAINMENT AND DRYWELL FAILURE CHARACTERISTICS

4.4.1 Containment Failure Modes

The Perry Mark III steel containment is designed to withstand an internal pressure of 15 psig and an external differential pressure of 0.8 psi. The potential containment and drywell failure modes under severe accident loading conditions were analyzed by the Perry containment architect for the IPE containment evaluation (Gilbert/Commonwealth 1992).

The Perry Mark III steel containment failure modes are the following:

- 1. Dome Knuckle
- 2. Dome Apex
- 3. Cylinder
- 4. Personnel Air Lock
- 5. Equipment Hatch (Bolts)
- 6. Penetration P123
- 7. Penetration P205
- 8. Penetration P414
- 9. Anchorage, Steel
- 10. Anchorage, Concrete

Penetration failures (at P414, P205 and P123) are most likely and are expected to commence progressively in size with increasing pressure after leakage initiation. Failure at all containment failure modes, other than the steel and concrete anchorage, results in a release into the shield building through a failure located above the suppression pool. The less likely failure of the containment anchorage can result in gross failure of the containment vessel at the basemat foundation which can impact RPV injection line integrity and suppression pool inventory, as well as provide a radiological release pathway from the drywell to the environment with no pool scrubbing.



The .usults of the Gilbert/Commonwealth containment failure modes analysis are provided in Table 4.4.1-1 and are summarized below. For a more complete disrussion refer to the Perry IPE Containment Capacity Analysis included as Appendix H.1.

The Dome Knuckle and Dome Apex failure modes result in rupture of the steel shell and consequential loss of pressure through the rupture opening. The Cylinder failure mode would result in gross rupture with a rapidly progressing failure area and an associated rapid depressurization of the containment.

The Personnel Air Lock failure mode results in leakage through the inflatable seals for failures occurring below the median failure pressure and rupture through the blown out seals for failures occurring above the median failure pressure.

The Equipment Hatch failure mode results in leakage through the seals for failures occurring below the median failure pressure and gross rupture (from hatch bolt failure) for failures occurring above the median failure pressure.

Penetration failure modes (associated with penetration P123 - RCIC Pump Discharge and RHR Spray, penetration P205 - Fuel Transfer Tube, and penetration P414 - Feedwater) commence with a small leakage area of about 5 square inches which increases with containment pressure to an area of about 30 inches.

Anchorage failure modes (associated with the 288 steel anchors and the adjacent basemat foundation concrete wedge) are modeled simplistically as resulting in gross failure of the containment vessel. This failure would be sudden with no yielding and could be progressive around the containment.

Failure of the Perry Mark III containment would result in pressurization of the shield building annulus which has silicone foam seals around pipe i netrations and neoprane expansion joints between building gaps. Failure of the low pressure rated silicone foam seals could route the steam release and radionuclides into the LPCS and HPCS pump rooms.

The Containment Capacity Analysis characterized the expected type of failure for each failure mode as: leakage, rupture, or gross rupture. Leakage was defined as an area of approximately 0.1 square feet which results in slow depressurization. Rupture was defined as an area from 0.1 to 7.0 square feet. Gross rupture was defined as an area of greater than 7.0 square feet. The Expected Types of Containment Failure are summarized in Table 4.4.1-2.

It is the containment evaluation identified the anchorage failure modes as at and generally classified the containment failure type as either failure includes piping penetrations, the personnel airlock, and the equipment hatch. Also, because of similar failure characteristics (i.e., failure occurs in the containment gas space above the suppression pool) the dome knuckle, dome apex and cylinder failure modes are also combined with the penetration modes.

4.4.2 Drywe? ailure Modes

The Perry III drywell is designed to withstand an internal pressure of 30

psid and and external pressure of 21 psid.

The drywell failure modes are:

Drywell wall
 Drywell of
 Drywell head
 Drywell equipment hatches
 Drywell personnel airlock

The analysis of the capacities of the above failure modes determined that the most significant is the drywell head. Internal pressure impacts all 5 failure modes; whereas, external pressure impacts failure modes 3 thru 5.

The results of the Gilbert/Commonwealth drywell failure modes analysis are provided in Table 4.4.2-1.

4.4.3 Containment Overpressure Fragility

A composite containment fragility curve was calculated using the methodology described in IDCOR Technical Report 10.1 Appendix B, Methodology Used to Generate Fragility Curves to Describe Containment Overpressure Failure Modes Suitable for Use n Probability Risk Assessment (IDCOR 1983).

The Containment Overpressure Fragility curve is provided as Figure 4.4.3-1. The Containment Overpressure Fragility curve exhibits a 1% probability of failure at 50 psig, a 5% probability of failure at 53.5 psig, a 50% probability of failure at 64.3 psig, and a 99% probability of failure at 79 psig. The containment pressure of 50 psig (with a 1% probability of failure) is defined to be the containment capacity overpressure threshold limit and is used to conservatively estimate the time of containment gradual overpressure failure in event trees and plant damage state event trees.

4.4.3.1 Slow Overpressure Conditional Probability of Anchorage Failure

The conditional probability for anchorage failure given slow overpressurization containment failure is 0.15. The Containment Capacity Analysis characterization of penetration failure states that early containment penetration failures which occur below the median failure pressure of each failure mode would initiate as a small leak that would breach the containment boundary but would not terminate the slow pressure increase. Containment failure leakage size is expected to increase to a larger leakage size in proportion to the increase in containment pressure toward the median failure pressure until the leakage from containment balances the steam generation rate. The Perry IPE calculated a best-estimate weighted average of the conditional probability of anchorage failure over the pressure range for the most likely containment failure modes (the 3 piping penetrations) of 70 to 80 psig where the expected leakage size of about 0.1 square foot was adequate to vent decay heat.

4.4.3.2 Fast Overpressure Conditional Probability of Anchorage Failure

The fast overpressure conditional probability of enchorage failure was examined to address the additional likelihood of anchorage failure due to fast pressure rises from uncontrolled hydrogen combustion for peak pressures above 79 psig,



where 99% containment failure is expected to occur. When the hydrogen ignition system is unavailable and uncontrolled hydrogen combustion overpressurization may occur, containment failures up to the size of a gross rupture (characterized with a lover bound of 7 square feet) do not significantly reduce the expected peak pressure rise. Expected burn pressures from hydrogen combustion would continue to individually challenge the concrete anchorage (with a 92 psig median failure pressure) and the steel anchorage (with a 135 psig median failure pressure) even if containment failure occurs at other failure locations. The expected hydrogen combustion peak pressures during a severe accident (without continuously available hydrogen ignitors) can range upward to 200 psig. Overpressurization Failure Mode is applied to hydrogen combustion Fast containment failures to determine the conditional probability of anchorage containment failure as a function of the peak burn pressure. For a complete discussion of hydrogen combustion analysis refer to sections H.3.3, H.3.6 and H.3.10 in Appendix H.3, PNPP IPE Accident Progression Event Tree Description.

The Fast Overpressure Conditional Probability of Anchorage Failure curve is provided as Figure 4.4.3-2. The Fast Overpressure Conditional Probability of Anchorage Failure curve exhibits a 26% conditional probability of anchorage failure at 80 psig, a 10% conditional probability of anchorage failure at 92 psig, and a 95% conditional probability of anchorage failure at 125 psig.

4.4.4 Containment Overpressure Failure Impact on RFV Injection

The containment overpressure failure impact on RTV injection is modeled in the front-end event trees and in the back-end accident progression event tree. The front-end event trees include the functional heading, Core Not Vulnerable To Damage, after the functional headings: Long-Term Containment Heat Removal - RHR, and Long-Term Containment Heat Removal - Venting. Given failure of Long-Term Containment Heat Removal, the functional event tree heading, Core Not Vulnerable to Damage, defines the susceptibility of the core to damage as a result of containment slow overpressure failure degrading the RPV injection system which was initially modeled as successfully maintaining adequate core cooling. The accident progression event tree similarly evaluates the impact of containment hydrogen combustion fast overpressure failures prior to RPV failure, and at RPV failure on the RHR containment spray and RPV injection systems.

The Perry IPE assessed the impact of containment failure from slow overpressurization before core damage on the operating RPV injection system, by accounting for the following factors that can degrade RPV injection sources: containment failure mode, injection system piping disruption, and injection system degradation due to environmental conditions. Special decomposition event trees are used to quantify the event tree heading. Core Not Vulnerable To Damage, for the following four RPV injection cases (shown in Figures 4.4.4-1 through 4.4.4-4): HPCS, low pressure ECCS, Injectic. Through the Feedwater Line, and Injection (from sources) Outside the Auxiliary Building.

The event tree for the Quantification of Core Not Vulnerable To Damage starts with the Containment slow overpressure conditional probability of 0.15 for anchorage failure and 0.85 for penetration failure.

The likelihood of injection system piping being disrupted due to anchorage failure was assigned a probability of 0.9 since there is a small likelihood that anchorage failure may occur without gross containment movement. The likelihood

of injection system piping being disrupted due to containment penetration failure for the case of Injection Through the Feedwater Line was assigned a probability of 0.05 since the failure of the feedwater penetration P414 has a small likelihood of causing structural disruption.

The likelihood of RPV injection system degradation due to environmental conditions was assessed for each of the four cases. HPCS failure due to the steam release through a penetration failure was assigned a probability of 0.5. Low Pressure ECCS failure due to steam release through a containment penetration failure was characterized as somewhat less likely with a probability of 0.3, since only the LPCS pump room has penetrations that lead directly to the shield building annulus. However, low pressure ECCS failure due to steam release from anchorage failure was characterized as having a higher failure potential and assigned a probability of 0.5. Failure of Injection Through The Feedwater Line was not considered credible due to the remote location of the associated condensate and feedwater pumps and assigned a probability of 0.0. Also, to account for structural failure of Injection Through The Feedwater Line associated with penetration failures in close proximity a probability of 0.05 was assigned. Failure of Injection Outside the Auxiliary Building was assigned a probability of 0.0 due to the remote location of the firewater pumps.

The Cv, Core Not Vulnerable To Damage failure probabilities were calculated for the following raw injection failure cases given failure of containment.

CV	-	HPCS	- 10	0.57
CV	-	Low Pressure ECCS		0.40
CV	-	Alt Injection Thru the Feedwater Line	491	0.18
CV	(10)	Alt Injection Outside the Auxiliary Bldg	10	0.14

4.4.5 Drywell Overpressure Fragility

A Drywell Overpressure Fragility curve was developed to support the evaluation of the impact of wetwell hydrogen combustion overpressurization on drywell integrity. This curve was developed using the Perry estimated mean failure pressures for external loading and the drywell failure mode uncertainties applied in the 1985 Kuosheng Nuclear Power Station Probabilistic Risk Assessment (ROC AEC).

The Drywell External Overpressure Fragility surve is provided as Figure 4.4.5-1. The Drywell External Overpressure Fragility surve exhibits a 5% probability of failure at 47.5 psid, a 50% probability of failure at 70.8 psid, and a 95% probability of failure at 95 psid.





4.5 CONTAINMENT EVENT TREES

4.5.1 Containment Severe Accident Analysis

The Perry IPE back-end analysis of a Mark III containment is developed to address the recommendations provided in the Generic Letter 88-20, Appendix 1, "Guidance of the Examination of Containment System Performance." To best transpose the severe accident analysis phenomenological framework and the associated quantification data of the Grand Gulf NUREG/CR-4551 evaluation (Brown 1990) and model the many dependencies associated with containment loading mechanisms such as steam gen ration, hydrogen generation and combustion, and the subsequent variations in pr isure and temperature within the containment, the generalized event tree proce for, EVNTRE was selected. EVNTRE (Griesmeyer 1989) was developed at Sandia National Laboratories for use in probabilistic risk analyses of severe accident progression for nuclear power plants, and was used in 'he Grand Gulf evaluation and which supported the final NUREG-1150 report (NRC 1989).

The Perry Accident Progression Event Tree (APET) is a concise version of the Grand Gulf NUREG/CR-4551 APET. The Perry APET consists of 68 questions or events that address four general time periods of severe accident analysis.

- Plant Damage State conditions prior to the initiation of core damage.
 events identify important plant damage state functional characteristics. The Plant Damage State Grouping Logic developed in section 4.3.2 is applied in the APET as the initial plant conditions.
- 2) Early accident progression from the beginning of core damage to just before vessel breach or Reactor Pressure Vessel (RPV) failure. 18 events analyze accident progression with regard to in-vessel cooling, hydrogen combustion before RPV Failure, and the impact of early containment failure on injection systems and RHR spray piping.
- 3) Intermediate accident progression from immediately before RPV failure to the time of significant Core Concrete Interaction (CCI). 24 events analyze accident progression from just before RPV failure with regard to drywell failure, hydrogen combustion at or near the time of RPV failure, pool bypass before or near the time of RPV failure, and the impact of containment failure on injection systems and RHR spray piping.
- 4) Late accident progression during CCI. 15 events analyze accident progression after RPV Failure with regard to pedestal failure from concrete erosion, late hydrogen combustion and slow overpressurization (from steam and non-condensible gases) containment failure, and late pool bypass from hydrogen combustion and other processes.

The 68 questions or events included in the Perry APET are listed in Table 4.5.1-1. These events are discussed in Section 4.5.2.2 along with the branch definitions. The Perry APET program input data file is provided in Appendix H.2. PNPP IPE APET Program. But Data File. A detailed description of the how the branch probabilities and assigned to the APET events is presented in Appendix H.3. PNPP IPE APET pescription.

4.5.1.1 Grand Gulf NUREG/CR-4551 Comparison

The Grand Gulf NUREG/CR-4551 APET consists of 125 questions covering the same four general time periods:

- Initial, 22 events describe the conditions at the beginning of the accident including plant damage state grouping, evaluation of containment and drywell structural capacities, whether the ignitors are operating and whether the containment is vented.
- 2) Early. 25 events for this period consider the status of important systems (coolant injection, AC power, hydrogen ignition system, etc.), the composition of the containment and drywell atmosphere, hydrogen burn phenomena (ignition and loads), and the containment and drywell response to the containment loads.
- 3) Intermediate. 41 events evaluate this intermediate period. The potential for in-vessel core damage arrest (no vessel failure) is addressed in this time period. The majority of these questions address the loads accompanying vessel breach and the containment and dryvell structural response to these loads. Hydrogen combustion is considered at the time of vessel breach and during the time period before significant CCI commences.
- 4) Late. 27 events evaluate containment failure from hydro in combustion and late over-pressurization, as well as drywell fail from hydrogen combustion and reactor pedestal failure.

4.5.2 Summary of Event Tree Structure

4.5.2.1 Perry Summary Containment Evaluation Tree

The Ferry APET analysis structure is graphically described with two figures: the previously described the Plant Damage State Grouping Logic, Figure 4.3.2-1, and by the Summary Containment Event Tree, Figure 4.5.2-1. These figures provide a transparent graphical summary of the entire containment evaluation analysis framework. The Summary Containment Event 'ree provides a general summary of the APET analysis framework over the three accident time periods: early, intermediate and late. The Summary Containment Event Tree is constructed to allow the various accident progression pathways to be easily understood since the detailed APET, because of its size, cannot be graphically presented. The Perry Summary CET is a graphical enhancement aid only, and is not used for quantification.

The Summary CET contains the most important events considered in the Level 2 analysis and summarizes possible paths that an accident sequence may progress slong. The Summary CET headings are the most important "events" which can lead to significantly different outcomes in the sequence progression where the major outcomes of interest relate to the ng and mode of containment failure and the atmospheric release of radionuclide The Summary CET events were chosen to:

 represent the uncertainties in physical phenomena (e.g. hydrogen combustion containment loading)

- 2) assess operator recovery, and mitigation action : and
- assess consequential failure of important systems given the occurrence of specific physical phenomena (e.g. hydrogen burns) or as a result of the general severe accident environment.

The 10 Perry Summary Containment E and Tree Headings are described below in section 4.5.2.2, Accident Progression Event Description. These events are also contained as distinct headings in the Perry IPE APET. The number for these events in the Perry APET is shown along with the APET events which these events are dependent.

Each Summary Containment Event Tree Heading is evaluated by a Decomposition Event Tree (DET) that includes the important APET events. (Reference DET Figures 4.5.2.2.1-1 through 4.5.2.2.10-1.) The DET logic structure depicts a general characterization of the APET and is provided to enhance the severe accident technological transfer.

4.5.2.2 Accident Progression Event Description

APET Events 1 through 11 are the Plant Damage State Grouping Logic parameters. The Plant Damage State parameter APET Events are fully described in section 4.3.2, PDS Grouping Logic and PDS Characteristics.

APET Events 12 through 68 are presented with a summary discussion below. A complete description of the APET Events is provided as Appendix H.3, PNPP IPE APET Description.

4.5.2.2.1 Debris Cooled In-Vessel

(APET Event 15)

This event assesses the probability that the damaged core can be cooled in-vessel and vessel failure prevented. To be coolable, a source of in-vessel injection with flow in excess of that required to remove decay heat must be available. If the reactor has not been shutdown by Standby Liquid Control during ATWS sequences, the current Plant Emergency Instruction (PEI) does not ensure containment integrity will be maintained, and late in-vessel cooling is assumed not possible. When the debris is cooled in-vessel the threat to containment integrity will be reduced since: 1) the potentially large containment and drywell loads resulting from mechanisms at vessel failure (fuel coolant interaction, and vessel blowdown) will not be present, and 2) the production of combustible gases (d2 and CO) and other non-combustible gases (CO2) resulting from debris/concrete attack will be avoided.

Figure 4.5.2.2.1-1, Debris Cooled In-Vessel Decomposition Event Tree (DET) shows the general characterization of this portion of the APET.

This APET event, Debris Cooled In-Vessel, is dependent on the following Events in the Perry APET.

APET Event 12. Late RPV Low Pressure Injection Available

Three Branches:

Summary Branches:

WATER INJECTION

1) Water Injection Available to the RPV

Page 4-19

2) No Injection Available

3) Critical Reactivity Condition

This event assesses if low pressure water injection to the reactor vessel can be established subsequent to core damage, but prior to reactor vessel failure. It should be noted, that CRD injection is not credited as a source of late injection. A separate branch is developed for the Critical (non-shutdown) ATVS sequences with failure of Standby Liquid Control.

APET Event 13. RPV Depressurized During Core Damage

Two Branches:

Summary Branches:

LOV PRESSURE 1) RPV Depressurized During Core Damage HIGH PRESSURE

2) RPV Not Depressurized

In-vessel cooling requires that the reactor pressure vessel be depressurized to permit the low pressure Lat -Injection systems to provide flow to the reactor core.

APET Event 14. Debris Mass Molten at RPV Breach

Two Branches:

Summary Branches:

1) Large Mass Molten Debris in Lower RPV 2) Small Mass Molten Debris in Lower RPV

LARGE DEBRIS SMALL DEBRIS

The mass of molten debris in the reactor vessel lower head is a key factor in determining the probability of successful in-vessel cooling.

APET Event 15. Debris Cooled In-Vessel

Two Branches;

COOLED INVESSEL

NOT COOLED

Summary Branches:

1) Debris Cooled In-Vessel 2) Debris is t Cooled

The Debris Cool-d In-Vessel event determines the probability that the debris is cooled in-V ssel (and reactor vessel failure is prevented). The In-Vessel coolation probability is determined as a function of debris mass, and late injection availability. If the reactor has not been shutdown during ATWS sequences and containment is failed at core damage, then late in-vessel cooling is assumed not possible.

A special case is led to consider the impact of an ATWS Alternate Shutdown modification th the following two elements.

1) A PEI change to direct RPV Power/Level be controlled just above the Minimum Steam Cooling Water Level when containment pressure control is challenged. The reduced reactor power will enable successful containment heat removal with venting, and reactor steady state operation ...en the RPV injection is through the feedwater spargers. RPV injection through the feedwater spargers when the RPV water level is deliberately lowered will provide a high rate of heat



NO TRIECTION CRITICAL ATVS transfer in the shroud annulus, and reduce the subcooling of the core inlet water such that limit cycle reactor power oscillations will be prevented.

2) A plant modification to add alternate shutdown capability.

4.5.2.2.2 Mode Of Containment Failure Before RPV Failure (APET Events 24,25)

These events assess the probability that gradual steam overpressure or early hydrogen combustion results in one of several possible modes of containment failure.

A description of the Perry containment failure modes is provided in Appendix H.1, Perry Nuclear Power Plant Individual Plant Examination Containment Capacity Analysis. This containment capacity analysis is fully discussed in section 4.4, Containment and Drywell Failure Characteristics. The failure modes which make the largest contribution to the probability of failure (i.e., those with the lowest strengths) are as follows:

- 1) Several small/intermediate size penetrations
- 2) Containment equipment hatch
- 3) Basemat anchorage of the cylinder containment shell

The most important failure modes identified in the containment capacity analysis were the failure of the fuel transfer tube penetration and failure of the containment shell anchorage in the basemat. The penetration failures are characterized as being a leak type failure (nominal leakage area of 0.1 square fior or less) up to pressures of about 64 psig, and of rupture type (nominal leakage area of between 0.1 and 7.0 square feet) for pressures in encess of 54 right the failure of the containment shell anchorage would involve gross intiger and the opening of a gross rupture area (greater than 7 square feet).

The we ipment hatch and penetration containment failure modes are combined together, since for these (relatively non-energetic) failure modes, the releases are into the containment shield building annulus gas space above the annulus concrete. The anchorage failure mode may be quite energetic with the failure location below the suppression pool water level and with the possibility of significant gross movement of the containment shell accompanied by loss of suppression pool water and/or disruption of ECCS suction and injection lines which penetrate the containment steel liner pressure boundary. Additionally, failure of the anchorage would result in flooding of the annulus with the potential to flood the LPCS and HPCS pump rooms.

For a Mark III containment, the possibility of hydrogen (deflagration and detonation) combustion occurring prior to reactor vessel failure with a sufficiently high pressure to rail the containment (or drywell) must be examined for sequences where the hydrogen ignitors are either not available during Station Blackout sequences, and for recovery of AC power sequences where the plant emerg "cy instruction inhibits ignitor operation when the hydrogen concentration cannot be determined. The human interaction, failure to initiate the Hydrogen Ignition System, is included in sequences when AC power is available. Very early hydrogen burns with sufficiently high intensities to seriously challenge containment integrity are considered not credible for sequences with the Hydrogen Ignition System (HIS) continually on based on test

Figure 4.5.2.2.2-1, Mode of Containment Failure Before RPV Failure DET, shows the general characterization of this portion of the APET. This DET provides additional information regarding hydrogen combustion. The containment hydrogen concentration is provided as a function of containment steam concentration and fraction of zirconium inventory reacted in-vessel. Also, this DET uses three informational headings after the Large H2 Burn to show the theoretical Adiabatic Isochoric Complete Combustion Pressure, the Burn Efficiency Factor, and the summary Expected Peak Burn Pressure.

The Mode of Cuntainment Failure Before RFV Failure is determined by APET events 24 and 25, which are dependent on the following Events in the Perry APET.

APET Event 16. Hydrogen Ignition System Available

Two Branches:

Summary Branches:

1)	Hydrogen	Ignition	System	Off	HIS	OFF
		Ignition			HIS	ON

With the hydrogen ignition system in operation it is assumed that controlled hydrogen combustion will preclude the build-up of hydrogen concentrations whose combustion would threaten containment integrity. Since the hydrogen ignition system requires AC power, station blackout results in loss of the ignitor system. When AC power is available, the human interaction, operator fails to initiate hydrogen ignition system, is modeled to evaluate this action which is initiated when the RPV water level decreases below Level 1, 16.5 inches above the top of the active fuel.

APET Event 17. Containment Vent Isolated Before RPV Failure

Two Branches:

Summary Branches:

Containment Vent Isolated Before RPV Failure ISOLATED
 Containment Vent Not Isolated NOT ISOLATED

This event summarizes whether the containment vent path is isolated before RPV failure for SBO sequences. The most likely mechanism for loss of isolation at the Perry plant is for the normally open Fuel Pool Cooling and Cleanup (FPCC) vent path to fail to isolate following a station blackout. The FPCC path is utilized in the Plant Emergency instruction for containment venting. AC power is equired to automatically isolate this containment penetration. If both motor operated isolation valves fail to close, manual isolation is estimated to be performed within 90 minutes. This human interaction is modeled as operator fails to close FPCC Outboard Isolation - G41-F145.

APET Event 18. Mode Of RHR Spray Operation Early

Three Branches:

Summary Branches:

Controlled Spray Operation
 Normal Spray Operation

CONTROLLED DESIGN COOLING



data.

3) Sprays Not Available

NO SPRAY

This event summarizes whether the RHR sprays are available for containment heat removal when hydrogen combustion may occur. This event determines when RHR spray is available from the Plant Damage State initial condition, containment heat removal with RHR Spray Loop, and further considers whether offsite power is available during SBO sequences.

This event further allows for the assessment of a Plant Emergency Instruction enhancement regarding controlled cooling spray operation. Controlled cooling spray operation mode is directed at controlling the containment spray cooling rate (by regulating the RHR heat exchanger bypass flow and/or the RHR spray flow) such that the cont inment atmosphere steam concentration would be optimally maintained during the absence of hydrogen igniter operation to prevent or mitigate hydrogen deflagrations and detonations. When containment pressure is above 30 psig, controlled spray can prevent deflagrations by maintaining the containment steam concentration above the steam inerting limit for hydrogen combustion (55 volume percent) and controlling containment pressure below the emergency procedure pressure limit of 40 psig. When containment pressure is < 30 psig, controlled spray can mitigate the expected deflagration burn pressure. The controlled cooling spray operation mode is not evaluated in the base case APET.

APET Event 19. Containment Steam Concentration Before RPV Failure

Six Branches:

Summary Branches:

1)	0-15	Volume	Percent	Steam	0-15%
2)	15-25	Volume	Percent	Steam	15-25%
3)	25-35	Volume	Percent	Steam	25-35%
4)	35-45	Volume	Percent	Steam	35-43%
5)	45-55	Volume	Percent	Steam	45-55%
6)	> 55	Volume	Percent	Steam	> 55%

This branch assesses the containment steam concentration during core damage before RPV failure. The probability of hydrogen burn ignition and the efficiency of the burn (considered in subsequent events) are dependent upon the branch taken under this heading. The containment steam concentration is a function of the mode of spray operation, the sequence type, the time of injection failure and whether the containment is intact at core damage. The steam concentration regime probabilities used for the various cases are estimated using MAAP results for each case and considering the variability of suppression pool temperature (since assuming a high initial temperature may be non-conservative for hydrogen combustion during SBO).

APET Event 20. Fraction Zirconium Inventory Reacted In-Vessel

Three Branches:

Summary Branches:

1)	33%	Core	Inventory	Zirconium	Oxidized	33%
2)	22%	Core	Inventory	Zirconium	Oxidize	22%
3)	11%	Core	Inventory	Zirconium	Oxidized	11%

The fraction of zirconium reacted in-vessel is used to determine the concentration of hydrogen in containment during core damage before RPV failure. Three discrete regimes are used to represent the range of in-vessel zirconium oxidation. These regimes are representative of the amounts estimated in the NUREG/CR-4551 Grand Gulf analysis (Provn 1990). The Perry IPE fraction of zirconium inventory oxidized probabilities are estimated using specific MAAP calculations for a spectrum of sequences (considering local blockage and no channel blockage).

APET Event 21. Small Burns At Low H2 Concentration

Two Branches:

Summary Branches:

No Small Burns Occur
 Small Burns Occur

NO SMALL BURNS SMALL BURNS

Burns which are ignited at low hydrogen concentrations (< 8%) will not threaten the containment integrity. For sequences with the hydrogen ignitors available it is assumed that the hydrogen will always burn at low concentrations or as diffusion flames. Furthermore, it is assumed that once one burn has ignited that all subsequent burns (through the time of vessel failure) will be small. This latter assumption, based on results from Grand Gulf (Brown - 1990), assumes that a burn will ignite transient combustibles in containment which will serve as an ignition source for future burn events without the HIS operable. (Since the Perry containment is maintained in accordance with a strict cleanliness standard, the impact of this transient combustible assumption is examined in the APET parameter sensitivity avalysis in section 4.6.2.) For sequences without the HIS the probability of igniting a small burn is a function of the sequence type (i.e., SBO or not SBO), the time of injection failure, and whether AC power recovery occurs prior to RPV failure for SBO sequences. In addition, a steam concentration in excess of 55 volume percent is assumed to inhibit ignition of small burns.

APET Event 22. Large H2 Burn During Core Damage

Two Branches:

Summary Branches:

No Large Burns Ignited
 Large Burn Ignited

NO BURN IGNITED LARGE BURN IGNITED

This even: assesses whether a large burn is ignited in the containment during core damage. Ignition of a large burn is assumed to be precluded by operation of the HIS, by ignition of a small burn or by a steam concentration in excess of 55 volume percent. The probability of igniting a large burn is a function of the containment steam concentration and hydrogen concentration. In addition to evaluating the probability of igniting a large burn this event sets the values of two EVNTRE parameters. Parameter 1 is the peak containment pressure for the burn and Parameter 2 is the pre-existing pressure in containment prior to the burn. These parameters are used in subsequent events o estimate the probabilities of containment and drywell failure given that a large burn has occurred. The values of these parameters, like the ignition probability, are a function of the containment steam and hydrogen concentrations.



APET Event 23. Hydrogen Detonation Containment Failure Before RPV Failure

1964		100						
Tw	Ph	34	97.5	3.77	れわ	100	ES ::	π.
2 W.	6.1	3.2	4.4	3.1.1	- 11	SC .	20	*.

Summary Branches:

1)	H2	Detonation.	Containment	Failure		DET CF
2)	No	Detonation	Failure			NO

Given that a large hydrogen burn is ignited, this event assesses the probability the burn transitions to a detonation and the defonation results in containment failure. If a large burn was not ignited then a detonation cannot occur. Based on Grand Gulf (Brown - 1990) it is assumed that the containment is inert to detonations if the steam concentrations is above 35 volume percent or if the containment hydrogen concentration is less than 12 volume percent. The probability of a hydrogen burn failing containment is a function of the containment hydrogen and steam concentrations, whether AC power recovery occurs, and whether sprays are available.

APET Event 24. Containment Failure Before RPV Failure

Two Branches:

Summary Branches:

1)	Containment	Failure	Before	RPV	Failure	FA	ILURE
21	No Containme	nt Fails	ire			NO	FAILURE

This event assess whether containment failure occurs before core damage due to gradual steam overpressure or during core damage as a result of a hydrogen combustion. If the containment is failed at core damage, then this is sorted as containment failure. If a hydrogen detonation containment failure occurred, then this is sorted as containment failure. If a large hydrogen burn occurred, then this event compares the expected peak containment pressure for the burn (Parameter 1) with the containment fragility curve and determines the split fraction of containment failure.

APET Event 25. Mode of Containment Failure Before RPV Failure

Two Branches:

Summary Branches:

- ANCHORAGE PENET-DOME/NO CF
- Anchorage Containment Failure
 Penetration-Dome Containment Failure
 - or No Containment Failure

This event determines the probability of anchorage containment failure given containment failure due to gradual overpressure or deflagration, and assigns detonation containment failure sequences and no containment failure sequences to the second branch.

The IPE evaluation of containment failure modes analysis determined that two appropriate classifications of failure mode for the APET are: anchorage and penetration. Since detonation failures are expected to result in containment shell failure in the upper containment dome, this suffix has been added to the general penetration containment failure class.

Note that the above two categories of containment failure modes can be

expanded into three containment failure modes (anchorage, penetration-dome, and no containment failure) by including the previous event. Containment Failure, in an event case logic structure. Thus, APET Event 24 (Containment Failure Before RPV Failure) and Event 25 (Mode of Containment Failure Before RPV Failure) are referenced as assessing the probability of the possible modes of containment failure in the introduction of this section.

For gradual steam overpressure containment failure before core damage, the estimated conditional probability of 0.15 is assigned for anchorage failure. All detonation failures are considered most likely to occur in the dome region and are sorted to the penetration-dome or no containment failure category. For sequences where the containment has failed by a hydrogen burn the expected peak containment pressure from the burn is used to estimate split fraction of anchorage failure. The individual fragility curves for the dominant failure modes are used to determine the conditional probabilities for each failure mode as a function of the failure pressure.

4.5.2.2.3 Injection & Spray Failure Due To Containment Failure Before RPV Failure

(APET Event 29)

This event assesses the probability that containment failure causes the loss of all in-vessel injection and the failure of the RHR containment spray system for sequences where hydrogen combustion and ATWS gradual steam overpressure occur. The PDS Event Trees include the impact of gradual overpressure containment failure on Late Injection for all event types except Critical ATWS.

The containment sprays represent an effective fission product mitigation feature which can significantly limit atmospheric releases of radionuclides. Containment sprays will be particularly important for sequences where suppression pool bypass has occurred, since the sprays then represent the only remaining major engineered safety system which can significantly mitigate radionuclide releases.

The mechanisms associated with containment failure which may cause failure of in-vessel injection and/or the containment spray system include:

- Movement of the containment shell and failure of in-vessel injection lines at/near penetrations in the shell containment.
- Release of hot containment gases and radiation into regions of the auxiliary and intermediate buildings, or to outside the plant with critical injection components which may impair equipment and prevent operator access to align and maintain running equipment.
- 3) Loss of suppression pool water (as result of anchorage failure).

Figure 4.5.2.2.3-1, Injection & Spray Failure Due To Containment Failure Before RPV Failure DET shows the general characterization of this portion of the APET.

The APET event, Injection & Spray Failure, is dependent on the following Events in the Perry APET.

APET Event 26. Containment Failure Before RPV Failure

Impact on ECCS Injection & Spray Piping

Two Branches:

	гу		

and the second s	A.A	ALC: 1		400 1 10	
	Bull of the second	12 4 44	- Bro 2001	10.01 5 1	5.5 8.4
1)	5463	F 1 D	3.11.6	7.21.2.1	111

NO	P/	IL	TRE
			12120
FAI	1.1	JRE	

2) Failure of ECCS Injection & Spray Piping

This event assesses the probability that either the dynamic forces or movement of the containment which occur at containment failure are sufficient to disrupt the injection and spray system piping. Disruption of this piping is expected to be a serious threat for containment anchorage failure.

APET Event 27. Containment Failure Before RPV Failure Impact On ECCS Injection & RHR Spray Motors

Two Branches:

Summary Branches:

1) No Failure

NO FAILURE FAILURE

2) ECCS Injection & Spray Motor Failure

This event assesses the probability that leakage of water, steam or hot gases from containment into the auxiliary building which occur at containment failure cause failure of the injection and/or spray system motors.

APET Event 28. Containment Failure Before RPV Failure Steam or Radiation Release Impact On Firewater Injection

Two Branches:

Summary Branches:

1)	No Failure			
		Firewater /	Alternate T	niection

NO FAILURE

2) Failure of Firewater Alternate Injection FAIL

This event assesses the probability that leakage of steam or radionuclides from containment failure or containment venting into the plant or outside the plant will limit personnel access to the firewater system and result in failure to perform required local manual actions to initiate, or to assure continued operation of firewater alternate injection.

APET Event 29. Injection & Spray Failure Due To Containment Failure Before RPV Failure

Two Branches:

Summary Branches:

1) Injection & RHR Spray Failure INJ & SPRAY FAILURE 2) No Failure NO FAILURE

Event 29 event summarizes the results of the prior three events in the APET.

4.5.2.2.4 Drywell Failure At/Near RPV Failure

(APET Event 39)

A number of possible mechanisms have been identified which may lead to drywell failure at the time of RPV failure. These include alpha mode steam explosion failures (which by definition fail the drywell and containment), in-vessel steam explosions which fail the lower RPV head, overpressure failure of the pedestal wall, ex-vessel steam explosion in the pedestal cavity, drywell overpressure failure, and a large hydrogen burn in containment.

Loss of drywell integrity results in bypass of the suppression pool and removes the suppression pool from the radionuclide release pathway to the environment.

Figure 4.5.2.2.4-1, Drywell Failure At/Near RPV Failure DET, shows the general characterization of this portion of the APET.

This APET event, Drywell Failure At/Near RPV Failure, is dependent on the following Events in the Perry APET.

APET Event 30. Alpha Mode Steam Explosion Dryvell and Containment Failure

Two Branches:

Summary Branches:

Summary Branches:

SMALL VF

ALPHA

NO ALPHA

Alpha Mode Failure
 No Alpha

This event assesses the probability that an in-vessel steam explosion occurs with sufficient energy to rupture the upper head of the RPV and create a missile with sufficient energy to fail the drywell and containment. The probability of an in-vessel steam explosion being triggered has been shown to be dependent on whether the RPV has been depressurized.

APET Event 31. Mode of In-vessel Steam Explosion Bottom Head RPV Failure

Four Branches:

 1) Alpha Mode Failure
 ALPHA

 2) No RPV Failure In-Vessel Steam Explosion
 NO FAILURE

 3) Large Bottom Head Breach RPV Failure
 LARGE VF

Large Bottom Head Breach RPV Failure
 Small Lower Head Breach RFV Failure

This event assesses the probability that an in-vessel steam explosion occurs with sufficient energy to rupture the lower head of the RPV. This event further differentiates between large (2 square meters) and small (0.1 square meter) vessel failure sizes. As noted previously the probability of an in-vessel steam explosion being triggered has been shown to be dependent on the RPV pressure.

APET Event 32. RPV Failure Mode & Failure Size

Four Branches:

1) Alpha Mode Failure

- 2) No RFV Failure Debris Cooled In-Vessel
- 3) Large Bottom Head Breach RPV Failure

4) Small Lower Head Breach RPV Failure

ALPHA NO FAILURE LARGE VF SMALL VF

Summary Branches:



Given that the debris is not cooled in-vessel, and that the RPV has not been previously failed by an alpha mode failure or by a steam explosion induced lower head failure, this event determines the probability of large (2. square meters) and small (0.1 square meters) vessel failure sizes due to thermal attach on the lower head.

APET Event 33. Water in Pedestal at RPV Failure

Four Branches:

Summary Branches:

1)	Flooding	+ Continu	ing Injection	FLD + INJ
2)	Residual	RPV Water	+ Continuing Injection	RPV + INJ
3)	Flooding			FLOODING
4)	Residual	RPV Water	Only	RPV WATER

Water in the reactor pedestal cavity at the time of RPV failure can impact the accident progression in several ways. With water in the pedestal cavity there is an increased potential for steam explosions (or rapid stoam generation) which may threaten the integrity of the pedestal. Water in the cavity early also enhances the possibility that the debris will be coolable.

The branch definitions are summarized above. Pedestal cavity flooding occurs as a result of pressurization of the wetwell (such as by boiling of the suppression pool or by a hydrogen burn), depression of the pool level on the wetwell side of the suppression pool and overflow of the suppression pool into the dryvell. Continuous injection to the pedestal cavity results from the addition of injection to the vessel following vessel breach. Residual RPV water refers to the water remaining in the RPV which is discharged from the RPV coincidentally (or following) expulsion of the core debris in the lower RPV head.

APET Event 34. Pedestal Failure Due to Overpressure at RPV Failure

Two Branches:

Summary Bianches:

1)	Pedestal Failure Due	to Overpressurization	PEDESTAL FAIL
25	No Pedestal Failure		NO FAILURE

Given that the debris is not cooled in-vessel, and that the RPV has not been previously failed by an alpha mode failure, this event determines the probability of overpressurization of the pedestal resulting from RPV depressurization and quenching of the debris. Pedestal structural failure would occur if: 1) the RPV is pressurized and a large RPV breach size occurs, 2) the RPV is pressurized and the pedestal cavity is flooded, and 3) the RPV is depressurized, the pedestal cavity is flooded and a large RPV breach size occurs.

APET Event 35. Pedestal Cavity Steam Explosion

Two Branches:

Summary Branches:

STM EXPLOSION

1) Large Ex-vessel Steam Explosion

Page 4-29

2) No Large Ex-vessel Steam Explosion NO FAILURE

This event assesses the probability of a large steam explosion occurring in the pedestal cavity following vessel failure. For sequences where the debris is cooled in-vessel and lover head failure does not occur, then an ex-vessel steam explosion will not occur. For sequences where an in-vessel steam explosion has failed the vessel, it is assumed that a large ex-vessel steam explosion cannot occur.

APET Event 36. Pedestal Failure Due To Steam Explosion

Two Branches:

Summary Branches:

1) Pedestal Failure Due to Steam Explosion PEDESTAL FAIL 2) No Pedestal Failure Due To Steam Explosion NO FAILURE

This event assesses the probability of a steam explosion failing the pedestal. Two failure mechanisms are considered. If an in-vessel steam explosion has caused a large breach in the lower reactor vessel head then it is considered possible that a large missile could be created (from part of the vessel lower head) which could cause failure in the pedestal wall. The second failure mechanism involves a steam explosion in the lower pedestal cavity which generates a shock wave which exceeds the impulse load capacity of the pedestal wall.

APET Event 37. Drywell Failure Due To Pedestal Failure

Two Branches:

Summary Branches:

DW FAILURE 1) Drywell Failure Due To Pedestal Failure 2) No Drywell Failure Due To Pedestal Failure NO FAILUES

Given that pedestal failure bas occurred this event assesses the probability that pedestal failure causes loss of drywell integrity.

APET Event 38. Dryvell Overpressure Failurs at RIV Failure

Two Branches:

Summary Branches:

1)	Drywell	Overpressure	Failure	DW	FAILURE
		ell Overpress		NO	FAILURE

This event assess the probability that drywell overpressure failure will occur following RPV failure. In order for drywell pressurization to challenge drywell integrity, the RPV must be at high pressure at vessel failure.

APET Event 39. Dryvell Failure At/Near RPV Failure

Two Branches:

Summary Branches:

1) Dryvell Failure

2) No Dryvell Failure

DW FAILURE NO FAILURE

This summary event assesses the probability that drywell failure will occur following RPV failure. This event considers drywell failure resulting from alpha mode steam explosions, pedestal failure and overpressure failure.

4.5.2.2.5 Mode Of Containment Failure At/Near RPV Failure APET Events (44,45)

These events assess the probability of containment failure and the mode of containment failure at or within an hour of reactor pressure vessel failure. Containment failure at RPV failure can potentially result from a combination of energetic processes and events which may occur at reactor vessel breach. These processes and events include hydrogen combustion, and a large in-vessel steam explosion causing an alpha mode containment failure.

For the Perry AFET, steam explosion induced (alpha mode) containment failures are also considered to result in a catastrophic rupture of the containment. Postulated alpha mode containment failures result from large coherent in-vessel steam explosions which fail the reactor vessel and generate a missile (from part of the reactor vessel upper head) with sufficient mass and energy to fail (the drywell and) containment. There is a substantial body of evidence to suggest that in-vessel steam explosions do not represent a credible threat to early containment failure (i.e., the probability of early containment failure from in-vessel steam explosions is negligibly small). This opinion appears to be shared by the authors of Appendix 1 to Generic Letter 88-20. However, if this event should occur, it can result in a large and early environmental releases. Therefore, this event is included in the Perry IPE APET.

Experimental evidence and calculations have shown that steam explosions are unlikely at elevated pressure; therefore, the probability of an alpha mode containment failure should be significantly less for high pressure sequences than for low pressure sequences.

Figure 4.5.2.2.5-1, Mode of Containment Failure At/Near RPV Failure DET, shows the general characterization of this portion of the APET. This DET provides addition information regarding hydrogen combustion. The containment hydrogen concentration is provided as a function of containment steam concentration and fraction of zirconium inventory reacted in-vessel. Following this, three informational headings show the theoretical Adiabatic Isochoric Complete Combustion Pressure, the Burn Efficiency Factor, and the summary Expected Peak Burn Pressure.

The Mode of Containment Failure At/Near RPV Failure is determined by APET events 44 and 45, which are dependent on the following Events in the Perry APET.

APET Event 40. Containment Steam Concentration At/Near RPV Failure

Six Branches:

Summary Branches:

1)	0-15	Volume	Percent	Steam		0-15%
2)	15-25	Volume	Percent	Steam		15-25%
3)	25-35	Volume	Percent	Steam		25-35%
4)	35-45	Volume	Percent	Steam		35-45%
5)	45-55	Volume	Percent	Steam		45-55%
6)	> 55	Volume	Percent	Steam		> 55%

This branch assesses the containment steam concentration at or near RPV failure. The containment steam concentration is a function of the mode of spray operation, the event type type, the time of injection failure and whether the containment is intact at core damage.

APET Event 41. Fraction Zirconium Inventory Reacted At/Near RPV Failure

Three Branches:

Summary Branches:

1)	33%	Core	Inventory	Zirconium	Oxidized	33%
2)			Inventory			22%
3)			Inventory			11%

The fraction of zirconium reacted in-vessel is used to determine the concentration of hydrogen in containment at or near RPV failure. Three discrete regimes are used to represent the range of in-vessel zirconium oxidation. These regimes are representative of the amounts estimated in the NUREG/CR-4551 Grand Gulf analysis (Brown 1990). The fraction of zirconium oxidized probabilities are estimated using specific MAAP calculations for a spectrum of sequences (considering local blockage and no channel blockage).

APET Event 42. Hydrogen Ignition Sources Available at RPV Failure

Two Branches:

Summary Branches:

1)	No Hydrogen Ignition Sources	NO IGN SOURCE
	Hydrogen Ignition Sources Available	IGNITION SOURCE

With a continuous ignition source available in containment (at the time of RPV failure) it is assumed that controlled hydrogen combustion (or small hydrogen burns) will preclude the build-up of hydrogen concentrations whose combustion would threaten containment integrity. A continuous ignition source is assumed to be available if the hydrogen ignition system is operating or if a burn in containment has already occurred during core damage. In the latter situation it is assumed that the prior burn which has occurred will result in ignition of combustible materials in containment which will act as ignition sources. Additionally, this event includes the recovery human interaction to place the hydrogen ignition system in service late.

APET Event 42. High Pressure Melt Ejection

Two Branches:

Summary Branches:

1) High Pressure Melt Ejection OccursHPME2) No High Pressure Melt Ejection OccursNO HPME

This event assesses whether a high pressure melt ejection occurs from the reactor pedestal cavity following vessel failure. For HPME to occur the RPV pressure must be elevated (above several hundred psi) at the time of vessel failure. HPME involves the entrainment and fragmentation of the debris in the pedestal cavity and transport of the debris throughout the drywell. If the drywell has failed then an HPME event can provide an



ignition source for hydrogen in the containment.

APET Event 43. Large Hydrogen Burn At/Near RPV Failure

Two Branches:

Summary Branches:

1) No Large Hydrogen Burn Ignited	NO LRG BURN IGN
2) Large Hydrogen Burn Ignited	LG BURN IGN

This event assess whether a large hydrogen burn is ignited in containment following RPV failure. If a continuous ignition source is available, then a large hydrogen burn is assumed to be prevented. Also if the steam concentration is above 55%, then the containment atmosphere is inert to hydrogen burns. The probability that a hydrogen burn is ignited is a function of the following parameters: containment steam concentration, containment hydrogen concentration (which is dependent on the fraction of zirconium reacted), Drywell failure, High Pressure Melt Ejection, and AC Power Recovery.

Forty eight cases (various combinations of the parameters listed above were identified to perform the quantification). In addition to assessing the probability of ignit on this event also sets two EVNTRE parameter values which are used by subsequent events: peak hydrogen burn pressure (parameter 2) and containment base pressure prior to the burn (parameter 4).

APET Event 45. Hydrogen Detonation Containment Failure At/Near RPV Failure

Two Branches:

Summary Branches:

1)	Detonation Containment	Failure	DET CF
	No Containment Failure		NO

Given that a large burn was ignited in containment following RPV failure this event assesses whether the burn transitioned to a detonation and whether containment failure resulted from the detonation impulse loading. If no large burn was ignited or if the containment atmosphere was inert to detonations (> CD% steam concentration) then no detonation was assumed to occur. The probability of a hydrogen detonation occurring is taken to be a function of the steam concentration, the hydrogen concentration, whether power recovery occurs and whether sprays are initiated during this time period.

APET Event 46. Containment Failure At/Near RPV Failure

Two Branches:

Summary Branches:

11	Containment Failure	FAILURE
	No Containment Failure	NO FAILURE

This event assesses whether containment failure occurs following RPV failure as a result of a hydrogen burn or alpha mode steam explosion. If a hydrogen detonation has occurred which fails the containment then containment failure has occurred. If a large hydrogen burn was ignited then this event compares the peak containment pressure for the burn

(Parameter 2) with the containment fragility curve and determines the probability of containment failure.

APET Event 47. Mode of Containment Failure At/Near RPV Failure

Two Branches:

Summary Branches:

1)	Anchorage Contain	nment Failur	e	ANCHORAGE	
2)	Penetration-Dome	Containment	Failure	PENET-DOME/NO	CF
	or	No	Containmen	t	Failure

This event determines the probability of anchorage containment failure given containment failure due to hydrogen deflagration, and assigns alpha mode and detonation failure sequences and no containment failure sequences to the second branch. For sequences where the containment has failed by a hydrogen burn the peak containment pressure from the burn is used to estimate the probability of anchorage failure. The individual fragility curves for the dominant failure modes are used to determine the conditional probabilities for each failure mode as a function of the failure pressure.

4.5.2.2.6 Pool Bypass Before/Near RPV Failure

(APET Event 49)

Fission product scrubbing in the suppression pool is an effective fission product mitigation mechanism. However, if the release pathway bypasses the suppression pool this mechanism is not effective. Pool bypass may result from a number of causes. These include: 1) structural failure of the drywell, 2) Drywell vacuum breaker failure, 3) loss of suppression pool water below the level of the horizontal vents or the SRV quenchers, and 4) other failure processes.

Drywell structural failure may result from transient over-pressurization of the drywell or wetwell resulting in a sufficiently high drywell/wetwell differential pressure to cause failure of the drywell head, ceiling or walls. Failure of Drywell vacuum breaker may occur during hydrogen combustion. Loss of suppression pool water may result from containment anchorage failure in the pool region.

Figure 4.5.2.2.6-1, Pool Bypass Before/Near RPV Failure DET, shows the general characterization of this portion of the APET.

This APET event, Pool Bypass Before/Near RPV Failure, is dependent on the following Events in the Perry APET.

APET Event 48. Drywell Failure Due to Containment Hydrogen Burn Before/Near RPV Failure

Two Branches:

Summary Branches:

1)	Drywell Fa	ilure Due To	Hydrogen Burn	DRYVELL	FAILURI
2)	No Drvwell	Failure		NO DW FA	ILURE

Given that a large hydrogen burn has occurred during core damage or at RPV failure this event assesses whether drywell failure results from excessive differential pressure across the drywell boundary. For cases where a large



hydrogen burn has occurred two parameters have been set which give the peak burn pressure in containment during the burn and the containment pressure prior to the burn. It is assumed that the drywell pressure remains constant during the burn in containment. Given the value of these two parameters the peak drywell differential pressure is calculated and compared against the drywell fragility curve in a user function to estimate the probability of drywell structural failure.

APET Event 49. Pool Bypass Before/Near RPV Failure

Two Branches:

Summary Branches:

1) Pool Bypass

POOL BYPASS NO FOOL BYPASS

2) No Pool Bypass

This event assess the probability that pool bypass will occur prior to, or at, RPV failure. This event considers pool bypass resulting from drywell failure resulting from processes occurring within the drywell structure, drywell failure form hydrogen combustion in the containment, pool bypass due to containment anchorage failure, drywell vacuum breaker failure due to large hydrogen burns, and other bypass failures.

4.5.2.2.7 Inject & Spray Failure Due To Containment Failure At/Near RFV Failure (APET Event 53)

This event assesses the probability that containment failure causes the loss of all in-vessel injection (assuming in-vessel injection has not previously failed) and failure of the RHR containment spray system. The containment sprays represent an effective fission product mitigation feature which can significantly limit atmospheric releases of radionuclides. Containment sprays will be particularly important for sequences where suppression pool bypass has occurred, since the sprays then represent the only remaining major engineered safety system which can significantly mitigate radionuclide releases.

The mechanisms ascociated with containment failure at/near RPV failure which may cause failure of in-vessel injection and/or the containment spray system are the same as those discussed above in section 4.5.2.2.3, Injection & Spray Failure Due To Containment Failure Before RPV Failure.

Figure 4.5.2.2.7-1, Injection & Spray Failure Due To Containment Failure At/Near RPV Failure DET, shows the general characterization of this portion of the APET.

This APET event, Injection & Spray Failure Due To Containment Failure At/Near RPV Failure, is dependent on the following Events in the Perry APET.

APET Event 50. Containment Failure At/Near RPV Failure Impact On ECCS Injection And Spray Piping

Two Branches:

Summary Branches:

1)	No Piping	Failure		NO FAILURE
2)	Failure o	f ECCS Injection	& Spray Piping	FAILURE

This event assesses the probability that either the dynamic forces or

movement of the containment which occur at containment failure are sufficient to disrupt the injection and spray system piping. Disruption of this piping is expected to be , serious threat for containment anchorage failure.

APET Event 51. Containment Failure At/Near RPV Failure Impact On ECCS Injection and Spray Motors

Two Branches:

Summary Branches:

1) No Motor Failure

NO FAILURE

2) ECCS Injection and Spray Motor Failure

This event assesses the probability that leakage of vater, steam or hot gases from containment into the auxiliary building which occur at containment failure cause failure of the injection and/or spray system motors and related components.

APET Event 52. Containment Failure At/Near RPV Failure Steam and Radiation Impact on Firewater Injection

Two Branches:

Summary Branches:

1) No Failure

NO FAILURE ON FAILURE

2) Failure of Firewater Alternate Injection

This event assesses the probability that leakage of radionuclides from containment into the plant or outside the plant will limit personnel access to the firewater system and result in failure to perform required local manual actions to initiate, or to assure continued operation of the firewater alternate injection.

APET Event 53. Injection & Spray Failure Due To Containment Failure Before/ 'sar RPV Failure

Two Branches:

Summary Branches:

1) No Injection & Spray System Failure NO FAILURE 2) Injection Or Spray System Failure FAILURE

Event 53 event summarizes the results of the prior three events in the APET.

4.5.4.8 Pedestal Failure Due To Core Debris Concrete Interaction

(APET Event 55)

This event assesses whether pedestal failure occurs as a result of sidewards core concrete attack in the pedestal cavity eroding the pedestal wall to a sufficient depth that the structural integrity of the pedestal wall is compromised. Failure of the pedestal wall may result in loss of support to the RPV and result in gross motion of the RPV. This motion may result in damage to the drywell or to containment penetrations.

The amount of radial erosion will be a function of the type and extent of core





concrete attack that occurs, the ratio of radial to downwards concrete attack and the failure depth for the pedestal wall.

Figure 4.5.2.2.8-1, Pedestal Failure Due To Core Concrete Interaction DET, shows the general characterization of this portion of the APET.

This APET event, Pedestal Failure Due To Core Concrete Interaction, is dependent on the following Events in the Perry APET.

APET Event 54. Type of Core Debris Concrete Interaction

Four Branches:

Summary Branches:

1) CCI In A Dry Pedestal Cavity	DRY-CCI
2) Rapid CCI With an Overlying V	later Layer FAST-WET
3) Slow CCI With an Overlying Wa	ater Layer SLOW-WET
4) NO CCI With Debris Cooled	NO-CCI

This event determines the probability of various types of CCI which may occur in the pedestal cavity following RPV failure. If no water is in the pedestal cavity prior to RPV failure and water is not supplied following RPV failure then dry CCI will occur. If a small amount of water is in the pedestal cavity prior to RPV failure but a continuing supply of water is not available then the debris/concrete attack may be delayed until the water pool is boiled away. (This case has been conservatively combined with DRY CCJ). For cases where a large pool of water has entered the drywell prior to RPV failure or where a continuous supply of water is available to the pedestal following vessel failure then a pool of water will cover the debris. Depending upon the surface area of the debris, the debris particle size and the effective upward heat transfer rate the debris may be cooled or CCI may occur. The last three branches assess the rate of CCI given a debris pool which is covered by water. The probabilities for the types of CCI were estimated using MAAP for a series of cases.

APET Event 55. Pedestal Failure Due to Core Debris Concrete Interaction

Three Branches:

Summary Branches:

1)	Fedestal Failure At RPV Failure	VESSEL BREACH
2)	Pedestal Failure After RPV Failure	AFTER VB
3)	No Pedestal Failure	NO FAILURE

Given a type of CCI determined in the previous event, this event assesses whether pedestal structural failure from CCI radial erosion of the pedestal wall will occur.

4.5.2.2.9 Mode Of Late Burn And Overpressure Containment Failure

(APET Events 64,65,66)

These events assess the probability (and mode) for containment failures which occur late in the accident sequences. These events assess containment failures resulting from hydrogen combustion and detonation and from gradual overpressurization due to steam and non-condensible gas production.

Figure 4.5.2.2.9-1, Mode of Late Burn & Overpressure Containment Failure DET, shows the general characterization of this portion of the APET. This DET provides addition information regarding the Expected Peak Burn Pressure during hydrogen combustion.

The Mode of Late Burn & Overpressure Containment Failure is determined by APET events 64, 65 and 66; which are dependent on the following Events in the Perry APET.

This event is dependent on the following Events in the Perry APET.

APET Event 56. Mode Of RHR Spray Operation Late

Three Branches:

Summary Branches:

Controlled Spray Operation
 Normal Spray Operation

3) Sprays Not Available

CONTROLLED DESIGN COOLING NO SPRAY

This event assesses whether the RHR sprays are available for containment heat removal when hydrogen combustion may occur late in the accident sequence. This event determines when RHR spray is available from the Plant Damage State initial condition, containment heat removal with RHR prey loop, and further considers whether offsite power is available during 580 sequences. It further allows for the assessment of a Plant Emergency Instruction enhancement for controlled cooling spray operation previously discussed in APET Event 18.

APET Event 57. Hydrogen Ignition Sources Available Late

Two Branches:

Summary Branches:

1) No Hydrogen Ignition Sources

NO SOURCE

2) Hydrogen Ignition Sources Available

With a continuous ignition source available in containment it is assumed that controlled hydrogen combustion (or small hydrogen burns) will preclude the build-up of hydrogen concentrations whose combustion would threaten containment integrity. A continuous ignition source is assumed to be available if the hydrogen ignition system is operating. Since there may have been a substantial time period between RPV failure and the time when late combustion may occur, earlier burns are not considered to provide a reliable ignition source for late burns (and thus ensure that only small burns would occur late).

APET Event 58. Containment Steam Concentration Late

Six Branches:

Summary Branches:

1)	0-15	Volume	Percent	Steam		0-15%
2)	15-25	Volume	Percent	Steam		15-25%
3)	25-35	Volume	Percent	Steam		25-35%
4)	35-45	Volume	Percent	Steam		35-45%
5)	45-55	Volume	Percent	Steam		45-55%

6) > 55 Volume Percent Steam

This branch assesses the containment steam concentration late in the accident. The probability of hydrogen burn ignition and the efficiency of the burn are dependent upon the branch taken under this heading. The containment steam concentration is a function of the mode of spray operation, the sequence type, the time of injection failure and whether the containment is intact at core damage. The steam concentration regimes probabilities for the various cases are estimated using MAAP results for each case.

APET Event 59. Hydrogen Combustion Before/At RPV Failure

Two Branches:

Summary Branches:

> 552

Early Burn Before/At RPV Failure
 No Early Burn

EARLY BURN NO EARLY BURN

This event summarizes whether an earlier burn in containment has occurred. This information is used to assess the late hydrogen concentration in containment.

APET Event 60. Containment Effective Hydrogen Concentration Late

Six Branches:

Summary Branches:

1)	< 4	Volume	Percent	dydrogen		< 4%
2)	4- 8	Volume	Percent	Hydrogen		4- 8%
3)	8-12	Volume	Percent	Hydrogen		8-12%
4)	12-16	Volume	Percent	Hydrogen		12-16%
5)	16-20	Volume	Percent	Hydrogen		16-20%
6)	> 20	Volume	Percent	Hydrogen		> 20%

This branch assesses the containment effective hydrogen concentration late in the accident sequency (which includes the carbon monoxide produced during CCI). The probability of hydrogen burn ignition and the efficiency of the burn are dependent upon the branch taken under this heading. The containment hydrogen concentration is a function of the mode of CCI, and whether a hydrogen burn occurred early in the sequence. The hydrogen concentration probabilities were estimated using MAAP calculations for a spectrum of sequences (considering local blockage and no channel blockage).

APET Event 61. AC Power Available Late

Two Branches:

Summary Branches:

1)	AC	Power Availab.	le Lat	te.		
23	No	AC Pover Avai	lable	Late		

This event summarizes whether AC power is available late in the sequence. AC power will be available late if AC power was never lost or if AC power was initially lost but was recovered. This information is used to assess the potential for hydrogen ignition late in the sequence. APET Event 62. Large Hydrogen Burn Late

Two Branches:

Summary Branches:

1)	No Large Hydrogen Burn Ignited	NO BURN
	Large Hydrogen Burn Ignited	LARGE BURN

This event assess whether a large hydrogen burn is ignited in containment late in the accident sequence. If a continuous ignition source is available, then a large hydrogen burn is assumed to be prevented. Also if the steam concentration is above 55% then the containment atmosphere is inert to hydrogen burns. The probability that a large hydrogen burn is ignited is a function of the following parameters: containment steam concentration, containment hydrogen concentration, and AC power availability.

Fifty four cases (various combinations of the parameters listed above were identified to perform the quantification). In addition to assessing the probability of ignition this event also sets two EVNTRE parameter values which are used by subsequent events; peak hydrogen burn pressure (parameter 5) and containment base pressure prior to the burn (parameter 6).

APET Event 63. Hydrogen Detonation Late Containment Failure

Two Branches:

Summary Branches:

1) Hydrogen Detonation Containment Failure DET CF 2) No Failure NO

Given that a large burn was ignited in containment late in the sequence this event assesses whether the burn transitioned to a detonation and whether containment failure resulted from the detonation impulse loading. If no large burn was ignited or if the containment atmosphere was inert to detonations (> 35% steam concentration) then no detonation was assumed to occur. The probability of a hydrogen detonation occurring is taken to be a function of the steam concentration, the effective hydrogen concentration, whether AC power recovery occurs, and whether sprays are available.

APET Event 64. Hydrogen Burn Late Containment Failure

Two Branches:

Summary Branches:

1) Containment Failure Due to Late Hydrogen Burn FAILURE 2) No Containment Failure NO FAILURE

This event assesses whether containment failure occurs late as a result of a hydrogen burn. If a hydrogen detonation containment failure occurred then this is sorted as containment failure. If a large hydrogen burn was ignited then this event compares the peak containment pressure for the burn (Parameter 5) with the containment fragility curve and determines the probability of containment failure.

APET Event 65. Containment Status At Accident Progression Completion

Four	Branches:	Summary Branches:
1) 2) 3) 4)	Early Containment Failure Late Overpres ure Failure Containment Vent No Containment Failure (i.e., no containment failure or vent)	EARLY CF LATE CF VENT NO CF

This event assesses whether containment failure occurs late in the sequence progression due gradual overpressurization from steam and non-condensible gas generation. This event also assess whether the containment is vented to prevent overpressure failure. The event pathway probabilities are a function of whether containment failure has already occurred earlier in the accident, whether containment heat removal is available, whether the pool is bypasses, whether the containment is vented, and the event type.

APET Event 66. Mode of Late Hydrogen and Overpressure Containment Failure

Two Branches:

Summary Branches:

1) Anchorage Contairment Failure

ANCHORAGE PENET-DOM/NG CF

 Penetration-Dome Containment Failure or No Containment Failure

This event determines the probability of anchorage containment failure given containment failure due to late overpressure or deflagration, and assigns detonation containment failure sequences and no containment failure sequences to the second branch. For late gradual steam overpressure containment failure, the estimated conditionally probability of 0.15 is assigned for anchorage failure. All detonation failures are considered most likely to occur in the dome region and are sorted to the penetration-dome or no containment failure category. For sequences where the containment has failed by a late burn the expected peak containment pressure from the burn is used to estimate the probability of anchorage failure.

AFET Event 64 (Hydrogen Burn Late Containment Failure), AFET Event 65 (Containment Status At Accident Progression Completion) and AFET 66 (Mode Of Late Hydrogen & Overpressure Containment Failure) can be referenced by the EVNTRE binner to determine the probability of the possible modes of containment failure, as indicated in the introduction of this section.

4.5.2.2.10 Pool Bypass Late

(APET Event 68)

Fission product scrubbing in the suppression pool is an effective fission product mitigation mechanism unless the suppression pool is saturated. However, if the release pathway bypasses the suppression pool this mechanism is not effective. Pool bypass may result from a number of causes. These include: 1) structural failure of the drywell, 2) drywell vacuum breaker failure, 3) excessive leakage through drywell penetrations, and 4)loss of suppression pool water below the level of the horizontal vents or the SRV quenchers.

Drywell structural failure may result from transient over-pressurization of the drywell or wetwell resulting in a sufficiently high drywell/wetwell differential

pressure to cause failure of the drywell head, ceiling or walls. Failure the drywell vacuum breakers may occur due to hydrogen burns. Loss of suppression pool water may result from containment anchorage failure. Dry CCI leads to high drywell temperature and failure of the drywell penetrations.

Figure 4.5.2.2.10-1, Late Pool Bypass DET, shows the general characterization of this portion of the APET.

This APET event, Late Pool Bypass, is dependent on the following Events in the Perry APET.

This event is dependent on the following Events in the Perry APET.

APET Event 67. Dryvell Failure Due To Late Hydrogen Burn In Containment

Two Branches:

Summary Branches:

1)	Dryvell	Failure	Due To	Late	Hydrogen	Burn	DW	FAILURE
2)	No Drywe	ell Fail	ure				NO	FAILURE

Given that a large hydrogen burn has occurred late in the sequence this event assesses whether drywell failure results from excessive differential pressure across the drywell boundary. For cases where a large hydrogen burn has occurred two parameters have been set which give the peak burn pressure in containment during the burn and the containment pressure prior to the burn. It is assumed that the drywell pressure remains constant during the burn in containment. Given the value of these two parameters the peak drywell differential pressure is calculated and compared against the drywell fragility curve in a user function to estimate the probability of drywell structural failure.

APET Event 68. Pool Bypass Late

Two Branches:

Summary Branches:

1)	Late Pool Bypass	LATE POOL BYP
2)	No Late Bypass	NO LATE BYPASS

This event assess the probability that pool bypass will occur late in the accident sequence. This event considers pool bypass resulting from: drywell failure from late hydrogen combustion in the containment, containment anchorage failure, pedestal failure caused by core concrete interaction pedestal erosion, drywell penetration failures associated with high temperature during dry CCI. drywell vacuum breaker failures due to large hydrogen burns, and other failure processes.

4.5.3 APET Quantification

The Accident Progression Event Tree summary results for the Perry Mark III containment performance are: no containment failure - represents a 39% conditional probability given core damage and a frequency of 5.0×10 , containment venting - represents a 29% conditional probability and a frequency of 3.7×10^{-6} , and containment structural failure - represents a 32% conditional probability and a frequency of 4.0×10^{-6} . A summary of the





quantified APET results for all sequences is provided in Table 4.5.3-1, APET Base Case Results.

Table 4.5.3-1 presents the containment failure modes in the format of the NUREG/CR-4551 Grand Gulf evaluation (Brown 1990). When the core debris is cooled in-vessel no RPV failure occurs and three modes of containment failure are snown: no containment failure, vent and containment (structural) failure. When the core is not cooled in-vessel RPV failure occurs and seven modes of containment failure are shown: no containment failure, vent, late containment (structural) failure, early containment failure with no pool bypass, early containment failure with late pool bypass, early containment failure with early pool bypass and containment spray, and early containment failure with early pool bypass and no containment spray. The containment failure frequency is the combination of both containment structural failure frequency and venting frequency (and includes both in-vessel cooling and no in-vessel cooling sequences). Early containment failure with pool bypass is the combination of early containment failure with: late pool bypass, early pool bypass with containment spray, and early pool bypass with no containment spray. The conditional probability estimates of the detailed failure modes evaluation are: 50.8% - in-vessel cooling and no RPV failure; and the balance of the sequences with RPV failure (49.2%) is composed of: 12.4% - no containment failure, 10% venting with a damaged core, 7.4% - late containment failure, 3.4% - early containment failure with no pool bypass, and 16.1% containment failure with pool bypass.

Detailed APET base case quantification results for all sequences are provided in Appendix H.4, PNPP IPE APET Program Frequency Output File.

Table 4.5.3-2, APET Containment Performance Base Case Results For Dominant PDS Groups, shows the ranked results of the 16 plant damage states that contribute 95% of the total containment failure probability. The containment performance results are shown in the same format as that described above. In addition, the containment failure and venting composite identifies the probability of structural containment failure in the penetration or anchorage mode, as well as the probabilities when summed equal the total failure and venting probability for each plant damage sequence and for All PDS sequences (which is listed last in this table). The All PDS sequences results show the following conditional probabilities for the containment structural failure modes: 26.7% - penetration failures, and 5.0% - containment anchorage failures.

4.5.3.1 Containment Failure And Dominant PDS Groups

The APET Containment Performance Base Case Results for each of the 16 dominant Plant Damage State groups representing 95% of the total containment failure are shown in Table 4.5.3-2. The individual core damage sequences contributing above 1% core damage listed with the dominant containment failure PDS groups in Table 4.5.3-3.

Sixteen PDS groups represent 95% of the core damage frequency. The two most dominant PDS groups are 56 and 73 which represent 60% of the total containment failure frequency. A general discussion of these two PDS groups is provided below.

PDS group 56, represents Non-SBO sequences with the Containment Intact At Core Damage and successful Containment Heat Removal With the Vent, Late Injection, and RPV Depressurization During Core Damage. PDS group 56 represents 43.9% of the total combined containment failure and venting frequency. PDS group 56 has an early containment failure percentage of 1% and a venting percentage of 99%. RPV Failure and Early Containment Failure with Early Bypass is estimated to occur 1% of the time for sequences in this plant damage state. PDS group 56 has 6 dominant sequences above 1% of the core damage frequency. The most dominant sequence (9% CDF) is a Flood in Zone 13B with failure of all injection. The second sequence (6% CDF) is a Loss Of Instrument Air with Loss of all injection. The third sequence (3% CDF) is a Station Blackout sequence with successful recovery of offsite power before core uncovery and subsequent loss of all injection. The fourth sequence (2% CDF) is a Flood in Zone FlD with loss of all injection. The remaining two sequences (1.6% CDF each) are a Large LOCA and LOOP with failure of injection.

PDS group 73, represents the OTHERS sequences (i.e., other than Critical ATWS or LCOP & SBO) with Containment Failed At Core Damage, unsuccessful Late Injection, and successful RPV Depressurization During Core Damage. PDS group 73 represents 16% of the total combined cortainment failure and venting frequency. RPV Failure and Early Containment Failure with Pool Bypass are predicted for all plant damage state sequences (with 16% early pool bypass and 84% late pool bypass). Early Pool Bypass is associated with the containment anchorage failure mode which results in suppression pool loss. Late Pool Bypass occurs due to the high drywell temperatures which challenge the drywell penetration seals and result in suppression pool bypass. PDS group 73 has just 1 dominant core damage sequence (8% CDF), Loss of PCS and failure of containment heat removal with subsequent failure of all late injection.

Malf of the 16 dominant containment failure PDS groups are in the general category of containment failed at core damage. These are PDS groups: 73, 71, 65, 67, 69, 63, 66 and 70 (which are ranked 2, 4, 5, 6, 7, 8, 11 and 16). These groups contribute a total containment failure frequency of 2.9 x10⁻⁶ or 37% of the total containment failure and venting frequency. Critical ATWS contributes 7.3% of the total containment failure and venting frequency with the 3 dominant PDS groups: 65, 63 and 66. LOOP & SBO contributes 7.1% of the containment failure frequency with the 3 dominant PDS groups: 67, 69 and 70. OTMERS contributes 23% of the total containment failure and venting frequency with the PDS groups: 71 and 73.

Station Blackout containment failure is represented by three dominant PDS groups: 25, 36 and 9 (which are ranked 9, 10 and 12). These 3 SBO PDS groups represent 2.6% containment structural failure and 1.3% containment venting which is 3.9% of the total containment failure and venting frequency. These 3 dominate SBO groups represent 3.2% of the core damage frequency.

All Station Blackout PDS group, represent 9.0% of the total core damage frequency. All the Station Blackout PDS sequences contribute 7.9% of the total containment failure and venting frequency. The total Station Blackout containment structural failure frequency is 5.0 x 10⁻⁶, which represents 4.7% of the total containment failure and venting frequency.

The containment structural failure conditional probability of 31.7% has contributors from the following PDS grouping categories: 22.8% - where the

containment is failed at core damage $(4.4\% - \text{from Critical ATWS PDS groups}, 4.3\% - \text{from LOOP & SBO PDS groups, and 14\% - from the other remaining PDS groups), and 8.9\% - where the containment is intact at core damage and failure occurs later (4.7\% - from SBO PDS groups, and 4.2\% - from other PDS groups with AC power available).$

4.6 ACCIDENT PROGRESSION

4.6.1 Summary of Sequences Analyzed

To support the development and quantification of the Accident Progression Event Tree (APET) an assessment of the physical progression of a spectrum of accident sequences was performed using the MAAP 3.0B code. This effort provided information regarding: the timing of key events, containment loads, debris relocation and cooling, mitigation effectiveness of injection system, the generation and combustion of hydrogen and carbon monoxide, and core cracrete interaction in the pedestal cavity. Over 200 MAAP computer runs sur art the assessment of accident progression.

The Perry accident progression analyses scope included the performance of all the recommended sensitivities applicable to a Mark III containment as described in the "Recommended Sensitivity Analyses For An Individual Plant Examination Using MAAP 3.0B" (EPRI 1990). This sensitivity evaluation scope included: the coefficient for critical heat flux used in debris coolability (FCHF), containment failure area (AOVPR), the impact of core geometry on cladding oxidation (FCRBLK), delayed hydrogen combustion (DXHIG), and diffusion flame modeling during hydrogen ignitor operation (FLPHJ). The MAAP cladding oxidation (FCRBLK) sensitivity key results for Station Blackout sequences without the hydrogen ignition system available are provided in Tables 4.6.1-1 and 4.6.1-2. The EPRI recommended sensitivities and the IPE insights gained guided the accident progression assessment and the development of the APET.

To derive the release fractions for the various source term categories, the Back-End Analysis also used the MAAP 3.0B code. The eleven source term MAAP runs are discussed in section 4.7.3.

4.6.2 APET Sensitivity Analysis

A sensitivity analysis was performed to identify significant contributors to containment performance in the quantification of the APET. The sensitivity analysis benchmarked the APET sensitivity results to the containment performance characteristics of: No RFV Failure, Containment Integrity (No Failure, Vent, Failure), and No Pool Bypass. The following subsections summarize the sensitivity analysis of 14 APET parameters of which the first 13 are related to arcident progression phenomena, and the last is the human interaction, failure initiate the hydrogen ignition system.

The results of the APET sensitivity analysis determined the the following APET parameters are significant: (1) assured in-vessel debris cooling would increase No RPV Failure with a 34% change, and (2) in-vessel steam explosion boctom head failure estimated with the Grand Gulf NUREG/CR-4551 (Brown 1990) probabilities decrease No RPV Failure with a 58% change and decrease No Pool Bypass with a 10% change. The significant sensitivity impact of in-vessel debris cooling is realized and will be fur examined by the industry during

accident management using MAAP 4.0. The significant sensitivity impact of in-vessel steam explosion bottom head failure demonstrates the profound effect of variations in the estimate of this phenomena which is not well understood.

4.6.2.1 APET Event 13. RPV Depressurized During Core Damage

The impact of increased RPV depressurization was measured by setting the probability of successful depressurization to 1. The measured sensitivity changes on the four benchmark parameters described in 4.6.2 were on the order of 1 percent change, demonstrating that the current RPV Depressurization capability is sufficient.

4.6.2.2 APET Event 15. Debris Cooled In-Vessel

The impact of in-vessel recovery was measured by setting the probability of cooling the debris in-vessel to 1 and 0 (given the recovery of low pressure injection before core plate failure). The sensitivity results of assured in-vessel coolability show that No RPV Failure would increase with a 34% change, and No Pool Bypass would increase with a 6% change. The sensitivity results of no in-vessel coolability show that No RPV Failure would decrease with a 100% change and No Pool Bypass would decrease with a 16% change.

4.6.2.3 APET Event 18 and 56. Mode of RHR Spray Operation

The impact of controlled cooling spray operation was measured by changing the assignment of RHR (Design) Spray to Controlled (Spray). The sensitivity results show a 2% decrease in No Containment Failure and an increase of 2.5% in Containment Structural Failure. The increase in Containment Failure was not anticipated from the perspective of engineering judgment and examination of the SBO sequences, where this enhancement should be effective, found the APET model to be simplistic. Additional APET modeling to evaluate controlled RHR spray cooling during SBO recovery with hydrogen generation should be considered during Accident Management.

4.6.2.4 APET Event 20. Fraction of Zirconium Reacted In-Vessel

The impact of setting all the sequences to the maximum hydrogen production case, 35% fraction of zirconium reacted in-vessel, was measured by case assignment changes. The sensitivity results show No RPV Failure and No Pool Bypass decrease with about a 3% change and Containment (structural) Failure increases with a 8% change.

4.6.2.5 APET Event 21. Small Burns At Low Hydrogen Concentrations

The impact of transient combustibles maintaining a low hydrogen concentration by providing an ignition source for continuing small burns was measured by setting the probability of small burns to 0, except when the hydrogen ignition system is operating. The sensitivity results show essentially no change in the key parameters.

4.6.2.6 APET Event 24. Containment Failure Fragility Model

The impact of changing the containment failure fragility curve to a point estimate of the median (64.3 psig) and the 5th percentile (53.5 psig) was measured by revising the EVNTRE user function. Both sensitivity case results show essentially no change.

4.6.2.7 APET Event 25, 47 and 66. Mode of Containment Failure

The impact of changing the probability of the mode of containment failure from the fragility curve assignments for anchorage and penetration failures was measured by assigning all containment failure cases to anchorage failure. The sensitivity results show no change in No RPV Failure and Containment Integrity, and found an 11% increase in No Pool Bypass.

4.6.2.8 APET Event 31. Mode of In-Vessel Steam Explosion Bottom Head Failure

The impact of changing the probability of the estimate of in-vessel steam explosion bottom head failure by a factor of 10 to the value used in Grand Gulf NUREG/CR-4551 (Brown 1990) was measured by a case assignment change. The sensitivity results show a 58% decrease in No RPV Failure, a 10% decrease in No Pool Bypass, and a 1% increase in Containment Failure.

4.6.2.9 APET Event 32. RPV Lower Head Failure Size

The impact of changing the probability of a large vessel failure size to 1. was measured by case assignment. The sensitivity results indicated essentially no change in the overall results.

4.6.2.10 APET Event 33. Water In Pedestal At RPV Failure

The impact of water in the pedestal at RPV Failure was measured by setting the probability of pedestal flooding to 1. The sensitivity results show no notable change.

4.6.2.11 APET Event 36. Pedestal Failure Due To Steam Explosion

The impact of changing the probability of the estimate of pedestal failure due to steam explosion by a factor of 10 to the value used in Grand Gulf NUREG/CR-4551 (Brown 1990) was measured by a case assignment change. The sensitivity results show no notable change.

4.6.2.12 APET Event 37. Drywell Failure Due To Pedestal Failure

The impact of pedestal failure on drywell failure was measured by changing the conditional probability of drywell failure given pedestal failure to 1 by case assignment. The sensitivity results show a 1% decrease in No Pool bypass.

4.6.2.13 APET Event 54. Type of Core Debris Concrete Interaction

The impact of ex-vessel debris coolability was assessed with two sensitivity cases. The sensitivity of assuming the ex-vessel core debris is never coclable was measured by case assignment with an equal probability of slow wet and fast wet core concrete interaction. The sensitivity results of non-coolable debris show a 2% decrease in No Pool Bypass. The sensitivity of assuming the debris is always cooling was measured by case assignment with a probability of 1, if late injection water to the pedestal cavity was available. The sensitivity results show a 8% increase in No Pool Bypass, and a 1% decrease in Containment Failure.

4.6.2.14 APET Events 16, 42 and 57. Hydrogen Ignitor Human Interaction

The impact of the human interaction, failure to initiate the hydrogen ignition system, on hydrogen combustion was accessed with two sensitivity cases. In the first case, the recovery luman interaction failure probability was set to 1. The sensitivity results for no recovery of the hydrogen ignitors show less than a 0.4% change in the results of the four benchmark parameters. For the second case, the probabilities for failure to initiate and failure to involve were both set to 1. The sensitivity results for complete failure to initiate the hydrogen ignitors show essentially no change in the results.

4.6.3 Containment Performance Improvement Sensitivity Analysis

Sensitivity analyses were performed to consider the improvement in containment performance with the following design change considerations: passive plant vent, ATWS automatic ADS inhibit and alternate shutdown system, and a secure power supply for the hydrogen ignition system. The sensitivity analysis results for these design togaiderations are shown in Table 4.6.3-1, Impact of Design Changes On Containment Fai? The Frequency.

4.6.3.1 Passive Containment Vent Design Consideration

The passive vent sensitivity was considered since 22.8% of the plant damage state sequences have a failed containment before core dumage, of which 18.4% are non-Critical ATWS sequences. The front-end sensitivity analysis included this impact of containment failure on the loss of injection in section 3.4.1.6 and identified the core damage frequency would be reduced by about 22% with the design change consideration of a passive vent.

The containment vent pathways include the normally open Fuel Pool Cooling & Cleanup (FPCC) return line and normally closed RHR Containment Spray alignment. The Fuel Pool Cooling And Cleanup is generally open during normal operations. When the containment is isolated and containment heat removal with an RHR heat exchanger is not available, motor operated valves must be opened to align either the FPCC vent or the RHR Spray vent. If motor operated valves associated with a venting pathway fail to open remotely from the control room, local manual opening of the motor operated valves located inside is containment is not possible. A passive vent design change would provide a passive rupture disk in an alternate vent path to ensure that the containment pressure would remain below the containment overpressure threshold limit.

The results of the passive vent design change to ensure the opening of a vent release path before the containment overpressure threshold limit are shown in Table 4.6.3-1. The favorable containment performance results from the passive vent are: increased arrest of core damage in-vessel with no RPV failure changing from 50.8% of core damage frequency to 61.0% (20% change), decreased containment structural failure frequency from 4.03 x 10° to 9.92 x 10° (75% change), and decreased RPV failure & early containment failure with pool bypass frequency from 2.04 x 10° to 4.48 x 10° (76% change).

4.6.3.2 ATWS Alternate Shutdown & ADS Inhibit Design Consideration

The ATWS alternate shutdown & ADS inhibit sensitivity was considered to address

the critical ATWS sequences with represent 4.4% of the core damage frequency and have containment failure before core damage. The front-end sensitivity analysis in section 3.4.1.6 included the impact of a design consideration to provide automatic ADS inhibit which would reduce the internal and flooding core damage frequency 19%. The containment performance improvement would provide an enhanced Plant Emergency Instruction to control the RFV Power/Level as a function of containment pressure with an RFV water level control band just above the Minimum Steam Cooling Water Level. This new water level control band just above the Minimum 3team Cooling Water Level (at 30 inches below the Top of the Active Fuel) would reduce the reactor power within the containment vent heat removal capability. This quasi steady-state RFV Power/Level control would provide a reasonable time for reactor shutdown recovery using an alternate boron injection system. A factor of 90% recovery from the Critical ATWS sequences was modeled in the rensitivity analysis.

The containment performance results of ATWS Alternate Shutdown & ADS Inhibit are shown in Table 4.6. 1. The favorable containment performance results with the ATWS improvements are irequency reductions for RFV failure and containment failure: the containment structural failure frequency decreases from 4.03 x 10^{-6} to 3.49 x 10^{-6} (-13% change), and the RFV failure & early containment failure with pool bypass, frequency decreases from 2.04 x 10^{-6} to 1.75 x 10^{-6} (14% change).

4.6.3.3 Cydrogen Ignicion System Design Change Consideration

Supplement No. 3 of Generic Letter 88-20 directed that Mark III containments are expected to evaluate the vulnerability to interruption of power to the hydrogen ignitors. This staff recommendation originated from NUREG-1417 (NRC 1990) entitled Safety Evaluation Report Related To Hydrogen Control Owners Group Assessment of Mark III Containments. On the basis of its evaluation, the staff found the Hydrogen Control Owners Group typical report "Generic Hydrogen Control Information for BWR-6 Mark III Containments" provided an acceptable basis for the technical resolution of the Mark III containment degraded-core hydrogen control issue. Additional plant-specific analysis will confirm that the equipment necessary to establish and maintain safe shutdown and to maintain containment integrity will be capable of performing its functions during and exposure to the environmental conditions resulting from hydrogen after generation in all recoverable degraded-core severe-accident scenarios. The staff's assessment identified that a plant specific evaluation of the adequacy of the hydrogen ignition system (HIS) alternate power supply should be included as part of the individual plant examination of the plants with Mark III containments. NUREG-1417 noted that an important factor in this decision process is the level of risk associated with an SBO event leading to core damage. The Grand Gulf Mark III plant risk study included in NUREG-1150 (NRC 1989) show the overall core melt frequency very low (i.e., 1 \times 10⁻⁶) and that SBO conditions dominate the residual risk from severe accidents.

The modification of the electrical power supply to ensure the availability of the hydrogen ignition system (HIS) during SBO would remove the possibility of high containment loads from hydrogen deflagrations and detonations. The HIS backup power supply sensitivity assumes 100% HIS a milability (and no unavailability due to human interaction error).

The containment performance results of the HIS backup power supply are shown in

Table 4.6.3-1. The favorable containment performance results with the HIS backup power supply are frequency reductions for containment failure: the containment structural failure frequency decreases from 4.03 x 10-6 to 3.76 x 10^{-6} (-6.7% change), and the RPV failure & early containment failure with pool bypass frequency decreases from 2.04 x 10^{-6} to 2.00 x 10^{-6} (-2% change).

4.6.3.4 Combined Passive Vent And ATWS Alternate Shutdown & ADS Inhibit Design Change Consideration

The combination of these two design consideration changes discussed above would reduce the core damage frequency from $1.27 \times 10-5$ to 8.01×10^{-6} (-37% change), and also reduce containment failure before core damage frequency from 2.90×10^{-6} to 5.3×10^{-6} (-98% change).

The containment performance results of this combined passive vent and ATWS modification are shown in Table 4.6.3-1 The favorable containment performance results with comparison to the base case are: increased arrest of core damage in vessel from 50.8% of core damage to 64.1% (23% change), decreased containment structural failure from 4.03 x 10⁻⁶ to 4.60 x 10⁻⁷ (-89% change), and decreased RPV failure and early containment failure with pool bypass frequency from 2.04 x 10^{-6} to 1.57 x 10^{-7} (-92% change).

4.6.3.5 Combined Passive Vent, ATWS Modifications And HIS Backup Power Supply Design to the Consideration

The commutation of these three changes discussed above further examines the impact of backup power to the hydrogen ignitors with the passive vent and ATWS modifications.

The containment performance results of this combined passive vent, ATWS modification and HIS backup power supply are shown in Table 4.6.3-1. The favorable containment performance results with comparison to the base case are: increased arrest of core damage in vessel from 50.8% of core damage to 64.1% (26% change), decreased containment structural failure from 4.03 x 10⁻⁶ to 1.75 x 10⁻⁷ (-96% change), and decreased RPV failure and early containment failure with pool bypass frequency from 2.04 x 10⁻⁶ to 1.14 x 10⁻⁷.

4.6.3.6 Updated Initiating Event Frequency

The front-end sensitivity discussion of initiating event frequency in section 3.4.1.5 identified that using updated initiating event frequencies would change the composition of dominate initiating events and reduce the core damage frequency. The updated initiator composition ranking is: SBO at 32% followed by LOOP at 20%, combined transient at 23%, and ATWS at 17%. The reduction in core dumage frequency for internal events and flooding is 1.27×10^{-5} to 8.05×10^{-6} (-37% change).

The containment performance results of the updated initiator frequency are shown in Table 4.6.3-2, Impact of Design Changes On Containment Failure Frequency Using Updated Initiator Frequency. Included in this Table are sensitivity cases using the updated initiating event frequency with the four design change considerations discussed above: updated passive vent; updated ATWS Alternate Shutdown and ADS Inhibit; Updated Passive Vent and ATWS Modification; and Updated Passive Vent, ATWS Modifications and HIS Backup Power Supply.



The results of the updated initiating event frequency sensitivity analysis are compared with the results of the previous generic initiating event sensitivity analysis in Table 4.6.3-3. The impact of the updated initiating event frequency on the containment performance results of the design change considerations is significant.

4.7 RADIONUCLIDE RELEASE CHARACTERIZATION

The binned end points of the Accident Progression Event Tree (APET) represent the outcomes of possible in-containment accident progression sequences. The endpoints represent complete severe accident sequences from initiating eve to release of radionuclides to the environment. The Level 1 system information is passed through to the Containment evaluation in discrete plant damage states. An atmospheric source term may be associated with each of these Containment sequences. Because of the large number of APET sequences and because of similarities in the sequence characteristics, however, it is neither necessary nor practical to develop a source term estimate for each Containment sequence. Sequences with similar characteristics are therefore grouped into release categories to reduce the required source term assessment effort.

4.7.1 Release Category Grouping Parameters and Grouping Logic

The first step in source term assessment effort is to identify the sequence characteristics which are most important 'o definition of the source term. These characteristics are identifiable from the Plant Damage State (PDS) characteristics and from the APET sequence characteristics since one of the primary objective. In the PDS grouping and APET evaluation has been to define those events and a nditions most important to source term assessment. This select set of sequence characteristics important to source term assessment are used as grouping criteria to define the release categories and the associated source term magnitude, composition and timing.

The Containment sequence characteristics selected for use in definition of the Perry source term release categories are:

Containment Bypass (Event V or Main steam Line Break Outside Containment) Debris Cooled In-Vessel Containment Status At Core Damage Time of Containment Failure (relative to core damage) Mode/Location of Containment Failure Suppression Pool Bypass Spray Operation Type of Core Concrete Interactions

The approach to the definition of release categories in similar to that discussed in Section 4.3 for plant damage state definition. It consisted of construction of a logic diagram with the grouping criteria defined above, as headings. The end points on the logic diagram represent unique release (source term) categories with their individual characteristi fined by the pathway through the logic diagram.

The gcal of the grouping process is to develop the minimum number of release categories necessary to distinguish the important combinations of sequence

characteristics that can result in distinctly different atmospheric source terms. The Source Term Grouping Logic diagram developed for the Perry IPE is shown in Figure 4.7-1. It defines 25 release categories. It is applicable for both the internal initiators and for internal flooding initiators.

The reasons for the selection of these parameters for definition of the Perry release categories and specific branch assignment decisions used in the logic diagram under each decision heading are discussed below.

Containment Bypass

Containment natural and engineered mitigation features (including scrubbing in the suppression pool) are ineffective in reducing fission product releases if the accident causes opening of a leakage path directly from the reactor vessel to a point outside of the Containment boundary which bypasses the drywell and containment gas volumes.

The two main ways that this can occur are if an unisolable steam line break outside of containment occurs or an interfacing system LOCA (Event V) occurs. These are both defined by the plant damage state attribute "Containment Bypass".

For interfacing system LOCAs the failures occur into the Auxiliary Building because of the failure of the check valves between the reactor vessel and the low pressure injection systems (or low pressure portions of high pressure injection systems), and subsequent failure of the low pressure piping outside of the containment. The factors of interest to source term assessment is whether or not the release point is above or below water in the Auxiliary Building at the time fission product releases are occurring and whether there is substantial deposition of radionuclides on Auxiliary Building surfaces. For unisolated steam line breaks the important considerations are the extent of radionuclide deposition in the Steam Tunnel and/or Turbine Building.

For containment bypass sequences, the phenomena that occur in the major containment volumes and containment ESF operation are largely irrelevant (at least until vessel failure), and the containment bypass sequences are assigned to a single source term category without differentiating other containment parameters considered for other sequence types.

Debris Cooled In-Vessel

This characteristic is important (for non-bypass sequences) since there is a significant probability of arresting the core-melt process in-vessel, thus preventing vessel failure, ex-vessel release (core concrete interaction) processes. (possibly) containment failure and reducing the magnitude of fission product release. This characteristic is only considered if Containment is not bypassed. Interfacing system LOCAs (Event V) and main steam line breaks outside containment generally preclude long-term cooling as reactor vessel and containment water inventory is lost from containment.

If the debris is cooled in-vessel (and reactor vessel failure prevented) then those processes involving ex-vessel debris interactions will be absent (ex-vessel debris coolability and debris concrete attack) and need not be considered in defining the source term categories.

However, sufficient hydrogen may be produced to threaten containment integrity. In addition, for loss of containment heat removal sequences - long term containment overpressure failure ay still occur. Containment failure (by either of the above mechanisms) may also result in pool bypass.

Containment Status At Core Damage

This attribute is considered important because any fission products in the containment atmosphere are released to the Intermediate Building/environment early (i.e., near the time of core melt) and continuously, if the containment is not isolated or has failed prior to core damage initiation.

In this case, the effective available time for fission product deposition and possible spray washout in containment is reduced. The size of the most likely isolation failure path (Fuel Pool Cooling Return with an effective area of .492 square feet) is large enough so that even if a later larger area containment failure were to occur, it would and significantly increase the radionuclide release magnitude. As discussed if here is 3.2.1, the Backup Hydrogen Purge line may be open initially during the for 13.2.1, the radionuclide release is limited by the maximum potential is the form is system (50 scfm). Sequences with successful in-vess is proved in overpressurize failure of containment prior to core damage initiation. For sequences with the containment failed before core damage, it is assumed that the leak path is directly to the atmosphere, or, if to the Intermediate fuilding, to a location where further attenuation is not effective. This assumption is partly based on conservation and partially on a review of the available release pathways.

Time Of Containment Failure

This release category attribute is considered important because it affects the time available for fission product release mitigatic, by natural removal processes and spray washout. It applies to all core damage sequences that do not involve containment bypass, or loss of isolation.

The times selected as significant are: At (or Before) Reactor Vessel Failure, and Late Failure (many hours after vessel failure). The possibility of no containment failure exists and is assigned to its own unique source term category.

Mode Of Containment Failure

This attribute is important because it governs the rate at which fission products are released to the atmosphere. It also affects the magnitude of the release by governing the time available for effective fission product attenuation in containment.

The three "failure" modes considered significant are: penetration failures, anchorage failures, and containment venting.

This attribute is only considered for those sequences evaluated to have an early or late containment failure. This attribute is clearly not a discriminant for sequences with no containment failure. This attribute is not relevant, (or at least not significant) for containment bypass sequences, as most of the fission products escape through the bypass. The mode of containment failure is also considered not relevant for other sequences that have containment failure before core damage since the containment will have already been depressurized prior to core damage.

Suppression Pool Bypass

Scrubbing in the suppression pool can be an effective mitigation mechanism for in-vessel radionuclide releases or from debris/concrete attack in the reactor pedestal cavity. If the pool is bypassed during periods of fission product release, then this attenuation process will not be effective. Pool bypass can occur as the result of containment failure (e.g., containment anchorage failure which allows the pool to drain down below the level of the SRV quenchers and/or the horizontal vents, as a result of drywell failure (e.g., a pedestal steam explosion causes pedestal failure which then fails the drywell) or due to failures of systems interfacing the drywell and containment gas space (e.g., a drywell vacuum breaker sticks open). Pool bypass will not have a significant impact on the source term if the containment does not fail (and is isolated). If the containment fails via the anchorage failure mode, it is assumed that pool bypass occurs.

Containment Spray Operation

This attribute is considered significant because it determines whether or not fission product washout by sprays occurs in the containment. This attribute also affects the energy level (i.e., temperature) of the release.

Spray operation is only used as a grouping parameter for sequences with pool bypass since if the suppression pool is in the radionuclide release pathway, an effective engineered safety feature radionuclide removal mechanism is already present. Consequently, for sequences with the suppression pool not bypassed no branching is done and it is assumed (for calculating source term magnitudes) that the sprays are not operating. For sequences with the pool bypassed, the sprays must be operational over the entire time period when radionuclide release is occurring in order to follow the successful spray operation branch.

This characteristic is not considered for containment bypass sequences, the sprays do not attenuate the important in-vessel releases. It is irrelevant for all requences in which containment failure does not occur as no significant release would occur.

Type Of Core Concrete Interaction

Three types of core debris are considered. No CCI - where the debris is cooled in the drywell and little or no CCI occurs. Dry CCI - where water is not supplied to the drywell following vessel failure or where pool overflow into the drywell has not occurred. Wet CCI - where a source of water to the drywell is present, however the debris is not coolable and CCI occurs in the presence of an overlying water layer.

Dry CCI cases and wet CCI cases result in significantly different fission product source terms since for CCI occurring with an overlying water pool the aerosols and radionuclides will be scrubbed by the overlying water pool. This can be particularly important for sequences where the suppression pool is



bypassed.

4.7.2 Release Category Grouping Logic Tree and Release Category Characteristics

The Source Term Category Grouping Logic figure developed for the Perry IPE is shown as Figure 4.7.1-1. It defines 25 release categories.

4.7.2.1 STC Grouping Logic Heading Definitions

The following STC Grouping Logic Headings are used in Figure 4.7.1-1.

CNIMT BYP Containment Bypass

A containment bypass sequence with core damage results in a radiological release to the environment. Potential bypass sequences include the traditional Event V, Interfacing LOCAs, and Main Steam Line Breaks. The STC grouping logic branches are labeled No and Yes.

RPV FAIL Debris Cooled In-Vessel

If the debris is cooled in-vessel (and reactor failure is prevented) then those processes involving ex-vessel debris interactions will be absent. The STC grouping logic branches are labeled RPV Failure and No RPV Failure.

CNIMT INT Containment Status At Core Damage

The success of containment at core damage maintains the radiological boundary. The failure of containment at, or before, core damage allows an early radiological release. The failure of the containment may result in the loss of injection due to the physical interaction between the containment structure and the injection systems. The STC grouping logic branches are labeled Containment Failed Before Core Damage and Intact.

TIME CF Time Of Containment Failure

The time of containment failure is characterized for the sequences that do not involve containment bypass or containment failed before core damage. The STC grouping logic branches are labeled: Early Containment Failure, Late (many hours after RPV failure) Containment Failure, and No Containment Failure.

MODE CF Mode Of Containment Failure

The modes of containment failure are: anchorage failure, penetration failure, and containment vent. The modes of containment failure are applied to the Early Containment Failure and Late Containment Failure branches.

POOL BYP Suppression Pool Bypass

Suppression Pool Bypass is evaluated for all sequences with

containment failure. The STC grouping logic branches are labeled Early or Late Pool Bypass and No Pool Bypass.

SPRAYS

Containment Spray Operation

Containment spray operation can be applied to sequences with suppression pool bypass. The STC grouping logic branches are labeled Late or No spray. [It should be noted that the spray operation assessment would be most effective on dominate STC branches. During the course of the IPE assessment the contribution of SBO and ATWS initiators shifted and the grouping logic was not enhanced in this area due to time constraints. The application of this attribute demonstrates the potential benefit of this Engineered Safety System.]

TYPE CCI Type of Core Concrete Interaction

Three types of Core Concrete Interaction are considered in section 4.7.1. However, to simply and conservatively model the source term release fraction for the IPE only two types of CCI are shown on the STC grouping logic: Dry CCI and No CCI. Wet CCI sequences are conservatively combined with Dry CCI sequences. Source term release assessment using all three categories for RPV Failure would develop a model which would require a more exhaustive guantification effort.

4.7.3 Release Category Source Term Characteristics

The determination of the source term magnitude, composition, and timing for each release category were performed with the MAAP 3.0B code. MAAP calculations were performed for eleven Source Term Category groups: 1, 2, 3, 5, 8, 10, 11, 13, 14, 21 and 23. The release fractions for the other categories were then characterized by similarity to one of the calculated MAAP source terms.

The representative sequences used for the MAAP release category calculations were selected on the basis of having the required characteristics as specified in the release category definitions, having a significant frequency of occurrence (at the Plant Damage State level), and having a significant containment failure probability. The sequences modeled for the source term release categories are listed in Table 4.7.3-1. The calculated times of occurrence of events important to radionuclide release are listed in Table 4.7.3.2. The calculated radionuclide release fractions for the analyzed release categories are shown in Table 4.7.3-3. The release fractions in this table are listed by MAAP "species" which are described below. The bases for characterizing the unanalyzed source term release categories are primarily the containment failure time and mode, and containment spray operation.

Fission product release in the MAAP code from the core in-vessel or core debris ex-vessel is modeled with "frozen" chemical states defined by the twelve species listed in Table 4.7.3-5. The chemical state is important in determining the transition between vapor and aerosol forms which affects the deposition and retention of fission products.

Each of the 12 MAAP fission product species can exist in up to four states in

each region of the containment and reactor vessel. These states are "vapor", "aerosol", "deposited", and "contained in the core or coriun". These states and the 12 species are used to characterized the MAAP calculated source term release.

4.7.4 Release Category Point Estimate Frequencies and Dominant Sequences

Twenty five source term release categories were developed for the containment evaluation sequences. The nine dominant source term categories which contribute 95% of the source term release are listed in Table 4.7.4-1. Table 4.7.4-2 presents the contribution of the notable individual Plant Damage State groups (those PDS groups that contribute greater that 0.1% of the core damage) to each source term category. The dominant core damage sequences in the PDS groups shown as being important to a STC group are included in Table 4.3.3-1.

Dominant Source Term Categories 24 and 12 (ranked 1 and 4, respectfully) represent No Containment Failure with No RFV Failure and with RFV Failure and contribute 27.7% and 14.4%, respectfully, of the source term category release fraction.

Dominant Source Term Category 23, ranked 2, represents No RPV Failure, Containment Intact At Core Damage and Late Venting and No Pool Bypass. This venting category contributes 19.2% of the release fraction.

Dominant Source Term Category 1, ranked 3, represents RPV Failure with Containment Failed at Core Damage and Pool Bypass. This source term category contributes 15.0% of the release fraction.

REFERENCES

- Brown, T.D. et al 1990 Evaluation of Severe Accident Risks: Grand Gulf Unit 1 NUREG/CR-4551 Volume 6 Revision 1 Parts 1 and 2, Sandia National Laboratories, Albuquerque, NM.
- Drouin, M.T. et al. 1989 Analysis of Core Damage Frequency: Grand Gulf, Unit 1. <u>Internal Events</u> NUREG/CR-4550 Volume 6 Rev.1 Part 1, Sandia National Laboratories, Albuquerque, NM.
- EPRI 1990 Generic Framework For Individual Plant Examination (IPE) Back-End (Level 2) Analysis, Preliminary Draft, Palo Alto, CA.
- EPRI 1990 Recommended Sensitivity Analyses For An Individual Plant Examination Using MAAP 3.0B, Gabor, Kenton & Associates Inc., Vestmont, IL.
- EPRI 1991 BVR Mark III MAAP Users Guide, Fauske and Associates, Incorporated., Burr Ridge, IL.
- Gilbert/Commonwealth, 1992, Cleveland Electric Illuminating Company Perry Nuclear Power Plant Individual Plant Examination Containment Capacity Analysis, Reading, PA.
- Griesmeyer, J.M. et al, 1989 A Reference Manual for the Event Progression Analysis Code (EVNTRE) NUREG/CR--5174, Science Applications International Corporation, Albuquerque, NM.
- IDCOR, (The Industry Degraded Core Rulemaking Program) 1983 Technical Report 10.1 Containment Structural Capacity of Light Water Nuclear Power Plants, Technology for Energy Corporation, Knoxville, TN.
- NRC 1989 Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants NUREG-1150 Volume 1 and 2 (Second Draft), Division of Systems Research Office of Nuclear Regulatory Research, Washington, DC.
- NRC 1990 Safety Evaluation Report Related To Hydrogen Control Owners Group Assessment of Mark III Containments, U.S. Nuclear Regulatory Commission, Office of Nuclear Reactor Regulation, Vashington, DC.
- ROC AEC, (Republic of China, Atomic Energy Council) 1985 "Probabilistic Risk Assessment Kuosheng Nuclear Power Plant Unit 1", Executive Yaun, Taipei, Taiwan.

Table 4.1.1-1

COMPARISON OF MARK III CONTAINMENT DESIGN CHARACTERISTICS

	Perry	Grand Gulf
	in the second	STERING STAR
Total Free Volume (Mft ³)	1.44	1.67
Pool Volume (Mft ³)	0.12	0.14
Containment Volume/Thermal Power (ft³/kW)	0.40	0.44
Containment Pool Volume/Thermal Power (ft ³ /kW)	0.032	0.037
Containment Design Pressure		
Internal (psig) External (psi)	15 0.8	15
Drywell Design Pressure		
Internal (psi) External (psi)	30 21	30 21





TABLE 4.3.3-1

DOMINANT PLANT DAMAGE STATES

Rank	PDS GR	OUP FREQUE	CDF	DOMINANT SEQUENCE	S CDF%
1	53	4.44E	-6 34.9%	T2-C-U3-X' T2-C-LC-C1 T2-C-U3-X T3B-C-U3-X' T2-CB U-V-Va T2-CA-V'	17.8% 4.9% 2.2% 1.9% 1.1% 1.0%
2	56	З.40ы	-6 26.7%	13B-U1-U2-Va1 TIA-U2-U1-V-Va-Wo B6-V-Wc F1D-U3-U2-U1-V-Va A-U1-V-Wc-Ws T15-Va	3.0%
3	73	1.221	-6 9.6%	T2-Wc-Ws-Y-CV-Li	8.2%
4	61	6.23	6-7 4.9%	T15-Va-R3 UR-V-Va-R3	2.6%
5	71	5.59	6-7 4.49	T2-WC-WS-Y-CV TIA-U2-WC-WS-Y-C	2.2% v 1.5%
(5 65	2.93	E-7 2.3	T2-CA-C1-Wc	1.1%
	7 61	7 2.65	E-7 2.1	۱	
	8 65	9 2.56	E-7 2.0	۱	
	9	2.51	E-7 2.0	§ B9Va	1.8%
	10 2	5 2.09	E-7 1.6	% B7-R3	1.6%
	11 6	3 1.69	E-7 1.3	% T2-CA	1.2%
	12 3	2 1.26	iE-7 1.0	£	
	13 3	1.0	2E-7 0.8	15	
	14 6	1.0	DE-7 0.8	1	
	15	9 9.7	3E-8 0.8	3%	

ej

FAILURE PRESSURE

	FAILURE MODE	5th Percentile	Median
1.	Dome Knuckle	65.1 psig	86.4 psig
2.	Dome Apex	86.7	115.1
3.	Cylinder	86.6	111.7
4.	- Charles and the second	94.0	119.2
5.	Equipment Hatch (Bolts)	60.8	77.1
6.	California and	60.0	77.3
7.	Penetration P205	58.9	75.5
8.	Penetration P414	57.4	74.0
9.		104.9	135.3
	Anchorage Concrete	64.9	92.0
CONT	AINMENT COMPOSITE FAILURE	53.5	64.3

TABLE 4.4.1-2 EXPECTED TYPE OF CONTAINMENT FAILURE

1. Dome Knuckle X	
2. Dome Apex X	
3. Cylinder	(
4. Personnel Airlock < Median > Median	
5. Equipment Hatch (Bolts) < Median > Me	edian
6. Penetration P123 < Median > Median	
7. Penetration P205 < Median > Median	
8. Penetration P414 < Median > Median	
9. Anchorage Steel	X
10. Anchorage Concrete	Х

NOTE: Median designates the median failure pressure for the associated containment failure mode. Leakage failure is expected to commence below the median failure pressure, and when the median failure pressure is exceed then transition occurs to a larger failure type, rupture or gross rupture.

	FAILURE MODE	MEAN FAILURE PRESSURE
1.	Dryvell Wall	98.5 psid
2.	Dryvell Roof	67.0
3.	Dryvell Bead	77.8 (internal) 83.3 (external)
4.	Equipment Hatches	84.7
5.	Personnel Airlocks	107.2





TABLE 4.5.1-1 PERRY IPE ACCIDENT PROGRESSION EVENT TREE QUESTIONS

Question Number

PLANT DAMAGE STATE GROUPING LOGIC

1. Not A Containment Bypass Sequence?

No Bypass, Event V or Main Steam Line Break

2. Containment Status At Core Damage?

Containment Intact, Containment Failed.

3. Event Type?

For Containment Intact At Core Damage:

SBO, LOOP With No HVAC, Other Types

For Containment Failed At Core Damage:

Critical ATWS, LOOP & SBO, Others

4. Initial Containment Heat Removal With Suppression Pool Cooling?

For LOOP With No HVAC:

Not Available, Initial Suppression Pool Cooling

5. Containment Vent Isolated At RPV Failure?

For SBO Sequences: Isolated, Not Isolated

6. RPV Injection Failure Time?

For Containment Intact At Core Damage and SBO Sequences:

0 - 2.8 hrs (characterizes no injection)
2.8 - 4.2 hrs (characterizes RCIC availability)
> 4.2 hrs (characterizes HPCS & Firewater availability)

7. Offsite Power Recovery Time?

8.

Prior To RPV Failure, Prior To Containment Limit, No Recovery Containment Heat Removal With RHR Spray Loop?

RHR Spray, RHR Suppression Pool Cooling, No RHR

9. Containment Heat Removal With Vent?

Vent, No Vent

- Late In-Vessel Injection & Pedestal Cavity Supply? Yes, No
- RPV Depressurized During Core Damage? Yes, No

CET EVENT 1. DEBRIS COOLED IN-VESSE,

- Late RPV Low Pressure Injection Available?
 Water Injection, No Injection, Critical ATWS
- RPV Depressurized During Core D: 'je? Low Pressure, High Pressure
- 14. Debris Mass Molten At RPV Failure? Large Debris, Small Debris
- 15. Debris Cooled In-Vessel? Cooled In-Vessel, Not Cooled In-Vessel

CET EVENT 2. MODE OF CONTAINMENT FAILURE BEFORE RPV FAILURE

16. Hydrogen Ignition System Available?

HIS On, HIS Off

- 17. Containment Vent Isolated Before RPV Failure? Isolated, Not Isolated
- Mode Of RHR Spray Operation Early?
 Controlled, Design Cooling, No Spray
- 19. Containment Steam Concentration Before RPV Failure? 0-15%, 15-25%, 25-35%, 35-45%, 45-55%, >55%
- 20. Fraction Zirconium Inventory Reacted In-Vessel?

11%, 22%, 33%

- 21. Small H2 Burns At Low H2 Concentration? No Small Burns, Small Burns
- 22. Large H2 Burn During Core Damage? No Burn Ignited, Large Burn Ignited
- 23. H2 Detonation Containment Failure Before RPV Failure?

Detonation Containment Failure, No

24. Containment Failure Before RFV Failure?

Failure, No Failure

25. Mode Of Containment Failure Before RPV Failure?

Anchorage, Penetration-Dome or No Failure

CET EVENT 3. UNJECTION & SPRAY FAILURE DUE TO CONTAINMENT FAILURE BEFORE RFV FAILURE

26. Containment Failure Before RPV Failure Impact on ECCS Injection and Spray Piping?

No Failure, Failure

27. Containment Failure Before RPV Failure Impact on ECCS Injection and Spray Motors?

No Failure, Failure

28. Containment Failure Before RPV Failure Steam and Radiation Impact On Firewater Injection?

No Failure, Failure

29. Injection & Spray Failure Due To Containment Failure Before RFV Failure?

No Failure, Injection & Spray Failure

CET EVENT 4. DRYWELL FAILURE AT/NEAR RFV FAILURE

30. Alpha Mode Steam Explosion Drywell and Corcainment Failure?

Alpha, No Alpha

Mode Of In-Vessel Steam Explosion Bottom Head RPV Failure? 31.

Alpha, Large, Small, No In-Vessel Steam Failure

RPV Failure Mode & Failure Size? 32.

> Alpha mode, No RPV Failure Debris Cooled In-Vessel, Small Size Bottom Head RPV Failure, Large Size Bottom Head Failure

Water In Pedestal At RPV Failure? 33.

> Flooded + Injection, Residual Water + Injection, Flooding, Residual Water Only

Pedestal Failure Due To Overpressure At RFV Failure? 34.

Pedestal Failure, No Failure

Pedestal Cavity Steam Explosion? 35.

Steam Explosion, No Explosion

Pedestal Failure Due To Steam Explosion? 36.

Pedestal Failure, No Failure

Drywell Failure Due To Pedestal Failure? 37.

Drywell Failure, No Failure

Drywell Overpressure Failure At RPV Failure? 38,

Drywell Failure, No Failure

Drywell Failure At/Near KPV Failure? 39.

Drywell Failure, No Failure

CET EVENT 5. MODE OF CONTAINMENT FAILURE AT/NEAR RPV FAILURE

Containment Steam Concentration At/Near RPV Failure? 40. 0-15%, 15-25%, 25-35%, 35-45%, 45-55%, >55%

Fraction Zirconium Inventory Reacted At/Near RPV Failure? 41. 11%. 22%, 33%

42. Hydrogen Ignition Sources Available At RPV Failure? No Ignition Source, Ignition Source

43. High Pressure Melt _ stion? HPME, No HPME

44. Large H2 Burn At/Near RPV Failure?

No Large Burn Ignited, Large Burn Ignited

- 45. Hydrogen Detonation Containment Failure At/Near RPV Failure? Detonation Containment Failure, No Failure
- 46. Containment Failure At/Near RPV Failure? Failure, No Failure
- 47. Mode Of Containment Failure At/Near RPV Failure? Anchorage, Penetration-Dome or No Failure

CET EVENT 6. POOL BYPASS BEFORE/NEAR RPV FAILURE

- 48. Drywell Failure Due To Containment H2 Burn Before/Near RPV Failure? Drywell Failure, No Drywell Failure
- 49. Pool Bypass Before Near RFV Failure?

Pool Bypass, No Pool Bypasss

CET EVENT 7. INJECTION & SPRAY FAILURE DUE TO CONTAINMENT FAILURE AT/NEAR RPV FAILURE

50. Containment Failure At/Near RPV Failure Impact On ECCS Injection And Spray Piping?

No Failure, Failure

51. Containment Failure At/Near RFV Failure Impact on ECCS Injection And Spray Motors?

No Failure, Failure

52. Containment Failure At/Near RPV Failure Steam & Radiation Impact

On Firewater System?

No Failure, Failure

53. Injection & Spray Failure Due To Containment Failure Before/Near RFV Failure?

No Failure, Injection & Spray Failure

CET EVENT 8. PEDESTAL FAILURE DUE TO CORE CONCRETE INTERACTION

54. Type Of Core Debris Concrete Interactions?

Dry CCI, Wast-Wet, Slow-Wet, No CCI

55. Pedestal Failure Due To Core Debris Concrete Interaction? At Vessel Breach, After Vessel Breach, No Failure

CET EVENT 9. MODE OF LATE BURN & OVERPRESSURE CONTAINMENT FAILURE

- 56. Mode Of RHR Spray Operation Late? Controlled, Design Cooling, No Spray
- 57. Hydrogen Ignition Sources Available Late? No Source, Hydrogen Ignition Source
- 58. Containment Steam Concentration Late?

0-15%, 15-25%, 25-35%, 35-45%, 45-55%, > 55%

59. H2 Combustion Before/At RPV Failure?

Early Burn, No Early Burn

60. Containment Effective Hydrogen Concentration Late?

< 4%, 4-8%, 8-12%, 12-16%, 16-20%, > 20%

61. AC Power Available Late?

AC Late, No AC Late

62. Large H2 Burn Late?

No Burn Ignited, Large Burn Ignited

63. Hydrogen Detonation Late Conttinment Failure?

Detonation Containment Failure, No

64. Hydrogen Burn Late Containment Failuie?

Failure, No Failure

65. Containment Status At Accident Progression Progression?

Early Containment Failure, Late Containment Failure, Vent, No Containment Failure

66. Mode Of Late Hydrogen & Overpressure Containment Failure? Anchorage, Penetration-Dome or No Failure

CET EVENT 10. LATE POOL BYPASS

- 67. Drywell Failure Due To Late Hydrogen Burn In Containment? Drywell Failure, No Failure
- 68. Pool Bypass Late?

Late Pool Bypass, No Late Bypass

TABLE 4.5.3-1 APET CONTAINMENT PERFORMANCE BASE CASE RESULTS

		FREQUENCY	FRACTION OF CDF
No RPV Fail:	No Containment Failure	3.39E6	26.7%
	Vent	2.45E-6	19.3%
	Containment Failure	6.18E-7	4.9%
Subtotal No RPV	Failure Core Damage Frequency:	б.46Е—б	50.8%
RPV Fail:	No Containment Failure	1.58E-6	12.4%
	Vent	1.27E-6	10.0%
	Late Containment Failure	9.38E-7	7.4%
	Early CF: No Pool Bypass	4.30E-7	3.4%
	Late Pool Bypass	1,54E-6	12.1%
	Early PB, Spray	6.12E-8	0.5%
	Eacly FB, No Spray	4.45E-7	3.5%
Subtotal RPV	Failure Core Damage Frequency:	6.27E-6	49.2%
	TOTAL CORE DAMAGE FREQUENCY:	1,27E-5	100.0%
Subtotal	Containment Venting Frequency:		29.2%
Subtotal Cntr	at Structural Failure Frequency:	4.03E-6	
TOTAL CONTAINM	ENT FAILURE & VENTING FREQUENCY:	7.76E-6	60.9%
	THE REAL PROPERTY PARTIES OF TAXABLE		

RFV FAILURE AND EARLY CONTAINMENT FAILURE WITH POOL BYPASS FREQUENCY: 2.04E-6 16.1% TABLE 4.5.3-2 APET CONTAINMENT PERFORMANCE BASE CASE RESULTS FOR DOMERATE FOS GROUPS

CHINE COLVE				BENING AFF FAMILY AND AND	NO REV FAILURE	61		BELL FAILURE	ILLINE							CONTAINMENT AND VENTING		3411SO464CO
FAILURE AND VENTING CORE DAMAGE FREQUENCT	TREQ	DA	HOUE NOT	No CF	VENT	ы	Total	5	Vent	d Iste	by	Contain Late	Containment Failure Early wrly Late FB, vd, on three En Co.	illure sely selv.	Total	CONTALINMENT STREECTORAL FALLIPE Parat Anch	BRDH CRAL	111100
	3.40E	9	34.0%	\$6.00	68.98	30.00	58.9%	10.04	30.1%	\$0.0%	00.04	00.04	0.00%	1.00%	31.1%	1.0%	0.0%	\$904
15.8 1.22E-6	1.22£	4	9.6	000	00.0	000	0.00	00.0	00.0	0.00	0.00	84.3	0.00	15.9	100.0	85.0	15.0	0.0
8.0 6.235-7	6.23	1	6.8	60.00	0.00	000	0.00	0.00	0.00	0.96	0.00	0.00	0.008	1.00	100.0	85.1	14.9	0.0
7.2 5.598-7	5.59	1-3	4.4	0.00	00.0	69.2	69.2	00.00	0.00	0.00	19.8	5.45	0.00	5.49	30.8	85.0	15.9	0.0
3.8 2.938-7	2.9	1-3	2.3	00.0	0.00	00.00	0.00	00.0	0.00	0.02	46.9	33.2	00	15.9	100.0	85.0	15.0	0.0
3.4 2.6	2.6	2.658-7	2.1	00.0	00.0	59.2	69.2	00.0	0.00	000	19.8	5.48	0.00	5.50	30.8	85.0	0.21	0.0
3.3 2.5	2.5	2.566-7	2.0	0.00	0.160	00.00	000	00.00	0.00	0.00	00.00	34.1	0.00	15.9	100.6	62.0	15.0	0.0
1.1 I.6	10	1-369-1	1.3	0.00	00.00	00.00	0.00	00.0	0.00	0.00	5.95	37.2	1.29	14.7	100.0	82.0	12.0	0.0
1.8 2.6	14	1.0%6-7	1.6	00.0	0.00	000	0.00	33.7	0.00	57.5	0.26	4.11	0.00	9.37	0.001	31.0	35.3	0.0
1.3 1.0		1.026-7	0.8	0.00	6.83	000	68.9	00.0	30.1	000	00.0	00.00	0.00	1.00	1.11	1.0	0.0	0.46
1.3 1.1	ed	1.998-7	8.0	000	00.0	00.00	00.00	00.00	0.00	0.00	46.8	36.5	0.00	16.7	100.0	82.0	15.0	0.0
	é	8-326-6	0.8	00.9	0.00	00.00	00.00	35.8	0.00	63.2	0.00	0.00	0.00	1.00	100.0	20.6	19°.4	0.0
3.8 6.	4	6.15E-8	0.5	000	0.00	00.00	00.00	6.00	6.86	50.0	0.00	00.00	0.00	1.01	100.0	1.0	1.0	5.85
0.7 3.1	di.	3-07E-8	9.4	000	90.0	00.00	0.00	00.00	00.00	6.22	0.00	0.00	0.00	0.11	100.0	85.0	15.0	0.0
0.4 4.1	-	4.445-6	34.9	69.2	0.00	0.01	69.2	29.8	0.00	0.00	0.00	00.00	1.00	000	30.8	1.0	0.0	0.0
9.4 3.2	1.1	3.236-8	5.0	000	000	000	00.00	00.00	0.00	0.00	0.00	1.15	0.00	16.7	0.00	85.0	15.0	9.0
100% 1.2	2.1	1.276-5	1001	26.7%	19.3%	4.9%	\$0.8%	12.68	10.01	7.4%	3.48	12.18	0.54	3.5%	42.23	26.7%	5.0%	N285

0

TABLE 4.5.3-3 DOMINANT CONTAINMENT FAILURE PLANT DAMAGE STATES

Rank	PDS CLASS	FREQUENCY	CNTMT FAILURE PERCENT	CDF PERCENT	DOM JANT SEQUENCES	CDF%
1	56	3.402-6	43.9%	34.0%	13B-U1-U2-Va1 TIA-U2-U1-V-Va-Wc-Ws B6-V-Wc F1D-U3-U2-U1-V-Va A-U1-V-Wc-Ws T15-Va	8.9% 5.9% 3.0% 1.8% 1.6%
2	73	1.22E-6	15.8%	9.6%	T2-Wc-Ws-Y-CV-Li	8.2%
3	61	6.23E-7	8.0%	4.9%	T15-Va-R3 UR-V-Va-R3	2.6%
4	71	5.59E-7	7.2%	4.4%	T2-WC-WS-Y-CV T1-U2-WC-WS-Y-CV	2.2% 1.5%
5	65	2.93E-7	3.8%	2.3%	T2-CA-C1-Wc	1.1%
6	67	2.65E-7	3.4%	2.1%		
7	69	2.56E-7	3.3%	2.0%		
8	63	1.69E-7	2.1%	1.3%	T2-CA	1.2%
9	25	2.09E-7	1.8%	1.6%		
10	36	1.02E-7	1.3%	0.8%		
11	66	1.00E-7	1.3%	0.8%		
12	9	9.73E-8	0.8%	0.8%		
13	58	6.15E-8	0.8%	0,5%		
14	62	5.02E-8	0.7%	0.4%		
21	5 53	4.44E-6	0.6%	34.9%		
1	6 70	3.23E-8	8 0.41	0.3%		

(1)

10.1

TABLE 4.6.3-1 IMPACT OF DESIGN CHANGES ON CONTAINMENT FAILURE FREQUENCY

Ø

ġ



	BASE CASE	(1) PASSIVE VENT	(2) ATWS ALTRNATE SHUTDOWN & ADS INHIBIT		(4) PASSIVE VENT, ALT 5/D 6 ADS INNIBIT	(5) PASSIVE VENT, ATHE ALT S/D & ADS INHIBIT, HIS BACRUP POWER SUPPY
No RPV Failure: No Containment Failure	3,39E=6 (26.7%)	3.39E-6 (32.6%)	1.828-6 (17.6%)	3.42E-6 (26.9%)	1.828-6	1.65E+6 (23.1%)
Vent	2.45E-6	2,92E-6	2.81E-6	2.45E-6	3.285-6	3.28E-6
	(19.3%)	(28,1%)	(27.2%)	(19.3%)	(41.64)	(41.0%)
Containment Failure	6.188-7	2.67E-8	6.18E-7	5.93E-7	2.888-8	3,588-9
	(4.9%)	(0.3%)	(6.0%)	(4.7%)	(4%)	(.04%)
Subtotal No RPV Pailure Core Dumage Freq:	6.46E-6	6.34E-6	5.25E-6	6.46E-6	5.13E-6	5.13E-6
	(50.8%)	(61.0%)	(50.9%)	(50.8%)	(64.1%)	(64.1%)
RPV Failure: No Containment Failure	1.58E-6	1.58E-6	9.06E-7	1.79E-6	9.06E-7	1.12E-6
	(12.4%)	(15.2%)	(8.8%)	(14.1%)	(11.3%)	(14.0%)
Vent	1.27E-6	1.52E-6	1.30E-6	1.31E-6	1.54E-6	1.598-6
	(10.0%)	(14.6%)	(12.5%)	(10.3%)	(19.3%)	(19.8%)
Late Containment Failure	9.38E-7	2.46E=7	9.39E-7	7.31E+7	2.46E-7	3.258-8
	(7.4%)	(2.4%)	(9.1%)	(5.7%)	(3.1%)	(0.4%)
Early CF: No Fool Bypass		2.678-7 (2.6%)	1.85E-7 (1.8%)	4.30E-7 (3.4%)	2.53E-8 (0.3%)	2.50E~8 (0.3%)
Lata Pool Bypass	1.548-6	2.26E-7	1.34E=6	1.53E-6	3.588-8	2.588-8
	(12.1%)	(2.2%)	(13.0%)	(12.0%)	(0.4%)	(0.3%)
Early PB, Spray	6.12E-8	6.12E-8	3.74E-8	5.128~8	3.748+8	2.742-8
	(0.5%)	(0.6%)	(0.4%)	(0.4%)	(0.5%)	(0.3%)
Early PB, No Spray	4.45E-7	1.61E+7	3,67E-7	4.228-7	8.36E-8	6.05E~8
	(3.5%)	(1.5%)	(3,6%)	(3.3%)	(1.0%)	(0.0%)
Subtotal RFV Failure Core Damage Freq:	6.275-6 (49.2%)	4.06E-6 (39.0%)	5.08E-6 (49.1%)	6.275-6	2.87E-6 (35.9%)	2.888-6 (35.9%)
TOTAL CORE DAMAGE PREQUENCY :	1.27E-5	1.04E-5	1.03E-5	1.27E-5	8.01E-6	8.01E-6
	(100%)	(100%)	(100%)	(100%)	(100%)	(100%)
Subtotal Containment Venting Prequency:	3.72E-6 (29.2%)	4.43E-6 (42.6%)	4.11E-6 (39.8%)	3.76E-6 (29.5%)	4.82E-6 (60.2%)	
Subtotal Cntmt Structural Pailure Preg:	4.03E+6 (31.7%)		3.49E+6 (33.8%)	3.762-6 (29.5%)		
TOTAL CONTAINMENT FAILURE & VENTING FREQ:	7.76E-6 (60.9%)		7.60E-6 (73.6%)			
RPV FAILURE & BARLY CONTAINMENT FAILURE WITH POOL BYPASS FREQUENCY:	2.04E-6 (16.1%)					

TABLE 4.6.3-2 IMPACT OF DESIGN CHANGES ON CONTAINMENT FAILURE FREQUENCY USING UPGATED INITIATOR FREQUENCY

		BASE CASE	UPDATED INTTIATOR FREQUENCY	(1) UPDATED PASSIVE VENT	(2) UPDATED ATWS ALT SHUTDOWN & ADS		(4) UPDATED PASSIVE VENT, ATWS MODS 4 RIS BACKUP POWER SUPPLY
No RPV Failure:	No Containment Failure	3.39E-6 (26.7%)	1.228-6 (15.2%)	1.22E-6 (18.3%)	7.348-7 (10.0%)	7.34E=7 (12.4%)	7.605-7 (12.8%)
	Vent	2.45E+6 (19.3%)	2.36E-6 (29.4%)	2.828-6 (42.3%)	2.45E+6 (33.5%)	2.91E-6 (49.0*)	2.918-6 (49.0%)
	Containment Failure	6.18E-7 (4.9%)	4.708-7 (5.8%)		4.70E-7 (6.4%)	2.905 ÷ (0.5%)	3.798-9 (0.06%)
Subtotal No RPV	failure Core Damage Freq:	6.46E-6 (50.8%)	4.06E~6 (50.3%)		3.65E-6 (50.0%)	3.67E-6 (61.9%)	3.67E6 (61.94)
RPV Feilure:	No Containment Failure	1.56E-6 (12.4%)	6.22E-7 (7.7%)		4.09E=7 (5.6%)	4.09E-7 (6.9%)	6.21E-7 (10.5%)
	Vent	1,27E-6 (10.0%)	1.23E-6 (15.3%)		1.248-6 (16.9%)	1.48E~6 (25.0%)	1.538-6 (25.7%)
	Late Containment Pailure	9.38E-7 (7.4%)	9.25E-7 (11.5%)		9.25E-7 (12.7%)	2.45E-7 (4.1%)	3.20E-8 (0.5%)
	Early CP: No Pool Bypass	4.30E-7 (3.4%)	1.88E-7 (2.3%)		1,28E-7 (1,7%)	7.37E-9 (0.1%)	7.00E-9 (0.1%)
	Late Pool Bypass	1.54E-6 (12.1%)	7.51E=7 (9.3%)		7.04E-7 (9.6%)	2.05E-8 (0.3%)	1.04E-8 (0.2%)
	Early PE, Spray	6.12E-8 (0.5%)	2.82E-8 (0.3%)		2.09E-8 (0.3%)	2.09E-8 (0.4%)	1.08E-8 (0.2%)
	Early PB, No Sprey	4.45E-7 (3.5%)	2.49E-7 (3.1%)		2,30E-7 (3,1%)	7.36E-8 (1.2%)	5.04E-8 (0.8%)
Subtotal RP	V Failure Core Damage Freq:	6.27E-6 (49.2%)	4.00E-6 (49.7%)	2.56E-6 (38.4%)	3.66E-6 (50.0%)	2.26E-6 (38.1%)	2.26E-6 (38.1%)
27	PTAL CORE DAMAGE PREQUENCY:	1.27E-5 (100%)	8.05E-6 (100%)	6.678-6 (100%)	7.31E-6 (100%)	5.53E-6 (100%)	5.93E-6 (100%)
Subtotal Con	tainment Venting Frequency:	3.72E-6 (29.2%)	3.59E~6 (44.7%)	4.29E-6 (64.4%)	3,698-6 (50,4%)	4.39E-6 (74.0%)	4.43E-6 (74.8%)
Subtotal Cnt	mt Structural Failure	.03E-6 (31.7%)	2.61E-6 (32.53)	5,34E-7 (8,0%)	2.481-6 (33.9%)	3,998-7 (6,7%)	1.158-7 (1.9%)
TOTAL CONTAINS	ENT FAILURE & VENILOS FREQ:	7.76E+6 (60.9%)	6.21E-6 (77,1%)	4.83E-6 (72.4%)	6.17E-6 (84.4%)	4,79E-6 (80,7%)	4.558-6 (76.7%)
RPV PAILURE &	EARLY CONTAINMENT FAILURE WITH FOOL BYPASS FREQUENCY:	2.04E-6 (16.1%)	1.03E=6 (12.8%)		9.54E=7 (13.1%)		7.16E-8 (1.2%)

GENERIC INITIATING EVENT FREQUENCY UPDATED INITIATING EVENT TREQUENCY

.

Ø

Bypass	Core Demage	Containment Structural Failure	RPV Failure And Early Contrment Fail With Fool Bass	Core Damage	Containment Structural Failure	RPV Failure And Early Containment Failure With Fool
Basu Case	1,38-5	4.08-6	2.0E-6	8.1E-6	2.68-6	1.06-6
Passive Vent	1.0E-5 (-18% CHG)	9.9E-7 (-75% CHG)	4.58-7 (-78% CHG)	6.78-6 (-17% CHG)	5.3E-7 (-80% CHG)	2.0E-7 (-81% CHG)
ATMS Mods: idt Shutdown 4 ADS Inhibit	1.0E~5 (-19% CBG)	3.5E~6 (~13% CHG)	1.8E-6 (-14% CHG)	7.3E6 (- 9% CHG)	2.5E-6 (- 5% CHG)	9.5E-7 (- 7% CHG)
Passive Vent <u>& ATWS Mods</u>	8.0E-6 (-37% CHG)	4.6E-7 (-89% CH^)	1.6E-7 (-92% CHG)	5.98-6 (-26% C.G)	4.0E-7 (-85% CHG)	1.2E-7 (-89% CHG)
Passive Vent, ATWS Mods Ignitor Power	8.0E-5 (-37% CNG)	1.8E-7 (-965 CHG)	1.1E-7 (-94% CHG)	5,9E6 (~26% CHG)	1.2E-7 (-96% CHG)	7.215-8 (-93% CHG)

These results are based on an analysis of the core damage analysis of the core damage sequences included in the plant damage state trees. Thus there are small differences in the impact of changes reported in this table compared with those reported for internal event core damage sequences in section 3.4. These differences do not change the overall conclusions.

NOTE :



ä

Q


STC	MAAP Run Nc.	Description
1	ST_01	Transient with loss of containment heat removal. Containment overpressure failure r
2	ST_02	Transient with loss of containment heat removal. Containment overpressure failure results in loss of all injection.
3	ST_03	Transient with loss of injection at 12 hours. RPV failure occurs near containment failure. Containment overpressure failure results in a anchorage failure and suppression pool bypass.
5	ST_05	Transient with loss of injection at 12 hours. RPV failure occurs near containment failure. Containment overpressure failure results in a penetration failure. Suppression pool bypass occurs near the time of containment failure.
8	ST_08	Transient with initial loss of injection. Containment overpressure results in penetration failure late in the accident sequence. Suppression pool bypass occurs near the time of containment failure.
10	ST_10	Transient with initial loss of all injection. RPV failure occurs before the containment vent is opened. Suppression pool bypass occurs near the time of containment venting.
11	ST_11	Transient with initial loss of all injection. RPV failure occurs before the containment vent is opened.
13	ST_13	Transient with loss of containment heat removal. Containment overpressure failure results in loss of injection and suppression pool bypass. Recovery of injection cools the debris in-vessel.
14	ST_14	Transient with loss of containment heat removal. Containment overpressure failure results in loss of injection. Recovery of injection cools the debris in-vessel.
21	ST_21	Transient with initial loss of all injection. Recovery of injection cools the debris in-vessel. Containment overpressure results in penetration failure.
23	ST_23	Transient with initial loss of all injection. Recovery of injection cools the debris in-vessel. Containment overpressure failure results in penetration failure.

TABLE 4.7.3-2 TIME OF OCCURRENCE FOR IMPORTANT EVENTS IN RELEASE CATEGORY CASES

Time in Hours

STC No.	Initial Injection Failure	Core Uncovery	Injection Recovery	RPV Failure	Containment Failure	Containment Vent Open	Suppression Pool Bypass	End Of Source Release Run
1	19.7	22.2	-	27.8	19.7	-	19.7	80.
2	19.7	22.2		27.8	19.7		-	100.
3	12.0	15.8		20.8	20.8			100.
5	12.0	15.8		20.8	20.8			100.
8	00.0	0.55		1.8	59.0	4 H H	59.0	100.
10	00.0	0.55		1.8	영화 등을 얻는	26.7	26.7	100.
21	00.0	0.55		1.8	10 - C	26.7		100.
13	19.6	22.1	25.5	1.11	19.6	사망 수 같아	19.6	60.
14	19.6	22.1	25.5		19.6			60.
21	0.	0.55	1.5		50.3			100.
23	0.	0.55	1.5			30.0	(† 4 ⁸)	100.





Source						мал	P Spacie R	elease Fra	ction				
Term Category	Basis	NOBLES	<u>CSI</u>	TEO2	590	<u>M002</u>	CSOH	BAO	LA203	CE02	58	TE2	002
1	MAAP	1.0	2.78-2	2.48-2	1.18-3	3.4E-4	2.96-2	6.1E-4	4.68-5	3.65-4	7.7E-2	4.9E-3	8.4E-7
2	MAAP	.93	3.62-3	2.06-3	3.08-5	4.5E-4	3.6E-3	5.78-5	9.0E-7	6.38-6	1.3E-3	8.5E-5	1.62-8
3	MAAP	1.0	6.0E-2	4.85-2	1.9E-4	3.1. 4	9.55-2	1.2E-4	9.05-6	8.56-5	1.1E-1	5.98-3	2.7E-7
4	Rec	(Use ST	c 5)										
5	MAAP	1.0	8.76-2	8.08-2	7.88-4	7.88-4	1.3E-1	5.6E-4	2.48-5	2.46-4	1.25-1	4.38-3	5.48-7
б	Rec	(Ura ST	c 5)										
7	Rec	(Use ST	C 8)										
8	MAAP	.85	6.28-3	1.6E-2	5.8E-7	5.2E-8	6.5E-3	3.98-6	2.2E-9	6.6E-9	5.0E-3	3.4E6	1E-8
9	Rec	(Use ST	C 11)										
10	MAAP	.99	1.4E-1	1.02-1	2.48-6	1.18-6	1.1E-1	3.38-6	3.3E-8	2.28-7	1.68-2	8.62-4	9.38-8
11	MAAP	.62	3.16-2	8.68-3	2.9E-7	2.58-7	2.98-2	3.7E-7	1.18-8	8.38-8	1.36-3	5.7E-4	1.0E-8
12	Rec	(Zero R	elease)										
13	MAAP	.92	9.98-2	7.6E-3	1.86-4	9.2E-3	1.02-1	1.36-3	1.3E-6	1.95-6	5.1E-2	6-3 >	< E-8
14	MAAP	.89	1.26-3	1.66-4	6.58-6	3.38-4	1.1E-3	5.58-5	4.8E-8	5.98-8	1.9E-3	< E-8	< E-8
15	Rec	(Use ST	C 13)										
16	Rec	(Use ST	c 13)										
17	Rec	(Use ST	c 13)										
18	Rec	(Use ST	c 13)										
19	Rec	(Use ST	C 13)										
20	Rec	(Use ST	c 13)										
21	MAAP	. 96	1.46-6	1,68-7	< E-8	< E-8	9.1E-6	< E-10	< E-10	< E-10	1.2E-6	< 5-8	< E-8
22	Rec	(Use ST	c 13)										
23	MAAP	.96	2.36-7	1.46-8	< E-3	< E-8	8.8E-6	< ≌−8	< 5-8	< E-8	2.06-7	< E-8	< E-8
24	Rec	(Zero R	elease)										

TABLE 4.7.3-4


RECOMMENDATIONS FOR RELEASE FRACTIONS FOR UNANALYZED SOURCE TERM CATEGORIES

STC No.	Containment Failure Time	Sprays	Recommended Alternate STC No.	Justification Bases
12,24	No CF		N/A	Assume Zero Release.
4	Early CF	Late	5	Conservatively ignore Late Sprays.
6	Early CF	No	5	Conservatively ignore the No pool bypass case.
7	Late CF	No	8	The rupture site associated with the penetration failure (3.5 sq ft) relatively large and is sufficient to model the anchorage failure (20 sq ft).
9	Late CF	No	11	Conservatively use the venting release which would occur earlier than penetration failure.
15 - 18	Early CF	Late/No	13	These Early CF categories which contribute less than 0.002 of the total release fraction can be conservatively modeled as having the containment failed at core damage with early pool bypass.
19,20,22	Late CF	No	13	The Late CF categories which contribute about 0.0004 of the total release fraction can be conservatively modeled as having the containment failed at core damage with early pool bypass.





TABLE 4.7.3-5 MAAP FISSION PRODUCT SPECIES



Notes: see following pages





TABLE 4.7.3-5 (Continued) MAAP FISSION PRODUCT SPECIES

Explanation of Species Notes

Specie (1): The Specie (1) vapors represent the noble gases. The Specie(1) aerosols are used to represent all non-radioactive aerosols (except for water droplets which are tracked separately in the thermal-hydraulic routines). The aerosol and deposited masses represent the core structural materials along with any concrete aerosols generated ex-vessel. The Specie (1) solid aerosols are assumed to have negligible vapor pressure at the temperatures of interest except in the core or core debris. The vapor pressure assumption used in the core and core debris are discussed in the write-ups for subroutines FPRATP and METOXA.

Specie (2): This specie represents the compounds CsI and RbI. all of the iodine is assumed to combine with the alkali fission products since the molar ratio is about 10 to 1 in favor of cesium and rubidium. Due to the dominance of cesium, CsI properties are chosen.

Specie (3): This specie represents tellurium that is oxidized to TeO. Tellurium released in-core is assumed to form TeO. directly. Tellurium released ex-vessel is assumed to be elemental; it is allowed to oxidize to TeO in the cavity if steam or oxygen are present (see subroutine METOXA).

Specie (4): Strontium is primarily released in elemental form ex-vessel and is assumed to oxidize to SrO in Containment. In-vessel release is also assumed to lead to SrO formation.

Specie (5): this specie is MoO . This chemical state is assumed since molybdenum is thought to be mainly released during concrete attack.

Specie (6): this specie includes CsOH and RbOH. It represents any cesium and rubidium that is left over after combination with iodine.

Specie (7): this specie is BaO. Barium behaves similarly to strontium due to its chemical periodicity.

Specie (8): This specie represents the lanthanides. All sesquioxides in the lanthanide series are grouped together due to similar chemical behavior. These are rather nonvolatile, but in-vessel release is allowed. They are believed primarily to be released ex-vessel as monoxides, which are further oxidized in Containment.

TABLE 4.7.3-5 (Continued) MAAP FISSION PRODUCT SPECIES

Specie (9): Cerium behavior is similar to lanthanide behavior but stoichiometry and vapor pressure differ enough to warrant a separate group.

Specie (10): Antimony is released in-vessel and ex-vessel in elemental form.

Specie (11): Tellurium released ex-vessel which doesn't oxidize in the cavity remains "frozen" as Te .

Specie (12): Uranium and the transuranics are grouped separately from the other fission products such as cesium because of their different radiological characteristics. These are only released ex-vessel, and are assumed to oxidize (or reduce) to the dioxide form in Containment.

TABLE 4.7.4-1 DOMINANT SOURCE TERM CATEGORIES

Rank	Source Term Category	Frequency	Percent of Total CDF	
1	24	3.39E-6	26.65	
2	23	2.45E-6	19.23	
3	1	1.90E-6	14.96	
4	12	1.58E-6	12.42	
5	11	8.92E-7	7.00	
6	8	6.67E-7	5.26	
7	14	4.86E-7	3.82	
8	2	4.29E-7	3.37	
9	10	3.79E-7	2.97	



TABLE 4.7.4-2 IMPORTANCE OF PLANT DAMAGE STATES TO RELEASE CATECORIES

Total Frequency = 1.27x10⁻⁵

Percent Percent Source of Total of STC STC PDS Term Frequency Frequency Frequency Category No. 14.96% 1.90E-6 STC 1 1.22E-6 64 PDS 73 PDS 65 8 PDS 63 5 PDS 71 3 PDS 66 3 PDS 67 2 PDS 70 2 2.56E-7 13 PDS 69 1.56E-7 8.98E-8 6.14E-8 5.32E-8 2.91E-8 3.23E-8 4.29E-7 3.37% STC 2 1.38E-7 32 PDS 65 1.11E-7 26 PDS 71 18 12 7.94E-8 PDS 63 5.26E-8 12 PDS 67 4.68E-8 PDS 66 11 0.23% 2.56E-8 STC 3 1.56E-8 53 PDS 25 6.25E-9 21 PDS 20 4.11E-9 14 PDS 32 2 1 1 1 5.10E-1C PDS 9 3.46E-10 PDS 1 1.88E-10 PDS 53 1.55E-10 PDS 8 4.89E-8 0.38% STC 4 3.33E-8 68 PDS 53 9.71E-9 PDS 25 20 4 1.88E-9 PDS 32 3 1.71E-9 PDS 20 1.65E-9 3 PDS 1 PDS 9 1 PDS 8 1 PDS 1 3.47E-10 2.75E-10



Source Term Category		Percent of STC Frequency	STC Frequency	Percent of Total Frequency
STC 5			6.16E-8	0.48%
	PDS 56 PDS 53 PDS 61 PDS 25 PDS 36 PDS 20 PDS 32 PDS 58 PDS 1	55 18 10 5 2 1 1 1	3.40E-8 1.11E-8 6.26E-9 2.87E-9 1.02E-9 8.51E-10 6.28E-10 6.18E-10 5.15E-10	
STC 6			7.90E-10	0.0052%
	PDS 25 PDS 20 PDS 32	70 10 9	5.50E-10 8.14E-11 6.95E-11	
STC 7			2.55E-7	2.00%
	PDS 61 PDS 25 PDS 9 PDS 1 PDS 62 PDS 62 PDS 8 PDS 32 PDS 4 PDS 20	36 23 19 4 3 2 1 1	9.25E-8 5.80E-8 4.91E-8 9.25E-9 7.52E-9 5.99E-9 3.66E-9 3.20E-9 2.02E-9	
STC 8			6.69E-7	5.26%
	PDS 61 PDS 25 PDS 62 PDS 9 PDS 1	78 8 6 2 1	5.24E-7 5.15E-8 4.26E-8 1.24E-8 4.96E-9	
STC 9			1.45E-8	0.11%
	PDS 40 PDS 1 PDS 32 PDS 8 PDS 4 PDS 20	37 5 2 2 2 1	5.40E-9 7.24E-10 2.85E-10 2.55E-10 2.44E-10 1.58E-10	





Source Term Category	PDS No.	Percent of STC Frequency	STC Frequency	Percent of Total Frequency
STC 10			3.79E-7	2.97%
	PDS 56 PDS 58 PDS 37 PDS 36 PDS 4 PDS 38	62 16 2 2 2 1	2 36E-7 6.08E-8 8.13E-9 7.15E-9 6.53E-9 4.06E-9	
STC 11			8.92E-7	7.01%
	PDS 56 PDS 36 PDS 37 PDS 4 PDS 38	88 3 2 2 2	7.88E-7 2.36E-8 1.70E-8 1.59E-8 1.41E-8	
STC 12			1.58E-6	12.42%
	PDS 53 PDS 25 PDS 1 PDS 54 PDS 9 PDS 32 PDS 20	84 4 2 2 2 1	1.32E-6 7.04E-8 5.99E-8 3.49E-8 3.48E-8 2.61E-8 1.32E-8	
STC 13			8.58E-8	0.67%
	PDS 71 PDS 67	68 32	5.81E-8 2.76E-8	
STC 14			4.86E-7	3.82%
	PDS 71 PDS 67	68 32	3.29E-7 1.56E-7	
STC 15			1.68E-8	0.13%
	PDS 32 PDS 20 PDS 53 PDS 56	52 45 1 1	8.78E-9 7.61E-9 1.14E-10 8.52E-11	

Source Term Category	PDS No.	Percent of STC Frequency	STC Frequency	Percent of Total Frequency
STC 16			6.06E-9	0.048%
	PDS 20 PDS 32 PDS 53	53 45 2	3.22E-9 2.71E-9 1.28E-10	
STC 17			2.00E-9	0.016%
	PDS 32 PDS 20 PDS 56 PDS 53	45 38 5 1	9.02E-10 7.68E-10 1.07E-10 1.54E-11	
STC 18			7.97E-10	0.0063%
	PDS 20 PDS 32 PDS 53 PDS 56	34 32 1 1	2.73E-10 2.54E-10 1.18E-11 7.99E-12	
STC 19			3.46E-9	0.027%
	PDS 40 PDS 53 PDS 56	83 6 5	2.89E-9 2.05E-10 1.56E-10	
STC 20			9.48E-11	0.00074%
	PDS 53 PDS 56 PDS 40	55 41 3	5.18E-11 3.92E-11 3.27E-12	
STC 21			1.76E-8	0.14%
	PDS 40	93	1.64E-8	
STC 22			1.79E-9	0.014%
	PDS 3 PDS 56 PDS 36		9.91E-10 5.35E-10 1.40E-11	

.

Source Term Category	PDS No.	Percent of STC Frequency	STC Frequency	Percent of Total Frequency
STC 23			2.45E-6	19.23%
	PDS 56 PDS 36 PDS 3	96 3 1	2.34E-6 7.02E-8 1.55E-8	
STC 24			3.39E6	26.65%
	PDS 53 PDS 1 PDS 32 PDS 20 PDS 8	91 5 2 1 1	3.07E-6 1.74E-7 7.44E-8 3.82E-8 3.45E-8	










Figure 4.1.1-1 PNPP Mark Ill Containment

	i	le,	8	a		
					4	
					2	1
					U	
					٩	
					١	

-180		
158	85.	
	A	

273 -- mino 26 7-01 TLE 5 DAT 23 -90 ŵ 604 PNPP 1







.



Sec.

I







.

1.


ler-







.....


-






ENTRY FIRDH MEANT DAMAGE STATE	DEBA18 COSLED LH-FERSEL	HODE OF CHINT FAILLARE BEFORE DPS FAILLARE	TALLUR OLE TO CNTHT FAILURE BETOTE BOY FAILURE	CHYRELL FAILDHE AT/HEAR BPs FAILLHHE	WOOLE OF ENTH? FAILUME AT/MEAR RPV FAILUME	POR # PASS B.FORE/MESP BPY FAILURE	INGECT & SPAT FAILUR DUE TO ONTHE FAILURE A1/HEAR SPY FAILURE	PEDESIAL FAILLPHE DARY FD DDI	HODE OF LATE BURN 5 DREAMESSUNE DREAM FAILURE	POD. S.YP455 .416	E F	5 T C .	PRD
681 - 2	IN= _0001	V ERLY CF	IN. FAILT	EARLY DR	CF VB	PB EARLY	INJ FAIL2	PED_FAL	LATE_CF	PB_LATE			
VENT -	INV_COOL	V_CHLT_LF	ale sant addresses convert	Lewing 1 - 100	An and the second second	149.1 10	Contraction in	he are an an article of the second	kana in minima and	A successive end of the second	1	1	
		196703167	HALEBERT FALL			544.1 M							
			23 and the second	OR FAILURE		148.1.98							
			INCOMPACT ALL					-		1.1.1. Pl	4		
			part of the second states	NO. 142 JUL				printed the subscription		<u>NO 21(6455</u>	5		
		FENETATE/DOWN		And the state of the second				NO FAILURE		1411.Ph	6		
				1.1.1.1						<u>-62. 81.74.93.</u>	7		
			NO FAILUM	DR. 131695		EARLY EVPRESS		PEDESTAL TALL			8		
				B DIME		HE 475-55		NO FAILURE			10		
							18.8 9291 FAD				11		
	NO1 200.40				195.9254.84	FAST_PB	NE FAILURE		-		12		
					-	1201 1 10	IN HERE YELL			anter anter a	1.1		
					PENETATA/SRIKE	1150-54	ME CALLARS				14		
									LUCHERICE	ens en en estador	12		
					NU FAILUNE		HE CALLAR		Presiding starte		1.8		
									NG 2 ⁴		12		
							INJERPRI FAIL				1.0		
		ala di Sa			102908161	1481.7 88	HE FAILURE				20		
			-	1.000							21		
		<u>NG_CF</u>	ND FAILURE	1995 640		133.1.78	10 FALSON				22		
										115 PR	-13		
					RENETATIN DONE		18.8891.5x1.			AG BYFEBS	20		
								NO TATION		- NO BIRADO	25		
						NO BURARS				1112.99	28		
								PEDERIAL FAIL			28		
	1.			NO. 7.671.5091	-		1.90 CALLARS			1415.00	29		
	1.00							Lag Palipate		ND @(P431	- 10	1.	
									A HE HEAT BE	1371.89	- 31		
										-LATE BYRASS	- 32		
									PENETRIN/DOM	L NO BURIES	- 23	1	1
					1255			PERSIAL PALS		LATE RYPASS	- 38		100
									(68)	NO 819190	36	1.1	1.1
									NO 21		- 47		
					30 TAIL (MA)	KQ RYPISS	40 FRILUEE	-	440307433	1478.00	- 20	1	
										40.818153	- 38	1.	
									ACRETATIN/DOM	14.11 M	40	14	1
								NO FAILURE	-	6112.54].	1	
									<u>.vist</u>		- 43		
									ND 27		- 11		1
		1.1.1	14.16 (PAR- 1.1)			110.1.00			analy in the second state			9	
		KHCHORAGI	ND FRILINE			14917.04					- 41	11	1
	1.00			ON PAILURE		EXEC. 28		in so the second second		1411 48			1
	1.00		1845(991.73)	MI 7415088						NO 819433	- 4		
		PENETATA/DO	<u>M(</u>			EXELY PR						11	1.
	COD. 0 3446846		ND FAILURE			-	and the second second second second				-		1
	CANEN ALLA ZALARA					NO 818455				WC 819155		- X	1
									100109308	1215.00	5	3	1
										NO BYPASS	-3		
									PENETR TH/DD	ME 80 81945	1	1	
		NO. 57	NO TAILOP			96 RTP133					- 5	- H	
									4887	40 BYF425	1,	1.1	1
									wù 27			3	
												1	-
				diversities and the						ANT UNIT 1			
					1.1.74		14	DIVIOUAL ETGUO	E & 5 2 1			-	
							S116	MARY CONT	ATNMENT E	VENT THEE			





REVISION 0



· Cor «

_ 6


			2		2.	
1	đ				88	٤.
4						
4						
3	ų					æ
	3	۶	9	1	æ	٩.

FROM INITION CET	AL PHIA WODE STEAM EXPLOSION ON & CHIMT	MEDE OF IN-YESSEL STEAM EXPLOSION BOTTOM MEAD	BALL 4 1 H 2	HATER IN PEOESTAL AT RAPY / LLURE	PEDESTAL FAILURE DUR TO DUR TO DUR DOMESSLOR	REDESTAL CAVITI STEAM EXPLOSION	PEDESTAL FALLANE SLE TO STEAM	OFFWELL FallORE DUAE TO PEDEDTAL	SALANE DATE HANNE STORE E & T. TONE E & T. TONE	DRIVING LL FAILLING AT/MEAR HOW
EVENT	FAILUNE	NEY FAILURE	LANGE + 2 #'2	PED_WATER	PED_DP	STH_EXP	PED_EXH	DN PED	DN OP	EARLY DW
EVENT ->	ALPHA	INV_EXPLN	An or a start of the second start of the secon	INCU MAICH	1 PED DP	1 SIN EAF	I TED EAT	1 00 100	1	NO TAILURE
			NO PAILORE	and the second sec	the state of the s			OR FALLURE		QN FAILURE
			1.2.1.2.1.1.1	F32 + 244	PEDESTRY CATS	and the second		NO FAILURE	PR YALLIMA	OR FELLINE
				10.00					THE FRIDE	NO FAILURS
				1	PEDERTAL FAIL			24 7115URE	ON TALLING	DA FAILURE
								190 X + 12 1991	- NO FAILURE	AD ESTIMAT
				1. Sec. 1.	the second second		PROPERTAL PAIL	in retains		R8.73.1-198
			1-36.70	HPR 1.18d			14932.35.140	WE FELLINE	OR FAILORE	BR FRILDER HD FRILDER
				1.11		118 81PARTON	1.3.2.0		BE FAILURE	DA FALLURE
			1.4955 VT		190 FX1,081	1. C. S	WO FAILURE		NO FAILLAR	AND PERSONAL
			Mart 2 M2 contract of the second			NO FASLIMO			DA FARLIN.	UN FAILURE
								04.7431-0ML	140 7A11488	DA FALLUAL
			100 C - 10	1.000 146	MORSTAL FELL			Junior Contraction of	DR. CALLURE	DR. FAILLING
			1 A. 12					SS THE PAL	MR. FAILURS	NO FAILURE
					PEDERIAS PROS			SH FAILURE	AN FAILURE	BA FAILURE
			10 al 17 al		-			145. FAILUAS	THE FAILLINE	40 FALLONE
		MD 743LUBS		Contract of the second				ON FAILURE	(alexandre alexandre	QN EASSLIER
		12-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-	6 - C - C - C - C - C - C - C - C - C -	(epy yeirs)	-		PERESTAL PAIL	NO PAILORE	OF FAILURE	De Fallund
			Dora da			ATH EXPLOSION	the state of the s		DR TREADE	BE FEILINE
		100.00					HD FAILURE		HE FATLURE	HE FELLINE
			10000			WO TALLING			ON FAILURE	DA FAILURE
		1.00	1 Contra 1			Mary 12 Mary States and States	and a state of the second s	Same and and	(HD TAILUTE	HO FAILUND
		Acres 1	1000		PEDESTON TALL			INC YATLORS		NO PAILORS
		1. Sec. 31.	100.000	P. 605 (107 + 110)				28 FALLERE	and the lot of the lot	Q4 FALLURE
			10 C C C C C	FL000(NG + 1N-)	1	\$18.22910510x	PEDER (AL FALL	THE TALLUAE		NO 743, UME
					San TAILURE	-	THE FAILURE	and the second second second second	and the second second	HO FAILURE
			1251	1		Leg Falssed		DA VELLURE	CARGO AND A COMPANY OF	ON KELLURE
		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Ref. 1	Y C	ROENCAL TALL	and the second second		- SEL FARLORS		HR. FALLURE
			100000	MP4 1 162	1		PERENIAL FALL	M. FAILONE		ge Extines
		1000	1000	product and the first state of the	1.1.1.1.1.1	574 EXPLOSION	NO PATLONE	THE EASLINES		40 FAILURE 40 FAILURE
				6.000	140 FALLURE	NO FAILURE	CON. AAAAPITA			NO FASLORE
			18855. FT			THE R. P. LEWIS CO., LANSING MICH.		PR VALLERE	sector of the sector of the sector of	BA FALLURE
		1		£	PROFILIAL FAIL			(AC LAILTHAN		HO FAILORI
				F1000146			PEGERTAL FALL	DR FEILURE		40 PAILON
					MR. FAILURE	174 21410210H	BR CASSING	Call of the Call State of the	and the second se	NO FAR UT
		Sector State		1 - C	Villar al de la deserve	IND FRILING				NR FALLORE
				1.0	MOLSTAL FAIL			58 F311 1988		RU FALLING
								DR CALLARE	and the state of the same state of the same	QA TALLUAS
				IOSY NATED	-	.165	PROKOTAL CALL	- WE FALLORE	an and the subject of a first state	40 Fall 641
					140. 12 11. WEL		WELLAND WAY			NU TRILLING
						1912	and the state of the second state	DA FATLURE		DA FAILORE
	NO 82 PHA			TLD + 184	PESESTAL PALL				De FAILURE	De Fallurs
								MI_111.081	SO FAILURE	NO FAILURE
								TAILER.		Da LETER
		1.		10.423	PEDERTAL CALL			TAILURE	NE FAILURE	NO. FALLUNE
				10.000				DR PASSARE	CHL. LALANCE	On selling
				APY Y LAL	1010 Jah		PERSIAL FALL	- SELECCERE	ON FAILSAN	OR FALLURS
		Sec. 12.			1.124	ATH EXPLOS		Maria Markey	MO PAILORE	NO FAILURE
		1.1		1000	ND FAILURE		HD FATLDME		NO FAILURE	04 /11168
		3439E.71	1455L 11	-	Station of the Station of the second s				ON KAILLAN	da falluna
		States and				INC. CATLINES				WE FALLURS
	1			a non test	PROPERTON FAIL			PA FAILURE	DA FAILURA	DR. FARLORE
		and the second second		N/800146	and the state of the second			-180_FR1LS#8	NO FAILURE	HE FALLER
		1.000		1.5.5				DE FAILURE	And the second second second second second	DR FAILURE
				1270.24	PROTEIRL PALL			NO. YALLUME	DA PAILURE	BR FALLOFF
				1.				SA PALLURE	(NC) (FA1) (INF	98.7874095
				RIPH HATEN	and the second		PERENTAL PARL		DM FRILURE	28 1.11/184
		1.1.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2			1.000			40 743, DRE	UNS TAILUTE	TALLEY
					Sec. Sec.		NO PAILURE		DR CALLINE	ON FALLING
	1.1.1	19 10 S. V.S.			Lee Fally Mi				ON FAILURE	ON FAILURE
	1					HO FAILORE				NO FAILURE
	1.1							DA TATIGAT		RA PAILURE
				fup + 184	PEDERTAL FAIL			HO FELLUAR		NO FAILURE
					UND FAILURE			DR 7411-004		DH FAILURE
	1.24	123.3		the second second	PERSONAL PARS.			THE FAILURE		40 5414081
				R#v + 18-1			the local second second second			RO FEELINE
	1.1.1.1.1.1	SHALL PT	THU IF		PESENTAL FAIL			DR. PAILORS		RO FAILURE
				#1,2007H4				(40 (A))/001		KO FAILORE
					IND MAILURE		Contraction of the Party of the	De FALLURE		CH FAILUME
	1-1-1-1-1-1-1									
				874 45128	PERESTAL FAIL			WO TELEORE		40 FAILUAE

T T / NUCLEAR POWER PLANT UNIT 1

INDIVIDUAL PLANT EXAMINATION FIGURE 4 5 2 2 4-1

DRYNELL FAILURE AT/NEAR RPV FAILURE DET REVISION O





4


ñ


REVISION D


Y












ø





5.1 IPE ORGANIZATION

The organizational structure for the IPE is shown in Figure 5.1-1. The team was put together to optimize the CEI resources while meeting the requirements of Generic Letter 88-20. A consultant was retained to provide probabilistic risk assessment technical management and technology transfer, in order to produce the results within the three year time frame. Up to five engineers from the Perry staff were assigned to be team members, three of whom were dedicated full time to the project. However, the consultant, Halliburton NUS Corporation, retained overall responsibilities for the technical aspects of the work. This approach helped to optimize the IPE process by ensuring that personnel with in depth plant knowledge performed the detailed analysis under the guidance of personnel with wide experience of PRA performance and application.

A breakdown of the tasks and the participation of the CEI and Halliburton NUS personnel is shown in Figure 5.1-2. It can be seen from the table that CEI personnel participated in all tasks enabling significant technology transfer in all areas.

5.2 INDEPENDENT REVIEW

As shown in Figure 5.1-1 the independent review and peer review was performed by station and corporate personnel and consultants. The consultants were retained for two reasons. First, among the CEI staff at Perry there was little prior experience with either core damage or accident progression analysis, therefore it was necessary to find experienced personnel outside CEI. Second, in the case of the Level 1 review station engineering and operations staff were able to provide good insights into the details of system modeling and personnel response, but again had little experience in PRA and modeling techniques. The personnel who performed the independent review of the Level 1 (RAPA) and Level 2 (ERIN contracted and EPRI peer review) are listed in Figure 5.1-2.

The review by the corporate staff involved a detailed review of the system models by design engineers and a detailed review of the accident sequence models by operators. Each of the system notebooks were reviewed by responsible design engineers. Before the review effort, design engineers were given training in probabilistic risk assessment methodology. The reviews took place as the system notebooks were completed between July 1990 and January 1991. Comments were documented and addressed.

The initial operations review took place in August 1990. Two licensed operators were assigned full time to the IPE project for a two week period to review the accident sequence models. As the operators worked directly with the IPE staff any comments were immediately addressed and incorporated into the models. Following quantification, the dominant sequences were reviewed by the licensed operators responsible for the Plant Emergency Instructions (PEIs) taken from the Emergency Plant Guidelines (EPGs). The coordinator of this effort was a Shift Supervisor.



The primary reviewer from RAPA has 11 years experience in performing and reviewing probabilistic risk assessments. Two independent reviews by RAPA have taken place at appropriate intervals during the IPE effort. Phase 1 covered initiating events, accident sequence analysis, and system modeling and was completed in March 1991. Phase 2 covered common cause and dependency analysis, data base, human interactions, internal flooding, and sequence quantification and was completed in April 1992.

The Level 2 Independent review by ERIN was directed by the General Manager of BVR Technology, Dr. Edward Burns, who has over 18 years of experience in the field of probabilistic risk assessment, severe accident analysis, and emergency procedure examination. The Level 2 independent review commenced with a onsite meeting in June 1991 to review the initial work completed on the plant model development with the MAAP parameter file and on the containment capacity analysis. A second meeting in March of 1992 reviewed the Level 2 analysis scope from the plant damage state grouping to the development of the Accident Progression Event Tree and on to the source term category release model. During this March meeting, Dr. Edward Fuller, the EPRI Modular Accident Analysis Program (MAAP) Program Director, graciously participated as an peer reviewer. The final ERIN review scope included the MAAP accident progression analysis and the Level 2 IFE submittal. The Level 2 Independent Review was completed in July 1992.

5.3 AREAS OF REVIEW AND MAJOR COMMENTS

5.3.1 Level 1 Review

The general areas of review for each of the reviewing organizations is listed above. Each review was performed on the analysis files available at the time the review took place. The majority of the comments by the design engineers resulted in changes to the descriptions of system design and operation in the system notebooks. Only a few minor modeling changes resulted from this review. Changes to the sequence models from the operations review were discussed and made at the time the review was being performed.

RAPA provided a report for each of the review phases. In addition to individual comments summary comments were provided. Summary comments from Phase 1 are listed below:

- The assumption not to model electric power into the support systems must be adequately defended. The logical means of doing this is through the use of dependency matrices.
- More than one special initiator. Loss of Control Complex Chilled Water, will have to be modeled as initiators. Some of the cooling water systems and the air systems should also be modeled as initiators.
- 3) The level of detail and the breadth of the station blackout event trees is impressive. These are some of the best representations of this complicated event for a BWR that have been seen.

The summary comments from the second phase of the review are listed

belov.

In general, no major deficiencies were identified in the process used in the Perry PRA. Some of the comments question specific values used in the quantification process. However, it is not felt that any of the comments call into question the overall process or results of the PRA to date. The most significant issues that were identified in the Phase 2 review are:

- The conclusion that no coupled human errors survived truncation is somewhat surprising. Although the use of BWR EPG based procedures does justify the decoupling of many actions, some coupling would still be expected to occur just because of time coincidence of actions.
- Some of the specific data values, such as those for RCIC and the diesel generators, are different than those generally quoted in the literature.
- 3) The overall importance of plant specific maintenance unavailability on core damage frequency was startling. This was particularly true of events where an entire division of ECCS was taken out for maintenance at one time. This may in fact identify a plant specific vulnerability.

The remainder of the comments are minor and when resolved, will provide a good basis for documenting the development process of the PRA. Many of the comments may be resolved by the addition of documentation. Therefore, resolution of the comments will provide documentation of the quantification and assembly process.

5.3.2 Level 2 Review

ERIN provided a report for each of the review phases after the initial site visit which are summarized below. Also included is the EPRI MAAP Program Director's peer review participation in the March 1992 meeting.

ERIN IPE Senior Review - March 1992 Meeting

The following aspects of the PNPP IPE process were effectively presented at the review meeting:

- 1) A summary presentation
- 2) Responses to questions
- 3) A discussion of applications

Based on the lucid presentation, an appreciation of the breadth and depth of the Perry IPE was obtained. The major written report section included in the review was the containment structural analysis. The review of this report, draft sections 4.3 and 4.7 of the back-end analysis report and the presentation by the Perry Level 2 analyst resulted in the following conclusions.

()

- It was clear from the review that PNPP has accomplished the objectives of the NRC Severe Accident Policy Statement Generic Letter 88-20 and the IPE Guidance Document NUREG-1335.
- o The basic assumptions and methods are state-of-the-technology.
- o The IPE is very useful and it is expected that the report will reflect the thoroughness and rigor of the analysis upon which it is based.

A list of summary comments was provided which was judged to be minor by the reviewers with respect to the goals of the IPE, but may be useful in finalizing the current version of the IPE and updating the IPE in the future.

It was observed that the MAAP analysis is among the most comprehensive and complete evaluations performed by any BWR utility, and the insights gained from these analyses will be valuable in establishing the accident management actions appropriate for Perry.

EPRI IPE Senior Review - March 1992 Meeting

Dr. Edward Fuller, the EPRI Modular Accident Analysis Program (MAAP) Program Director and Manager of Nuclear Reactor Safety, also attended the March 1992 meeting with ERIN. In addition, five station blackout MAAP runs were reviewed offsite to investigate the effects of hydrogen combustion that may cause containment failure early. Dr. Fuller's meeting report noted the thoroughness of the back-end analysis and the insights identified.

ERIN Review of MAAP Analysis To Support The Perry IPE - May 1992

The independent review of the Perty IPE MAAP analysis was performed by Jeff Gabor of Gabor, Kenton and Associates. The review included the following items.

- 1. Validation of MAAP 3.0B Revision 7.02
- 2. Perry Parameter File and other related I/O files
- 3. Results of sequences without the hydrogen ignition system
- 4. MAAP prediction for peak pedestal pressure
- 5. Sample MAAP output
- 6. MAAP sensitivity analysis scope

The comments from this MAAP review identified opportunities for additional accident progression analysis, but were judged not to materially affect the basis conclusions of the analysis.

ERIN Review of the Perry Level 2 IPE Submittal - June & July 1992

The Perry IPE submittal is a thorough and technically sound analysis. The IPE framework will be very useful to Cleveland Electric in the future as the basis for the "living" PRA. Because the Perry IPE is a living PRA, it is judged appropriate to submit the results when CEI is ready to support the IPE commitments. The comments provided previously and enclosed can be resolved in the future, and are judged not to materially affect the basic conclusions of the analysis. Several suggestions and comments are included to enhance the presentation to the NRC.

5.4 RESOLUTION OF COMMENTS

The comments discussed above have been resolved. The process of resolving the comments consisted of evaluation by the IPE team, communication with the reviewing organization to clarify any issues and subsequent decision by the IPE team on comment resolution. The resolution was documented on the comment forms.

5.4.1 Resolution of Comments on Level 1

For the summary comments noted above the resolutions are noted below:

Phase 1

- Electric power to each of the components modeled in the support systems was traced back through the 120 V and 480 V circuits to the 4,160 V buses. Dependency matrices were developed as the tracing was performed. The switchgear and MCCs for these are not crossied but divisionally separated. They are also housed in the same room by division. Therefore, any common event affecting one bus would affect them all.
- Special initiators were also developed for the Loss of Instrument Air and Loss of Service Water events. The loss of other cooling water systems are bounded by these initiators or by the other initiating events such as loss of feedwater.
- 3) No response necessary.

Phase 2


- At the time of the review the human reliability analysis was undergoing internal review. This resulted in the identification of major coupling of HIs in some of the ATWS sequences and in the initiation of some systems. This has resulted in modification to the human reliability modeling and quantification.
- 2. The values used for the failure to start and run for RCIC and HPCS are those used in the Grand Gulf study done on behalf of the NRC. Plant specific data for these failure modes was not available at the time the IPE started due to insufficient operating history. This is in line with the declared intention in the IPE of using data from the

Grand Gulf study.

3. Due to the importance of this contributor, plant-specific data for the most recent operating cycle has been used for the HPCS and RCIC systems in the final quantification of the core damage frequency. Now that Perry has achieved sufficient operating experience it is expected that more plant-specific data will be used in future modifications to the plant model. Note that maintenance did not appear as a vulnerability although it is important.

5.4.2 Resolution of Comments on Level 2

Since the Level 2 comments did not materially affect the basic conclusions of the back-end analysis, no resolution response was required.








Figure 5,1-2 Project Organization

6.0 POTENTIAL FLANT IMPROVEMENTS AND UNIQUE SAFETY FEATURES

The analysis of the Perry plant is the fourth Probabilistic Risk Assessment of a BWR6 and therefore it is possible to compare features of the various designs and the way in which such features either enhance the safety of the plant or represent a vulnerability in terms of other core damage or fission product release. The presentation of the results in section 3.4 identifies the 'ndividual contributions to core damage, and in section 4.5.3 identifies the contributions to cortainment failure.

6.1 UNIQUE SAFETY FEATURES

The safety features associated with the current design and operation of Perry which contribute to the base case core damage frequency or prevention of containment failure or bypass are discussed in this section.

6.1.1 Core Damage Safety Features

There are a number of unique features at Perry which help to minimize the frequency of hore damage from certain initiating events.

There is a motor driven feed pump which is normally in standby and will start on receipt of an automatic signal at level 2, following failure of the turbine driven pumps. Thus there are effectively three high pressure injection systems available to respond to loss of power conversion system or main steam isolation events. This has the effect of reducing the core damage frequency from such events.

The original design for the Perry site was for two units. Although only one unit has been completed, many of the support systems for the second unit were completed. For example, there are two sets of batteries for the safety-related DC buses. In the event of a loss of offsite power or station blackout the operators are instructed, by procedures, to use both sets of batteries to support Unit 1 operation thus considerably extending the availability of dc in this situation. The impact of this is to reduce the contribution from station blackout in relation to loss of offsite power. If it was not possible to use the second battery, the core damage from station blackout would be dependent on earlier recovery of offsite power which would raise the core damage frequency.

The diesel generator which supplies the HPCS system is not the same size or design as the two diesels supplying the emergency bus bars so common cause failure of all three diesel generators is less likely to occur. Similarly the differences in design between the emergency service water train for HPCS and the other emergency service water trains will lessen the probability of common cause failure of all three trains.

The facility exists to cross connect the supply from the HPCS diesel generator to the Division 2 emergency bus, which enables the containment vent valves (and potentially hydrogen ignitors) to be powered in the event of loss of offsite power and failure of both Division 1 and 2 emergency diesel generators. This reduces the frequency of core damage sequences as the result of station blackout.

6.1.2 U ique and/or Important Containment Features

The most significant feature in the design of the containment are the expected failure modes following a slow overpressurization following loss of containment heat removal (where RHR suppression pool cooling or containment spray, and containment venting have failed). The evaluation of containment overpressure in section 4.4.3 determined the gradual overpressure conditional probability of anchorage failure given containment failure is 0.15. Anchorage failure will result in loss of the suppression pool and most likely will fail all other injection sources. Thus anchorage containment failure has the effect of resulting in core damage as well as suppression pool bypass. Additionally, any failure of the containment is likely to pressurize the silicone foam seal on the adjacent auxiliary building and cause failure of the ECCS pumps.

6.2 PLANT DESIGN CONSIDERATIONS

The sensitivities and vulnerabilities analysis discussed in section 3.4.2 showed that according to the definition in the NUMARC document there are no vulnerabilities associated with core damage. However a number of items were identified which would lead to a reduction in the core damage frequency.

Similarly the containment analysis discussed in section 4.5.3 identified the dominant contributors to containment failure. Some potential design considerations which would reduce the core damage frequency and containment failure frequency are discussed in the following sections. It must be stressed that the potential design considerations are strictly conceptual. The feasibility of implementation (e.g., code compliance, materials availability, regulatory acceptance, cost justification, etc.) has not been evaluated.

6.2.1 Plant Improvements Made Due to IPE Insights

During the course of the IPE a number of areas were identified where changes to procedures or plant design would result in a reduction in core damage frequency. The following changes were implemented:

Loss of Offsite Power Instruction

- Retention of RCIC isolation bypass for high steam tunnel temperature
- Enhanced process for crosstieing Unit 1 and Unit 2 batteries
- Enhanced process for offsite power recovery to HPCS and alternate injection system buses

Flooding Instruction

- Enhanced response instructions for flooding scenarios

System Modifications

ADS automatic initiation

"Fast Firevater" tie between Fire Protection and HPCS

Permanent Division 3 to Division 2 "quick" connect

Reduction of Out-of-Service Time for certain critical components

6.2.2 Design Considerations for Reduction in Core Damage Frequency

Section 3.4 provided a discussion of the sensitivity analysis performed for the Perry IPE. In addition to the safety features discussed above, an analysis of several other potential design considerations were provided. These changes to the plant are described below. The impact of making each of the changes is summarized in Table 6-1.

Passive Containment Vent Path

One of the sensitivity analyses performed was to assess the impact of containment failure on loss of RPV injection and subsequent core damage. The addition of a passive containment vent path that does not depend on AC power would reduce the core damage frequency from internal and flooding events by 18 percent or from 1.3 X 10^{-5} to 1.1×10^{-5} .

Automatic ADS Inhibit for ATWS

One of the contributors to core damage frequency for ATWS is manually inhibiting ADS. By installing an automatic inhibit of ADS, those ATWS sequences in which manual inhibit fails would drop out. The overall core damage frequency is reduced by 19 percent from 1.3 X 10⁻⁵ to 1.0 X 10⁻⁵. The sequences resulting from this failure result in an uncontrolled flow to the RFV from the low pressure injection systems with subsequent core damage and containment failure. The addition of the auto inhibit would reduce the frequency of this set of sequences.

6.2.3 Design Considerations for Reduction in Containment Failure

The sensitivity of the frequency of containment failure to various assumptions and potential design considerations is discussed in section 4.6.3. The design considerations are discussed below and the impact of performing them is summarized in Table 6-2 and shown in pie charts in Figures 6.2.2-1 through 6.2.2-6.

Passive Containment Vent

This consideration is described in section 6.2.2. As well as reducing the frequencies of containment failure before core damage sequences from 2.9 x 10^{-6} to 5.7 X 10^{-7} it will impact the fission product release with pool bypass. The overall impact is to reduce: the RFV failure and early containment failure with pool bypass frequency from 2.0 x 10^{-6} to 4.5 x 10^{-7} (-78% change), and the containment structural failure frequency from 4.0 x 10^{-6} to 9.9 x 10^{-7} (-75% change).

ATWS Automatic ADS Inhibit & Alternate Shutdown

Automatic ADS Inhibit for ATWS is described in section 6.2.2. The automatic

ADS inhibit feature would directly reduce the core damage frequency. Additionally, providing an enhanced instruction to control RPV Power/Level as a function of containment pressure with a RPV water level control band just above the Minimum Steam Cooling Water Level would reduce reactor power within the venting heat removal capability. This quesi steady-state RPV Power/Level control would provide a reasonable time for reactor shutdown recovery using an alternate boron injection system. This potential change is conservatively assumed to reduce the containment failure frequency from 5.6 x 10⁻⁷ to 4.3 x 10⁻⁶. This impacts the potential for containment failure and fission product release with pool bypass. The overall impact is to reduce: the RPV failure and early containment failure with pool bypass frequency from 2.0 x 10⁻⁶ to 1.8 x 10⁻⁶ (-14% change), and the containment structural failure frequency from 4.0 x 10⁻⁶ to 3.5 x 10⁻⁶ (-13% change).

Secure Electrical Supply to Hydrogen Ignitors

Supplement No. 3 of Generic Letter 88-20 identified that Mark III containments are expected to evaluate the vulnerability to interruption of power to the hydrogen ignitors. The modification of the electrical supply to the hydrogen ignitors to ensure availability during station blackout would remove the possibility of high containment loads from hydrogen deflagrations and detonations. The overall impact is to slightly reduce: the RPV failure and early containment failure with pool bypass frequency from 2.0 x 10-6 to 2.0 x 10-6 (-2% change), and the containment structural failure frequency from 4.0 x 10⁻⁶ to 3.8 x 10⁻⁶ (-6.7% change).

Combined Passive Vent & ATWS Automatic ADS Inhibit & Alternate Shutdown

The combination of the two considerations discussed above would reduce significant contributors to core damage as well as containment failure. The overall impact is to reduce: the core damage frequency from 1.3 $\times 10^{-5}$ to 7.7 $\times 10^{-6}$ (-41% change), the RPV failure and early containment failure with pool bypass frequency from 2.0 $\times 10^{-5}$ to 1.6 $\times 10^{-7}$ (-92% change), and the containment structural failure frequency from 4.0 $\times 10^{-6}$ to 4.6 $\times 10^{-7}$ (-89% change).

Combined Passive Vent, ATWS Modifications and Hydrogen Ignition Power

The combination of these three changes together, further examines the impact of backup power to the hydrogen ignitors in with the passive vent and the ATWS modifications discussed above. The overall impact when compared to the base case is to reduce: the RPV failure and early containment failure with pool bypass frequency from 2.0 X 10^{-6} to 1.1×10^{-7} (-94% change), and the containment structural failure frequency from 4.0 x 10^{-6} to 1.8×10^{-7} (-62% change).

6.3 PROGRAM FOR INCLUSION OF PLANT DESIGN CHANGES

As stated earlier the core damage frequency from all initiators is 1.3×10^{-5} and there is no class of sequences contributing above 1.0×10^{-5} which indicates there are no vulnerabilities at the Perry Nuclear Power Plant. The study has been performed using industry generic data for the majority of data (the major exceptions being the maintenance unavailabilities and a detailed



analysis of the human interaction). The indication from the last two operating cycles is that the plant-specific initiating event frequencies are lower than those used in the study. As it is the intention to use the results of this study as a living PRA it is expected the study will be updated using plant-specific data, when available, starting in 1994, after development of the procedures for collection of data and the management of the living PRA have been developed. The use of the plant-specific data will enable a reassessment to be made of the design changes identified in the current base case study.

184	- 1	61	Sec.		÷6
T.	21	D I.	£3.	B	а.
*	829.3			20	18.

Impact of Design Change Considerations on Total Core Damage Frequency


Modification	Approx CDF After	Percent Change
Passive Vent Path	1.1E-5	-20
Automatic ADS Inhibit for ATWS	1.0E-5	-22
Combined	7.7E-6	-41

Note: The impact of the passive vent path will have an equivalent effect in reducing the core damage frequency due to flooding.



TABLE 6-2 IMPACT OF DESIGN CHANGE CONSIDERATIONS ON CONTAINMENT FAILURE FREQUENCY

		BASE CASE	(1) PASSIVE VENT	(2) ATMS ALTRNATE SHUTDOWN & ADS INHIDIT	(3) HIS BACKUP FCMER SUFFLY	(6) FASSIVE VENT, ALT 8/D & ADS INNIBIT	(5) PASSIVE VENT, ATWS ALT S/D & ADS INHIBIT 215 BACEUP POWER SUPPY
No RPV Failure:	No Containment Pailure	3.39E+6 (26.7%)	3.39E-6 (32.6%)	1.82E-6 (17.6%)	3.42E-6 (26.9%)	1.828-6 (22.7%)	1.858-6 (23.1%)
	Vent	2.45±-6 (19.3%)	2.92E~6 (28.1%)	2.81E-6 (27.2%)	2.45£~6 (19.3%)	3.288-6 (41.0%)	3.28E-6 (41.0%)
	Containment F.	6.18E-7 (4.9%)	2.87E-8 (0.3%)	6.188-7 (6.0%)	5.93E-7 (4.7%)	2.88E-8 (.4%)	3.58E-9 (.04%)
Subtotal No RPV	Pailure Core Denage Freq:	6.46E-6 (50.8%)	6.34E-6 (61.0%)	5,258-6 (50,9%)	6.46E-6 (50.8%)	5.13E-6 (64.1%)	5.13E~6 (66.1%)
RPV Failure:	No Containment Failure	1.58E-6 (12.6%)	1.58E-6 (15.2%)	9.06E-7 (8.8%)	1.79E-6 (14.1%)	9.06E-7 (11.3%)	1.12E-6 (14.0%)
	Vent	1.27E-6 (10.0%)	1.525-6 (14.6%)	1.308-6 (12.5%)	1.31E+6 (10.3%)	1.f4E-6 (19.3%)	1.598-6 (19.8%)
	Lete Containment Pailure	9.38E-7 (7.4%)	2.46E-7 (2.4%)	9.39E-7 (9.1%)	7.31E-7 (5.7%)	2.46E-7 (3.1%)	3.25E-8 (0.4%)
	Early CF: No Pool Bypass	4.30E-7 (3.4%)	2.678-7	1.858-7	4.30E-7 (3.4%)	2,538-8	2.50E-8 (0.3%)
	Late Pool Bypass	1.54E-6 (12.1%)	2.26E-7 (2.2%)	1.348-6 (13.0%)	1.538-6 (12.0%)	3,588~5 (0,4%)	2.588-8 (0.3%)
	Early PB, Spray	6,12E-8 (0,5%)	6.12E-8 (0.6%)	3,74E-8 (0.4%)	5.12E-8 (0.4%)	3.748-8 (0.5%)	2.748-8 (6.3%)
	Early PB. No Spray	4.45E-7 (3.5%)	1.61E-7 (1.5%)	3.67E-7 (3.6%)	4.228-7 (3.3%)	8.36E-8 (1.0%)	6.05E-8 (0.8%)
Subtotal RP	V Failure Core Damage Freq:	6.27E-6 (49.2%)	4.06E-6 (39.0%)	5.08E-6 (49.1%)	6.27E-6 (49.2%)	2.87E-6 (35.9%)	2.88E-6 (35.9%)
T	OTAL CORE DAMAGE PREQUENCY:	1,278-5 (100%)	1.04E-5 (100%)	1.03E-5 (100%)	1.27E-5 (100%)	8.01E-6 (100%)	8.01E-6 (100%)
Subtotal Con	tainment Venting Frequency:	3.72E-6 (29.2%)	4,43£-6 (42,6%)	4.11E-6 (39.8%)	3.76E-6 (29.5%)	4,828-6 (60,2%)	4.878~6 (60.8%)
Subtotal Ont	mt Structural Failure Freq:	4.03E-6 (31.7%)	9.92E-7 (9.5%)	3,49E-6 (33,85)	3.76E-6 (29.5%)	4.60E-7 (5.7%)	1.758-7 (2.2%)
TOTAL CONTAINS	MENT FAILURE & VENTING FREQ:	7.76E-6 (60.9%)	5.438-6 (52.2%)	7.60E+6 (73.6%)	7.52E-6 (59.1%)		5.04E-6 (63.0%)
RPV FAILARE &	EARLY CONTAINMENT FAILURE WITH POOL BYPASS FREQUENCY:	2.04E-6 (16.1%)		1.758-6 (16.9%)	2.00E-6 (15.8%)		






000+300 1 -001

No REV F. NO CF No RPV FAIL, VENT No CNTMT FAIL, VENT No CNTMT FAIL VENT ECF. HO POOL BYP LATE CNTMT FAIL ECF. LATE PL BYP NO RPV F, CNTWT F ECF. ERLY PB. SPY ECF. E PB. No SPY 100 in. ŝý

Ņ

2

m.









Figure 6.2.2-5

CNIM PERFORMANCE: PASSIVE VENT & ATMS MODY







7.0 SUMMARY AND CONCLUSION

7.1 CORE DAMAGE FREQUENCY

The point estimate of core damage frequency from internal initiating events is 1.2×10^{-5} per year and from internal flooding 1.5×10^{-6} per year giving an overall core damage frequency of 1.3×10^{-5} per year. Eighty-six percent of the contribution from internal events comes from 21 sequences with a core damage frequency greater than 10^{-7} per year and the contribution to internal flooding comes from seven areas in which floods will result in core damage frequencies greater than 10^{-7} .

The dominant accident inting event type is anticipated transient without scram at 40.7 percent, in blackout contributes 19.3 percent and loss of offsite power contributes 12.4 percent. All other transients contribute 25.0 percent and LOCAs 2.6 percent.

For the internal floods analysis, flooding in Zone 13, cont. ibute 57 percent and in Zone 17 contributes 21 percent.

The breakdown by class of initiator is shown in Figure 7-1, by internal initiator in Figure 7-2, and by flood area in Figure 7-3.

The plant-specific safety feature and design considerations are discussed at length in section 6.0 and will not be repeated in this section. However it is considered appropriate to compare the results of this study with other published studies of BWR/6 plants to identify variations in the results and possible reasons for these differences.

The Grand Gulf plant, a BWR/6 Mark III very similar to the Perry plant, was the subject of a recent analysis reported in NUREG/CR-4550 (Drouin, 1989). The NRC study was performed using similar methodology, that is fault tree linking, so it is possible to compare the results in terms of sequences contributing to core damage. As the Grand Gulf study did not include an internal flooding analysis, only the results from the Perry internal analysis are compared with the Grand Gulf results.

In addition to comparing the results with those of previous studies, the results are also evaluated against the Nuclear Management and Resources Council (NUMARC) severe accident closure guidelines (NUMARC, 1992).

7.1.1 COMPARISON WITH GRAND GULF RESULTS

The major purpose of this study was to ensure that the PRA model was developed and understood by the CEI staff at Perry and represented the as-built as-operated condition at Perry as far as possible. Guidance for performing the IPE indicated that heavy reliance could be placed on the results of previous studies for similar plants (e.g., the Grand Gulf study). However it was decided that if the completed PRA was to be used as a living PRA, the success criteria and plant models would have to be developed for the ns-built condition of the Perry plant and incorporate the latest understanding of the BWR/6 response to ATWS events, and the thermal hydraulic performance of the core when the water level is below the top of the active

level.

In addition a plant-specific human reliability analysis was performed in order to incorporate the impact of the current emergency procedures at Perry into the event and fault trees and to ensure that the dependencies between the various operator actions are correctly modeled.

It can be seen in Table 7-2 that as the result of incorporating the plant specific insights into the models and developing a completely new set of event and fault trees the core damage frequency from internal events at Perry is 1.2×10^{-5} compared with 4.0×10^{-6} in NUREG/CR-4550 for Grand Gulf. The results from the BWR6/s in Taiwan (Kuosheng) and Spain (Cofrentes) are also included in Table 7-2 for comparison purposes. It was not possible to compare the results with the utility developed IPEs for Grand Gulf, Clinton or River Bend as the IPE submissions were not available at the time of production of this report.

The only significant differences between Perry and Grand Gulf are in the results for anticipated transient without scram, transients without the power conversion system available and loss of instrument air. Some of the reasons for these differences are discussed in the following paragraphs.

It can be seen from Table 7-2 that there is a wide variation in the assessment of ATWS events in the four studies, ranging from less than 10" to , a factor of over 250. The specific reasons for the differences 2.6 x 10 between the Grand Gulf core damage frequency and the Perry frequency are the result of different success criteria being used in the two studies. In the Perry study the latest information from the BWR/6 owners group that the High Pressure Core Spray can not be used to maintain vessel level has been factored in. In the Grand Gulf study, it was assumed that if HPCS started successful injection would be achieved. When it is assumed that HPCS can not be used for high pressure injection, the feedwater system becomes important. Runback occurs following ATWS requiring the operators to take control to restore feedwater injection and maintain level. The net effect is to place a dependence on the operator to achieve the required plant status. The quantification of the operator actions based on a detailed evaluation of the PEI resulted in the core damage frequency of 4.74×10^{-6} for ATWS.

The only other two initiators which show a lgnificant difference are the Transient without PCS $(1.7 \times 10^{-6} \text{ at Perry compared with } 1.3 \times 10^{-8} \text{ for Grand Gulf})$ and loss of Instrument Air $(1.0 \times 10^{-6} \text{ compared with less than } 10^{-7})$. In the case of loss of PCS the failure of recovery of PCS at Grand Gulf is two orders of magnitude lower than at Perry. This is not in line with the value generally used in other studies which has been used in the Perry study. Similarly, in the loss of instrument air analysis, it is considered that ron-conservative recovery actions have been used in the Grand Gulf study.

7.1.2 SEVERF ACCIDENT CLOSURE ISSUES

A concise definition of vulnerability is not given in the documentation associated with the performance and reporting of the IPE. In the response to questions in Appendix C to the Submittal Guidance Document (NRC, 1989), mention is made of examining sequences that are above the screening criteria in order to determine if a weakness exists. Thus the word weakness replaces the word vulnerability neither of which is defined in numerical or comparative terms. In another response it is suggested that a vulnerability is an outlier. The NUMARC Severe Accident Issues Closure Guidelines (NUMARC, 1992) proposes a set of guidelines based on a combination of the core damage frequency for a group of sequences and the individual contribution from a sequence group (Table 7-4). If the contribution from a given initiator or system failure is greater than 50 percent of the total core damage frequency it is interpreted as a significant vulnerability, if it contributes 20 to 50% it is interpreted as a potential vulnerability to be investigated. Similarly, contributions from sequence groups between core damage frequencies of 10⁻⁵ and 10⁻⁴ are reviewed to determine if there is an effective plant procedure or hardware change which would reduce the frequency of the sequences.

In this childy Importance and Sensitivity measures have been used to determine the nificant contributions to the core damage frequency, containment system ance, and decay heat removal functions.

1 accident sequence groups and the definition of each group and cf sequences in each group are shown in Table 7-3. It can be table that there are no significant vulnerabilities as defined ous section as all the accident sequence groups have a frequency and no group contributes more than 50% to the overall core damage frequency. However there are two groups of accident sequences that contribute between 20 and 50 percent: Group 4 which is made up of accident sequences involving Anticipated Transient Without Scram and Group 2 which is made up of accident sequences involving loss of containment heat removal leading to containment failure and subsequent failure of coolant inventory make-up.

The contribution to core damage from sequences in group 4 comes primarily from ATWS sequences in which the motor feed pump has failed to inject water and ADS has not been inhibited resulting in rapid depressurization of the RPV and injection of low pressure ECCS. This leads to a series of reactivity oscillations resulting in generation of large quantities of steam and ultimately containment failure and core damage. However, it should be noted from the sensitivity analysis that the use of the plant operating data for cycles 2 and 3 will reduce the frequency of the initiators which contribute to this group and thus the contribution to core damage frequency of these sequences from 34% to approximately 15% which is no longer a potential vulnerability in terms of the NUMARC criteria.

The contribution to core damage from sequences in Group 2 arises from the failure of containment heat removal leading to containment failure and subsequent loss of injection. One of the reasons that this is a significant contributor is that the containment design is such that in approximately 15% of cases containment failure leads to injection failure. Thus if a passive vent was fitted, the core damage frequency of these sequences would be reduced. This also has an impact on source term magnitude and is further discussed in section 3.4.2.3 under containment vulnerabilities.

7.1.2.1 Closure Issue Sensitivity Analysis

A review of the plant operations during the past two operating cycles has shown that the frequency of scrams is much lower than the generic frequency used for the Grand Gulf study and this study. The results of using a revised set of initiating event frequencies based on the past two cycles results in a core damage frequency reduction from 1.2×10^{-5} to 7.0×10^{-5} . The contribution from the various initiators thus becomes 30% from station blackout, 23% from transients, 20% from loss of offsite power and 17% from ATWS (see Table 3.4.1-16). More significantly, the accident sequence groups which are now between 20 and 50 percent are Groups 1C and Group 2. Group 4 is no longer important. The contribution, in frequency terms of any group is now barely above 2.0 x 10^{-5} .

If this operational trend continues and the importance of the various accident sequences in Group 4 remains low, it is clear that the updating of the PRA using plant-specific data should be done before deciding on the necessity of performing any design changes.

7.2 CONTAINMENT ANALYSIS

7.2.1 SEVERE ACCIDENT CLOSURE ISSUES (NUMARC 91-04)

The Level 2 containment analysis assessed the performance of the Perry Mark III containment in mitigating severe accidents by defining the accident progression in containment, estimating the timing and mode of containment failure and estimating the source terms for the spectrum of accident sequences. The low values for the plant damage state frequency can be attributed to good plant emergency instructions and to prioritized alignment of alternate injection systems to recover a damaged core in-vessel.

The Modular Accident Analysis Program (MAAP) was used to analyze the dominant accident sequences. The ATWS and Station Blackout sequences were closely examined to determine key figures of merit (e.g., RPV core uncovery, RPV failure time and containment failure time). MAAP source term analyses were used to evaluate the fission product transport for the dominant source term categories from the reactor core to the drywell, through the suppression pool to the containment, and to the environment in accordance with the modes of containment failure.

The Perry Mark III steel containment was analyzed by the Perry plant architect to identify the potential failure modes under severe accident loading conditions. The analysis determined the expected failures from containment penetrations and other containment structural components as well as the less likely failure of the containment anchorage. Penetration failures would commence with a small leakage area and increase with containment pressure. Concrete and steel anchorage failure would result in gross failure of the containment vessel from the mat foundation. The IPE found that the drywell head is susceptible to external overpressure failure if a hydrogen burn should occur in containment. The containment capacity analysis characterized the expected type of failure for each failure mode into three classes (leakage, rupture or gross rupture) which is modeled in source term analyses. The Perry IPE level 2 containment analysis used the Event Progression Analysis (EVNTRE) code which was utilized in the Grand Gulf NUREG/CR-4551 study (Brown, 1990). The Accident Progression Event Tree analyzed the progression of the accident from the onset of core damage through ex-vessel core-concrete interaction to containment failure and fission product release. To enable the complex structure of the Accident Progression Event Tree to be more clearly understood by the plant staff, the Perry APET is graphically described by a "Summary" Containment Event Tree. The Perry Accident Progression Event Tree generally references the Grand Gulf template study event data. However, the primary reference to modeling phenomenological parameters is with the MAAP 3.0B code.

The MAAP code was applied to determine values for key parameters in the Perry Accident Progression Event Tree; e.g., best-estimate hydrogen generation, pedestal overpressurization, and pedestal core-concrete interaction. All the sensitivity analyses recommended by the EPRI report "Recommended Sensitivity Analyses For An Individual Plant Examination Using MAAP 3.0B" were performed.

The plant damage state profile from the level 1/2 interface is: 0% containment bypass; 77% containment intact at core damage (9% - Station Blackout, and 68% - transients and other event types with AC power available), 23% - containment failed at core damage (4.4% - critical (not shutdown) ATWS sequences, 4.3% - Loss Of Offsite Power and Station Blackout, and 14% - other events).

Accident Progression Event Tree summary results for containment The performance are: no containment failure - represents a 39% conditional probability given core damage and a frequency of 5.0 x 10⁻⁶, containment venting - represents a 29% conditional probability and a frequency of 3.7 x 10^{-6} , and containment structural failure - represents a 32% conditional probability and a frequency of 4.0 x 10^{-6} . The conditional probability estimates of the detailed containment failure modes evaluation are: 50.8% in-vessel cooling and no RPV failure; and the balance of the sequences with RPV failure (49.2%) is composed of: 12.4% - no containment failure, 10% venting with a damaged core, 7.4% - late containment failure, 3.4% - early containment failure with no pool bypass, and 16.1% containment failure with pool bypass.

7.2.2 COMPARISON WITH GRAND GULF RESULTS

The Perry IPE level 2 containment analysis used the same Event Progression Analysis (EVNTRE) code applied in the Grand Gulf NUREG/CR-4551 study (Brown, 1990) to transpose the severe accident analysis phenomenological framework of the template study and to model the many dependencies associated with containment loading mechanisms such as steam generation, hydrogen generation and combustion, and the resultant changes in containment pressure and temperature. The Perry IPE Accident Progression Event Tree consists of 68 questions which addresses the four general time frames of accident progression: initial, early, intermediate and late. The more extensive NUREG/CR-4551 Grand Gulf evaluation consists of 125 questions.

To evaluate the vulnerability to interruption of power to the hydrogen ignitors, the Perry APET addressed hydrogen combustion phenomena in a manner similar to the NUREG/CR-4551 Grand Gulf APET. The Perry APET models the

recovery of offsite power both before RPV failure as well as after RPV failure, and possible variations in hydrogen concentration at the time of power restoration were evaluated including the possibility of detonable concentrations.

The Perry IPE use of the same event progression analysis code as the Grand Gulf template study enabled a good transfer of phenomenological modeling as well as of the quantification bases. The Perry APET routinely referenced the Grand Gulf template study and transferred only of the event models, such as the bounding model of alpha steam explosions. However, the primary reference to modeling phenomenological parameters was the EPRI maintained MAAP 3.0B code.

The IPE sensitivity analysis of parametric values used to quantify the Accident Progression Event Tree found one parameter important to containment performance: large in-vessel steam explosion bottom head failure. Bottom head steam explosion phenomena is not modeled in the MAAP code nor addressed in the EPRI Recommended Sensitivity Analyses discussed above in section 7.2. The probabilities applied in the Grand Gulf template plant study appeared to be overly conservative and were reduced by a factor of 10 for the Perry APET. The sensitivity of inputting the Grand Gulf NUREG/CR-4551 values for large in-vessel steam explosion failure resulted in a 58% decrease for successful in-vessel cooling and No RPV Failure (from the base case estimate of 51% to the sensitivity estimate of 21%).

The results of the Percy IPE containment performance differ from those in the NUREG/CR-4551 Grand Gulf Study, due to differences in containment failure modes, phenomenological assumptions, and plant damage state group frequencies. The Grand Gulf study was dominated by Station Blackout (97% plant damage state frequency) and determined that hydrogen combustion was the dominant cause if containment failure. The Perry IPE was dominated by shutdown ATWS (______uences (ATWS with successful SLC) and other transients with Station Blackout only accounting for 9%. The modeling for debris cooled in-vessel is similar with the one variance noted above regarding the estimated value for large in-vessel steam explosions. When the Perry APET event for large in-vessel steam explosion was set to the Grand Gulf value the estimated results for No RPV Failure compare closely with 21% for the Perry APET and 18% for the Grand Gulf APET. The Perry APET estimates for the conditional probability of Containment Ferformance are shown below with the 4551 Grand Gulf APET estimates:

	Perry	NUREG/CR-4551 Grand Gulf
No RPV Failure	51%	18%
RPV Failure and No Containment Failure	12%	5%
RPV Failure and Venting	10%	4%
RPV Failure and Late Containment Failure	78	28%
RPV Failure and Early Containment Failure With No Pool Bypass	3%	22%

RPV Failure and Early Containment Failure 16% With Pool Bypass

7.2.3 SEVERE ACCIDENT CLOSURE ISSUES

The containment bypass (unisolated breach of the primary containment outside the containment) frequency is determined to be less than ¹ : 10⁻⁸ and therefore does not require any action at Perry.

Supplement No. 3 of Generic Letter 88-20 identified that Mark III containments are expected to evaluate the vulnerability to interruption of power to the hydrogen ignitors. The modification of the electrical supply to the hydrogen ignitors to ensure availability during SBO would remove the possibility of high containment loads from hydrogen deflagrations and detonations. The overall reduction of this change on the base case assessment is very minor: 1) the RPV failure and early containment failure with pool bypass frequency changes from 2.04 \times 10⁻⁶ to 2.00 \times 10⁻⁶ (-2% change), 2) the containment structural failure frequency changes from 4.03 \times 10⁻⁶ to 3.76 \times 10⁻⁶ (-6.7% change). Thus, a hardware upgrade to provide uninterrupted electrical supply to the hydrogen ignitors is not warranted by this improvement.

Containment Performance base case results with the generic initiating event frequency (provided in Table 6-2) showed that the frequency of RPV failure and early containment failure with pool bypass was 2.0 $\times 10^{-6}$ or 15% of the core damage frequency. IPE Level 2 engineering insights suggest the greatest opportunity for containment performance improvement is with the following two design considerations: 1) passive vent, and 2) ATWS modifications (ADS Inhibit and Alternate Shutdown). The passive vent impact is to reduce the core damage from 1.3 $\times 10^{-5}$ to 1.0 $\times 10^{-5}$ (-18% change), and to reduce the RPV failure and early containment failure with pool bypass from 2.0 $\times 10^{-6}$ to 4.5 $\times 10^{-7}$ (-78% change). The ATWS modifications impact is to reduce the core damage frequency from 1.3 $\times 10^{-5}$ to 1.0 $\times 10^{-5}$ (-19% change), and to reduce the core damage frequency from 1.3 $\times 10^{-5}$ to 1.0 $\times 10^{-5}$ (-19% change), and to reduce the core damage frequency from 1.3 $\times 10^{-5}$ to 1.0 $\times 10^{-5}$ (-19% change), and to 2.0 $\times 10^{-6}$ to 1.8 $\times 10^{-6}$ (-14% change).

7.2.4 SEVERE ACCIDENT CLOSURE SENSITIVITY ANALYEIS

A review of containment performance design considerations using updated initiator frequencies (similar to that performed in section 7.1.2.1) showed that the associated reduction in core damage frequency and plant damage state frequency impacts the results of the containment performance analysis (Table 7-7). A summary comparison of design considerations using the the base case and updated initiator base case results provided in Table 7-5.

7.3 CONCLUSIONS

The performance of the level 2 PRA in response to the NRC's request in Generic Letter 88-20 for an Individual Plant Examination of the Perry Plant has resulted in the CEI gaining a number of insights into the contribution to risk at the plant. The outcome was the performance of the following improvements during the course of the study.

21%

Loss of Offsite Power Instruction

- Retention of RCIC isolation bypass for high steam tunnel temperature
- Enhanced process for crosstieing Unit 1 and 2 batteries
- Enhanced process for offsite power recovery to HPCS and alternate injection system bus bars.

Flooding Instruction

Enhanced response instructions to flooding scenarios.

In addition, the following improvements are expected to be made in the near future.

- Implementation of automatic RPV depressurization for non-ATWS events (following USNRC review).
- "Fast Firewater" tie between Fire Protection and HPCS
- Permanent Division 3 to Division 2 "quick" connect
- Reduction of Out of Service Time for certain critical components (already achieved for HPCS and RCIC)

The result of the improvements is an overall core damage frequency for the internal and internal flooding events of 1.3 x 10" per year and an RPV failure with early containment fail with pool bypass of 2 x 10⁻⁶ per year. Beyond the base case, a number of further enhancements discussed in the previous section have been identified and are being evaluated further. However careful analysis is required before any further improvements beyond those identified above are made.

When performing a major analysis of this type, it is necessary to fix the date for collection of design and operational information, in this case January 1, 1990. At this time Perry had only completed one full cycle of operation and therefore little or no operational data was available. Since that time, it has been possible to include data for maintenance outages on a small number of components. It is clear from the experience in operating cycles 2 and 3 that the initiating event frequencies are significantly lower than the generic values used in the NRC Grand Gulf study and therefore in the Perry study. Therefore, before any further decisions are made concerning plant improvements the first step will be to update the living PRA to include this data, and any design changes made since the freeze date of January 1, 1990. In the case of the latter, a brief review of the work performed during the first two cycles indicate that there have been no major design changes to the ECCS.

enhancements discussed earlier improve the decay heat removal The capabilities following an initiating event. It is considered that the current core damage frequency, as the result of decay heat removal failures is within the current guidelines and therefore the results of this study represent satisfactory resolution of Unresolved Safety Issue A-45 for the Perry Nuclear Power Plant.

There were no specific vulnerabilities identified with regard to containment performance in the Perry IPE. The Perry backend containment analysis indicates that the Perry containment response to severe core damage accidents is generally similar to that for other BWR/6 Mark III plants (e.g., NUREG-1150 Grand Gulf [NRC, 1989]).

The containment performance summary results for the Perry Mark III containment were: no containment failure - represents a 39% conditional probability given core damage and a frequency of 5.0×10^{-6} , containment venting - represents a 29% conditional probability and a frequency of 3.7×10^{-6} , and containment structural failure - represents a 32% conditional probability and a frequency of 4.0×10^{-6} . The conditional probability of RPV failure and early containment failure with pool bypass was estimated to be 0.16 in the Perry IPE (compared to 0.21 for Grand Gulf in NUREG-1150). The difference in these results between the Perry IPE and NUREG-1150 mainly result from significant difference in the sequences contributing to core damage, from different containmer. failure modes, and from the phenomenological assumption made in the Perry IPE regarding the probability of steam explosions failing the lower RPV head.

References

- Drouin, M. T. et al, 1989. Analysis of Core Damage Frequency; Grand Gulf Unit 1, NUREG/CR-4550 Vol 1 Rev 1 Sandia National Laboratories, Albuquergue, NM.
- Brown, T. D. et al 1990. Evaluation of Severe Accident Risks: Grand Gulf, Unit 1, NUREG/CR-4551 Vol 6 Rev 1 Parts 1 and 2. Sandia National Laboratories, Albuquerque, NM.
- NRC, 1989a Severe Accident Risks: An assessment for Five U.S. Nuclear Power Plants NUREG-1150 Vol 1 & 2 (Second Draft), USNRC Washington, D.C.
- NUMARC, 1992 Severe Accident Issue Closure Guidelines, NUMARC 91-04. Nuclear Management and Resources Council, Inc., Washington D.C.

	Core Damage Free	Percent of CDF	
Loss of Offsi	te Power		
Tl R	1.80 X 10 ⁻⁷ 7.19 X 10 ⁻⁷	1.5 6.2	(Loss of Offsite Power) (Loss of Offsite Power and no Offsite Power
υ	4.14 X 10 ⁻⁷	3.6	Recover at 3 hr) (Loss of Offsite Power w/no HPCS or RCIC)
T1P1	7.62 X 10 ⁻⁸	0.7	(Loss of Offsite Power and 1 SORV)
TIPIU	1.53 X 10 ⁻⁸	0.1	(Loss of Offsite Power and 1 SORV w/no HPCS or RCIC)
T1P2	3.89 X 10 ⁻⁶	0.3	(Loss of Offsite Power and 2 SORVs)
Total	1.44 × 10 ⁻⁶	12.4	
Station Black	out		
B BP1	2.11 X 10 ⁻⁶ 8.36 X 10 ⁻⁸	18.1 0.7	(Station Blackout) (Station Blackout and 1 SORV)
BP2	5.91 X 10 ⁻⁸	0.5	(Station Blackout and 2 SORVS)
Total	2.25 X 10 ⁻⁶	19.3	
Transients			
T3A T3AP1 T3AP2	$< 10^{-8}$ $< 10^{-8}$ $< 10^{-8}$	0.0 0.0 0.1	(Transient w/PCS)
T3B T3C T2 T2P1 T2P2	< 10 ⁻⁸ 1.38 x 10 ⁻⁷ 1.64 x 10 ⁻⁶ 2.47 x 10 ⁻⁸ < 10 ⁻⁸	0.0 1.2 14.1 0.2 0.0	(Loss of feedwater) (Inadvertent open SRV) (Transient w/o PCS)
TIA TIAP1 TIAP2	1.01 X 10 ⁻⁰ < 10 ⁻⁸ < 10 ⁻³	8.7 0.1 0.0	(Loss of instrument air)
TSW TSWP1 TSWP2	6.68 X 10 ⁻⁸ < 10 ⁻⁸ < 10 ⁻⁸	0,6 0.0 0.0	(Loss of service water)
Total	2.90 X 10 ⁻⁶	25.0	

Summary of Core Damage Frequency by Initiating Event & Flood Zone

Table 7-1



Tabl	e	7-1	cont	inued
			1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 - 1987 -	

	Core Damage Freq	Percent of CDF	
LOCAS			
A S1 S2	$\begin{array}{c} 2.11 \times 10^{-7} \\ 6.18 \times 10^{-8} \\ 3.34 \times 10^{-8} \end{array}$	1.8 0.5 0.3	(Large LOCA) (Intermediate LOCA) (Small LOCA)
Total	3.06 X 10 ⁻⁷	2.6	
ATWS			
T1-C T3A-C T3B-C T3C-C T2-C T1AC	$3.61 \times 10^{-8} \\ < 10^{-8} \\ 5.42 \times 10^{-7} \\ 9.38 \times 10^{-8} \\ 4.02 \times 10^{-6} \\ 4.33 \times 10^{-8} \\ \end{cases}$	0.3 0.1 4.6 0.8 34.5 0.4	
Total	4.74 X 10 ⁻⁶	40.7	

Total Core Damage Frequency (internal initiators) 1.17 X 10⁻⁵ (88%)

Flooding

Zone	13	8.84 X 10 ⁻⁷	57
Zone	17	3.22 X 10 ⁻⁷	21
TPC		8.70 x 10 ⁻⁸	б
Zone	1	1.93 X 10 ⁻⁷	12
Zone	1A	< 10 ⁻⁸	< 1
Zone	8	2.80 X 10 ⁻⁸	2
Zone	16	1.10 X 10 ⁻⁸	1

Total Core Damage Frequency (flooding) 1.54 X 10⁻⁶ (12%)

Total Core Damage Frequency (internal initiators & flooding) 1.32 X 10⁻⁵

Initiating Event	Perry	Kuosheng	Cofrentes	NUREG/CR-4550
Loss of Offsite Power	1.4 X 10 ⁻⁶	1.0 X 10 ⁻⁶	1	
Station Blackout	2.2 X 10 ⁻⁶	3.3 X 10 ⁻⁶	1.7 X 10	3.9 X 10 ⁻⁶
Transient w/ PCS (T3A)	< 10 ⁻⁸	1.1 X 10 ⁻⁶	÷	< 10 ⁻⁷
Loss of feedwater (T3B)	< 10 ⁻⁸	3.0 X 10-7		< 10 ⁻⁷
Inadvertent open SRV (T3C)	1.4 x 10 ⁻⁷	3.0 X 10 ⁻⁸		< 10 ⁻⁷
Transient w/o PCS (T2)	1.7 X 10 ⁻⁶	1.3 X 10 ⁻⁶	+ - 7	1.3 X 10 ⁻⁸
Loss of instrument air (TIA)	1.0 X 10 ⁻⁶	NA	< 10 ⁻⁷	< 10 ⁻⁷
Loss of service water (TSW)	6.7 x 10 ⁻⁸	-144-		-NA-
Large LOCA (A)	2.1 X 10 ⁻⁷	< 10 ⁻⁷	*	< 10 ⁻⁷
Intermediate LOCA (S1)	6.2 X 10 ⁻⁸	4.1 X 10 ⁻⁷	-7	< 10 ⁻⁷
Small LOCA (S2)	3.3 X 10 ⁻⁸	< 10 ⁻⁷	< 10 ⁻⁷	< 10 ⁻⁷
ATWS	4.7 x 10 ⁻⁶	2.6 X 10 ⁻⁵	< 10 ⁻⁷	1.1 X 19 ⁻⁷
Vessel Rupture	< 10 ⁻⁷	2.7 X 10 ⁻⁷	< 10 ⁻⁷	< 10 ⁻⁷
Total Core Damage Freq®	1.2 x 10 ⁻⁵	3.4 x 10 ⁻⁵	2.6 X 10	4.0 x 10 ⁻⁶
Internal Flooding CDF	1.5 x 10 ⁻⁶	5.7 x 10 ⁻⁷	-NA-	-NA-

* Total CDF does not include flooding.



Comparison of Perry IPE with Kuosheng, Cofrentes, & NUREG/CR-4550 Results

3

Table 7-3

Accident Sequence Grouping Criteria

Functiona	Accident Sequence Grouping Criteria	2	
Sequence	Definition	CDF	Percent CDF
1A	Accident Sequences Involving Loss of Coolant Inventory Makeup in Which Reactor Pressure Remains High.	7.0E-8	<1
1B	Accident Sequence Involving a Loss of All AC Power and Loss of Coolant Inventory Makeup.	1.5E-6	13
1C	Accident Sequence Involving a Loss of All AC Power and No Recovery of AC Power.	1.2E-6	10
1D	Accident Sequences Involving a Loss of Coolant Inventory Makeup and ATWS	5.8E-7	4
1E	Accident Sequence Involving a Loss of Coolant Inventory Makeup in which Reactor Pressure has been successfully resolved.	1.5E-6	8
2	Accident Sequences Involving Loss of Containment Heat Removal Leading to Containment Failures and Subsequent Loss of Coolant Inventory Makeup.	2.6E-6	22
3A	Vessel Rupture Leading beyond makeup capability.	<1.0E-7	<1
3B	Accident Sequence Initiatied or resulting in a small or medium LOCA for which reactor cannot be depressurized and inventory makeup is inadequate.	<1.0E-7	<1
3C	Accident sequences initiatied or resulting in medium or large LOCA for which the reactor is at low pressure and inadequate coolant inventory makeup is available.	3.9E-7	3
3D	Accident sequences which are initiated by a LOCA or failure for which vapour suppression is inadequate.	<1.0E-7	<1
4	Accident involving an ATWS leading to containment failure due to high pressure and subsequent loss of inventory.	4.0E-6	34
5	Unisolated LOCA outside containment leading to loss of effective coolant inventory makeup.	<1.0E-7	<1



Table 7-4

Frimary IPE Core Damage Evaluation Process

Mean CDF Per Sequence Group (per reacto: year)	Licensee Response
Greater than 1E-4 or greater than 50	 Find a cost effective plant administrative procedural or hardware modification with emphasis on reducing the likelihood of the source of the accident sequence initiator.
percent of total CDF	 If unable to satisfy above response, treat in EOPs or other plant procedure with emphasis on prevention of core damage.
	 If unable to satisfy above responses, ensure SAMG is in place with emphasis or prevention/mitigation of core damage or vessel failure, and containment failure.
1E-4 to 1E-5 or	 Find a cost effective treatment in EOPs or other plant procedure or minor hardware change with or emphasis on prevention of core damage.
20 percent to 50 percent of total CDF	 If unable to satisfy above response, ensur SAMG is in place with emphasis on prevention/mitigation of core damage or vessel failure, and containment failure.
1E-5 to 1E-6	Ensure SAMG is in place with emphasis on prevention/mitigation of core damage or vessel failure, and containment failure.
Less than 1E-6	No specific action required.



CONTAINMENT PERFORMANCE COMPARISON OF DESIGN CHANGE CONSIDERATIONS

GENERIC INITIATING EVENT FREQUENCY

UPDATED INITIATING EVENT FREQUENCY

Bypass	Core Damage	Containment Structural <u>Failure</u>	RPV Feilure And Early Containment Failure With Pool Bypase	Core Damage	Containment Structural Failure	RPV Failure And Early Containment Failure With Pool
Base Case	1.38-5	4.08-6	2.0E+6	8.18-6	2.6E-6	1.08-6
Passive Vent	1.0E-5 (~18% CHG)	9.9E-7 (-75% CHG)	4.5E-7 (-78% CHG)	6.7E-6 (-17% CHG)	5.3E-7 (~80% CHu)	2.0E-7 (-81% CHG)
ATWS Mods: Alt Shutdown & ADS Inhibit	1.3E-5 (-19% CHG)	3.5E+6 (→13% CHG)	1.8E~6 (-14% CHG)	7.3E-6 (- 9% CHG)	2.58-6 (~ 5% CHG)	9.5E-7 (- 7% CHG)
Passive Vent & ATWS Mods	8.0E-6 (-37% CHG)	4.6E-7 (-89% CHG)	1.6E-7 (-92% CHG)	5.9E~6 (-26% CHG)	4.08-7 (~85% CHG)	1.2E-7 (-89% CHG)
Passive Vent, ATWS Mods & Ignitor Power	8.0E-6 (-37% CHG)	1.8E-7 (-96% CHG)	1.1E-7 (-94% CHG)	5.9E~6 (-26% CHG)	1.2E-7 (-96% CHG)	7.2E-8 (-93% CHG)

NOT-

These results are based on an analysis of the core damage sequences included in the plant damage state trees. Thus there are small differences in the impact of changes reported in this table compared with those reported for internal event core damage sequences in section 3.4. These differences do not change the overall conclusions.

Table 7-6

IPE Containment Bypass Evaluation Process

Mean Containment Bypass Frequency (per reactor year)	Licensee Response
Greater than 1E-5 or	 Find a cost effective plant administrative, procedural or hardware modification with emphasis on eliminating or reducing the likelihood of the source of the accident sequence initiator.
greater than 20 percent of total CDF	 If unable to satisfy above response, find cost effective treatment in EOPs or other plan procedure with emphasis on prevention of core damage.
	 If unable to satisfy above responses, ensure SAMG is in place with emphasis on prevention/mitigation of core damage or vessel failure, and containment failure.
1.5 to 1E-6 or	 Find a cost effective treatment in EOPs or other plant procedure or minor hardware change with emphasis on prevention of core damage.
5 to 20 percent of total CDF	 If unable to satisfy above response, ensure 3AMG is in place with emphasis on prevention/mitigation of core damage or vessel failure, and containment failure.
1E-6 to 1E-7	Ensure SAMG is in place with emphasis on prevention/mitigation of core damage or vessel failure, and containment failure.
Less than 1E-7	No specific action required





TABLE 7-7 IMPRCT OF DESIGN CHANGES ON CONTAINMENT FAILURE FREQUENCY USING UPDATED INITIATOR FREQUENCY



	base Case	UPDATED INITIATOR FREQUENCY	(1) UPDATED PASSIVE VENT	(2) UPDATED ATWS ALT SHUTDOWN & ADS		(4) UPDATED PASSIVE VENT, ATWS MODS . HIS BACKUP POWER SUPPLY
No RFV Failure: No Containment Failure	3.398-6 (26.7%)	1.22E-6 (15.2%)	1.22E-6 (18.3%)		7.34E-7 (12.4%)	7.60E-7 (12.8%)
Vent	2.45E-6 (19.3%)	2.36E-6 (29.4%)	2.828-6 (42.3%)	2.458-6 (33.5%)	2.91£~6 (49.0%)	2.918-6 (49.0%)
Containment Failure	6.18E-7 (4.9%)	4.70E-7 (5.8%)		4,705-7 (6,4%)	2.90E-8 (0.5%)	3.79E-9 (0.06%)
Subtotal No RPV Failure Core Damage Freq:	6.46E-6 (50.8%)	4.06E-6 (50.3%)		3.65E-6 (50.0%)	3.67E-6 (61.9%)	3.678-6 (61.9%)
RPV Fuilure: No Containment Failure	1.58E-6 (12.4%)	6.22E-7 (7.7%)		4.098-7 (5.6%)	4.09E-7 (6.9%)	6.21E-7 (10.5%)
Vent	1.27E-6 (10.0%)	1.23E6 (15.3%)		1.24E-6 (16.9%)	1.40E-6 (25.0%)	1.53E-6 (25.7%)
Late Containment Failure	9.38E-7 (7.4%)	9.25E-7 (11.5%)	2.45E-7 (3.7%)	9.25E-7 (12.7%)	2.45E-7 (4.1%)	3.20E-S (0.5%)
Early CF: No Pool Bypass	4.30E-7 (3.4%)	1.88E-7 (2.3%)	2.00E-8 (0.3%)	1.28E-7 (1.7%)	7.37E-9 (0.1%)	7.00E-9 (0.1%)
Late Pool Bypass	1,54E-6 (12,1%)	7.51E-7 (9.3%)	8.40E-8 (1.3%)	7.04E-7 (9.6%)	2.05E-8 (0.3%)	1.04E-8 (0.2%)
Early PB, Spray	6.12E-8 (0.5%)	2.82E-8 (0.3%)		2.09E-8 (0.3%)	2.09E-8 (0.4%)	1.08E-8 (0.2%)
Early PB, No Spray	4.458-7 (3.5%)	2.49E-7 (3.1%)		2.30E-7 (3.1%)	7.36E-8 (1.2%)	5.048-8 (0.8%)
Subtotal RPV Failure Core Damage Freq:	6.27E-6 (49.2%)	4.00E-6 (49.7%)		3.662-6 (50.0%)	2.26E-6 (38.1%)	2.26E++6 (38.1%)
TOTAL CORE DAMAGE FREQUENCY:	1.27E-5 (100%)	8.05E-6 (100%)	6.67E-6 (100%)	7.31E-6 (100%)	5.938-6 (1004	5.93E-6 (100%)
Subtotal Containment Venting Frequency:	3.72E-6 (29.2%)	3.59E-6 (44.7%)		3.69E-6 (50.4%)	4.39E-6 (71.0%)	4.43E-6 (74.8%)
Subtotal Cntmt Structural Failure Freq:	4.03E-6 (31.7%)			2.48E→6 (33.9%)		1.15E-7 (1.9%)
TOTAL CONTAINMENT FAILURE & VENTING FREQ:	7.76E-6 (60.9%)			6.17E6 (84.4%)		4.55E-6 (76.7%)
RPV FAILURE & EARLY CONTAINMENT FAILURE WITH POOL BYPASS FREQUENCY:	2.04E-6 (16.1%)	1.03E-6 (12.8%)	1.99E- (3.0%)	9.548-7 (13.1%)	1.15E-7 (1.9%)	7.16E-8 (1.2%)








×


1E-006

•

1

]





APPENDIX D

HUMAN RELIABILITY ANALYSIS FILE FOR THE PERRY PLANT IPE

Prepared by G.W. Parry B.O.Y Lydell W. Colvia

HALLIBURTON MUS Environmental Corporation 910 Clopper Road Gaithersburg, Maryland 20878

TABLE OF CONTENTS

.

1

INTRODUCTION

Q

PART	A. ANALYSIS OF TYPE A HUMAN INTERACTIONS	2
PART	B. ANALYSIS OF TYPE C HUMAN INTERACTIONS	5
	1.0 Introduction 1.1 Overview 1.2 Quantification Approach	5 5 7
	<pre>2.0 PNPP ATWS Sequences 2.1 MSIV Closure ATWS (T2-C) 2.1.1 Introduction 2.1.2 Dependencies</pre>	8 8 8 11
	 2.1.3 Quantification of Non-Response Probabilities 2.1.4 ATWS With Loss of PCS 2.2 ATWS With PCS Available 2.3 Event Tree (T3B-C) 2.4 Event Tree (TIAC) 2.5 Event Tree (T1-C) 2.6 IORV ATWS (T3C-C) 	12 26 32 32 32 32
	3.0 PNPP Loss of Offsite Power Sequences	34
	4.0 PNPP Station Blackout Sequence	47
	5.0 Transients And LOCAs	53
	 6.0 Other HI Events 6.1 Other Type CP Human Interactions 6.2 Other Type CR Human Interaction 	56 56 63

-12

ATTACHMENTS

Α.	HEP Error	Factor Basis	64
в.		Flooding Analysis	65
с.	Perry IPE	HI List	69

FIGURES

ATWS And Loss Of PCS Event Tree 25 ATWS With PCS Available Event Tree ATWS With Loss Of Feedvater Event Tree ATWS And Loss Of Instrument Air Event Tree 27 28 29 ATWS And LOOP Event Tree 30 ATWS And IORY Event Tree 31 LOOP Event Tree 41 LOOP Without Recovery of Offsite AC Event Tree 42 LOOP With RCIC Failure Event Tree LOOP And One Stuck Open SRV Event Tree 43 44 LOOP With 1 SORV & RCIC Failure 45 LOOP And Two Stuck Open SRVs 46 Station Blackout Event Tree 50 Station Blackout With One BORV 51 Station Blackout With Two SORVs 52





.. O INTRODUCTION

The objective of the human reliability analysis (HRA) is to provide estimates of the probabilities of the human interaction (HI) basic events included in the Perry Plant IPE logic model. In general, human interactions considered for inclusion in a PRA can be divided into three general classes according to the time phase in which they occur.

Type A HIS arise before an initiating event, when plant personnel can affect availability and safety of the plant by inadvertently leaving equipment disabled following test, maintenance and calibration activities.

Type B HIs are those HIs that result in, or contribute to, initiating events. Examples are: plant trips following mistakes during testing, failures to control feedwater leading to plant trip, etc. Type B events are almost invariably incorporated implicitly in the initiating event frequencies obtained from plant operating experience. No explicit consideration of Type B His has been included in this study.

Type C HIS cover a wide range of specific actions <u>following</u> an accident. There are two sub-categories of Type C: (1) operator action performed in response to an Emergency Operating Procedure (EOP), including manual backup on failure of automatic initiation of systems, and (2) recovery actions in response to unavailability of a safety function that failed because of equipment malfunction. Events in the first sub-category (Type CP) can either appear as headings in the event trees, or as basic events in system or functional fault trees, while recovery actions (Type CR) are addressed at the accident sequence cutset level.

This analysis file consists of two parts: Part A addresses type A HIS, and Part B, the Type C HIS.

Part A

Analysis of Type A Human Interactions

Type A HIs are those interactions that occur during normal plant operations and include testing, maintenance, and calibration activities. The adverse impact of these activities that is accounted for in PRA models is the potential for leaving components inadvertently available. Typically these include miscalibration of sensors or instrument channels, and leaving valves in an incorrect configuration.

Generally miscalibration events have not been found to be significant contributors to core damage, unless they are common cause failures, where the event affects more than one redundant train. In this study, the common cause error was not evaluated explicitly but was included with a value given by a tenth of the failure of a single sensor.

Because there are a large number of potential restoration error opportunities, a qualitative screening was performed using the following guidelines:

General Component Type A Guidelines

- Restoration faults following maintenance will not be postulated if the system undergoes a full functional test following completion of maintenance.
- Restoration faults will not be postulated if the component has an indication in the control room which is verified on a daily basis <u>and</u> is readily apparent to the operators if out of position or if power is disconnected.
- Restoration faults will not be postulated if the components are included on a daily checklist.

Manual Valve Type A Guidelines

- o Restoration faults will not be postulated if there is double (independent) verification of position following test/maintenance and the valve is also verified in the correct position between test events (e.g., on a checklist).
- Restoration or mispositioning faults will not be modeled if the valve is administratively controlled to be in its correct alignment as locked open, locked closs, or locked throttled and checked guarterly or more frequently.

Valves (Other than Manual) Type A Guidelines

- Restoration faults will not be postulated if the valve has an individual position indication in the control room <u>and</u> is included on a daily (or more frequent) checklist.
- Restoration faults will not be postulated if the valve receives a signal to go to the correct position <u>and</u> a position indication light shows if power is not connected.
- c Restoration faults will not be postulated if there is double (independent) verification of position following test/maintenance and the valve is also verified in the correct position between test events (e.g., on a checklist).
- o Restoration faults will not be modeled if the valve is administratively controlled to be in its correct alignment as locked open, locked closed, or locked throttled with motive power removed.

Only the non-safety systems remained after applying these screening guidelines. A value of 10⁻³ was used for restoration errors in the instrument air and system air systems.



FART B ANALYSIS OF TYPE C HUMAN INTERACTIONS

1.0 INTRODUCTION

1.1 Overview

The plant logic model, the event trees and fault trees, were constructed to include human interaction basic events. To define the plant 1. 'c, these events are adequately defined in terms of the failure mode they represent e.g., operators fail to depressurize the reactor following a loss of high pressure injection. However, in order to quantify these events, i.e., estimate their probabilities, it is essential to define them in greater detail. For example, it is necessary to understand what cues and procedures the operators use to guide them to perform the required function, what they have to do to successfully accomplish that function, the time available, and other factors that might influence their probability of success or failure. These factors are all scenario specific. The first step in the HRA was, therefore, to define the events as clearly as possible in preparation for the quantification. This was done by studying the scenarios to which the human interaction events contributed, and understand, among other things, the time line of the events. This was documented in a series of calculation files (AS-09, AS-10, AS-11, etc.).

Another function of this step of the HRA task is an identification of potential dependence between the human interaction events that occur in the model. Functional dependencies of the type, "if event A occurs, event B cannot be successful," are handled in the overall structure of the model, i.e., they are nardwired into the event tree structure. What is principally of concern here is the influence of success or failure in a preceding event on the probability of success or failure of another event. There are a variety of reasons why the events may be probabilistically dependent; one important issue is that the cognitive processes needed to recognize the need for multiple actions may have common elements. To assist in the

5

identification of such cognitively correlated HIs, the following groundrules are adopted:

- (a) If two HI events are associated with responses to the same plant status (e.g., initiate HPCS pump, initiate RCIC on failure of auto initiation at Level 2), the cognitive part of the failure probabilities are considered to be totally dependent.
- (b) As a corollary to this, if, in the chronological development of the scenarios, an HI failure event follow a successful HI, and the procedural instructions for both events are closely related, the cognitive failure probability of the second HI should be very small and can be neglected, since the success in the first event implies a successful recognition of the scenario.
- (c) If human interactions are i) separated by a significant time (i.e., time between cues or required responses is long), or ii) separated chronologically in the sequence by a successful action, and/or iii) responses to different cues in different parts of the EOPs, they may be regarded as being independent. However, when applying this would result in very

low values for products of HEPs, this was not always used (see discussion on RHR and venting).

(d) In addition, the early memorized responses may be regarded as inde, indent from those actions for which the procedures are expected to be providing the direction.

Other types of dependency, such as the fact that performing one function may take resources away from another is also considered by addressing, in the evaluation of the HEPs, the role of crew personnel, both in performing the actions called for, and in recovering from failure to execute correctly.

1.2 Quantification Approach

The model of human interactions used . It the evaluation of a human error probabilities is the simple one that splits the response into two components, a detection, diagnosis and decision (DDD) base, and an execution phase. This is compatible with the ASEP methodology (1), the more recent EPRI proposed methodology (2), and the HRA Handbook (3), all of which were used in the quantification. Reference is made to these documents for details.

For the key time-critical human interactions, the time-reliability curve approach of Reference 2 was used to estimate the probability of failure in the DDD phase. The alternate approach of Reference 2 was used to evaluate the HEPs for those HIs considered dependent on the time critical HI, or which are not time critical. A simplified THERP or ASEP approach was used to estimate the HEP for the execution phase. The details can be found in the following sections.

The analysis is documented essentially on a function-by-function basis in the context of the sequences, rather than on an HI by HI basis, so that **: relationship between the HI events and the scenario can be explored. Because of the large number of events included in the model, the detailed analysis has concentrated on these human interaction events which are direct contributors to system performance and appear in functional fault trees or as contributors to the top gates of system fault trees. Those that are responses to specific component or subsystem failures are handled by assigning fairly coarse screening values.

Because all the HRA methods available are to some extent arbitrary, the analysis should be regarded in some cases as providing plausibility arguments rather than accurate assessments. This is particularly true of the long-term actions such as initiation of RHR for which failures are believed to be of extremely low probability.

REFERENCES:

- "Accident Sequence Evaluation Program Human Reliability Analysis Procedure", Alan D. Swain, NUREG/CR-4772, Feb 1987.
- "An Approach to the Analysis of Operator Actions in Probabilistic Risk Assessment," EPRI-TR-100259, Dec 1991.
- NUREG/CR-1278, August 1983, "Handbook of Human Reliability Analysis with Emphasis on Nuclear Power Plant Application", A.D. Swain and H.E. Guthman.

2.0 INPP ATWS SEQUENCES

The purpose of this section is to document the human reliability analysis for postulated ATWS scenarios at PNPP.

2.1 MSIV Closure ATWS (T2-C):

2.1.1 Introduction

In the event of an MSIV-ATWS all the steam that is generated goes to the suppression pool via the SRVs. It is assumed that the MSIV closure leads to a loss of feedwater turbine-driven pumps and the PCS; i.e., no heat sink is available. During the initial few seconds the reactor responds to the transient as it would with control rod insertion, then it responds to the recirculation pump trip (RPT) which reduces core flow and therefore power to that corresponding to natural circulation. With no rods going in, the vessel level reaches the Level 2 set-point causing the HPCS and RCIC to automatically actuate and inject water into the vessel. The motor-driven feedwater pump (MFP) starts on L-2, but with the MFP feedwater regulation valves closed by the run-back of MFP, operator action is required to inject water into the vessel. Operator actions play an important role in the progression of the MSIV closure ATWS sequences. There are four basic goals of the CR crew response to an ATWS: (i) reactivity control, (ii) reactor pressure vessel (RPV) level control, (iii) RPV pressure control, and (iv) suppression pool temperature control. The operators are expected to not only attempt to insert control rods, but to be awave of the limitations of the SLCS (i.e., relatively slow acting) and how void effects can be used to reduce reactor power: i.e., increasing voids by recirculation pump trip, depressurization, or lowering of the water level. During the postulated MSIV-ATWS scenarios, the CR operators will be guided by the PEIs and supporting documentation and the available control room aids (e.g., the Emergenc^w Response Information System, ERIS). As indicated by the event tree and the supporting fault trees for the MSIV-ATWS initiating event, the following HIs are addressed:

- U3: manual start of the motor-driven feedwater pump (MFP) given failure of the auto-start, and opening of the feedwater regulation valves. LC: manual control of RPV level between the
 - Minimum Steam Cooling Water level (MSCWL) topof-active fuel (TAF) and L-1 (46" band).
- X'; inhibit the ADS to avoid an uncontrolled depressurization and overfilling the RPV with cold water from low pressure injection(LPI) systems.
- Cl; manual initiation of SLC (1 pump).
- K: emergency depressurization of the RPV to maintain suppression pool temperature below the Eeat Capacity Temperature Limit/ (HCTL).
- V; initiation of LPCI (or RHR A/B) to maintain vessel level.
 - V'; prevention of inadvertent overfill of the vessel that causes boron dilution.
 - W; manual initiation of long-term heat removal with RHR.
 - Y; initiation of containment venting after

successful shutdown with boron, given that other means of containment heat removal have failed.

In performing the quantitative assessment of theme HIs, the concept of the <u>cue-response atructure</u> as a means of placing each HI in a context of key plant parameters applicable to the operator action of concern was utilized⁽²⁾. This also assists in assessing dependencies between HEPs. For the analysis of the MSIV-ATWS the following reference points are defined:

> Suppression pool temperature is assumed to be just below 90°F at the start of the transient. This temperature limit is alarmed in the control room and the operators are very familiar with the practical implications of it. The operating practice at Perry is such that, prior to reaching a pool temperature of 90°F, the suppression pool cooling is started and is kept operating until the temperature is brought to its lower level. Hence, at the start of the postulated transient the plant is at the high point of a pool cooldown-heatup cycle. The operators may be anticipating a need for suppression pool cooling at the time of the transient.

Suppression pool temperature of 110°F. This is a limit identified in the technical specifications for the plant. If this limit is reached then a plant shutdown is required. The PEIs also use this temperature limit as a reference point for initiation of boron injection if the reactor cannot be shutdown with control rods, and is also used as one of the cues for initiation of the power-level control contingency. The accident sequence analysis file, AS-11, provides the following times measured from the initiating event of MSIV closure:

Time to L1 without HPCS or MFP: 1.9 minutes.

Time to HCTL (185°F);

-- No level control: 8.8 minutes

-- With level control: 15.1 minutes

- Time to reach containment pressure of 15 psig (cue for initiation of containment venting): 5.5 hours
- Time to pressurize containment to 50 psig (IPE containment pressure threshold limit): 9 hours

2.1.2 Dependencies

The human interactions (HIs) in the ATWS model are highly dependent, which complicates the HRA. The dependencies and their implications are discussed below:

The transient starts with the reactor at full power and the plant transient response will be very rapid requiring timely operator response. The event tree functions U1 and U3 are associated with the auto-start of HPCS and MFP, respectively, upon reaching L-2. The HIs in these functions relate to manual back-up to the autostart failure and should be regarded as totally dependent as they are responses to the same step (RC/L-2) in the EOPs. However, opening the MFP feedwater control valves is also an important action and is associated strongly with the level-power control actions.

Subsequent operator actions depend on whether HPCS and MFP run or not. If there is high pressure injection initially, there will be more time available to deal with the transient. Hence, the dependence between UI and U3 and subsequent event tree functions are accounted with different time-windows, as well as different definitions of functions. For example, if the MFP is not initiated early enough, the level will drop to below -30" and the level/power control procedure instruct the operator to go to emergency depressurization. However, if the level is restored before -30",

which can only be achieved with the MFP, the reason for depressurization is to maintain reactor pressure below the HCTL.

The level/power control (operator action to lower level) and power control (operator action to initiate SLC injection) are coupled by a requirement to control reactor pressure below the Heat Capacity Temperature Limit (HCTL), and/or to prevent containment failure. Per the PEI, the instructions for both these actions are associated with an instruction to inhibit the ADS. The purpose of the ADS inhibit is to prevent uncontrolled depressurization and LP-injection (which causes reactor power to go up again). This operator action is a simple action with the cue afforded by a procedural step. There are at least two prompts to inhibit ADS: (i) the first is in the PEI directs the operators to inhibit and (ii) the second results from actuation of the ADS timer (set at 105 seconds) which is alarmed.

Depressurization is called for when the suppression pool temperature exceeds 122°F and RPV pressure is greater than 1050 psig. If the suppression pool temperature cannot be maintained below the HCTL, then the operators are directed to perform Emergency RPV Depressurization. The initiation of RHR has a minor impact on the initial pool heatup rates, but on its own cannot remove enough heat to prevent containment failure without the other actions. To a large extent it can be considered independent of the other actions, since in any case it is only asked in the event tree when successful shutdown is accomplished.

2.1.3 Quantification of Non-Response Probabilities

As discussed earlier, non-response probabilities are expanded into two contributions, P_c - probabilities are failure of initiation (or of recognition of the need to act), and P_c - failure in execution.

2.1.4 ATW3 With Loss Of PCS

Function C

The functional fault tree for event C contains the event RPHICPERC-1:Q-2 which represents failure or the operator to attempt to manually scram the reactor on the occurrence of a scram signal. This is an automatic instinctive response, and an HEP of 10⁻⁴ is considered appropriate. Swain ⁽¹⁾ suggests that failure of the cognitive part of the response can be essentially neglected, and, since the controls are very clearly identified, the likelihood of an error of commission is negligible.

Function U3

One human interaction in function U3, FWHICPEL-2-FDW, relates to manual backup to failure of auto-initiation on Level 2. However, in the case of an ATWS another event FWHICPEL-2-FDW-V, is included in the U3 functional fault tree, to account for the fact that the operators have to manually open the feedwater regulation valve to allow the MFP to inject given it has started on level 2. The procedural instruction is given in the level/power control procedure to maintain level while pressurized between -30" and 217" with feedwater and RCIC, (but HPCS is used only above TAF). SLC will be having little effect at this time. The time to reach TAF with no injection is 2.2 minutes, and the time to reach -30" is 2.5 minutes. There is a 55 second delay after the MSIV closure before the operators can take control of FW. This HI will be analyzed later, since chronologically the cues to initiate SLC will be occurring at about the same time (pool temperature reaches 110° F in about 40 seconds), and this is regarded as the principal concern of the operators. In the ATWS tree, the manual back-up event FWHICPEL-1-FDW is subsumed in this event and removed from the U306 function.

The functions that follow success in function U3:

Function LC

The functional fault tree for LCO2 is purely an HEP-FWHICPEC5:3-2. It follows an initial success in restoring the MFP injection before

the level reaches -30". The value for this HEP is highly dependent on that used for the failure to initiate SLC in function C1. Chronologically it should occur after initiation of SLC. The operators are trained to initiate SLC before the BIIT temperature of 110°F is reached. Lowering level is only initiated when the BIIT is reached, and the other conditions, (a relief valve open, and power level above 4%) have also occurred.

Success in C1 implies that the operators have correctly diagnosed an ATWS and therefore are in the correct path through the procedures. From the above, therefore, success in LC implies that the operators have correctly diagnosed the need to initiate boron injection, since both actions involve a common que (110°F pool temperature). It is also important to note that, feedwater has been restored successfully. Thus, what failure implies here is failure to pay heed to the instruction "maintain level between -30" and the level to which it was lowered to control power", and results in water level being maintained too high.

The value used for LCO2 is propagated through the event tree into sequences S=10 through S=16 as a conditional probability of failure to control level, given that SLC has been successfully initiated.

We will use the decision trees of EPRI TR-100259 as a basis for estimating this number.

Since this number is contingent upon the successful recognition of the need to inject SLC, and this is likely to occur early, given successful identification of the need for level control (P_c success), there should be ample chance to recover from an initial step in execution. (i.e., $P_e < 10^{-3}$, and the HEP is dominated by P_c (see attached worksheet).

FWHICPEC5:3-2 $P_c = 10^{-2}$ (Mean value)

An error factor of 3 is assigned (see attachment A)

ADS Inhibit

With successful level control and successful identification of the need to initiate SLC, the operators will have had two separate written instructions to inhibit ADS. In addition, when level is lowered, the ADS alarm will come on at Level 1 acting as a further prompt.

11 0

If the level is not lowered, which can only occur if the MFP is initiated before level 1 is reached, there will be no need to inhibit ADS.

MORKSHEET FOR CALCULATION OF DC

Scenario:						
HI:	<u>(c</u>		ana ana aona aona aona aona ao	enderstation of an indication for		
Cue(s):	-				
Durat	ion of time window available for	action (Tw):	-	Seconds.		
Appro	ximate start time for Tw:	ning second states in the second state of the	No. No. No. No.			
Proce	dure and step governing HI:	eneral a contracture in the set	-	-		
Á.	Initial Est mate of pc					
	Pc Failure Mechanism	Branch	YEP	Reduce Ty by		
Pca:	Availe/ility of information	NA		#in.		
pcb:	Failure of attention	NA	-	H/A_win.		
Pec:	Misread/miscommunicate data	NA		_4/A_#in.		
ped:	Information misleading	NA				
pcei	Skip a step in procedure	e of .		N/A win.		
pcf:	Misinterpret instruction	NA		4/A #1/		
pcg:	Misinterpret decision logic	:00 b	-	N/A_min.		
pch.	Deliberate violation	NA	-	H/A sin.		

Sum of pea through peh + Initial pe -01

Total reduction in Ty . ______min.

Effective Ty = _____win.

.062 or 1004

Check here if recovery credit claimed on page 2: ______

However, this action is dependent on the initiation of SLC and level control. If these are successful, the only way to miss this action is by missing the two steps in the procedures, and by missing the alarm. This is extremely low probability and the failure to manipulate the switch, i.e., P, will dominate.

This value is taken from NUREG/CR-1278, assuming item 2 Table 20-12. It is certainly arguable that items 3 or 4 may be more appropriate, but item 2 is chosen as a conservative option.

To convert a median value into a mean value the following formula is used:

mean =	exp	1	[ln_EF]	2
Median		2	1.645	

Summary: HEP for event ADHICPC51-ADS-A is given a mean value = 3.8E-3 and an EF = 3

The same value is used on both the success and failure of level control as the same failure mechanism and conditions apply. Even if level is restored and restored high, it is judged that leve? would dip below level 1 for a brief period. However, it should be noted that the timer will stop running if the level exceeds level 1 again, therefore, use of this value on the failure to control level branch is probably conservative.

Initiation of SLC

On the successful level control branch, as mentioned earlier, it is assumed that the operators have successfully recognized the need to initiate SLC. In this case, the remaining failure mechanism is failure to initiate.

P, is taken from Table 20-12 of NUREG/CR-1278, using item no. 3 as a typical value.

median = 10^{-3} EF = 3. mean = 1.25×10^{-3}

for event SLHICPEQ-6-SLC1

It should be noted that with successful level control there is ample time to recover from the execution error and hence this value is considered conservative.

On the branch for failure to control level, it is conservatively assumed that the probability of failure to initiate SLC is unity. An alternate approach would have been to estimate an HEP based on the time available before containment failure using the HCR/ORE model.

Function X - Initiation of Depressurization

It is assumed that depressurization is always needed i.e., HCTL is always reached. Given successful level control and initiation of SLC, there is no failure even if depressurization is not performed when SP temp exceeds HCTL. Therefore, it is difficult to define a time window. Thus, the HCR method is inapplicable. Instead the alternate EPRI TR-100259 method is used as shown on the attached worksheet.

With failure to lower level, the HCTL is reached earlier and thus the probability of failure is expected to be a little higher. Even though not part of the EPRI method, this HEP will be evaluated by doubling the number for the previous case. This is somewhat arbitrary, but done to maintain relative significance.

Therefore:

ADHICPEC5-ADS-FL = .007 EF = 5 ADHICPEC5-ADS-FX = .014 EF = 3

The P, contribution is negligible, since given the decision has been

made to depressurize, there is obvious feedback in whether it has been successfully performed, and the action is simple, and as discussed earlier, failure to depressurize is not a failure. MORKSHEET FOR CALCULATION OF PC

.

11:	Film la degrenes	in in	14676	
ue(s)	1 HETL			ana ana amin'ny solatana amin'ny solatana amin'ny solatana amin'ny solatana amin'ny solatana amin'ny solatana a
Duration of time window available for action (Tw) :				Seconds.
pprox	imate start time for Tw:			
roced	ure and step governing HI:		ana destructures d	values and the second second second second
. 1	nitial Estimate of pc			Reduce
	c Failure Mechanism	Branch	HEP	TH by
ca:	Availability of information	a	neg	sin.
cb:	Failure of attention	Al	-	N/A min.
ec:	Misread/miscommunicate data	a		N/A sin.
ed:	Information misleading	a.	-	H/A win.
Dce:	Skip a step in procedure	e/f_		N/A_min.
pcf:	Misinterprez instruction			N/A_win
Pcg:	Misinterpret decision logic	_ke_		N/A_Bin
ach:	Deliberate violation	NA		H/A min

neg - because . 008 aughing disc menty. has been neg . seen to long . JOL /. JUY this paral neg . Can sugar neg : low with

Effective Tw = ______min.

Check here if recovery crudit claimed on page 2:

Notes:

O but is

Event V

The initiation of low pressure systems is necessary following successful inhibit of ADS, and successful blowdown. When the emergency blowdown procedure is used, the procedure says to terminate and prevent injection from LPCS and LPCI.

This event is clearly coupled with event X cognitively, and therefore, the probability is estimated on the basis of the P_e torm. There is no time to recover from errors of commission or of omission in this scenario.

The probability should be no different from a non-ATWS case since the reactor is being shutdown. Indeed, in the case of successful LC and SLC in a timely manner, HCTL is reached at 0.25 hrs (MAAP 11_03_48) and therefore the reactor is close to being shutdown.

Given that the decision has been made to blowdown and it has been performed correctly, the primary failure mechanism is assumed to be an error of commission. Using Table 20-12 of Ref. 1, item 3, and treating initiating all three pumps (RHR A, RHR B, and LPCS) as being totally correlated, a median value of .001 is used.

Summary: HEP for HIHICPEC5-3:2-S has a mean value of 0 001 and an EF = 3

Event V' - RPV Overfill

This event is dependent on successful initiation of low pressure injection, and is really a control action. None of the models is really applicable. The operators have be alert to level changes and control level if it gets too high.

However, one possible mechanism is to miss the step in the procedure that says (terminate and prevent). Using the EPRI TR-100259 approach,

Mechanism (e), end point (e) gives an HEP = 0.002

Summary: HEP for HIHICPEC5-5-CRIT has a mean value of 0.002, and an EF = 3

Initiation of RHR and Venting

For the upper branch, with successful initiation of SLC and level control, the time window for successful initiation of RHR and venting is long (several hours) and therefore, the HEP is small. This is assumed to be the same as for the transients with scram (see discussion under the loss of offsite power event tree).

For the lower branch (ie., LC failed), the time scale is shorter, although not significantly so, and the same HEPs are used.

Functions following Failure of Feedwater R"anch, Uz.

Chronologically, the first action required (or even possible, taking into account the 55 sec. delay for FW restoration) is initiation of SLC. However, even with successful SLC it is not clear that core damage can be avoided without restoring the level above -30". Therefore, the two connected actions of restoring MFP and/or depressurizing and establishing LPI before reaching -30" are regarded as key.

In the worst case, (no HPCS and no FW), Level 1 is reached in 1.9 minutes. Therefore, inhibiting ADS, must be achieved before 1 min 55 secs + 105 secs from the beginning of the transient, i.e., 220 secs. In addition, MAAP run 11_03_47 shows that there are an extra 33 secs before the RPV pressure reaches the LPCS shut-off head.

Inhibiting ADS is almost at the level of a memorized action, but even it if is not, there are two separate occasions that are called for in the procedures RP/Q, and Level/Power control.

These should be reached at about 40 seconds into the accident. Treating this as a type CPI action $^{(2)}$, assume 60 secs for $T_{1/2}$, and assume 15 secs to get the keys for the ADS inhibit switch, then Tw = 253 - 55 = - 203 secs.

$$P_c = 1 - \bigoplus (\frac{\ln(205/60)}{.7}) = 1 - \bigoplus (1.755) = 0.036$$

Given the switches are well indicated, the failure to perform the action is 10⁻³. (no chance credited for recovery). Thus the failure to inhibit ADS is assessed as .036. Since this event appears in the event tree after failure to restore feedwater, it is included as a conditional probability given by:

ADH1CPC5-1-ADS-0 = .036 = .036 = 7.2 FWHICPEL-2-FDW-V .005

. where AWHICPEL-2-FDW-V is the failure to restore feedwater - see below.

Failure to restore feedwater, FWHICPEL-2-FDW-V, has a time window greater than 12 minutes. The time window is measured up to the onset of core damage. (MAAP run 11_03_49)

The first procedural instruction encountered will be in level/power control procedure, which should be picked up in about 1 minute (power is >4%, and SRV is open and pool temp reaches 110°F in about 40 sec).

Restoring feedwater is a simple task - controlling MFP flow control valves - therefore the DDD contribution ought to be dominant. Given this is the case, and the actions to initiate FW and to blowdown are guided by the same symptom level and by the same part of the procedure, the cognitive parts of the HIs to initiate injection from MFP and to initiate blowdown are regarded as completely correlated.


If it is assumed that the operators take charge of FW as quickly as

they can in accordance with procedures, then the median time is assumed to be about 2 minutes (the operator cannot succeed before 55 secs because of interlocks). With a time window of 12 mins, the HCR/ORE model gives a probability of failure for event FWHICPEC-2-FDW-V, of

$$1 - \Phi(\frac{\ln(12/2)}{.7}) - 0.005$$
, EF = 5


Note that this same basic event is used in both the U3 FFF event and in the X14 FFT.

Given that SLC follows successful ADS inhibit on the tree, the same value for failure to initiate is used as before. The same HEPs are used in all the remaining functions.




2.2 ATWS with PCS available (T3A-C):


In this case, the level will drop extremely quickly, to below level 1 in 1.9 minutes. Bypassing the MSIV isolation signal on level 1, although a simple action, does not appear to be high on the list of priorities of the operators. Therefore, the likelihood they will succeed is essentially zero. Therefore, HEP NSHICPEC5-L173 = 1.0. However, if the MFP is restored early enough, and level can be kept above level 1, the MSIVs will not close, so event Q in function Q01 could be modified as:




Since the time is so short, estably no credit is given and Q01 is assumed to be 1.0. The tree then is developed exactly like the T2-C event tree, ie., MSIVs closed. If it could be shown that the SRVs would reclose with the level above Level 1, then it is possible that some chance of maintaining MSIVs open could be given.









-

-

ļ

C

i

· · ·

den.


1.

.

C

-

ar




ŵ,

•

C





REVISION 7 (DA/02/92)

2.3 Event Tree (T3B-C): As for T3 A-C, function Q01 is 1.0 as above.

The other events may be analyzed as in the T2-C tree. However, in this case the function U3 = 1.0, and the value for ADS inhibit is the actual value calculated, not the ratio used previously, i.e., 0.036.

2.4 Event Tree (TIAC):

Model as for the T3 B-C event tree with U3 failed since feedwaver is lost.

2.5 Event Tree (T1-C):

Model as for failure of U3 branch in T2-C, with ADS inhibit value being 0.036.

2.6 IORV ATWS (T3C-C):

The pool temperature reaches 110°F in about 20 minutes (analysis file AS-11). This is the cue to scram the reactor, and if it does not scram, to initiate be on injection, and since all these conditions (power >4%, pool temperature above 110°F, and an SRV open) exist, the operators will begin to lower level. This is done in a controlled manner, although the level/power procedure instructs the operators to terminate and prevent all injection. Since this is a controlled level reduction, the chances of restoring feedwater (motor-driven) at TAy are much greater.

The level will have to be dropped to TAF, since an SRV is open, otherwise if it reclosed, level may be maintained above level 1. Therefore bypassing the MSIV closure signal is of concern. This is addressed in the power/level procedure. A screening value of 0.1 is considered adequate for maintaining SRVs open. This is event NSHICPEC5-2-4L1.

A screening value of 10⁻² is proposed for establishing injection with the MFF, event FWHICPEL-2-FDW-L, since the transition can be performed in an orderly manner.

With the feedwater available, the other HEPs are as in the MSIV closure ATWS case (they are all conditional probabilities, not time dominated HEPs).

With MSIVs open, RHR is still required since heat is going to the pool through the SORV. I war in, failure to initiate RHR and venting could be lower. Using the values suggested for ATWS will be conservative, but won't contribute much to CDF.

With failure to establish feedwater, inhibit ADS still has to be achieved in the same time scale. Therefore, the same value as for T2-C with failure in U_3 is used. However, this is fed into the model as a conditional probability for event ADHICPC5-1-ADS-I equal tc

P(failuze	to	inhibit)	1 (berrie) 1	 .036	~~~	3.6
P(failure	to	maintain	FW)	.01		

3.0 PNPP LOSS OF OFFSITE POWER SEQUENCES

The purpose of this section is to document the human reliability analysis for postulated loss of offsite power sequences at PNPP. Again, the HI events are discussed in the order in which they appear in the event trees. The events are as follows:

Event Tree T1

- Event C Contains RPHICPERC-1:Q-2 failure to manually scram the reactor. This is a skill-based action and is given an HEP of 10⁻⁴.
- Event U, Contains HPHICPEL-1 failure to initiate high pressure injection give auto-start failed. This is an instinctive type of annunciator response and is also covered by a step in the RPV- Level Control procedure. An HEP 1.25E-3 is used as a typical value.
- <u>Event U</u>₂ Contain: . CPEL-1 this is the same event as above but related to RCIC. It is included in the model with the <u>Same</u> identifier as above since the two actions are clearly correlated.

For both these actions there is a long time (24 mins from MAAP run 10_00_50) from Level 2 to TAF, the time within which the operators have to take note of th failure to initiate.

Contains RCHICPSE51-LDTRIP - failure to recover from RCIC High Temperature Leak Detection trip during LOOP event. This trip is actuated after a 30 minute time delay. The alarm condition is clearly annunciated in the main control room. A value of 0.05 is considered conservative. <u>Event W</u> - The functional fault tree contains the events CVHICPEPC-COM and CVHICPEPC-RHR-E, and the system fault tree for the suppression pool cooling function contains the HI basic event SCHICPSE12-5:3.

> In function W_s, the success criterion is that suppression pool cooling should be started before the pool temperature gets to 185° (RCIC limitation), which occurs in 2.8 hours. In this model the first two events are associated with the cognitive part of the response, i.e., the product of the two events is the probability of not recognizing the need to initiate RHR (DDD phase). The reason for including two events is discussed later under event Y. The SCHICPSER-5:3 event is associated with the line-up of RHR for suppression pool cooling.

> The failure probability in the DDD phase is estimated using the HCR/ORE approach. If a response time (T1/2) of 5 mins is assumed, since this is a type CP3 HI, with a value of 0.75 and an assumed 5 minutes required for lineup,

$$PC = 1 - \oint \left[\frac{\ln(151/5)}{.75} \right] - 1 - \oint (4.5) - 10^{-4}$$

For reasons explained later this is partitioned between the CV events in the following way

 $CVHICPEPC-COM = 10^{-3}$ $CVHICPEPC-RHR-E = 10^{-1}$

For suppression pool cooling only four manual actions (per train) that need to be performed in the control room (SOI-E12, p.9). Initiation of suppression pool cooling is an action that is performed relatively frequently and practiced in the simulator. In addition, there is ample time to correct for mistakes given that

initial line-up has not succeeded, and suppression pool temperature is a key parameter that is attended to. Therefore, an HEP of 10⁻⁴ is considered adequate for this function.

This is based on the following argument. An error of omission of 10^{-3} per item and an error of commission of 10^{-4} per item is obtained per item 3 of Table 20-7, and item 4 of Table 20-12 (corrected by a factor of 2.7 per EF, all numbers rounded to nearest whole number) giving a base HEP cf 5×10^{-3} per train. However, st ps 9+11 require checking flow through the pump and act as a potent recovery mechanism. A recovery factor of 0.1 per step is applied and this reduces the HEP to 5×10^{-5} . The value is conservatively taken as 1.0×10^{-4} .

Function X, Emergency Depressurization

Even though, in this scenario, the operators may be depressurizing slowly by following the HCTL, the more demanding scenario that RCIC fails, and the reactor has to be depressurized to allow low pressure injection, will be assumed.

The cues are based on RPV level and are different from these associated with function Ws. Therefore, even if failure in unction Ws is a result of operator inaction, this set of cues acts like a new set of stimuli and the event is treated as independent. This late into the accident, the time for boil-off is considerably longer than that available in the case of immediate loss of all injection. Therefore, the value used for transients with loss of high pressure injection is conservatively used in this case, and also for functions X22, and X23, which occur even later into the transient (see later). The value is conservatively taken as 1.00E-3.

Event V

Contains event LPHICPEL-1. This is the event representing failure to align low pressure injection given su cessful blowdown. The value of 1.25E-3 is used for event LPHICPEL-1. This is the same as used for HPHICPEL-1, even though this could be argued to be lower as it is a planned action, rather than a response to a sudden change in plant status.

Event V.

Function tree Val2 contains the HI event FPHICPPS4:2RCIC3, which represents failure to align fire water after HPCS fails due to high MCC temp. The time window to the failure is on the order of 10 hours. At this time, the boil-off time ought to be on the order of at least 3-4 hours per (MAAP 10_01_01).

According to a walkdown performed by the operations department, it takes about 75 mins to perform the line-up, thus this allows at least a couple of attempts to line up.

It 's judged that the execution probability will dominate the HEP, since the procedure clearly calls for alignment of RHR loop B containment flooding (PEI-SP1 section 4.2) if no more than one source of injection is lined up.

If it can be assumed that the operators would attempt to line up all the sources of LPI before lining up Firewater Alternate Injection, the time window could be much greater than 3-4 hours.

There about ten steps in the procedure, therefore conservatively assume a 0.1 value for a raw P_e . Since there is time for at least one more attempt to perform the alignment, we model the HI as $(.1)^2$ i.e., 0.01.

Also included in the function is event FPHICPPS4:2-DD-0, fai' re to maintain fuel oil for the diesel-driven fire pump. This is called out as step 9 in Section 4.3 of ONI-R10. Given that a loss of offsite power is obvious, the main failure mechanism will be missing the step in the procedure. Given that about 7.5 hours is available on 1/2 tank, the execution steps ought to be achievable. Assume a value of 3×10^{-2} since the procedure is somewhat long.

Function Tree Va07 contains the HI event FPHICPPS4:2RCIC1 - failure to align firewater given RCIC fails due to Emergency RPV Depressurization at the Heat Capacity Temperature Limit of 185°F. This failure occurs at about 3 hours, with a boil-off time 6f about 2 hours. We conservatively use an HEP = 0.3. However, this action is proceduralized and is emphasized in training which encourages the pre-lineup of an alternate injection system if no more than one injection system is available. On the other hand, the lineup is mimicked though not actually performed during simulator exercises. On balance, it is considered that this assessment may be somewhat conservative.

Function Tree Va04 contains the HI event FPHICPPS4:2RCIC2 - failure to align firewater given RHR fails due to MCC temp. This failure occurs at about 5 hours, with a boil-off time of about 2 hours. (See analysis file AS-10 under discussion for sequence B-U1). We conservatively use an HEP = 0.1, but take no credit for a second attempt as in the case of function Val2. Again, it is considered this assessment may be somewhat conservative.

Function Tree Val2 contains the HI event FPHICPPS4:2RCIC3 - failure to align firewater given HPCS fails due to MCC temperature. This failure is postulated at about 10 hours, with a boildown time of about 2.7 hours. Since the timewindow is extended from the beginning of the transient, an HEP of 0.01 is conservatively assumed.

Function Tree Va20 contains the HI event FPHICPPS4:2RCIC4 - failure to align fast fire protection alternate injection given a loss of all injection before the indicated minimum zero injection water level MZIWL is reached. The boildown time from Level 2 to the indicated MZIWL of 24 minutes will provide ample time for a fast connecting 3-valve lineup. Since the time is short an HEP of 0.1 is conservatively applied.

Function W - Containment Heat Removal with RHR

The functional fault tree has the same structure as for W_s discussed earlier. However, because of the longer time available, and the additional opportunities for recovery from an error in the DDD phase, afforded by a shift change, and input from the tech support center, the HEP in this phase is assessed to be lower than the 10⁻⁴ assessed for W_s . It is taken to be 10⁻⁵. This is accommodated by giving event CVHICPEPC-RHR the value of 10^{-2.}

In addition, the containment spray mode of RHR has an event SCHICPSE12-5:3. This represents failure to execute the action of initiation, which is essentially to arm and depress the manual pushbutton (p. 9 of SOI-E12). The HEP is conservatively assessed as 10⁻⁴, similar to RHR SP initiation. (Note this is manually much simpler, but the same HEP is used).

Function Y - Venting

The decision to vent is considered to be somewhat correlated with the decision to initiate KHR. This is a little conservative, since the cues are different, suppression pool cooling being cued off suppression pool temperature, and venting being cued off containment pressure. The HEPs are combined to give a total HEP of failure to initiate RHR and venting of 10⁻⁶. Failure to decide to vent is assessed to have a moderately higher HEP than the decision to initiate RHR because of its implications for potential offsite releases. Therefore the independent value is assumed to be 10⁻⁴. While the constraints that failure to initiate RHR is at 10⁻⁵, the constraint imposed not to give an HEP lower than 10⁻⁶ was met by creating the event CVHIPEPC-COM with a value of 10⁻³, and the event CVHIPEPC-RHR has a value of 10⁻², and CVHICPEPC-FPCC has a value of 10⁻¹.

The system fault tree for venting also contains two events which represent the lineup of venting paths. These are called for in the procedures when the pressure reaches 15 psig. The events are CVHICPPS7:3G41-T representing failure to align the FPCC for vent, and CVHICPPS7:4E12-T, failure to align for RHR containment venting


through the containment spray sparger.

The preparatory work for both paths is initiated when containment pressure is at 15 psig. Both involve opening a manual valve. For the FPCC lineup, in addition, a tank has to be drained (PEI-SPI, page 49). The time taken to achieve the lineup is on the order of 25 mins according to the operations staff. Since about 5 hours is available between 15 psig and the venting pressure (on the order of 35 psig) (MAAP run 05_01_01) there is ample time to do this. The containment spray initiation overrides are precautionary and failure to accomplish them would not defeat the venting function.

Venting through the FPCC is accomplished by opening two valves, (1G41-F145 and 1G41-F140). Since failure will not occur for some time after the initiation temperature and close attention will be paid to containment pressure, the HEP for execution is judged to be low and on the order of 10⁻⁴.

The procedure for implementing the RHR vent path involves closing two valves, opening a manual valve (1 for each train), and contains precautionary steps to inhibit containment spray, and therefore is somewhat more complex than implementing the FPCC path. Nevertheless, given the slowly developing accident, the HEP of 10⁻⁴ is again used.

The system fault tree for Function Y also contains event CVHICRPS7:3G41-T which represents failure of a recovery action to open the outboard valve manually, given it has failed to open remotely. This is assessed as having an HEP of 5x10⁻² on the basis of there being adequate time to identify the problem and carry out the recovery.



0

•

 \mathbb{R}^{2} 1

. 1


8 in


37

l

41

52.






0

C,

,

÷

d.



* *

4

4. V

44


1


6

 \mathbf{o}

1. 1







Event Tree R

The HIs are the same as in event tree T1.

Event Tree U

The HIs are the same as in event tree T ..

Event Trees T1P1, T1P1U, T1P2

The analysis file AS-09 does not differentiate between the success criteria for the HEP for these trees and the T1 tree.

4.0 PNPP STATION BLACKOUT SEQUENCES

The purpose of this section is to document the human reliability analysis for postulated station blackout scenarios at PNPP. The principal HI events are discussed as they occur in the scenarios.

Event Tree B

Lvent U1, High Pressure Core Spray

The event contains HI event HPHICPEL-1, representing failure to start HPCS given auto start fails on level 2. The time window is 28 minutes (given RCIC has also failed). This is an instinctive type of response, and the screening value of 1.25E-3 is used as in "he case of "use of offsite power sequences.

Event HI - Operator Actions Taken to Extend HPCS Operation

This is conservatively modeled as an OF gate of two HIS. The first is HIHI CPOR10-4:3-B which represents failure to cross tie unit 1 and unit 2 batteries and perform load shedding. The action is directed by ONI-R10 (section 4.3). The time window to perform the cross-tie is 2 hours. A caution warns against cross-tying batteries after two hours. There is ample time to enter the procedure, therefore the P parameter should be small- use 10⁻³.

The P_e parameter is a function of the complexity of the process for cross-tying the DC buses. A value of 10⁻² is conservatively assumed as a screening value. The action, per train involves closing two breakers only, and should be simple. However, a relatively high value was assumed to reflect uncertainty in h w much of the load shedding is effective and therefore how much margin for error there is. In fact, the shedding task has been enhanced by operator walkthrough and its effectiveness verified by engineering calculations.

The second event is MINICPOR10-4:3-D, which represents failure to open the Division 3 switchgear room doors. The time wild will be 10 hours, and the applicable procedure is ONI-R10. The action is a much simpler one (i.e., open a door), thus assume a total HEP of 2x10⁻³. This event should be considered for a sensitivity analysis. Given success in HI, HPCS is assumed to be operable for 24 hours.

Event W - FF1 WI5

Civen restoration of power to division 1 or 2 before 13 hours, (success in R), RHR has to be initiated before containment pressure reaches 50 psig (14.4 hours). The alignment time for the RHR system is estimated to be .8 hrs. Therefore, in this case, the time window measured from power recovery is 1.4 hours. This is long enough to assume a low P_c (~10⁻⁴) given that the accident has been in progress for sc long, and that concern for containment heat removal will be high.

Event Y - Function Y16

Since this is a long-term action, it is treated the same way as for the loss of offsite power or transient trees.

Function Y17

Event CVHICRPS7:3G41-T is a contributor to the top gate of this function. Since it relates to a valve called out explicitly in the vent procedure, and DC power is available to provide indication of position, and there is a long time to perform the recovery, a value of 0.05 is considered an appropriate HEP.

For sequences following failure of HPCS (U1), the analysis assumes failure of RCIC on depressurization as a result of high suppression pool temperature at 2.6 hours, with a 1.5 hour time window to initiate the diesel-driven fire pump before TAF is reached at 4.1 hours. Since the failure assumes depressurization there is no need to consider failure to depressurize, which would in any case prolong RCIC life.

For consistency with the evaluation of event Va in the T1 event tree, HI event FPHICPPS4:2RCIC1 will be assumed to have the same value, i.e., 0.3.

Other HEPs are the same as for success in HPCS.


Event Tree BP1

The major difference in timing in this event tree is that, on failure of HPCS, but success of RCIC, the fire water system is required in a somewhat shorter time, about 3.8 hours, because RCIC will fail on depressurization when the suppression pool temperature of 185°F is reached at 2.3 hours. The likelihood of success in Va is similar for this situation as in the B event tree since the timing is almost the same.


All other HEPs are the same as for the B tree.


Event free BP2

Use HEPs from B event tree.









Samo

•

*

ť.

0

52

1 - 1 - F

5.0 TRANSIENTS AND LOCAS

For most of the functions, the principal HIs are the same as for the loss of offsite power event tree. However, the analysis for event ADHICPEC2-ADS-T, the probability of failure to depressurize the reactor, is presented here.

It is assumed that, in accordance with the procedures, ADS is inhibited, and that it is necessary to initiate a blowdown.

The initial cue is RPV level reaching level 2, with HPCS and RCIC not operating. The final cue to initiate emergency blowdown is RPV level reaching TAF. There is some margin, as the level can drop to the MZIW level before core damage occurs. While the HCR/ORE methods could be used, the method is not particularly realistic for type CP2 actions with a long delay between the initial and secondary (or trigger) cue. Therefore, the decision tree approach will be used (see attached).

The action is a simple action, and there is ample indication to show whether it is being successful. Therefore, given that the correct decision has been made, the probability of incorrectly executing the blow α is considered negligible, and the HEP is given by 1 x 10⁻³.

WORKSHEET FOR CALCULATION OF PC

P & 4 1 1000	ADHECPEC 2-ADS-7			
Cueis	1: level at ievel 2 and day	neing for	id and	at TAF
Durat	ion of time window available for a	ction (Tw):		Seconds.
Approx	ximate start time for Tw:			
Proces	dure and step governing HI:			
A.,	Initial Estimate of Pc			
,	oc Failure Mechanism	Branch	HEP	Reduce Ty by
Pcā:	Availability of information	NA	neg.	#in
ocb:	Failure of attention	(6)	-00015 19454	N/A ein.
occ:	Misread/miscommunicate data	<u>(a)</u>	Aco	N/A min
ocd:	Information misleading	<u>(a)</u>	122	N/A min
ce:	Skip a step in procedure	<u>(a)</u>	.001	N/A sin
	Misinterpret instruction	La)	~~~)	N/A min
Def:				
Pcf: Pcg:	Misinterpret decision logic	(k)	nen	<u>N/A</u> sin

Total reduction in Ty = _____min.


Effective Ty = _____min.

nonsemble

Check here if recovery credit claimed on page 2:

54

WORKSHEET FOR CALCULATION OF DC RECOVERY FACTORS



C. Recovery Factors Applied to pe

Initial <u>HEP</u>	Recovery Factor	Multiply by:	Final Value	When Effective
	and the state of the	-		-
- 20075	level 1 alum	<u>• /</u>	· 00007j	aurentationites
		-		-
-		-	same same common	
.001	anna. An Anna an Anna			
			-	
		annan ann an Anna Anna Anna Anna Anna A	-	-
	and a second second second second	-	-	-
	<u>468</u>	<u>HEP</u> <u>Recovery Factor</u> - 1007 - 001	NEP Recovery Factor Dx1 -SOO 7 5 leadl / alarm -1 -SOO 1	HEP Recovery Factor Dri Yalue -30073 -30073 -1 -000073 -3007 -1 -000073

Sum or issurered pea through pen . Recovered pe 100/

Could apply reverseny for STA, but for

invenation de a.

Time at which all recovery factors effective

Given the minor differences in timing for TP1 and TP2 (reference MAAP runs 10_00_50, 10_00_51, 10_00_53) this value is equally good for all trees.

6.0 CTHER HI EVENTS

There are several other events included in the fault tree models, which represents failure of the operator to recover from specific failures. These human actions are generally governed by system operating procedures, or special plant instructions. Since they often appear in the fault tree models in an AND gate with hardware failures, they are generally not important contributors. Rather than perform a detailed analysis, the HFPs were assigned screening values judgmentally using the following guidelines. In addition, an attempt was made to characterize the relative likelihoods of the event failures by considering the scenario specific influences.

- 1. If an action is called out in an SPI or an SOI that is called for by the EOPs, then if the response time is limited with respect tot he time taken to perform th required action an HEP of 0.1 is assumed. A higher value is used when the available time constraints are very tight.
- 2. If as above, but not time limited, then allow for recovery by assessing HEPs in the range 0.1 to 10⁻³, particularly if these are alternate cues to lead to the required action, or if there are annunciators that direct attention.
- 3. If the actions are not called out specifically via the EOPs, a lower value than 0.1 is definitely not used.
- For well practiced actions or those which are memorized responses, an HEP of 10⁻³ may be assumed.

F.1 OTHER TYPE CP HI:

Theses events are discussed in turn below:

ADHICPEC2-AD-LR

Failure to recover from RPV depressurization (when core damage has occurred) in a plant damage state tree when depressurization has not yet been asked. The value of 0.0001 is considered appropriate since this is equal to the HEP for failure to Emergency RPV Depressurize during a Transient times a recovery factor of 0.1.

C'AHICP1008-4:2

Failure to shift condenser air removal to vacuum pump and Auxiliar, Boiler. This is routinely done as part of any shutdown in a controlled manner and is regarded as skill of the craft. It is also guided by the Integrated Operating Instruction. Therefore, the ' is considered to be low and estimated as 10

CCHICPSP47-5:4 Failure to realign CCCW loop in 4.5 hours. The are many indications of loss of a CCCW pun; train, and a long time to recover. Therefore, the HEP is considered to be low and estimated as 10⁻³.

CDHICPPS2:1-XH1X Failure to bypass the RHR LOCA signal and recetablish power to stub buses XH11 and/or XH12. This is required to restore instrument air and nuclear closed cooling. This is a practiced response to a LOCA signal and the HEP is 10⁻¹.

CTHICPPS4:4-ALT Failure to align condensate transfer as an alternate injection system. This is essentially a simple task (PEI-SPI, section 4.4) directed by the EOPs. It does involve one ex-control room action at the RHR Flush Water Control panel (1H51-P275) on the 620' elevation of the Aux. Building, and a verification step on the 599' elevation at the RHR pump room. Because these might cause delays of several minutes, even though there are more than 20 minutes to complete the action, following the indication of no injection at Level 2, relative'_ little credit is taken for this action in the shortterm and an HEP of 10⁻¹ is assumed.

CTHICPPS4:4-ALT6 Failure to align condensate transfer in 6 hours, following success in HPCS. Since the available time is now long, the boildown time is greater than 1 hour, and the action is proceduralized in the PEI-SPI, the value of 10⁻³ is assumed.

CTHICPPS4:4-ALTC This event is as above, but for the IORV transient. Since the boil-off time to TAF is shorter (~15 vs 20 min), the HEP is correspondingly higher and is assumed to be $3x10^{-1}$.

DGHICP0011-2:5 Failure to initiate diesel generators. Attempting to start a system which should have started but didn't is an instinctive, learned response and in uniformally given a value of 1.25E-3. (see also HPHICPEC-1).

ECHICPSP42-4:2 Failure to close Emergency Closed Cooling to Control Complex Chiller A/B Bypass Valve following failure of the bypass valve to close during auto start. ECC is required for the RHR Room Cooler support of low pressure pump operation. The time window is considered to be several hours. A screening value of 0.05 is assumed.

ECHICPSP42-4PMP Failure to initiate Emergency Closed Cooling pump following auto start failure. It is considered that this failure to start would be identified with the normal control room verification of automatic actions. A value of 0.05 is considered conservative.

ERHICPPS4:2-ESW Failure to establish ESW into the RPV for containment flooding per PEI-SPI, section 4.2. Although there may be a relatively long time available, the valve line-up is difficult so little credit is taken, and an HEP of 10⁻¹ is assumed.

FPHICPPS4:2FP-LE Failure to align the injection path for FPHICPPS4:2FP-IL alternate injection, (given core damage has occurred), in accordance with PEI-SPI, section 4.2, in two time frames, less then 3 hours, and greater then 3 hours. The HEPs are given gradually lower values with increasing time frame of 5E-2 and 5E-3, respectively.

FWHICPSN27-4:11A Failure to control feedwater and condensate during a loss of instrument air. This is a skill of the craft action, not explicitly addres od in the procedures. An HEP of 10⁻¹ is assumed.

FWHICPSN27-4:11? As for FWHICPSN27-4:11A, failure to control reactor feed pump following a loss of instrument air, but later in the sequence. Since boil-off time is much larger, a lower HEP of 5x10⁻³ is used.

HIHICPOR10-4:0-I Failure to close Fuel Pool Cooling & Cleanup Outboard Isolation valve 1G4:0F145, Containment Fools Return Outboard Isolation before RPV Failure during a Station blackout event. RPV failure occurs at about 1.8 hours with loss of all injection. The symptomatic Off-Normal Instruction ONI-R10, Loss of All AC, directs that this isolation by manually closed within 1.5 hours, and monitors the completion of this task within the defined time window with Attachment 6, Steps That Have Time Requirements. The HEP of 0.05 is considered conservative for the timewindow and the enhance ONI.

HIHICPOR10-XTIE

Failure to cross-tie division 3 to the division 2 MCC. The power transfer task with hardwired switchgear would open the closed inboard containment isolation to enhance containment venting reliability. Since the time to pressurize containment is on the order of 12 hours, a value and 105 is conservatively applied.

HPHICPSE22-5:0 HPHICPSE22-5:2

Failure to control HPCS min flow valve, given failure to auto control, and failure to transfer to suppression pool given failure to auto switchover. They are called out via verification steps in the system operating instruction and well practiced. Therefore an HEP of 5x10⁻² is used for both.

IAMICPSP51-4:2 Failure to reposition NCC lube oil cooler outlet valve when an instrument air compressor auto starts. This is a well practiced task. A screening HEP of 5x10⁻² is assumed.

IGHICLEH-1-H2IC Operator fails to initiate Hydrogen Ignition System is modeled in the Level 2 Accident Progression Event Tree. The most limiting time window for hydrogen generation to commence is for a loss of all injection accident where the maximum core clad temperature reaches 2200°F after 51 minutes. The crew is trained to routinely monitor and control hydrogen during an accident in the Plant Emergency Instruction flowchart by placing the hydrogen analyzers on the third step of entering RPV Control. During a loss of all injection the reactor water level decreases below I1 (<16.5 inches above the TAF) at about 29 minutes. The RPV water level decrease below L1 is the entry condition to Hydrogen Control. The Unit Supervisor will typically direct action from the Hydrogen Control flow chart that the Hydrogen Ignitors be place on about 1 minute after entering the flow chart. The execution time to initiate this system at a nearby back panel is relatively short requiring about 30 seconds. Thus, the value of 0.005 is considered conservative.

LCHICPSE12-5:1 LPHICPSE21-5:1 Failure to control RHR and LPCS min flow values, given failure to auto control. They are called out in verification steps in the respective system operating instruction and well practiced. Therefore, an HEP of 5x10⁻² is used for both.

RCHICPSE51-5:1 RCHICPEL-2-CST-S Failure to control ACIC min flow valve, given failure to auto control; and failure to transfer to the suppression pool when the CST become depleted. They are called out via verification steps in the system operating instruction and plant emergency instruction flow chart, and well practiced. Therefore an HEP of 5x10⁻² is used for both.

SIHICPSP57-7:1

Failure to connect air cylinders to safety related air system which backs up loss normal system pressure. Since the safety related air receiver tanks are large, it is considered that the need to replenish the air would be several hours after the start of the initiator. Safety Related Air is indicated and alarmed in the main control room. A value of 0.05 is conservatively assigned.

SLHICPEQ-6-RPVLV Failure during ATWS to control RPV level and maintain boron inventory given failure to ADS Inhibit. During a full power ATWS with failure of ADS Inhibit, studies like EPRI : P-5562, Analysis of Anticipated Transients Without Scram in Severe BWR Accidents (1987) have shown that extended periods of time are available for operator recovery action prior to postulated severe core degradation or containment failure. In the case of ADS Inhibit failure with auto low pressure LPCS injection, a Peach Bottom type reactor was determined to self-regulate the reactor power by maintaining RPV pressure slightly above the LPCS pump shutoff head and reactor power was maintained at a guasi-static power level of 2.5% of rated for several hours. Furthermore, no excessive fuel pellet cladding temperatures are predicted at any time during the accident. Since it is more likely that ADS Inhibit failure will occur during a full power ATWS due to the smaller time window, it is also more likely that SLC recovery will overfill the RPV with water injection due to the selfregulating ATWS characteristic. Therefore, an HEP of 0.05 is conservatively applied to define the probability that RPV level will be maintained and boron will not be flushed out the SRVs.

SPHICPPS4:5SPCU SPHICPPS4:5SPCUL Failure to align suppression pool clean up system for alternate injection. Although addressed in PEI-SPI, section 4.5, no credit is taken in the pre-core da ige phase (-SPCU). However, limited credit (5.E-2) is taken in the plant damage state trees for late injection (SPCUL).

TBHICPSM35

Failure to start the back-up fan in the turbine building. Failure of a fan is alarmed in the control room, and immediate action is not required, therefore this is not a time critical action and an intermediate HEP of 5x10⁻² is assumed.

6.2 OTHER TYPE CR HIS

In addition, any HIS that relate to recovery in the post core-damage phrise are estimated on the basis of multiplying the HEP evaluated for the phase up to core damage by a factor of 0.1. This is somewhat arbitrary, but given that the procedures are being followed, then there is some chance that the extra time available will allow success. The following events fall into this category:

ADHICREC2-ADS-R

Operator fails to recovery recover from RPV emergency depressurization core damage before RPV failure.

IAHICRSP52-7:2 Operator fails to override isolation signal to reestablish instrument air following a LOCA signal. Again, this is a practiced response to the LOCA signal and an HEP of 0.1 is assumed.

SLCHICREQ-6-SLCR Operator fails to initiate SLC given core damage failure before containment pressure threshold limit.

ATTACHMENT A HEP ERROR FACTOR BASIS

The EPRI methods used in this analysis do not address uncertainty. Consequently, the somewhat arbitrary approach of assigning error factors on the basis of the point estimate was adopted as shown below:

0.14	¢	HEP<1.0	EF	-	1.2
		HEP~0.1	EF	-	1.5
10'2	<	HEP < 10'1	EF	-	3
10-3	<	$HEP < 10^{-2}$	EF	-	5
10-3	<	HEP	EF		10

ATTACHMENT B HEPS FOR FLOODING ANALYSIS

FLOODING TYPE CP HI MULTIPLIER FACTORS

Internal Flooding has the initiators of PCS Loss, IA Loss, SW Loss, and transient with PCS. Therefore, the HI associated with the following initiators are not included: LOCA, ATWS, LOOP and SBO.

Multiplier Factors for the HI basic event where determined as noted below during a meeting with Wallace Colvin, John Spano, Bengt Lydell, and Eric Jorgensen on 18 December 1991. The basis for assignment is provided on the following page.

> FLOODING MULTIPLIER

HI BASIC EVENT HI DESCRIPTION

1 FAILS TO EMERG RPV DEPRESS - TPANSIENT ADHICPEC2-ADS T OPERS FAIL TO SHIFT CONDENSER AIR REMOVAL TO VP & AB 2 CAHICPIOO8-4:2 2 OPER FAILS TO REALIGN CCCW LOOP C BEFORE 4.5 HOURS CCHICPSP47 5:4 1 CDHICPPS2: 1-XH1X OPER FAILS TO BYPASS RHR LOCA SIGNAL-XH1X 1 OPER FAILS TO INITIATE CNTMT SPRAY CSHICPET-2:P-1 ŧ. CTHICPPS4:4 ALT OPERS FAIL TO ALIGN CONDENSATE TRANSFER CTHICPPS4:4 ALT6 OPERS FAIL TO ALIGN CONDENSATE TRANSFER - AT 6 HOURS F OPER FAILS TO INITIATE CNTMT PRESS CNTL AND VENT 1 CVHICPEPC-COM OPER FAILS TO INITIATE CNTMT PRESS CNTL VENTING CVHICPEPC-FPCC OPER FAILS TO INITIATE CNTMT PRESS CNTL RHR CVHICPEPC-RHR CVHICPEPC-RHR-E OPER FAILS TO INITIATE RHR SPC EARLY CVHICPPS7: 3E12-T OPER FAILS TO ALIGN RHR FOR CNTMT VENT 1 CVHICPPS7:3G41-T CPER FAILS TO ALIGN FPCC FOR CNTMT VENT 1 OPERFAILS TO CLOSE VALVE OP42-F0150A(B) ECHICPSP42-4:2 FPHICPPS4:2RCIC1 FAIL TO ALIGN FP AFTER RCIC FAILS DUE TO SP TEMP FPHICPPS4:2RCIC4 FAIL TO ALIGN FAST FIRE PROTECTION ALT INJECTION ECHICPSP42-4PMP OPER FAILS TO INITIATE PUMP 1P42-COOIA(B) 1 FWHICPSN27-4:1IA OPER FAILS TO CNTRL RX FEED BOOSTER PUMP DURING IA LOSS 2 HIHICPAH13870AB1 FAIL TO SECURE SW/ESW DURING 8-10 MIN FOR AB FLOOD NA HIHICPAH13870AB2 FAIL TO SECURE SW/ESW DURING 10-15 MIN FOR AB FLOOD NA HIHICPAH13870AB3 FAIL TO SECURE SW/ESW DURING 15-40 MIN FOR AB FLOOD NA HIHICPAH13870AB4 FAIL TO SECURE SW/ESW/CNDS XFR AFTER 40 MIN FOR AB FLD NA HIHICPAH13870TB1 FAIL TO SECURE CIRC WATER/SW BY 14 MIN FOR TE FLOOD NA HIHICPAH13870TB2 FAIL TO SECURE SW AFTER 30 MIN FOR TE FLOOD NA NA DURING 8-10 MIN FOR CC FLOOD HIHICPAH13970CC1 FAIL TO SECURE SW/ESW NA DURING 10-12 MIN FOR CC FLOOD HIHICPAH1397OCC5 FAIL TO SECURE SW/ESW DURING 10-15 MIN FOR CC FLOOD NA HIHICPAH13970CC2 FAIL TO SECURE SW/ESW HIHICPAH13970CC3 FAIL TO SECURE SW/ESW DURING 15-40 MIN FOR CC FLOOD HIHICPAH13970CC4 FAIL TO SECURE SW/ESW AFTER 40 MIN DURING CC FLOOD NA OPER FAILS TO INITIATE HIGH PRESSURE INJECTION HPHICPEL-1 OPER FAILS TO CONTROL MIN FLOW VALVE 1E22-F012 HPHICPSE22-5:0 OPER FAILS TO XFR TO SUPR POOL WITH 1E22-F015 HPHICPSE22-5:2 2 OPER FAILS TO REPOSITION NCC LUBE OIL CLR OUTLET VLV IAHICPSP51-4:2 OPER FAILS TO CONTROL MIN FLOW VALVE 1E12-F064A LCHICPSE12-5:1 1 OPER FAILS TO INITIATE LOW PRESSUR! ECCS LPHICPEL-1 OPER FAILS TO CONTROL MIN FLOW VALVE 1E21-F011 LPCPSE21-5:1

FLOODING MULTIPLIER

HI BASIC EVENT HI DESCRIPTION

RCHICPEL-2 CST S RCHICPS51-LDTRTP	OPER FAILS TO	PREVENT RCIC SUCTION SHIFT TO SP RECOVERY FROM RCIC HIGH TEMP LD TRIP	, 5F
RCHICPSE51-5:1	OPER FAILS TO	PERFORM RCIC SUCTION SHIFT	1
RPHICPERC-1:0-2	OPER FAILS TO	MANUALLY SCRAM REACTOR	1
SCHICPSE12-5:3		ALIGN RHR SUPR POOL COOLING	. 1
SIHICPSP57-7:1	OPER FAILS TO	CONNECT AIR CYLINDERS	1.1.1.
	OPERS FAIL TO	ALIGN SUPR POOL C/U ALT INJECTION LATE	2
TBHICPSM35	OPER FAILS IN) START STANDBY FAN	

BASIS FOR MULTIPLIER FACTOR ASSIGNMENT

Multiplier Factors are applied to the HIs used in the initial IPE study of internal plant initiator to model the increased failure probability when performing flooding tasks to mitigate a plant transient. Increase human interaction error is due to: 1) increased stress as a result of the control room response to a low frequency event that challenges reactor safety, 2) increased stress as a result of mitigating a flooding event with less available operations staff to perform routine recovery task - due to need to man power to attend to the initiating flooding event, and/or 3) increased stress due to a high alarm and information processing during the unique flooding accident progression.

- MULTIPLIER FACTOR = 1 No quantitative increase to the normal human interaction model of operator response. The basis is that these actions are the same or nearly the same as those previously modeled for non-flooding events. No significant impact of any flooding initiator was identified which would degrade the control room response or the local manual action.
- 2. MULTIPLIER FACTOR = 2 The normal human interaction model of operator response is increased by a factor of two. The basis is that these actions may be impacted by unique man power demands to mitigate the flooding event or by the increased stress associated with the response to a challenging low frequency event. This multiplier factor of 2 is considered to conservatively bound the human interactions identified as listed below. These human interaction events are not performed in critical time windows and thus a low, yet conservative factor of 2 is postulated.


CAHICPIOO8-4:2 OPERS FAIL TO SHIFT CONDENSER AIR REMOVAL TO VP & AB CCHICPSP47 5:4 OPER FAILS TO REALIGN CCCW LOOP C BEFORE 4.5 HOURS FWHICPSN27-4:11A OPER FAILS TO CNTEL RX FEED BOOSTER PUMP DURING JA LOSS IAHICPSP51-4:2 OPER FAILS TO REPOSITION NCC LUBE OIL CLR OUTLET VLV TBHICPSM35 OPER FAILS TO START STANDBY FAN 3. MULTIPLIER - .5F The normal human interaction model of operator response is conserv cively set to a high screening value of 0.50 to account for the potential for this alarm to be masked by the high frequency of alarm/information processing during the the first half hour of a low frequency flooding accident.

RCHICPS51-LDTRIP OPER FAILS TO RECOVERY FROM RCIC HIGH TEMP LD TRIP

4. MULTIPLIER = F The normal human interaction model of operator response is conservatively set to the failed state to conservatively model: the demand for plant operators to attend to the flooding event results in the immediate unavailability of personnel during the critical initial transient time window, or the potentially hazardous environment associated with the task of walking through a flooded hallway. A Multiplier Factor "F" will be calculated on a case by case basis which results in a system failure probability of between .99 and 1.00. The events classified into this type are the following.

CTHICPPS4:4 ALT OPERS FAIL TO ALIG. CONDENSATE TRANSFER CTHICPPS4:4 ALT6 L/ERS FAIL TO ALIGN CONDENSATE TRANSFER - AT 6 HOURS

 MULTIPLIER = NA Not applicable, no multiplier factor is required with those human interaction which are used only for flooding.



1. LEVEL 1 AND PLANT DAMAGE STATE TYPE CP HIS

HI ID	HI DESCRIPTION	HEP	FACTOR
ADHICPC5-1-ADS-A	OPER FAILS TO INHIBIT ADS - ATWS WITH FEEDWATER	3.80E-3	5
ADHICPC5-1-ADS-I	OPER FAILS TO INHIBIT ADS - ATWS WITH IORV & WITH FDW	3.6	-
ADHICPC5-1-ADS-L	OPER FAILS TO INHIBIT ADS - ATWS WITH LOOP	3.60E-2	3
ADHICPCS-1-ADS-0	OPER FAILS TO INHIBIT ADS - ATWS WITH NO FEEDWATER	7.2	100 million (1990)
ADHICPEC2-ADS-T	FAILS TO EMERG RPV DEPRESS - TRANSIENT	1.00E-3	5
ADHICPEC5-ADS-FL	FAILS TO EMERG RPV LEPRESS - AIWS, FDW & LEVEL CONTROL	7.00E-3	5
ADHICPECS-ADS-FX	FAILS TO EMERG RPV DEPRESS - ATWS, FDW & NO LEVEL CNTL	1.40E-2	3
CAHICPIOO8-4:2	OPERS FAIL TO SHIFT CONDENSER AIR REMOVAL TO VF & AB	1.00E-3	5
CCHICPSP47-5:4	APPR PATTC TO PEALTCH CCCU LOSD C REFORE & 5 HOU'S	1.00E-3	5
CDHICPPS2:1-XH1X	OPER FAILS TO REALIGN COCK LOOF C DEFORE 413 BOORD OPER FAILS TO BYPASS RER LOCA SIGNAL-XHIX OPER FAILS TO INITIATE CNTMT SPRAY OPERS FAIL TO ALIGN CONDENSATE TRANSFER	1.002-3	5
CSHICPET-2:P-1	OPER FAILS TO INITIATE COTMT SPRAY	1.70E-2	3
CTHICPPS4:4-ALT	OPERS FATL TO ALTEN CONDENSATE TRANSFER	1.00E-1	1.5
CTHICPPS4:4-ALT6	OPERS FAIL TO ALIGN CONDENSATE TRANSFER - AT 6 HOURS	1.00E-3	5
CTHICPPS4:4-ALTC	OPERS FATL TO ALICN CONDENSATE TRANSFER - IN T3C	3.00E-1	hel
CVHICPEPC-COM	OPEP ZATIS TO INITIATE CNTMT PRESS CNTL AND VENT	1.00E-3	5
CVHICPEPC-FPCC	ODED PATTE TO INTETATE COPPAT DECC CNTI VENTING	$1.00E_{-1}$	1.5
CVHICPEPC-RHR			
CVHICPEPC-RHR-E	OPER FAILS TO INVITATE CNIMI PRESS CNIL RHR OPER FAILS TO INITIATE RHR SPC EARLY OPER FAILS TO ALIGN RHR FOR CNIMI VENT OPER FAILS TO ALIGN FPCC FOR CNIMI VENT OPER FAILS TO INITIATE DIV 1 D/G OPER FAILS TO CLOSE VALVE OP42-F0150A(B) OPER FAILS TO INITIATE PUMP 1P42-CO01A(B) OPERS FAIL TO ALIGN 2 VLVS FOR RPV INJECTION	1.008-1	1.5
CVHICPPS7: 3E12-T	OPER FAILS TO ALIGN RHR FOR CNIMI VENI	1.00E-4	10
CVHICPPS7:3G41-T	OPER FAILS TO ALIGN FPCC FOR CNIMI VENT	1.00E-4	10
DGHICPOS11-2:5	OPER FAILS TO INITIATE DIV 1 D/G	1.258-3	5
ECHICPSP42-4:2	OPER FAILS TO CLOSE VALVE OP42-F0150A(B)	5.00E-2	3
ECHICPSP42-4PMP	OPER FAILS TO INITIATE PUMP 1P42-COOIA(B)	5.00E-2	. 3
ER" PPS4:2-ESW	OPERS FAIL TO ALIGN 2 VLVS FOR RPV INJECTION	1.00E-2	3
FPH'CPPS4:2-DD-0	UNKER FAIL IN MAINIAIN UIP LOU DIPOPP DUIADU LIND LOUR	3 - 10 10 kg - km	
FPHICPPS4:2RCIC1	FATL TO ALIGN FP AFTER RCIC FAILS DUE TO SP TEMP	3.00E-1	1.2
FPHICPPS4:2RCIC2	FAIL TO ALICN FP AFTER RHR FAILS DUE TO MCC TEMP	1.00E-1	1.5
FPHICPPS4:2RCIC3	FAIL TO ALIGN HPCS AFTER HPCS FAILS DUE TO MCC TEMP	1.00E-2	3
FPHICPPS4:2RCIC4	FAIL TO ALIGN FAST FIRE PROTECTION ALT INJECTION	1.00E-1	1.5
FWHICPEC5-2:3LCS	OPER FAILS TO CONTROL LVL AT TAF WITH FDW DURING IORV	1.00E-2	- 3
FWHICPEC5-3:2	FAILS TO CNTRL RPV LVL AT TAF	1.00E-2	3
FWHICPEL-2-FDW-L	OPER FAILS TO REOPEN MEP CONTROL VALVES FOR T3C-C	1.00E-2	3
FWHICPEL-2-FDW-V	OPER FAILS TO PROPEN MEP CONTROL VALVES	5.00E-3	1.2
FWHIC: SN27-4:1IA	OPER FAILS TO CNTRL RX FEED BOOSTER PMP DURING IA LOSS	1.20E-1	1.5

FRROR

FWEICPSN27-4:1IL HIHICPEC5-3:2-F HIHICPEC5-3:2-S HIHICPEC5-3:2-S HIHICPEC5-5-CRIT HIRICPORIO-4:3-B HIHICPORIO-4:3-D HIRICPORIO-XTIE HPHICPEL-1 HPHICPEL-1 HPHICPSE22-5:0 HPHICPSE22-5:2 IAHICPSE22-5:1 LPHICPSE12-5:1 LPHICPEL-1 LPHICPEL-1 LPHICPEC5-2-LIT3 RCHICPEC5-2-LIT3 RCHICPEC5-2-LIT3 RCHICPEC5-2-LIT3 RCHICPS51-LDTRIP RCHICPSE51-5:1 RPHICPERC-1:0-2 SCHICPSE12-5:3 SIHICPSP57-7:1 SLHICPE0-6-SLC1 SLHICPE0-6-SLC1 SPHICPPS4:5SPCU TBHICPSM35	OPER FAILS TO CNTRL RFBP DURING IA LOSS > 2 HR FAILS TO RESTR RHR A/B CR LPCS & CNTL AT TAF - W/FDW FAILS TO RESTR RHR A/B OR LPCS & CNTL AT TAF - W/G FDW OPER FAILS TO CNTRL RPV LVL & FLUSHES BORON OPERS FAIL TO X-TIE UNIT 1 & 2 BATTERIES AND LOAD SHED OPER FAILS TO OPEN DIV 3 SWITCHGEAR ROOM DOOR OPER FAILS TO X-TIE DIV 3 AND 2 MCCS OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F012 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F012 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F015 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F015 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F016 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F017 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F016 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F017 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F016 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F016 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F017 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F016 OPER FAILS TO CONTROL MIN FLOW VALVE 1522-F016 OPER FAILS TO PREVENT NCC LUBE OIL CLR OUTLET VLV OPER FAILS TO PREVENT RECOVER FROM REACTOR OPER FAILS TO PREVENT RCIC SUCTION SHIFT TO SP OPER FAILS TO BYP MSIV LVL 1 ISOL FOR T3C-A OR T3B-C OPER FAILS TO PREVENT RCIC SUCTION SHIFT TO SP OPER FAILS TO PREVENT RCIC SUCTION SHIFT OPEN FAILS TO PREVENT RCIC SUCTION SHIFT OPER FAILS TO PREVENT RCIC SUCTION SHIFT OPER FAILS TO ALIGN RHR SUPR PUOL COLING OPER FAILS TO ALIGN RHR SUPR PUOL COLING OPER FAILS TO INITIATE SLC - 1 PUMP INJECTION OPER FAILS TO INITIATE SLC - 1 PUMP INJECTION OPER FAILS TO INITIATE SLC - LEVEL CONTROL FAILURE OPER FAILS TO INITIATE SLC - LEVEL CONTROL FAILURE OPER FAILS TO ALIGN SUPR POOL C/U ALT INJECTION OPER FAILS TO START STANDEY FAN	5.00E-3 1.00E-3 1.00E-3 2.00E-3 1.00E-2 2.00E-3 3.0CZ-3 1.2SE-3 5.00E-2 5.00E-2 5.00E-2 1.00E-1 1.00E-1 1.00E-1 1.00E-2 5.00E-2 5.00E-2 5.00E-2 5.00E-2 5.00E-2 5.00E-2 1.00E-4 1.09E-4 5.00E-2 1.2SE-3 1.00E+0 1.00E+0 5.00E-2	5555333533531.33300135 - 12
--	--	--	-----------------------------

HI ID	HI DESCRIPTION	MULTIPLIER OR HEP
ADDITODDOG ADD T	FAILS TO EMFRG RPV DEPRESS - TRANSIENT	1x
AUHICPEUZ-ADS-1	OPERS FAIL TO SHIFT CONDENSER AIR REMOVAL TO VP & AB	
CCHICPSP4/-J:4	OPER FAILS TO RUDACS PHR LOCA SIGNAL XHIX	X
CDEICPPSZ:1-Anix	OPER FAILS TO REALIGN CCCW LOOP C BEFORE 4.5 HOURS OPER FAILS TO BYPASS RHR LOCA SIGNAL-XHIX OPER FAILS TO INITIATE CNTMT SPRAY OPERS FAIL TO ALIGN CONDENSATE TRANSFER OPERS FAIL TO ALIGN CONDENSATE TRANSFER - AT 6 HOURS	1x
CSHICPE1-ZIP-1	OPER FAILS TO ALTON CONDENSATE TRANSFER	1.00E+0
CIHICPPS4:4-6-1	OPERS FAIL TO ALIGN CONDENSATE TRANSFER - AT 6 HOURS	1.00E+0
	OPER FAILS TO INITIATE CNTMT PRESS CNTL AND VENT	1x
CVHICPEPC-COM CVHICPEPC-FPCC	ODDD CATLO TO THITTATE ONTAT DDP'S CATL VENTINE.	1 X
CVHICPERC-FFCC	OPER FAILS TO INITIATE CNTHT PRESS CNTL RHR	1x
CVHICPEPC-RBR	OPER FAILS TO INITIATE CNTHI PRESS CNTL PHENO OPER FAILS TO INITIATE CNTHI PRESS CNTL RHR OPER FAILS TO INITIATE RHR ST. JARLY OPER FAILS TO ALIGN FPCC FOR EMT VENT	lx
CURICIPECT-ABA-E	OPER FAILS TO ALTCN FPCC FOR THT VENT	1x
CVELCTEST: 3641-1	OPER FAILS TO ALICN RHR FOR CNIMI VENT	1x
CVHICPED(2, 4, 2	OPER FAILS TO ALIGN FPCC FOR THE VENT OPER FAILS TO ALIGN RHR FOR CNIMI VENT OPER FAILS TO CLOSE VALVE OP42-F0150 OPER FAILS TO INITIATE PUMP 1F42-C001 FAIL TO ALIGN FP AFTER RCIC FAILS DUE TO SF TEMP	1x
ECHICPSP42-4:2	OPER FAILS TO INITIATE PUMP 1P42-COO1	1x
EURIGEDEC. (DCTC)	FATL TO ALICN FP AFTER RCIC FAILS DUE TO SP TEMP	1x
FPHICPPS4:2RCIC4	FAIL TO ALIGN FAST FIRE PROTECTION ALT INJECTION	2x.
FWHICPSN27-4:1IA	OPER FAILS TO CNTRL RX FEED BOOSTER PUMP DURING IA LOSS	2x.
HPHICPEL-1	OPER FAILS TO INITIATE HIGH PRESSURE INJECTION	1x 1x
HPHICPSE22-5:0	OPER FAILS TO INITIATE HIGH PRESSURE INJECTION OPER FAILS TO CONTROL MIN FLOW VALVE 1E22-F012	1x
HPHICPSE22-5:2	OPER FAILS TO XFR TO SUPR POOL WITH 1E22-F015	1x
IAHICPSP51-4:2	OPER FAILS TO REPOSITION NCC LUBE OIL CLR OUTLET VLV	2::
LCHICPSE12-5:1	OPER FAILS TO CONTROL MIN FLOW VALVE 1E12-F064A	lx
LPHICPEL-1	OPER FAILS TO INITIATE LOW PRESSURE ECCS	1x
LPCPSE21-5:1		1x
RCHICPEL-2-CST-S	OPER FAILS TO PREVENT RCIC SUCTION SHIFT TO SP	1x
RCHICPS51-LDTRIP	OPER FAILS TO RECOVERY FROM RCIC HIGH TEMP LD TRIP	5.00E-1
RCHICPSE51-5:1	OPER FAILS TO PERFOR' RCIC SUCTION SHIFT	1x
RPHICPERC-1:0-2	OPER FAILS TO MANUALLY SCRAM REACTOR	1x
SAHICPSP51-4:2	OPER FAILS TO REPOSIT NCC LO CLR OUTLET	2×
SCHICPSE12-5:3	OPER FAILS TO ALIGN RER SUPR POPT. COOLING	1x
SIHICPSP57-7:1	OPER FAILS TO CONNECT AIR CYLINELAS	1x
SPHICPPS4:5SPCUL	OPERS FAIL TO ALIGN SUPR POOL C/U ALT INJECTION LATE	1x
TBHICPSM35		2x

2. FLOODING MULTIPLIER FACTORS AND ADJUSTED BEPS TYPE CP HIS

3. FLOODING ONLY TYPE CF BIS

HI ID	HI DESCRIPTION	HEP	FACTOR
HIHICPAH13870AB1 HIHICPAH13870AB2 HIHICPAH13870AB2 HIHICPAH13870AB3 UIHICPAH13870AB4 HIHICPAH13870TB1 HIHICPAH13870TB2 HIHICPAH13970CC1 HIHICPAH13970CC2 HIHICPAH13970CC3 HIHICPAH13970CC3	FAIL TO SECURE SW/ESW DURING 8-10 MIN FOR AB FLOOD FAIL TO SECURE SW/ESW DURING 10-15 MIN FOR AB FLOOD FAIL TO SECURE SW/ESW DURING 15-40 MIN FOR AB FLOOD FAIL TO SECURE SW/ESW/CNDS XFR AFTER 40 MIN FOR AB FLD FAIL TO SECURE CIRC WATER/SW BY 14 MIN FOR TB FLOOD FAIL TO SECURE SW AFTER 30 MIN FOR TB FLOOD FAIL TO SECURE SW/ESW DURING 8-10 MIN FOR CC FLOOD FAIL TO SECURE SW/ESW DURING 8-10 MIN FOR CC FLOOD FAIL TO SECURE SW/ESW DURING 10-12 MIN FOR CC FLOOD FAIL TO SECURE SW/ESW DURING 10-15 MIN FOR CC FLOOD FAIL TO SECURE SW/ESW DURING 15-40 MIN FOR CC FLOOD FAIL TO SECURE SW/ESW AFTER 40 MIN DURING CC FLOOD F7 L TO SECURE SW/ESW AFTER 40 MIN DURING CC FLOOD	5.00E-1 1.00E-1 5.00E-2 5.00E-3 5.00E-2 5.00E-3 5.00E-2 3.09E-1 1.00E-1 5.00E-2 5.00E-2 5.00E-3	1.2 1.5 3 5 3 1.2 1.5 3 5

ERROR

-

4. PLANT DAMAGE STATE TYPE CP HIS

23

-

1

HI ID	HI DESCRIPTION	HEP	ERROR
ADHICPEC2-ADS-LR FPHICPPS4:2FP-LE FPHICPPS4:2FP-LL HIHICPCR1G-4:0-I SLHICPEQ-6-RPVLV SPEICPPS4:5SPCUL	FAILS TO RECOVER FROM RPV DEPRESS CD FAILURE OPERS FAIL TO ALIGN VLVS FOR FP LATE-INJ - BEFOR 3 HRS OPERS FAIL TO ALIGN VLVS FOR FP LATE-INJ - AFTER 3 HRS OPER FAILS TO CLOSE FPCC OTBD ISOLATION - G41-F145 OPER FAILS TO CNTL RPV LEVEL & MAINTN BORON INVENTORY OPERS FAIL TO ALIGN SUPR FOOL C/U ALT INJECTION LATE	1.00E-4 5.00E-2 5.00E-3 5.00E-2 5.00E-2 5.00E-2	10 5 5 5 5

5. ACCIDENT PROGRESSION EVENT TREE TYPE CP EI

HI ID	HI DESCRIPTION	HEP	ERROR FACTOR
IGHICPEH-1-H2IG	OPER FAILS TO INITIATE HYDROGEN IGNITION SYSTEM	5.00E-3	5

6. LEVEL 1, FLOODING & PLANT DAMAGE STATE TYPE CR HIS

HI EVENT	HI DESCRIPTION	HEP	ERROR FACTOR
CVHICRPS7:3G41T	OPER IS UNABLE TO LOCALLY OPEN 1G41-F0145	5.00E-2	5
TAJICRSP52-7:2	OPER FAILS TO OVERRIDE ISOLATION SIGNAL	1.00E-1	1.5

7. PLANT DAMAGE STATE TYPE CR HIS

HI ID	HI DESCRIPTION	HEP	ERROR FACTOR
ADHICREC2-ADS-R	FAILS TO RECOVER FM REV DEPRESS CD GIVEN EARLY FAILURE	1.00E-1	1.5
SLitCREQ-6-SLCR	OPER FAILS TO INITIATE SLC - GIVEN CD FAILURE	1.00E-1	1.5



8. TYPE MA HIS

HI ID	HI DESCRIPTION	HEP	ERROR FACTOR
DGHIMASR-3-4:1:A	FAILURE TO RESTORE FOLLOWING MAINTENANCE	0.0CE+0 0.00E+0	
TGHIMASR43-4:1:B	FAILURS TO RESTORE FOLLOWING MAINTENANCE FAILURE TO RESTORE FOLLOWING MAINTENANCE	0.00E+0	
OHHIMASE22B-4:1 ECHIMASP42-4:1A	ECC TRAIN A NOT RESTORED FOLLOWING MAINTENANCE	0.00E+0	
ECHIMASP42-4:18 ECHIMASP42-4:18	ECC TRAIN & NOT RESTORED FOLLOWING MAINTENANCE	0.00E+0	
ESHIMASP45-4:1A	ESW TRAIN A NOT RESTORED FOLLOWING MAINTENANCE	0.002+0	
ESHIMASP45-4:18	ESW TRAIN B NOT RESTORED FOLLOWING MAINTENANCE	0.GOE+0 0.00E+0	
ESHIMASP45-4:1C	ESW TRAIN C NOT RESTORED FOLLOWING MAINTENANCE	0.00E+0	
HPHIMASE22-4:1	FAILURE TO RESTORE HPCS AFTER MAINTENANCE FAILURE TO RESTORE FOLLOWING MAINTENANCE	1.00E-3	5
IAHIMASP51-4:1:2 LCHIMASE12-4:1A	FAILURE TO RESTORE TRAIN A LPCI FOLLOWING MAINT	0.005+0	
LCHIMASE12-4:18	FAILURE TO RESTORE TRAIN B LPCI FOLLOWING MAINT	0.00E+0	
LCHIMASE12-4:1C	FAILURE TO RESTORE TRAIN C LPCI FOLLOWING MAINT	0.00E+0	
LPHIMASE21-4:1	FAILURE TO RESTORE LPCS AFTER MAINTEPANCE	0.00E+0 0.00E+0	
RCHIMASE51-4:1	FAILURE TO RESTORE RCIC FOLLOWING MAINTENANCE	1.006-3	5
SAHIMASP51-4:1:2	FAILURE TO RESTORE FOLLOWING MAINTENANCE FAILURE TO RESTORE FOLLOWING MAINTENANCE	0.00E+0	
SIHIMASP57-4:0:A SIHIMASP57-4:0:B	PAILURE TO RESTORE FOLLOWING MAINTEMANCE	0.00E+0	
SLHIMA	FAILURE TO RESTORE SLC FOLLOWING MAINTENANCE/TEST	0.00E+0	

APPENDIX H.1

CLEVELAND ELECTRIC ILLUMINATING COMPANY PERRY NUCLEAR POVER PLANT INDIVIDUAL PLANT EXAMINATION CONTAINMENT CAPACITY ANALYSIS

by

S. N. Maruvada R. L. Mnuchline R. J. Schmehl

Submitted to NUS CORPORATION Gaithersburg, Maryland February 17, 1992

Submitted by GILBERT/COMMONWEALTH, INC. P.O. Box 1498 Reading, PA 19603-1498

Table of Contents

Tit	le	Page
List of	Figures	ii
List of	Tables	iv
1.0	Purpose and Scope	1
2.0	Description of the Containment	1
3.0	Dryvell Failure Modes	7
4.0	Containment Failure Modes	16
5.0	Fragility Curves	27
6.0	Leakage	31
7.0	Conditional Probability Matrix	41
8.0	Effects of High Temperatures	44
9.0	Summary and Conclusions	49
10.0	References	50



List of Figures

Figure Number	Description
1	PNPP Reactor Building
2	Containment Personnel Airlock
3	Containment Equipment Hatch
4	Typical Mechanical Penetrations
4A	Fuel Transfer Tube Penetration
5	Electrical Penetrations
6	Foundation Mat
7	Annulus Concrete
8	Drywell Vent Structure
9	Upper Drywell Wall and Slab
10	Dryvell Head
11	Drywell Personnel Lock
12	Drywell Equipment Hatch
13	Dome Knuckle Fragility Curve (PF 1)
14	Dome Apex Fragility Curve (PF 2)

Page H.1 - ii

List of Figures (Cont'd)

Figure Number	Description
15	Cylinder Fragility Curve (PF 3)
16	Personnel Airlock Fragility Curve (PF 4)
17	Equipment Hatch (Bolts) Fragility Curve (PF 5)
18	Penetration P123 Fragility Curve (PF 6)
19	Penetration P205 Fragility Curve (PF 7)
20	Penetration P414 Fragility Curve (PF 8)
21	Concrete Anchorage Fragility Curve (PF 9)
22	Steel Anchorage Fragility Curve (PF 10)
23	Containment Composite Fragility Curve

Page H.1 - iii

List of Tables

Table Number	Description
1	Estimate of PNPP Dryvell Mean Failure Pressure
2	Material Properties
3	Containment Failure Modes
4	Containment Failure Mode Data
5	Containment Composite Fragility Curve
6-15	Not Used
16	Qualification Tests for Electrical Penetration
17	Effects of Elevated Temperature on Concrete
18	Effects of Elevated Temperatures on Reinforcing Steel
19	Effects of Elevated Temperatures on SA516 Grade 70 Plate
20	Seal Life of Ethylene Propolene
21	Leakage From Other Than Structural Failure

1.0 Purpose and Scope

An Individual Plant Examination is being performed for the Perry Nuclear Power Plant Unit I that meets the requirements of NRC Generic Letter 88-20. Gilbert/Commonwealth is under subcontract to NUS Corporation to define the capacity of the containment structure subjected to pressure resulting from a postulated accident. In this report, the probability of failure as a function of internal pressure is developed. Also included is the variability in the probability of failure which may be expected along with a description of potential leak paths and estimates of leak areas. The report also considers the effects of elevated accident temperatures on containment failure capacities.

2.0 Description of the Containment

The containment vessel for this plant is a free standing steel vessel which is located inside of a concrete shield building. The annulus concrete located between the containment and the shield building strengthens and stiffens the containment vessel. The drywell is located inside the containment vessel. All of these structures are supported on the foundation mat. A description of the structures that comprise the containment system is presented below.

2.1 Containment Vessel

The containment vessel is a pressure retaining structure composed of a

free standing steel cylinder with ar ellipsoidal dome, secured to a steel lined reinforced concrete foundation mat. The mat is the common foundation for the major structures of the reactor building complex. The free standing portion of the containment vessel is supported by and anchored into the foundation mat, and is designed, fabricated and erected in accordance with the requirements of ASME Code Section III for Class MC components.

The containment vessel is designed to contain radioactive material which might be released from the nuclear steam supply system following a loss-of-coolant accident. The steel containment vessel ensures a high degree of leak tightness during normal operating and design accident conditions. It is designed for a maximum internal pressure of 15 psig with a coincident temperature of 185°F at accident conditions, and a maximum external pressure differential of 0.8 psi due to accidental operation of the spray headers.

The basic dimensions of the containment vessel are:

- a. Cylinder inside diameter 120 feet
- b. Cylinder height 152 feet 2 inches.
- c. Ellipsoidal dome ratio 2:1.

The containment vessel cylinder has six external stiffening rings at various elevations. Details of the containment vessel cylinder, dome and stiffeners are shown in Figure 1. Two personnel access airlocks and one equipment hatch are provided. Details are shown on Figures 2 and 3. Details of typical penetrations are shown in Figures 4 and 5. The fuel transfer tube (penetration P205) is shown on Figure 4A. This penetration is oriented parallel to the 180° azimuth, 15 feet 2 inches east of the reactor building centerline. The penetration is skewed 32° 30' from vertical at Elevation 636'-6-3/4". "he lower 18 feet 6 inches of the containment vessel forms the outside boundary of the suppression pool; the inside boundary of the suppression pool is formed by the dryvell weir vall. Corrosion of the lower 23 feet 6 inches of the containment vessel and exposed steel mat liner is minimized by the use of ASME SA 516, Grade 70, plate clad with stainless steel. At Elevation 721'-0" a 125 ton capacity polar crane is supported from the containment vessel.

Final design plate thickness of the containment vessel cylinder and dome is 1 1/2 inches. Local areas of the vessel, near large penetrations, have thicknesses greater than 1 1/2 inches.

2.2 Shield Building

The shield building is a reinforced concrete structure consisting of a flat foundation mat, a cylindrical wall and a shallow dome. The general configuration of the shield building and its relation to the other structures of the reactor building complex is shown in Figure 1. The foundation mat, common to the shield building, annulus concrete, containment vessel, and interior structure is circular in plan with a diameter of 136 fee and a thickness of 12 feet 6 inches. The foundation mat is founded on Chagrin shale at Elevation 562'-3", approximately 56 feet below grade. The shield ' ilding cylindrical wall extends from the top of the foundation mat at Elevation 574'-10" to Elevation 749'-9" and has an outside diameter of 136 feet with a wall thickness of 3 feet 0 inches. The shallow dome has a radius of 120 feet 0 inches, with a thickness of 2 feet 6 inches. There is no thickened ring girder, but the elevation of the wall at the junction of the wall and dome was raised to provide a greater section to help resist the outward thrust of the dome. Details of the shield building and mat foundation are shown in Figures 1 and 6.

The concrete has a minimum 28 day cylinder compressive strength of 3,000 psi. The steel reinforcement is in accordance with the requirements of ASTM A615, Grade 60. A general reinforcing pattern of orthogonal bars arranged vertically and circumferentially in both faces of the wall was used in the shield building wall.

The reinforcing pattern for the done is essentially radial and circumferential with the center section arranged orthogonally for ease of placing.

2.3 Annulus Concrete

The annulus concrete extends from the key of the foundation mat at Elevation 574'-10" to Elevation 598'-4" and has a radial thickness of 4 feet 10-1/2 inches. This annulus concrete provides stiffness to the steel containment vessel to reduce the dynamic response of the steel containment vessel due to the postulated safety relief value discharge loading phenomena. Three inches of compressible material are also provided between the containment vessel and the annulus concrete below Stiffener #1 and above Stiffener #4 to reduce thermal compressive stresses. The concrete has a minimum 28 day cylinder compressive strength of 3,000 psi. The steel reinforcement is in accordance with the requirements of ASTM A615, Grade 60.

A general reinforcing pattern of orthogonal bars arranged vertically and circumferentially in both faces of the wall was used in the annulus concrete. The general reinforcement pattern is shown in Figure 7.

2.4 Drywell

The drywell wall is generally a right, vertical cylinder. It is 83 feet 0 inches outside diameter, 85 feet 9 inches high and 5 feet 0 inches thick. The drywell wall is subdivided into two regions which have different construction and design methods. The drywell is shown in Figure 1.

The lower 26 feet 2 inches of the drywell is the vent region. The main suppression pool area in the containment vessel is connected to the drywell by 120 vents. The vent sleeves are 28 inch outside diameter, 1/4 inch thick, stainless steel tubes located in 3 rows 40 vents. Vents are constructed from ASTM A 240, Grade 304, stainless steel. The vent structure is a steel concrete composite construction thich consists of two concentric cylinders fabricated from 1 inch thick ASTM A 516, Grade 70, steel with a ten percent Type 304 stainless steel cladding. The annulus between the cylinders is stiffened vertically by radial steel plates and is filled with 5,000 psi concrete. The steel plates are designed to carry all membrane tensile forces in this region. At Elevation 574-10", the vent region is anchored to the containment base mat by means of vertical tension ties in the form of anchor bars made of ASTM A 537 CL.2 steel for the transfer of any uplift forces to the base mat. The anchor plate and stiffeners at the bottom of the anchor bars are sized for the capacity of the anchor bars. There are a total of 144 anchor bars on each face of the drywell. Details of the vent region are shown in Figure 8.

The upper drywell wall is a reinforced concrete cylinder connected to the lower vent region by cadvelding all vertical and diagonal reinforcement to the ring girder at Elevation 600'-10". The inside face of the drywell is formed with a 1/4 inch thick steel plate of ASTM A 285, Grade A, material which is stiffened vertically by 2 inch x 3 inch x 1/4 inch angles spaced at approximately 1 foot 3 inches and horizontally by stiffener rings of 3 inch x 4 inch x 1/4 inch angles spaced at about 5 feet 0 inches center to center. The stiffener angles are ASTM A36 material. This steel liner is very conservatively not considered in the design as contributing to structural strength or leak tightness of the drywell.

The drywell top slab is a flat horizontal, circular, reinforced concrete slab. It contains a central circular opening of 31 feet 11 1/2 inch diameter which is closed by the drywell head. The configuration and seal details of the 14 feet 9 1/4 inch deep steel ellipsoidal drywell head are shown in Figure 10. The top slab is stiffened by two longitudinal reinforced concrete walls which are part of the upper pool water system. Details of the upper drywell wall and drywell slab are shown in Figure 9. The personnel access air lock has an outside diameter of 9 fact 8 inches and is located at the 599'-9" elevation floor to provide access to the drywell. For large pieces of equipment, an 11 foot 0 inch square clear opening, bolted, double gasket sealed, equipment access hatch is provided at Elevation 599'-9". The personnel air lock and the equipment hatch are integrally connected by full penetration welds to steel frames designed to act as end anchorage for all of the drywell wall reinforcement in the vicinity of the lock and hatch. Details of the personnel air lock and the drywell equipment hatch are shown in Figures 11 and 12.

Penetrations through the drywell wall for piping and electrical systems are of the single barrier leak tight type. The main steam lines are anchored at the drywell and are provided with guard pipes through to the isolation valves outside containment.

3.0 Drywell Failure Modes

Stresses produced by pressure are the primary cause of postulated failure in the following components:

- 1. Dryvell vall
- 2. Dryvell roof
- 3. Dryvell head
- 4. Dryvell equipment hatches
- 5. Drywell personnel airlock

3.1 Failure Definitio

For the purposes of this report, failure pressures are defined as the pressures associated with mean yield stress in the structural components. Although higher pressures may be possible based on the ultimate strength the materials, the load deflection relationships complex structures difficult to predict for stresses above yield; therefore the pressure els at yield represent a practical limit for quantitative description failure.

3.° Failure Pressures From Previous Studies

Previous studies of BWR Mark III containments with similar drywell structures are reported by References 1, 4, 8 and 12.

Reference ? failure of the orywell well, equipment hatch and personnel airlocks f + the Kuosheng Nuclear Plant are considered to be important failure modes from pressure induced stresses. From Table 1 and 2, Appendix F2 of Reference 1, failures from internal pressure are above 105 psi for all structural elements except the personnel airlock and upper equipment hatch. These "fail" at 53 psi and 60 psi respectively with an associated "minor" ?eakage. For external pressure the capacities are much the same as for internal except for the dryvell head which could buckle at 70 psi with minor leakage and at 80 psl with major leakage.

In Reference 4, Volume 2, Appendix C, Table C.8.1, the failure pressure range for the Grand Gulf Nuclear Station is identified as 50-120 psi

differential pressure for probabilities between 5 and 95 percentile.

In Reference 12 p. 9-15 the capacities of the Grand Gulf drywell structure and personnel hatch are identified as 67 psi and 72.9 psi respectively. These are termed "ultimate capacities" but in the context of Reference 12 they are based on yield, which we can conservate ally assume to be mean yield.

In Reverence 8 p. 16-17 the "ultimate capacity" of Grand Gulf drywell is identified at +67 and -89 psi differential pressure. Again, it is conservatively assumed that these pressures are based on mean yield material strengths.

3.3 Comparison of PNPP and Drywells from Previous Studies

A direct comparison of physical dimensions and structural details of the Perry and Kuosheng containments is unavailable. Both are BWR Mark III containments with similar loadings and both designs would be based on the same or very similar codes and acceptance criteria. From this it can be surmised that the capability of the overall designs are similar.

PNPP USAR (Reference 7) and Grand Gulf (Reference 10) show similar drywell structures. While exact dimensions and details for both structures are not available for a thorough comparison, it can be assumed that the overall size, design pressures, design codes and acceptance criteria for both drywells are the same; ther fore, the overall design of the concrete wall and roof should be very similar. 3.4 PNPP Unique Data

The following PNPP unique data has been obtained:

1. Drywell Head:

From Reference 26 the following estimates are made: Stress level at design pressure of 30 psi = 15.12 ksi (radial in flange). Flonge material is stainless steel SA 240 Type 304.

Therefore,

.

Pressure at minimum yield stress of 30 ksi =

$$\begin{array}{r} 30\\ 30 \text{ psi x} = 59.5 \text{ psi}\\ \overline{15..2} \end{array}$$

Assuming that the ratio of mean yield to minimum yield is the same as for SA 516 Grade 70 (see Section 4.0), the mean yield pressure, based on the flange capability is,

 $\frac{49.7}{59.5 \text{ x}} = 77.8 \text{ psi mean yield internal pressure}$

For external pressure the head has a design allowable

of 33 psi from Reference 26. It is difficult to accurately determine buckling failure pressure because buckling theory has difficulty accounting for all the variables like tolerances in curvature and thickness. The smallest estimate of critical buckling pressure from Reference 26 is 210 psi. Note also that the PNPP drywell head is 1 1/2" thick, compared to 1 3/8" for the Kuosheng head, for which Reference 1 reports a failure pressure of 70 psi. Assuming that buckling is proportional to t⁴, the estimated failure buckling pressure for the PNPP head by comparison to the Kuosheng head is,

 $\left(\frac{1.5}{1.375}\right)^2$ x 70 psi = 83.3 psi external buckling failure pressure

2. Equipment Hatch

1

The equipment hatch is a stiffened flat plate structure and would have similar stress levels for internal or external pressure except that bolts and bolting flange are not challenged by external pressure. The material is SA 516 Grade 70. Reference 27 p. 98 shows a membrane stress in the coverplate of only 8.9 ksi at 30 psi pressure (thermal stresses not included). On p. 101 of Reference 27, maximum stress in the stiffener is identified as 18,000 psi under 30 psi pressure and thermal load. Fur her investigation of Reference 27 computer output could be performed to separate out the bending stresses from the total stress in the stiffener. Also there would be additional capacity in the stiffened door based on plastic strength of stiffeners and redistribution of moments. Conservatively using the 18,000 psi as a measure of bending stress level at 30.69 psi pressure (includes 0.69 psi "live load"), the projected failure pressure for a mean yield of 49.7 ksi equals,

 $\begin{array}{rrrr} 49.7 \\ 30.69 \text{ psi x} \\ \hline 18 \end{array} = 84.7 \text{ psi} \quad \text{mean yield pressure based} \\ \text{on stiffened plate strength} \end{array}$

From Reference 27 p. 104, comparison of bolt stress to allowable bolt stress and of flange stress to allowable flange stress under 30.69 psi pressure is,

bolt allowable = $\frac{27.5}{17.63} = 1.56$

and,

flange allowable 28.59 = 1.52 flange stress 18.845

Conservatively, assuming that the bolt or flange yield stresses are at least 2 times their respective allowable stresses would give a failure capacity at yield of, 30.69 x 1.52 x 2.0 = 93 psi mean yield pressure based on bolt strength

In summary 84.7 psi can conservatively be used as an estimate of mean failure capacity of the drywell hatch.

3. Personnel Access Airlock

The drywell airlock is nearly identical to the containment airlocks, except for a slightly smaller door size. The evaluation and mean yield pressure from the containment evaluation (Section 4.0) apply to the drywell airlock, i.e. mean yield pressure of 107.2 psi.

4. Drywell Wall

The circumferential reinforcement in the drywell wall is #18 bars @ 12", each face. Using the nominal bar area of 4.0 in², reinforcement per inch = 0.667 in². Using a mean yield stress for ASIM A615 Grade 60 reinforcing steel of 71,900 psi (Reference 12, p. 9-13), a Ø of 0.9, and an inside drywell radius of 36.5 ft x 12 = 438 in, the mean failure pressure based on hoop capacity is,

The vertical reinforcement in the drywell wall is #18 bars at approximately 18" spacing on each face, or 0.44 in²/in. Mean failure pressure based on longitudinal membrane capacity is therefore,

The hoop capacity is controlling, giving a drywell concrete structure capacity of 98.5 psi. Since reinforcement at discontinuities and penetrations is typically designed to at least continue the basic strength of the shell, 98.5 psi is a reasonable estimate of mean yield failure pressure for the concrete portion of the drywell above the suppression pool.

The lower portion of the drywell is actually a double wall steel shell (ASTM A516 Grade 70) with connecting stiffeners and concrete fill. Hoop steel area can be found by subtracting the vent holes (ID = 27.5 in.) from the plate area,

(54 - 27.5) ip2	where 54" is the
x 2" = 0.98	vertical spacing
54 in	between vent holes and
	2" is the combined
	thickness of inner and
	outer shells.

Using .9 x 0.98 in^2/in to account for 10% stainless steel cladding on the exposed plate surface, the steel area becomes 0.88 in^2 . Using 49.7 ksi (see "Drywell Head" this section) as the mean yield strength, the estimate of mean failure pressure capacity of the lower steel plate portion of the drywell is,

0.88 in² x 49700 psi mean yield pressure = 99.9 psi based on steel hoop capacity

3.5 Selection of PNPP Mean Failure Pressures

The above summaries of previous drywell evaluations (Kuosheng and Grand Gulf) and the examination of some specific PNPP calculations and details, shrw that the drywell structure has higher pressure retaining capability than the steel containment. This is not surprising considering that the 30 psi internal design pressure for the drywell is twice that of the steel containment. A lower bound mean failure pressure (internal or external) for the drywell can be chosen based on the information presented above. More specifically, Table 1 gives an estimate of the pressure capacities of the various structural components of the drywell. For the cylindrical shell and roof the mean failure pressure of 67 psi from the Kuosheng analysis is used rather than the 98.5 psi calculated from PNPP specific data. This conservative pressure is used because the PNPP specific data did not include a detailed examination of all drywell shell discontinuities.

The mean failure pressures are considered to be proportional to the mean yield of the materials. Statistical descriptions of concrete strength and SA 516 Crade 70 plate strength are established in Section 4.0, Containment Failure Modes. ASTM A516 Grade 70 is considered to be identical to SA516 Grade 70. SA 240 Type 304 flange material on the drywell head is assumed to have the same ratio between mean yield and minimum yield as SA 516 Grade 70, i.e. 1.31. Reference 12 p. 9-13 gives the following statistical data on ASTM A615 Grade 60 reinforcing steel:

Specified minimum yield		60 ksi
Actual lower bound yield		57.3 ksi
Actual mean yield		71.9 %si
Actual upper bound yield	cs	75.1 ksi

For reinforced concrete, the strength of a particular element is generally more dependent upon reinforcing steel than on concrete strength. There are two reasons for this: (1) the steel is considered to carry all the tension loads (2) nearly all elements in bending are under-reinforced for both economical and design reasons. Concrete strength can be controlling in some cases such as in development of reinforcing steel or anchor bolts, and in members with high shear loads. For the statistical variation in strength of the upper Drywell wall and roof it should be sufficient to consider the properties of the reinforcing steel.

4.0 Containment Failure Modes

The following potential failure modes have been considered for the containment vessel: memorane failure, failure of the mat foundation, failure of the air locks and equipment hatch, thermal buckling of the suppression pool liner, failure at pipe penetrations, failure of the containment anchorage into the mat foundation, fracture due to existing weld defects, thermal buckling of the lower containment vessel, and thermal forces on stiffener #4 as a result of embedment into the annulus concrete. Each potential failure mode is discussed below.

Some components may be subjected to hydrostatic pressure in addition to gas pressure loadings. The hydrostatic pressure results from flooding of the containment vessel. Hydrostatic loading in addition to gas pressure loading will be evaluated on a sequence specific basis during the IPE.

Table 2 provides a summary of the mean value of yield and ultimate strength and their standard deviations for the dome and cylinder regions of the containment vessel. The mean value for the mat concrete ultimate compressive strength along with the standard deviation is also presented in Table 2 (References 17 and 18). For stee) components, failure pressure is established by calculating the pressure producing the ASME Level D limit stress in the component. This pressure is set equal to a 5% probability of failure. Pressures at any probability of failure level can then be determined by using the statistical equations explained in Item 7.0 of this report. The basic ASME Level D limit (Reference 9) for membrane stress intensities is 0.595 times the ultimate tensile stress of the material (0.595*Fu). This level of stress obviously has considerable factor of safety as compared to the the ultimate stress capability of the material; therefore it is reaconable to assign a 5% probability of failure to pressures producing ASME Level D limit stresses.

In the case of the concrete anchor the failure mechanism used to calculate capacity is based on the ultimate tensile strength of concrete which in turn is a function of the ultimate compressive tests of concrete

specimens. In contrast to reinforced concrete behavior as a general case (see item 3.5) the strength of the concrete anchors are only indirectly affected by any reinforcing steel in the concrete, so that the best measure of strength is the ultimate strength of the concrete itself.

A summary of the pressures at 5%, 50%, and 95% probability of failure for the various potential failure modes is provided in Table 4.

4.1 Membrane Failure

The containment pressure/stress relationship is based upon a KSHEL axisymmetric computer analysis (Reference 18). The containment internal pressure required to cause a membrane stress equal to the ASME Level D limit stress is 65.10 ps. for the dome knuckle, 86.77 psi for the dome apex, and 86.68 psi for the cylinder. The failure modes for the dome apex or knuckle would result in rupture of the steel plate and consequential loss of pressure through the rupture opening. The failure mode of the cylinder would result in rupture, progressing rapidly in size with rapid depressurization of the containment. Section 7.0 of this report compares expected opening sizes for the identified locations/modes of failure. See also Appendix B for m_{c} e calculation details of the above pressures. The above pressures are set equal to a 5% probability of failure.

4.2 Mat Foundation Failure

The Kuosheng PRA considers both the shear failure and the flexural failure of the mat foundation. These failure modes are generally applicable to the Perry containment vessel because the concrete mat foundation and base liner provide the bottom closure to the hybrid containment vessel. The conclusion documented in the Kuosheng PRA are considered to be applicable to the Perry containment on the basis of the following comparison.

The design compressive strength for the Kuosheng containment concrete is 5000 psi at 28 days while the median compressive strength at 90 days is 5760 psi with a logarithmic standard deviation of 0.10. The design compressive strength for the Perry mat fourdation was originally 3000 psi at 28 days and subsequently qualified as a 4000 psi 28-day mix and as a 5000 psi-90 day mix. However, further evaluation of the data available for the mat foundation concrete shows that by using the mix qualification defined by ACI 318 and ACI 214, an allowable concrete compressive strength of 5840 psi at 28 days may be calculated. The mean value for the mat foundation compressive strength is 6442 psi with a standard deviation of 448 psi.

The reinforcement for the Kuosheng containment vessel conforms to ASTM A615 Grade 60 for which the minimum specified yield stress is 60 ksi. The reinforcement for the Perry mat foundation also conforms to ASTM A615 Grade 60. The thickness and radius of the Kuosheng mat foundation is approximately 10 feet 0 inches and 70 feet 0 inches respectively based upon Figure 3-3 of Reference 1. The thickness and radius of the Perry mat foundation is 12 feet 6 inches and 68 feet 0 inches respectively.

The Ruosheng PRA concluded that shear and flexural failure of the mat was not determined to be an important failure mode. Based upon the similarities between the Kuosheng mat foundations and the Perry mat foundation, it is concluded that a shear or flexural failure of the Perry nat foundation is not a significant failure mode and additional strength evaluations are not required.

4.3 Equipment Hatch

The various components that comprise the equipment hatch are evaluated in Reference 14 for 45 µsi internal pressure and dead load. To obtain the pressure at the ASME Level D limit stress, the 45 psi pressure used in Reference 14 was multiplied by the ratio of (stress at Level D limit stress at 45 psi pressure) to obtain 60.80 psi. See Appendix B for more detailed explanation of this calculation. The 60.80 psi produce is set equal to a 5% probability of failure. The equipment hatch can experience hydrostatic pressure under post LOCA flooding.

4.4 Personnel Airlock

The various components that comprise the personnel airlock are evaluated in Reference 19. The acceptance criteria is ASME Code Service Level D limit stresses. The maximum pressure that the personnel airlock can resist was calculated to be 94.0 psi at the Service Level D limit stress allowable of 41.65 ksi. See Appendix B for additional explanation of the basis of the 94 psi pressure. The PNPP suppression pool liner is SA 516, Grade 70 plate with a 10% thickness of stainless steel cladding conforming to SA 240, Type 304. The cladding meets the requirements of SA 264. The tee sections used for the base liner anchorage are SA 36. The minimum specified yield strength for the plate is 38 ksi fc⁻ the SA 516 Grade 70 and 30 ksi for the SA 240, Type 304.

The Kuosheng liner conforms to SA 285 Grade A or C. The specified yield strengths for these materials are 24 ksi for Grade A and 30 ksi for Grade C. The probability of a failure resulting from the liner buckling was found to be negligible compared to that for other Kuosheng failure modes.

The following discussion from the Ruosheng PRA is considered to be applicable to the PNPP analysis and along with the fact that the PNPP liner has a greater yield strength than the liner for Kuosheng forms the basis for concluding that a failure resulting from liner buckling is also necligible for PNPP.

"The liner system consists of steel plate welded to rlates or structural sterl shapes embedded in the containment vessel concrete. Buckling of the liner could occur as a result of severe thermal gradients being developed between the liner and the concrete during an accident. The membrane compressive stresses in the liner result from the fact that the liner has a somewhat higher coefficient of thermal expansion than the concrete, and also heats up much more rapidly during the early transient portion of the accident. At the same time, the pressure increases in the containment, which tends to induce tension in the liner. Although the stress in the liner could be determined for given temperature and pressure time-histories, this was not considered necessary because even if the liner does buckle, the buckled configuration of the liner is deformation controlled by the thermal gradients and does not increase without bound as in load controlled buckling. Also the liner is in compression, which tends to limit any crack formation, and the internal pressure somewhat reduces the deformation expected. If the containment pressure rises quickly compared to the liner temperature, the liner may always be in tension, although possibly at proportionately lower stresses than at the ultimate load condition near failure. Even if the liner does buckle, this is not expected to lead to loss of liner integrity."

4.6 Pipe Penetrations

The pressure capacities for the pipe penetrations are summarized in Reference 18 for ASME Code Service Level C limits. The three most critical penetrations have been selected on the basis of the least pressure capacity. These are P123 - RCIC Pump Discharge and RHR Spray, P414 - Feedwater, and P205 - Fuel Transfer Tube.

Penetration P123 was previously investigated for a 45 psi pressure at which the calculated maximum stress was 40.2 ksi (Reference 18). To obtain the pressure at the ASME Level D limit stress, the 45 psi was multiplied by the ratio of (stress at Level D limit /stress at 45 psi pressure) to obtain 60 psi. See Appendix B for the calculation. This



60.0 psi pressure is set equal to a 5% probability of failure.

Penetration P414 was previously investigated for ultimate pressure capability corresponding to ASME Level D limit in Reference 18. The pressure was determined to be 74.7 psi using the ultimate material strength based on material certifications, and considering the increased stresses from the effects of a nearby penetration. See Appendix B for additional explanation. This 54.7 psi is set equal to a 5% probability of failure.

Penetration P205 was previously investigated in Reference 18 for ultimate pressure capability corresponding to the ASME Level D limit stress. This pressure was determined to be 58.9 psi using an elastic/plastic analysis. See Appendix B for additional explanation. This 58.9 psi pressure is set equal to the 5% probability of failure.

The leakage area associated with failure of each penetration is estimated to be 5.0 square inches and will increase with pressure. The maximum leakage area is estimated to be 30.0 s_4 uare inches for each penetration. It should be noted that a failure of P205 could not result in the upper pool draining into the annulus between the shield building and containment vessel unless there is also a failure of the transfer tube or manual gate valve located below the pipe sleeve embedded in the drywell concrete at Elevation 647'-5 3/8". P205 is located at Elevation 636'-6 3/4" which is below Elevation 541'-0", the maximum water elevation during post LOCA flooding of the containment vessel. 4.7 Containment Vessel Anchorage into the Mat Foundation The containment vessel anchorage evaluation consists of an evaluation for the steel component of the anch rage (containment vessel) and of an evaluation for the concrete capacity of the anchorage.

The steel portion of the anchorage consists of 288 anchors. Each anchor is a 9.25" wide vertical extension of the containment vessel shell with bearing elements at the bottom of each anchor. Appendix B shows that the vertical extensions are critical and that the pressure corresponding to ASME Level D limit stress is 104.98 psi. See Appendix B for additional explanation. The 104.98 psi pressu a is set equal to 5% probability of failure.

The concrete capacity for the containment vessel anchorage is based upon the methods defined in Reference 16 using the mean concrete ultimate compressive strength of 6442 psi. The resulting mean failure pressure capacity is 94.10 psi. A failure of the containment anchorage into the mat foundation could result in a gross failure of the containment vessel because the failure mechanism is the tension overstress of a concrete wedge. This failure would be sudden with no yielding and could be progressive around the containment as adjacent areas attempt to carry udditional load net carried by the failed segment. The model used to calculate the 94.10 psi failure pressure and to predict the failure he avior is shown in Appendix A. As discussed there, this model is simplistic and conservative. A more accurate model might well show that the mean failure pressure is somewhat higher and that the failure mechanism involves the Shield Building structure. This more complex behavior might not be sudden and gross. The pressure at any probabiltiy of failure can be derived from the mean tailure pressure of 94.10 psi using the statistical methods described in Section 7.0.

4.8 Fracture

A review of radiographics for the Perry Nuclear Power Plant found certain welds that contained potentially rejectable indications when evaluated according to the requirements of the ASME Boiler and Pressure Vesse? Code Section III, Subsection NE-5320. References 21, 22, and 23 provide evaluations that document that failure will not occur during the plant design lifetime and a means to evaluate severe accident type loadings which werp not a part of the plant design basis.

The containment meridional stresses are applicable to the weld defect problem (Reference 21). Base poin the limiting stress of 27000 ksi from Reference 23, the pressure capacity is 112.4 psi. The pressure capacity neglects dead load and is based upon the containment nominal 1 1/2 inch thickness. As a result, it is concluded that weld fracture does not significantly influence the results and conclusions of the report.

4.9 Thermal Buckling of the Lower Containment Vessel

The lower containment vessel is bounded on the outside surface by the annulus concrete. The shield building is located adjacent to the annulus concrete. The top of the annulus concrete is at Elevation 594'-4". As a result of this geometry and the fact that the steel containment vessel

heats more quickly than the concrete, thermal circumferential compressive stresses in the containment vessel are caused by the constraint provided by the annulus concrete and shield building.

The existing design is based upon uncracked concrete (Reference 25). The safety factor for buckling is 2.03 for the accident condition which includes 15.0 psig internal pressure, 185°F design accident temperature, suppression pool hydrostatic pressure, and dynamic loads. The thermal loading is the most dominant loading for this design condition at this area of the vessel. Based upon this information and a thermal stress free temperature of 70°F, the estimated temperature at which buckling will occur is approximately 300°F.

Distinction is made between load-controlled buckling and strain-controlled buckling. Load-controlled buckling is characterized by continued application of an applied load in the post-buckling regime, leading to failure. Strain-controlled buckling is characterized by the immediate reduction of strain-induced load upon initiation of buckling, and Ly the self-limiting nature of the resulting deformations. Even though it is self-limiting, strain-controlled buckling must be avoided to guard against failure by fatigue, excessive strain, and interaction with load-controlled instability.

The thermal buckling limit for the lower containment vessel as described above is strain-controlled buckling and is a conservative estimate of the buckling capacity since it is based upon a stress limit instead of a strain limit. In addition, fatigue and interaction with load-controlled



instability are not problems because the accident loading is not going to occur multiple times and because there are no significant loads that cause compression other than thermal.

4.10 Thermal Forces on Stiffener #4

Reference 20 defines a temperature and pressure limit based upon the stresses in stiffener #4 (embedded in the annulus concrete). The magnitude of the temperature and pressure is 280.4°F and 35.1 psi. The annulus concrete prevents displacement of this stiffener which results primarily from the thermal loads. The acceptance criteria for evaluation that was performed is based upon the ASME Service Level D limits which are a function of the minimum specified tensile strength of the steel.

Inelastic beha ior could be considered as described in Reference 20 in order to obtain additional pressure capacity. For this reason it is concluded that the thermal stresses in the stiffener would rat be a limiting condition for determining co tainment capacity.

5.0 Fragility Curves

As discussed in Section 4.0, the following failure locations have been identified for PNPP:

- 1. Dome Knuckle
- 2. Dome Apex
- 3. Cylinder

- 4. Personnel Air Lock
- 5. Equipment Hatch (Bolts)
- 6. Penetration P123
- 7. Penetration P205
- 8. Penetration P414
- 9. Anchorage, Steel
- 10. Anchorage, Concrete

For each steel component (Items 1-9), a 5% probability of failure pressure was established to the ASME Level D stress intensity limit. For anchorage, concrete, the mean failure pressure was calculated based on the mean ultimate strength of the containment mat concrete.

The fragility calculations are based on the assumption that the containment strength has a log-normal distribution, since this distribution, which does not permit negative values and has a positive skewness, has been shown to be descriptive of variation of material properties.

The cumulative log-normal distribution is described by the equation (Reference 1):

$$Pf= \operatorname{Prob} \left(P \neq p\right) = \emptyset[\ln'p/p')/\beta]$$
(1)

in which

Pf propability that failure occurs at a pressure P < p

standard deviation of the natural logarithm of the pressure capacity

- p, or logarithmic standard deviation of p
- p' median pressure capacity
- Ø(.) cumulative distribution function for a standard normal random variable

BC the log standard deviation of capacity, is a combination of the log standard deviation of material properties BS and the log standard deviation due to modeling uncertainty, Bm and is calculated from the standard relationship

$$\beta c = \{\beta_{1}^{2} + \beta_{2}\}^{0.5}$$
(2)

Bs is calculated from the coefficient of variation &p of material properties using the relationship

$$Bs = \{\ln (\delta^2 + 1)\}^{0.5}$$
(3)

for the log-normal distribution (Reference 12)

The median pressure capacity p^{v} is calculated from the mean pressure capacity p(mean) and the log standard deviation bc using the relationship

$$p'(median) = p(mean) * e(-1/2 + \beta c^2)$$

(4)

for the log-normal distribution (Reference 12). It should be noted that the median of a log-normally distributed variable is always less than the mean.

Am, the log standard deviation for modeling uncertainty was estimated on the basis of similarity of PNPP failure modes/locations to failures considered in the Ruosheng PRA (Reference 1).

Table 4 lists, for each failure mode/location, the pressure corresponding to 5%, 50% and 95% probability of the failure as well as the log standard deviation of capacity used in calculating the pressures. The log standard deviation of strength and the log standard deviation of modeling, which form the basis for the log standard deviation of capacity, are also listed.


Tables 5 through 14 document the calculations for the fragility curves for the ten failure modes/locations. Table 15 shows the calculation of the containment composite fragility curve, based on the relationship,

$$P_{\mu} = 1 - \Pi_{\mu} (1 - P_{\mu})$$
(5)

in which

P_{fc} = probability of containment failure

P _ probability of failure mode/location i



Equation (5) is based on the assumption of statistical independence of the individual failure modes. While it is highly probable that the failure modes are dependent because of commonalty of material vendor, location and fabricator, the assumption of independence is conservative, i.e., it gives higher failure probabilities than the assumption of dependence.

Fragility curves for each of the ten failure modes/locations and the containment composite fragility curve are provided as Figures 13 through 23. It should be noted that while the fragility curves depict the expected behavior of each component and the containment as a composite over a wide range of containment pressures, the curves should be considered valid only over a limited range around the median capacity (i.e., the lower bound of failure pressure is in the range of the 1st - 5th percentile).

6.0 Leakage

6.1 Leakage Concerns

Leakage at pressures below mean yield pressures is a concern for penetrations of the containment vessel and the drywell where the pressure boundary integrity is dependent upon special details and materials such as elastomer seals or convoluted bellows. Components within this general description are 1) personnel airlocks, 2) equipment hatches, 3) drywell head. 4) mechanical (piping) penetrations, and 5) electrical penetrations. In addition to high pressures, high temperatures can be a contributing factor to leakage. Degradation of materials under elevated temperatures is discussed in section 8.

Deflections and stresses due to temperature and pressure induced relative movements is also a concern, particularly at piping penetrations which physically connect shield building, containment vessel and the drywell and must therefore accommodate the relative movements of these structures.

Per Reference 7, the design leakage rate of the containment vessel is 0.2% of contained volume over 24 hours at a pressure of 11.31 psi. The allowable test leakage rate for the containment vessel is 0.75 times this amount. The design leakage rate of the Drywell is given by:

 $A/(K)^{0.5} = 1.68 \text{ ft}^2$ where A = flow area of leakage path and K = geometric friction loss coefficient

The allowable test leakage rate for the drywell is one tenth of this or 0.168 ft^2 .

6.2 Personnel Airlocks

0

.

The personnel airlocks for the containment vessel and drywell are shown in

Figures 2 and 11. The drywell has one personnel airlock and the containment vessel has two. The potential leakage path is around the moveable doors. Each airlock has two doors which seal by inflatable seals. Details of door size, door design, and seals for PNPP airlocks are very similar to the Grand Gulf personnel airlock which is analyzed for leakage in Reference 2, Appendix F to Appendix B. This Reference assumes that the seals fail to function or are deflated due to temperature degradation giving a leakage area for each airlock of 47.14 in². The same Reference also calculates a leak area of 125.70 in² if seals blow out. This seems like an extremely remote possibility for a number of reasons: 1) there are double seals on each end of the airlock (total = 4). 2) the seals are tested by introducing 30 psi pressure between seals, and again by a 34.5 psi test of theairlock itself. 3) the long sides of the rectangular doors have door stops which would prevent seals from blowing out even if they were blown loose. 4) if there were a pressure spike capable of blowing out the twin seals on one end of the airlock, the pressure build-up would be relatively slow within the airlock (as compared to the spike) with time for the initiating pressure to be dissipated by other means such as clearing of vent holes in the suppression pool.

In conclusion the potential leakage area for personnel airlocks is estimated at 47 in² based on non-functioning seals on both ends of the airlock.

6.3 Equipment Hatches

Containment vessel and drywell equipment hatches are shown in Figures 3

and 12. The removable hatch doors are attached by bolted flanged joints with o-ring seals. The bolts are preloaded to compress the seals and to limit flange separation under the design pressures. Even if the bolts had no preload and assuming no seals, leakage area due to flange separation would be very small as illustrated below:

flange separation assuming 6" long bolts and pressure of 87 psi giving a bolt stress of 49 psi,

elongation = <u>49 ksi</u> x 6^{*} = 0.01 in 29 x 10^{3} ksi

In practice flanges rotate so that the gap is smaller than the bolt deflection. Also, the compressible seals provide effective sealing under such small flange deflections. Reference 1, Table 9-2 and Reference 2, Appendix F to Appendix B also indicate very small leak areas for equipment hatches under mean yield pressures.

In conclusion we can say that the potential leakage area for the equipment hatches is negligible.

6.4 Drywell Head

The drywell head is shown in Figure 10. All of the above general discussion on equipment hatches as to the improbability of leakage applies to the drywell head. We can conclude that the drywell head has insignificant leakage under mean yield pressures.

6.5 Electrical Penetrations

Figure 5 shows electrical penetrations through the containment vessel and the drywell.

The electrical penetrations used in the containment vessel were subjected to a number of environment qualification tests including a simulated accident test and a simulated 40 year aging test. (References 32, 33) After each test the penetrations were tested for leakage. The results of these tests are shown in Table 16. These tests indicate that leakage through electrical penetrations in the containment vessel is very unlikely.

The drywell penetrations were also tested for simulated aging and accident conditions. (Reference 34). Very minor leakage occurred after the tests as shown on Table 16. See item 8.4 for a discussion of the effects of temperature on electrical penetrations and the potential leak areas.

6.6 Mechanical (Pipe) Penetrations

Figure 4 shows pipe penetrations through the drywell, containment vessel and shield building. For the purposes of leakage considerations we can categorize these as follows.

1. No Leakage

These penetrations pass through the containment vessel and shield building only, with the guard pipe anchored to the containment vessel and the process pipe anchored to the guard pipe nearby. These anchor configurations are steel-to-steel attachments forming a pressure boundary. Moveable components are at the shield building and are not part of the containment pressure boundary. The majority of penetrations are of this type.

2. Leakage at Containment Vessel only:

These penetrations pass through the drywell, containment vessel and shield building. The guar: pipe is anchored at the drywell, while the process pipe is anchored to the guard pipe outside the shield building. A potential leakage path exists between the guard pipe and the guide rings at the containment vessel. Under design conditions the pressure boundary is maintained at the containment vessel by convoluted bellows, inside and outside the containment vessel. Should both bellows fracture, leakage would occur at the gap between the guard pipe and the guide rings. There are 9 penetrations of this type. The data below show the penetrations, the size of the guard pipe and the leak area if bellows were to completely rupture.

Potential		O.D. of Gap Around					
Penetration No.	n 	Designation	Guard Pipe (in)	Guard Pipe (in)	Leak Area (in2)		
P122	Main	Steam	38	1"	121		
P123	RCIC	Pump Discharge	18	0.25"	14		
P124	Main	Steam	38	2~	121		
P131	RWCU	Pump Suction	18	0.25"	14		
P415	Main	Steam	38	1"	121		
P416	Main	Steam	38	1	121		
P421	RHR S	hutdown Suction S	upply 32	1"	102		
P422	RHR a	nd RCIC Steam Supp	ply 22	1."	71		
P423	Main	Steam Drain	14	0.25"	11		

Penetration Data - Leakage at Containment Vessel Only

3. Leakage at Containment Vessel and Drywell:

These penetrations are through drywell, containment vessel and shield building. The guard pipe and process pipe are anchored at the shield building, with sliding details at the containment vessel and drywell. A potential leak path exists at the containment vessel and at drywell. Under design conditions, convoluted bellows maintain the pressure boundary at both drywell (single bellows) and containment vessel (bellows inside and outside). Leakage would occur if bellows fracture. There are 2 penetrations of this type. The data below shows the penetrations, the size of the guard pipe and the leak area if the bellows were to completely rupture.

	Penetration Data - Leak	netration Data - Leakage at Containment Vessel and Drywel.					
Penetrati No.	ion Designation	O.D. of Gap Around Guard Pipe Guard Pipe Leak (in) (in) (in)		Leak Area (in ²)			
P121	Feedwater	32	1"	102			
P414	Feedwater	32	1"	102			

Two critical Containment Vessel bellows were investigated under the Hydrogen Ignition Evaluation (Reference 8). These two bellows were shown to have a minimum factor of safety on critical buckling of 5.3 under 45 psi pressure. It should be noted that buckling would only be possible for the bellows inside the containment vessel. If this bellows were to fail, the pressure boundary would still be maintained by the bellows outside the

tainment vessel. The pressure direction on this outside bellows would not produce buckling. We can conclude that bellows cracking and consequential leakage at the containment vessel wall is extremely unlikely at the mean pressure capacities identified in section 4.0.

The two penetrations through the drywell with potential leakage in the event of bellows failure were not analyzed for ultimate pressure capability. In general they should have similar pressure retaining capacity to the bellows at the containment vessel and therefore failure at the mean drywell pressure of 67 psi is extremely unlikely. 6.7 Summary of Leakage Concerns

Table 21, "Leakage From Other Than Structural Failure" lists potential leak areas, cause of leakage, effects of temperature and a judgmental estimate of probability of leakage. At temperatures below 300°F the probability of leakage is very small. At temperatures above 300°F the probability of leakage for some components becomes difficult to judge because of either degradation of seal materials or effects of differential thermal expansion (mechanical penetrations).

The effects of pressure are not included in Table 21. In general we might expect some increase in probability of leakage with higher pressures due to greater probability of seal blow-out or of bellows fracture in the case of mechanical penetrations. The pressure effects are not considered to be very significant in comparison to temperature and therefore are not included in the judgmental probabilities of Table 21.

6.8 Attenuation of Radionuclides by the Shield Building

The shield building provides another barrier which may attenuate the radiom ic s released subsequent to the initiation of leakage from the containment vessel. The shield building provides a relatively leak tight structure, for HVAC purposes, so that the annulus exhaust gas treatment system can be used to minimize the escape of the radionuclides to the environment by maintaining the annulus air space at a slight negative pressure. The design value for the negative pressure is approximately 0.01 psig. Should a positive pressure develop in the annulus region, the pressure boundary would include the concrete shield building and the Bisco silicone foam used to seal the annular space between the pipe sleeve penetrations embedded in the concrete and he pipe: through the penetrations. If leakage is initiated through the penetrations, the escaping grases could enter the 3 inch gap that is located between the snield building and adjacent structures. The waterproofing membrane is located at the bot⁺om of this gap and is the upper boundary to the porous concrete and the groundwater. An architectural detail consisting of neoprene expansion joint material forms the top boundary of the gap. The auxiliary building steam tunnel will also be a potential leakage path from the gap located between the buildings. The following list of shield building penetrations provides potential paths that the radionuclides could use to enter the adjacent structures:

MPL	ELEVA'I'ION	AZIMUTH	FROM	TO	ROOM
1PRB2003	603'-6"	62	RB	AB	LPCS
1PRB4001	647'	58	RB	AB	LPCS
1PRB4002	6471	62	RB	AB	LPCS
1PRB4003	647'	66	RB	AB	LPCS
1PRB4005	6471	298	RB	AB	HPCS
1PRB4006	6471	302	RB	AB	HPCS
1PRB2005	603'-6"	254	RB	IB	
1ERB4019	631'-6"	223	RB	IB	
1PRB3091	641'-6"	150	RB	IB	

1ERB3006	641'-6"	235	RB	IB
1ERB4005	643'-3"	240	RB	IB
1PRB6C02	678'	153	RB	IB
1PRB_003	6781	150	RB	IB
1PRB6005	6781	262	RB	IB

7.0 Conditional Probability Matrix

Failure locations are shown in Table 4. For failure locations 3, 9 and 10, the expected type of failure is gross rupture. For failure locations 1 and 2 the expected type of failure is rupture. For failure locations 4 through 8 the expected type of failure is leakage at lower pressures and either rupture or gross rupture at higher pressures. "Higher pressures" can be defined as any pressure above median failure pressure for that component; since, at these pressures, large areas of the structure are at high stress level tending to cause the rapid propogation of any fracture or deformation initiating the failure. Summarizing in tabular form:

Expected Type of Failure(3)

Mod	e / Location	Leakage	Rupture	Gross Rupture
1.	Dome knuckle		Х	
2.	Dome apex		Х	
3.	Cylinder			X
4.	Personnel airlock	(1)	(2)	
5.	Equipment hatch	(1)		(2)
6.	Penetration P123	(1)	(2)	
7.	Penetration P205	(1)	(2)	

Page H.1 - 41

8. Penetration P414 (1)

9. Anchorage, steel

10. Anchorage, concrete

 Expected type of failure at median failure pressure or below.

(2)

X

X

- (2) Expected type of failure above median failure pressure.
- (3) Leakage is defined as an area of approximately 0.1 ft². which results in slow depressurization. Rupture is defined as an area from 0.1 to 7.0 ft². Gross rupture is defined as an area of >7.0 ft².

Based on the above data for individual modes/locations, the composite conditional probability matrix of pressure and expected type of failure can be made:

Pressure, Psi	Leakage	Rupture	Gross Rupture
60	.85	.07	.08
65	.83	.08	.09
70	.79	.11	.10
75	.40	.50	.10
80	0	,58	.42

Conditional Probability Matrix

The conditional probability matrix was developed by first separating, at each pressure, the failure locations that would exhibit leakage, rupture and gross rupture. If the probability of failure is represented by $P_{\rm fl}$,

 P_{fr} and P_{fos} respectively,

 $P_{fL} = 1 - \Pi (1 - P_{fi}) \dots (2)$

where i, j, and k are the failure locations at which leakage, rupture and gross rupture cause failure respectively at the presure being evaluated. For instance, at 40 psi, locations 4, 5, 6, 7, and 8 exhibit failure by leakage, locations 1 and 2 by rupture, and locations 3, 9, and 10 by gross rupture.

The conditional probability of leakage, rupture, and gross rupture are then obtained by the application of Bayes' theorem.

For leakage,

$$P(f/L)(P_{fL}) = (5)$$

 $P(f/L)(P_{fL}) + P(f/R)(P_{fR}) + P(f/GR)(P_{fGR})$

Since the probability of containment failure given leakage, rupture or

gross rupture is one by definition,

$$P(f/L) = P(f/R) = P(f/GR) = 1.0$$

P(L/f) = $P_{fL} + P_{fR} + P_{fGR}$ (6)

Similarly,

. . . .

0

$$P_{fR}$$

$$P(R/f) =$$

$$P_{fL} + P_{fR} + P_{fRR}$$
(7)

and
$$P(GR/f) =$$

8.0 Effects of High Temperatures

The effects of high temperatures on concrete, reinforcing steel, steel plate and seal materials are discussed below.

(8)

8.1 Effects on Concrete

Reference 28 addresses effects of temperatures to 1112°F (600°C) on concretes with limestone and dolomite aggregates. Reference 11 addresses effects of heading to 1600°F (871°C) on a concrete with a "carbonate" aggregate. There are a number of differences in the testing methods between Reference 28 and 11. Reference 11 investigates specimens that are stressed to valious levels during heating and then loaded to failure, as well as heated specimens that are stored at room temperature for 7 days before being loaded to failure. Reference 28 only investigates unstressed specimens that have been heated and allowed to cool before testing. Reference 28 also looks at various exposure times: 48 hours, 1 month, and 4 months. There are significant differences in residual concrete strengths that result from the testing methods and also from the different aggregates. Based on short term exposure only (48 hours or less) and taking the lowest values from both references (unstressed specimen during heating, then cooled and tested to failure) some estimates of concrete strength at high temperatures are presented in Table 17. The strength of concrete exposed to these temperatures for longer periods of time could be lower than the values in Table 17.

8.2 Effects on Reinforcing Steel

Data on the effects of elevated temperature specifically on ASTM A 615 Grade 60 reinforcing steel was not obtained; however, some general information on carbon steels is provided by References 29 and 30. Table 18 shows effects of elevated temperatures on a number of steels including a high strength steel SAE 1040 (Reference 29). This steel has a high carbon (C = 0.41) and manganese ($M_n \approx 0.77$) content similar to what might be expected for reinforcing steel.Reference 30 provides information on common structural steel, ASTM A 36 (C = 0.26 max.), for temperatures to 1800°F. The PNPP values are based on the values for SAE 1040 except that above 1000°F the curve is extrapolated to follow the shape of the curve for ASTM A36.

Reinforced concrete is a composite material which could be affected by loss of strength of reinforcing steel or concrete. In general, the strength of reinforcing steel is more significant than concrete because all tension loads are assumed to be carried by the steel and because nearly all bending components (beams, walls, slabs, etc.) are under-reinforced for both economical and design reasons. Concrete strength is significant as affecting development of reinforcing steel stresses at bar ends and splices.

8.3 Effects on Steel Plate

Containment/drywell hatches, airlocks and the drywell head are mainly composed of SA 516 Grade 70. Reference 9 Table I-1.1 gives allowable stresses for this steel for temperatures from 100 to 700°F. It is reasonable to assume that the % loss of yield stress is very similar to the % loss of allowable stress. For higher temperatures than 700°F we can use References 29 and 30 which were previously discussed under effects on Reinforcing Steel. Estimated strengths of SA 516 Grade 70 are presented in Table 19. The PNPP values follow Reference 9 up to 700°F since this is data specifically for ASTM A 516 Grade 70. Above 700°F the values are generally based upon the lower of References 29 and 30.

8.4 Effects on Seal Materials

Airlocks and Equipment Hatches

The seals for personnel airlocks and equipment hatches for both the containment and drywell are ethylene propylene diamene monomer (EPDM). We do not have specific chemical and physical properties for these seals, however the project specifications required that the drywell seals be able to withstand 330°F for the airlocks and 285° for the hatch. The design accident temperatures for the containment seals was not as high (185°F); however it seems likely that the same seal material was used for containment and drywell airlocks/hatches because these components are by the same manufacturers and are nearly identical as far as sealing details.

Reference 2 Figure 2.14 shows "seal life" in hours for a number of seal materials including thylene propylene. Data from the graph of ethylene propolene is shown in Table 20.

Reference 2, Appendix A to Appendix B reports testing of two models of bealing configurations: neoprene o-rings in trapezoidal grooves and silicone compound in tongue and groove. The neoprene o-ring, which has the same seal life curve as EPDM, was tested at both room temperature and at 420°F. Some small leakage was detected at 420°F indicating some seal distress. The seals were also deformed by the high temperature test even though the leakage was very small.

In summary, for PNPP seal materials, we might expect the seals to significantly change in physical characteristics above 400°F. Whether this change results in seal leakage or seal blow-out cannot be determined from the information just presented. Even with specific information about the characteristics of seal material at 'emperatures above 400°F, the function of each seal detail could still be highly dependent on the magnitude of the pressure, the deflection of the flanges and the particulars of the configuration itself. For example the behavior of the o-ring seals on the equipment hatches would non necessarily be the same as the inflatable seals or the personnel airlocks even if the temperatures, pressures and flange deflections were identical.

Electrical Penetration Seals

There are 40 electrical penetrations through the containment vessel (see Figure 5). As indicated in Table 16, these have been tested at high temperature and pressure with negligible subsequent leakage. The penetrations have four o-ring seals, two of EPR material and two to silicon. These seals should perform well up to 300°F. Even if the seals were degraded, the potential leakage area would be small and is estimated as 200 in² for all 40 penetrations.

The drywell has 52 electrical penetrations. See Figure 5. These penetrations are sealed on the outside of the drywell wall by neoprene

material under clamping pressure. These seals are designed as fire barriers and have been tested to withstand a 3 hour fire per U.L. rating and a 5 hour fire per American Nuclear Insurers. In addition, fire proofing material has been added within the electrical boxes between the neoprene seals and the drywell wall. The sealing material is uctually designed to swell under increasing temperature up to 600°F to compensate for the possibility of degraded cable insulation. The potential leak area can be conservatively taken as the inside area of a 5" conduit, 19.6 in²/penetration, or a total about 1000 in².

9.0 Summary and Conclusions

The composite fragility curve for the containment indicates a pressure capacity of 53.5 psi at a 5% probability of failure and a pressure capacity of 64.3 psi at a 50% probability of failure. The most critical failure mode was found to be a failure of the containment vessel plate adjacent to penetration P414. A pressure capacity of 57.4 psi at a 5% probability of failure with a logarithmic standard deviation of 0.151 was estimated for this failure mode. The next most likely failure mode is expected to be a failure in the containment vessel plate adjacent to penetration P205 wit¹ a pressure capacity of 58.1 psi at a 5% probability of failure with a logarithmic standard deviation of 0.135. .

- Probabilistic Risk Assessment, Fuosheng Nuclear Power Station, Unit 1, Volumes 1 and 4, July 1985.
- Containment Performance Working Group Report, Draft Report for Comment,
 U.S. Nuclear R. ulatory Commission, NUREG-1037, May, 1985.
- Estimates of Early Containment Loads from Core Melt Accidents, Draft Report for Comment, U.S. Nuclear Regulatory Commission, NUREG-1075, December, 1985.
- Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants, Summary Report. Second Draft for Peer Review, U.S. Nuclear Regulatory Commission, NUREG-1150, June 1989.
- Evaluation of Severe Accident Risks: Grand Gulf Unit 1, Volume 6, Revision 1, Sandia National Laboratories, NUREG/CR-4551.
- PRA Procedures Guide, A Guide to the Performance of Probabilistic Risk Assessments for Nuclear Power Plants, Review Draft, September 28, 1981, NUREG/CR-2300.
- The Cleveland Electric Illuminating Company, Perry Nuclear Power Plant, Updated Safety Analysis Report (USAR), Revision 2, March, 1990.

- The Cleveland Electric Illuminating Company, Preliminary Evaluation of the Perry Nuclear Power Plant Hydrogen Control System, March 21, 1985.
- ASME Boiler and Pressure Vessel Code, Section III, Division 1, Subsection NE, Class MC Components, 1977 Edition.
- Final Safety Analysis Report, Grand Gulf Nuclear Station, Units 1 and 2, Volume 4.
- Temperature and Concrete, American Concrete Institute Publication SP-25, 1971.
- IDCOR Program Report, Technical Report 10.1, Containment Structural Capability of Light Water Nuclear Power Plants. July 1983.
- SP-669, Specification for the Fabrication and Delivery of Steel Plate Structures Inside Containment, Perry Nuclear Plant, Units 1 and 2.
- 14. SP-660, Design Report, Containment Equipment Hatch Assembly, Perry Nuclear Power Plant, Cleveland Electric Illuminating Company, September 22, 1982, Volume 42.
- 15. SP-660, Stress Report, Containment Equipment Hatch Assembly, Perry Nuclear Power Plant, Cleveland Electric Illuminating Company, January 29, 1976, Volume 29.

- Code Requirements for Nuclear Safety Related Concrete Structures, Appendix
 B ~ Steel Embedments.
- Memorandum to R. J. Schmehl, from C. W. Whitehead/R. W. Alley, dated April 3, 1981, PY-STR-1303.
- Letter to Mr. B. J. Youngblood, from Mr. M. R. Edelman, dated February 4, 1985, PY-CEI/NRR-0131 L.
- 19 Structural Engineering Calculation 3:07.7.4, Revision O.
- 20. Structural Engineering Calculation 3:07.7.5, Revision O.
- 21. Analysis of Inaccessible and Potentially Rejectable Defects in Perry Nuclear Power Plant, Aptech Engineering Services, Inc., AES 8211352-1, July, 1983.
- Letter to Mr. P. B. Gudikunst (GAI) from Mr. T. Feiereisen (Aptech Engineering Services, Inc.), dated February 9, 1984.
- Letter to Mr. W. J. Leininger (G/C) from Mr. T. Feiereisen (Aptech Engineering Services, Inc.), dated July 31, 1985.
- 24. SP-660, Design Report, Containment Vessel Anchorage Analysis, Perry Nuclear Power Plant, Cleveland Electric Illuminating Company, June 7, 1985, Volume 25.

- 25. SP-660, Design Report, Buckling Calculations on Lower Containment Analysis, Perry Nuclear Power Plant, Cleveland Electric Illuminating Company, November 8, 1983, volume 8.
- 26. SP-669 Stress Report, Drywell Closure Head Flange, Perry Nuclear Power Plant, Cleveland Electric Illuminating Company, Revision A, 1983.
- SP-669, Stress Report, Drywell Equipment Hatch, Perry Nuclear Power Plant, Cleveland Electric Illuminating Company, Revision B, 1985.
- 28. ASIM SIP858 Temperature Effects on Concrete, symposium 1983, paper titled "Performance of Dolostone and Limestone Concretes at Sustained High Temperatures", G/C. Carette and V. M. Malhotra.
- 29. ASTM STP180 Elevated-Temperature Properties of Carbon Steels, W. F. Simmons and H. C. Cross, 1955.
- 30. U.S.S. Steel Design Malual, R. L. Brockenbrough and B. G. Johnston, 1974.
- 31. Structural Engineering Calculation 3:07.7.0, Revision 0.
- SP-563, Qualification Report PEN-TR-82-54 by Westinghouse for Low Voltage, Control and Instrumentation Electrical Penetrations, 1982.
- SP-563, Qualification Report PEN-TR-82-52 by Westinghouse for Medium Voltage Modular Electrical Penetracions, 1982.

- 34. SP-793-45, Environmental Qualification Report of a Multi-Cable Transit Assembly by Farwell and Hendricks, Inc., 1985.
- 35. Gilbert/Commonwealth drawings SS-215-310 Sheets 1A and 1B.
- 36. SF-660 Volume 3, NNIC Stress Report for Containment Vessel, Appendices 2.H through 2.M Rev. A, May 7, 1985.
- 37. Calculation 3:07.7.5, Containment Venting Analysis, June 1, 1990.





Figures

Tables

Appendix A


Appendix B







PNPP REACTOR BUILDING


FIGURE 1




#IGURE 2









FUEL TRANSFER TUBE PENETRATION FIGURE 4A




-


2






ANNULUS CONCRETE FIGURE 7






1.46



DRYWELL HEAD FIGURE 10








FIGURE 12





CEI - PERRY NUCLEAR POWER PLANT UNIT #1 DOME KNUCKLE FRAGILITY CURVE (Pf1)


FIGURE 13


H.1 - 69




















15

H.1 - 76

•







6

3

- Ale

ESTIMATE OF PNPP DRYWELL MEAN FAILURE PRESSURE

Component	Material	Mean Failure Preseure (pai)
.ower well	SA 516 - Grede 70	99.9
Upper well	Reinforced concrete	87.0 (1)
Roof	Reinforced concrete	67 O (1)
Head	5A 516 - Grade 70	77.8
Equipment hatches	SA 516 - Grade 70	84.7
Personnel sirlocke	84 516 - Grede 70	107.2

(1) This pressure is concernatively based on the Kuosheng analysis (Reference 1). Sections 3.4 and 3.5 of this PNPP (PE Containment analysis indicate that mean failure pressures tiased on actual PNPP structural details may be higher that of 7 psi.

MATERIAL PROPERTIES

Component	Mean Tield Strength (ksi)	Mean Tensile Strength (ksi)	T(eld Strength Standard Deviation (KSi)	Tensile Strength Standard Deviation (ksi)
Dome	51.3	77.2	2.97	2.02
Cylinder	49.7	74.9	3.22	2.80

CONTAINBAENT FAILURE MODES

TABLE 3

tel Percentile 50h Percentile Fallure Pressure (psig) (psig)	53.35 B0 32	84 54 78 61	80.62 80.10	74.01 82.20 ***	53.26 54 15	51 95 54 05	42.03 45.74	43.87 49.02	45.83 52.85	53.32 54.54	
Mean Falure 1 Prasure Fal (psig)	85 40	107 40	119 50	107.20	27 10	98.92	64.400	e5 00	76.75	78.90	
Meteriai Properties	goue	dome	cytendae	cylinder	cylinder	rglindee	cylinder	cylinder	Contrate	cylin' ar	
Containment Faiture Miode	1. DOME KNUCKLE	DOME APEX	CYLINDER	PERSONNEL AIRLOCK	5 EQUIPMENT HATCH (BOLTS)	PENETRATION P123	7. PENETRATION P205	8 PENETRATION P414	8 ANCHORAGE CONCRETE	10 ANCHORAGE STEEL	

CONTAINMENT FAILURE MODE DATA

PAILURE MODE/LOCATION	MEAN FAILURE PRESSURE (PSI)	OF VARIATION	LOG. STANDARD DEVIATION OF STRENGTH,Be	LOG. STANDARD DEVIATION FOR MODELING UNCERTAINTY, Sm	LOG. ST/ NDARD DEVIATION OF CAPAC/TY, Bo	MEDIAN FAILURE PRESSURE (PSI)
1. DOME KNUCKLE	82.40	0.54	.054	.17	.180	81.1
2. DOME APEX	107.40	058	058	.17	.180	105.7
3. CYLINDER	119.50	066	.065	.18	163	117.8
A PERSONNEL AIRLOCK	107.20	.065	.065	.14	154	105.9
5. EQUIPMENT HATCH (BOLTS)	77.10	065	.065	.14	154	76.2
6. PENETRATION P122	76.90	065	.065	.16	.163	75.0
7. PENETRATION P208	58.90	037	.037	13	135	58.4
PENETRATION P' 14	65.00	.086	066	.16	163	64.1
. ANCHORAGE CONCRETE	78.75	070	070	.26	211	78.1
10. ANCHORAGE, STEEL	78.9	.088	.066	15	163	77.9

-

1

Failure Mode: Dome Knuckle (Pf1) Nedian Pressure, Pm: 81.1 psi Bc : 0.18

Pressure P,psi	umin(P/Pm)/Bc	рł
30.00	-0.52	0,0000
40.00	-3.93	0,0000
42.50	-3.59	0.0002
45.00	-3.27	0.0005
47.5M	-2.97	0.0010
50,00	-2.69	0.0040
52.50	-2.42	0.0080
55.00	-2,16	0.0150
\$7.50	-1,91	0.0280
60.00	-1.67	0.0670
62.30	-1,45	0.0740
65.00	-1.23	0.1090
67.50	-1.02	0.1540
70.00	-0.82	0.2060
75.00	-0.43	0.3340
80.00	-0.08	0.4680
85.00	0.26	0.6030
90.00	0.58	0.7190
95.00	0.88	0.811
100.00	1.16	0.877
110.00	1.69	0.956
120.00	2.18	0.985
130.00	2.62	0.996
140.00	3.05	0.999
150.00	3.42	1,000
160.00	3.77	1.000

-

é

TAPLE 6

Failure Mode: Dome Apex (Pf2) Median Pressure, Pm: 105.7 pai &c : 0.18

Pressure P,psi	umin(P/PM)/Bc	81
40.00	-5,40	0.000
50.00	-4.16	0.000
52.50	-3.89	0.000
55.00	-3.63	0.000
\$7.50	-3.38	0.000
60.00	-3.15	0.000
62.50	-3,15 -2,92	0.002
65.00	-2.70	0.003
67.50	-2.49	0.006
70.00	-2,29	0.011
75.00	-1,91	0.028
80.00	-1.55	0.061
85.00	- 5 ,21	0.113
90.00	-0.89	0.187
95.00	-0.59	0.278
100.00	-0.31	0.378
105.00	-0.04	0.484
110.00	0.22	0.587
115.00	0.47	0.681
120.00	0.70	0.758
130.00	1,15	0.875
140.00	1.56	0.941
150.00	1.94	0.974
160.00	2.30	0.989
170.00	2.64	0.996
180.00	2.96	0,998

.

-

1

5.

6

9

Failure Mode: Cylinder (Pf3) Median Pressure, Pm: 117.8 pai Bc : 0.163

Pressure P,psi	uein(P/Pm)/Bc	Pf
50.00	-5.26	0.0000
2.00	-6.16	0.0000
62.50	-3.89	0.0000
65.00	-3.65	0.0001
67.50	-3.42	0.0003
70.00	3.19 -2.77	0.0007
75.00	-2.77	0.0030
80.00	-2.37	0.0090
85.00	- 2.00	0.0230
90.00	.1.65	0.0490
95.00	-1.32	0.0934
100.00	-1.01	0.156
105.00	-0.75	6.227
110,00	-0.42	0.337
115.00	-0.16	0.436
120.00	0.11	0.566
130.00	0.60	0.726
140.00	1.06	0.855
150.00	1.48	0.931
160.00	1.88	0,970
170.00	2.25	0.988
180.00	2.00	0.995
190.00	2.93	0.998
200.00	3.25	0.999
210.00	3.55	1,000
220.00	3.83	1.000

8.1 - 86

Su.

Failure Mode: Personnel Airlock (Pf4) Median Pressure Pm: 105.9 p. Bc : 0.154 .

Pressure P,psi	uein(P/Pm)/Bc	Pf
50.00	-4.87	0.0000
55.00	-4.25	0.0000
57.50	.3.97	0.0000
60.00	-3.69	0.0001
62.50	-3.42	0,0003
65.00	-3.17	8000.0
67.50	-2.92	0.0020
70.00	-2.69	0.0040
75.00	-2.24	0.0130
80.00	-1.82	0.0340
15.00	.1.43	0.0760
90.00	.1.06	0.1450
95.00	-0.71	0.2390
100.00	0.37	0.3560
105.00	-0.06	0.4760
110.00	0.25	0.6000
115.00	0.54	0.7050
120.00	0.81	0.7910
130.00	1.33	0.9050
123.00	1.81	0.9650
150.00	2.26	0.9680
150.00	86.5	0.9966
170.00		0.9990
180.00	3,46	1.000
190.00	3.80	1.000
200.00	control for the production of the product of the local data and the second statements of the second s	1.000

7

•••



Failure Mode: Equipment Natch (Bolts) (PF5) Median Pressure, Pm: 76.2 p6i Bc : 0.154

Pressore Pypsi	u=ln(P/Pm)/Bc	PŤ
30.00	-6.05	0.0000
40.00	-6.18	0.0000
42.50	-3.79	0.0000
45.00	-3.42	0.0003
47.50	-3.07	0.0010
50.00	-2.74	0.0030
52.50	-2.42	0.0080
55.00	-2.12	3.0170
\$7.50	-1.83	0.0346
60.00	-1.55	0.0610
62.50	-1.29	0.0990
65.00	-1.03	0.151
67.50	-0.79	0.215
70.00	-0.55	0.291
75.00	-0.10	0.460
80.00	0.32	0.626
85.04	0.71	0.761
90.00	1.08	0.860
95.00	1.43	0.924
100.00	1.76	0.961
110.00	2.38	0.991
120.00	2.95	0.908
130.00	3.47	1.000
140.00	3.95	1.000
150.00	6.40	1.000

Feilure Hode: Penetration P123 (Pf6) Median Pressure, Pm: 75.9 psi Bc : 0.163

Pressure P,psi	u=(n(P/Pm)/Bc	Pf
30.00	-5.69	0.0000
40.00	-3.93	0.0000
42.50	-3.56	0.0002
45.00	-3.21	0.0007
67.50	-2.88	0.0020
50.00	-2.56	0.0050
52.50	-2.26	0.0120
55.00	-1.98	0.0240
57.50	-1.70	0.0450
50.00	-1.64	0.0750
62.50	-1.19	0,1170
65.00	-0.95	0.1710
67.50	-0.72	0.2360
70.00	-0.50	0.3080
75.00	-0.07	0.4720
80.00	0.32	0.6260
85.00	0.69	0.7550
90.00	1.05	0.8530
95.00	1.38	0.9160
100.00	1.69	0.9540
110.00	2.28	0.9890
120.00	2.81	0.9980
130.00	3.30	1,0000
160.00	3.76	1.0000
150.00	4.18	1.0000

N - : -

12

Feilure Rode: Penetration P205 (Pf7) Median Pressure, Pm: 58.4 psi Bc : 0.135

Pressure P,psi	um(P/Pm)/Bc	Pt
52.50	-4.336	0.0000
35.00	-3.788	0.0001
37.50	-3.276	0.0005
40.00	-2.798	0.0026
62.50	-2.349	0.0094
45.00	-1.926	0.0270
47.50	-1.526	0.0635
50.00	-1.146	0.1259
52.50	-0.784	0.2165
55.00	-0.440	0.3300
57.50	-0.110	0,4562
60.00	and the result of the result o	0,5813
62.50	0.507	0.6940
65.00	0.798	0.797
67.50	1.077	0.859
70.00	1.346	
75.00	1.858	
80.0	Accessing of the Accessing the second s	0.990
85.0	2.785	
90.0	0 3.208	
\$5.0	0 3.609	
100.0	the same first on the base of the property of	9 1.000

Failure Mode: Penetration P414 (Pf8) Median Pressure, Pa: 64.1 pai Bc : 0.163

Pressure F,psi	u*(n(P/Pm)/Bc	Pf
30.00	-4.66	0.0000
32.50	-4.17	0.0000
35.00	-3.71	0.0001
37.50	-3.29	0.0005
40.00	-2.89	0.0020
42.50	-2.52 -2.17	0.0064
45.00	-2.17	0.0150
47.50	-1.84	0.0330
50.00	-1.52	0.0640
\$2.50	.1.22	0.1110
55.00	-0.94	0.1740
57.50	-0.67	0.2510
60.00	-0.41	0.3410
62.50	-0.16	0.4366
65.00	0.09	0.5366
67.50	0.32	0.6266
70.00	0.54	0.7050
75.00	0.96	0.8320
80.00	1.36	0.9130
85.00	1.73	0.9580
90.00	2.08	0.981
95.00	2.41	0.9920
100.00	2.73	0.9971
110.00	3.31	1.0000
120.00	3.85	1.0000
130.00	4.36	1.0000



Failure Mode: Anchorage, Concrete (Pf9) Median Pressure, Pa: 75.0 psi Bc : 0.212

		Pf		
32.50	-3.947	0.000		
35.00	-3.598	0.0003		
37.50	-3.272	0.0005		
40.00	-2.968	0.001		
42.50	-2.682	0.003		
45.00	-2.412	0.007		
47.50	-2.157	0.015		
50.00	-1.915	0.027		
52.50	-1.685	0.046		
55.00	-1.466	0.071		
57.50	-1.256	0.106		
60.00	-1.055	0.1450		
62.50	-0.863	0.194		
65.00	-0.678	0.248		
67.50	· J. SOO	0.308		
70.00	-0.328	0.371		
75.00	0.003	0.501		
80.00	0.301	0.618		
85.00	0.587	0.721		
90.00	0.857	0.804		
95.00	1.112	0.866		
100.00	1.354	0.912		
110.00	1.804	0.966		
120.00	2.214	0.985		
130.00	2.592	0.995		
140.00	2.961	0.998		
150.00	3.267	0.999		
160.00	3.571	0.999		
170.00	3.857	0,999		

Failure Mode: Anchorege, Steel (Pf10) Median Pressure, Pm: 77.9 psi Bc : 0.163

Pressure P,psi	u=(n(P/Pz)/8c	Pf	
30.00	-5.85	0.0000	
35.00	-4.91	0.0000	
40.00	-4.09	0.0000	
42.50	-3.71	0.0001	
45.00	-3.36	0.0004	
47.50	-3.03	0.0010	
50.00	-2.72	0.0030	
52.50	-2.42	0.0080	
55.00	-2.13	0.0170	
\$7.50	-1.86	0.0310	
50.00	-1.50	0.0550	
62.50	-1.35	0.0890	
65.00	-1,11	0.1340	
67.50	-0.88	0.1800	
70.00	-0.65	0.2580	
75.00	-0.23	0.4090	
80.00	0.17	0.5680	
85.00	0.54	0.7050	
90.00	0.89	0.8130	
95.00	1.22	0.8890	
100.00	1.54	0.9380	
110.00	2.12	0.9830	
120.00	2.65	0.9960	
130.00	3.15	0.9990	
160.00	3.60	0.9998	
150.00	4.02	1,0000	





IABLE 15

	2	c		
1				
1		1		
2	2	2		
		1		
	1	1		
ŝ	ŝ			
į	5	ì		
į	4	4		
,			i	
	2		ŀ.	
ì		í		
į	8	5		
	ļ		Ē	
		•	ę	
i	2	5	1	
10.00				
1	i	5		
1	2			
	3	Ē		
	Ē	3	Ē	

Failure Failure Probability 1-PI(1-Pfi)	0.0000	0.0004				0.0510		0.2164				0.8185		0.9599		0.9953	0.9997	1.01
(114-1)14	1.0000	0.9996	1 1 1	0.9939		0.9490	0.5871	0.7836	0.6409	0.4773	0.3167	0.1842	0.0931	1070.0	0.0147	0.0047	0.0003	1
1-9110	1.0	1.0	10	1,0		0.9996	0.9990	0.9970	0.9920	0.9830	0.9690	0.9450		0.8660	0.8110	0.7420	0.5910	0.4320
1-969	1.0	0.9998	0.9995	0.9985	0.9963	0.9921				0.9286	0.8.55	0.8542			9.6915	0.6285	0.4988	0.3818
1-915	1.0	1.0.0	5666.0	1 1	1.7.4	1.7.4	1 1	1.7.1		1.12	1.16	1.20	£	0.4640	1	1 A	0.1680	0.0870
114-1	1.0	0.0000	1.1	1.1	8 C.R.	0.9730	0.9365	0.8741	0.7835	0.6700	0.5438	0.4188	0.3060	0.2125	0.1408	0.0891	0.0316	0.0097
1-916	1.0	1.01	1.0	1.0	0.9996	0.9993	0.9980	0.9950	0.9880	0.9760	0.9550	0.9250	0.8830	0.8290	0.7640	0.6920	0.5280	0.3740
1-Pf5	1.0	1.0	1.0	1.01	1.0	1666.0	0.9990	0.9970	0.9920	0.9830	0.9660	0.9390	0.9010	0.8490	0.7850	S	0.5400	0.3740
1-Pf4	1.0	1.0	1.0	1.0	1.0	10.1	1.0	1.01	1.0	10.1	1.0	0.0009	4.1.4	0.9992	100	1.1.4	0.9870	1.04
1-243	1.0	0.1	10.1	1.0	10.1	1.01	1.01	1.01	1.01	1.01	10.1	1.0	1.0	0.9999	10.00	1 2000 0	0.9970	0.9916
1-912	1.0	101	1.0	1.0.1	1.01	1.0	1.01	1.01	1.01	0.9999	0.9996	0.9992	0.9980	0.9979	0.9940	0.9890	1.1	0.9390
114-5	101	10.1	0.1	1.0	0.9998	0.9995	0.9990	0.9960		1.0	0.9720			0.8910		1.0	0.6640	
Pressure (psi)	12.51	35.0	37.5	10.07	42.5	45.0	47.5	50.01	52.5	55.0	57.5	60.09	62.5	65.0	67.5	70.01	75.0	80.0

Penetration Type	Conditions for aging Test	Conditions for Appident Test	Leskage After Tests (per penetration)
Low Voltage through C.V.	302 Degree(F) for 100 hours	340 degree(F) and 108 pailor 3 hours	< 6E-4 in**3/asc al 75 ps
Medium Voltage through C.V.	302 Degree(F) for 100 hours	343 degree(F) and 111 per for 3 hours	< 6E-4 in**3/sec at 75 pai
Drywell(MCT)	185 degræe for 852 hours		259 in ** 3/asc at 5 pa
Drywell(MCT)		> 250 degree(F) and > 10psi for 2 days	190 in **3/sec at 5 ps

QUALIFICATION TESTS FOR ELECTRICAL PENETRATION



.

EFFECTS OF ELEVATED TEMPERATURES ON CONCRETE

	% of compressive strength at room temperature for 48 hours exposure						
Temp Degree(F)	ASTM Publication STP 858 (Ref. 28)	ACI Publication SP 25 (Rel. 11)	PNPP estimate				
200	85	940	85				
300	85	85	8.5				
400	80	80	80				
600	55	60	55				
800	40	50	40				
1,000	33	45	30				
1,200	20	40	20				
1,400	*	30	10				
1,800		7	5				

6

	% of yield strength at room temperature							
Temp Degree(F)	ASTM Publication STP 180 (Rel. 29)	United State Steel Manual (Ref. 30)	PNPP estimate for ASTM A615 Grade 60					
200	948	90	98					
400	90	95	90					
600	78	96	78					
800	52	88	52					
1,000	20	73	20					
1,200		40	10					
1,400	4	20	05					

EFFECTS OF ELEVATED TEMPERATURES ON REINFORCING STEEL

1

% of yield strength at room temperature ASME B. & P.V. CODE ASTM STP 180 U.S.S. STEEL Temp DESIGN MANUAL PNPP estimate Degree(F) (Rel. 30) (Ref. 29) (Rol. 9) 1,000 1,200 1,400 1,800 1,800

EFFECTS OF ELEVATED TEMPERATURES ON SA 518 GRADE 70 PLATE

St. Ste .



SEAL LIFE OF ETHELENE PROPOLENE

Temperature (Degree F)	Seal Life (hours)
300	1,000
400	5
500	0.75
800	0.1 to 0.2





LEAKAGE FROM OTHER THAN STRUCTURAL FAILURE (1)

Cause of Item Leakage		Potential Leak Area (in *2) and Probability of Leakage (2)							
	200 Deg.(F)	300 Deg.(F)	400 Deg.(F)	500 Deg.(F)	800 Deg.(F)				
Alriocks	Temperature	47	47	47	47	47			
	Degrades Seal	A	A	B	c	D			
Alriocka	Seal Looses	47	47	47	N/A	N/A			
	Inflation Pressure	8	8	Ø	(Seal Degrades)	(Sesi Degrades)			
Equipment	Bolte Stretch	2	2	2	2	2			
Hatch	and Seal Looses Compression	A	8	¢	D	D			
Mechanical	Frecture of	200 (3,5)	200 (3.5)	200 (3.5)	200 (3,5)	200 (3,5)			
Penetrations (Dryweil)	Bellows	A	8	c	D	D			
Mechanical	Fracture of	900 (4.5)	900 (4,5)	900 (4,5)	900 (4.5)	900 (4.5)			
Penetrations (Containment)	Bellows	A	В	c	0	D			
Dectrical	Temperature	1000 (6)	1000 (6)	1000 (6)	1000 (6)	1000 (6)			
Penetrations (Drywell)	Degrades Seals	A	A	A	A	A			
Electrical	Temperature	200 (7)	200 (7)	200 (7)	200 (7)	200 (7)			
Penetrations (Containment)	Degrades Seals	A	0	c	D	0			

Notes:

(1) Effects of temperature on materials and componants is discussed in item 8.4

(2) Key to estimated probabilities:

A - Highly unlikely : Probability of occurrence of .001 or less

- B Very unlikely : Probability of occurrence of .01 or less
- C Ulikely : Probability of occurrence of .10 or less
- D Indeterminent : Probability higher than 0.10 but not further defined
- (3) Based on 2 penatrations with potential leakage of 100 in*2 each
- (4) Based on 11 penetrations including 4 penetrations with 121 in*2 each
- (5) Potential leakage area is a maximum that should never be reached. We should expect that some penetrations would fail before others because of different belows configurations and relative moviments. In addition a cracked belows could give a much smaller leak area than the "potential" which is halculated on the basis of beliows being totally ineffective in holding preveure.
- (6) Based on 52 penetrations. See item 8.4
- (7) Based on 40 penatrations. See item 8.4


APPENDIX A

CONTAINMENT VESSEL ANCHORAGE, CONCRETE

- 1. Calculation of mean failure pressure based on concrete strength
- 2. Selection of log standard deviations for materials, $B_{\rm s}\,,$ and for modeling, $B_{\rm w}\,,$

IDENTIFIER PAGE SUBJECT APPENDIX A C.V. ANCHORAGE - CONCRETE Gilbert/Commonwealth REV. 3 2 SHOWNERPS/COMMILTANTS PATES MICROFILMED CALCULATION ORIGINATOR DATE CALCULATION OF MEAN FAILURE PRESSURE Capacity of Containment Anchorage - Concrete Find ultimate capacity of Containment Anchorage using ACI 34a Appendix B with the following Refus assumptions 1. p= 1.00 No reduction in strength due to workmanship materials and modeling incentanties. See discussion below for Justification Concrete strength for = 6422 psi - mean strength Ref 17 established by 28 days cylinder tests of foundation that concrete. See additional comments belove Justification of p=100 for this calculation For the IPE analysis, the variations in materials and workmanship and the modeling uncentainties are accounted for by estimated values Be and Bm in the probability analysis, < 1.00 would To use a to factor of be to include these uncentainties fince which is misleading and unnecessarily concervative ioncrete strangth The E = 6442 psi is the mean concrete strength based on 145 samples at 28 days. The expected mean strength of the m-place concrete would significantly higher because of strength gain with age H.1 - 102GAL-446 7-84 PROPRIETARY INFORMATION OF GILBERT/COMMONWEALTH . FOR INTERNAL USE ONLY DO NOT DESTROY

THIS IS A PERMANENT RECORD



SUBJECT APPENDIX H IDENTIFIER PAGE C. V. ANCHORAGE - CONCRETE 3.1 Gilbert/Commonwealth AEV. 0 1 2 3 ENGINEERS/CONBUT SANTE MICROFILMED PAGES CALCULATION ORIGINATOR DATE CALCULATION OF MEAN FAILURE PRESSURE Anchonage Capacity, Concrete Pressure Capacity of Containment based on Ancharage Capacity Ref. 36 From SP660 Volume 3 (pages 04 and c5) Stress (compression) in 11/2" thick plate due D.L. = 520 psix 2.25 = 280 pri meridional Stres (tension) in 11/2" thick plate due to 15 psi internal pressure = 2187 psi, 225 = 3280,5 psi * 2.25" is notio of thickness at doubler (2.25") 1.5" basic thickness of vessel (1.5") D.L./ = 780 pr: «1.5" «2TT «720.75" = 18.40 t comp. landhor 288 auchors UphA/ (From 15 ps.) = 3280.5 + 1.5 - 20 - 720.75, 77.38 * andrean 288 tense Pressure capacity based on 377.55 anchor strugth p (men failure) = (377.55+18.4) = 15psi 76.75psi 77.38 a The calculated tension stress in the c.v. below the stiffeners is conservative (high) because at a conservative assumption in modeling the fixity of the stiffeners in the annulus concrete. See Reference 36, Page Rid H.1 - 104PROPRIETARY INFORMATION OF GILBERT/COMMONWEALTH - FOR INTERNAL USE ONLY GAI-445 7-94 DO NOT DESTROY THIS IS A PERMANENT RECORD

IDENTIFIER PAGE SUBJECT A POENDIX A A C.V. ANCHORAGE -CONCRETE Gilbert/Commonweelth - OF 1 3 REV. 2 0 ENGINEERS/CC.MBLILTANTS PAGES MICROFILMED CALCULATION ORIGINATOR DATE CALCULATION OF MEAN FAILURE PRESSURE - Capacity, Concrete Anchorage Enhancement of Anchorage Capacity By Rainforcing Steel to kinectum 1 1. Removering steel min designers feel that removering steel 1 to direction of anchors parallel to suntace. concrete) helps to limit tensila strain thus enhances the capability at concrete and concrete to withstand the tensile spresses om anchon The code does not provide (Rat. 16 B.A. pull-out. this enhancement calculate dues means (R. 16, B.4.2) where rule to account for uncertauties) tactor can be revised from 0.65 to 0.85. tension uncracked the concrete surface based on stree 2 LM tion is less than SIE. Thather calculated 00 stresses in the concrete low on thes tensim questionable and 15 inould require to calculate. In any case it we molex inde his remtorcing steel as en hancing to capability it would appear the estimate anc auscuesion un centrainty, See mode ine selection of this Br as discussed Later in this Appund in 2. Remforcing stell parallel the +0 anchorthe calculation of The code does allow and ventorcing steel that is par capacity bused on and intersecting the assumed pull he an Ref 16 BA.4 ormander anchon, alock orcing steel should be with destance of the anchor, t 12 death code allours the mohor The 19.* rale x H 1 _ 105 GAI-446 7-84 PROPRIETARY INFORMATION OF GILBERT/COMMONWEALTH - FOR INTERNAL USE ONLY

THIS IS A PERMANENT RECORD DO NOT DESTROY

DENTIFICA PAGE SUBJECT ADDENICIX A C.V. ANCHORAGE - CONCRETE Gilbert/Commonwealth 2 3 REV. 0 KINNERS BE THE COMBRILITION . PAGES UCROFILMED. CALCULATION ORIGINATUR DATE CALCULATION OF MEAN FAILURE PRESSURE Anchorage Capacity Concrete 2 Reinforcing Steel parallel (continued) capacity to be based on either the concrete tenerle strength on the remboring steel strength but not the addition of the two, This is because the increte is assumed to creek at low stress ie 4 Vfc at which the strain is also low and the vemborcement is only stressed to a fraction of its strength = EG ATVE' = 3000 ps. After the the concrete cracks the remotioning steel must carry the entire load Calculating the anchor strength based on 11 > 2 ties (4 bars) @ 2°-30' specing or 2 tres @ every other anchor As = 4 = 400 m2 = 4.00 m2 Tic capacity = As " mean yield of rebar = 4,00 = 71.9 231 = 288 tor 144 to This is less than the tension capacity of the the concrete anchor = 322 Manchor. Use 377 Fanchar based on concrete pull-out. previously calculated. Mean failure pressure remains at 76.25 psi GAL-446 7-84 . FOR INTERNAL USE ONLY PROPRIETARY INFORMATION OF GILBERT/COMMONWEALTH DO NOT DESTROY THIS IS A PERMANENT RECORD

Pays 6

APPENDIX A - CONTAINMENT VESSEL ANCHORAGE, CONCRETE

SELECTION OF LOB STANDARD DEVIGTIONS FOR CONCRETE ANCHORAGE

Be. Variation in Material Properties

Reference 17 shows that the mean cylinder test strength (28 days) of the concrete foundation mat is 6442 psi, with a standard deviation of 448 psi. The coefficient of variation is 448/6442 = 0.8695. Therefore,

B. = [1n(0.8695^* + 1)]^*-= 0.07

B. Variation in Modeling

A number of factors can cause the strength of a concrete anchor to vary from the theoretical predicted on the basis of material test strength:

- 1. concrete in tension in the anchor zong
- 2. local variations in concrete strength due to placing and curing techniques
- 3. tolerances in anchor position and concrete surfaces 4. modeling inaccuracy

1. Concrute in Tension:

Tension stresses in the conc. ete from other loads can reduce the concrete capacity for anchor pull-out. In particular, internal pressures could cause significant bending moments in the concrete mat at the anchor locations. Although these stresses may be small, we can conservatively assign a coefficient of deviation of 0.20 to the concrete anchor capacity to allow for the presence of they tension stresses.

2. Local Variations in Concrete:

Strength of the same concrete mix can vary locally due to differences in placing and curing techniques. These differences are significant for relatively shallow enchors that could be affected by local variations. The depth of the Containment Vensel anchors means that a number of pours is involved in the concrete associated with any one anchor and that any variation over a small thickness or area of the concrete would not significantly affect the strength of the concrete ring holding the 3+ feet deep anchors. Therefore no reduction in strength need be considered for local variations in concrete due to placing and curing techniques

APPENDIX A - CONTAINMENT VESSEL ANCHORAGE, CONCRETE

3. Talerances on Anchor Position and Concrete Surfaces :

Typical construction tolerances of from 1/16" to 1/2" on anchors position and concrete surfaces can be cumulative and significant for shallos anchors. Tolerances on the Containment Vessel anchors are small, especially when compared to the anchor depth of 36 ~. In addition these tolerances have already been considered in the calculation for the mean yield capacity of the concrete anchor We should not assign any additional reduction in concrete streng for construction ()lerances.

4. Modeling inaccuracies:

Loads on anchorages and distribution of loads to individual anchors can vary from the calculated values due to simplifying assumptions in the model. This is certainly true for the Cortainment Vessel anchor analysis where the load path at the junction of the Containment Vessel with the foundation mat is made complicated and redundant by the presence of the annulus concrete. In effect this concrete transfers a large part of the meridional loads in the Containment Vessel to the Shield Building. This means that the weight of the annulus concrete, the weight of the Shield Building, and the vertical reinforcing steel of the Shield Building are available to help resist uplift from internal pressure in the Containment Vessel. The meridional stresses in Reference 36 (Appendix C) from which the mean failure pressure of the containment anchors is calculated. are based on a model which is conservative in assigning the load transferred through the annulus concrete. In addition, temperature loads on the steel Containment Vessel actually produce downward forces in the containment vessel steel due to the effect of the annulus concrete in restraining prowth of the containment vessel.

The significance of the annulus concrete in reducing the loads on the Containment Vessel anchors can be seen in Reference 37, where the anchors are actually in compression when the Containment Vessel experiences 31.82 psi. pressure and 275.8 degree F. temperature. It is apparent that the modeling assumptions used in calculating the mean yield pressure for anchors are all conservative, therefore we should not consider any strength reduction for modeling uncertainties.



APPENDIX A - CONTAINMENT VEBSEL ANCHORAGE, CONCRETE

Summary of Los Standard Deviation for Modeling

From the above discussion it is apparent that the only uncertainty tending to reduce anchor capacity is the presence of tension stresses in the concrete foundation mat. The coefficient of variation for modeling is therefore estimated at 0.20 and the log standard deviation for modeling is.

B. = [in (0.20^* + 1)]^* = 0.198 Use 0.20

(file phppeva)

APPENDIX H.2

PNPP IPE APET PROGRAM INPUT DATA FILE

The following PNPP IPE Accident Progression Event Tree (APET) Program Input Data File is developed for the Event Progression Analysis (EVNTRE) code developed at Sandia National Laboratories. Note that the EVNTRE code examines all cases sequentially, and once it finds a "true" outcome for a dependency it stops processing the case dependency logic. A complete discussion of the EVNTRE code is provided in the SAIC NUREG/CR--5174 reference manual (Griesmeyer 1989).

REVISION 0 19JUN1992 PERRY IPE APET 68 EVNTRE PROGRAM: PY_APETO.DAT 1 1.0 NO. OF SEQUENCES AND SEQUENCE FREQUENCIES 'ALL SEQUENCES ' SEQUENCE NAME S. S ŝ S PDS PARAMETER 1 NOT A CONTAINMENT BYPASS SEQUENCE - CNT BYP 1 2 'NOBYPASS' 'EVENT V' 1 1 2 0. 1. 2 PDS PARAMETER 2 CONTAINMENT STATUS AT CORE DAMAGE - CNT FAL 2 'INTACT' 'FAILED' 2 2 1 2 S IF NOT A BYPASS SEQUENCE 1 1 1 NOBYPASS .9942.0058\$ SENSITIVITY FOR PASSIVE VENT & ALT S/D.8123.1877\$ SENSITIVITY FOR ALT S/D ATWS.9449.0551\$ SENSITIVITY FOR PASSIVE VENT.7720.2280\$ BASECASE .9942 S Ś S OTHERWISE 0. 1. 3 PDS PARAMETER 3 EVENT TYPE: "TMT INTACT/FAILED AT CORE DAMAGE - EVENT_TYP 6 'SBO''LOOP NO H''OTHER TYPE: 'CRIT ATWS ''LOOP & SBO' 'OTHERS' 2 1 2 3 4 5 6 2 S IF CNTMT INTACT AT CORE DAMAGE 1 2 1 INTACT .1116 0. .8393 .0491 0. 0. \$ ALT S/D .1170 0. .8830 0. 0. 0. \$ BASECASE OTHERWISE \$ DEFAULT TO NO BRANCH Š OTHERVISE .1945 .1910 .6145 \$ BASECASE .9826 .0042 .0132 \$ PSV VENT .0236 .2314 .7450 \$ ALT S/D .8494 .0361 .1145 \$ PV+A_S/D 0. 0. 0. 0. 0. 0. 0. 0. 0. S S 0. 0. Ŝ. 0. PDS PARAMETER 4 INITIAL CNTMT HEAT REMOVAL WITH SUPR POOL COOLING - SUPR PL 2 'IN PL' 'NO IN PL' 2 1 2 2 1 3 S LOOP NO HVAC WITH CNTMT INTACT 2 LOOP NO H 0. 1. S NOT A LOOP NO HVAC OTHERVISE 1. 0.

5 PDS PARAMETER 5 2 'ISOLATED' 2 1 2		VENT ISOLATED AT RPV FAILURE - CNT_ISOL
1 3 1 SB0		\$ IF AN SBO SEQUENCE
.9965 OTHERVISE 1.	.0035 0.	S DEFAULT TO ISOLATED
6 PDS PARAMETER 6 4 'NO INJECT' 2 1		N FAILURE TIME - INJ_F_TIM HPCS ' 'NO BRANCH' 3 4
5 2 3 1 *	5 1	\$ SBO AND ISOLATED
SB0 .4347	1SOLATED . 2798	.2854 0.
1 3 1		\$ SBC (NOT ISOLATED) \$ {ASSUME SAME SPLIT FRACTION AS ABOVE}
SB0 ,4347	.2798	.2854 0.
2 3 2 * LOOP_NO_H 1.	4 2 NO_IN_PL 0.	S LOOP WITH NO HVAC S NO INITIAL POOL COOLING S TOKEN VALUES - NOT DEVELOPED O. O.
2 3 2 * LOOP_NO_H 1. OTHERWISE	4 IN_PL 0.	<pre>\$ LOOF WITH NO HVAC \$ WITH INITIAL POOL COOLING \$ TOKEN VALUES - NOT DEVELOPED 0. 0. \$ DEFAULT 0. 0.</pre>
1.	0.	0. 0. R RECOVERY TIME - PWR R_TIM
7 PDS PARAMETER 7 4 'PRIOR RV' 2 1	1.7.4 & 1.7.16 & M.Y. & 1.7 TO M	'NO RECOV' 'NO BRANCH' 3 4
4 2 3 1 *	6 1	\$ SBO WITH INJECTION FAILURE NO INJECTION
SBO .6148	NO_INJECT .3567	.0285 0.
2 3 *	6 2 PCTC	\$ SBO WITH INJECTION FAILURE RCIC
SBO .2484	RCIC .7006	.0510 0.
2 3 1 *	6 3	\$ SBO WITH INJECTION FAILURE HPCS

	1	SBO	HF	°CS	
		.4231		0.	.5769 0.
1	OTH	ERVISE			
		0.		0.	1, 0,
		PARAMETER 'RHR_SPRN 1		ONTAINME RHR_POOL 2	NT HEAT REMOVAL WITH RHR SPRAY LOOP - SPRAY ' 'NO_RHR' 3
10	2	3	*	5 2	\$ SBO WITH LOSS ISOLATION
		SBO O.	NU	T ISOL 0.	1.
	3	3 1 SBO	* NO_I	6 1 NJECT	7 \$ SBO WITH INJECTION FAILURE NO INJECT, * 1 \$ POWER RECOVERY PRIOR TO RPV FAILURE PRIOR_RV .1688
		.8312		0.	.1000
	3	3 1 SBO .8284	* NO_1	6 1 NJECT 0.	7 \$ SBC WITH INJECTION FAILURE NO INJECT, * 2 \$ POWER RECOVERY PRIOR TO CNTHT LIMIT CNTHT_LMT .1716
	3	3 1 SB0 .9479	*	6 2 RCIC 0.	7 \$ SBO WITH INJECTION FAILURE RCIC, * 1 \$ POWER RECOVERY PRIOR TO RPV FAILURE PRIOR_RV .0521
	3	3 1 SBO .928	*	6 2 RCIC 0.	7 \$ SBO WITH INJECTION FAILURE RCIC, * 2 \$ POWER RECOVERY PRIOR TO CNTMT LIMIT CNTMT_LMT .0717
	3	3 1 SB0 .909	*	6 3 HPCS 0,	7 \$ SBO WITH INJECTION FAILURE HPCS, * 1 \$ POWER RECOVERY PRIOR TO RPV FAILURE PRIOR_RV .0910
	1	3			\$ CTHER TYPES (NON SBO/LOOP)
		OTHER .517		0.	. 4829
	2	3	*	2 2	S ATWS WITH CNIMT FAILURE PRIOR TO CD
		CRIT /		FAILED O.	.6975
					S ATWS NO CNTMT FAILURE PRIOR TO CD S SENSITY TY ALT S/D ATWS S (ASS PLIT FRACTION .1 LOWER THAN S THE ABOVE. HOWEVER, HAS NO C IMPAL (IN SOURCE TERM RELEASE)

H.2 - 4

3 4 * 1 3 CRIT ATWS INTACT . 8 .2 0. OTHERWISE 0. 1. 0. 9 PDS PARAMETER 9 CONTAINMENT HEAT REMOVAL WITH VENT - VENT 2 'VENT' 'NO VENT' 2 2 1 11 S SBO WITH INJECTION FAILURE NO INJECT, S POWER RECOVERY PRIOR TO RPV FAILURE, S NO RHR CNTNT HEAT REMOVAL 8 6 1 3 1 1 PRIOR RV NO RHR NO INJECT SBO 0. 1. S SBO WITH INJECTION FAILURE NO INJECT. S POWER RECOVERY PRIOR TO CNTMT LIMIT, S NO RHR CNTMT HEAT REMOVAL 7 8 2 * 3 6 1 1 * NO_INJECT CNTMT_LIM NO_RHR SBO 1. 0. 6 7 \$ SBO WITH INJECTION FAILURE NO INJECT, 1 4 3 \$ NO POWER RECOVERY 3 3 1 SBO NO INJECT NO RECOV .1324 ,8676 S SENSIL VITY FOR PASSIVE VENT 0. Ś 1. S SBO WIT. INSL. TON FAILURE RCIC, S POWER PROVING RIOR RV FAILURE, S NO RHR STAT HEAT REMOVAL R 7 3 6 1 2 1 PRIOR RV NO RHR RCIC SBO. 0. 1. S SBO WITH INJECTION FAILURE RCTC. S POWER RECOVERY PRIOR CNTMT LIM. S NO RHR CNTMT HEAT REMOVAL 8 7 3 2 * 3 2 1 RCIC CNTMT LIM NO_RHR SBO 0. 1. 3 7 S SBO WITH INJECTION FAILUR 2 RCIC, 2 * 3 NO POWER RECOVERY RCIC NO_RECOV 3 1 SBO .8176 .1824 \$ SENSITIVITY FOR PASSIVE VENT 1. 0. 影

0

S SBO WITH INJECTION FAILURE HPCS, S POWER RECOVERY PRIOR RV FAILURE, S NO RHR CNTMT HEAT REMOVAL 3 6 1 - 8 il. 1 3 1 3 SBC HPCS PRIOR RV NO RHR 1. 0. 6 7 S SBO WITH INJECTION FAILURE HPCS, 3 3 3 3 NO POWER RECOVERY 1 3 -NO RECOV HPCS SBO ,7976 .2024 S SENSITIVITY FOR PASSIVE VENT Š 0. 1. 8 S OTHER TYPES (NON SBO/LOOP), 2 3 3 S NO RHR CNTMT HEAT REMOVAL 3 . 16 OTHER TYPES NO RHR 0. 1. S SENSITIVITY FOR PASSIVE VENT Ś .8394 .1606 2 3 2 S CRIT ATVS WITH CONT INTACT AT CD 4 * 3 S ALTERNATE SHUTDOWN ATWS CRIT_ATWS S SENSITIVITY ALT S/D ATV: INTACT 1. 0. S VENTING UNNECESSARY OR IRRELAVENT OTHERWISE 1. 0. - LAT INJ 10 PDS PARAMETER 10 LATE IN-VESSEL INJECT & PEDESTAL CAVITY SUPPLY 2 'LAT INJ' 'NO LT INJ' 2 2 1 24 S SBO WITH INJECTION FAILURE NO INJECT, \$ POWER RECOVERY PRIOR TO RPV FAILURE S CNTMT HEAT REMOVAL WITH RHR SPRAY 8 7 6 4 悦 1 1 1 1 PRIOR RV NO INJECT RHR SPRY SBO .0134 . 9866 S SBO WITH INJECTION FAILURE NO INJECT, S POWER RECOVERY PRIOR TO RPV FAILURE S CNTMT HEAT REMOVAL WITH VENT 7 9 4 3 6 1 1 1 1. SBO NO INJECT PRIUR RV VENT .0027 .9973 S SBO WITH INJECTION FAILURE NO INJECT, S POWER RECOVERY PRIOR TO CNTMT LIMIT, S RHR CNTMT HEAT REMOVAL WITH SPRAYS 7 8 3 6 4 2 1 1 1 * SBO NO INJECT CNTMT LIM RHR SPRY .3393 .6607

S SBO WITH INJECTION FAILURE NO INJECT. \$ POWER RECOVERY PRIOR TO CNTMT LIMIT, S NO RHR CNTMT HEAT REMOVAL 7 3 8 4 6 2 2 1 3 SBO NO_INJECT CNTMT LIM NO RHR . 6887 .3113 \$ SBO WITH INJECTION FAILURE NO INJECT. \$ NO POVER RECOVERY, S CNTMT VENT 7 0 4 3 6 1 3 1 1. SBO NO RECOV NO INJECT VENT .9363 .0637 \$ SBO WITH INJECTION FAILURE NO INJECT. \$ NO POWER RECOVERY, \$ NO CETHT VENT h 3 6 7 9 3 2 1 1 * NO RECOV NO VENT SBO NO INJECT 1. 0. \$ SBO WITH INJECTION FAILURE RCIC S POWER RECOVERY PRIOR RV FAILURE S RHR CNTMT HEAT REMOVAL SPRAY 3 7 8 4 6 1 1 2 1 PRIOR RV RHR SPRY SBO RCIC 1. 0. S SBO WITH INJECTION FAILURE RCIC S POWER RECOVERY PRIOR RV FAILURE S CNTMT VENT 3 7 9 6 4 1 1 2 1 PRIOR RV RCIC VENT SBO 1. 0. 7 S SBO WITH INJECTION FAILURE RCIC, - 3 6 3 * 2 \$ POWER RECOVERY PRIOR TO CNTMT LIMIT 2 1 CNTMT LIM SBO RCIC 1. е. S SBO WITH INJECTION FAILURE RCIC, S NO POWER RECOVERY, CNTMT VENT 7 9 3 6 4 3 2 1 1 黄 NO RECOV VENT RCIC \$80 0. 1.

S SBO WITH INJECTION FAILURE RCIC,

S NO POVER RECOVERY, NO CNTMT VENT 0 7 3 6 3 2 2 1 NO RECOV NO VENT RCIC SBO 1. 0. S SBO WITH INJECTION FAILURE HPCS, S POWER RECOVERY PRIOR TO RPV FAILURE S CNTMT HEAT REMOVAL WITH RHR SPRAY 8 7 1 6 3 . 1 3 1 PRIOR RV RHR SPRY HPCS SBO 0. 1. S SBO WITH INJECTION FAILURE HPCS, S POWER RECOVERY PRIOR TO RPV FAILURE S CNTMT VENT 0 7 6 3 1 1 3 1. VENT PRIOR RV HPCS SBO 0. 1. S SBO WITH INJECTION FAILURE HPCS. S NO POWER RECOVERY, CNTMT VENT 0 6 3 1 3 3 1 VENT NO RECOV SBO HPCS .1568 .8432 \$ SHO WITH INJECTION FAILURE HPCS, S NO POWER RECOVERY, NO CNTMT VENT 7 . 9 3 3 * HPCS 1 * SB0 .7460 2 3 NO RECOV NO VENT .2540 S SBO, CNTMT NOT ISOLATED 3 1 * SBO 5 2 2 NOT_ISOL . 4954 .5046 S OTHER TYPES (NON SBO/LOOP), 8 3 2 S AND RHR CNTMT HEAT REMOVAL WITH SPRAY 1 3 * OTHER TYPES RHR SPRY .9969 .0031 S OTHER TYPES (NON SBO/LOOP), 3 * 9 2 S CNTMT HEAT REMOVAL JITH VENT 1 OTHER TYPES VENT .9.16 .0284 \$ OTHER TYPES (NON SBO/LOOP), 3 * 0 2 2 S NO CNTMT HT REMOVAL, NO VENT OTHER TYPES NO VENT

	.00022	. 39978	
2	5 4 CRIT_MVS 1.	n 1 INTACT 0.	\$ CRIT ATVS WITH CONT INTACT AT CD \$ ALTERNATE SEUTDOWN ATVS \$ SENSITIVITY ALT S/D ATVS
2	3 4 * CRIT_ATWS .95	2 2 FAILED .05	\$ CRIT ATWS WITH CONT FAILED PRIOR CD \$ (ASSUMED AVAILABILITY OF LATE INJECT \$ PRIOR TO CNTMT FAILURE IMPACT)
2	2 * FAILED .4797	3 5 580_6_LOOP .5203	\$ CONTAINMENT FAILED PRIOR CORE DAMAGE, \$ SBO OR LOOP EVENT TYPE
2	2 * FAILED .3137 OTHERWISE O.	3 6 OTHERS .6863 1.	\$ CONTAINMENT FAILED PRIOR CORE DAMAGE, \$ ALL OTHERS TYPE SEQUENCES
	PARAMETER 'LOW PRES' 1	11 RPV DEPRESSURIZED 'HI PRES' 2	S SBO WITH INJECTION FAIL NO INJECT, S POWER RECOVERY PRIOR RV FAILURE,
5	3 1 * SB0 .4650	6 7 1 * 1 NO_INJECT PRIOR .5350	S VENT AND LATE INJECTION 9 10 * 1 * 1 _RV VENT LAT_INJ
5	3 1 * SB0 1,	6 7 1 * 1 NO_INJECT PRIOR 0.	S SBO WITH INJECTION FAIL NO INJECT, S POWER RECOVERY PRIOR RV FAILURE, S VENT AND NO LATE INJECTION 9 10 * 1 * 2 RV VENT NO_LT_INJ
5	3 1 * SBO ,2284	6 7 1 * 2 NO_INJECT CN/M7 .7/16	명한 - 2017년 - 1997년 - 1997년 - 1997년 - 1997년 명화, 1997년 - 1997년 - 1997년 - 1997년 - 1997년 - 1997년 - 199
			S SBO WITH INJECTION FAIL NO INJECT, S NO POWER RECOVERY, VENT,

S LATE INJECTION 7 9 10 3 * 1 * 1 6 5 3 6 3 * 1 * 1 NO_RECOV VENT LAT_INJ 1 SBO NO INJECT .0096 . 9904 S SBO WITH INJECTION FAIL NO INJECT, S NO POWER RECOVERY, VENT, S NO LATE INJECTION 10 9 7 5 3 2 3 * 1 1 1. NO_RECOV VENT NO_LT INJ NO INJECT SBO 0. 1. \$ SBO WITH INJECTION FAIL NO INJECT, S NO POWER RECOVERY, NO VENT, S NO LATE INJECTION 10 1 9 7 6 5 3 3 2 1 1 NO RECOV NO VENT LAT INJ NO INJECT SBO 0. 1. \$ SBO WITH INJECTION FAILURE RCIC, S NO POWER RECOVERY, NO VENT S NO LATE INJECTION 9 10 2 * 2 7 3 6 5 3 2 1 NO LLCOV NO VENT NO LT_INJ RCIC SBO 1. 0. S SBO WITH INJECTION FAILURE HPCS S NO POWER RECOVERY, VENT S LATE INJECTION 10 7 9 5 6 3 3 3 1 3 1 LAT INJ NO RECOV VENT SBO HPCS ,1986 .8014 S SBO WITH INJECTION FAILURE HPCS S NO POWER RECOVERY, VENT S NO LATE INJECTION 3 * 10 9 6 5 3 2 1 * 3 1 NO RECOV VENT NO LT INJ HPCS SBO .2296 .7704 S SBO WITH INJECTION FAILURE HPCS S NO POWER RECOVERY, NO VENT \$ LATE INJECTION * 10 * 2 5 3 6 0 3 1 NO RECOV NO VENT LAT_INJ HPCS SBO .9768 .0232

S SBO WITH INJECTION FAILURE HPCS S NO POVER RECOVERY, NO VENT S NO LATE INJECTION 7 9 3 * 2 10 6 5 3 2 2 3 1 NO RECOV NO VENT NO LT_INJ SB0 HPCS 0. . 1 . 10 S SBO WITH LOSS ISOLATION, * 1 S LATE INJECTION AVAILABLE 5 3 3 2 1 NOT ISOL LAT INJ SBO .3068 .6932 5 10 \$ SBO WITH LOSS ISOLATION, 2 * 2 \$ NO LATE INJECTION AVAILABLE 3 - 3 1 NOT ISOL NO LT INJ SBO ē. 1. S ALL OTHER SBOS ARE DEPRESSURIZED 3 1 1 SBO 1. 0. 8 10 S OTHER TYPES (NON SBO/LOOP), 1 * 1 \$ RHR HT REMOVAL W/ SPRAY, LATE INJECT 3 3. * 3 OTHER TYPES RHR SPRY LAT INJ .9924 .0076 S OTHER TYPES (NON SBO/LOOP) S NO RHR, VENTING, AND LATE INJECTION 10 9 3 8 4 3 * 1 3 1 shi OTHER TYPES NO RHR VENT LAT_INJ .9950 .0050 S OTHER TYPES (NON SBO/LOOP), \$ NO RHR, NO VENTING, AND LATE INJECTION 10 9 8 3 4 3 * 3 2 1 OTHER TYPES NO RHR NO VENT LAT INJ ō. 1. S OTHER TYPES (NON SBO/LOOP), \$ NO RHR, NO VENTING, AND NO LAT INJECT 9 10 2 * 2 3 * 8 4 3 NO VENT NO LT INJ OTHER TYPES NO RHR .9255 .0745 \$ CONTAINMENT INTACT, CRITICAL ATVS 2 3 2 3 4 * 1 S SENSITIVITY ALT S/D CRIT ATVS INTACT 0. 1.

```
3 2 3 8 S CNTMT FAILED PRICE TO CORE DAMAGE
2 * 4 * 1 S CRITICAL ATVS WITH RHR SPRAY
     FAILED CRIT_ATVS RHR_SFRY
.9918 .0082
              3 8 S CNTMT FAILED PRIOR TO CORE DAMAGE
4 * 3 S CRITICAL ATVS WITH NO RHR
     2
   3
      FAILED CRIT ATWS NO RHR
              .2542
      .7458
            3 10 $ CNTMT FAILED PRIOR TO CORE DAMAGE
* 5 * 1 $ LOOP & SBO, AND LATE INJECTION
   3 2
      2
      FAILED LOOP & SBO LAT_INJ
.99940 .00060
     2 *
             3 10 $ CNTMT FAILED PRIOR TO CORE DAMAGE
* 5 * 2 $ LOOP & SBO, AND NO LATE INJECTION
   3
      FAILED LOOP & SBO NO LT INJ
      .8882 .1118
     2
                  2
                                 S ALL REMAINING PDS ARE LOW PRESSURE
   2
     2 +
                 1
                                 S WITH THE CNTMT FAILED/INTACT ARE
                INTACT
                                 S LOW PRESSURE SEQUENCES
      FAILED
     1.
                  0.
     OTHERWISE
    1.
                   0.
S
Ś
S
S
                                                             - LATE INJ
12
  LATE LOW PRESSURE RPV INJECTION AVAILABLE
   3 'WATER_INJ' 'NO INJECT' 'CRITICAL'
                  2
   2 1
                                 3
 4
                                  S LATE IN-VESSEL INJECTION FAILED
   1 10
     2
     LAT INJ
     ö.
                                0.
                   1.
   1 3
                                 S NON-SHUTDOWN ATWS SEQUENCES
     4
     CRIT ATWS
    0.
                                1.
                   0.
                                  S LATE IN-VESSEL INJECTION AVAILABLE
   1 10
       1
     LAT INJ
     Ι.
                                 0.
                   0.
                                 S SHOULD NEVER REACH THIS CASE
     OTHERVISE
     0.
                   1.
```

```
H.2 - 12
```

13 RPV DEFFESSURIZED DURING CORE DAMAGE - RX PRESS 2 'LOW_PRES' 'HI PRES' 2 1 2 2 S RPV HAS BEEN DEPRESSURIZED 1 11 1 LOW FRES 1. 0. S RPV HAS NOT BEEN DEPRESSURIZED OTHERVISE 1. 0. DEBRIS MASS MOLTEN AT RPV FAILURE - MOLTEN VB 14 2 'LG DEB' 'SM DEB' 2 2 1 2 13 S IF NO WATER INJECTION AVAILABLE, OR 2 12 + 2 2 S (WATER INJ AVAILABLE, BUT) S RPV NOT DEPRESSURIZED HI PRES NO INJECT 0.1 0.9 S "ATER INJECTION AVAILABLE OTHERWISE .025 .975 DEBRIS COOLED IN-VESSEL - INV COOL 15 2 'COOL INV' 'NCOOL INV' 2 1 2 5 S CRITICAL REACTOR (NOT SHUTDOWN) 2 2 12 2 S CONTAINMENT FAILED PRIOR CORE DAMAGE 3 - 44 CRITICAL FAILED 1. 0. \$ CRITICAL REACTOR(NOT SHUTDOWN), 1 12 S ALTERNATE SHUTDOWN ATWS 3 CRITICAL 0. 1. 14 S LATE INJECTION, RPV DEPRESSURIZED, 1 S LARGE MOLTEN DEBRIS MASS IN LOVER HEAD 12 13 3 1 1 * - 14 LOV PRES LG DEB LAT INJ .5 - . 5 14 S LATE INJECTION, RPV DEPRESSURIZED, 2 S SMALL MOLTEN DEBRIS MASS IN LOWER HEAD 12 1 13 1 * 3 LAT INJ LOW PRES SM DEB .25 S ALL OTHER CASES OTHERWISE 0. 1. \$ S

S CET EVENT 2 MODE OF CONTAINMENT FAILURE BEFORE RPV FAILURE ******* V_ERLY_CF

```
ŝ
                                                              - H2_IGN
  HYDROGEN IGNITION SYSTEM AVAILABLE
16
   2 'HIS OFF' 'HIS ON'
   2 1
                 2
 2
                                S IF NO LOSS OF AC POVER
   2
                 3
     /1 * /5
     not SB0 not LOOP & SB0
.005 .995
                                 $ LOSS OF AC POWER
     OTHERVISE
                  0.
     1.
                                S SENSITIVITY FOR HIS PACKUP POVER
$
     0.
                  1.
   CONTAINMENT VENT ISOLATED BEFORE RPV FAILURE
                                                             - ISOL
17
   2 'ISOLATED' 'NOT ISOL'
   2
                  2
     1
  2
      5
                                 S CNTMT VENT ISOLATED
   1
                                 S BEFORE VESSEL FAILURE
      1
      ISOLATED
      1.
       0.
                               S SP) WITH CNTMT VENT NOT ISOLATED
     OTHERVISE
      0. 1.
    MODE OF RHR SPRAY OPERATION EARLY
                                                             - RHR MODE
18
   3 'CONTROLD' 'SPRAY ' 'NO SPRAY'
                 2
                          3
   2
      1
  5
       8
                                 S RHR SPRAYS NOT AVAILABLE
   1
      /1
      NRHR SFRY
      0.
                 0.
                             1.
                                 $ SBO EVENT TYPE,
        3
   2
                  /1
                                 S POVER NOT RECOVERD PRIOR TO RPV FAILURE
       1
       SBO
            not PRIOR RV
                  0.
                             1.
       0.
                             $ NON-SBO EVENT TYPES,
       3
    2
                   8
                                  S RHR SPRAYS ARE AVAILABLE
                   1
       /1
                 RHR SPRY
      not SBO
                 1.
                             0.
       0.
                 7 8 $ SBO EVENTS,
1 * 1 $ POWER RECOVERED PRIOR TO VESSEL FAILURE
    3
        3
       1
                 PRIOR RV RHR SPRY S SPRAYS ARE AVAILABLE
       SBO
                   1.
                              0.
       0.
                                 S SHOULD NEVER GO THIS PATH
      OTHERWISE
       0.
                  0.
                             1.
   CONTAINMENT STEAM CONCENTRATION BEFORE RPV FAILURE
                                                           - ST_CONC
19
    6 '0-15%' '15-25%' '25-35%' '35-45%' '45-55%' '> 55%'
    2 1 2 3 4 5 6
```

S DESIGN SPRAY OPERATION 18 2 SPRAY 0. 0. 0. 0. 0. 1. S SBO EVENT, 6 2 3 1 S INJECTION FAILURE TIME: NO INJECTION .1 NO INJECT SBO 0. 0. 0. 0. 0. 1. \$ SBO EVENT, 6 2 3 S INJECTION FAILURE TIME: RCIC 2 1 RCIC SBO 0. 0. 0. .51 .49 0. \$ SBO EVENT, 6 2 3 3 S INJECTION FAILURE TIME: HPCS 1 HPCS SBO 0. 0. 1. 0. 0. 0. \$ CONTAINMENT NOT INTACT AT CORE 2 1 S DAMAGE 2 FAILED 0. 0. 1. 0. 0. 0. S FOR ALL OTHER EVENTS OTHERWISE 1. 0. 0. 0. 0. 0. FRACTION ZIRCONIUM INVENTORY REACTED IN-VESSEL - H2 INV 20 3 '33%' '22%' '11%' 3 2 2 1 4 6 1 S SBO EVENT 2 3 S INJECTION FAILURE TIME: NO INJECTION 1 NO INJECT SBO 0. 1. 0. \$ SBO EVENT 62 2 3 S INJECTION FAILURE TIME: RCIC 1 SBO RCIC .13 .87 0. 6 \$ SBO EVENT 3 2 \$ INJECTION FAILURE TIME: HPCS 1 HPCS SBO 0. 1. 0. S BOUND OTHERS WITH DISTRIBUTION OTHERWISE 0. .13 .87 S FOR SBO WITH RCIC INJECTION FAILURE - SM BURN 21 SMALL HYDROGEN BURNS AT LOW H2 CONCENTRATION 2 'NO_SMAL' 'SMALL_BRN'

2 1 2

6

1 19 S IF > 55% STEAM, THEN INERT 6 > 55% 0. 2. S HYDROGEN IGNITION SYSTEM AVAILABLE 1 16 2 HIS ON 0. 1. \$ NON-SBO EVENT, 16 2 3 12 \$ (AC POWER NEVER LOST), . 1 S HYDROGEN IGNITION SYSTEK INOP HIS OFF not SBO .75 .25 3 7 S SBO EVENT. 2 - 1 S POVER RECOVERED PRIOR TO RPV FAILURE 1 SBO PRIOR RV S IGNITERS ASSUMED NOT AVAILABLE .96 .04 2 3 7 S SBO EVENT, S NO POWER RECOVERY PRIOR TO RPV FAILURE 1 * /1 SBO not PRIOR_RV 1. 0. 0. S SHOULD NEVER GO THIS PATH OTHERVISE 0. 1. - LG_BRN LARGE H2 BURN DURING CORE DAMAGE 22 2 'NO BURN' 'LG BURN' - 2 4 1 19 S CONTAINMENT FAILED PRIOR TO 2 1 5 CORE DAMAGE 2 FAILED 0. 1. 2 1 .15 3 0. S CONTAINS COND PROB OF ANCHORAGE FAILURE .15 0. S SMALL BURN IGNITED 1 21 2 SMALL BRN 1. 0. 2 1 0. 0. 0. 0. 3 S IF > 55% STEAM, THEN INERT 1 19 6 > 55% 0. 1. 2 S CONTAINS COND PROB OF ANCHORAGE FAILURE .15 .15 1 0. 0. 3

0

2 19 1 0-15% .5 2 1 3	* 0. 0.	20 1 33% .5 142. 9.	\$ 0-15% STEAM AND \$ 33% ZIPC OXIDATION = 25.6% H2
2 19 1 0-15% .5 2	*	20 2 22% .5 98.	\$ 0-15% STEAM AND \$ 22% ZIRC OXIDATION = 18.8% HZ
1 3 2 19 1 0-15% .72	0. *	20 3 11% .28	S 0-15% STEAM AND S 11% ZIRC OXIDATION = 10.5% H2
2 1 3 2 19 2	0. 0, *	42. 4. 20 1	S 15-25% STEAM AND S 33% ZIRC OXIDATION = 22.1% H2
15-25% .5 2 1 3	0. 0.	33% .5 123. 14.	
2 19 2 15-25% .5 2	*	20 2 22% .5	\$ 15-25% STEAM AND \$ 22% ZIRC OXIDATION = 16.2% H2
1 3	0. 0.	87. 11.	
2 19 2 15-25% .72 2	*	20 3 11% .28	S 15-25% STEAM AND S 11% ZIRC OXIDATION - 9.0% H2
1 3	0. 0.	37. 9.	
2 19 3 25-35% 5	*	20 1 33% .5	S 25-35% STEAM AND S 33% ZIRC OXIDATION * 19.4% H2

1 3	0. 0.	113. 20.	
2 19 3 25-35% .61 2	*	20 2 22% .39 80.	\$ 25-35% STEAM AND \$ 22% ZIRC OXIDATION = 14.2% H2
3 2 29 3 25-35% .75 2	*	16. 20 3 11% .25	\$ 25-35% STEAM AND \$ 11% ZIRC OXIDATION = 7.9% H2
1 3 2 19	0. 0.	36. 13. 20	\$ 35-45% STEAM AND
4 35-45% .56 2 1 3	* 0. 0.	1 33% .44 104. 27.	\$ 33% ZIRC OXIDATION = 16.6% H2
2 19 4 35-45% .67 2 1 3	* 0. 0.	20 2 22% .33 75. 23.	S 35-45% STEAM AND S 22% ZIRC OXIDATION = 12.2% H2
2 19 4 35-45% .77 2 1 3	* 0. 0.	20 3 11% .23 37. 19.	\$ 35-45% STEAM AND \$ 11% ZIRC OXIDATION = 6.8% H2
2 19 5 -55% .61 2 1 3	* 0. 0.	20 1 33% .39 98. 37.	\$ 45-55% STEAM AND \$ 33% ZIRC OXIDATION * 13.8% H2
2 19 5 45-55%	*	20 2 22%	\$ 45-55% STEAM AND \$ 22% ZIRC OXIDATION = 10.2% H2

	2	.72	0.	.28 76.			
		3	0.	32.			
2		19 5-55% .77	*	20 3 11% .23			45-55% STEAM AND 11% ZIRC OXIDATION # 5.7% H2
		1 3 THERVI 1.		41. 27. 0.		Ş	SHOULD NEVER GO THIS PATH
		1 3	0.	0. 0.			
23		DETON		ONTAINMENT 'NO' 2	FAILURE		- H2_DET
10	1	22 1 NO BURN O.		1.		S	NO LARGE BURN IGNITED
		19 4 35-45% 0.	÷	19 5 + 45-55% + 1.	19 6 > 55	\$	IF > 35% STEAM, THEN INERT TO DETONATIONS
	1	20 3 11 % 0.		1.			IF 11% ZIRC OXIDATION, THEN [H2] < 12%; DETONATIONS HAVE NEGLIGIBLE PROBABILTY
		19 1 *		* 1 *	7 * 1 * PRIOR RV	000000	STEAM CONC > 35% (HIGH), H2 CONC 12 - 16 %, POWER RECOVERED PRIOR TO RPV FAILURE, RHR IS AVAILABLE IN SPRAY MODE, NO EARLY INJECTION FAILURE SINCE THE STEAM CONC IS LOW FOR THAT SEQUENCE 18 6 2 * /1 SPRAY not NO_INJECT
		.022		.978			
		19 3 25-35% 0,	*	20 2 22% 1.		0.03	STEAM CONC < 35 % (LOW) H2 CONC 12 - 16 %

3 19 19 20 \$ STEAM CONC < 35 % (LOW), (1 + 2) * 2 \$ H2 CONC 16 - 20 % 0-15% 15-25% 22% .84 .16 \$ STEAM CONC < 35 % HIGH S H2 CONC > 20% \$ IF AC POWER LOST AND RECOVERED S PRIOR TO VESSEL FAILURE S AND RHR IS AVAILAELE IN SPRAY MODE S NO EARLY INJECTION FAILURE SINCE THE \$ STEAM CONC IS LOW FOR THAT SEQUENCE 3 7 18 6 * 1 * 1 * 2 * /1 6 19 20 3 1 * 1 0-15% 33% SBO PRIOR RV SPRAY not NO INJECT ,975 .025 * 20 \$ STEAM CONC < 35% (LOW) * 1 \$ H2 CONC > 20% 19 2) * 15-25% 3 19 (1 + 0-15% 33% .73 .27 2 19 3 \$ STEAM CONC < 35 % (LOW) 20 1 \$ H2 CONC 16 - 20 % 25-35% 33% .84 S SHOULD NEVER REACH THIS CASE OTHERVISE 1. 0. CONTAINMENT FAILURE BEFORE RFV FAILURE 24 2 'FAILURE' 'NO_FAILUR' 1 2 6 3 \$ CONTAINMENT NOT INTACT AT CORE DAMAGE 1 2 \$ IMPLIES STEAM OVER PRESSURE 2 S PRIOR TO CORE DAMAGE PAILED 1 BURNPRES XAM GETKRESH 1 -1. SET PROB OF CNTMT FAILURE FOR FOR SLOV OF (FORCE FIRST BRANCH) S H2 DETONATION CONTAINMENT FAILURE 1 23 1 DET CF 1 1 BURNPRES MAX GETHRESH 1 -1. H2 DETONATION -- FORCE FIRST BRANCH S CONTAINMENT INTACT PRIOR CORE DAMAGE OTHERWISE 1 1 BURNPRES FUN-F BURN

```
EQUAL O
      CALCULATE PROB OF CNTMT FAILURE (ANY MODE) GIVEN EXPECTED BURN PRESSULE
25 MODE OF CONTAINMENT FAILURE BEFORE RPV FAILURE
                                                                    - V ER CF
   2 'ANCHORAGE' 'PN-D/NoCF'
                        2
   6
 4
   1 2
                                     S CNTMT FAILED AT CORE DAMAGE INITIATION
      2
                                     S EARLY SLOW OVER PRESSURE
     FAILED
                                     S IN THIS CASE BURNPRES CONTAINS COND
       1 1
                                     S PROB OF ANCHORAGE FAILURE (0.15)
        BURNPRES
         MAX
        EQUAL O
       CNTMT NOT INTACT AT CORE DAMAGE INITIATION
                                     $ H2 DETONATION CONTAINMENT FAILURE
    1 23
       1
      DET_CF
         BURNPRES
         MAX
         GETHRESH 1 1.E20
       H2 DETONATION --- FORCE SECOND BRANCH
    1 24
                                     S CONTAINMENT NOT FAILED BY H2 BUPN
       2
     NO FAILUR
       1 1
         BURNPRES
         MAX
         GETHRESH 1 1.E20
       NO FAILURE CASE -- FORCE SECOND BRANCH
                                     S CONTAINMENT FAILED BY H2 BURN
     OTHERWISE
       1 1
         BURNPRES
         FUN-F MODE
         EQUAL O
       GET MODE OF CONTAINMENT FAILURE
S
Ś
S CET EVENT 3 INJECT & SPRAY FAILURE DUE TO CNTMT FAILURE BEFORE RPV FAILURE ***
S
                                                                     INJ FAL1
S
Ś
S
     CNIMI FAILURE BEFORE RPV FAILURE IMPACT ON ECCS INJECTION AND SPRAY PIPING
26
                                                                  - PIPE FAIL
S
      'NO FAILUR' 'FAILUR'
    2
    2
        1
                      2
  2
```

S ANCHORAGE CNTMT FAILURE MODE, AND S EXCLUDE THE SEQS WHERE CNTMT IS FAILED S AT CORE DAMAGE FOR SBO & LOOP & OTHERS S SINCE THE PDS ET -Li INCLUDES THIS 3 3 25 2 (1 1 4) 4 INTACT CRIT ATVS ANCHORAGE . 9 .1 S - NOT ANCHORAGE CNTMT FAILURE MODE OTHERWISE 0. 1. CNTMT FAILURE BEFORE RPV FAILURE IMPACT ON ECCS INJECTION AND SPRAY MOTORS 27 - MTR-FAIL Ŝ. 'FAILUR' 2 'NO FAILUR' 2 1 2 3 S CNTMT FAILURE, AND NO PIPING FAILURE S EXCLUDE THE SEQS WHERE CNTMT IS FAILED S AT CD SINCE THE LI PDS FT INCLUDES THIS S FOR LOOP & SBO AND OTHERS. 2 26 3 24 4 (1 4) 1 1 CRIT ATVS INTACT FAILURE NO FAILUR .5 .5 5 S CONTAINMENT VENT (OR NOT ISOLATED) 9 2 2 1 NOT ISOL VENT .95 .05 S NO CF, NO VENTING AND NO LOSS ISOLATION OTHERWISE 0. 1. CNTMT FAIL BEFORE RPV FAILURE STEAM & RADIATION RELEASE IMPACT ON FIREWATER 28 - STM/RAD S 'NO FAILUR' 'FAILUR' 2 2 2 1 3 S CNTM' FAILURE & NO PIPING FAILURE S EXCLUDE THE SEQS WHERE CNTMT IS FAILED S AT CD SINCE THE LI PDS FT INCLUDES THIS S FOR LOOP & SBO AND OTHERS. 2 3. 24 26 4 1 (1 4) 1 4 INTACT CRIT ATWS FAILURE NO FAILUR .5 .5 S CONTAINMENT VENTED (OR NOT ISOLATED) 5 9 2 2 1 VENTED NOT ISOL .1 . 9 S NO CF, NO VENTING AND NO LOSS ISOLATION OTHERWISE 1. 0. INJECT & SPRAY FAILURE DUE TO CONTAINMENT FAILURE BEFORE RPV FAILURE 29

1.00

H.2 - 22

```
- INJ/SP FL
S
   2
    'NO FAILUR' 'INJ&SPY F'
  2 1
                 2
 3
                              S PIPING FAILED
   1 26
    2
    FAILUR
    0.
                1.
                              $ ECCS INJECTION MOTORS FAILURE,
                28
   2 27
    2
                             S ALTERNATE FIREWATER INJECT FAILURE
               2
    FAILUR
               FAILUR
                1.
     0.
                              S ALL INJECTION NOT FAILED
    OTHERVISE
                0.
    1.
S
S
S
S
  ALPHA MODE STEAM EXPLOSION DRYWELL AND CONTAINMENT FAILURE - ALPHA
30
  2 'ALPHA' 'NO ALPHA'
                 2
   2 1
 2
                              S REACTOR VESSEL DEPRESSURIZED
   1 13
    1
     LOW PRES
    .ō1
                  .99
                              S REA TOR VESSEL NOT DEPRESSURIZED
    OTHERWISE
                 .999
     .001
   MODE OF IN-VESSEL STRAM EXPLOSION BOTTOM HEAD FAILURE - INV EXPLN
31
   4 'ALPHA' 'NO FAIL' 'LARGE VF' 'SMALL VF'
              -2
                       3
                                  4
   2 1
 3
                             S ALPHA MODE FALURE H. ] OCCURED
   1 30
     1
     ALPHA
               0. 0. 0.
   1.
                             S REACTOR VESSEL DEPRESSURIZED
   1 13
     1.
     LOW PRES
                 .398
                         .344 .258 $ 4551 GRAND GULF #'S
.034 .026
     0.
S
                 .94
     0.
                           S NO ALPHA FAILURE & RPV NOT DEPRESSURIZD
    OTHERVISE
                           .04 .03 $ 4551 GRAND GULF #'S
.004 .003
                 .93
    0.
S
                 .993
     0.
                                                - AREA FAIL
  RPV FAILURE MODE AND SIZE OF RFV FAILURE
32
   4 'ALPHA' 'NO_FAIL' 'LARGE_VF' 'SMALL_VF'
                         3
                                  4
                 2
   2 1
 5
```

```
H.2 - 23
```

1 30 S ALPHA MODE FALURE HAS OCCURED 1 ALPHA 1. 0. 0. 0. 1 31 S STEAM EXPLOSION CAUSES LARGE FAILURE 3 LARGE VF 0. 0. 0. 2... 1 31 \$ STEAM EXPLOSION CAUSES SMALL FAILURE 4 SMALL VF 1. 0. 0. 0. S CORE DEBRIS COOLED IN VESSEL, & S IN-VESSEL INJECTION N.I FAILED; S THEREFORE NO RPV FAILURE 29 2 15 1 * 1 COOL_INV NO FAILUR 0. 0. 0. 1. S CORE DEBRIS CAUSES LOVER RPV FAILURE OTHERWISE 0. .0 .1 .9 - PED WATER 33 WATER IN PEDESTAL AT RPV FAILURE 4 'FLD+IPJ' 'RPV+INJ' 'FLD' 2 1 2 3 'RPV WTR' 4 2 1 4 S LATE INJECTION/CAVITY WATER SUPPLY, S INJECTION NOT FAILED BY EARLY CF. \$ LARGE CONTAINMENT H2 BURN OR SBO, S LATE LOSS OF NORM INJECTION CAUSES S WATER OVERFLOW INTO DW 5 12 29 22 3 6 /2 * 1 * (2 * (1 * 3)) not NO_INJECT HO_FAILUR LG_BURN SBO HPCS 1. 0. 0. 0. S LATE INJECT/CAVITY WATER SUPPLY FAILURE S AND LARGE CONTAINMENT H2 BURN, Co 3BO S LOSS OF NORM INJECTION CAUSES 22 3 6 2 4 (1 * 3)) LG_BURN SBO HPCS 0. 1. 0 S WATER OVERFLOW INTO DW 4 29 2 * INJ&SPR F 0. S LATE INJECTION/CAVITY WATER SUPPLY, \$ AND INJECTION NOT FAILED BY EARLY CF S - AND NO WATER OVERFLOW INTO DW 2 12 29 /2 * 1 not NO INJECT NO FAILUR 0. 1, 0. O, \$ RESIDUAL RV WATER ONLY OTHERWISE 0. 0. 0. 1.

34	PEDESTAL FAILU 2 'PED_FAIL' 2 1		URI	E AT RFV FAILURE - PED_OP
	1 32 2 NO_FAIL 0.	1.	S	CORE DEBRIS COOLED IN-VESSEL THEREFORE NO RFV FAILURE OR PEDESTAL FAILURE
	3 13 2 * HI PRES 1.	33 (1 + 3) FLD+INJ FLD 0.	(1) (1)	RPV NOT DEPRESSURIZED AT VESSEL FAILURE AND WATER IN PEDESTAL FROM FLOODING
	4 13 2 *	33 33 33 (2 + 4)	00 00	RFV NOT DEPRESSURIZED AT VESSEL FAILURE NO WATER IN PEDESTAL FROM FLOODING AND LARGE RPV FAILURE 32 * 3
	HI PRES	RPV+INJ RV_WTP 0.		LG_VF
		33 33	00.00	RFV NOT DEPRESSURIZED AT VESSEL FAILURE NO WATER IN PEDESTAL FROM FLOODING AND SMALL RFV FAILURE 32
	HI PRES	(2 + 4 RPV+INJ RPV_VTR 1.)	* 4 SM_VF
	4 13 1 * LO PRES	33 33 (1 + 3 FLD+INJ FLD	ss o	RFV DEPRESSURIZED AT VESSEL FAILURE WATER IN PEDESTAL FROM FLOODING AND LARGE RFV FAILURE 32 * 3 LG_VF
	ī.	0.		RPV DEPRESSURIZED AT VESSEL FAILURE
	1 13 1 LO_PRES		10.02	- ADDRESSES ALL OTHER SEQUENCES
	0. OTHERWISE 0.	1.	57	S SHOULD NEVER GO THIS PATHWAY
35	2 'STM_EXP' 2 1	TTY STEAM EXPLOSTION		- STM_EXP
4	1 32 2 NO_FAIL 0.	1.		S DEBRIS COOLED IM-VESSEL S THEREFORE NO STM EXPLOSION

H.2 - 25

S NO WATER IN CAVITY PRIOR TO RPV FAILURE S THEREFORE NO STM EXPLOSION 33 4 2 33 2 RPV WTR RPV+INJ 1. 0. 31 \$ IN-VESSEL STEAM EXPLOSION FAILED VESSEL + 4 \$ - THEN ASSUME LARGE EX-VESSEL STEAM 31 3 31 1 3 LARGE VF SMALL VF S EXPLOSION CANNOT OCCUR ALPHA 1. 0. S WATER IN CAVITY OTHERVISE .86 .14 36 PEDESTAL FAILURE DUE TO STEAM EXPLOSION - PED EXP 2 'PED FAIL' 'NO' 2 2 1 3 S IN-VESSEL STEAM EXPLOSION CAUSED 1 31 S LARGE BOTTOM HEAD FAILURE 3 LARGE VF .5 S GRAND GULF 4551 #'S .5 ŝ .05 .95 S NO EX-VESSEL STEAM EXPLOSION 1 35 2 NO EXP ō. 1. S EX-VESSEL STEAM EXPLOSION OCCURRED **OTHERWISE** .5 .5 Ś .05 .95 - DW PED DRYWELL FAILURE DUE TO PEDESTAL FAILURE 37 2 'DW FAIL' 'NO' 2 Ī 2 2 S PEDESTAL FAILURE HAS RESULTED FROM 2 34 1 36 S OTHER THAN AN ALPHA MODE FAILURE 1 PED FAIL PED FAIL .825 .175 S PEDESTAL FAILURE HAS NOT OCCURRED OTHERVISE 1. 0. - DV OP 1.7.YTELL OVERPRESSURE FAILURE AT RPV FAILURE 8 2 'by FAIL' 1 NO1 2 1 2 3 \$ DEBRIS COOLED IN-VESSEL 1 32 S THEREFORE NO DV FAILURE 2 NO FAIL ō. 1. S HIGH PRESSURE SEQUENCE, 2 13 32 S LARGE RPV FAILURE SIZE 2 3 ·/ PEES LG VF

,99 .01 OTHERVISE 0. 1. DRYVELL FAILS AT/NEAR TIME OF RPV FAILURE - EARLY DV 39 'NO' 2 'DV FAIL' 2 2 3 S DEBRIS COOLED IN-VESSEL 32 1 S THEREFORE NO VESSEL FAILURE 2 NO FAIL ō. 1_{∞} 38 \$ ALPHA FAILURE, PEDESTAL FAILURE OR 1 \$ OVERPRESSURE HAS FAILIED THE DRYVELL 37 3 30 1 1 DV_FAIL DW FAIL ALPHA 0. 1. S NO DRYVELL FAILURE OTHERVISE 1. 0. S Ś S CET EVENT 5 MODE OF CONTAINMENT FAILURE AT/NEAR RPV FAILURE ********* CF VB \$ Š - ST VB CONTAINMENT STEAM CONCENTRATION AT/NEAR RPV FAILURE 40 6 '0-15%' '15-25%' '25-35%' '35-45%' '45-55%' '> 55%' 5 6 2 3 4 2 1 6 S DESIGN SPRAY COOLING OFERATION 18 1 2 SPRAY 0. 0. 0. 0. 0. 2. 2 - 3 6 S SBO EVENT, 1 \$ INJECTION FAILURE TIME: NO INJECTION 1 NO INJECT SBO 0. 0. 0. 0. 1. 0. 6 \$ SBO EVENT, 2 3 2 S INJECTION FAILURE TIME: RCIC 1 SBO RCIC 0. 0. 0. .44 .56 0. \$ SBO EVENT, 3 6 2 S INJECTION FAILURE TIME: HPCS 3 1 SBO HPCS 0. 0. 1. 0. 0. 0. S CON INMENT FAILED AT CORE DAMAGE 1 2 2 FAILED 0. 0. 1. 0. 0. 0. S UTHER NON-SBO TYPE EVENTS OTHERVISE

H.2 - 27

Mr. Comment

1. 0. 0. 0. 0. 0. FRACTION ZIRCONIUM INVENTORY REACTED AT/NEAR RPV FAILURE 41 - H2_VB 122%' 11%' 3 '33%' 2 1 3 2. 4 2 3 6 S SBO EVENT 1 1 S INJECTION FAILURE TIME: NO INJECTION SBO NO INJECT 0. 0. 1. 3 2 6 S SBO EVENT 2 1 S INJECTION FAILURE TIME: RCIC RCIC SBO 0. .31 . 69 3 2 6 S SBO EVENT 3 S INJECTION FAILURE TIME: HPCS 1 SBO HPCS 0. .21 .79 OTHERVISE S BOUND OTHERS WITH DISTRIBUTION 0. .31 ,69 S FOR SBO WITH RCIC INJECTION FAILURE 42 HYDROGEN IGNITION SOURCES AVAILABLE AT/BEFORE RPV FAILURE - IG SOURC 2 'NO IG SRC' IGNIT SRC' 2 1 2 4 1 16 S H2 IGNITORS AVAILABLE EARLY 2 HIS ON 0. 1. S HIS NOT AVAILABLE EARLY DUE TO HI S (OPERATOR FAILS TO INITIATE HIS) \$ NO LOSS OF AC POWER, AND RECOVERY 3 \$ OF HIS BEFORE CNTMT [H2] EXCEEDS 3 16 3 1 /1 * /5 \$ H2 DEFLAGRATION OVERPRESSURE LIMIT HIS OFF not SBO not SBO & LOOP .1 . 9 21 2 + 2 22 \$ H2 BURN BEFORE RPV FAILURE 2 LG BURN SMALL BRN 0. 1. OTHERWISE S NO CONTINUOUS IGNITION SOURCE AVAILABLE 1. 0. HIGH PRESSURE MELT EJECTION AT RPV FAILURE 43 2 'HPME' 'NO HPME' 2 1 2 3 1 32 S NO VESSEL FAILURE 2 NO_FAIL

0. 1. S LOW RPV PRESSURE AT RPV FAILURE 1 13 1 LOV_PRES 1. S RPV FAILURE AT HIGH PRESSURE OTHERVISE .2 .8 LARGE H2 BURN IGNITED AT/NEAR RPV FAILURE - LG BRN 44 2 'NO BRN IG' 'LG BRN IG' 2 4 1 48 \$ CONTINUOUS IGNITION SOURCE AVAILABLE 42 1 2 IGNIT_SRC 1. 0. 2 2 0. 0. 4 0. 0. S IF > 55% STEAM 7 JEN INERT 40 1 6 ---3 0. (m, \bar{n}) 2 2 0. 0. 4 0. 0. \$ 0-15% STEAM AND \$ 33% ZIRC OXIDATION AT RPV FAIL S AND DW FAILED OR AC POWER RECOVERED \$ [H2] = 21.7% 39 7 40 41 4 1) 1 法 1 11 + 0-15% 33% L'V FAIL PRIOR RV 1. 0. 2 2 0. 147. 4 0. 13. 43 \$ 0-15% STEAM AND 41 3 40 1 S 33% ZIRC OXIDATION AT RPV FAIL 1 1 演 33% HPME \$ AND HPME 0-15% \$ [H2] = 21.7% .63 .37 2 2 0. 151. 0. 17. 4 S 0-15% STEAM AND 40 41 2 \$ 33% ZIRC OXIDATION AT RPV FAIL 1 1 * S NO DW FAILURE, NO AC POWER, NO HPME 33% 0-152 .49 \$ [H2] = 21.7% .51 2

2 4	0. 0.	147. 13.		
4 40 2 15-25% 0. 2 2 4	* 0. 0.	41 1 33% 1. 131. 20.	•	<pre>\$ 15-25% STEAM AND \$ 33% ZIRC OXIDATION AT RPV FAIL \$ AND DW FAILED OR AC POWER RECOVERED \$ [H2] = 18.8% 39 7 (1 + 1) DW_FAIL PRIOR RV</pre>
3 40 2 15-25% .37 2	*	41 1 33% .63		43 \$ 15-25% STEAM AND 1 \$ 33% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME \$ [H2] = 18.8%
2 4	0. 0.	135. 24.		
2 40 2 15-25% .51		41 1 33% .49		\$ 15-25% STEAM AND \$ 33% ZIRC OXIDATION AT RPV FAIL \$ NO DV FAILURE, NO AC POWER, NO HPME \$ [H2] = 18.8%
2 2 4		131. 20.		
4 40 3 25-35% 0.	•	41 1 33% 1.	*	\$ 25-35% STEAM AND \$ 33% ZIRC OXIDATION AT RPV FAIL \$ AND DW FAILED OR AC POWER RECOVERZD \$ [H2] = 16.4% 39 7 (1 + 1) DW_FAIL PRIOR_RV
2 2 4	0. 0.	120. 26.		
3 40 3 25-35% .37 2	•	41 1 33% .63	•	43 \$ 25-35% STEAM AND 1 \$ 33% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME \$ [H2] = 16.4%
2	0. 0.	124. 30.		
2 40 3 25-35%	•	i 33%		S 25-35% STEAM AND S 33% ZIRC OXIDATION AT RPV FAIL S NO DW FAILURE, NO AC POVER, NO HPME



.49 S [H2] = 16.4% .51 2 2 0. 120. 0. 26. 4 \$ 35-45% STEAM AND \$ 33% ZIRC OXIDATION AT RPV FAIL S AND DV FAILED OR AC POVER RECOVERED S [H2] = 14.1% 4 40 41 4 * 1 DV FAIL PRIOR RV 35-45% 33% 0. 1. 2 2 113. 0. 0. 4 43 \$ 35-45% STEAM AND 41 3 40 1 1 \$ 33% ZIRC OXIDATION AT RPV FAIL 4 33% HPME S AND HPME 35-45% . 44 .56 S [H2] = 14.1% 2 2 0. 117. - 4 0. 39. 2 40 41 \$ 35-45% STEAM AND \$ 33% ZIRC OXIDA AT RPV FAIL \$ NO DV FAILURE, FOWER, NO HPME 4 1 * 33% 35-45% .38 S [H2] = 14.1% . 62 2 2 0. 113. 4 0. 35. S 45-55% STEAM AND \$ 33% ZIRC UXIDATION AT RPV FAIL S AND DV FAILED OR AC POVER RECOVERED \$ [H2] = 11.7% 41 4 40 5 1 * DW FAIL PRIOR RV 33% 45-55% 0. 1. 2 2 0. 109. 46. 4 0. 43 \$ 45-55% STEAM AND 1 \$ 33% ZIRC OXIDATION AT RPV FAIL 3 40 41 5 1 33% HPME S AND HPME 45-55% . 57 .43 \$ [H2] = 11.7% 2 2 113. 50. 4 0. S 45-55% STEAM AND 41 2 40

5 45-55% .72 2	*	1 33% .28		\$ 33% ZIRC OXIDATION AT RFV FAIL \$ NO FAILURE, NO AC POWER, NO HPME \$ [H2] = 11.7%
2 4	0. 0.	109. 46.		
				<pre>\$ 0-15% STEAM AND \$ 22% ZIRC OXIDATION AT RPV FAIL \$ AND DV FAILED OR AC POWER RECOVERED \$ [H2] = 15.7%</pre>
4 40 1 0-15% 0. 2	*	41 2 22% 1.	*	39 7 (1 + 1) DW_FAIL PRIOR_BV
2	0. 0.	104. 11.		
3 40 1 0-15% .44 2	*	41 2 22% .56	*	43 \$ 0-15% STEAM AND 1 \$ 22% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME \$ [H2] = 15.7%
2	0. 0.	108. 15.		
2 40 1 0-15% .62 2	*	41 2 22% .38		<pre>\$ 0-15% STEAM AND \$ 22% ZIRC OXIDATION AT RPV FAIL \$ NO DW FAILURE, NO AC POWER, NO HPME \$ \$ [H2] = 15.7%</pre>
2 4	0. 0.	104. 11.		
				\$ 15-25% STEAM AND \$ 22% ZIRC OXIDATION AT RPV FAIL \$ AND DW FAILED OR AC POWER RECOVERED \$ [H2] = 13.6%
4 40 2 15-25% 0. 2	*	41 2 22% 1.	*	39 7 (1 + 1) D'_FAIL PRIOR_RV
2 4	0. 0.	94.3 17.		
3 40 2 15-25% .44 2	*	41 2 22% .56	*	43 \$ 15-25% STEAM AND 1 \$ 22% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME \$ [H2] = 13.6%
2 4	0. 0.	98.3 21.		

41 2 S 15-25% STEAM AND 2 40 * S 22% ZIRC OXIDATION AT RPV FAIL 22% S NO DW FAILURE, NO AC POWER, NO HPME S 15-25% . 62 .38 S [H2] = 13.6% 2 2 94.3 0. 0. 17. 4 S 25 35% STEAM AND S 22% ZIRC OXIDATION AT RPV FAIL S AND DW FAILED OF AC POWER RECOVERED S [H2] = 11.9% 39 7 (1 + 1) 41 4 40 2 - 3 -DW FAIL PRICE RV 22% 25-35% 0. 1. 2 2 83.3 0. 23. 4 0. 43 \$ 25-35% STEAM AND 3 40 41 2 1 \$ 22% ZIRC OXIDATION AT RPV FAIL 3 * 22% HPME S AND HPME 25-35% \$ [H2] = 11.9% .43 .57 2 87.3 2 0. 4 27. 0. S 25-35% STEAM AND 41 2 40 2 \$ 22% ZIRC OXIDATION AT RPV FAIL 3 * S NO DW FAILURE, NO AC POWER, NO HPME 25-35% 22% .72 S [H2] = 11.9% .28 2 83.3 2 0. 23. 4 0. \$ 35-45% STEAM AND \$ 22% ZIRC OXIDATION AT RPV FAIL S AND EU FAILED OR AC POWER RECOVERED S [H2] = 10.2% 39 7 (1 + 1) 4. 40 4 4 * DW HAIL PRIOR RV 35-45% 0. 1. 2 2 0. 80.8 31. 4 Ga 41 43 \$ 35-45% STEAM AND 2 * 1 \$ 22% ZIRC OXIDATION AT RPV FAIL 22% HPME \$ AND HPME 3 40 4 Q. 35-45% S[H2] = 10.2%.57 .43 2

2 4	0. 0.	84.8 35.		
2 40 4 35-45% .72 2	*	41 2 22% .28		\$ 35-45% STEAM AND \$ 22% ZIRC OXIDATION AT RPV FAIL \$ NO DW FAILURE, NO AC POWER, NO HPME \$ [H2] = 10.2%
	0. 0.	80.8 31.		
45-55%	*	22%	*	\$ 45-55% STEAM AND \$ 22% ZIRC OXIDATION AT RPV FAIL \$ AND DW FAILED OR AC POWER RECOVERED \$ [H2] = 8.5% 39 7 (1 + 1) DW_FAIL PRIOR_RV
0. 2 2 4	0. 0.	1. 80.8 41.		
3 40 5 45-55% .57 2	*	41 2 22% .43		43 \$ 45-55% STEAM AND 1 \$ 22% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME \$ [H2] = 8.5%
	0. 0.	84.8 45.		
2 40 5 45-55% .72 2	*	41 2 22% ,28		\$ 45-55% STEAM AND \$ 22% ZIRC OXIDATION AT RPV FAIL \$ NO DW FAILURE, NO AC POWER, NO HPME \$ [H2] = 8.5%
2 4	0. 0.	80.8 41.		
				\$ 0-15% STEAM AND \$ 11% ZIRC OXIDATION AT RPV FAIL \$ AND DW FAILED OR AC POWER RECOVERED \$ [H2] = 8.6%
4 40 1 0-1.5% 0.	*	41 11% 1.	*	39 7 (1 + 1) DW_FAIL PRIOR_RV
2 4	0. 0.	38.2 8.4		
3 40 1 0-15%	*	41 3 11%	*	43 \$ 0-15% STEAM AND 1 \$ 11% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME

.57 .43 S [H2] = 8.6% 2 42.2 2 0. 4 0. 12.4 41 S 0-15% STEAM AND 2 40 3 S 11% ZIRC OXIDATION AT RPV FAIL 1 * 11% \$ NO DV FAILURE, NO AC POWER, NO HPMF 0-15% .73 .28 S [H2] = 8.6% 2 38.2 2 0. 4 0. 8.4 \$ 15-25% STEAM AND S 11% ZIRC OXIDATION AT RPV FAIL \$ AND DV FAILED OR AC POWER RECOVERED \$ [H2] = 7.4% 4 40 41 2 3 DW FAIL PRIOR RV 15-25% 11% 0. 1. 2 36.2 2 0. 14. 4 0. 41 3 11% 43 \$ 15-25% STEAM AND 3 40 1 S 11% ZIRC OXIDATION AT RPV FAIL 2 15-25% HPME \$ AND HPME .71 .29 S [H2] = 7.4% 2 2 40.2 0. 4 18. 0. 2 40 41 \$ 15-25% STEAM AND 2 3 S 11% ZIRC OXIDATION AT RPV FAIL * 11% 15-25% S NO DW FAILURE, NO AC POWER, NO HPME .79 .21 S [H2] = 7.4% 2 2 36.2 0. 4 0. 14. S 25-35% STEAM AND \$ 11% ZIRC OXIDATION AT RPV FAIL S AND DW FAILED OR AC POWER RECOVERED S [H2] = 6.5% 39 7 (1 + 1) 4 40 41 3 3 DW FAIL PRIOR RV 25-35% 11% 0. 1. 2 2 37.3 0. 19. 0. 4 41 43 S 25-35% STEAM AND 3 40

25-35% .71 2	*	11%		1 \$ 11% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME \$ [H2] = 6.5%
2 4	0, 0,	41.3 23.		
2 40 3 25-35% .79	*	41 3 112 .21		S 25-35% STEAM AND S 11% ZIRC OXIDATION AT RPV FAIL S NO DW FAILURE, NO AC POWER, NO HPME S [H2] = 6.5%
2	0. 0,	37.3 19.		
				\$ 35-45% STEAM AND \$ 11% ZIRC OXIDATION AT RPV FAIL \$ AND DV FAILED OR AC POWER RECOVERED \$ [H2] = 5.6%
4 40 4 35-45% 0. 2	*	41 3 11% 1.	*	39 7 (1 + 1) DV_FAIL PRIOR_RV
2 4	0, 0,	40.8 27.		
3 40 4 35-45% .71	*	41 3 11% .29	*	43 \$ 35-45% STEAM AND 1 \$ 11% ZIRC OXIDATION AT RPV FAIL HPME \$ AND HPME \$ [H2] = 5.6%
2 2 4	0. 0.	44.8 31.		
2 40 4 35-45% .79	×	41 3 11% .21		\$ 35-45% STEAM AND \$ 11% ZIRC OXIDATION AT RPV FAIL \$ NO DW FAILURE, NO AC POWER, NO HPME \$ [H2] = 5.6%
2 2 4	0. 0.	40.8 27.		
4 40		41		<pre>\$ 45-55% STEAM AND \$ 11% ZIRC OXIDATION AT RPV FAIL \$ AND DW FAILED OR AC POWER RECOVERED \$ [H2] = 4.6% 39 7</pre>
5 45-55% 0, 2	*	3 11% 1.	*	(1 + 1) DW_FAIL PRIOR_RV
2 4	0. 0.	46.1 36.		

41 43 \$ 45-55% STEAM AND * 3 * 1 \$ 11% ZIRC OXIDATION AT RPV FAIL 11% HPME \$ AND HPME .29 \$ [H2] = 4.6% 3 40 5 * 45-55% .71 2 2 50.1 0. 40. 4 0. 41 3 11% \$ 45-55% STEAM AND \$ 11% ZIRC OXIDATION AT RPV FAIL 2 40 5 * \$ NO DV FAILURE, NO AC POVER, NO HPME 45-55% .21 S[H2] = 4.6%.79 2 2 0. 46.1 4 0. 36. S SHOULD NEVER GO THIS PATH OTHERWISE . 1. 0. 2 2 0. 0. 4 0. 0. 45 CONTAINMENT FAILURE DUE TO H2 DETONATION AT/NEAR RPV FAILURE - H2 DET 2 'DET CF' 'NO' 2 2 1 10 S NO LARGE BURN IGNITED 1 44 1 NO BRN IG 0. 1. 40 40 \$ IF > 35% STEAM THIN INERT TO 5 + 6 \$ DETONATIONS 3 40 4 35-45% > 55% 45-55% 0. 1. S > 33% ZIRC OXIDATION S (> 20% H2 CONC) AND S HIGH STEAM (POWER RECOV + SPRAY) S NO EARLY INJECTION FAILURE SINCE THE S STEAM CONC IS 'OW FOR THAT SEQUENCE 7 18 6 1 * 2 * /1 PRIOR_RV SPRAY not NO_INJECT 5 41 1 4 33% 3 1 SBO .025 .975 41 1 33% S > 33% ZIRC OXIDATION 2 40 1 \$ (> 20% H2 CONC) AND S LOW STEAM 0-15% .73 .27

 40
 40
 41 \$> 33% ZIRC OXIDATION

 (2 + 3)
 * 1 \$ (16-20% H2 CONC) AND

 15-25%
 25-35%

 33% \$ LOW STEAM

 3 40 (2

.16 .84 1 41 \$ 11% ZIRC OXIDATION 3 \$ (<12% H2 CONC) 11% 0. 1. S 22% ZIRC OXIDATION \$ (12 - 16% [H2]), AND HI STEAM \$ (POWER WITH SFRAY MODE) NO EARLY INJECT S FAILURE SINCE [ST] IS LOW 5 41 2 * 22% .022 18 7 18 6 2 * /1 3 1 * 1 SBO PRIOR RV SPRAY not NO INJECT .978 3 40 (2 40 3) * 41 S 22% ZIRC OXIDATION 2 \$ (12-16% [H2]), AND LOW STEAM 15-25% 25-35% 22% 0. 1. 2 40 1 * 41 \$ 22% ZIRC OXIDATION 2 \$ (16-20% [H2]), AND LOW STEAM 0-15% 22% .16 .84 OTHERVISE S SHOULD NEVER REACH THIS CASE 0. 1.0 CONTAIMENT FAILURE AT/NEAR RPV FAILURE 46 2 'FAILURE' 'NO FAILUR' 1 2 6 3 1 30 S ALPHA MODE FAILURE 1 ALPHA 1 2 BURNPRES MAX GETHRESH 1 -1. ALPHA (FORCE FIRST BRANCH) 1 45 S DETONATION FAILURE 1 DET CF 1 2 BURNPRES MAX GETHRESH 1 -1. DETONATION (FORCE FIRST BRANCH) OTHERWISE 1 2 BURNPRES FUN-F BURN EQUAL 0

```
CALCULATE PROB OF CONT FAILURE (ANY MODE) GIVEN BURN PRESSURE
                                                               - CF VB
    MODE OF CONTAIMENT FAILURE AT/NEAR RPV FAILURE
47
   2 'ANCHORAGE' 'PN-D/NoCF'
                     2
   6
      1
 3
                                 S CNTMT NOT FAILED BY ALPHA OR H2 BURN
   1
      46
      2
     NO FAILUR
      1 2
        BURNPRES
        MAX
        GETHRESH 1 1.E20
      NO FAILURE CASE
   2 45 30
                                 S DETONATION OR ALPHA MODE
                                 S FAILURE OF CONTAINMENT
      1 +
               1
     DET CF
              ALPHA
      1 2
        BURNPRES
       MAX
        GETHRESH 1 1.E20
      H2 DETONATION OR ALPHA MODE FAILURE -- FORCE SECOND BRANCH
    OTHERWISE
          2
      1
        BURNPRES
        FUN-F MODE
        EQUAL O
      GET MODE OF CONTAINMENT FAILURE
Ś
S
$
Ś
   DRYWELL FAILURE DUE TO CONTAINMENT H2 BURN BEFORE/NEAR RPV FAILURE - H2BURN
48
   2 'DW FAIL' 'NO DW FL'
                     2
   6
         1
 3
                                  S LARGE BURN IN CNTMT BEFORE RPV FAILURE
   1 22
      2
     LG BURN
       2
        1
                      3
        BURNPRES CNTNT PRESSURE
        FUN-DVDELP
        EQUAL O
      PROB OF CNTMT BURN FAILING DRYVELL
                                  S LARGE BURN IN CNTMT AT RPV FAILURE
   1 44
      2
     LG BRN IG
       2
           2
                      4
        BURNPRES CONT PRESSURE
```

```
FUN-DVDELP
        EQUAL O
      PROB OF CNTMT BURN FAILING DRYWELL
                  $ NO LARGE BURNS IN CNTMT BEFORE/AT/
    OTHERWISE
                  4
                                S NEAR RPV FAILURE
     2 2
        BURNPRES CNTMT PRESSURE
        MAX
        GETHRESH 1 1.E20
      NO CNTMT H2 BURN (FORCE SECOND BRANCH)
49 POOL BYPASS BEFORE/NEAR RPV FAILURE
                                                           - POOL BYP
   2 'POOL BP' 'NO PL BP'
   2 1
                   2
 5
                                S DRYVELL FAILURE BY PROCESSES INSIDE DW
   1 39
     1
     DW FAIL
     ī.
                  0.
                                S DRYWELL FAILURE BY CNTMT H2 BURN
   1 48
     1
     DV FAIL
     ī.
                  0.
                47
                                S POOL BYPASS BY CONTAINMENT
   2 25
     1
                                S ANCHORAGE FAILURE
                1
            4
     ANCHORAGE
                ANCHORAGE
     1.
                0.
                                 S VACUUM BREAKERS FAILING OPEN FOR
                                 $ SEQUENCES WITH AC POWER (HENCE
                                 S VB ISO VALVES ARE OPEN
                                 S AND LARGE H2 BURN OCCURS IN CNTHT
    8 22 44 3
    LG_BURN LG_BRN OTHER TYPES CRIT_ATWS OTHERS SBO LOOP_&_SBO PRIOR_RV
.05 .95
                                 S BYPASS FOR SEQUENCES WITH VB ISOLATED
    OTHERWISE
       .0001
                   .9999
Ś
S
S CET EVENT 7 INJECT & SPRAY FAILURE DUE TO CNTMT FAIL BEFORE/NEAR RPV FAILURE
S
                                                           -INJ/FAL2
S
S
S
50 CNTMT FAILURE AT/NEAR RPV FAILURE IMPACT ON ECCS INJECTION AND SPRAY PIPING
                                                           - PIPE FAL
S
   2 'NO FAILUR' 'FAILUR'
   2 1
                   2
  2
                                 S ANCHORACE CNTMT FAILURE
    1 47
     1
```

```
ANCHORAGE
                  .9
     .1
    OTHERVISE
                                $ NOT ANCHORAGE
      1.
                0.
    CNTMT FAILURE AT/NEAR RPV FAILURE IMPACT ON ECCS INJECTION AND SPRAY MOTORS
51
S
                                                            - MTR FAIL
   2
    'NO FAILUR' 'FAILUR'
      ī
   2
                  2
 2
   2
                  50
                               S CNTMT FAILURE AND NO PIPING FAILURE
     46
      1 *
                 1
      FAILURE
              NO FAILUR
                .5
       .5
     OTHERWISE
                                 S NO CNTMT FAILURE
                  0.
      1.
    CNTMT FAIL AT/NEAR RPV FAILURE STEAM/RADIATION RELEASE IMPACT ON FIREWATER
52
S
                                                             - STM/RAD
      'NO FAILUR'
                 'FAILUR'
   2
      1
   2
                 2
 2
   2
     46
                 50
                                S CNTMT FAILURE AND NO PIPING FAILURE
     1 *
                1
                 NO FAILUR
      FAILURE
                 .5
      .5
    OTHERWISE
                                 $ NO CNTMT FAILURE
                  0.
      1.
53
    INJECT & SPRAY FAILURE DUE TO CNTMT FAILURE AT/NEAR RPV FAILURE
                                                           - INJ/SP FL
Ś
   2 'NO FAILUR' 'INJ&SPY F'
   2 1
                    2
  3
   1 50
                                 S ECCS INJ & SPRAY PIPING FAILURE DUE TO
                                  S CNTMT FAILURE AT/NEAR RPV FAILURE
      2
     FAILUR
      0.
                   1.
                                 S ECCS INJECTION & SPRAY MOTORS FAILURE,
   2 51
                  52
      2
                   2
                                  S AND FIREWATER INJECTION FAILURE
     FAILUR
               FAILUR
     0
                   1.
                                  $ ALL INJECT NOT FAILED AT/NEAR
    OTHERWISE
                                  S RPV FAILURE
                   0.
      1.
Ś
S
S
Ś
                                                            - CCI TYPE
54
   TYPE OF DEBRIS CONCRETE INTERACTIONS
Ś
   4 'DRY-CCI' 'FAST-WET' 'SLOW-WET' 'NO-CCI'
```

```
H.2 - 41
```

2	1		2	3	4
11	32			1	\$ NO VESSEL FAILURE
	NO FAIL		0.	0.	1.
3	33 4 RPV_VTR 1.	•	(2 RPV+INJ	* 2) 1	\$ NO WATER IN CAVITY NEAR TO RPV FAILURE \$ DUE TO ONLY RPV WATER OR SUBSEQUENT \$ FAILURE OF RPV+INJ DUE TO CNTMT FAILUR 0.
4	33 (3 FLD 0.	+	FLD+INJ		HPME
5	33 (3 FLD 0.	•	33 (1 FLD+INJ .28		S WATER IN CAVITY AT RPV FAILURE S NO INJECTION TO CAVITY OR INJ FAILURE S NEAR RPV FAILURE DUE TO CNTMT FAILURE S NO HPME - LARGE MOLTEN MASS 43 14) * 2 * 1 NO_HPME LG_DEB .24
5	33 (3 + FLD 0,		33 (1	53	S WATER IN CAVITY PRICE RPV FAILORE \$ NO INJECTION TO CAVITY OR INJ FAILS \$ AT RPV FAILURE DUE TO CONT FAILURE \$ NO HPME - SMALL MOLTEN MASS 43 14) * 2 * 2
3	33 (2 RPV+IN 0.	*	53 1) NO_FAILUR .315	* 1	<pre>\$ NO WATER 'N CAVITY AT RPV FAILURE \$ CONTINUOUS INJECTION TO CAVITY 3 AND HPME .2075</pre>
51	33 (2 RPV+IN 0.			* 2	\$ NO WATER IN CAVITY AT RPV FAILURE \$ CONTINUOUS INJECTION TO CAVITY \$ AND NO HPME .1875
	33 (1 FLD+IN 0.	* IJ	53 1) NO_FAILUR .175	* 1	\$ WATER IN CAVITY AT RPV FAILURE S CONTINUOUS INJECTION TO CAVITY S AND HPME OCCURS .3375

S WATER IN CAVITY AT RPV FAILURE S CONTINUOUS INJECTION TO CAVITY S NO HPME & LARGE MOLTEN MASS 43 14 2 * 1 NO HPME LG_DEB .48 .24 4 33 53 (1 * 1) FLD+INJ NO FAILUR 0. .28 S WATER IN CAVITY AT RPV FAILURE \$ CONTINUOUS INJECTION TO CAVITY S NO HPME & SMALL MOLTEN MASS

 33
 53
 43
 14

 (1 * 1) * 2 * 2
 2

 FLD+INJ NO_FAILUR
 NO_HPME
 SM_DEB

 0.
 .28
 .48
 .24

 4 33 53 (1 * 1) * \$ SHOULD NEVER TAKE THIS PATH 0. 0. OTHERWISE 1. 0. 55 PEDESTAL FAILURE DUE TO CORE DEBRIS CONCRETE INTERACTION - PED FAIL 3 'AT VB' 'AFTER VB 'NO_FAILUR' 2 1 2 3 2 1 7 48 1 S DRYWELL FAILURE BY PROCESSES INSIDE DW 2 39 S OP BY H2 BURN IN CONTAINMENT 1 DW FAIL DV FAIL ī. 0. 0. S NO VESSEL FAILURE 1 32 2 NO FAIL Õ. 0. 1. \$ DRY CCI 1 54 1 DRY-CCI .43 .57 0. S FAST WET CCI 1 54 2 FAST-VET .71 .29 0. S SLOW WET CCI 1 54 3 SLOW WET .75 .25 0. S NO CCI 1 54 4 NO CCI õ. 0. 1. S SHOULD NEVER GO THIS PATH OTHERWISE 1. 0.

ŝ ŝ Ś Ś - DE INERT MODE OF RHR SPRAY OPERATION LATE 56 3 'CONTROLD' 'SPRAY ' 'NO SPRAY' 2 3 2 1 5 S RHR SPRAYS NOT AVAILABLE 1 8 /1 not RHR SPRY 1. 0. 0. S IF AC POWER NEVER LOST AND 8 2 3 /1 S RHR SPRAY AVAIABLE 1 * not SBO RHR SPRY ī. 0 .0 8 \$ IF AC POWER LOST AND RECOVERED
 * 1 \$ BEFORE RPV FAILURE AND 7 3 3 1 1 RHR SPRY S RHR SPRAY AVAILBLE PRIOR RV SBO -0. 1. 0. B S IF AC POWER LOST AND RECOVERED 7 3 3 * 1 S BEFORE CNTMT THRESHOLD LIMIT AND 2 1 RHR STRY S RHR SPRAY AVAILABLE CNTMT LIM SBO е. 1. 0. S SHOULD NEVER GO THIS WAY OTHERWISE 0. 1. 0. - IG SOURC 57 HYDROGEN IGNITION SOURCES AVAILABLE LATE 2 'NO SOURCE' 'IGN SOURC' 2 1 2 5 S IGNITORS AVAILABLE EARLY 1 16 2 HIS ON 1. 0. S HIS NOT AVAILABLE EARLY DUE TO HI S (OPEPATOR FAILS TO INITIATE HIS) S NO LUSS OF AC POWER, AND RECOVERY 3 S OF HIS BEFORE CNTMT [H2] EXCEEDS 3 3 16 * /5 \$ H2 DEFLAGRATION OVERPRESSURE LIMIT 1 * /1 HIS OFF not SBO not SBO & LOOP .1 .9 S LOSS OF AC POWER AND 7 3 2 S POWER RECOVERY FRIOR PRIOR RPV FAILURE 1 1 PRIOR RV SBO .5 .5 S SENSITIVITY FOR HIS BACKUP POWER 1. S 0.

S LOSS OF AC POWER AND 7 3 2 2 1 S POVER RECOVERY PRIOR CONTAINMENT LIMIT SBO CNTMT LIM 1. 5 SENSITIVITY FOR HIS BACKUP POWER 0. 1. Ś 0. S LOSS OF AC POWER NO RECOVERY OTHERWISE 1. 0. S SENSITIVITY FOR HIS BACKUP POWER 1. Ś 0. - ST CONC CONTAINMENT STEAM CONCENTRATION LATE 58 6 '0-15%' '15-25%' '25-35%' '25-45%' '45-55%' '> 55%' 2 1 2 3 4 5 6 S WJC REV 21APR1992 START 7 S DESIGN SPRAY OPERATION 1 56 2 SPRAY 0. 0. 0. 0. 0. 1. S BOUNDED BY SBO WITH INJECT FAILURE 1 5 S AND NO LATE INJECTION 2 NOT ISOL .25 .00 0. 0. .75 .00 6 1 2 3 S SBO EVENT 1 S INJECTION FAILURE TIME: NO INJECTION SBO NO INJECT 0. 0. 0. .99 .01 0. 6 2 3 S SBO EVENT 2 S INJECTION FAILURE TIME: RCIC 1 RCIC SBO. .71 0. 0. .29 0. 0. S SBO EVENT 2 3 6 S INJECTION FAILURE TIME: HPCS 3 1 HPCS SBO 0. 0. 1. 0. 0. 0. S CONTAINMENT FAILED AT CORE DAMAGE 1 2 2 FAILED 0. 0. 1. 0. 0. 0. S NON-SBO TRANSIENTS WITH INTACT CNTMT OTHERWISE 0. 0. 0. 0. 1. 0. - BURN B4 59 H2 COMBUSTION BEFORE/AT RPV FAILURE 2 'EARLY_BRN' 'NO_ERLY_B' 2 1 2 2 22 2 + 21 S SMALL OR LARGE BURN EARLY 3 44 2 + 2 LG BRN IG LG BURN SMALL BRN 1. õ.

OTHERVISE 0. 1. - H2 CONC CONTAINMENT H2 CONCENTRATION LATE 60 6 '< 4 %' '4-8 %' '8-12 %' '12-16 %' '16-20 %' ' > 20 %' 2 1 2 3 4 5 6 2 1 24 54 4 S H2 BURN EARLY 2 59 1 * S NO CCI EARLY BRN NO CCI .5 .5 0. 0. 0. 0. 59 54 1 * 3 EARLY_BRN SLOW-WET \$ H2 BURN EARLY 2 59 1 * S SLOW VET CCI .25 .1 0. .1 .25 .3 2 59 54 1 * 2 \$ H2 BURN EARLY \$ FAST WET CCI FAST-WET EARLY BRN .35 .35 0. 0. .1 .2 \$ H2 BURN EARLY, DRY CCI, NO SPRAY S SBO WITH NO INJECTION 56 3 6 3 * 1 * 1 NO_SPRAY SBO NO_INJECT .06 .06 .46 54 1 * 5 59 1 * DRY-CCI EARLY BRN 0. .35 .07 S H2 BURN EARLY, DRY CCI, NO SPRAY S SBO WITH RCIC FAILURE 56 3 6 3 * 1 * 2 NO_SPRAY SBO RCIC .36 0. 0. 54 1 5 59 1 DRY-CCI EARLY BRN .60 0. .04 \$ H2 BURN EARLY, DRY CCI, NO SPRAY S SBO WITH HPCS FAILURE 54 1 56 3 6 3 * 1 * 3 5 59 1 * 3 * 1 * 3 NO_SPRAY SBO HPCS 0. 0. 0. DRY-CCI EARLY BRN .64 .36 0. S H2 BURN EARLY, DRY CCI, SPRAY S SBO WITH NO INJECTION
 59
 54
 56
 3
 6

 1
 *
 1
 *
 1
 *
 1

 EARLY_BRN
 DRY-CCI
 SPRAY
 SB0
 NO_INJECT

 0.
 .36
 .07
 .06
 .06
 .45
 5 59 54 1 * 1 S H2 BURN EARLY, DRY CCI, NO SPRAY S SBO WITH RCIC FAILURE 3 6 56 3 2 * 1 * 2 54 5 59 1 1

EARLY_BRN DRY-CCI SPRAY SBO RCIC 0. .05 .43 .37 .14 .01 S H2 BURN EARLY, DRY CCI, NO SPRAY \$ H2 BURN EARLY, DRY CC1, NO\$ SBO WITH HPCS FAILURE5632*2*362*1*35PRAYSBOHPCS0.0. 54 1 5 59 1 * EARLY BRN DRY-CCI .38 .51 .11 S NO H2 BURN EARLY, NO CCI, NO SPRAY S SBO WITH NO INJECTION 56 3 6 3 * 1 * 1 NO_SPRAY SBO NO_INJECT 0. 0. 0. 5 59 54 2 * 4 * NO_ERLY_B NO-CCI 0. 1. 0. S NO H2 BURN EARLY, NO CCI, NO SPRAY S NO H2 BORN EARLY, NO CCI, P S SBO WITH RCIC FAILURE 56 3 6 3 * 1 * 2 NO_SPRAY SBO RCIC .2 0. 0. 5 59 54 2 * 4 * NO ERLY B NO.-CCI 0. 0. .8 \$ NO H2 BURN EARLY, NO CCI, NO SPRAY \$ SBO WITH HPCS FAILURE 56 3 6 3 * 1 * 3 NO_SPRAY SBO HPCS 0. 0. 0. 5 59 54 2 * 4 * NO_ERLY_B NO-CCI .59 .41 0. \$ NO H2 BURN EARLY, NO CCI, SPRAY \$ SEO WITH NO INJECTION 5 59 54 2 * 4 * NO_ERLY_B NO-CCI 0. 1. 0.
 56
 3
 6

 2
 *
 1
 *
 1

 SPRAY
 SBO
 NO_INJECT
 0.
 0.
 S NO H2 BURN EARLY, NO CCI, SPRAY
 S NO N2 BORN EARDI, NO COI,

 \$ SBO WITH RCIC FAILURE

 56
 3
 6

 2
 *
 1
 *
 2

 SPRAY
 SBO
 RCIC
 .38
 .06
 0.
 5 59 54 2 * 4 * NO_ERLY_B NO-CCI 0. 0, .56 S NO H2 BURN EARLY, NO CCI, SPRAY S SBO WITH HPCS FAILURE 5 59 54 56 3 6 2 * 4 * 2 * 1 * 3 NO_ERLY_B NO-CCI SPRAY SBO HPCS .33 .51 .16 0. 0. 0.

2 59 54 \$ NO H2 BURN EARLY 2 * 3 \$ SLOW_WET CCI

NO ERLY_B SLOW-WET 0. .1 .15 .25 .5 0. S NO H2 BURN EARLY 2 59 54 2 * 2 \$ FAST VET CCI NO_ERLY_B FAST-WET

0. 0. .1 .15 .75 0.

S NO H2 BURN EARLY, DRY CCI, NO SPRAY S SEO WITH NO INJECTION 56 3 6 3 * 1 * 1 NO_SPRAY SBO NO_INJECT .06 .04 .51 5 59 54 2 * 1 * NO_ERLY_B DRY-CCI 0. .30 .07

> S NO H2 BURN EARLY, DRY CCI, NO SPRAY S SBO WITH RCIC FAILURE 56 3 6 3 * 1 * 2 NO_SPRAY SBO RCIC .36 .04 0. .60

S NO H2 BURN EARLY, DRY CCI, NO SPRAY S SBO WITH HPCS FAILURE 56 3 6 3 * 1 * 3 NO_SPRAY SBO HPCS 0, 0, 0,

\$ NO H2 BURN EARLY, DRY CCI, SPRAY \$ SBO WITH NO INJECTION 56 3 6 2 * 1 * 1 SPRAY SBO NO_INJECT .06 .06 .50

S NO H2 BURN EARLY, DRY CCI, SPRAY S SBO WITH RCIC FAILURE 56 3 6 2 * 1 * 2 SPRAY SBO RCIC .42 .14 .01

\$ NO H2 BURN EARLY, DRY CCI, SPRAY \$ SBO WITH HPCS FAILURE 56 3 6 2 * 1 * 3 SPRAY SBO HPCS 0. 0. 0. NO ERLY B DRY-CCI
 .33
 .51
 .16
 0.
 0.
 0.

 OTHERWISE
 \$ SHOULD NOT TAKE THIS PATH
 \$ SHOULD NOT TAKE THIS PATH

 0.
 0.
 0.
 1.
 0.

61 AC POWER AVAILABLE LATE 2 'AC LATE' 'NO AC LAT'

5 59 54 2 * 1

NO ERLY B DRY-CCI

ō. ⁻⁻⁻ 0.

5 59 54 2 * 1

NU ERLY B DRY-CCI .59 .41 0.

5 59 54 2 * 1 * NO_ERLY_B DRY-CCI

59 54 2 * 1

5 59 54 2 * 1

NO ERLY B DRY-CCI 0. 0. .43

ū.

5 59

.31 .07

- AC_PWR

1 2 2 2 7 S SBO EVENT 2 3 S NO POWER RECOVERY 3 1 NO RECOV \$30 ī. 0. S AC POWER AVAILABLE LATE OTHERWISE 0. 1. - LG BRN 62 LARGE H2 BURN IGNITED LATE 2 'NO BURN' 'LG BURN' 4 1 2 54 S CONTINUOUS IGNITION SOURCE AVAILABLE 1 57 2 IGN SOURC 0. 2. 2 2 0. 0. 0. 4 0. S IF > 55% STEAM THEN INERT 1 58 6 > 55% 0. 1. 2 5 0. 0. 6 0. 0. S IF < 4 % H2 THEN NO BURN 1 60 1 < 4 % 0. 1. 2 5 0. 0. 0. 0. 6 60 61 \$ 0-15 % STEAM AND 2 * 2 \$ 4-8 % H2 IN CNTMT = 6% H2 4-8% NO_AC_LAT \$ NO AC POWER LATE 3 58 1 * 0-15% .71 .29 2 5 0. 19.4 7.6 0. 6 60 61 \$ 0-15 % STEAM AND 3 * 2 \$ 8-12 % H2 IN CNTMT = 10% H2 8-12% NO_AC_LAT \$ NO AC POWER LATE 3 58 1 0-15% .67 .33 2 0. 51.6 0. 8.8 S 6 60 61 \$ 0-15% STEAM AND 3 58

. 58	*	4 12-15% .42	* 2 \$ 12-16 % H2 IN CNTMT = 14% H2 NO_AC_LAT \$ NO AC POWER LATE
		92.6 10.	
3 58 1 0-15% .49 2	*	60 5 16-20% .51	61 \$ 0-15% STEAM AND * 2 \$ 16-20% H2 IN CNTMT = 18% H2 NO_AC_LAT \$ NO AC POWER LATE
5	0. 0.	121. 11.	
3 58 1 0~15% .49 2	*	6 > 20%	61 \$ 0-15% STEAM AND * 2 \$ > 20 % H2 IN CNTMT = 24% H2 NO_AC_LAT \$ NO AC POWER LATE
5 6	0. 0.	166. 14.	
3 58 2 15-25% .71	*	60 2 4-8% .29	61 \$ 15-25% STEAM AND * 2 \$ 4-8 % H2 IN CNTMT = 6% H2 NO_AC_LAT \$ NO AC POWER LATE
		26.7 13.	
3 58 2 15-25% .67 2	•	60 3 8-12% ,33	61 \$ 15-25% STEAM AND * 2 \$ 8-12 % H2 IN CNTMT = 10% H2 NO_AC_LAT \$ NO AC POWER LATE
5 6	0. 0.	59.7 15.	
3 58 2 15-25% .58 2		4	61 \$ 15-25% STEAM AND * 2 \$ 12-16 % H2 IN CNTMT = 14% H2 NO_AC_LAT \$ NO AC POWER LATE
5		96.8 17.	
3 58 2 15-25% .49 2	*	5 16-20% .51	61 \$ 15-25% STEAM AND * 2 \$ 16-20 % H2 IN CNTMT = 18% H2 NO_AC_LAT \$ NO AC POWER LATE
5 6	0. 0.	126. 19.	

3 58 60 61 \$ 15-25% STEAM AND 2 * 6 * 2 \$ >20% H2 IN CNTMT = 24% H2 15-25% > 20% NO_AC_LAT \$ NO AC POWER LATE .49 .51 2 5 170. 0. 6 0. 23. 60 61 \$ 25-35% STEAM AND 2 * 2 \$ 4-8 % H2 IN CNTMT = 6% H2 4-8% NO_AC_LAT \$ NO AC POWER LATE 3 56 3 25-35% .71 .29 2 34.1 19. 5 0. 6 0. 3 58 3 60 61 \$ 25-35% STEAM AND 3 * 2 \$ 8-12 % H2 IN CNTMT = 10% H2 * 25-35% 8-12% NO AC LAT \$ NO AC POWER LATE .67 .33 2 67.9 5 0. 6 0. 21. 60 61 \$ 25-35% STEAM AND * 4 * 2 \$ 12-16 % H2 IN CNTMT = 14% H2 3 58 3 25-35% 12-16% NO AC LAT S NO AC POWER LATE .58 .42 2 5 0. 103. 0. 24. 61 \$ 25-35% STEAM AND * 2 ~ 16-20 % H2 IN CNTMT = 18% H2 3 58 3 60 5 * 16-20% NO AC LAT : NO AC POWER LATE 25-35% .49 .51 2 5 0. 134. 6 0. 28. 60 61 \$ 25-55% STEAM AND 6 * 2 \$ >20 % H2 IN CNTMT = 24% H2 > 20% NO_AC_LAT \$ NO AC POWER LATE 3 58 3 25-35% .49 .51 2 5 0. 161. 34. 0. 3 58 60 €1 \$ 35-45% STEAM AND 4 * 2 * 2 \$ 4-8 % H2 IN CNTMT = 6% H2 35-45% STEAM AND 35-45% 4-8% NO_AC_LAT \$ NO AC POWER LATE .71 .29 2

6	0.	44. 27.	
3 58 4 35-45% .67	*	60 3 8-12% .33	61 \$ 35-45% STEAM AND * 2 \$ 8-12 % H2 IN CNTMT = 10% H2 NO_AC_LAT \$ NO AC POWER LATE
5 6	0. 0.	79.6 30.	
3 58 4 35-45% ,58 2	*	60 4 12-16% .42	61 \$ 35-45% STEAM AND * 2 \$ 12-16 % H2 IN CNTMT = 14% H2 NO_AC_LAT \$ NO AC POWER LATE
5	0.	112. 35.	
3 58 4 35-45% .49 2	*	60 5 16-20% .51	61 \$ 35-45% STEAM AND * 2 \$ 16-20 % H2 IN CNTMT = 18% H2 NO_AC_LAT \$ NO AC POWER LATE
5 6	0.	143.	
3 58 4 35-45% .49 2	*	60 6 > 20% .51	61 \$ 35-45% STEAM AND * 2 \$ >20 % H2 IN CNTMT ~ 24% H2 NO_AC_LAT \$ NO AC POWER LATE
5	0.	157. 50,	
3 58 5 45-55% .71 2		2	61 \$ 45-55% STEAM AND * 2 \$ 4-8 % H2 IN CNTMT = 6% H2 NO_AC_LAT \$ NO AC POWER LATE
5 6	0. 0.	58.2 38.	
3 58 5 45-55% .67 2		60 3 8-12% ,33	61 \$ 45-55% STEAM AND * 2 \$ 8-12 % H2 IN CNTMT = 10% H2 NO_AC_LAT \$ NO AC POWER LATE
2 5 6	0. 0.	97.9 44.	
3 58 5 45-55%	*	60 4 1.2-16%	61 \$ 45-55% STEAM AND * 2 \$ 12-16 % H2 IN CNTMT = 14% H2 NO_AC_LAT \$ NO AC POWER LATE

.58		.42					
5 6	0. 0.	128. 51.					
45-55%	16-	5	* .	2	Ş	45-55% STEAN AND > 16 % H2 IN CNTMT = 18% H2 NO AC POWER LATE	
5 6		146. 59.					
5	* >	6	*	2	\$	45-55% STEAM AND >20 % H2 IN CNTMT = 24% H2 NO AC POWER LATE	
5 6	0. 0.						
CASES FOR AC	POWER	AVAILABI	LE				
3 58		60		61	S	0-15 % STEAM AND	

\$ 1

1 * 2 * 1 \$ 4-8 % H2 IN CNTHT = 6% H2 0-15% 4-8% AC_LATE \$ AC POWER AVL LATE 0. 1. 2 0. 19.4 0. 7.6 5 0. 6 60 63 \$ 0-15 % STEAM AND * 3 * 1 \$ 8-12 % H2 IN CNTMT = 10% H2 8-12% AC_LATE \$ AC POWER AVL LATE 3 58 1 0-15% 1. 0. 2 0. 51.6 5 6 60 61 \$ 0-15% STEAM AND * 4 * 1 \$ 12-16 % H2 IN CNTMT = 14% H2 12-16% AC_LATE \$ AC FOWER AVL LATE 1. 3 58 1 0-15% 0. 2 0. 92.6 0. 10. 5 6 60 61 \$ 0-15% STEAM AND * 5 * 1 \$ 16-20% H2 IN CNTMT = 18% H2 3 58 1 0-15% 16-20% AC_LATE \$ AC POWER AVL LATE 0. 1. 0. 2 0. 121. 5 0. 11. 6

3 58 60 61 \$ 0-15% STEAM AND 1 * 6 * 1 \$ > 20% H2 IN CNTMT = 24% H2 0-15% > 20% AC_LATE \$ NO AC POWER LATE 1. 0. 2 5 0. 165. 6 0. 14. 60 €1 \$ 15-25% STEAM AND * 2 * 1 \$ 4-8% H2 IN CNTMT = 6% H2 4-8% AC_LATE \$ AC POWER AVL LATE 3 58 2 15-25% 1. 0. 2 0. 26.7 0. 13. 5 6 60 61 \$ 15-25% STEAM AND * 3 * 1 \$ 8-12 % H2 IN CNTMT = 10% H2 8-12% AC_LATE \$ AC POWER AVL LATE 3 58 2 15-25% 1. 0. 2 5 0. 59.7 0. 15. 6 60 61 \$ 15-25% STEAM AND * 4 * 1 \$ 12-16 % H2 IN CNTMT = 14% H2 12-16% AC_LATE \$ AC POWER AVL LATE 3 58 2 15-25% 1. 0. 0. 96.8 5 0. 17. 6 60 61 \$ 15-25% STEAM AND * 5 * 1 \$ 16-20 % H2 IN CNTMT = 18% H2 3 58 2 16-20% AC_LATE \$ AC POWER AVL LATE 15-25% 1. 0. 2 5 0. 126. 0. 19. 0. 126. 6 60 * 6 * 1 \$ 15-25% STEAM AND * 1 \$ >20% H2 IN CNTMT = 24% H2 > 20% AC_LATE \$ NO AC POWER LATE 1. 3 58 2 15-25% 0. 2 5 0. 170. 0. 23. 6 3 58 60 61 \$ 25-35% STEAM AND 3 * 2 * 1 \$ 4-8 % H2 IN CNTMT = 6% H2 25-35% 4-8% AC_LATE \$ AC POWER AVL LATE 25-35% 1. 0. 2

5 6	0. 0.	34.1 19.	
3 58 3 25-35% 0. 2	*	60 3 8-12% 1.	61 \$ 25-35% STEAM AND * 1 \$ 8-12 % H2 IN CNTMT = 10% H2 AC_LATE \$ AC POWER AVL LATE
5 6	0. 0,	67.9 21.	
3 58 3 25-35% 0, 2	*	60 4 12-16% 1.	61 \$ 25-35% STEAM AND * 1 \$ 12-16 % H2 IN CNTMT = 14% H2 AC_LATE \$ AC POWER AVL LATE
5		103. 24.	
3 58 3 25-35% 0, 2	*	60 5 16-20% 1.	61 \$ 25-35% STEAM AND * 1 \$ 16-20% H2 IN CNTMT = 18% H2 AC_LATE \$ AC POWER AVL LATE
5	0. 0.	134. 28.	
3 58 3 25-35% 0. 2	*	60 6 > 20% 1.	61 \$ 15-25% STEAM AND * 1 \$ 20 % H2 IN CNTMT = 24% H2 AC_LATE \$ NO AC POWER LATE
	0. 0.	161. 34.	
3 58 4 35-45% 0. 2			61 \$ 35-45% STEAM AND * 1 \$ 4-8 % H2 IN CNTMT = 6% H2 AC_LATE \$ AC POWER AVL LATE
5 6	0. 0.		
3 58 4 35-45% 0, 2	*	60 3 8-12% 1.	61 \$ 35-45% STEAM AND * 1 \$ 8-12 % H2 IN CNTMT = 10% H2 AC_LATE \$ AC POWER AVL LATE
5 6	0. 0.	79.6 30.	
3 58 4 35-45%		60 4 12-16%	6: \$ 35-45% STEAM AND * 1 \$ 12-16 % H2 IN CNTMT = 14% H2 AC_LATE \$ AC POWER AVL LATE

0. 1. 2 0. 5 112. 0. 35. 6 60 * 5 61 S 35-45% STEAM AND * 1 S 16-20% H2 IN CNTMT = 18% H2 3 58 4 16-20% AC LATE S AC POWER AVL LATE 35-45% 1. 0. 2 0. 143. 0. 40. 5 0. 6 3 58 60 61 \$ 35-45% STEAM AND 4 * 6 * 1 \$ >20 % H2 IN CNTMT = 24% H2 35-45% > 20% AC_LATE \$ NO AC POWER LATE 0. 1. 2 0. 157. 0. 50. 5 6 3 58 60 61 \$ 45-55% STEAM AND 5 * 2 * 1 \$ 4-8% H2 IN CNTMT = 6% H2 45-55% 4-8% AC_LATE \$ AC POWER AVL LATE 45-55% 1. 0. 2 0. 58.2 0. 38. 5 6 3 58 60 61 \$ 45-55% STEAM AND 5 * 3 * 1 \$ 8-12 % H2 IN CNTMT = 10% H2 45-55% 8-12% AC_LATE \$ AC POWER AVL LATE 1. 0. 2 0. 97.9 5 0. 6 60 61 \$ 45-55% STEAM AND * 4 * 1 \$ 12-16 % H2 IN CNTMT= 14% H2 12-16% AC_LATE \$ AC POWER AVL LATE 3 58 5 45-55% 1. 0. 2 0. 128. 5 6 0. 51. 60 61 3 45-55% STEAM AND * 5 * 1 \$ 16-20 % H2 IN CNTMT= 18% H2 3 58 5 45-55% 16-20% AC_LATE \$ AC POWER AVL LATE 1. 0. 2 5 0. 146. 59. 6 0. 3 58 60 61 \$ 45-55% STEAM AND

5 6 1 \$ >20 % H2 IN CNTMT = 24% H2 15-25% > 20% AC_LATE \$ NO AC POWER LATE 1. 0. 2 5 168. 0. 5 0. 6 0. 78. S SHOULD NEVER GO THIS PATH OTHERVISE 0. 1. 2 5 0. 0. 0. C. 6 H2 DETONATION LATE CONTAINMENT FAILURE - H2 DET 63 2 'DET CF' 'NO' 2 2 1 3 1 52 S NO LARGE BURN IGNITION LATE 1 NO BURN ö. 1. 58 \$ IF > 35% STEAM 6 \$ THEN INERT TO DETONATIONS > 55% 58 3 58 5 4 45-55% 35-45% 0. 1. 60 \$ < 12 % H2 IN CONT ATM LATE 3 3 60 60 1 2 4-12% 8-12% < 4% 0. 1. \$ STEAM > 35% HIGH S 12 - 16% H2 IN CNTMT ATM LATE S POWER RECOVERED PRIOR TO CNTMT LIMIT S RHR IS AVAILABLE IN SPRAY MODE, 56 7 4 60 3 4 - 2 2 1 CNTMT LMT SPRAY SBO 12-16% .022 .978 S 12 - 16% H2 IN CONT ATM LATE 1 60 S < 35% STEAM LOW 4 12-16% 0. 1. S STEAM > 35% HIGH S 16-20% OR > 20% H2 IN CNTMT ATM LATE S POWER RECOVERED PRIOR TO CNTMT LIMIT S RHR IS AVAILABLE IN SPRAY MODE, 3 7 56 1 * 2 * 2 SBO CNTMT_LMT SPRAY 3 5 60 (5 60 6) * 4 16-20% > 20% .975 .025

```
1 60
                                  S 16 - 20% H2 IN CNTMT ATM LATE
    5
                                  S < 35% STEAM LOW
     15-20%
                    .84
     .16
                                   $ > 20% H2 IN CNTMT ATM LATE
   1 60
     6
                                   $ < 35% STEAM
    > 20%
     .27
                   .73
    OTHERWISE
                                  S SHOULD NEVER GO THIS PATH
    0.
                 1.
  HYDROGEN BURN LATE CONTAINMENT FAILURE
                                                                    ··· CF
64
   2 'FAILURE' 'NO FAILUR'
                     2
   6 1
 2
   1 63
                                  S LATE DETONATION FAILS C NTAINMENT
    1
      DET CF
     1 5
       BURNPRES
       MAX
        GETHRESH 1 -1
      LATE DETONATION (FORCE FIRST BRANCH)
    OTHERWISE
      1 5
          BURNPRES
           FUN-F BURN
            EQUAL O
      CALCULATE PROB OF CNTMT FAILURE (ANY MODE) GIVEN BURN PRESSURE
   CONTAINMENT STATUS AT ACCIDENT PROGRESSION COMPLETION
                                                          - CNTMT ST
65
   4 'EARLY_CF' 'LATE_CF' 'VENT' 'NO_LAT_CF'
4 1 2 3 4
 14
   1 2
                                   S CONTAINMENT FAILED AT CORE DAMAGE
     2
     FAILED
      1.
                   0.
                             0
                                           0.
    1
                                           0.
                   .15
    7 .15
                            0.
                                   S CONTAINMENT VENT NOT ISOLATED FOR SBO
   1 5
                                   $ SEQUENCES
      2
      NOT_ISOL
      1.
                             0.
                                           0.
                  0.
    1
                                           0.
                            0.
    7 0.
                  0.
                                   S CNTMT FAILURE PRIOR TO RPV FAILURE
    1 24
      1
    FAILURE
                             0
                                           0.
      1.
                  0.
     1
```

0. 7 .15 .15 0. 1 46 S CNTMT FAILURE AT RPV FAILURE 1 FAILURE 0. 0. 1. 0. 1 0. 7 .15 .15 0. 3 9 \$ CONTAINMENT INTACT AT CD AND 4 * 1 \$ CRITICAL ATWS - THIS COMBINATION CRIT_ATWS VENT \$ IMPLIES THE ALTERATE SHUTDOWN 3 2 1 INTACT S ATWS SEQUENCES 1. 0. 0, 0. 1 7.15 .15 0. 0. S CONTAINMENT HEAT REMOVAL WITH SPRAY S OR RHR WITH POOL AND NO POOL BYPASS
 S OK RHK with PO


 8
 49
 54

 (2
 *
 2))
 *
 1

 RHR_POOL NO_PL_BP
 DRY-CCI
 .1
 0,
 .9
 4 8 (1 * RHR SPRY 0. 1 7 .15 .15 0. 0. \$ CONTAINMENT HEAT REMOVAL WITH SPRAY \$ OR RHR WITH POOL AND NO POOL BYPASS 8 49 54 (2 * 2)) * /1 RHR_POOL NO_PL_BP Not DRY-CCI 0, 0, 1, 8 4 (1 + RHR SPRY 0. 1 .15 0. 0. 7 .15 9 \$ CNTMT HEAT REMOVAL WITH POOL COOLING * 2 \$ AND POOL BYPASS 49 3 8 2 1 NO_VENT POOL BP RHR POOL 0. .75 0. .25 1 7 .15 .15 0. 0. 1 9 S CONTAINMENT VENT OPENED 1 VENT 1. 0. 0. 0. 1 0. 7 .15 .15 S NO CONTAINMENT HEAT REMOVAL \$ AND SBO WITH EARLY AND INTER LOSS INJ 6 6 (1 + 2) 8 3 4 3 1 * NO INJECT RCIC NO RHR SBO

0. 1. 0. 0. 1 0. 0. 7 .15 .15 6 S NO CONTAINMENT HEAT REMOVAL * 3 S AND SBO WITH LATE LOSS INJ 3 3 8 3 1 HPCS SBO NO RHR 0. 0. 0. 1. 0. 0. .15 .15 6 6 \$ NO CONTAINMENT HEAT REMOVAL (1 + 2) \$ WITH EARLY/INTER LOSS OF INJECTION 3 8 3 NO INJECT RCIC NO RHR 0. U. 1. 0. 1 7 .15 0. 0. .15 S NO CONTAINMENT HEAT REMOVAL 1 8 S ALL OTHER SEQUENCES 3 NO RHR 0. 0. 0. 1. 1 7 .15 0. \$ SHOULD NEVER GO THIS PATH 0. 0. .15 OTHERWISE 1. 0. 1 .15 0. 0. 7 .15 MODE OF LATE HYDROGEN AND OVERPRESSURE CONTAINMENT FAILURE - LATE CF 66 2 'ANCHORAGE' 'PN-D/NoCF' 2 6 1 4 S LATE STEAM OVERPRESSURE FAILURE 65 1 2 LAT_CF 1 7 OP ANC PR MAX EQUAL O LATE STEAM OVERPRESSURE FAILURE CASE S CNTMT NOT FAL. O BY H2 BURN LATE 1 64 2 NO FAILUR 1 5 BURNPRES MAX GETHRESH 1 1.E20 NO FAILURE CASE -- FORCE SECOND BRANCH S DETONATION FAILURE OF CNTMT 1 63 1 DET CF

```
1 5
         BURNPRES
         MAX
        GETHRESH 1 1.E20
      NO FAILURE C. A -- FORCE SECOND BRANCH
     OTHERVISE
        1
           5
          BURNPRES
         FUN-F MODE
         EQUAL O
        GET MODE OF CONTAINMENT FAILURE
$
Ś
                                                         ******* PB LATE
S CET EVENT 10 LATE POOL BYPASS **********
5
Š.
  DRYWELL FAILURE DUE TO LATE HYDROGEN BURN IN CONTAINMENT
                                                                 - DV LATE
67
   2 'DV_FAIL' 'NO_DV_FAL'
6 1 2
    6
  2
                                    S LARGE BURN IGNITION IN CNTMT LATE
    1
      62
       2
       LG BURN
       2 5
                       6
          BURNPRES CNTMT PRESSURE
         FUN-DWDELP
        EQUAL O
        PROB OF CONT BURN FAILING DRYWELL
                               S NO LARGE BURNS IN CNTMT LATE
     OTHERVISE
        2 5
                     6
          BURNPRES CNTMT PRESSURE
          MAX
          GETHRESH 1 1.E20
        RO CNTMT H2 BURN
                                                                   - LATE PB
    POOL BYPASS LATE
 68
    2 'LAT_PL_BP' 'NO_LAT_BP'
2 1 2
   6
                                     S DRYVELL FAILED BY LATE CNTMT H2 BURN
     1 67
        1
       DW FAIL
       ī.
                      0.
                                      S POOL BYPASSED BY CONTAINEENT
     1 66
                                      S ANCHORAGE FAILURE LATE
        1
       ANCHORAGE
       1.
                      0.
                                      S FOOL BYPASSED BY PEDESTAL
     1 55
                                      $ FAILURE DUE TO CCI EROSION
        - 2 -
       AFTER VB
                      0.
        1.
```



.

APPENDIX H.3

PNPP IFE APET DESCRIPTION

The following description of the IPE Level 2 Accident Progression Event Tree (APET) provides a case by case discussion of each of the 68 events. The Perry IPE APET is processed by the Event Progression Analysis (EVNTRE) code developed at Sandia National Laboratories. Note that the EVNTRE code examines all cases sequentially, and once it finds a "true" cutcome for a dependency it stops processing the case dependency logic. A complete discussion of the EVNTRE code is provided in the SAIC NUREG/CR--5174 reference manual (Griesmeyer 1989).

H.3.1. FLANT DAMAGE STATE GROUPING LOGIC

This APET Group consisting of events 1 thru 11 inputs the conditions prior to the initiation of core damage using the plant damage state grouping parameters and logic tree described in sections 4.3.1 and 4.3.2.

The outcomes of this APET group are Plant Damage States 1 thru 75. Reference Figure 4.3.2-1, Plant Damage State Grouping Logic. (It should be noted during the development of the Plant Damage State Event Trees, 150 Plant Damage States (or Classes) are model to include LOOP With No HVAC. When it was determined that LOOP With No HVAC is not a contributor to core damage, the Plant Damage States initially modeled were revised to 75.)

The PDS frequencies transferred into the NUS containment accident process code (NUPCAP+) and the frequencies are summed back through the Plant Damage State Grouping Logic to calculate the total Front-End Damage State Frequency and all the branch frequency. Manual calculations of the branch split fractions are then input into the depending sorting events in the APET Plant Damage State Grouping Logic to enable the Perry APET to determine the probability of each outcome with an input frequency of 1. The probability results can be transposed to frequency by multiplying through with the total Plant Damage State Core Damage Frequency.

EVENT 1. NOT A CONTAINMENT BYPASS FREQUENCY

- CNT BYP

Two branches:

NO BYPASS	Not A containm	ent bypass sequence.
EVENT V	A containment	bypass sequence.

EVNTRE Question Type: 1. (Independent sorting event)

PROBABILITIES:

CASE 1. No Containment Bypass Sequence

NO BYPASS 1.0 EVENT V 0.0

Event Dependencies: None

Quantification Basis: IPE Calculation PDS Branch Split Fractions.

EVENT 2. CONTAINMENT STATUS AT CORE DAMAGE

- CNT FAL

Two branches:

INTACT	Containment	Intact	At	Core	Damage.
FAILED	Containment	Failed	At	Core	Damage.

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

CASE 1.	Not A Containment	Bypass	Sequence
	INTACT FAILED	0.7720	

CASE 2. Otianalas, and der reach this case.

Event Dependencies:	Not A Contrinment Bypass Sequence (Event 1).
Quantification Basis:	IPE Calcul tion PDS Branch Split Fractions.

EVENT 3. EVENT TYPE: FOR CONTAINMENT INTACT OR FAILED AT CORE DAMAGE

- EVENT TYP

Six branches:

SBO LOOP NO H	Station Blackout With Cntmt Intact At Core Damage LOOP No HVAC With Containment Intact At Core Damage
OTHER TYPES CRIT ATWS	Other Event Types With Cntmt Intact At Core Damage Critical ATWS With Containment Failed at Core Damage LOOP & SBO With Containment Failed At Core Damage
LOOP & SBO OTHERS	All OTHERS With Containment Failed At Core Damage

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

CASE 1. Containment Intact At Core Damage

SBO	0.1170
LOOP NO H	0.0
OTHER TYPES	0.8830
CRIT ATVS	0.0
LOOP & SBO	0.0
OTHERS	0.0

H.3 - 3

CASE 2. Otherwise, Containment Fulled At Core Damage

SBO	0.0
LOOP NO H	0.0
OTHER TYPES	0.0
CRIT ATVS	0.1945
LOOP & SBO	0.1910
OTHERS	0.6145

Event Dependencies:	Containment Status At Core Damage (Event 2)
Quantification Basis:	IPE Calculation PDS Branch Split Fractions.

EVENT 4. INITIAL CONTAINMENT HEAT REMOVAL WITH SUPR POOL COOLING - SUPR_PL Two branches:

Two pranches:

NOT AVAILABLE Suppression Pool Cooling Initially Not Available. INIT SP COOLING Initial Suppression Pool Cooling Available.

The Initial Containment Heat Removal With Suppression Pool Cooling functional characteristic was included to better characterize the containment for LOOP With No WAC sequences. However, the IPE front-end review later determined that core damage from this sequence was not possible. The Back-End Plant Damage State set of functional characteristics are maintained in the interest of minimizing changes. The LOOP With No HVAC branching as shown in Figure 4.3.2-1 is not developed.

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

CASE 1.

LOOP With No HVAC Sequence NOT AVAILABLE 1.

INIT SP COOLING 0.

CASE 2. Otherwise, Not A LOOP No HVAC Sequence.

NOT AVAILABLE 1. INIT SP COOLING 0.

Event Dependencies: Eve

Event Type: Cntmt Intact/Failed At Core Damage (Event 3).



Quantification Basis: Not applicable for a token place holder value.

EVENT 5. CONTAINMENT VENT ISOLATED AT RPV FAILURE

- CNT ISOL

Two branches:

ISOLATED Containment Isolated At RPV Failure. NOT ISOLATED Containment Not Isolated At RPV Failure.

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

CASE 1. SBO Sequence

ISOLATED 0.9965 NOT ISOLATED 0.0035

CASE 2. Otherwise, Default to Isolated for other sequences.

ISOLATED 1.0 NOT ISOLATED 0.0

Event Dependencies: Event Type (Event 3).

Quantification Basis: IPE Calculation PDS Branch Split Fractions.

EVENT 6. RPV INJECTION FAILURE TIME

- INJ F TIM

Three branches:

NO INJECT	SBO RPV Injection Failure Time: 0 - 2.8 Hours	
RCIC	SBO RPV Inject on Failure Time: 2.8 - 4.2 Hours	8.
HPCS	SBO RPV Injection Failure Time: > 4.2 Hours	5
No Branch	Verifies APET branching assignment.]	

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

CASE 1.

NO INJECT 0.4347

SBO Event And Containment Isolated At Core Damage

RCIC	0.2798
HPCS	0.2854
No Branch	0.0000

CASE 2. SBO Event And Containment Not Isolated At Core Damage

NO INJECT	0.4347
RCIC	0.2798
HPCS	0.2854
No Branch	0,0000

CASE 3. LOOP With No HVAC And Initial Pool Cooling Not Available

NO	INJECT	1.0
RCI	C	0.0
HPC	S	0.0
No	Branch	0.0

CASE 4.

LOOP With No HVAC And Initial Pool Cooling

NO	INJECT	1.0
RCI	С	0.0
HPC	S	0.0
No	Branch	0.0

CASE 5.

Otherwise, Default to No Injection

NO	INJECT	1.0
RCI	C	0.0
HPC	S	0.0
No	Branch	0.0

Event Dependencies:	Event Type (Event 3), Initial Containment Heat Removal With RHR Suppression Pool Heat Removal (Event 4).
Quantification Basis:	IPE Calculation PDS Branch Split Fractions. Cases 3 and 4 are token place holders, so a basis is not applicable.

EVENT 7. OFFSITE POWER RECOVERY TIME

Three branches:

PRIOR RPV	Offsite power recovery prior to RPV tailure.
CNTMT LIM	Offsite power recovery prior to containment limit.
NO RECOV	No recovery of offsite power.
No Branch	Verifies APET branching assignment.]

- PWR_R_TIM

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

SBO And No Injection CASE 1.

PRIOR REV	0.6148
CNTMT LIM	0.3567
NO RECOV	0.0285
No Branch	0.0000

CASE 2. SBO And RC13 Injection Failure

PRIOR RPV	0.2484
CNTMT LIM	0.7006
NO RECOV	0.0510
No Branch	0.0000

CASE 3.

SBO And HPCS Injection Failure

PRIOR RPV	0.4231
CNTMT LIM	0.0000
NO RECOV	0.5769
No Branch	0.0000

CASE 4. Otherwise, Default to No Recovery

PRI	OR	RPV		0.0
CNT	MT	LIM		0.0
NO	REC	VO		1.0
No	Bra	nch		0.0

Event Dependencies:	Event Type (Event 3), Offsite Power Recovery (Event 6).	Time
Quantification Basis:	IPE Calculation PDS Branch Split Fractions.	Engineering

EVENT 8. CONTAINMENT HEAT REMOVAL WITH RHR SPRAY LOOP

- SPRAY

Three branches:

R

R

N

HR SPRAY	RHR containment spray loop available before containment
	overpressure limit threshold.
RHR POOL	RHR suppression pool cooling loop available before containment overpressure limit threshold.
10 RHR	No RHR loop available for containment heat removal.

It should be noted that RHR suppression pool cooling is currently not directly applied in the AFET. Containment spray is the only KHR mode used for containment heat removal.

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

CASE 1. SRO And Containment Not Isolated

RHR	SPRAY	0.
RHR	POOL	0.
NO I	a shares	1 .

CASE 2. SBO, No Injection And Offsite Power Recovery Prior to RPV Failure

RHR SPR	AY	0.	8312
RHR POO	L	0.	0000
NO RHR		0.	1688

CASE 3. SBO, No Injection And Offsite Power Recovery Prior to the Containment Limit

RHR	SPRAY	0.8284
RHR	POOL	0.0000
NO 1	RHR	0.1716

CASE 4. SBO, RCIC Injection Failure And Offsite Power Recovery Prior to RFV Failure

RHR	SPRAY	0.9479
		0.0000
NO F	RHR	0.0521

CASE 5.

SBO, RCIC Injection Failure And Offsite Power Recovery Prior to Containment Limit

RHR	SPRAY	0.9283	
RHR	POOL	0.0000	
NO	RHR	0.0717	

CASE 6.

SBO, HPCS Injection Failure And Offsite Power Recovery Prior to RPV Failure

RHR	SPRAY	0.	90	90
RHR	POOL	0.	00	00

NO RHR 0.0910

CASE 7.

OTHER TYPES Sequences

RHR	SPRAY	0.5171
RHR	POOL	0.0000
NO F	RHR	0.4829

CASE 8.

CRITICAL ATWS And Containment Failed At Core Damage

RHR	SPRA	Y	0.3025	
RHR	POOL		0.0000	
NO I	HR		0.6975	

CASE 9. CRITICAL ATWS And Containment Intact At Core Damage

This case is not included in the Plant Damage State Grouping Logic, but is included in the base case to fully characterize the APET framework for later sensitivity analysis on ATWS modifications.

RHR	SPRAY	0.2
RHR	POOL	0.0
NO F		0.8

CASE 10.

Otherwise, Default to No RHR.

RHR	SPRAY	0.
RHR	POOL	0.
NO	RHR	1.

Event Dependencies: Containment Status At Core Damage (Event 2), Event Type (Event 3), Containment Vent Isolated At Core Damage (Event 5), Offsite Pover Recovery Time (Event 7).

Quantification Basis: IPE Calculation PDS Branch Split Fractions. Case 9 is applied to later sensitivity analysis of ATWS modification and the value is conservatively assigned by Engineering judgement.

EVENT 9. CONTAINMENT HEAT REMOVAL WITH VENT

- VENT

Two branches:

VENT

NO VENT

Fuel Pool Cooling & Cleanup Vent or RHR Spray Herder Vent available before containment overpressure limit. No vent available before containment overpressure limit. EVNTRE Question Type: 2. (Dependent split fraction) PROBABILITIES: SBO, No Injection, Offsite Pover CASE 1. Recovery Prior To RPV Failure, And RHR Containment Heat Removal Not Available 1. VENT 0. NO VENT SBO, No Injection, Offsite Fover CASE 2. Recovery Prior To Containment Limit, And RHR Containment Heat Removal Not Available 1. VENT 0. NO VENT SBO, No Injection And No Offsite Power Recovery CASE 3. 0.8676 VENT NO VENT 0.1324 SBO, RCIC Injection Failure, Offsite Power CASE 4. Recovery Prior To RPV Failure, And RHR Containment Heat Removal Not Available 1. VENT NO VENT 0. SBO, RCIC Injection Failure, Offsite Power CASE 5. Recovery Prior To Containment Limit, And RHR Containment Heat Removal Not Available 1. VENT 0. NO VENT SBO, RCIC Injection Failure CASE 6. And No Offsite Power Recovery VENT 0.1824 0.8176 NO VENT SBO, HPCS Injection Failure, Offsite Fover CASE 7. Recovery Prior To RPV Failure,

And RHP. Containment Heat Removal Not Available

	VENT NO VENT	1. 0.
CASE 8.	SBO, HPCS Inje And No Offsite	ection Failure Power Recovery
	VENT NO VENT	0.7976 0.2024
CASE 9.	OTHER TYPES of And RHR Contag	Event Sequences Inment Heat Removal Not Available
	VENT NO VENT	0.8394 0.1606
CASE 10.	CRITICAL ATWS	And Containment Intact At Core Damage
	VENT NO VENT	1. 0.
CASE 11.	Otherwise, Ver Def	ating Unnecessary Or Irrelevant - Fault to No Vent.
	VENT NO VENT	0. 1.
Event Dependencies:	(Event 3), RPV	atus At Core Damage (Event 2), Event Type / Injection Failure Time (Event 6), Offsite / Time (Event 7), Containment Heat Removal (Event 8).
Quantification Basis:	Case 10 is app modification a	on PDS Branch Split Fractions. Died to later sensitivity analysis of ATWS and the value is assigned by Engineering ed on the success criteria.
EVENT 10. LATE IN-VESS	SEL INJECT & PEI	DESTAL CAVITY SUPPLYAT_INJ
Two branches:		
LAT INJ NO LT INJ	Late Injection No Late Inject	Available Before RPV Failure. ion.
EVNTRE Question Type:	2. (Dependent	split fraction)
PROBABILITIES:		

CASE 1.	SBO, No Injection Recovery Prior And RHR Spray A	on, Offsite Power To RPV Failure, vailable
	LAT INJ NO LT INJ	0.9866 0.0134
CASE 2.	SBO, No Inject Recovery Prior And Vent Avail	ion, Offsite Power To RPV Failure, able
	LAT INJ NO LT INJ	0.9973 0.0027
CASE 3.	SBO, No Inject Recovery Prior And RHR Spray	tion, Offsite Power r To Containment Limit, Available
	LAT INJ NO LT INJ	0.3393 0.6607
CASE 4.	Becaupry Prid	ction, Offsite Power or To Containment Limit, y Not Available
	LAT INJ NO LT INJ	0.6887 0.3113
CASE 5.	SBO, No Inje And Vent Ava	ection, No Offsite Pover Recovery ailable
	LAT INJ NO LT INJ	0.9363 0.0637
CASE 6.	SBO, No Inj And Vent Av	ection, No Offsite Power Recovery ailable
	LAT INJ NO LT INJ	1. 0.
CASE 7.	Recovery	Injection Failure, Offsite Pover rior To RPV Failure, ray Available
	LAT INJ NO LT INJ	1.

ø

CASE 8.	SBO, RCIC Injection Failure, Offsite Pover Recovery Prior To RPV Failure, And Vent Available		
	LAT INJ 1. NO LT INJ 0.		
CASE 9.	SBO, RCIC Injection Failure, Offsite Pover Recovery Prior To Containment Limit		
	LAT INJ O. NO LT INJ 1.		
CASE 10.	SBO, RCIC Injection Failure, No Offsite Power Recovery, And Vent Available		
	LAT INJ 0. NO LT INJ 1.		
CASE 11.	SBO, RCIC Injection Failure, No Offsite Power Recovery, Ani No Vent		
	LAT INJ 0. NO LT INJ 1.		
CASE 12.	SBO, HPCS Injection Failure, Offsite Power Recovery Prior To RPV Failure, And RHR Spray Available		
	LAT INJ 1. NO LT INJ 0.		
CASE 13.	SBO, HPCS Injection Failure, Offsite Power Recovery Prior To RPV Failure, And Vent Available		
	LAT INJ 1. NO LT INJ 0.		
CASE 14.	SBO, HPCS Injection Failure, No Offsite Power Recovery, And Vent Available		
	LAT INJ 0.8432 NO LT INJ 0.1568		
CASE 15.	SBO, RCIC Injection Failure, No Offsite Power Recovery,		

And No Vent

LAT	INJ		0.	7460	
NO L	TI	LV.	0.	2540	

CASE 16. SBO And Containment Vent Not Isolated At RPV Failure LAT INJ 0.5046

NO	LT	INJ	0.4954

CASE 17. OTHER TYPES of Sequences And RHR Spray Available

THUR T	3,13	167.	212200
NO 1	LT	INJ	0.0031

CASE 18. OTHER TYPES of Sequences And Vent Available

LAT INJ 0.9716 NO LT INJ 0.0284

CASE 19. OTHER TYPES of Sequences And No Vent LAT INJ 0.00022

NO LT INJ 0.99978

CASE 20. CRITICAL ATWS And Containment Intact At Core Damage

LAT INJ 1. NO LT INJ 0.

CASE 21. CRITICAL ATWS And Containment Failed At Core Damage

LAT INJ 0.95 NO LT INJ 0.05

CASE 22. SBO & LOOP Sequences And Containment Failed At Core Damage

> LAT INJ 0.4749 NO LT INJ 0.5203

CASE 23. All OTHERS With Containment Failed At Core Damage

LAT	T IN	IJ	0.3137
NO	LT	INJ	0.6863

CASE 24.

Otherwise, Should not reach this case.

TAJ	IN	J	0.
NO	LT	INJ	1.

Event Dependencies: Containment Status At Core Damage (Event 2), Event Type (Event 3), RPV Injection Failure Time (Event 6), Offsite Pover Recovery Time (Event 7), Containment Heat Removal With RHR Loop (Event 8), Containment Heat Removal With Vent (Event 9).

Quantification Basis: IPE Calculation PDS Branch Split Fractions.

Case 20 is applied to later sensitivity analysis of ATWS modification and the value is assigned by Engineering judgement based on the success criteria.

Case 21 is applied to the CRITICAL ATWS sequence where Late Injection Availability is not explicitly modeled in the PDS e.ent trees and the value is selected based on examination of similar late injection sequences when AC power is available and containment is intact at core damage.

EVENT 11. RPV DEPRESSURIZED DURING COPS DAMAGE

- RX PRESS

Two branches:

LOW PRES	RPV	Dept	ressurized	Dur	ing Cor	e Damage.
HI PRES	RPV	Not	Depressuri	ized	During	Core Damage.

EVNTRE Question Type: 2. (Dependent split fraction)

PROBABILITIES:

CASE 1.

SBO, No Injection, Offsite Power Recovery Prior To RPV Failure, Vent Available, And Late Injection Available

LOW PRES 0.4650 HI PRES 0.5350

CASE 2.

SBO, No Injection, Offsite Power Recovery Prior To RPV Failure, Vent Available, And No Late Injection

LOW PRES 1. HI PRES 0.

CASE 3.	SBO, No Injection, Offsite Pover Recovery Prior To Containment Limit, Vent Available, And Late Injection Available
	LOW PRES 0.2284 HI PRES 0.7716
CASE 4.	SBO, No Injection, No Offsite Power Recovery, Vent Available, And Late Injection Available
	LOW PRES 0.9904 HI PRES 0.0096
CASE 5.	SBO, No Injection, No Offsite Power Recovery, Vent Available, And No Late Injection
	LOW PRES 1. HI PRES 0.
CASE 6	SBO, No Injection, No Offsite Power Recovery, No Vent, And Late Injection Available
	LOW PRES 1. HI PRES 0.
CASE 7.	SBO, RCIC Injection Failure, No Offsite Power Recovery, No Vent, And No Late Injection
	LOW PRES 0. HI PRES 1.
CASE 8.	SBO, HPCS Injection Failure, No Offsite Power Recovery, Vent Available, And Late Injection Available
	LOW PRES 0.8014 HI PRES 0.1986
CASE 9.	SBO, HPCS Injection Failure, No Offsite Power Recovery, Vent Available, And No Late Injection
	LOW PRES 0.7704 HI PRES 0.2296
CASE 10.	SBO, HPCS Injection Failure, No Offsite Power Recovery, No Vent, And Late Injection Available



LOW PRES	0.9768
HI PRES	0.0232

CASE 11. SBO, HPCS Injection Failure, No Offsite Pover Recovery, No Vent, And No Late Injection

LOW		PR	ES	1.
HI.	P	RE	S	0.

CASE 12. SBO, Containment Not Isolated At RPV Failure, And Late Injection Available

LOW	PRES	0.6732
HI F	RES	0.3068

CASE 13.

SBO, Containment Not Isola. J At RPV Failure, And No Late Injection

LOW	PRES	1.
HI	PRES	0.

CASE 14.

All other SBO Sequences are Depressurized

LOW	PRES		1.
HI	PRES		0.

CASE 15. OTHER TYPES Sequences, RHR Spray Available And Late Injection Available

> LOW PRES 0.9924 HI PRES 0.0076

CASE 16. OTHER TYPES Sequences, No RHR Available, Vent Available and Late Injection Available

> LOW PRES 0.9950 HI PRES 0.0050

CASE 17. OTHER TYPES Sequences, No RHR Available, No Vent And Late Injection Available

> LOW PRES 1. HI PRES 0.

CASE 18.

OTHER TYPES Sequences, No RHR Available,

No Vent And No Late Injection

LOW	PRES	0.	9255
HI	PRES	0.	0745

CASE 19. CRITICAL ATWS And Containment Intact At Core Damage

LOW	PRES	1.
HI	PRES	0.

CASE 20. CRITICAL ATWS, Containment Failed At Core Damage And RHR Spray Available

LOW	PRES	0.9918
HI	PRES	0.0082

CASE 21. CRITICAL ATWS, Containment Failed At Core Damage And No RHR

> LOW PRES 0.7458 HI PRES 0.2542

CASE 22. SBO & LOOP Sequences, Containment Failed At Core Damage, And Late Injection Available

> LOW PRES 0.99940 HI PRES 0.00060

CASE 23. SBO & LOOP Sequences, Containment Failed At Core Damage, And No Late Injection

> LOW PRES 0.8882 HI PRES 0.1118

CASE 24.

In All Remaining Sequences With the Containment Intact or Failed At Core Damage The RPV Is Depressurized During Core Damage

LOW PRES 1. HI PRES 0.

CASE 25.

Otherwise, Should Never Reach This Case.

LOW	PRES	1,
HI	PRES	0.



Event Dependencies: Containment Status At Core Damage (Event 2), Event Type (Event 3), RPV Injection Failure Time (Event 6), Offsite Power Recovery Time (Event 7), Containment Heat Removal With RHR Loop (Event 8), Containment Heat Removal With Vent (Event 9), Late In-Vessel Injection & Pedestal Cavity Supply (Event 10).

Quantification Basis: IPE Calculation PDS Branch Split Fractions.

Case 19 is applied to later sensitivity analysis of ATWS modification and the value is assigned by Engineering judgement based on the success criteria.

H.3.2. DEBRIS COOLED IN-VESSEL

This APET Group determines in Events 12 thru 15 the probability that the debris is cooled in-vessel (and reactor vessel failure is prevented).

The two possible outcomes from this APET group are:

Debris is Cooled In-Vessel (and RPV Failure Prevented) Debris is Not Cooled In-Vessel (and RPV Failure Occurs)

EVENT 12. LATE RPV LOW PRESSURE INJECTION AVAILABLE

- LATE INJ

Three branches:

WATER INJECT	Late water injection into vessel.
NO INJECTION CRITICAL	No late water injection. ATWS and the reactor is not shut own with recovery action.

This question assesses whether there is water injection to the reactor vessel established subsequent to core damage but prior to reactor failure in excess of that provided by the CRD system alone. In addition, there 's a separate branch for the ATWS sequence where it is assumed that even if a water supply is provided to the vessel subsequent to core damage that in-vessel cooling is not possible.

EVNTRE Question Type: 2. (Dependent Sorting Event)

SORTING:

CASE 1.

No Late In-Vessel Injection

WATER INJECT 0. NO INJECTION 1. CRITICAL 0.

CASE 2. CRITICAL ATWS

WATER INJECT	0.
NO INJECTION	0.
CRITICAL	1.

CASE 3.

Late In-Vessel Injection Available

VAT	ER INJECT	1
NO	INJECTION	0
CRI	TICAL	0

CASE 4.

Otherwise, Should never reach this case.

WATER	IN.IECT	0,
NO IN	JECTION	1.
CRITI	CAL	0.

Event Dependencies:

Event Type (Event 3), and Late In-Vessel Injection and Cavity Supply (Event 10).

EVENT 13. RPV DEPRESSURIZED DURING CORE DAMAGE

- RX PRESS

Two Branches:

LOW PRESSURE	RPV Depressurized before core pla	te failure
HI PRESSURE	RPV Not Depressurized during core	damage

In-vessel cooling requires the that the reactor pressure vessel be depressurized to permit the low pressure Late-Injection systems to provide flow to the reactor core.

EVNTRE Question Type: 2. (Dependent sorting event)

SORTING:

CASE 1. All Sequences Where RPV Is Depressurized During Core Damage LOW PRESSUR 1. HI PRESSURE 0.

CASE 2.

Otherwise, Assign to High Pressure

LOW PRESSUR O. HI PRESSURE 1.

Event Dependencies: RPV Depressurized During Core Damage (Event 11)

EVENT 14. DEBRIS MASS MOLTEN AT VESSEL BREACH

- MOLTEN VB

Two branches:

LARGE DEBRIS Large mass of molten debris in lover reactor vessel SMALL DEBRIS Small mass of molten debris in lover reactor vessel

The mass of molten debris in the reactor vessel lower head is a key factor in determining the probability of successful in-vessel cooling. Two discrete magnitudes were evaluated: Large (~40% of core mass), and Small (~10% of core mass). The Grand Gulf (Brown 1990) APET provided the following estimated probabilities.

EVNTRE Question Type: 2.

PROBABILITIES:

CASE 1.

No Late Injection Or RPV Not Depressurized During Core Damage.

LARGE DEBRIS 0.1 SMALL DEBRIS 0.9

CASE 2. Otherwise, for Late Injection Available and the RPV spressurized During Core Damage, or Critical reactor state.

> LARGE DEBRIS 0.025 SMALL DEBRIS 0.975

Event Dependencies: Late RPV Low Pressure Injection Available (Event 12), and RPV Depressurized During Core Damage (Event 13).

Quantification Basis: Grand Grif (Brown 1990) APET Event Number 61.

EVENT 15. DEBRIS COOLED IN-VESSEL

- INV COOL

Two Branches:	COOLED IN-VESSEL	Debris Cooled In-Vessel
INO DIGUCUES:	NOT COOLED IN-VESSEL	Debris Not Cooled In-Vessel

In NUREG/CR-4551 the mass of molten material in the reactor vessel at vessel breach was used as a discriminant for the coolability of the debris in-vessel. For sequences with a large mass of molten debris (~40% of core mass) it was judged that the debris had a 0.5 probability of being cooled in-vessel. For sequences with a smaller amount of molten debris (~10% molten), the NUREG/CR-4551 authors judged that the probability of successfully cooling the debris in-vessel is approximately 0.75.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. Critical Reactor, And Containment Failed Before Core Damage

> COOLED INV 0. NOT COOLED INV 1.

CASE 2. Critical Reactor And Alternate Shutdown With Containment Integrity Maintained

This case is designed to apply to the later sensitivity analysis of the 'mpact of controlling RPV Power/Level during an unmitigated ATWS such that the containment is maintained intact at core damage. Therefore this case applies to recovered ATWS sequences with alternate shutdown, if late injection is available in Event 12, Late RPV Low Pressure Injection Available, then In-Vessel Core Cooling is fully credited.

COOLED INV 1. NOT COOLED INV 0.

CASE 3. Water Injection Available, RPV Depressurized During Core Damage And Large Molten Debris Mass

> COOLED INV 0.5 NOT COOLED INV 0.5

CASE 4.

Water Injection Available, RPV Depressurized During Core Damage And Small Molten Debris Mass

COOLED INV 0.75 NOT COOLED INV 0.25

CASE 5.

Otherwise, No Locling Writer Available For Other Sequences.

COOLED INV 0

NOT COOL INV 1.

Event Dependencies:

Late Water Injection to Reactor Vessel (Event 12), RPV Depressurized During Core Damage (Event 13), and Debris Mass Molten at Vessel Breach (Event 14).

Quantification Basis: Grand Gulf (Brown 1990) APET Event Number 63.

H.3.3. MODE OF CONTAINMENT FAILURE BEFORE RPV FAILURE

This APET group determines in Events 16 thru 25 the probability and the mode of containment failure following a hydrogen deflagration or a hydrogen detonation.

A hydrogen deflagration results in a sudden pressure rise that can fail the containment in either of two possible modes: penetration failure (which includes the equipment hatch), or anchorage failure. The penetration failure modes are grouped with the equipment hatch failure mode to minimize the complexity of the analysis.

The three possible outcomes from this DET group are:

ANCHORAGE	Concrete/steel anchorage failure
PENETRATION/DOME	Penetration, containment shell, or
	equipment hatch failure
NO FAILURE	No containment failure

EVENT 16. HYDROGEN IGNITION SYSTEM AVAILABLE

- H2 IGN

Two Branches:

HIS OFF Hy	drogen Ignitor	System	Tuoberapre	OF TU OFT	Draino.
HIS ON Hy	drogen Ignitor	System	Available	and In On	Status

EVNTRE Question: Type 2. (Dependent Split Fraction)

PROBABILITIES:

CASE 1. No Loss Of AC Pover:

For this case it is assumed the ignitors are very likely to be available through out the sequence. The likelihood of the HIS being maintained off when AC Power is available is associated with the human interaction, Operator Fails To Initiate Hydrogen Ignition System. Monitoring and controlling hydrogen with the hydrogen analyzers and hydrogen ignitors is integrated in the simulator training of the Plant Emergency Instruction (PEI). The most limiting time window for hydrogen generation to commence is for a loss of all injection accident where the maximum core clad temperature reaches 2200 F after 51 minutes. During licensed operator simulator training, the control room operators are trained to routinely monitor and control hydrogen in the PEI flow chart by placing the hydrogen analyzers in service in the third step of the RPV Control entry. During a loss of all injection the reactor water level decreases below Level 1 (< 16.5 inches above the Top of the Active Fuel) at about 29 minutes. The RPV water level decrease below Level 1 is the entry condition to Hydrogen Control. The Unit Supervisor will typically direct action from the Hydrogen Control flow chart that the Hydrogen Ignitors be placed in service about 1 minute after entering the flow chart. The execution time to initiate this system at a nearby back panel is relatively short requiring about 30 seconds. Therefore, the human error probability of 0.005 is considered conservative.

HIS OFF		0.	005
HIS ON		0.	995

CASE 2. Otherwise, For Remaining Sequences Default to AC Pover Lost Early

For this case, it is assumed that the AC powered ignitors are not available at any time during the sequence. Even if power recovery occurs it is not clear that the ignitors would be turned on in sufficient time to mitigate the accident. The Perry Plant Emergency Instructions direct the operators not to turn on the ignitors until containment and dryvell hydrogen measurement is available and the respective concentrations are determined to be less than the associated Hydrogen Deflagration Overpressure Limits of 9% and 6%. It is estimated that hydrogen measurement would require as much as two hours following power recovery. The hydrogen analyzer equipment is AC powered and requires at least an hour to reach steady state calibrated conditions following restoration of AC power.

HIS	OFF	1.
HIS	ON	0.

Event Dependencies: Event Type (Event 3). IPE Human Interaction Technical Assignment File, Perry Quantification Basis: Plant Emergency Instruction, and Discussion with Operation and Chemistry Staff.

EVENT 17. CONTAINMENT VENT ISOLATED BEFORE RPV FAILURE

Two branches:

ISOLATED	Containment Isolated	
NOT ISOLATED	Containment Not isolated	
	(Fuel Pool Cooling & Cleanup Isolation Open)

- ISOL

This event determines whether the containment is isolated, or not, at the time of RPV failure for SBO sequences. Branching under this event is determined uniquely by the branch taken under Plant Damage State Event 5.

EVNTRE Question: 2. (Dependent Sorting Event)

SORTING:

CASE 1.

Containment Vent Isolated Before RPV Failure For SBO Sequences

ISOLATED 1. NOT ISOLATED 0.

CASE 2.

Otherwise, Postulate Not Isolated For SBO Sequences.

ISOI	LATED		0.
NOT	ISOL	ATED	1.

Event Dependencies: Containment Vent Isolated At RFV Failure (Event 5).

Quantification Basis: Not Applicable.

EVENT 18. MODE OF SPRAY OPERATION EARLY

Three Branches:

CONTROLLED	Sprays are operating in a throttled cooling mode to mitigate o: exclude hydrogen deflagrations and
SPRAY	detonations. Sprays are operating at full design cooling.
NO SPRAY	Sprays are not available.

This event defines the conditions of containment spray operation at the time of core damage or vessel failure. The sprays can oither be available or not available. If a containment spray loop is available, the operators could operate the system in a throttled RHR heat exchanger flow control mode such that the containment atrocchere remains at elevated pressure (~30 psig) in order to assure that the containment steam-inert to hydrogen combustion or maintains the a: 'ound containment steam concentration to minimize the expected peak burn pressures.

EVNTRE Question Type: 2. (Dependent Sorting Event)

SORTING:

CASE 1. RHR Spray Not Available



- RHR MODE

RHR Spray is determined to be not available in the Plant Damage State Grouping Logic.

CONTROLLED	0.
SPRAY	0.
NO SPRAY	1.

CASE 2.

AC Pover Lost and Not Recovered Prior to RPV Failure

CONTROLLED	0.
SPRAY	0.
NO SPRAY	1.

CASE 3. AC Power Never Loot And RHR Spray Available

With AC Power available, it is almost certain that the hydrogen igniters are available to control hydrogen by combining the available oxygen with the hydrogen generated. Therefore, a controlled, steam-inerted containment atmosphere is not necessary to credit the mitigative impact of controlled spray operation.

CON	TROLLED	0.
SPE	YAY	1.
NO	SPRAY	0.

CASE 4.

AC Power Lost and Recovered Prior to The ailure And RHR Spray Available

CONTROLLED	0.
SPRAY	1.
NO SPRAY	0.

Under these conditions it is probable that there will be significant quantities of hydrogen released into the containment and that the hydrogen ignition system will not be energized during the first hour or two following AC power recovery. (Reference Event 16 discussion.) Under these conditions it is possible to limit the threat from hydrogen combustion by throttling the RHR bypass flow to maintain the containment steam concentration in the steam-inert regime. However, since this mode — operation is not in the Perry Plant Emergency Instruction, this mode of operation has been assigned a zero probability for base case evaluation.

CASE 5.

Otherwise, Should never reach this case.

ON	TROLLED	0.	
	RAY	1.	
04	SPRAY	٦.	

Event Dependencies: Event Type (Event 3), Offsite Power Recovery Time (Event 7), and Containment Heat Removal With RHR Spray Loop (Event 8). Sorting Basis: Perry Plant Emergency Instruction and Engineering Judgement.

EVENT 19. CONTAINMENT STEAM CONCENTRATION BEFORE RFV FAILURE

- ST CONC

Six branches:

0-15 % Containment Steam Volume Percent 15-25 % 25-35 % 35-45 % 45-55 %

The hydrogen burn ignition probability and burn efficiency is a function of the steam concentration in the containment. The steam concentration regime probabilities given for the cases below were estimated using MAAP results for each case and considering the variability of suppression pool temperature.

EVNTRE Question : 2: (Dependent Split Fraction)

PROBABILITIES:

CASE 1.

1. Spray Loop Operation At Design Cooling

With a containment spray loop operating at design cooling with containment heat removal optimized with the Residual Heat Removal heat exchanger, the steam concentration would be low.

0-15	%	1.
15-25	%	0.
25-35	%	0.
35-45	%	0.
45-55	%	0.
>55	%	0.

CASE 2.

SBO And No Injection Failure Early (0 - 2.8 Hrs)

0-15	%	1.
15-25	%	0.
25-35	%	0.
35-45	%	0.
45-55	%	0.
>55	%	0.

CASE 3.

SBO And RCIC Injection Failure (2.8-4.2 Hrs)

0-15	%	0.
15-25	%	0.51
25-35	%	09
35-45	%	0.
45-55		0.
>55		0.

CASE 4.

SBO And HPCS Injection Failure (> 4.2 Hrs)

-15	%	0
15-25	%	0
25-35	%	0
35-45		0
45-55		0
>55		1

CASE 5.

Containment Failed At Core Damage

0-15	%	C	۱.
15-25	%	C).
25-35	%	0),
35-45	%	().,
45-55	%	().
>55	%	1	

CASE 6.

Otherwise, Other Sequences Default To Low Steam Concentration

All other sequences are conservatively evaluated by assuming a low steam concentration (which implies fast _ore damage) and can produce a higher expected burn pressure.

0-15	%	1.
15-25	%	0.
25-35	%	0.
35-45	%	0.
45-55	%	0.
>55	%	0.

Event P ondencies: Containment Status At Core Damage (Event 2), Event Type (Event 3), RPV Injection Failure Time (Event 6), and Mode of RHR Spray Operation Early (Event 18).

Quantification Basis: IPE Engineering Calculation - Hydrogen Burns (see APET Event 20 for summary description of hydrogen generation modeling which is related to the steam concentration), and Engineering Judgement.

EVENT 20. FRACTION OF ... RE INVENTORY OF ZIRCONIUM REACTED IN-VESSEL - H2_INV

Three Branches:

11	%	Percent	In-Vessel	Zirconium	Reacted	In-Vessel
22	%					
33	%					

The mean values for the fraction of core inventory reacted in-vessel ranged from 0.104 to 0.218 for the long term ATWS and short term SBO case described in NUREG/CR-4551. Perry MAAP calculations for a wide spectrum of sequence types show the fraction of zirconium reaction ranging from approximately 0.03 to 0.20 for the no injection SBO (modeled with Local Blockage), and for RCIC injection loss with a cool suppression pool (modeled by No Blockage - no local node cutoff). The Perry IPE MAAP calculations implemented the best-estimate values for the model parameters discussed in the "Recommended Sensitivity Analyses For An Individual Plant Examination Using MAAP 3.0B" (EPRI 1991). The IDCOR BWR "blockage" model of Local Blockage option was considered more likely and the No Blockage option less likely, and a probability of 0.8 and 0.2 was assigned to each option, respectively. These results were used to define the split fractions shown below.

EVNTRE Question: Type 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1.	SBO And No Injection Failure Early (0 - 2.8 Hrs)
	11 % 1. 22 % 0. 33 % 0.
CASE 2.	SBO And RCIC Injection Failure (2.8 - 4.2 Hrs)
	11 % 0.87 22 % 0.13 33 % 0.
CASE 3.	SB0 And HPCS Injection Failure ($>$ 4.2 Hrs)
	11 % 1. 22 % 0. 33 % 0.
CASE 4.	Otherwise, Other Sequences Are Assigned The Maximum Fraction Zirc Reacted

Used in Case 2, SBO Vi h RCIC Injection Loss

11	%	0.87
22	%	0.13
33	%	0.

Event Dependencies:	Event Type (Event 3), and RPV Injection Failure Time (Event 6).
Quantification Basis:	Grand Gulf (Brown 1990) APET Event 35, "Recommended Sensitivity Analyses For An IPE Using MAAP 3.0B" (EPRI 1991), and Perry IPE Engineering Calculations using "Recommended Sensitivity Analyses For An IPE Using MAAP 3.0B" (EPRI 1991).

EVENT 21. SMALL BURNS AT LOW HYDROGEN CONCENTRATION

Two Branches:

NO SMALL	No Sma	11 Bur	ns Occur
SMALL BURN	Small	Burns	Occur

If small burns are ignited at low hydrogen concentrations, then the threat to containment integrity from a large hydrogen burn is effectively eliminated. Ignition of small burns at low hydrogen concentrations depletes the containment of hydrogen (and oxygen) and results in an ignition source for later hydrogen burns (from residual fires or smoldering transient "trash").

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. Inert Steam Atmosphere

For this case the occurrence of small burns is not possible.

NO	SMA	LL	1.
SMA	LL	BURN	0.

CASE 2. Hydrogen Ignitors On

For this case the occurrence of small burns are virtually assured.

N	0	S	MA	LL	0	
S	MA	L	L	BURN	1	

CASE 3. AC Power Available, But Ignitors Not Available



- SM BRN

Under these conditions NURFG/CR-4551 indicated that it was likely that the ignition source available as a result of the operation of AC powered equi ment inside containment would result in the ignition of a small burn at low hydrogen concentrations.

NO	SMALL	0.25
SM/	ALL BURN	0.75

CASE 4.

AC Power Lost and Recovered Prior to Vessel Failure

NUREG/CR-4551 estimated that there was a small time window within which AC power had to be recovered following the initiation of core damage in order for a small burn to be ignited (prior to release of sufficient large amounts of hydrogen that a large burn would occur). The following probabilities are taken from NUREG/CR-4551 for the case without the igniters available.

NO	SMA	LL	0.	96
SMA	LL	BURN	0.	04

CASE 5. AC Power Lost a

AC Power Lost and Not Recovered Before RPV Failure

For this case ignition of a small burn at low hydrogen concentrations was estimated to be negligible from random ignition sources.

NO SMALL 1. SMALL BURN 0.

CASE 6.

Otherwise, Should Never Reach This Case

NO SMALL 1. SMALL BURN 0.

Event Dependencies:

Containment Steam Concentration Before RPV Failure (Event 19), Hydrogen Ignitors Available (Event 16), Event Type (Event 3), RPV Injection Failure Time (Event 6) and Offsite Power Recovery (Event 7).

Quantification Basis: Grand Gulf (Brown 1990) APET Event 41.

EVENT 22. LANGE HYDROGEN BURN DURING CORE DAMAGE

- LG BURN

Two Branches:

NO		No Large			
LG	BURN	Large Hy	/drogen H	Burn Ign	ited

This event assess whether a large hydrogen burn is ignited in containment prior to reactor vessel failure. If a hydrogen burn is ignited this event sets the value of two parameters (1 and 3) used in subsequent events. Parameter 1 is the peak containment pressure (psig) expected from the hydrogen burn. Parameter 3 is the pre-existing containment pressure (psig) before the burn.

The expected peak containment pressure was determined as follows. First, the adiabatic isochoric combustion pressure (AICC) was calculated for each combination of hydrogen concentration and steam concentration resulting from the branching under Events 19 and 20. Then, the AICC pressure was multiplied by a burn efficiency factor taken from NUREG/CR-4551 for each steam and hydrogen concentration case, which relates the expected peak pressure to the maximum (AICC) burn pressure. Table H.3.2-1 shows the results of the hydrogen pressure calculation and the input for each case where a large hydrogen burn was predicted to occur. Table H.3.2-1 also shows the probability assigned for ignition of a large burn.

EVNTRE Question Type: 4. (Dependent Split Fractions with parameter values set for each case)

PROBABILITIES:

CASE 1. Containment Failed At Core Damage

N

The steam-inert containment atmosphere prevents hydrogen combustion. Note in this case, the EVNTRE parameter for the Peak Containment Pressure is used to carry the probability of anchorage failure for gradual steam overpressurization.

NO	BURN	1.						
LG	BURN	0.	BASE	PRESS	0	PEAK P	RESS	.15

CASE 2. Small Burn Occurs At Low Hydrogen Concentrations

The small burn is assumed to prohibit the occurrence of a subsequent large burn.

NC BURN 1. LG BURN 0. BASE PRESS O PEAK PRESS O

CASE 3. Containment Concentration Is Greater Than 55%

The steam-inert containment atmosphere prevents hydrogen combustion. Note in this case, the EVNTRE parameter for the Peak Containment Pressure is used to carry the probability of anchorage failure for gradual steam overpressurization.

H.3 - 32

NO BURN 1. LG BURN O. BASE PRESS O PEAK PRESS .15

CASE 4.	Cntmt Steam [0-15%] & 33% Zirc Reacted, [H2] = 25.6%
	NO BURN 0.5 LG BURN 0.5 BASE PRESS 9 PEAK PRESS 142
CASE 5.	Cntmt Steam [0-15%] & 22% Zirc Reacted, [H2] = 18.8%
	NU BURN 0.5 LG BURN 0.5 BASE PRESS 6 PEAK PRESS 98
CASE 6.	Cntmt Steam [0-15%] & 11% Zirc Reacted, [H2] = 10.5%
	NO BURN 0.72 LG BURN 0.28 BASE PRESS 4 PEAK PRESS 40
CASE 7.	Cntmt Steam [15-25%] & 33% Zirc Reacted, [H2] = 22.1%
	NO BURN 0.5 LG BURN 0.5 BASE PRESS 14 PEAK PRESS 123
CASE 8.	Cntmt Steam [15-25%] & 22% Zirc Reacted, [H2] = 16.2%
	NO BURN 0.5 LG BURN 0.5 BASE PRESS 11 PEAK PRESS 87
CASE 9.	Cntmt Steam [15-25%] & 11% Zirc Reacted, [H2] = 9.0%
	NO BURN 0.72 LG BURN 0.28 BASE PRESS 9 PEAK PRESS 37
CASE 10.	Cntmt Steam [25-35%] & 33% Zirc Reacted, [H2] = 19.4%
	NO BURN 0.5 LG BURN 0.5 BASE PRESS 20 PEAK PRESS 113
CASE 11.	Onimt Steam [25-35%] & 22% Zirc Reacted, [H2] = 14.2%
	NO BURN 0.61 LG BURN 0.39 BASE PRESS 16 PEAK PRESS 80
CASE 12.	Cntmt Steam [25-35%] & 11% Zirc Reacted, [H2] = 7.9%
	NO BURN 0.75 LG BURN 0.25 BASE PRESS 13 PEAK PRESS 36

H.3 - 33

CASE 13.	Cntmt Steam [35-45%] & 33% Zirc Reacted, [H2] = 16.6%
	NO BURN 0.56 LG BURN 0.44 BASE PRESS 27 PEAK PRESS 104
CASE 14.	Cntmt Steam [35-45%] & 22% Zirc Reacted, [H2] = 12.2%
	NO BURN 0.67 LG BURN 0.33 BASE PRESS 23 PEAK PRESS 75
CASE 15.	Cntmt Steam [35-45%] & 11% Zirc Reacted, [H2] = 6.8%
	NO BURN 0.77 LG BURN 0.23 BASE PRESS 19 PEAK PRESS 37
CASE 16.	Cnimt Steam [45-55%] & 33% Zirc Reacted, [H2] = 13.8%
	NO BURN 0.61 LG BURN 0.39 BASE PRESS 37 PEAK PRESS 98
CASE 17.	Cntmt Steam [45-55%] & 22% Zirc Reacted, [H2] = 10.2%
	NO BURN 0.72 LG BURN 0.28 BASE PRESS 32 PEAK PRESS 76
CASE 18.	Cntmt Steam [45-55%] & 11% Zirc Reacted, [H2] = 5.7%
	NO BURN 0.77 LG BURN 0.23 BASE PRESS 27 PEAK PRESS 40
CASE 19.	Otherwise, Should Never Reach This Case
	NO BURN 1. LG BURN 0. BASE PRESS 0 PEAK PRESS 0
Event Dependencies:	Containment Steam Concentration (Event 19), Fraction of Zircalloy Reacted In-Vessel (Event 20), Small Burns At Low Hydrogen Concentration (Event 21).
Quantification Basis:	Grand Gulf (Brown 1990) APET Events 43 and 46, and Perry IPE Engineering Calculation - Hydrogen Burns (reference intermediate results in TABLE H.3.2-1.)

EVENT 23. HYDROGEN DETONATION CONTAINMENT FAILURE BEFORE RPV FAILURE - H2_DET

Two Branches:

DET CF NO Hydrogen Detonation Containment Failure No Hydrogen Detonation Containment Failure

Given that the containment hydrogen is ignited (as previously determined in the APET by taking the Large Burn Ignited During Core Damage branch) this event assesses whether a detonation occurs which fails the containment. It is assumed that if detonation does occur, that it occurs in the upper containment and results in a large (> 7 square feet) failure area in the dome or upper cylindrical wall of the containment.

The probabilities for containment failure estimated below are based on the results from the Grand Gulf NUREG/CR-4551 analyses for hydrogen detonation loading and the Sehqoyah steel containment impulse strength.

Based on NUREG/CR-4551 results detonations are assumed to have negligible probabilities for steam concentrations in excess of 35% or hydrogen concentrations less than 12%. The probabilities of hydrogen detonation and the mean impulse loading under other conditions are shown in Table H.3.2-2 below.

The mean value of the containment failure impulse for Grand Gulf given in NUREG/CR-4551 was 19.5 kPa-s. However, unlike Grand Gulf, Perry is a free standing steel containment. Hence, the nearest containment design to Perry of the NUREG-1150 plants is Sequoyah which also has a free standing steel containment. For the Sequoyah plant the mean value of the containment failure was estimated to be 12.1 kPa-s (for the upper containment region). Assuming this value is appropriate to assess the containment failure impulse loading at Perry the containment failure probabilities shown on Table H.3.2-2 were estimated.

As in NUREG/CR-4551, the "high" steam level case represents sequences which were initially inert to detonations and where the steam is condensed and brought into the detonation range by spray operation. The low steam level corresponds to cases where the detonatable mixture formed while the containment atmosphere remained in a flammable regime (non-inert). In the Perry IPE analyses, it is assumed that the only time that a "high" steam level case could occur would be for SBO sequences with power (and spray) recovery subsequent to core damage.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. No Large Burn Ignited

With no large burn, no trigger exists for a nydrogen detonation.

DET	CF	0.
NO		1.

CASE 2.

Containment Steam Concentration Greater Than 35%

Steam concentrations greater than 35% prevent hydrogen detonation.

DET CF 0. NO 1.

CASE 3. 11% Fraction of Zirconium Reacted

Hydrogen concentrations of < 12% are associated with 11% Zirconium Reacted sequences which do not support detonation.

DET CF 0. NO 1.

CASE 4.

Containment Steam Concentration High And Slowly Decreasing Less Than 35%, And Hydrogen Concentration Is 12-16%

This occurs when power is recovered before RPV failure and sprays are available. This range of hydrogen concentration can be associated with 22% Zirc Reacted sequences. This case is assigned to those sequences where the containment steam concentration is 0-15%, the Fraction of Zirc Reacted In-Vessel is 22%, the Event Type is SBO, Power is Recovered Before RPV Failure, the Mode of RHR Spray Operation Early is Spray, and no Loss of Injection Early.

DET	CF	0.022
NO		0.978

CASE 5. Containment Steam Concentration Low And Hydrogen Concentration Is 12-16%

This occurs when the containment steam concentration is between 25-35% and the Fraction of Zirc Reacted is 33%.

DET CF 0. NO 1.

CASE 6.

Containment Steam Concentration Low And Hydrogen Concentration Is 16-20%

This occurs when the containment steam concentration is between 0-25% and the Fraction of Zirc Reacted is 22%.

DET	100	0	16
DEL	Ur	1.1	7.0
NO		0.	84

CASE 7.

Containment Steam Concentration High And Slowly Decreasing Less Than 35%,

And Hydrogen Concentration is Greater Than 20%

This occurs when power is recovered before RPV failure and sprays are available. This range of hydrogen concentration can be associated with 33% Zirc Reacted sequences. This case is assigned to those sequences where the containment [Steam] is 0-15%, the Fraction of Zirc Reacted In-Vessel is 33%, the Event Type is SBO, Power is Recovered Before RPV Failure, the Mode of RHR Spray Operation Early is Spray, and no Loss of Injection Early.

DET C	F	0.	02	5
NO		0.	97	5

CASE 8. Containment Steam Concentration Low And Hydrogen Concentration Is Greater Than 20%

This occurs when the containment steam concentration is between 0-25% and the Fraction of Zirc Reacted is 33%.

DET	CF	0.	27
NO		0.	73

CASE 9. Containment Steam Concentration Low And Hydrogen Concentration Is 16-20%

This occurs when the containment [Steam] is between 25-35% and the Fraction of Zirc Reacted is 33%.

D	ET		C	F				0	я.	1	6	
N	0	D	E	T	C	F		0		8	4	

CASE 10. Otherwise, Should Never Reach This Case

DET CF 0. NO 1.

- Event Dependencies: Event Type (Event 3), RPV Injection Failure Time (Event 6), Offsite Power Recovery Time (Event 7), Mode of RHR Spray Operation Early (Event 13), Containment Steam Concentration (Event 19), Fraction of Zirconium Inventory Reacted In-Vessel (Event 20), Large H2 Burn Ignited During Core Damage (Event 22).
- Quantification Basis: Grand Gulf (Brown 1990) APET Events 18 and 44, and Sequoyah Analysis (Volume 5 Rev 1 Part 1 Page 2.2, Part 2 Table A.3.1-1) page 15 and 16.

EVENT 24. CONTAINMENT FAILURE BEFORE RPV FAILURE

Two Branches:

FAILURE	Containment	Failure Bef	ore RPV	/ Failure
NO FAILURE	No Containm	ent Failure	Before	RPV Failure

This event assigns a probability of 1 for failure to sequences with overpressure failure prior to core damage and to sequences with hydrogen detonation failure. For the hydrogen burns sequences remaining, this event compares the expected peak hydrogen burn pressure (Parameter 1 in APET event 22) with the Perry Containment Fragility Curve (Reference section 4.4.3) using a user function and returns the associated containment failure probability.

EVNTRE Question Type: 6	(Dependent Event using previously d and a User Function)	efined parameters
PROBABILITIES:		
CASE 1.	Containment Failed At Core Damage	
	FAILURE 1. NO FAILURE 0.	
CASE 2.	lydrogen Detonation Containment Failur	e
	FAILURE 1. NO FAILURE 0.	
CASE 3.	Otherwise, For Those Sequences With th Intact At Core Damage - Det Probability of Containment Due To The Remaining Large	termine the Failure
USER FUN	TION: FAILURE	NO FAILURE
If Peak	ontainment Pressure > 80 Psig 1. > 75 0.98 > 70 0.90 > 65 0.69 > 60 0.39 > 55 0.15 > 50 0.034 Else 0.	0. 0.02 0.10 0.31 0.61 0.85 0.966 1.
Event Dependencies:	Containment Status At Core Damage (Ev Hydrogen Detonation Containment Failu	ent 2), and re (Event 23).
Quantification Basis:	Perry Nuclear Power Plant IPE Contain Analysis, and IPE Engineering Calcula	ment Capacity tion - Containment

H.3 - 38

Fragility.

Two Branches:

ANCHORAGE PEN-DOM/NO CF Containment Anchorage Failure Mode Containment Penetration or Dome Failure Mode, Or No Containment Failure Mode

Given that the containment has failed as a result of a hydrogen burn, this event assigns a conditional probability for the mode of containment failure. The conditional probability that is assigned is dependent on the peak burn pressure (Parameter 1) and is evaluated in a user function. The user function assessed the conditional probability for each Perry failure mode based on the the Perry Containment Capacity (Reference section 4.4.3.2) for rapid containment loading conditions.

Note that this succinct sorting of failure modes into just two categories can be used to characterize penetration/dome containment failure with a question asking sequence of: 1) No Containment Failure, 2) Anchorage Containment Failure, and then 3) Containment Failure (which would provide the remaining Penetration/Dome containment failures).

EVNIRE Question Type: 6. (Dependent Event using previously defined parameter and a user function)

PROBABILITIES:

CASE 1. Containment Failed At Core Damage

This case is for gradual steam overpressure failure prior to the initiation of core damage.

ANCHORAGE 0.15 PEN-DOM/NO CF 0.85

CASE 2.

Hydrogen Detonation Containment Failure

All detonation failures are considered to most likely occur in the dome region and are assigned to penetration/dome failure or no containment failure.

ANCHORAGE 0. PEN-DOM/NO CF 1.

CASE 3.

No Containment Failure

This sorting case assigns the no containment failure sequences.

ANCHORAGE		0.
PEN-DOM/NO	CF	1.

CASE 4.

Otherwise, The remaining sequences are Hydrogen Deflagration Containment Failure

USER FUNCTION	ANCHURAGE PENETRAT		
If Peak Containment Pressu		Psig 1.	0.
	> 130	0.98	0.02
	> 120	0.95	0.05
	> 115	0.90	0.10
	> 110	0.85	0.15
	> 105	0.78	0.22
	> 100	0.71	0.29
	> 95	0.61	0.39
	> 90	0.51	0.49
	> 85	0.41	0.59
	> 80	0.30	0.70
	> 75	0.21	0.79
	Else	0.15	0.85

Event Dependencies:	Containment Status At Core Damage (Event 2), Hydrogen Detonation Containment Failure (Event 23), and Containment Failure Before RPV Failure (Event 24).				
Quantification Basis:	Perry Nuclear Power Plant IPE Containment Capacity Analysis, and IPE Engineering Calculation - Containment Failure Modes Conditional Probability.				

H.3.4. INJECTION & SPRAY FAILURE DUE TO CONTAINMENT FAILURE BEFORE RPV FAILURE

This APET Group determines in Events 26 thru 29 the probability that containment failure causes the loss of all RPV injection (assuming the RPV injection has not previously failed) and the failure of RHR containment spray.

The two possible outcomes from this APET group are:

Injection and Spray Failure No Failure

.....

EVENT 26. CONTAINMENT FAILURE BEFORE RPV FAILURE IMPACT ON ECCS INJECTION & SPRAY PIPING



- PIPE FAIL

Two branches:

FAILURE	Failure of ECCS Injection & Spray Piping	5
NO FAILURE	No Piping Failure.	

This event assesses the probability that either the dynamic forces or movement of the containment which occur during gross failure are sufficient to disrupt the injection and spray system piping when the containment is intact at core damage. Disruption of this piping is expected to be a serious threat for containment anchorage failure.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1.

Anchorage Failure Mode Containment Failure With the Cntmt Intact At Core Damage Or With Critical ATWS

Those sequences with the containment intact at core damage and those associated with Critical ATWS and the containment not intact at core damage are evaluated for impact to associated systems when anchorage failure occurs before RPV Failure.

Note that the Plant Damage State event trees include this impact of containment failure in the Late Injection Fault Trees for SBO & LOOP and OTHERS when the containment has failed due to overpressure prior to core damage initiation. Therefore these sequences are excluded from this case.

FAILURE	0.9
NO FAILURE	0.1

CASE 2.

Otherwise, For The Remaining Sequences Default to No Failure

> FAILURE 0. NO FAILURE 1.

Event	Dependenc	ies:

Containment Status At Core Damage (Event 2), Event Type (Event 3), Mode of Containment Failure Before RPV Failure (Event 25).

Quantification Basis: Containment Capacity Analysis (Gilbert/Commonwealth 1992) and engineering judgement.

EVENT 27. CONTAINMENT FAILURE BEFORE RPV FAILURE IMPACT ON ECCS INJECTION & SPRAY MOTORS

- MTR FAIL

Two branches:

AILURE	- Failure of ECCS Injection &	Spray Motors
NO FAILURE	No Motor Failure.	

This event assesses the probability that leakage of water, steam or hot gases from containment into the Auxiliary Building which may occur at containment failure cause failure of the ECCS injection and spray system motors.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. Containment Failure With the Containment Intact At Core Damage Or With Critical ATWS And No Piping Failure (Modeled in the Above Event)

Those sequences with the containment intact at core damage and those associated with Critical ATWS and the containment not intact at core damage are evaluated for impact to associated systems during anchorage or penetration/dome containment failure before RPV failure. Those sequences which are modeled above in Event 26 with piping failure are not evaluated in this case, since piping failure is considered a single failure cutset.

Note that the Plant Damage State event trees include this impact of containment failure in the Late Injection Fault Trees for SBO & LOOF and OTHERS when the containment has failed due to overpressure prior to core damage initiation. Therefore these sequences are excluded from this case.

FAI	LURE	0.	5
NO	FAILURE	0.	5

CASE 2.

Containment Heat Removal With Vent Or Containment Not Isolated During SBO

Venting within the Fuel Handling Building may overpressurize low pressure rated BISCO seals in the Shield Building penetrations (and other plant walls) and provide a steam and radiation release path to the in plant areas with firewater alternate injection lineup valves or may release to the environment through doorways and building seals to the diesel driven firewater pump oil tank and the backup fire truck engine.

H.3 - 42

FAILURE	0.05	
NO FAILURE	0.95	

CASE 3.

Otherwise, For No Containment Failure And No Loss

Of Isolation - Default to No Failure.

FAI	LURE	0.
NO	FAILURE	1.

Event Dependencies: Containment Status At Core Damage (Event 2), Event Type (Event 3), Containment Isolated (Event 5), Containment Heat Pemoval With Vent (Event 9), Containment Failure Before RPV Failure (Event 24), Containment Failure Before RPV Failure Impact On ECCS Injection and Spray Piping (Event 26).

Quantification Basis: Containment Capacity Analysis (Gilbert/Commonwealth 1992) and engineering judgement.

EVENT 28. CONTAINMENT FAILURE BEFORE RPV FAILURE STEAM OR RADIATION RELEASE IMPACT ON FIREWATER INJECTION

- STM/RAD

Two branches:

FAILURE NO FAILURE Failure of Firewater Injection No Failure

This event assesses the probability that leakage of steam or radionuclides from containment will limit personnel access to the firewater system and result in failure to perform required local manual actions to initiate, or to assure continued operation of the firewater alternate injection system.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1.

Containment Failure With the Containment Intact At Core Damag Or With Critical ATWS And No Piping Failure

Those sequences with the containment intact at core damage and those associated with Critical ATWS and the containment not intact at core damage are evaluated for impact to associated systems during anchorage or penetration/dome containment failure before RPV failure. Those sequences which are modeled above in Event 26 with piping failure are not evaluated in this case, since piping failure is considered a single failure cutset. Failure of the ECCS motor and firewater alternate injection will be considered a two failure cutset in the following summary event.

FAILURE 0.5

H.3 - 43

NO FAILURE 0.5

CASE 2. Containment Heat Removal With Vent Or Containment Not Isolated During SBO

> FAILURE 0.1 NO FAILURE 0.9

CASE 3. Otherwise, For Other Sequences FAILURE 0. NO FAILURE 1.

- Event Dependencies: Containment Status At Core Damage (Event 2), Event Type (Event 3), Containment Isolated (Event 5), Containment Heat Removal With Vent (Event 9), Containment Failure Before RPV Failure (Event 24), Containment Failure Before RPV Failure Impact On ECCS Injection and Spray Piping (Event 26).
- Quantification Basis: Containment Capacity Analysis (Gilbert/Commonwealth 1992) and engineering judgement.

EVENT 29. INJECTION & SPRAY FAILURE DUE TO CONTAINMENT FAILURE BEFORE RPV FAILURE

Two branches:

INJ & SPRY FAIL Failure of Injection & Spray NO FAILURE No Failure.

This event summarizes the results of the three APET events

EV. TRE Question Type: 2. (Dependent Sorting Event)

SORTING:

CASE 1. ECCS Injection & Spray Piping Failure

Single failure modeled in Event 26, Containment Failure Before RPV FAilure Impact on ECCS Injection & Spray Piping.

> INJ & SPRY FAIL 1. NO FAILURE 0.

CASE 2.

ECCS Injection And Alternate Injection Failure

- INJ/SP FL

For the loss of all late injection include a two failure cutset modeled in Event 28, ECCS Injection & Spray Motor Failure; and in Event 29, Firewater Injection Failure.

> INJ & SPRY FAIL 1. NO FAILURE 0.

CASE 3.

Otherwise, For Other Remaining Sequences Where All Injection Is Not Failed Default to No Failure.

INJ & SPRY FAIL 0. NO FAILURE 1.

Event Dependencies: Previous three events (Event 26, 27, and 28).

Quantification Basis: Not Applicable.

H.3.5. DRYWELL FAILURE AT/NEAR RPV FAILURE

This APET Group in Events 38 thru 39 determines the probability of drywell failure at or near the time of RPV failure. A number of possible mechanisms have been identified which may lead to drywell failure at this time period. These include alpha mode steam explosion failures (which by definition fails the drywell and containment), an in-vessel steam explosion which fails the lower RPV head, an ex-vessel steam explosion in the pedestal cavity, drywell overpressure failure, and a large hydrogen burn in containment.

The two possible outcomes from this APET group are:

Drywell Failure No Drywell Failure

EVENT 30. ALPHA MODE STEAM EXPLOSION DRYWELL AND CONTAINMENT FAILURE - ALPHA

Two branches:

ALPHA	Al	oha	Mod	e	Fai	lur	e
NO ALPHA	No	Alp	ha	Mo	de	Fai	lure

This event assesses the probability that an in-vessel steam explosion occurs with sufficient energy to rupture the RPV upper head and create a missile with sufficient energy to fail the drywell and containment. The probability of an in-vessel steam explosion has been shown to be dependent on whether the RPV has been depressurized. The probabilities for alpha mode containment failure were taken directly from the Grand Gulf (Brown 1990) APET. These values are judged to be bounding values rather than best estimates.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. RPV Depressurized During Core Damage ALPHA 0.01 NO ALPHA 0.99

CASE 2. Otherwise, Sequences With RPV Not Depressurized

ALPHA	0.001
NO ALPHA	0.999

Event Dependencies:	RPV Depressurized	During Core Damage (Event 13).
Quantification Basis:	Grand Gulf (Brown	1990) APET Event 58.

EVENT 31. MODE OF IN-VESSEL STEAM EXPLOSION BOTTOM HEAD RPV FAILURE - INV_EXPLN

Four Branches:

ALPHA	ALPHA Mode In-Vessel Steam Explosion
NO FAILURE	No RPV In-Vessel Steam Explosion Failure
LARGE VF	Large Bottom Head RPV Failure
SMALL VF	Small Lover Head RPV Failure

This event assesses the probability that an in-vessel steam explosion occurs with sufficient energy to rupture the lower head of the RPV. This event further differentiates between large (2 square meters) and small (0.1 square meter) vessel failure sizes. As noted previously the probability of an in-vessel steam explosion being triggered has been shown to be dependent on the primary system pressure.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1.

Alpha Mode Failure

ALPHA		1.
NO FAI	LURE	0.
LARGE	VF	0.
SMALL	VF	0.



CASE 2. Sequences With RPV Depressurized During Core Damage

A review of the NUREG/CR-4551 Grand Gulf APET (Brown 1090), the Steam Explosion Review Report NUREG-1116 (SERG 1985), and BWR Lower Head Failure Assessment For CSNI Comparison Exercises (Rempe 1991) has convinced the Perry IPE analysts that the probabilities for steam explosion induced RPV botter head failure were significantly overestimated in NUREG/CR-4551. Consequently the Grand Gulf 4:31 failure estimates were reduced by a factor of 10.

ALPHA	0.
NO FAILURE	0.94
LARGE VF	0.034
SMALL VF	0.026

CASE 3. Otherwise, Remaining Sequences With No Alpha Mode Failure And RPV Not Depressurized

Reference the above discussion for case 2.

ALPHA	0.
NO FAILURE	0.993
LARGE VF	0.004
SMALL VF	0.003

Event Dependencies:

RPV Depressurized During Core Damage (Event 13) and Alpha Mode Steam Explosion Dryvell and Containment Failure (Event 30).

Grand Gulf (Brown 1990) APET Events 60 and 62, Steam Quantification Basis: Explosion Review Group (SERG 1985), and BWR Lover Head Failure Assessment For CSNI Comparison Exercises (Rempe 1991); and engineering judgement.

EVENT 32. RPV FAILURE MODE AND FAILURE SIZE

- AREA FAIL

Four Branches:

ALPHA	ALPHA Mode In-Vessel Steam Explosion
NO FAILURE	No RPV Failure - Debris Cooled In-Vessel
LARGE VF	Large Size Bottom Head RPV Failure
SMALL VF	Small Size Bottom Lower Head RPV Failure

This event characterizes the RPV failure is and the vessel breach failure size. The Alpha mode failure, the large lover head failure by in-vessel steam explosion, and the small lower head failure by in-vessel steam explosion determined in the last APET event are similarly categorized here with regard to RPV failure size. If the debris is not cooled in-vessel, and the RPV has not been previously failed by an Alpha mode failure or by a steam explosion induced lower head failure, this event then determines the probability of large (2 square meters) and small (0.1 square meter) vessel failure sizes due to thermal attack on the lower head.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1.

Alpha Mode Failure

ALPI	1A		1.
NO I	TAT	LURE	0.
LARC	3E	VF	0.
SMAI	LL	VF	0.

CASE 2.

In-Vessel Steam Explosion Large Bottom Head RPV Failure

ALPHA 0. NO FAILURE 0. LARGE VF 1. SMALL VF 0.

CASE 3.

In-Vessel Steam Explosion Small Bottom Head RPV Failure

ł	LP	AH		0
ą	0	FAI	LURE	0
	AR	GE	VF	0
3	MA	LL	VF	1

CASE 4.

Core Debris Cooled In-Vessel And RPV Late Injection Available

ALPHA	0.
NO FAILURE	1.
LARGE VF	0.
SMALL VF	0.

CASE 5.

Otherwise, Core Debris Causes RPV Melt Thru Failure Assign RPV Failure Size

ALPHA	0.
NO FAILURE	0.
LARGE VF	0.1
SMALL VF	0.9

Event Dependencies:

Cooled In-Vessel (Event 15), Injection & Spray Failure Due to Containment Failure (Event 29), Alpha Mode Steam



Explosion Drywell and Containment Failure (Event 30), and Mode Of In-Vessel Steam Explosion Bottom Head RPV Failure (Event 31).

Quantification Basis:

Grand Gulf (Brown 1990) APET Event 63; engineering judgement based on a recent study of BVR lover head failures (Rempe 1991).

Event 33. WATER IN PEDESTAL AT RPV FAILURE

- PED WATER

Four Branches:

FLOOD + INJ	Flooded From	Wier Flow and Continuing Injection
RPV + INJ	Residual RPV	Water and Continuing Injection
FLOOD		Suppression Pool Wier Overflow
RPV WATER	Residual RPV	Water Only

Water in the reactor pedestal cavity at the time of RPV failure can impact the accident progression in several ways. With water in the pedestal cavity there is an increased potential for steam explosions (or rapid steam generation) which may threaten the integrity of the pedestal. Water in the cavity early also enhances the possibility that the debris will be coolable.

The branch definitions are summarized above. A flooded pedestal cavity occurs as a result of pressurization of the containment wetwell (such as evaporation or boiling of the suppression pool, or by a hydrogen burn), depression of the pool level on the wetwell side of the suppression pool and overflow of the suppression pool into the dryvell. Continuous injection to the pedestal cavity results from the addition of injection to the vessel following vessel breach. Residual RPV water refers to the water remaining in the RPV which is discharged from the RPV coincidentally (or following) expulsion of the core debris in the lover RPV head.

EVNTRE Question Type: 2. (Dependent Sorting Event)

SORTING

CASE 1.

Late In-Vessel Injection & Cavity Supply Available And Cavity Flooded Due To SBO With Long Term Injection Or Large Hydrogen Burn

FLO(D	+ INJ	1.
RPV	+	INJ	0.
FLO	DD		0.
RPV	W	ATER	0.

CASE 2.

Late In-Vessel Injection & Cavity Supply Not Available And Cavity Flooded By A Large Burn During Core Damage, Or Cavity Flooded Due To SBO With Long Term Injection

	FLOOD + INJ RPV + INJ FLOOD RPV WATER	0. 0. 1. 0.
CASE 3.		Injection & Cavity Supply ble And Cavity Not Flooded
	FLOOD + INJ RPV + INJ FLOOD RPV WATER	0. 1. 0. 0.
CASE 4.		Remaining Sequences idual RPV Water Only Is Available
	FLOOD + INJ RPV + INJ FLOOD RPV WATER	0. 0. 0. 1.
vent Dependencies:	6), Late In-Ve H2 Burn During	ent 3), RPV Injection Failure Time (Event essel Injection Available (Event 12), Large Core Damage (Event 22), Injection & Spray Containment Failure Before RPV Failure
uantification Basis:	flooding of th will only occu (past 11 hours containment ar breaker isolat	rolled hydrogen combustion phenomena, he cavity due to a heated suppression pool in during a SBO with long term injection b) due to the differential pressure between hd the drywell since the Drywell vacuum tion valves are closed. All other have the Drywell Vacuum Breaker ves open.

EVENT 34. PEDESTAL FAILURE DUE TO OVERPRESSURE AT RPV FAILURE

- PED OP

TWo Branches:

Ev

Qu

PED FAIL	Pedestal Failure Due to Overpressurization
NO FAIL	No Pedestal Failure

Given that the debris is not cooled in-vessel, and that the RPV has not been previously failed by an ALPHA mode failure, this event determines the probability of of overpressurization of the pedestal resulting from the depressurization of the RPV and the quenching of the debris. MAAP calculations indicate that the pedestal integrity may be challenged from overpressure at the time of RPV failure under the following conditions:

- High RPV pressure and a large RPV breach size (on the order of 2 square meters).
- High RPV pressure and any RPV breach size with water in the pedestal cavity at RPV failure.
- Low RPV pressure, a large RPV breach and Water in the pedestal cavity at RPV failure.

The peak pedestal pressures which were observed in the MAAP calculations are summarized in Table H.3.3-1.

In NUREG/CR-4551 it was estimated that the median (differential) failure pressure for the Grand Gulf Mark III pedestal (which is similar in design to Perry) would be 188 psi. Considering the results shown on Table H.3.3-1 and assuming 188 psi as the failure pressure for quasi-static loading, the following cases were evaluated in the Perry APET for pedestal overpressurization.

EVNTRE Question Type: 2. (Dependent Sorting Events)

SORTING:

CASE 1. No RPV Failure With Debris Cooled In-Vessel

PEDESTAL FAIL 0. NO FAILURE 1.

CASE 2. RPV Not Depressurized At RPV Failure And Pedestal Cavity Flooded

> PEDESTAL FAIL 1. NO FAILURE 0.

CASE 3. RPV Not 'spressurized At RPV Failure And Large RPV Failure Size

> PEDESTAL FAIL 1. NO FAILURE 0.

CASE 4. RPV Not Depressurized At RPV Failure, No Water in Pedestal Cavity From Flooding, And Small RPV Failure Size

> PEDESTAL FAIL 0. NO FAILURE 1.

CASE 5. RPV Depressurized At RPV Failure Pedestal Cavity Flooded And Large RPV Failure Si.e

> PEDESTAL FAIL 1. 0. NO FAILURE

CASE 6.

Remaining Sequences Where RPV Is Depressurized

PEDESTAL FAIL 0. NO FAILURE 1.

CASE 7.

Otherwise, Should Never Reach This Case.

PEDESTAL FAIL 0. NO FAILURE 1.

Event Dependencies: RPV Dopressurized During Core Damage (Event 13), RPV Failure Mode And Failure Size (Event 32), Water in Pedestal At RPV Failure (Event 33), .

Quantification Basis: Grand Gulf (Brown 1990) APET Questions 71 and 74. IPE Engineering Calculation - MAAP Analysis of Pedestal Overpressure (reference TABLE H.3.3-1).

- STM EXP

EVENT 35. PEDESTAL CAVITY EX-VESSEL STEAM EXPLOSION

Two Branches:

STM EXPLOSION Large Ex-vessel Steam Explosion NO EXPLOSION No Large Ex-vessel Steam Explosion

This event assesses the probability of a large steam explosion occurring in the pedestal cavity following vessel failure. For sequences where the debris is cooled in-vessel and lover head failure does not occur, then an ex-vessel steam explosion will not occur. For sequences where an in-vessel steam explosion has failed the vessel, it is assumed that a large ex-vessel steam explosion cannot occur.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

8

CASE 1. No RPV Failure With Debris Cooled In-Vessel

STM EXPLOSION 0.

NO FAILURE 1.

CASE 2. No Water In Pedestal Cavity Before RPV Failure

STM EXPLOSION 0. NO EXPLOSION 1.

CASE 3. In-Vessel Steam Explosion Already Failed RPV, Therefore Assume Large Ex-Vessel Steam Explosion Cannot Occur

> STM EXPLOSION C. NO EXPLOSION 1.

CASE 4.

Otherwise, For All Remaining Sequences With Water In Pedestal Cavity At RFV Failure A Large Ex-Vessel Steam Explosion May Occur

STM EXPLOSION 0.86 NO EXPLOSION 0.14

Event Dependencies: Mode of In-Vessel Steam Explosion Bottom 49ad RPV Failure (Event 31), RPV Failure Mode And Failure Size (Event 32), Water in Pedestal At RPV Failure (Event 33).

Quantification Basis: Grand Gulf (Brown 1990) APET Question 67.

EVENT 36. PEDESTAL FAILURE DUE TO STEAM EXPLOSION

- PED EXP

Two Branches:

PEDESTAL FAIL Pedestal Failure Due to Steam Explosion NO FAILURE No Pedestal Failure Due To Steam Explosion

This event assesses the probability of a steam explosion failing the pedestal. Two failure mechanisms are considered. If an in-vessel steam explosion has caused a large breach in the lower reactor vessel head then it is considered possible that a large missile could be created (from part of the vessel lower head) which could cause failure in the pedestal wall. The second failure mechanism involves a steam explosion in the lower pedestal cavity which generates a shock wave which exceeds the impulse load capacity of the pedestal wall.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

In-Vessel Steam Explosion Caused Large Bottom Head Failure

0

PEDESTAU FAIL 0.05 NO FAILURE 0.95

CASE 2.

CASE 1.

No Ex-Vessel Steam Explosion

PEDESTAL FAIL 0. NO FAILURE 1.

CASE 3.

Otherwise, All Rema ing Sequences Are Ex-Vessel Steam Explosion

Grand Gulf NUREG/CR-4551 (Brown 1990) assumed a conditional probability of 0.5 for pedestal failure given a steam explosion in the lower pedestal cavity. Based on a review of NUREG/CR-4551 and NUREG-1116, this estimate appears exceptionally high. The Perry IPE reduced the Grand Gulf NUREG/CR-4551 failure estimate by a factor of 10 for the Perry APET best-estimate.

, Losion Review Group Report (SERG 1985), NUREG-1116.

PED	B	ST	AL	FAIL	0.	05
NO	ŗ	IA	LUR	E	0.	95

Ev('	Dependencies:	Mode of In-Wessel Steam Explosion Bottom Head RPV Failure (Event 31), and Pedestal Cavity Ex-Vessel Steam Explosion (Event 35).
Quant	ification Basis:	F and Gulf (Brown 1990) APET Question 75. The Steam

EVENT 37. DRYVELL FAILURE DUE TO PUDESTAL FAILURE

- DW PED

Two Branches:

DRYWELL FAIL Drywell Failure Due To Pedestal Failure NO FILLURE No Drywell Failure Due To Pedestal Failure

Given that pedestal failure has occurred this event assesses the probability that pedestal failure causes loss of dryvell integrity.

EVNTRF Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. Pedestal Failure From Other Than Alpha Mode Failure

This case includes pedestal failure due to overpressure at RPV failure and pedestal failure due to steam explosions.

DRY	WELL	FAIL	0.	17	5
NO	FAILU	RE	Ô,	82	5

CASE 2.

Otherwise, For the Remaining No Pedestal Failure Sequences, the Default is No Dryvell Failure

DRYWELL FAIL 0. NO FAILURE 1.

Event Dependencies: Pedestal Failure Due to Overpressure At RPV Failure (Event 34), and Pedestal Frilure Due To Steam Explosion (Event 36).

Quantification Rasis: Grand Gulf (Brown 1990) APET Guestion 76.

EVENT 38. DRYVELL OVERPRESSURE FAILURE AT RPV FAILURE

- DW OP

Two Branches:

DRYWELL FAIL Drywell Overpressure Failure NO FAILURE No Drywell Overpressure Failure

This event assess the probability that drywell overpressure failure will occur following RFV failure. In order for drywell pressurization to challenge drywell integrity the RFV must be at high pressure at vessel failure and the vessel breach size must be large.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. No RPV Failure With Debris Cooled In-Vessel

DRYWELL FAIL 0. NO FAILURE 1.

CASE 2. RPV Not Depressurized At RPV Failure And Large RPV Failure Size

> DRYWELL FAIL 0.01 NO FAILURE 0.99

Otherwise,	the Rema	ining	Sequence	8.8
	Default	to No	Dryvel1	Failure

"RYWELL FAIL 0. NO FAILURE 1.

EVENT DEPENDENCIES: RPV Depressurized During Core Damage (Event 13), RPV Failure Mode And Failure Size (Event 32). QUANTIFICATION BASIS: Grand Gulf (Brown 1990) APET Questions 19 and 70. IPE Containment Capacity Analysis (Gilbert/Commonwealth

EVENT 39. DRYVELL FAILURE AT/NEAR RPV FAILURE

- EARLY DW

Two Branches:

CASE 3.

DRYWELL FAIL Drywell silure NO FAILURE No Drywell Failure

1992).

This summary event assess the probability that drywell failure will occur following RPV failure. This event considers drywell failure resulting from alpha mode steam explosions, pedestal failure, and overpressure failure.

EVNTRE Question Type: 2. (Dependent Sorting Event)

SORTING:

CASE 1.

1. No RFV Failure With Debris Cooled In-Vessel

DRYVELL FAIL O. NO FAILURE 1.

CASE 2.

Dryvell Failure Due To Alpha Failure, Pedestal Failure, Or Dryvell Overpressurization Failure

DRYWELL FAIL 1. NO FAILURE 9.

CASE 3. Otherwise, the Remaining Sequences Default to No Dryvell Failure

> DRYWELL FAIL 0. NO FAILURE 1.

EVENT DEPENDENCIES:

Alpha Mode Steam Explosion Drywell and Contrinment Failure (Event 30), RPV Failure Mode and RPV Failure Size (Event 32), Dryvell Failure Due To Pedestal (Event 37), and Dryvell Overpressure Failure At RPV Failure (Event 38).

H.3.6. MOF INTAINMENT FAILURE AT/NEAR RPV FAILURE

This APET Group determines with Events 40 thru 45 the probability of containment failure, and for containment fuilure, assigns the mode of containment failure at (or within a few hours of) reactor pressure vessel failure. Containment failure at RPV failure can potentially result from a combination of energetic processes and events which may occur at reactor vessel breach. These processes and events include hydrogen combustion and a large in-vessel steam explosion causing an alpha mode containment failure.

For the Perry APET, steam explosion induced (alpha mode) containment failures are also considered to result in a catastrophic rupture of the containment. Postulated alpha mode containment failures result from large coherent in-vessel steam explosions which fails the reactor vessel and generates a missile (from part of the reactor vessel upper head) with sufficient mass and energy to fail (the drywell and) containment. There is a substantial body of evidence to suggest that in-vessel steam explosions do not represent a credible threat to early containment failure (i.e., the probability of early containment failure from in-vessel steam explosions is negligibly small). This opinion appears to be shared by the authors of Appendix 1 to Generic Letter 88-20. However, it this event should occur, it can result in a large and early environmental releases. Therefore, this event is included in the Perry IPE APET.

Experimental evidence and calculations have shown that steam explosions are unlikely at elevated pressure, subsequently the probability of an alpha mode containment failure should be significantly less for h pressure sequences than for low pressure sequences.

This event is dependent on the following Events in the Perry APET.

EVENT 40. CONTAINMENT STEAM CONCENTRATION AT/NEAR RPV FAILURE

- ST VB

Six Branches:

0-15 % 15-25 % 25-35 % 35-45 % 45-55 % Containment Steam Volume Percent

H.3 - 57

This branch assesses the containment steam concentration at or near RPV failure (from the time of RPV failure to 1 hour afterwards). The probability of hydrogen burn ignition and the efficiency of the burn (considered in subsequent events) are dependent upon the branch taken under this heading. The containment steam concentration is a function of the mode of spray operation, the sequence type, the time of injection failure and whether the containment is intact at core damage. The steam concentrations regime probabilities given for the cases below were estimated using MAAF results for each case.

EVNTILE Question Type: 2. (Dependen' Split Fractions)

PROBABILITIES:

CASE 1. Spray Loop Operation At Design Cooling

With a containment spray loop operating at design cooling with containment heat removal optimized with the Residual Heat Removal heat exchanger, the steam concentration would be low.

	0	-	1	5	%		1.
1	5		2	5	%		0.
2	5	-	3	5	1%		0.
3	5	-	4	5	×.		0.
4	5	-	5	5	1/2		0.
		>	5	5	%		0.

CASE 2.

SBO And No Injection Failure Early (0- 2.8 Hrs)

0-15	%	1.
15-25	%	0.
25-35	×	0.
35-45	%	0.
45-55	2	0.
>55	%	0.

CASE 3.

SBO And RCIC Injection Failure (2.8-4.2 Hrs)

0-15	%	0.
15-25	%	0.44
25-35	%	0.56
35-45	%	0.
45-55	%	0.
>55	%	0,

CASE 4.

SBO And HPCS Injection Failure (> 4.2 Hrs)

	0-	1	5	%	0.
1	5-	2	5	2	0.

2	5		1	5	2	0.
3	5		4	5	%	0.
6	5	-	5	5	2	0.
		5	5	5	2	1.

CASE 5.

Containment Failed At Core Damage

0-15	2	0.
15-25	%	0.
25-35	%	0.
35-45	%	0.
45-55	%	0.
>55	%	1.

CASE 6.

Otherwise, All Other Sequences Default to Low Steam Concentration

All other sequences are conservatively evaluated by assuming a low steam concentration.

0	-15	%	1.
5	-25	%	0.
	-35		0.
5	-45	%	0.
5	-55	%	0.
	>55	7.	0.

Event Dependencies:

Containment Status At Core Damage (Event 2), Event Type (Event 3), RPV Injection Failure Time (Event 6), and Mode of RHR Spray Operation Early (Event 18).

Quantification Basis:

IPE Engineering Calculation - Hydrogen Burns [with MAAP 3.0B Rev 7.02 using "Recommended Sensitivity Analyses For An IPE Using MAAP 3.0B" (EPRI 1991)].

EVENT 41. FRACTION ZIRCONIUM INVENTORY REACTED AT/NEAR RPV FAILURE - H2_VB

Three Branches:

33	%	Core	Inventory	Zirconium	Oxidized
22	%				
11	%				

The fraction of zirconium reacted in-vessel and during RPV failure blowdown is used to determine the concentration of hydrogen in containment at/near RPV failure (from the time of RPV failure to an hour afterwards). Three discrete regimes are used to represent the range of zirconium oxidation. These regimes are representative of the amounts estimated in the Grand Gulf Analysis (Brown 1990) and for Perry specific MAAP calculations. The Perry IPE MAAP calculations implemented the best-estimate values for the model parameters discussed in the "Recommended Sensitivity Analyses For An Individual Plant Examination Using MAAP 3.0B" (EPRI 1991). The IDCOR BWR "blockage" model of Local Blockage option was considered more likely and the No Blockage option less likely, and a probability of 0.8 and 0.2 was assigned to each option, respectively. These results were used to define the split fractions shown below.

EVNTRE Question: Type 2. (Dependent Split Fractions)

PROBABILITIES:

E

CASE 1.	SBO And No Inject	ion Failure Early (0 - 2.8 Hrs)
		1. 0. 0.
CASE 2.	SBO And RCIC Inje	ection Failure (2.8 - 4.2 Hrs)
	11 % 22 % 33 %	0.69 0.31 0.
CASE 3.	SBO And HPCS Inj	ection Failure (> 4.2 Hrs)
	11 % 22 % 33 %	0.79 0.21 0.
CASE 4.		ther Remaining Sequences Conservatively lt to SBO And RCIC Injection Failure
	11 % 22 % 33 %	0.69 0.31 0.
vent Dependencies:	Event Type (Even (Event 6).	t 3), and RPV Injection Failure Time
uantification Basis:	3.0B Rev 7.02 us	Calculation - Hydrogen Burns [with MAAP ing "Recommended Sensitivity Analyses MAAP 3.0B" (EPRI 1991)].
	For comparison r Event 35.	reference Grand Gulf (Brown 1990) APET

EVENT 42. HYDROGEN IGNITION SOURCES AVAILABLE AT/BEFORE RPV FAILURE - IG SOURC

Two Branches:

NO IGN SOURCE No Hydrogen Ignition Sources IGNITN SOURCE Hydrogen Ignition Sources Available

With a continuous ignition source available in containment (at the time of RPV failure) it is assumed that controlled hydrogen combustion (or small hydrogen burns) will preclude the build-up of hydrogen concentrations whose combustion would threaten containment integrity. A continuous ignition source is assumed to be available if the hydrogen ignition system is operating or if a burn in containment has already occurred during core damage. In the latter situation it is assumed that the prior burn which has occurred will result in ignition of combustible materials in containment which will act as ignition sources. This event also includes a recovery of the human interaction, Operator fails to initiate Hydrogen Ignition System.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1.

Hydrogen Ignition System Available Before RPV Failure

NO I	GN	SOU	RCE	0,
IGNI	TN	SOU	RCE	1.

CASE 2.

No Loss Of AC Power, Operator Failure To Initiate Hydrogen Ignition System, And Recovery of Hydrogen Ignitors

When AC power is never lost, a nominal screening value is assigned to the recovery of the human interaction, Operator Fails To Initiate Hydrogen Ignition System, included in Event 1f, Hydrogen Ignition System Available. For the loss of all injection sequence the expected containment hydrogen concentration at vessel failure would be < 4% (which is the SAFE region of the PEI Hydrogen Deflagration Overpressure Limit) and the recovery of Hydrogen Ignitors at RPV failure (1.8 hours into the sequence and 1.3 hours after the Level 1 cue) is very likely. For a sequence like loss of RCIC at 2.8 hours, when hydrogen generation commences a rapid increase in hydrogen concentration to above the Hydrogen Deflagration Overpressure Limit may occur in a half hour interval. However, recovery of Hydrogen Ignitors for a loss of RCIC transient with AC power is supported by the relatively long period of time from the Level 1 cue at about 4 hours to 2200 F maximum fuel clad temperature when hydrogen generation commences actively at 1.5 hours.

Since time windows greater than an hour generally exist for Perry IPE sequences for recovery of Hydrogen Ignitors and hydrogen analyzers are available for hydrogen contentration information, a screening value human error probability of 0.1 is conservatively assigned for this

case.

NO	IGN	SOU	RCE	0.1
IGN	ITN	SOU	KCE.	0.9

CASE 3. Hydrogen Burns Before RPV Failure

Both large and small hydrogen burns are included.

NO IGN SOURCE 0. IGNITN SOURCE 1.

CASE 4. Otherwise, For Remaining Sequences No Continuous Ignition Source Is Available

> NO IGN SOURCE 1. IGNITN SOURCE 0.

EVENT DEPENDENCIES: Event Type (2vent 3), Hydrogen Ignition System Available (Event 16), Small H2 Burns At Low H2 Concentrations (Event 21), and Large H2 Burn During Core Damage (Event 22).

QUANTIFICATION BASIS: IPE Human Interaction Technical Assignment File, IPE Engineering Calculation - MAAP Accident Progression Analyses, Perry Plant Emergency Instruction, and Discussion with Operation and Chemistry Staff.

Event 43. HIGH PRESSURE MELT EJECTION AT RPV FAILURE

Tvo Branches:

HPME High Pressure Melt Ejection NO HPME No High Pressure Melt Ejection

This event assesses whether a high pressure melt ejection occurs from the reactor pedestal cavity following vessel failure. For HPME to occur the RPV pressure must be elevated (above several hundred psi) at the time of vessel failure. HPME involves the entrainment and fragmentation of the debris in the pedestal cavity and transport of the debris throughout the dryvell. If the dryvell has failed, then an HPME event can provide an ignition source for hydrogen in the containment.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. No RPV Failure With Debris Cooled In-Vessel

No HPME occur when the debris is cooled in-vessel with no subsequent RPV injection failure.

HPM	E	0.
NO	HPME	1.

CASE 2.

RPV Depressurized During Core Damage

HPME	0.
NO HPME	1.

CASE 3.

Otherwise, For Remaining Sequences RPV Failure At High Pressure And HPME May Occur

HPME 0.8 NO HPME 0.2

Event Dependencies: RPV Depressurized During Core Damage (Event 13), RPV Failure Mode and Failure Size (Event 32).

Quantification Basis: Grand Gulf (Srown 1990) APET Event 64.

Event 44. LARGE HYDROGEN BURN IGNITED AFTER RPV FAILURE

- LG BRN

Two Branches:

NO BURN IGN No Large Hydrogen Burn LG BURN IGN Large Hydrogen Burn Ignited

This event assess whether a large hydrogen burn is ignited in containment following RPV failure. If a continuous ignition source is available (as defined in event 42) then a large hydrogen burn is assumed to be prevented. Also if the steam concentration is above 55% then the containment atmosphere is inert to hydrogen burns. The probability that a hydrogen burn is ignited is a function of the following parameters:

- 1. Containment Steam Concentration,
- 2. Containment Hydrogen Concentration
 - (or the fraction of zirconium reacted)
- 3. Dryvell Failure,
- 4. High Pressure Melt Ejection,
- 5. AC Pover Recovery.

Forty eight cases (various combinations of the parameters listed above are identified to perform the quantification). In addition to assessing the

probability of ignition this event also sets two parameter values which are used by subsequent events; peak hydrogen burn pressure (parameter 2), and containment base pressure before the burn (parameter 4). Table H.3.5-1 shows the results of the hydrogen pressure calculation and the input for each case where a large hydrogen burn was predicted to occur, and probability assigned for ignition of a large burn.

EVNTRE Question Type: 4. (Dependent Split Fraction with parameter values set for each case.)

PROBABILITIES:

Hydrogen Ignition Sources Available Early At RPV Failure CASE 1. NO BURN IGN 1. LG BURN IGN 0. BASE PRESS O PEAK PRESS 0 CASE 2. Containment Steam Concentration Is Greater Than 55% NO BURN IGN 1. LG BURN IGN 0. BASE PRESS O PEAK PRESS 0 Containment Steam [0-15%], 33% Zirc Reacted, And CASE 3. Dryvell Failure Or AC Pover Recovery. 12 = [21.7%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 13 PEAK PRESS 147 Containment Steam [U-15%], 33% Zirc Reacted, CASE 4. And High Pressure Melt Ejection. H2 = [21.7%]NO BURN IGN 0.37 LG BURN IGN 0.63 BASE PRESS 17 PEAK PRESS 151 Containment Steam [0-15%], 33% Zirc Reacted, And CASE 5. No DV Failure, or No AC Pover, or No HPME. H2 = [21.7%] NO BURN IGN 0.51 LG BURN IGN 0.49 BASE PRESS 13 PEAK PRESS 147 Containment Steam [15-25%], 33% Zirc Reacted, And CASE 6. Drywell Failure Or AC Power Recovery. H2 = [18.8%] NO BURN IGN 0. BASE PRESS 20 PEAK PRESS 131 LG BURN IGN 1.



CASE 7.	Containment Steam [15-25%], 33% Zirc Reacted, And High Pressure Melt Ejection. H2 = [18.8%]
	NO BURN IGN 0.37 LG BURN IGN 0.63 BASE PRESS 24 PEAK PRESS 135
CASE 8.	Containment Steam [15-25%], 33% Zirc Reacted, And No DW Failure or No AC Power or No HPME. H2 = [18.8%]
	NO BURN IGN 0.51 LG BURN IGN 0.49 BASE PRESS 20 PEAK PRESS 131
CASE 9.	Containment Steam [25-35%], 33% Zirc Reacted, And Drywell Failure Or AC Power Recovery. H2 = [16.4%]
	NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 26 PEAK PRESS 120
CASE 10.	Containment Steam [25-35%], 33% Zirc Reacted, And High Pressure Melt Ejection. H2 = [16.4%]
	NO BURN IGN 0.37 LG BURN IGN 0.63 BASE PRESS 30 PEAK PRESS 124
CASE 11.	Containment Steam [25-35%], 33% Zirc Reacted, And No DW Failure or No AC Power or No HPME. H2 = [16.4%]
	NO BURN IGN 0.51 LG BURN IGN 0.49 BASE PRESS 26 PEAK PRESS 120
CASE 12.	Containment Steam [35-45%], 33% Zirc Reacted, And Drywell Failure Or AC Power Recovery. H2 = [14.1%]
	NO BURN IGN 0. LG BURN IGN 1, BASE PRESS 35 PEAK PRESS 113
CASE 13.	Containment Steam [35-45%], 33% Zirc Reacted, And High Pressure Melt Ejection. H2 = [14.1%]
	NO BURN IGN 0.44 LG BURN IGN 0.56 BASE PRESS 39 PEAK PRESS 117
CASE 14.	Containment Steam [35-45%], 33% Zirc Reacted, And No DV Failure or No AC Power or No HPME. H2 = [14.1%]
	NO BURN IGN .62

H.3 - 65

(1)

LG BURN IGN . 38 BASE PRESS 35 PEAK PRESS 113 CASE 15. Containment Steam [45-55%], 33% Zirc Reacted, And Drywell Failure Or AC Power Recovery. H2 = [11.7%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 46 PEAK PRESS 109 CASE 16. Containment Steam [45-55%], 33% Zirc Reacted, And High Pressure Melt Ejection. H2 = [11.7%] NO BURN IGN 0.57 LG BURN IGN 0.43 BASE PRESS 50 PEAK PRESS 113 CASE 17. Containment Steam [45-55%], 33% Zirc Reacted, And No DW Failure or No AC Power or No HPME. H2 = [11.7%] NO BURN IGN 0.72 LG BURN IGN 0.28 BASE PRESS 46 PEAK PRESS 109 CASE 18. Containment Steam [0-15%], 22% Zirc Reacted, And Dryvell Failure Or AC Pover Recovery. H2 = [15.7%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 11 PEAK PRESS 104 CASE 19. Containment Steam [0-15%], 22% Zirc Reacted, And High Pressure Melt Ejection. H2 = [15.7%]NO BURN IGN 0.44 LG BURN IGN 0.56 FASE PRESS 15 PEAK PRESS 108 CASE 20. Containment Steam [0-15%], 22% Zirc Reacted, And No DW Failure or No AC Power or No HPME. H2 = [15.7%] NO BURN IGN 0.62 LG BURN IGN 0.38 BASE PRESS 11 PEAK PRESS 104 CASE 21. Containment Steam [15-25%], 22% Zirc Reacted And Drywell Failure Or AC Power Recovery. H2 = [13.6%] NO BURN IGN 0. LG BUR I IGN 1. BASE PRESS 17 PEAK PRESS 94.3 CASE 22. Containment Steam [15-25%], 22% Zirc Reacted And High Pressure Melt Ejection. H2 = [13.6%]

	NO BURN IGN 0.44 LG BURN IGN 0.56 BASE PRESS 21 PEAK PRESS 98.3
CASE 23.	Containment Steam [15-25%], 22% Zirc Reacted, And No DW Failure or No AC Pover or No HPME. H2 = [13.6%]
	NO BURN IGN 0.62 LG BURN IGN 0.38 BASE PRESS 17 PEAK PRESS 94.3
CASE 24.	Containment Steam [25-35%], 22% Zirc Reacted, And Drywell Failure Or AC Power Recovery. H2 = [11.9%]
	NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 23 PEAK PRESS 83.3
CASE 25.	Containment Steam [25-35%], 22% Zirc Reacted, And High Pressure Melt Ejection. H2 = [11.9%]
	NO BURN IGN 0.57 LG BURN IGN 0.43 BASE PRESS 27 PEAK PRESS 87.3
CASE 26.	Containment Steam [25-35%], 22% Zirc Reacted, And No DV Failure or No AC Power or No HPME. H2 = [11.9%]
	NO BURN IGN 0.72 LG BURN IGN 0.28 BASE PRESS 2.3 PEAK PRESS 83.3
CASE 27.	Containment Steam [35-45%], 22% Zirc Reacted, And Drywell Failure Or AC Power Recovery. H2 = [10.2%]
	NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 31 PEAK PRESS 80.8
CASE 28.	Containment Steam [35-45%], 22% Zirc Reacted, And High Pressure Melt Ejection. H2 = [10.2%]
	NO BURN IGN 0.57 LG BURN IGN 0.43 BASE PRESS 35 PEAK PRESS 84.8
CASE 29.	Containment Steam [35-45%], 22% Zirc Reacted, And No DW Failure or No AC Power or No HPME. H2 = [10.2%]
	NO BUR 'GN 0.72 LG BUN 0.28 BASE PRESS 31 PEAK PRESS 80.4

1

CASE 30. Containment Steam [45-55%], 22% Zirc Reacted, And Dryvell Failure Or AC Pover Recovery. H2 = [8.5%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 41 PEAK PRESS 80.8 CASE 31. Containment Steam [45-55%], 22% Zirc Reacted, And High Pressure Melt Ejection. H2 = [8.5%] NO BURN IGN 0.57 LG BURN IGN 0.43 BASE PRESS 45 PEAK PRESS 84.8 CASE 32. Containment steam [45-55%], 22% Zirc Reacted, And No DV Failure or No AC Pover or No HPME. H2 = [8.5%] NO BURN IGN 0.72 LG BURN IGN 0.28 BASE PRESS 41 PEAK PRESS 80.8 CASE 33. Containment Steam [0-15%], 11% Zirc Reacted, And Drywell Failure Or AC Pover Recovery. H2 = [8.6%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 8.4 PEAK PRESS 38.2 CASE 34. Containment Steam [0-15%], 11% Zirc Reacted, And High Pressure Melt Ejection. H2 # [8.6%] NO BURN IGN 0.57 LG BURN IGN 0.43 BASE PRESS 12.4 PEAK PRESS 42.2 CASE 35. Containment Steam [0-15%], 11% Zirc Reacted, And No DV Failurs or No AC Pover or No HPME. H2 (8.6%) NO BURN IGN 0.72 LG BURN IGN 0.28 BASE PRESS 8.4 PEAK PRESS 38.2 CASE 36. Containment Steam [15-25%], 11% Zirc Reacted, And Drywell Failure Or AC Power Recovery. H2 = [7.4%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 14 PEAK PRESS 36.2 Containment Steam [15-25%], 11% Zirc Reacted, And CASE 37. H2 = [7.4%] High Pressure Melt Ejection. NO BURN IGN 0.71 0.39 BASE PRESS 18 PEAK PRESS 40.2 LG BURN IGN

CASE 38. Containment Steam [15-25%], 11% Zirc Reacted, And No DV Failure or No AC Pover or No HPME. H2 = [7.4%] NO BURN IGN 0.79 LG BURN IGN 0.21 BASE PRESS 14 PEAK PRESS 36.2 CASE 39. Containment Steam [25-35%], 11% Zirc Reacted, And Dryvell Failure Or AC Pover Recovery. H2 = [6.5%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 19 PEAK PRESS 37.3 CASE 40. Containment Steam [25-35%], 11% Zirc Reacted, And High Pressure Melt Ejection. H2 = [6.5%] NO BURN IGN 0.71 LG BURN IGN 0.29 BASE PRESS 23 PEAK PRESS 41.3 CASE 41. Containment Steam [25-35%], 11% Zirc Reacted, And No DW Failure or No AC Power or No HPME, H2 = [6.5%] NO BURN IGN 0.79 LG BURN IGN 0.21 BASE PRESS 19 PEAK PPLo. 37.3 Containment Steam [35-45%], 11% Zirc Reacted, And CASE 42. Drywell Failure Or AC Power Recovery. H2 = [5.6%] NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 27 PEAK PRESS 40.8 Containment Steam [35-45%], 11% Zirc Reacted, And CASE 43. H2 = [5.6%]High Pressure Melt Ejection. NO BURN IGN 0.71 0.29 BASE PRESS 31 PEAK PRESS 44.8 LG BURN IGN Containment Steam [35-45%], 11% Zirc Reacted, And CASE 44. No DW Failure or No AC Power or No HPME. H2 = [5.6%] NO BURN IGN 0.79 0.21 BASE PRESS 27 PEAK PRESS 40.8 LG BURN IGN Containment Steam [45-55%], 11% Zirc Reacted, And CASE 45. Drywell Failure Or AC Power Recovery. H2 = [4.6%]

H.3 - 69

	NO BURN IGN 0. LG BURN IGN 1. BASE PRESS 36 PEAK PRESS 46.1
CASE 46.	Containment Steam [45-55%], 11% Zirc Reacted, And High Pressure Melt Ejection. H2 = [4.6%]
	NO BURN IGN 0.71 LG BURN IGN 0.29 BASE PRESS 40 PEAK PRESS 50.1
CASE 47.	Containment Steam [45-55%], 11% Zirc Reacted, And No DV Failure or No AC Power or No HPME. H2 = [4.6%]
	NO BURN IGN 0.79 LG BURN IGN 0.21 BASE PRESS 36 PEAK PRESS 46.1
CASE 48.	Otherwise, Should Never Reach This Case.
	NO BURN IGN 1. LG BURN IGN 0. BASE PRESS O PEAK PRESS O
t Dependencies:	Offsite Power Recovery Time (Event 7), Drywell Failure At/Near RPV Failure (Event 39), Containment Steam Concentration At/Near RPV Failure (Event 40), Fraction Zirconium Reacted At/Near RPV Failure (Event 41), Hydrogen Ignition Sources Available At RPV Failure (Event 42), and High Pressure Melt Ejection (Event 43).
tification Basis:	IPE Engineering Calculation - Hydrogen Burns [with MAAP 3.0B Rev 7.02 using "Recommended Sensitivity Analyses For An IPE Using MAAP 3.0B" (EPRI 1991)]. Grand Gulf

Event 45. H2 DETONATION CONTAINMENT FAILURE AT/NEAR RPV FAILURE - H2 DET

Two Branches:

Even

Quar

DET CF	H2	Detonation	Cor	ntainment	Fai	lure	At/Near	RPV	Failure
NO	No	H2 Detonat	ion	Containme	ent	Fail	ure		

(Brown 1990) APET Events 84 and 85. (see Table H.3.5-1.)

Given that a large burn was ignited in containment following RPV failure this event assesses whether the burn transitions to a detonation and whether containment failure results from the detonation impulse loading. If no large burn was ignited or if the containment atmosphere is inert to detonations (i.e., > 35% steam concentration), then no detonation is assumed to occur.

The probability of a nydrogen detonation occurring is taken to be a function of the steam concentration, the hydrogen concentration, whether power recovery occurs, and whether sprays are initiated during this time period.

EVNTRE Question Type: 2. (Dependent Split Fre .ions) PROBABILITIES:

CASE 1. No Large Burn At/Near RPV Failure

With no large burn, no trigger exists for a hydrogen detonation.

DET	CF		0.	
NO			1.	

CASE 2. Contrinment Steam Concentration Greater Than 35%

Steam concentrations greater than 35% prevent hydrogen detonation.

DI	ET	CF			0.	
N	0				1.	

CASE 3.

Containment Steam Concentration High And Slovly Decreasing Less Than 35%, And Hydrogen Concentration Greater Than 20%

This occurs when offsite power is recovered before RPV Failure and sprays are available for those SBO sequences where high steam concentrations are possible (i.e., not early failure of all injection). This range of hydrogen concentration can be associated with 33% fraction of zirconium inventory reacted at/near RPV failure.

DET	CF	0.	025
NO		0.	975

CASE 4.

Containment Steam Concentration Lov And Hydrogen Concentration Greater Than 20%

This occurs when the steam concentration is 0-15% and the fraction of zirconium reacted is 33%.

DET	CF		0.	2	7
NO			0.	7	3

CASE 5. Containment Steam Concentration Low And Hydrogen Concentration Greater Than 20%

This occurs when the steam concentration is 15-35% and the fraction of zirconium reacted is 33%.

DET	CF	0.16
NO		0.84

CASE 6. Hydrogen Concentration Less Than 12%

This occurs when the fraction of zirconium reacted is 11%.

DET	CF	0.
NO		1.

CASE 7. Containment Steam Concentration High And Slowly Decreasing Less Than 35%, And Hydrogen Concentration 12-16%

This occurs when offsite power is recovered before RPV Failure and sprays are available for those SBO sequences where high steam concentrations are possible (i.e., not early failure of all injection). This range of hydrogen concentration can be associated with 22% fraction of zirconium inventory reacted at/near RPV failure.

DET	CF		0.	0	2	2
NO			0.	9	7	8

CASE 8.

Containment Steam Concentration Low And Hydrogen Concentration 12-16%

This occurs when the steam concentration is 15-35% and the fraction of zirconium reacted is 22%.

DET	CF		0.
NO			1.

CASE 9.

Containment Steam Concentration Low And Hydrogen Concentration 16-20%

This occurs when the steam concentration is 0-15% and the fraction of zirconium reacted is 22%.

DET	CF		0	ł.	1	6
NO			0	ļ	8	4

CASE 10.

Otherwise, Should Never Reach This Case.

DET	CF		0
NO			1

Event Dependencies:

Event Type (Event 3), RPV Injection Failure Time (Event 6), Offsite Pover Recovery Time (Event 7), Mode of RHR Spray Operation Early (Event 18), Containment Steam Concentration At/Near RPV Failure (Event 40), Fraction



Zirconium Inventory Reacted At/Near RPV Failure (Event 41), Large H2 Burn After RPV Failure (Event 44).

Quantification Basis:

Grand Gulf (Brown 1990) APET Events 18, 44 and 86; and Sequoyah Analysis (Volume 5 Rev 1 Part 1 Page 2.2, Part 2 Table A.3.1-1) page 15 and 16. Reference Table H.3.5-2.

EVENT 46. CONTAINMENT FAILURE AT/NEAR RPV FAILURE

Two Branches:

FAILURE	Containment Failure
NO FAILURE	No Containment Failure

This event assesses whether containment failure occurs following RPV failure as a result of an alpha mode steam explosion or a hydrogen burn. The alpha mode in-vessel steam explosion has sufficient energy to rupture the upper head of the RPV and create a missile with sufficient energy to fail the drywell and containment. If a hydrogen detonation has occurred which fails the containment then containment failure has occurred. If a large hydrogen burn was ignited then this event compares the peak containment pressure for the burn (Parameter 2) with the containment fragility curve and determines the probability of failing the containment.

EVNTRE Question Type: 6. (Dependent event using previously defined parameters and a user function)

PROBABILITIES:

CASE 1.

Alpha Mode Steam Explosion Containment Failure

FAILURE 1. NO FAILURE 0.

CASE 2.

Hydrogen Detonation Containment Failure At/Near RPV Failure

FAILURE 1. NO FAILURE 0.

CASE 3. Otherwise, For Those Remaining Sequences Determine the Probability of Containment Failure Du: To Large Hydrogen Burns

USER FUNCTION			FAILURE	NO FAILURE
If Peak Containment	>	80 75 70	1. G.98 0.90	0. 0.02 0.10

> 65	0.69	0.31
> 60	0.39	0.59
> 55	0.15	0.85
> 50	0.034	0.966
Else	0.	1.

Event Dependencies:	Alpha Mode Steam Explosion Dryvell and Containment Failure (Event 30), Hydrogen Detonation Containment Failure At/Near RPV Failure (Event 45).				
Quantification Basis:	Perry Nuclear Power Flant IPE Containment Capacity Analysis, and IPE Engineering Calculation - Containment Fragility.				

EVENT 47. MODE OF CONTAINMENT FAILURE AT/NEAR RPV FAILURE

Two Branches:

ANCHORAGE Containment Anchorage Failure Mode PEN-DOM/NO CF Containment Penetration or Dome Failure Mode, Or No Containment Failure Mode

Given that containment failure has occurred then the probability of various modes of containment failure are determined by this event. For sequences where the containment has failed by a hydrogen burn the peak containment pressure from the burn is used to estimate the probability of each failure mode. The individual fragility curves for the dominant failure modes were used to determine the conditional probabilities for each failure mode as a function of the failure pressure. The peak burn pressure is then used to determine the probability of each failure mode.

Note that this succinct sorting of failure modes into just two categories can be used to characterize penetration/dome containment failure with a question asking sequence of: 1) No Containment Failure, 2) Anchorage Containment Failure, and then 3) Containment Failure (which would provide the remaining Penetration/Dome containment failures).

EVNTRE Question Type: 6. (Dependent event using previously defined parameters and a user function)

PROBABILITIES:

CASE 1. No Containment Failure At/Near RPV Failure

This sorting case assigns the no containment failure sequences.

ANCHORAGE 0. PEN-DOM/NO CF 1.

CASE 2.

Alpha Mode Containment Failure

1 t

- CF VB

H.3 - 74

And Detonation Containment Failure At/Near RPV Failure

The Alpha mode and detonation failures are considered most likely to occur in the dome region and are assigned to penetration/dome failure or no containment failure.

ANCH	IORAC	E		0.
PEN-	DOM/	NO	CF	1.

CASE 3

Otherwise, The Remaining Sequences Are Hydrogen Deflagration Containment Failure

of FUNCTION		AN	CHORAGE	PENETRATION
If Peak Containment	> 140 > 130 > 120 > 115 > 110 > 105 > 100 > 95 > 90 > 85 > 80 > 75 Else	Psig	1. 0.98 0.95 0.90 0.85 0.78 0.71 0.61 0.51 0.41 0.30 0.21 0.15	0. 0.02 0.05 0.10 0.15 0.22 0.29 0.39 0.49 0.59 0.70 0.79 0.85

Event Dependencies:	Alpha Mode Steam Explosion Dryvell and Containment Failure (Event 30), Hydrogen Detonation Containment Failure At/Near RFV Failure (Event 45), and Containment Failure At/Near RFV Failure (Event 46).
Quantification Basis:	Perry Nuclear Power Plant IPE Containment Capacity Analysis, and IPE Engineering Calculation - Containment

Failurs Modes Conditional Probability.

H.3.7. POOL BYFASS BEFORE/NEAR RPV FAILURE

This APET Group of Events 48 and 49 determines the probability of pool bypass early, before or near the time of RPV failure. Fission product scrubbing in the suppression pool is an effective fission product mitigation mechanism. However, if the release pathway bypasses the suppression pool this mechanism is not effective. Pool bypass may result from a number of causes. These include: 1) structural failure of the drywell, 2) Drywell vacuum breaker failure, 3) loss of suppression pool water below the level of the horizontal vents or the SRV quenchers, and 4) other failure processes.

Dryvell structural failure may result from transient over-pressurization of the

dryvell or vetwell resulting in a sufficiently high dryvell/vetvell differential pressure to cause failure of the drywell head, ceiling or walls. Failure of Drywell vacuum breakers may occur dvring large hydrogen burns. Loss of suppression pool water may result from containment anchorage failure in the pool region.

DRYVELL FAILURE DUE TO CONTAINMENT HYDROGEN BURN Event 48. BEFORE/NEAR RPV FAILURE

- H2 BURN

Two Branches:

Dryvell Failure Due To Hydrogen Burn DV FAILURE NO DV FAILURE No Dryvell Failure Due to Hydrogen Burn

Given that a large hydrogen burn has occurred during core damage or at RPV failure this event assesses whether drywell failure results from excessive differential pressure across the dryvell boundary. If a large burn has not occurred in containment then dryvell integrity is not challenged (by hydrogen combustion). For cases where a large hydrogen burn has occurred two parameters have been set which give the peak burn pressure in containment during the burn and the containment pressure prior to the burn. It is assumed that the drywell pressure remains constant during the burn in containment. Given the value of these two parameters the peak drywell differential pressure is calculated and compared against the drywell fragility curve in a user function to estimate the probability of dryvell structural failure.

EVNTRE Question Type: 6. (Dependent event using previously defined parameters and a user function)

PROBABILITIES:

CASE 1.

Large Hydrogen Burn During Core Damage

NO FAILURE DV FAILURE USER FUNCTION 1. If Cntmt/DW Differential Pressure < 40 Psid 0. 0.95 0.05 55 < 0.83 < 60 0.17 0.73 0.27 < 65 0.59 0.41 < 70 0.55 0.45 < 75 0.32 0.68 < 80 0.21 0.79 < 85 0.12 0.88 < 90 0.07 0.93 < 95 0. 1.

Else

CASE 2. Large Hydrogen Burn At/Near RPV Failure

Same probability assignment as above for Case 1.

CASE 3. Otherwise, For Remaining Sequences With No Large Burns Default To No Dryvell Failure

- POOL BYP

DV FAILURE O NO DV FAIL 1

Event Dependencies: Large H2 Burn During Core Damage (Event 22), and Large H2 Burn At/Near RPV Failure (Event 44).

Quantification Basis: Perry Nuclear Power Plant IPE Containment Capacity Analysis, and IPE Engineering Calculation - Dryvell Fragility.

EVENT 49. POOL BYPASS BEFORE/NEAR RPV FAILURE

Two Branches:

POOL BYPASS Pool Bypass NO POOL BYP No Pool Bypass

This summary event assess the probability that pool bypass will occur before or near RPV failure. This event considers pool bypass resulting from drywell failure resulting from processes occurring within the drywell structure, drywell failure from hydrogen combustion in the containment, pool bypass due to containment anchorage failure, and miscellaneous pool bypass mechanisms (e.g. failed open vacuum breakers).

EVNTRE Question Type: 2. (Dependen. split fractions)

PROBABILITIES:

CASE 1. Dryvell Failure At/Near ?PV Failurs

Event 30, Drywell Failure At/Near RPV Failure, summarizes the evaluation of Drywell failure by processes inside the Drywell which are assessed with events 30 - 38.

P00	LI	BY	P/	1S	S	1.
NO	PO	nL.	E	3 Y	P	0.

CASE 2.

Drywell Failure Due To Containment Hydrogen Burn Before/Near RPV Failure

POO	L BYP	PASS	1.
NO	POOL	BYP	0.

CASE 3. Suppression Poel Bypass Due To Anchorage Containment Failure Before/Near RPV Failure

POO	L BY	PASS	1.
NO	POOL	BYP	 0.

CASE 4. Drywell Vacuum Breaker Failure Due To Large Burn When AC Power Is Available

When AC power is available, the dryvell vacuum breaker isolation valves will automatically open on dryvell/containment differentia? pressure. If the isolation valve is open on a dryvell vacuum breaker line, then large burns may fail the check valve open.

POO	L BYF	ASS	0.05
NO	POOL	BYP	0.95

CASE 5.

Otherwise, For The Remaining Sequences Pool Bypassed By Other Failures

POO	L BYP	ASS	0.0001
NO	POOL	BYP	0.9999

Event Dependencies: Event Type (Event 3), Offsite Power Recovery Time (Event 7), Large H2 Burn During Core Damage (Event 22), Mode of Containment Failure Before RPV Failure (Event 25), Drywell Failure At/Near RFV Failure (Event 39), Large H2 Burn At/Near RPV Failure (Event 44), Mode of Containment Failure At/Near RPV Failure (Event 47), Drywell Failure Due To C_atainment Hydrogen Burn Before/Near RPV Failure (Event 48).

Quantification Basis: Grand Gulf (Brown 1990) APET 95, and engineering judgement.

H.3.8 CONTAINMENT FAILURE BEFORE/NEAR RPV FAILURE FAILS INJECTION & SPRAY

This APET Group of Events 50 thru 53 determines the probability that containment failure causes the loss of all in-vessel injection (assuming in-vessel injection has not previously failed) and failure of the RHR containment spray system. The wetwell sprays represent an effective fission product mitigation feature which can significantly limit atmospheric releases of radionuclides. Containment



sprays will be particularly important for sequences where suppression pool bypass has occurred, since the sprays then represent the only remaining major engineered safety system which can significantly mitigate radionuclide releases.

The mechanisms associated with containment failure which may cause failure of in-vessel injection and/or the containment spray system are discussed above in H.3.4.

Event 50. CONTAINMENT FAILURE AT/NEAR RPV FAILURE IMPACT ON ECCS INJECTION AND SPRAY PIPING

- PIPE FAIL

Two Branches:

FAILURE Failure of ECCS Injection & Spray Piping NO FAILURE No Piping Failure

This event assesses the probability that either the dynamic forces or movement of the containment which occur at containment failure are sufficient to disrupt the injection and spray system piping. Disruption of this piping is expected to be a serious threat for containment anchorage failure.

EVNTRE Question Type: 2. (Dependent split fractions)

PROBABILITIES:

CASE 1.

Anchorage Failure Mode Containment Failure At/Near RPV Failure

FAILURE	0.9
NO FAILURE	0.1

CASE 2.

 Otherwise, For Other Non Anchorage Failure Sequences Default to No Failure.

> FAILURE 0. NO FAILURE 1.

Event Dependencies:

Mode of Containment Failure At/Near RPV Failure (Event 47).

Quantification Basis:

Containment Capacity Analysis (Gilbert/Commonwealth 1992) and engineering judgment.

Event 51. CONTAINMENT FAILURE AT/NEAR RPV FAILURE IMPACT ON ECCS INJECTION AND SPRAY MOTORS

- MTR FAIL

Two Branches:

Failure of ECCS Injection & Spray Motors FAILURE NO FAILURE No Motor Failure

This event assesses the probability that leakage of vater, steam or hot gases from containment into the auxiliary building which may occur at containment failure cause failure of the injection and/or spray system motors and related components.

EVNTRE Question Type: 2. (Dependent split fractions)

PROBABILITIES:

CASE 1.

Containment Failure At/Near RPV Failure And No Anchorage Piping Failure

> 0.5 FAILURE 0.5 NO FAILURE

CASE 2.

Otherwise, For Other Non Containment Failure Sequences Default to No Failure.

FAILURE 0. NO FAILURE 1.

- Containment Failure At/Near RPV Failure (Event 46), and Event Dependencies: Containment Failure At/Near RPV Failure Impact on ECCS Injection and Spray Piping.
- Containment Capacity Analysis (Gilbert/Commonwealth Quantification Basis: 1992) and engineering judgment.

Event 52. CONTAINMENT FAILURE AT/NEAR RPV FAILURE STEAM AND RADIATION IMPACT ON FIREWATER INJECTION - STM/RAD

Two Branches:

Failure of Firevater Injection FAILURE NO FAILURE No Failure

This event assesses the probability that leakage of radionuclides from containment will limit personnel access to the firewater lineup or components (e.g., Diesel Driven Firewater Pump Oi? Tank, or Perry Pumper) and result in failure to perform required local manual actions to initiate, or to assure continued operation of the firevater injection.

EVNTRE Question Type: 2. (Dependent split fractions)

PROBABILITIES:

CASE 1. Containment Failure At/Near RPV Failure And No Anchorage Piping Failure

FAI	LURE	0.5
NO	FAILURE	0.5

CASE 2. Otherwise, For Other Non Containment Failure Sequences FAILURE O. NO FAILURE 1.

Event Dependencies: Containment Failure At/Near RPV Failure (Event 46), Containment Failure At/Near RPV Failure Impact on ECCS Injection and Spray Piping.

Quantification Basis: Containment Capacity Analysis (Gilbert/Commonwealth 1992) and ...gineering judgment.

Event 53. INJECTION & SPRAY FAILURE DUE TO CONTAINMENT FAILURE AT/NEAR RPV FAILURE -

- INJ/SP FL

Two Branches:

INJ & SPRY FAIL Injection & Spray Failure NO FAILURE No Failure

This event summarizes the results of the prior three events in the APET.

EVNTRE Question Type: 2. (Dependent Sorting Event)

SORTING:

CASE 1.

ECCS Injection & Spray Piping Failure Due To Containment Failure At/Near RPV Failure

> INJ & SPRY FAIL 1. NO FAILURE 0.

CASE 2.

ECCS Injection & Spray Motor Failure, And Firewater Injection Failure Due To Containment Failure At/Near RPV Failure

INJ& SPRY FAIL 1. NO FAILURE 0. CASE 3.

Otherwise, For Other Remaining Sequences Where All Injection Is Not Failed Default to No Failure.

INJ& SPRY FAIL 0. NO FAILURE 1.

Event Dependencies:

Containment Failure At/Near RPV Failure Impact on ECCS Injection and Spray Piping (Event 50), Containment Failure At/Near RPV Failure Impact on ECCS Injection and Spray Motors (Event 51), Containment Failure At/Near RPV Failure Steam & Radiation Impact on Firevater (Event 52).

Quantification Basis: Not Applicable for summary vent.

H.3.9 PEDESTAL FAILURE DUE TO CORE DEBRIS CONCRETE INTERACTION

This APET Group of Events 54 thru 55 determines the probability of pedestal failure as a result of sidewards core concrete attack in the pedestal cavity eroding the pedestal wall to a sufficient depth that the structural integrity of the pedestal wall is compromised. Failure of the pedestal wall may result in loss of support to the RPV and result in gross motion of the RPV. This motion may result in damage to the drywell or to containment penetrations.

The amount of radial erosion will be a function of the type and extent of core concrete attack that occurs, the ratio of radial to downwards concrete attack and the failure depth for the pedestal wall.

This event is dependent on the following Events in the Perry APET.

Event 54. TYPE OF CORE DEBRIS CONCRETE INTERACTION

- CCI TYPE

Four Branches:

DRY-CCI	CCI In A Dry Pedestal Cavity
FAST-WET	Rapid CCI With an Overlying Water Layer
SLOW-WET	Slow CCI With an Overlying Water Layer
NO-CCI	NO CCI With Debris Cooled

This event determines the probability of various types of CCI which may occur in the pedestal cavity following RPV failure. If no water is in the pedestal cavity prior to RPV failure and water is not supplied following RPV failure then dry CCI will occur. If a small amount of water is in the pedestal cavity prior to RPV failure but a continuing supply of water is not available then the debris/concrete attack may be delayed until the water pool is boiled away. (This case has been conservatively combined with DRY CCI).

For cases where a large pool of water has entered the drywell prior to RPV failure or there a continuous supply of water is available to the pedestal following vessel failure then a pool of water will cover the debris. Depending upon the surface area of the debris, the debris particle size and the effective upward heat transfer rate the debris may be cooled or CCI may occur. The last three branches assess the rate of CCI given a debris pool which is covered by water.

EVNTRE Question Type: 2. (Dependent split fractions)

PROBABILITIES:

CASE 1. No RPV Failure With Debris Cooled In-Vessel

DRY-CCI	0.
FAST-WET	0.
SLOW-VET	0.
NO-CCI	1.

CASE 2.

No Water In Pedestal Cavity At RPV Failure, And No Continued Injection to the Pedestal Cavity

DRY-CCI	1.
FAST-WET	0.
SLOW-WET	0,
NO-CCI	0.

CASE 3.

Water in Pedestal Cavity At RPV Failure From Flooding, No Continued Injection To The Pedestal Cavity, And HPME

DRY-CCI	0,
FAST-VET	0.175
SLOW-WET	0.4875
NO-CCI	0.3375

CASE 4.

Water in Pedestal Cavity At RPV Failure From Flooding, No Continued Injection To The Pedestal Cavity, No HPME, And Large Molten Mass of Debris in Lower Head At RPV Failure

DRY-CCI	0.
FAST-WET	0.28
SLOW-WET	0.48
NO-CCI	0.24

CASE 5.

Water in Pedestal Cavity At RPV Failure From Flooding, No Continued Injection To The Pedestal Cavity, No HPME, And Small Molten Mass of Debris in Lower Head

At RPV Failure

DRY-CCI	0.
FAST-WET	0.28
SLOW-WET	0.48
NO-CCI	0.24

CASE 6.

No Water in Pedestal Cavity At RPV Failure, Continued Injection To The Pedestal Cavity, And HPME 60

DRY-CCI	0.
FAST-WET	0.315
SLOW-FET	0.4775
NO-CCI	0.2075

CASE 7.

No Water in Pedestal Cavity At RPV Failure, Continued Injection To The Pedestal Cavity, And No HPME

DRY-CCI	0.
FAST-WET	0.3375
SLOW-WET	0.475
NO-CCI	0.1875

CASE 8.

Water in Pedestal Cavity At RPV Failure, Continued Injection To The Pedestal Cavity, And HPME

DRY-CCI	0.
FAST-VET	0.175
SLOW-WET	0.4875
NO-CCI	0.3375

CASE 9.

Water in Pedestal Cavity At RPV Failure, Continued Injection To The Pedestal Cavity, No HPME and Large Molten Mass

DRY-CCI	0.
FAST-WET	0.28
SLOW-WET	0.48
NO-CCI	0.24

CASE 10.

Water in Pedestal Cavity At RPV Failure, Continued Injection To The Pedestal Cavity, No HPME and Small Molten Mass

DRY-CCI 0. FAST-WET 0.28

SLOW-WET	0.	48
NO-CCI	0.	24

CASE 11.

Otherwise, Should never reach this case.

DRY-CCI	1.
FAST-WET	0.
SLOW-WET	0.
NO-CCI	0.

Event Dependencies:

Debris Molten Mass At RPV Failure (Event 14), RPV Failure Mode & Failure Size (Event 32), Water In Pedestal At RPV Failure (Event 33), HPME (Event 43), Injection & Spray Failure Due to Containment Failure Before/Near RPV Failure (Event 53).

Quantification Basis: Grand Gulf (Brown 1990) APET 99, IPE Engineering Calculation - CCI And Pedestal Ablation.

Event 55. PEDESTAL FAILURE DUE TO CORE DEBRIS CONCRETE INTERACTION - PED FAIL

Three Branches:

AT VB Pedestal Failure At RPV Failure FAIL AFTER VB Pedestal Failure After RPV Failure NO FAILURE No Pedestal Failure

Given a type of CCI determined in APET Event 54 this event assesses whether pedestal structural failure from CCJ radial erosion of the pedestal wall will occur. The mean erosion depth for failure was taken as 3.6 feet from the Grand Gulf Pedestal Erosion expert's determination (Harper 1991).

EVNTRE Question Type: 2. (Dependent split fractions)

PROBABILITIES:

CASE 1.

Drywell Failure At/Near RPV Failure By Processes Inside The Drywell Or Drywell Failure Due To Containment Hydrogen Burn Before/Near RPV Failure

AT	VB		1	
AFT	ER	VB	0	
NO	FAI	LURE	Ū	

CASE 2.

No RPV Failure With Debris Cooled In-Vessel

AT VB

0.

	AFTER VB NO FAILURE	0. 1.
CASE 3.	Dry CCI	
	AT VB AFTER VB NO FAILURE	0. 0.43 0.57
CASE 4.	Fast Wet CCI	
	AT VB AFTER VB NO FAILURE	0. 0.29 0.71
CASE 5.	Slow Wet CCI	
	AT VB AFTER VB NO FAILURE	0. J.25 0.75
CASE 6.	No CCI	
	AT VB AFTER VB NO FAILURE	0. 0. 1.
CASE 7.	Otherwise, Shoul	ld never reach this case.
	AT VB AFTER VB NO FAILURE	0. 0. 1.
Event Dependencies:	Failure At/Near Due to Containm	e and Failure Size (Event 32), Dryvell RPV Failure (Event 39), Dryvell Failure ent H2 Burn Before/Near RPV Failure Type of Core Debris Concrete Interaction
Quantification Basis:	Interaction Iss Erosion Section CCI cases were results from Ta	olume 2 Part 2, Molten Core Containment ues (Harper 1991) Grand Gulf Pedestal 6.2. Radial erosion depths for the dry based on a weighted average of the ble 6-3 (Groups 5, 6 and 7). The ses were based on an average of Groups 1

of Groups 2 and 3.

and 2. The slow-wet CCI cases were based on an average

8.3.10 MODE OF LATE BURN AND OVERPRESSURE CONTAINMENT FAILURE

This APET Group of Events 56 thru 66 determines the probability (and mode) for containment failures which occur late in the accident sequences. These events assess containment failures resulting from hydroge, combustion and detonation and from gradual overpressurization from steam and non condensible gas production.

This event is dependent on the following Events in the Perry APET.

EVENT 56. Mode Of RHR Spray Operation Late

- DE INERT

Three Branches:

CONTROLLED	Sprays are operating in a throttled cooling mode
	to mitigate or exclude hydrogen deflagrations and
	detonations
SPRAY	Sprays are operating at full design cooling
NO SPRAY	Sprays Not Available

This event summarizes whether the RHR sprays are available (and are operated) late in the accident sequence. It further allows for the assessment of controlled (throttled) spray operation or for normal design flow operation. The controlled spray operation mode is directed at limiting the spray flow rate such that containment atmosphere steam concentration would remain elevated above the sceam inerting limit for hydrogen combustion (55 volume percent) and below the emergency procedure pressure limit of 40 psig, or maintains the the as-found containment steam concentration to minimize the expected peak burn pressures. The controlled spray operation mode is not currently considered in the Perry Plant Emergency Instruction. Consequently, this mode of spray operation was not considered in the base case Perry analysis (the Controlled Spray Operation branch probability was set to zero). This branch was included for use in sensitivity analysis.

EVNTRE Question Type: 2. (Dependent Sorting Event)

SORTING:

CASE 1. RHR Spray Loop Not Available

RHR Spray is determined to be not available in the Plant Damage State Grouping Logic.

CONTROLL	ED 0.	j.
SPRAY	0.	
NO SPRAY	1.	į.

CASE 2. AC Power Never Lost, And RHR Spray Available

With AC Power available, it is almost certain that the hydrogen igniters are available to control hydrogen. Therefore, a controlled, steam-inerted containment atmosphere is not necessary to credit the mitigative impact of controlled spray operation.

CON	TROLLED	0.
SPF	YAS	1.
NO	SPRAY	0.

CASE 3.

3 8

AC Power Lost, Power Recovered Prior to RPV Frilure, And RHR Spray Available

Under these conditions it is probable that there will be a significant quantities of hydrogen released into the containment and that the hydrogen ignition system will not be energized during the first hour or two following AC power recovery. (Reference Event 16 discussion.) Under these conditions it is possible to limit the threat from hydrogen combustion by throttling the RHR bypass flow to maintain the containment steam concentration in the steam-inert regime. However, since this mode of operation is not in the Perry Plant Emergency Instruction, this mode of operation has been assigned a zero probability for base case evaluation.

CON	TROLL	ED	0.
SPF	YAJ		1.
NO	SPRAY		0.

CASE 4.

AC Power Lost, Power Recovered Prior to Containment Capacity Overpressure Threshold, And RHR Spray Available

Under these conditions it is probable that there will be a significant quantities of hydrogen released into the containment and that the hydrogen ignition system will not be energized during the first hour or two following AC power recovery. (Reference Event 16 discussion.) Under these conditions it is possible to limit the threat from hydrogen combustion by throttling the RHR bypass flow to maintain the containment steam concentration in the steam-inert regime. However, since this mode of operation is not in the Perry Plant Emergency Instruction, this mode of operation has been assigned a zero probability for base case evaluation.

CONTI	ROLLED	0.
SPRA	Y	1.
NO S	PRAY	0.

CASE 5.

Otherwise, 'should never reach this case.

CONTROLLED

0.

SPRAY O. NO SPRAY 1.

Event Dependencies:

Event Type (Event 3), Offsite Power Recovery Time (Event 7), Containment Heat Removal With RHR Spray Loop (Event 8).

Quantification Basis: Not Applicable.

EVENT 57. HYDROGEN IGNITION SOURCES AVAILABLE LATE

- IG SOURC

Two Branches:

NO SOURCE No Hydrogen Ignition Source IGN SOURCE Hydrogen Ignition Sources Available

With a continuous ignition source available in containment it is assumed that controlled hydrogen combustion (or small hydrogen burns) will preclude the build-up of hydrogen concentrations whose combustir. would threaten containment integrity. A continuous ignition source is assumed to be available if the hydrogen ignition system is operating. Since there may have been a substantial time period between RPV failure and the time when late combustion may occur, earlier burns are not considered to provide a reliable ignition source for late burns (and thus ensure that only small burns would occur late).

EVNTRE Question Type: 2. (Dependent Split Fraction)

PROBABILITIES:

CASE 1 Hydrogen Ignition System Available Early

This is true is the HIS was placed in service early with no human interaction error.

NO SOURCE 0. IGN SOURCE 1.

CASE 2.

No Loss Of AC Power, Operator Fsilure To Initiate Hydrogen Ignition System, And Recovery Of Hydrogen Ignitors.

This recovery of ignitors before the Hydrogen Deflagration Overpressure Limit is reach is the same recovery modeled in Event 42., Hydrogen Ignition Sources Available At RPV Failure.

N	0	S	0	URCE	0	÷	1
I	GN		S	OURCE	0	ć	9

CASE 3. SBO And Power Recovery Prior To RPV Failure

The HIS will not be placed on immediately after power recovery due to the hydrogen analyzers being out of calibration or due to the hydrogen concentration not determined. After the hydrogen analyzers warm up and reach steady state calibration, it is likely that the hydrogen concentration will be above the hydrogen deflagration overpressure limit, and the HIS will not be placed in service. Therefore, the availability of this ignition source is uncertain.

NO	SOURCE		0.	5
IGN	SOURCE		0.	5

CASE 4. SBO With Power Recovery Prior To Containment Limit

The HIS will not be placed on immediately after power recovery due to the hydrogen analyzers being out of calibration or due to the hydrogen concentration not determined. After the hydrogen analyzers warm up and reach steady state calibration, it is likely that the hydrogen concentration will be above the hydrogen deflagration overpressure limit, and the HIS will not be placed in service. Therefore, the availability of this ignition source is highly uncertain, and the availability of the ignition source is conservatively set to 0.

N	0	3	0	U	R	C	E				1	
I	GN		S	0	Ū	R	С	E			0	2

CASE 4.

Otherwise, For The Remaining Sequences With Loss Of AC Power and No Power Recovery Assign to No Hydrogen Ignition Source

NO SOURCE 1. IGN SOURCE 0

Event Dependencies: Fvent Type (Event 3), Offsite Power Recovery Time (Event 7), Hydrogen Ignition System Available (Event 16).

Quantification Basis: Review of the M51 Combustible Gas Control System and the M56 Hydrogen Ignition System, Perry Plant Emergency Instruction IPE Human Interaction Technical Assignment File, and engineering judgement.

Event 58. CONTAINMENT STEAM CONCENTRATION LATE

- ST CONC

S.x branches:

0-15	9/ /x	Containment	Steam	Volume	Percent
15-25	2,				

25-35 % 35-45 % 45-55 % >55 %

This branch assesses the containment steam concentration late in the accident. The probability of hydrogen burn ignition and the efficiency of the burn (considered in subsequent events) are dependent upon the branch taken under this heading. The containment steam concentration is a function of the mode of spray operation, the sequence type, the time of injection failure and whether the containment is intact at core damage. The steam concentration regime probabilities given for the cases below were estimated using MAAP results for each case.

EVNTRE Question Type: 2. (Dependent split fractions)

PROBABILITIES:

CASE 1. Spray Loop Operation At Design Cooling

With a containment spray loop operating at design cooling with containment heat removal optimized with the Residual Heat Removal heat exchanger, the steam concentration would be low.

0-15	%	1.
15-25	%	0.
25-35	%	0.
35-45	2	0.
45-55	%	0.
>55	%	0.

CASE 2. Containment Vent Not Isolatri At RPV Failure

For the range of distributions in SBO sequences, the steam concentration is conservatively bounded by the case of SBO with no injection with the containment vent open.

0-15	%	0.25
15 - 25	2	0.75
25-35	%	0.
35-45	%	0.
45-55	%	0.
>55	X	0.

CASE 3.

SBO And No Injection Failure Early (0 - 2.8 Hrs)

0-15	%	0.99
15-25	% /6	0.01
25-35	%	0
35-45	%	0.
45-55	%	0.
>55	%	0.

CASE 4.

SBO And RCIC Injection Failure (2.8-4.2 Hrs)

0-15	X	0.
15-25	%	0.
25-35	%	0.29
35-45	%	0.71
45-55	%	0.
>55	%	0.

CASE 5.

SBO And HPCS Injection Failure (> 4.2 Hrs)

0-15	%	0,
15-25	%	0.
25-35	%	0.
35-45	%	0.
45-55	%	0.
>55	1000	1.

CASE 6.

Containment Failed At Core Damage

0-15	%	0.
15-25	%	0.
25-35	%	0.
35-45	X	0.
45-55	%	0.
>55	%	1.

CASE 7.

Otherwise, All Other Sequences Default to Low Steam Concentration

All other sequences are conservatively evaluated by assuming a low

steam concentration.

0-15	%	1.
15-25	%	0.
25-35	%	0.
35-45	%	0.
45-55	%	0.
>55	%	0.
>55	%	0

Event Dependencies: Containment Status At Core Damage (Event 2), Event Type (Event 3), Containment Vent Isolated At RPV Failure (Event 5), RFV Injection Failure Time (Event 6), Mode of RHR Spray Operation Late (Event 56).

Quantification Basis: IPE Engineering Calculation - Hydrogen Burns [with MAAP 3.0B Rev 7.02 using "Recommended Sensitivity Analyses For An IPE Using MAAP 3.0B" (EPRI 1991)].



EVENT 59. HYDROGEN COMBUSTION BEFORE/AT RPV FAILURS

Two Branches:

EARLY BURN Early Burn Before/At RPV Failure NO EARLY BURN No Early Burn

This event summarizes whether an earlier burn in containment has occurred. This information is used to assess the late hydrogen concentration in containment.

EVNTRE Question Type: 2. (Dependent sorting event)

SORTING:

CASE 1. Early H2 Burn During Core Damage Or At/Near RPV Failure

Early burns include both small and large burns which occurred before RPV failure or at/near RPV failure.

EARLY BURN 1. NO EARLY BURN 0.

CASE 2.

Otherwise, No Early Burn

EARLY BURN 0. NO EARLY BURN 1.

Event Dependencies: Small H2 Burns At Low H2 Concentrations (Event 21), Large H2 Burn During Core Lamage (Event 22), and Large H2 Burn At/Neur RPV Failure (Event 44).

Quantification Basis: Not Applicable.

EVENT 60. CONTAINMENT EFFECTIVE HYDROGEN CONCENTRATION LATE

- H2 CONC

SIx Branches:

< 4% Volume Percent Hydrogen 4- 8% 8-12% 12-16% 16-20% > 20%

This branch assesses the containment effective hydrogen concentration (including the carbon monoxide produced during core concrete interaction). The probability of hydrogen burn ignition and the efficiency of the burn (considered in



- L'URN B4

subsequent events) are dependent upon the branch taken under this heading. The containment hydrogen concentration is a function of the mode of CCI (APET Event 54), and whether a hydrogen burn occurred early in the sequence (APET Event 59).

EVNTRE Question Type: 2. (Dependent split fractions)

PROBABILITIES:

CASE 1. Early Hydrogen Burn And No CCI

This case is estimated by judgement and comparison from the calculated distribution for SBO with Spray, No Burn, and No CCI. It is considered that an early burn would reduce the initial hydrogen concentration to a lower plateau of about 4.5% based on 1/4 testing of Mark III containment hydrogen combustion (EPRI - 1938).

< 4%	0.5
4- 8%	0.5
8-12%	0.0
2-16%	0.0
6-20%	0.0
> 20%	0.0

CASE 2. Early Hydrogen Burn And Slow Wet CCI

This case is estimated by judgement and comparison from the calculated distribution for SBO with Spray, No Burn, and Dry CCI. It is considered that an early burn would reduce the initial hydrogen concentration to a lower plateau of about 4.5% based on 1/4 testing of Mark III containment hydrogen combustion (EPRI - 1988).

	<	4%	0.	1
	4-	8%	0.	25
	8-	12%	0.	3
1	2-	16%	0.	25
l	6-	20%	0.	1
	>	20%	0.	0

CASE 3.

Early Hydrogen Burn And Fast Wet CCI

This case is conservatively estimated by judgement and comparison from the calculated distribution for SBO with Spray, No Burn, and Dry CCI. It is considered that an early burn would reduce the initial hydrogen concentration to a lower plateau of about 4.5% based on 1/4 testing of Mark III containment hydrogen combustion (EPRI - 1988).

<	4%	0.0	
4-	8%	0.1	
8-1	2%	0.2	
12-1	6%	0.35	
16-2	02	0.35	

9



CASE 4. Early Hydrogen Burn, Dry CCI and No Spray During SBO And No Injection

This case is conservatively estimated by comparison from the calculated distribution for SBO with No Spray, No Burn, and Dry CCI with little credit for significant hydrogen reduction.

<	4%	0.0
4-	8%	0.35
8-1	2%	0.07
2-1	6%	0.06
6-2	0%	0.06
> 2	0%	0.46

CAGE 5.

Early Hydrogen Burn, Dry CCI and No Spray During SBO And RCIC Injection Failure

This case is conservatively estimated by comparison from the calculated distribution for SBO with No Spray, No Burn, and Dry CCI with little credit for significant hydrogen reduction.

<	4%	0.0
4-	8%	0.04
8-1	2%	0.60
2-1	6%	0.36
6-2	0%	0.04
> 2	0%	0.00

CASE 6.

Early Hydrogen Burn, Dry CCI and No Spray During SBO And HPCS Failure

This case is conservatively estimated by comparison from the calculated distribution for SBO with No Spray, No Burn, and Dry CCI with little credit for significant hydrogen reduction.

< 4%	0.64
4- 8%	0.36
8-12%	0.00
2-16%	0.00
6-20%	0.00
> 20%	0.00

CASE 7.

Early Hydrogen Burn, Dry CCI and Spray During SBO And No Injection

This case is conservatively estimated by comparison from the calculated distribution for SBO with Spray, No Burn, and Dry CCI with little credit for significant hydrogen reduction.

< 4%	0.0
4- 8%	0.36
8-12%	0.07
12-16%	0.06
16-20%	0.06
> 20%	0.45

CASE 8.

Early Hydrogen Burn, Dry CCI and Spray During SBU And RCIC Injection Failure

This case is conservatively estimated by comparison from the calculated distribution for SBO with Spray, No Burn, and Dry CCI with little credit for significant hydrogen reduction.

< 4%	0.0
4- 8%	0.05
8-12%	0.43
12-16%	0.37
6-20%	0.14
> 20%	0.01

CASE 9.

Early Hydrogen Burn, Dry CCI and Spray During SBO And HPCS Failure

This case is conservatively estimated by comparison from the calculated distribution for SBO with Spray, No Burn, and Dry CCI with little credit for significant hydrogen reduction.

< 4%	0.38
4- 8%	0.51
8-12%	0.11
12-16%	0.00
6-20%	0.00
> 20%	0 00

CASE 10.

No Early Hydrogen Burn, No CCI and No Spray During SBO And No Injection

This case is estimated by directly using the calculated distribution for SBO with No Spray, No Burn, and No CCI.

5	4%	0.0
4-	8%	1.0
8-1	2%	0.0
2-1	6%	0.0
6-2	.02	0.0
> 2	0%	0.0

CASE 11.

No Early Hydrogen Burn, No CCI and No Spray

During SBO And RCIC Injection Failure

This case is estimated by directly using the calculated distribution for SBO with No Spray, No Burn, and No CCI.

<	4%	0.0
4-	8%	0.0
8-1	2%	0.8
12-1	6%	0.2
16-2	20%	0.0
> 1	20%	0.0

CASE 12.

No Early Hydrogen Burn, No CCI and No Spray During SBO And HPCS Failure

This case is estimated by directly using the calculated distribution for SBO with No Spray, No Burn, and No CCI.

<	4%	0.59
4-	8%	0 41
8-	12%	0.00
2-	16%	6.00
6-	20%	0.00
>	20%	0.00

1

11

CASE 13.

No Early Hydrogen Burn, No CCI and Spray During SBO And No Injection

This case is estimated by directly using the calculated distribution for SBO with Spray, No Burn, and No CCI.

< 4%	0.0
4- 8%	1.0
8-12%	0.0
2-16%	0.0
6-20%	0.0
> 20%	0.0

CASE 14.

No Early Hydrogen Burn, No CCI and Spray During SBO And RCIC Injection Failure

This case is estimated by directly using the calculated distribution for SBO with Spray, No Burn, and No CCI.

< 4% 0.0	
4- 8% 0.0	
8-12% 0.5	6
12-16% 0.3	8
16-20% 0.0	6
> 20% 0.0	

CASE 15.

No Early Hydrogen Burn, No CCI and Spray During SBO And HPCS Failure

This case is estimated by directly using the calculated distribution for SBO with Spray, No Burn, and No CCI.

< .	4%	0.	33
4-	8%	0,	51
8-1	2%	0.	16
2-1	6%	0,	00
6-2	0%	Ö.	00
> 2	0%	0.	00

CASE 16. No Early Hydrogen Burn And Slow Wet CCI

This case is conservatively estimated by comparison with the calculated distribution for SBO with Spray, No Burn, and Dry CCI.

< 4%	0.0
4- 8%	0.1
8-12%	0.15
2-16%	0.25
6-20%	0.5
> 20%	0.0

CASE 17. No Early Hydrogen Burn And Fast Wet CCI

This case is very conservatively estimated by with comparison from the calculated distribution for SBO with Spray, No Burn, and Dry CCI.

< 4%	0.0
4- 8%	0.0
8-12%	0.1
2-16%	0.15
6-20%	0.75
> 20%	0.0

CASE 18.

No Early Hydrogen Burn, Dry CCI and No Spray During SBO And No Injection

This case is estimated by directly using the calculated distribution for SBO with No Spray, No Burn, and Dry CCI.

<	4%	0.0
4-	8%	0.30
8-	12%	0.07
12-	16%	0.06
16-	20%	0.06
>	20%	0.51

No Early Hydrogen Burn, Dry CCI and No Spray CASE 19. During SBO And RCIC Injection Failure

This case is estimated by directly using the calculated distribution for SBO with No Spray, No Burn, and Dry CCI.

<	4%	0.0
4-	8%	0.0
8-1	1.2%	0.60
2-1	16%	0.36
6-1	20%	0,04
> :	20%	0.0

CASE 20.

No Early Hydrogen Burn, Dry CCI and No Spray During SBO And HPCS Failure

This case is estimated by directly using the calculated distribution for SBO with No Spray, No Burn, and Dry CCI.

<	4%	0.59
4-	8%	0.41
8-1	2%	0.00
12-1	6%	0.00
16-2	0%	0.00
> 2	.0%	0.00

CASE 21.

No Early Hydrogen Burn, Dry CCI and Spray During SBO And No Injection

This case is estimated by directly using the calculated distribution for SBO with Spray, No Burn, and Dry CCI.

<	4%	0.00
4	8%	0.31
8-1	2%	0.07
2-1	6%	0.06
6-2	0%	0.06
> 2	0%	0.50

CASE 22.

No Early Hydrogen Burn, Dry CCI and Spray During SBO And RCIC Injection Failure

This case is estimated by directly using the calculated distribution for SBO with Spray, No Burn, and Dry CCI.

<	4%	0.00
4-	8%	0.00
8-1	2%	0.43
12-1	.6%	0.42
16-2	20%	0.14

No Early Hydrogen Burn, Dry CCI and Spray CASE 23. During SBO And HPCS Failure

This case is estimated by directly using the calculated distribution for SBO with Spray, No Burn, and Dry CCI.

	<		4	%	0.33
	4-		8	%	0.51
	8-	1	2	%	0.16
l	2-	1	6	%	C.00
į	6-	2	0	%	0.00
	>	2	0	%	0.00

CASE 24. Otherwise, The Remaining Sequences

This case is estimated with judgement with comparison to the calculated distribution for SBO with Spray, No Burn, and Dry CCI.

< 4%	0.
4- 8%	0.
8-12%	0,
2-16%	0
6-20%	1.
> 20%	0.

Event Type (Event 3), RPV Injection Failure Time (Event Event Dependencies: 6), Type Of Core Debris Concrete Interactions (Event 54), Mode of RHR Spray Operation Late (Event 56), H2 Combustion Before/At RPV Failure (Event 59).

IPE Engineering Calculation - Hydrogen Burns [with MAAP Quantification Basis: 3.0B Rev 7.02 using "Recommended Sensitivity Analyses For An IPE Using MAAP 3.0B" (EPRI 1991)]. Hydrogen Combustion Experiments In a 1/4 Scale Model Of A Mark III Nuclear Reactor Containment (EPRI - 1988).

Event 61. AC POWER AVAILABLE LATE

- AC PWR

Two Branches:

AC	LATE	AC	Power	Avail	able	Lat	e
	AC LATE	No	AC Pow	et Av	ailab	le	Late

This event summarizes whether AC power is available late in the sequence. AC power will be available late if AC power was never lost or if AC power was initially lost but was recovered. This information is used to assess the potential for hydrogen ignition late in the sequence.



EVNTRE Question Type: 2. (Dependen: sorting event) SORTING:

CASE 1. SBO And No AC Power Recovery

AC	LAT	E	0	
NO	AC	LATE	1	•

CASE 2.

Otherwise, AC Power Available

AC LATE 1. NO AC LATE 0.

Event Dependencies:

Event Type (Event 3), and Offsite Power Recovery Time (Event 7).

Quantification Basis: Not Applicable.

EVENT 62. LARGE HYDROGEN BURN LATE

- LG BURN

Two Branches:

1)	No Large Hydrogen Burn Ignited	10 BURN
2)	Large Hydrogen Burn Ignited	LARGE BURN

This event assess whether a large hydrogen burn is ignited in containment late in the accident sequence. If a continuous ignition source is available (as defined in Event 57) then a large hydrogen burn is assumed to be prevented. Also if the steam concentration is above 55% then the containment atmosphere is inert to hydrogen burns. The probability that a large hydrogen burn is ignited is a function of the following parameters;

- 1. Containment steam concentration,
- 2. Containment hydrogen concentration, and
- 3. AC power availability.

Forty four cases (various combinations of the parameters listed above were identified to perform the quantification). In addition to assessing the probability of ignition this event also sets two parameter values which are used by subsequent events; peak hydrogen burn pressure (parameter 5) and containment base pressure prior to the burn (parameter 6).

EVNTRE Question Type: 4. (Dependent Split Fraction with parameter values set for each case.)

PROBABILITIES:

CASE 1.	Hydrogen Ignitions Sources Available Late							
	NO BURN LG BURN	1. 0.	BASE	PRESS	0	PEAK	FRESS	0
CASE 2.	Containment Conce	entratio	on Is	Greate	r Thai	n 55%		
	NO BURN LG BURN	1. 0.	BASE	PRESS	0	PEAK	PRESS	0
CASE 3.	Containment Hydr	ogen Cor	ncenti	ation	Less	Than 🕹	X	
No large burns	are possible.							
	NO BURN LG BURN	1. 0.	BASE	PRESS	0	PEAK	PRESS	0
CASE 4.	Cntmt Steam [0-1 And No AC Power				4-8%]	i	H2] =	6%
	NO BURN LG BURN	0.71 0.29	BASE	PRESS	7.6	PEAK	PRESS	19.4
CASE 5.	Cntmt Steam [0-1 And No AC Power				(8-12%	1	[H2] =	10%
	NO BURN LG BURN	0.67 0.33	BASE	PRESS	8.8	PEAK	PRESS	51.6
CASE 6.	Cntmt Steam [0-] And No AC Power				[12-34	5%]	[H2] =	. 14%
	NO BURN LG BURN	0.58 0.42	BASE	PRESS	10	PEAK	PRESS	92.6
CASE 7.	Cntmt Steam [0- And No AC Power				[16-2	0%]	[H2]	= 18%
	NO BURN LG BURN	0.49 0.51	BASI	E PRESS	5 11	PEAK	PRESS	121
CASE 8.	Cntmt Steam [0-	15%], C	ntmt	Eff H2	[> 2	0%]	[H2]	= 24%

And No AC Pover Available Late

		0.49 0.51	BASE PRESS 14 PEAK PRESS 166
CASE 9.	Cntmt Steam [15-2] And No AC Power Av		ntmt Eff H2 [4-8%] [H2] = 6% Le Late
	NO BURN (LG BURN (BASE PRESS 13 PEAK PRESS 26.7
CASE 10.	Cntmt Steam [15-2] And No AC Power A		ntmt Eff H2 [8-12%] [H2] = 10% le Laie
	NO BURN LG BURN		BASE PRESS 15 PEAK PRESS 59.7
CAST 11.	Cntmt Steam [15-2 And No AC Power A		ntmt Eff H2 [12-16%] [H2] = 14% le Late
	NO BURN LG BURN		BASE PRESS 17 PEAK PRESS 96.8
CASE 12.	Cntmt Steam [15-2 And No AC Pover A		ncmt Eff H2 [16-20%] [H2] = 18% le Late
	NO BURN LG BURN		BASE PRESS 19 PEAK PRESS 126
CASE 13.	Cntmt Steam [15-2 And No AC Power /		Cntmt Eff H2 [> 20%] [H2] = 24%
	NO BURN LG BURN		BASE PRESS 23 PEAK PRESS 170
CASE 14.	Cntmt Steam [25- And No AC Power		Cntmt Eff H2 [4-8%] [H2] = 6% ble Late
	NO BURN LG BURN	0.71 0.29	BASE PRESS 19 PEAK PRESS 34.1
CASE 15.	Ontmt Steam [25- And No AC Pover		Cntmt Eff H2 [8-12%] [H2] = 10% ble Late
	NO BURN LG BURN		BASE PRESS 21 PEAK PRESS 67.9
CASE 16.	Cntmt Steam [25-	-35%],	Cntmt Eff H2 [12-16%] [H2] = 14%

£ .

And No AC Power Available Late

	NO BURN LG BURN	0.58 0.42	BASE PRESS	5 24 PEAK	PRESS 103	
CASE 17.	Cntmt Steam [25 And No AC Power	-35%], (Availat	Chimt Eff H2 ble Late	2 [16-20%]	[H2] = 18%	
	NO BURN LG BURN	0.49 0.51	BASE PRESS	5 28 PEAF	CPRESS 134	
CASE 18.	Cntmt Steam [25 And No AC Power	-35%], (Availa	Cotmt Eff H2 ble Late	2 [> 20%]	[H2] = 24%	
	NO BURN LG BURN	0.49 0.51		S 34 PEAN	CPRESS 161	
CASE 19.	Cntmt Steam [35 And No AC Power	-45%], Availa	Cntmt Eff Hi ble Late	2 [4-8%]	[H2] = 6%	
	NO BURN LG BURN	0.71 0.29	BASE PRES	S 27 PEAI	K PRESS 44	
CASE 20.	Cotmt Steam [35 And No AC Power	-45%], Availa	Cntmt Eff H ble Late	2 [8-12%]	[H2] = 10%	(
	NO BURN LG BURN	0.67 0.33	BASE PRES	S 30 PEA	K PRESS 79.6	•
CASE 21.	Cntmt Steam [35 And No AC Power	-45%], Availa	Cntmt Eff H ble Late	2 [12-16%]	[H2] = 147	1
	NO BURN LG BURN	0.58	BASE PRES	S 35 PEA	K PRESS 112	2
CASE 22.	Cntmt Steam [35 And No AC Power	5-45%], Availa	Cntmt Eff H ble Late	2 [16-20%]	[H2] = 182	5
	NO BURN LG BURN	0.49 0.51	BASE PRES	S 40 PEA	K PRESS 14:	3
CASE 23.	Cntmt Steam [3: And No AC Power	5-45%], r Availa	Cntmt Eff H ble Late	2 [> 20%]	[H2] = 24	200
	NO BUNN LG BURN	0.49 0.51	BASE PRES	S 50 PEA	K PRESS 15	7

CASE	24.	Cntmt Steam (And No AC Pow	and the second se		[4-8%]	[H2] * 6%
			0.71	BLEE BREES	20 5544	
		LG BURN	0.29	BASE PRESS	38 PEAK	PRESS 58.2
CASE	25.	Cntmt Steam [And No AC Pow			[8-12%]	[H2] = 10%
			0.67			
		LG BURN	0.63	BASE PRESS	44 PEAK	PRESS 97.9
CASE	26.	Cntmt Steam [And No AC Pov			[12-16%]	[H2] = 14%
			0.58			
		LG BURN		BASE PRESS		
CASE	27.	Cntmt Steam [And No AC Pow	45-55%], C er Attellet	ntmt Eff H2 1 Late	[16-20%]	[H2] = 18%
		NO BURN LG BURN	0.49	RASE PRESS	50 PEAK	PRESS 146
			0101			11000 110
CASE	28.	Cntmt Steam [And No AC Pow			[> 20%]	[H2] = 24%
		NO BURN			70	DDEED 1/0
		LG BURN	0.51	BASE PRESS	78 PEAK	PRESS 168
CASE	29,	Cntmt Steam [And AC Power			[4-8%]	[H2] = 6%
		NO BURN	0.			
		LG BURN	1.	BASE PRESS	7.6 PEAK	PRESS 19.4
CASE	30.	Cntmt Steam [And AC Power			[8-12%]	[H2] = 10%
		NO BURN	0.			
		LG BURN	1.	BASE PRESS	8.8 PEAK	PRESS 51.6
CASE	31.	Cntmt Steam [And AC Power			[12-16%]	[H2] = 14%
		NO BURN	0.			
		LG BURN	1.	BASE PRESS	10 PEAK	PRESS 92.6

H.3 - 105

CASE	32.	Cntmt Steam [0-1 And AC Power Ava			ff H2 (16-20%	1	[H2]	= 18%	4
		NO BURN LG BURN	0. 1.	BASE	PRESS	11 P	EAK P	RESS	121	
CASE	33.	Cntmt Steam [0-1 And AC Power Ava			Cff H2 (> 20%	1	[H2]	= 24%	
		NO BURN LG BURN	0. 1.	BASE	PRESS	14 P	EAK P	RESS	166	
CASE	34.	Cntmt Steam [15- And AC Power Ava			Eff H2	[4-8%]		[H2]	= 6%	
		NO BURN LG BURN	0. 1.	BASE	PRESS	13 P	EAK 7	PSSS	26.7	
CASE	35.	Cntmt Steam [15- And AC Power Ava			Eff H2	[8-12%	() (H2] *	10%	
		NO BURN LG BURN	0. ?.	BASE	PRESS	15	PEAK	PRESS	\$ 59.7	(
CASE	36.	Cntmt Steam [15- And AC Power Ave			Eff H2	[12-16	52]	[H2]	= 14%	
		NO BURN LG BURN	0. 1.	BASE	PRESS	17	PEAK	PRESS	\$ 96.8	
CASE	37.	Cntmt Steam [15- And AC Power Ave	-25%], ailable	Cntmt Late	Eff H2	[16-20	0%]	[H2]	= 18%	
		NO BURN LG BURN	0. 1.	BASE	PRESS	19	PEAK	PRES	s 126	
CASE	38.	Cntmt Steam [15 And AC Power Av				[> 20	0%]	[H2]	= 24%	
		NO EURN LG BURN	0. 1.	BASE	PRESS	23	PEAK	PRES	s 170	
CASE	39.	Cntmt Steam [25 And AC Pover Av				[4-8%]	[H2]	= 6°.	
		NO BURN LG BURN	0. 1.		E PRESS	19	PEAK	PRES	S 34.1	

CASE 40.	Cntmt Steam [25-35%], Cntmt Eff H2 [8-12%] [H2] = 10% And AC Power Available Late
	NO BURN O. LG BURN 1. BASE PRESS 21 PEAK PRESS 67.9
CASE 41.	Cntmt Steam [25-35%], Cntmt Eff H2 [12-16%] [H2] = 14% And AC Power Available Late
	NO BURN O. LG BURN 1. BASE PRESS 24 PEAK PRESS 103
CASE 42.	Cntmt Steam [25-35%], Cntmt Eff H2 [16-20%] [H2] = 18% And AC Powe: Available Late
	NO BURN O. LG BURN 1. BASE PRESS 28 PEAK PRESS 134
CASE 43.	Cntmt Steam [25-35%], Cntmt Eff H2 [> 20%] [H2] = 24% And AC Power Available Late
	NO BURN O. LG BURN 1. BASE PRESS 34 PEAK PRESS 161
CASE 44.	Cntmt Steam [35-45%], Cntmt Eff H2 [4-8%] [H2] = 6% And AC Power Available Late
	NO BURN 0. LG BURN 1. BASE PRESS 27 PEAK FRESS 44
CASE 45.	Cntmt Steam [35-45%], Cntmt Eff H2 [8-12%] [H2] = 10% And AC Power Available Late
	NO BURN O. LG BURN 1. BASE PRESS 30 PEAK PRESS 79.6
CASE 46.	Cnimt Steam [35-45%], Cnimt Eff H2 [12-16%] [H2] = 14% And AC Power Available Late
	NO BURN 0. LG BURN 1. BASE PRESS 35 PEAK PRESS 112
CASE 47.	Cntmt Steam (35-45%), Cntmt Eff H2 [16-20%] [H2] = 18% And AC Power Available Late
	NO BURN 0. LG BURN 1. BASE PRESS 40 FEAK PRESS 143

1

CASE 48.	Cntmt Steam [35 And AC Power Av			[> 20	2] [(H2) =	24%
	NO BURN LG BURN	0. 1.	BASE PRESS	50	PEAK	PRESS	157
CASE 49.	Cntmt Steam [4] And AC Power A			[4-8%]		(H2) ×	6%
	NO BURN LG BURN	0. 1.	BASE PRESS	38	PEAK	PRESS 5	8.2
CASE 50.	Cntmt Steam [4 And AC Power A			2 [8-123	()	[H2] =	10%
	NO BURN LG BURN	0. 1.	BASE PRES	s 44	PEAK	PRESS 9	97.9
CASE 51.	Cntmt Steam [4 And AC Pover A			2 [12-10	6%]	[H2] =	14%
	NO BURN LG BURN	0. 1.	BASE PRES	S 51	PEAK	PRESS 3	128
CASE 52.	Cntmt Steam [4 And AC Power A			2 [16-2	0%]	[H2] =	18%
	NO BURN LG BURN	0. 1.	BASE PRES	s 59	PEAK	PRESS	146
CASE 53.	Cntmt Steam [4 And AC Pover 4			2 [> 2	0%]	[H2] =	24%
	NO BURN LG BURN	0. 1.	BASE PRES	s 78	PEAK	PRESS	168
CASE 54.	Otherwise, She	ould Nev	er Reach Thi	s Case			
	NO BURN LG BURN	1. 0.	BASE PRESS	5 0	PEAK	PRESS	0
vent Dependencies:	Hydrogen Igni Containment S Containment E 60), AC Power	team Cor ffective	centration 1 Hydrogen Co	Late (Ex oncentra	vent 5 ation	8),	
uantification Basis:	IPE Engineeri 3.0B Rev 7.02 For An IPE Us	using	"Recommended	Sensit	ivity	Analys	es 🔮

14

E

01

(Brown 1990) APET Event 110. Reference Table H.3.10-1.

EVENT 63. HYDROGEN DETONATION LATE CONTAIN. INT FAILURE

- H2 DET

Tvo Branches:

DET CF H2 Detonation Late Containment Failure NO No H2 Detonation Late Containment Failure

Given that a large burn war ignited in containment late in the sequence this event assesses whether the burn transitioned to a detonation and whether containment failure resulted from the detonation impulse loading. If no large burn was ignited or if the cont inmont atmosphere was inert to detonations (> 35% steam concentration) then _ detonation was assumed to occur.

The probability of a hydrogen detonation occurring is taken to be a function of the steam concentration and the effective hydrogen concentration in containment.

EVNTRE Question Type: 2. (Dependent Split Fraction)

PROBABILITIES:

CASE 1. Large Burn Late

With no large burn late, no trigger exists for a hydrogen detonation.

DET	CF			0.
NO				1.

CASE 2. Containment Steam Concentration Greater Than 35%

Steam concentrations greater than 35% prevent hydrogen detonation.

DET	CF	1.11	0.	
NO		111	1.	

CASE 3.

Containment Effective Hydrogen Concentration Less Than 12%

DET CF O. NO 1.

CASE 4.

Containment Steam Concentration High And Slowly Decreasing Less Than 35% And Effective Hydrogen Concentration 12-16% This occurs when offsite power is recovered before the containment overpressure threshold limit and sprays are available during SBO sequences, and the effective hydrogen is 12-16%.

DET	CF	0.022
NO		0.978

CASE 5. Containment Steam Concentration Low And Effective Hydrogen Concentration 12-16%

DET	CF		0.
NO			1.

CASE 6. Containment Steam Concentration High And Slovly Decreasing Less Than 35% And Effective Hydrogen Concentration > 16%

This occurs when offsite power is recovered before the containment overpressure threshold limit and sprays are available during SBO sequences, and the effective hydrogen is > 16%.

DET	CF		0,	025
NO			0.	975

CASE 7. Containment Sceam Concentration Low And Effective Hydrogen Concentration 16-20%

DET CF	0.16
NO	0.84

CASE 8. Containment Steam Concentration Low And Effective Hydrogen Concentration > 20%

> DET CF 0.27 NO 0.73

CASE 9.

DET CF 0.

Otherwise Should Never Reach This Case.

NO 1.

Event Dependencies:

Event Type (Event 3), Orisite Power Recovery Time (Event 7), Mode of RHR Spray Operation Late (Event 56), Containment Steam Concentration Late (Event 58), Containment Effective Hydrogen Concentration Late (Event Large H2 Burn Late (Event 62).

Quantification Basis: Grand Gulf (Brown 1990) APET Events 18, 44, 86, and 111; and Sequoyah Analysis (Volume 5 Rev 1 Part 1 Page 2.2, Part 2 Table A.3.1-1) page 15 and 16. Reference Table 1.3.10-2.

EVENT 64. "ydrogen Burn Late Containment Failure

Two Branches:

FAILURE Containment Failure Due to Late Hydrogen Burn NO FAILURE Containment Not Failed

This event assesses whether containment failure occurs following RPV failure as a result of a hydrogen burn. If a hydrogen detonation has occurred which fails the containment then containment failure has occurred. If a large hydrogen burn was ignited then this event compares the peak containment pressure for the burn (Parameter 5) with the containment fragility curve and determines the probability of failing the containment.

EVNTRE Question Type: 6. (Dependent event using previously defined parameters and a user function)

PROBABILITIES:

CASE 1.

Hydrogen Detonation Late Containment Failure

FAILURE 1. NO FAILURE 0.

CASE 2.

Otherwise, For Those Remaining Sequences Determine the Probability of Containment Failure Due To Large Hydrogen Burns

USER FUNCTION				FAILURE	NO	FAILURE	
If Peak Containment	Pressure	~ ~ ~ ~ ~ ~ ~ ~	75 70 65 60	1. 0.98 0.90 0.69 0.39 0.15 0.034 0.		0. 0.02 0.10 0.31 0.59 0.85 0.966 1.	

Event Dependencies: Hydrogen Detonation Late Containment Failure (Event 63). Quantification Basis: Perry Nuclear Power Plant IPE Containment Capacity Analysis, nrd IPE Engineering Calculation - Containment Fragility.

- CF

EVENT 65. CONTAINMENT STATUS AT ACCIDENT PROGRESSION COMPLETION

- CNTMT ST

Four Branches:

EARLY CF	Early Containment Failure
LATE CF	Late Overpressure Failure
VENT	Containment Vent
NO LATE CF	Containment Not Failed or Vented

This event assesses whether containment failure occurs late in the sequence progression due gradual overpressurization from steam and non-condensible gas generation. This event also assess whether the containment was vent. prevent overpressure failure. The event pathway probabilities are a ... tion of whether containment failure has already occurred earlier in the accive. whether containment heat removal is available, whether the containment is vented, and the sequence type.

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE 1. Containment Failed At Core Damage

EARL	Y CF	1.
LATE	CF	0.
VEN"		0.
NO 1	LATE CF	0.

CASE 2.

Containment Vent Not Isolated At RPV Failure During SBO Sequences

EAF	RLY	CF	1.
LA1	CE C	F	0.
VEN	TV		0.
NO	LAT	E CF	0.

CASE 3.

Containment Failure Defore RPV Failure

EARLY CF	1.
LATE CF	0.
VENT	0.
NO LATE CF	0.

CASE 4.

Containment Failure At/Near RPV Failure

EARLY CF 1. LATE CF 0.

VENT			0.
NO LA	ΤE	CF	0.

CASE 5. Containment Infact At Core Damage And A Critical ATVS Sequence

This applies to the sensitivity case of improving the Plant Emergency Instructions to control reactor power such that containment heat removal can be successful with venting.

EAR	LY CF	0.
LAT	E CF	0.
VEN	Т	1.
NO	LATE CF	0.

CASE 6.

Containment Heat Removal With RHR Spray or RHR Pool Cooling and No Pool Typass, And Dry CCI

EARLY CF	0.0
LATE CF	0.1
VENT	0.0
NO LATE CF	0.9

CASE 7.

Containment Heat Removal With RHR Spray or RHR Pool Cooling and No Pool Bypass, And No Dry CCI

EARLY CF	0.
LATE CF	0.
VENT	0.
NO LATE CF	1.

CASE 8.

Containment Heat Removal With RHR Pool Cooling And No Pool Bypass, And No Vent

EARLY CF	0.00
LATE CF	0.75
VENT	0.00
NO LATE CF	0.25

CASE 9.

Containment Heat Removal With Vent

EARLY CF	0.
LATE CF	0.
VENT	1.
NO LATE CF	Ο.

CASE 10.	No Containment Heat Removal With RH And SBO Sequences With Early and In Loss Of Injection	
	EARLY CF O. LATE CF 1. VENT O. NO LATE CF O.	
CASE 11.	No Containment Heat Removel With RH And SBO Sequences With Late Injecti	
	EARLY CF O. LATE CF 1. VENT O. NO LATE CF O.	
CASE 12.	No Containment Heat Removal With RI And Early or Intermediate Loss of 1	
	EARLY CF 0. LATE CF 1. VENT 0. NO LATE CF 0.	
CASE 13.	No Containment Heat Removal With R For All Other Sequences	HR
	EARLY CF 0. LATE CF 1. VENT 0. NO LATE CF 0.	
CASE 14.	Otherwise, Should Never Reach This	Case
	EARLY CF LATE CF VENT NO LATE CF	
Event Dependencies:	Containment Status At Core Damage (Event 3), Containment Vent Isola (Event 5), RFV Injection Failure Power Recovery Time (Event 7), Co With RHR Loop (Event 8), Containm Vent (Event 9), Containment Failu (Event 24), Containment Failure A (Event 46), Pool Bypass Before/Ne	ted At RPV Failure Time (Event 6), Offsite ntainment Heat Removal ent Heat Removal With re Before RPV Failure t/Near RPV Failure

0-

49).

Quantification Basis:

IPE Engineering Calculation - MAAP Accident Progression Analysis, and engineering judgement.

EVENT 66. MODE OF LATE HYDROGEN AND SLOW OVERFRESSURE CONTAINMENT FAILURE

- LATE CF

Two Branches:

ANCHORAGE	Containment	Anchorage Failure Mode
FEN-DOM/NO CF	Containment	Penetration or Dome Failure Mode,
	Or No Con	tainment Failure Mode

Given ' at containment failure has occurred then the probability of various modes of containment failure are determined by this event. For sequences where the containment has failed by a hydrogen burn the peak containment pressure from the burn is used to estimate the probability of each failure mode. The individual fragility curves for the dominant failure modes were used to determine the conditional probabilities for each failure mode as a function of the failure pressure. The peak burn pressure is then used to determine the probability of each failure mode.

Note that this succinct sorting of failure modes into just two categories can be used to characterize penetration/dome containment failure with a q estion asking sequence of: 1) No Containment Failure, 2) Anchorage Containment Failure, and then 3) Containment Failure (which would provide the remaining Penetration/Dome containment failures).

EVNTRE Question Type: 6. (Dependent event using previously defined para eters and a user function)

PROBABILITIES:

CASE 1. Late Containment Failure Due To Steam Overpressure

This case is for gradual steam overpressure late.

ANCHORAGE	0.	15
PEN-DOM/NO CF	0,	85

CASE 2. No Containment Failure Late Due to Hydrogen Burns

This sorting case assigns the no containment failure sequences.

ANCHORAGE 0. PEN-DOM/NO CF 1. CASE 3. Hydrogen Detonation Containment Failure.

All detonations are considered to most likely occur in the dome region and are assigned to the perstration-dome or no containment failure.

ANCH	ORA	GE		0.
PEN-	DOM.	/NO	CF	1.

CASE 4.

Otherwise, The Remaining Sequences Are Hydrogen Deflagration Containment Failure

USER FUNCTION	ANCHORAGE	PENETRATION
If Peak Containment Pressure > 140 Ps > 130 > 120 > 115 > 110 > 105 > 100 > 95 > 90 > 85 > 80 > 75 Else	sig 1. 0.98 0.95 0.90 0.85 0.78 0.71 0.61 0.51 0.41 0.30 0.21 0.15	0. 0.02 0.05 0.10 0.15 0.22 0.29 0.29 0.39 0.49 0.49 0.59 0.70 0.70 0.79 0.85

Event Dopendencies:	Hydrogen Burn Late Containment Failure (Event 64), Containment Status At Accident Completion (Event 65).
Quantification Basis:	Perry Nuclear Fower Plant IPE Containment Capacity Analysis, and IPE Engineering Calculation - Containment Failurr Modes Conditional Probability.

H.3.11 POOL BYPASS LATF

This APET Group of Events 67 and 68, determines the probability of pool bypass late in the accident progression. Fission product scrubbing in the suppression pool is an effective fission product mitigation mechanism. However, if the release pathway bypasses the suppression pool this mechanism is not effective. Pool bypass may result from a number of causes. These include: 1) structural failure of the drywell, 2) excessive leakage through drywell penetrations, or loss of suppression pool water below the level of the horizontal vents or the SRV guenchers.

Drywell structural failure may result from transient over-pressurization of the drywell or wetwell resulting in a sufficiently high drywell/wetwell differential pressure to cause failure of the drywell head, ceiling or walls. Loss of suppression pool water may result from containment failure modes (such as the containment anchorage) in the pool region or as a result of interfacing systems LOCAs.

This event is dependent on the following Events in the Perry APET.

EVENT 67. DPYVELL FAILURE LATE DUE TO LATE HYDROGEN BURN IN THE CONTAINMENT

- DV LATE

Tvo Branches:

DW FAILURE Drywell Failure Due To Late Hydrogen Burn NO DW FAIL No Drywell Failure

Given that a large hydrogen burn has occurred late in the sequence this event assesses whether drywell failure results from excessive differential pressure across the drywell boundary. If a large burn has not occurred in containment then drywell integrity is not challenged (by hydrogen combustion). For cases where a large hydrogen burn has occurred two parameters have been set which give the peak burn pressure in containment during the burn and the containment pressure prior to the burn. It is assumed that the drywell pressure remains constant during the burn in containment. Given the value of these two parameters the peak drywell differential pressure is calculated and compared against the drywell fragility curve in a user function to estimate the probability of drywell structural failure.

EVNTRE Question Type: 6. (Dependent event using previously defined parameters and a user function)

PROBABILITIES:

CASE 1. Large Hydrogen Burn Late

USER FUNCTION

DV FAILURE NO FAILURE

If	Cntmt/DW	Differential H	ressure	<	40 Psid	0.	1.
				5	55	0.05	0.95
				<	60	0.17	0.83
				<	65	0.27	0.73
				<	70	0.41	0.59
				<	75	0.55	0.45
				<	80	0.68	0.32
				<	85	0.79	0.21
				<	90	0.88	0.12
				<	95	0.93	0.07
				21	20	1	0.

CASE 2.

Otherwise, For Remaining Sequences With No Large Burns Default To No Dryvell Failure

DV	FAI	LURE	(
NÖ	DV	FAIL	1

Event Dependencies:	Large Hydrogen Burn Late (Event 62).	
Quantification Basis:	Perry Nuclear Power Plant IPE Containment Analysis, and IPE Enginetring Calculation Fragility.	

EVENT 68. POOL BYPASS LATE

Tvo Branches:

LATE POOL BYP	Late Pool Bypass
NO LATE BYP	No Late Bypass

This summary event assess the probability that pool bypass will occur late in the accident sequence. This event considers pool bypass resulting from drywell failure form hydrogen combustion in the containment (APET Event 60), pool bypass due to containment anchorage failure (APET Event 64) and pool bypass resulting from pedestal failure caused by CCI (APET Event 53).

- LATE PB

EVNTRE Question Type: 2. (Dependent Split Fractions)

PROBABILITIES:

CASE i. Drywell Failure Due To Late Hydrogen Burn In Containment

> LATE POOL BYP 1. NO LATE BYP 0.

CASE 2. Pool Bypass By Containment Anchorage Failure Late

LATE POOL BYP 1. NO LATE BYP 0.

CASE 3. Pool Bypass By Pedestal Failure Due To CCI Erosion LATE POOL BYP 1. NO LATE BYP 0.

CASE 4. Pocl Bypass By Penetration Failure Associated With High Temperature During Dry CCI

LATE POOL BYP 1.

H.3 - 118

NO LATE BYP 0.

CASE 5.

Drywell Vacuum Breaker Failure Due To Large Burn When AC Power Is Available

LATE POOL BYP 0.05 NO LATE BYP 0.95

CASE 6.

Otherwise, For The Remaining Sequences Fool May Be Bypassed By Other Failures

LATE FOOL BYP 0.0001 NO LATE BYP 0.9999

Event Dependencies:

Event Type (Event 3), Offsite Power Recovery Time (Event 7), Type Of Core Debris Concrete Interactions (Event 54), Pedestal Failure Due To Core Debris Concrete Interaction (Event 55), Large Hydrogen Burn Late (Event 62), Mode of Late Hydrogen And Overpressure Containment Failure (Event 66), Drywell Failure Due To Late Hydrogen Burn In Containment (Event 67).

Quantification Basis:

. 1

. . . .

Grand Gulf (Brown 1990) APET 95, and engineering judgement.

REFERENCES

Brown, T.D. et al 1990 Evaluation of Severe Accident Risks: Grand Gulf Unit 1 NUREG/CR-4551 Volume 6 Revision 1 Parts 1 and 2, Sandia National Laboratories, Albuquerque, NM.

EPRI 1988 Project RP Y101-01, Hydrogen Combustion Experiments in a 1/4 Scale Model of a Mark III Nuclear Containment, Volume 1 and 2, Factory Mutual Research Corporation, Norword MA.

EPRI 1990 Recommended Sensitivity Analyses For An Individual Plant Examination Using MAAP 3.0B, M.A. Gabor, Kenton & Associates, Inc., Westmont, IL

- Gilbert/Commonwealth, 1992, Cleveland Electric Illuminating Company Perry Nuclear Power Flant Individual Plant Examination Containment Capacity Analysis, Reading, PA.
- Griesmeyer, J.M. et al 1989 <u>A Reference Munual for the Event Progression</u> <u>Analysis Code (EVNTRE)</u> NUREG/CR-5174, Science Applications International Corporation, Albuquerque, NM.
- Harper, F.T. et al 1991 Evaluation of Severe Accident Risks: <u>Quantification of</u> <u>Major Input Parameters</u>, <u>Expert's Determination of Containment Loads a</u>... <u>Molten Core Containment Interaction Issues</u>; <u>NUREG/CR-4551 Volume 2</u>, <u>Rev</u> 1, Part 2; Sandia National Laboratories, Albuquerque, NM.
- ROC AEC, (Republic of Coina, Atomic Energy Council) 1985 "Probabilistic Risk Assessment Kuosheng Nuclear Power Plant Unit 1", Executive Yaun, Taipei, Taiwan.

Rempe, J.L. et al 1991 BWR Lover Head Failure Assessment For CSNI Comparison Exercises, Idaho National Engineering Laboratory, EGG-ENST-9609.

SERG, (Steam Explosion Review Group) 1985 A Review of the Current Understanding of the Potential for Containment Failure From In-Vessel Steam Explosions NUREG/1116, Office of Nuclear Regulatory Research, Washington, DC.

H.3.3-1	HYDROGEN COMBUSTION PARAMETERS BEFORE RPV FAILURE
H.3.3-?	PROBABILITY OF CONTAINME.4T FAILURE FROM A H2 DETONATION PRIOR TO RPV FAILURE
8.3.5-1	MAAP PREDICTION FOR PEAK FEDESTAL PRESSURE AT RFV FAILURE FOR LOOP AND SBO SEQUENCE TYPES WITH LOSS OF ALL INJECTION
H.3.6-1	HYDROGEN COMBUSION PARAMETERS AT/NEAR RPV FAILURE
H.3.6-2	PROBABILITY OF CONTAINMENT FAILURE FROM A H2 DETONATION AT/NEAR RPV FAILURE
H.3.10-1	HYDROGEN COMBUSION PARAMETERS AT LATE CONTAINMENT FAILURE
H.3.10-2	PROBABILITY OF CONTAINMENT FAILURE FROM A H2 DETONATION LATE

TABLES

TABLE H.3.3-1 HYDROGEN COMBUSTION PARAMETERS BEFORE RPV FAILURE

CASE	[H2]	[STEAM]	H2 BURM EFFICIENCY	BASE PRESSURE	AICC FRESSURE	PEAK PRESSURE	LARGE BURN PROBABILITY
1	Low		(Small Burn	At Lov Hydro	gen Conce	ntration)	.0
2		>55%	(Steam-Inert	Containment	Atmosphe	re }	.0
3	.256	.075	.88	9	161	142	. 5
4	.188	.075	.88	6	111	98	.5
5	.105	.075	.62	4	62	40	.28
6	.221	.20	.75	14	159	123	.5
7	.162	.20	.74	11	113	87	.5
8	. 090	.20	.50	9	65	37	.28
9	.194	.30	.65	20	163	113	.5
10	.142	. 30	.63	16	118	80	. 39
11	.079	.30	.40	13	69	36	.25
12	.166	.40	.54	27	169	104	. 44
13	.122	.40	.51	23	124	75	.33
14	.060	.40	, 33	19	74	37	.23
15	.138	.50	.43	37	179	98	.39
16	.102	. 50	.44	32	133	76	.28
17	.057	. 50	.25	27	82	40	.23

H.3 - 122

S.

TABLE H.3.3-2 PROBABILITY OF CONTAINMENT FAILURE FROM A H2 DETONATION PRIOR TO RPV FAILURE

CASE	[H2]	[STEAM]	DETONATION PROBABILI" ?	MEAN IMPULSE LOADING (KPA-S)	CONTAINMENT CONDITIONAL FAILURE PROBABILITY (GIVEN A H2 DET)	CONTAINMENT FAILURE PHOBABILITY
1	i den b	**			(NO LARGE BU	JRN IGNITED)
2	ALL	>35%	0.	0.	0.	0.
3	< 12%	ALL	0.	Ō.,	0.	0.
4	12-16	HI & DECRE	ASING .22	5.8	0.1	0.022
5	12-16	LOV	0.	0.	0.	0.
7	> 20	HI & DECRE	ASING .25	5.8	0.1	0.025
8	> 20	LOW	.45	12.4	0.6	0.27
6,9	16-20	LOV	.26	12.4	0.6	0.16



TABLE H.3.5-1 MAAP PREDICTION FOR PEAK PEDESTAL PRESSURE AT RPV FAILURE FOR LOOP AND SBO SEQUENCE TYPES WITH LOSS OF ALL INJECTION

MAAP RUN NUMBER	WATER IN PEDESTAL FM SPMU (FEET)	RPV PRESS	INITIAL SIZE OF RPV LOVER HEAD FAILURE (SQUARE FEET)	PEAK PEDESTAL PRESSURE (PSID)
PPD_0_01	6	HIGH	INSTRUMENT TUBE PENETRATION .023	648
PPD_0_02	6	HIGH	CONTROL ROD DRIVE PENETRATION .20	289
PPD_0_03	6	HIGH	BOTTOM RPV HEAD LARGE FAILURE 21.5	1124
PPD_0_06	0	HIGH	INST TUBE PENETRATION	78
PPD_0_07	0	HIGH	CRD DRIVE PENETRATION	48
PPD_0_08	0	HIGH	BTM HEAD LARGE FAILURE	533
PPD_0_11	0	Low	Inst Tube Penetration	2.8
PPD_0_12	0	Lov	CRD Drive Penetration	1.8
PPD_0_13	Ō	Lov	Btm Head large Failure	15.9
PPD_0_16	3	Low	Inst Tube Penetration	59
PPD_0_17	3	Lov	CRD Drive Penetration	46
PPD_0_18	3	Low	Btm Head large Failure	e 791

TABLE H.3.6-1 HYDROGEN COMBUSTION PARAMETERS AT/NEAR RPV FAILURE

CASE	[H2]	[STEAM]	H2 BURN EFFICIENCY	BASE PRESSURE	AICC PRESS	PEAK PRESS	BURN PARM	LARGE BURN PROBABILITY
1	lov		(Continuous					0.
2	-	>55%	(Steam-Inert	Containmen				0.
3	.217	.075	.88	13	165	147	A,D	1.
4	.217	.075	.85	17	169	151	H	0.63
5	.217	.075	.88	13	165	147	0	0.49
6	.188	.20	.75	20	169	131	A,D	1.
7	.188	.20	.75	24	173	135	H	0.63
8	.188	.20	.75	20	169	131	0	0.49
9	.164	.30	. 64	26	173	120	A,D	1.
10	.164	.30	.64	30	177	124	H	0.63
11	.164	.30	.64	26	173	120	0	0,49
12	.141	.40	.53	35	182	113	A,D	1.
13	.141	.40	.53	39	186	117	H	0.56
14	.141	.40	.53	35	182	113	0	0.38
15	.117	.50	.43	46	193	109	A.D	1.
16	.117	.50	.43	50	197	113	H	0.43
17	.117	.50	.43	46	193	109	0	0.28
18	.157	.075	.87	11	118	104	A,D	1.
19	.157	.075	.87	15	122	108	H	0.56
20	.157	.075	.87	11	118	104	0	0.38
21	.136	.20	.73	17	123	94	A,D	1.
22	.136	.20	.73	21	127	98	H	0.56
23	.136	.20	.73	17	123	94	0	0.38
24	.119	.30	. 58	23	127	83	A,D	1.
25	.119	.30	.58	2.7	131	87	Н	0.43
26	.119	.30	. 58	23	127	83	0	0.28
27	.102	.40	.48	31	135	81	A,D	1.
20	.102	.40	.48	35	139	85	H	0.43
29	.102	.40	.48	31	135	81	0	0.28
30	.085	.50	.38	41	145	81	A,D	1.
31	.085	.50	.38	45	149	85	H	0.43
32	.085	.50	.38	11	145	81	0	0.28
33	,086	.075	.50	8	68	38	A,D	1.
34	.086	.075	.50	12	72	42	Н	0.43
35	.086	.075	.50	9	68	38	0	0.28
36	.074	.20	.38	14	72	36	A,D	
37	.074	.20	.38	18	76	4C	Н	0.29
38	,074	.20	. 38	14	72	36	0	0.21

BURN PARAMETER KEY: A - AC Power Lecovered

D Dryvell Failure H - High Pressure Melt Fjection

O - Other, No AC Power - No Dryvell Failure - No HPME



TABLE H.3.6-1 (cont) HYDROGEN COMBUSTION PARAMETERS AT/NEAR RPV FAILURE

CASE	{H2}	[STEAM]	12 BURN EFFICIENCY	BASE PRESSURE	AICC PRESS	PEAK PRESS	BURN PARM	LARGE BURN PROBABILITY	
39	.065	.30	. 31	19	77	37	A,D	1.	
40	.065	.30	.31	23	81	41	Н	0.29	
41	.065	.30	.31	19	77	37	0	0.21	
42	.056	.40	.25	27	84	41	A,D	1.	
43	.056	.40	.25	31	88	45	Н	0.29	
44	.056	.40	.25	27	84	41	0	0.21	
45	.046	.50	.18	36	91	46	A,D	1.	
- 46	.046	.50	.18	40	95	50	Н	0.29	
47	.046	.50	.18	36	91	46	0	0.21	

BURN PARAMETER KEY: A - AC Power Recovered

- D Drywell Failure
- H High Pressure Melt Ejection
- 0 Other, No AC Power No Dryvell Failure No HPME

TABLE H.3.6-2

PROBABILITY OF CONTAINMENT FAILURE FROM A H2 DETONATION AT/NEAR TO RPV FAILURE

CASE	[H2]	(Stean)	Detonation Probability	an Impulse Loading (k ^p a-s)	Containment Conditional Failure Probability (Given a H2 Des	Containment Failure Probability
1	**	**			(No Large	Burn Ignited
2	A11	>35%	0.	0.	0.	0.
6	< 12%	A11	0.	0.	0.	ο.
7	12-16	Hi & Decrea	ising .22	5.8	0.1	0.022
8	12-16	Lov	0.	0.	0.	0.
3	> 20	Hi & Decrea	sing .25	5.8	0.1	0.025
4,6	> 20	Lov	.45	12.4	0.6	0.27
5,9	16-20	Lov	.26	12:4	0.6	0.16



TABLE H.3.10-1 HYDROGEN COMBUSTION PARAMETERS AT LATE CONTAINMENT FAILURE

CASE	[#2] [12 BURN PFICIENCY PR	BASE ESSURE PI	AICC RESSURE 1	PEAK PRESSURE	LARGE BURN PROBABILITY
2 .	Lov .04	>55% (S	ontinuous Igni team-Inert Con arge Deflagrat	tainment /	Atmosphere	e)	.0 .0
[Cases	4 - 28	are for the	e condition: N	lo AC Pove	r Late		1
5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23	.06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .10 .14 .10 .14 .10 .14 .10 .14 .10 .14 .10 .14 .10 .14 .14 .18 .24 .06 .10 .14 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .06 .10 .14 .18 .24 .10 .14 .18 .24 .10 .14 .18 .24 .10 .14 .18 .24 .10 .10 .14 .18 .24 .10 .10 .14 .18 .24 .10 .10 .14 .18 .24 .10 .10 .14 .18 .24 .10 .14 .18 .24 .10 .10 .14 .18 .24 .10 .118 .24 .10 .118 .24 .10 .118 .24 .10 .118 .24 .10 .118 .24 .10 .118 .24 .10 .118 .24 .10 .118 .24 .10 .118 .24 .108 .24 .24 .24 .24 .24 .24 .24 .24 .24 .24	.075 .075 .075 .075 .075 .20 .20 .20 .20 .20 .20 .20 .20 .30 .30 .30 .30 .30 .30 .40 .40 .40 .40	. 28 .62 .86 .88 .88 .28 .57 .73 .75 .75 .75 .28 .53 .63 .65 .65 .65 .28 .48 .53 .54 .54	7.6 8.8 10 11 14 13 15 17 19 23 19 21 24 28 34 27 30 35 40 50	50 78 106 135 187 61 93 126 161 219 72 109 149 191 229 88 133 181 231 249	19 4 51.5 93 121 166 26.7 59.7 97 126 170 34.1 67.9 103 134 161 44 79.6 112 143 157	.29 .33 .42 .51 .51 .29 .33 .42 .51 .51 .29 .33 .42 .51 .51 .29 .33 .42 .51 .51 .51 .51 .51 .51
25 26 27	.06 .10 .14 .18 .24	.50 .50 .50 .50 .50	, 28 , 44 , 43 , 44 , 44	38 44 51 59 78	110 167 230 256 283	58.2 98 128 146 164	.27 .33 .42 .51 .51

TABLE H.3.10-1 continued

HYDROGEN COMBUSTION PARAMETERS AT LATE CONTAINMENT FAILURE

CASE	[H2]	[STEAM]	H2 BURN EFFICIENCY	BASE PRESSURE	AICC PRESSUPE	PEAK PRESSURE	LARGE BURN PROBABILITY
[Case	es 29 -	54 are for	the condition	on: AC Pove	r Availabl	e Late	1
29	.06	.075	.28	7.6	50	19 4	1.
30	.10	.075	.62	8.8	79	51.6	1.
31	.14	.075	.86	10	106	93	1.
32	.18	.075	.88	11	135	121	1.
33	.24	.075	.88	14	187	166	1.
34	.06	.20	.28	13	61	26.7	1.
35	.10	.20	.57	15	93	59.7	1.
36	.14	.20	.73	17	126	97	1.
37	.18	.20	.75	19	161	126	1.
38	.24	.20	.75	23	219	170	1.
39	.06	.30	.28	19	72	34.1	1.
40	.10	.30	.53	21	109	67.9	1.
41	.14	.30	. 63	24	149	103	1.
42	.18	.30	.65	28	191	134	1.
43	.24	.30	.65	34	229	161	1.
44	.06	.40	.28	27	88	44	1.
45	.10	.40	. '3	30	133	79.6	1.
46	.14	.40	.53	35	* 01	112	1.
47	.18	.40	.54	40	231	143	1.
48	.24	.40	.54	50	249	157	1.
50	.06	50	.28	38	110	58.2	1.
51	.10	0	.44	44	167	98	1.
52	.14	.50	.43	51	230	128	1.
53	.18	. 50	.44	59	256	146	1.
54	.24	.50	. 44	78	283	168	1.



i.

TABLE H.3.10-2

PROBABILITY OF CONTAINMENT FAILURE FROM A H2 DETONATION LATE

CASE	[H2]	[Steam]	Detonation Probability	Mean Impulse Loading (kr -s)	Contaicment Conditional Failure Probability (Given a H2 Det)	Containment Failur Probability
1	**				{ No Large Bu	irn Ignited)
2	A11	>35%	0.	0.	0.	0.
3	< 12%	All	0.	0.	0.	0.
4	12-16	Hi & Decr	easing .22	5.8	0.1	0.922
5	12-16	Lov	0.	0.	0.	0,
6	> 16	Hi & Decr	easing .25	5.8	0.1	0.025
8	> 20	Lov	.45	12.4	0.6	0.27
7	16-20	Low	.26	12.4	0.6	0.16

H.3 - 130

APPENDIX H.4

PNPP IPE APET PROGRAM PREQUENCY OUTPUT FILE

The PNPP IPE Accident Progression Even: Tree (APET) Program Frequency Output File from the Event Progression Analysis (EVNTRE) code with the base case input data file provides a record of how the paths through the tree were propagated. It provides useful information concerning split fractions for event branches and cases.



IONS: ENCE: E ID:	68		BASE CASE QUENCES +00	RI	EVISION C	19JUN1992
SKED: CHFS:		INDEP. INF NoBYPA 1	SS EVENT V	ONTAINMENT	BYPASS :	SEQUENCE 1
SKED: CHES:		DEP. INPUT INTACT	ETER 2 CONTAIN T PROB. T FAILED 2 -01 2.280E~01		S AT COR	e damage 2
	SUMMA	RY BY CASE				
CIES: CHES: TION:	1 1 NoBY		+00 -01 2.280E-01			
SPLIT: PTION: SPLIT:	2	0.000E OTHERWISE 0.000E	+00 +00 0.000E+00			
ASKED:		DEP. INPU SBO 1	ETER 3 EVENT T PROB. LOOP NO B 2 -02 0.000E+00	OTHER TYP	CRIT AT	5 15 LOOP & SE 5
	SUMM/	ARY BY CASH				
SPLIT: NCIES:	1 2	7.7201	8-01			

1 TREE ID:	PERPY IPE	APET	BASE CASE
# OF QUESTIONS:	68		
STATS FOR SEQUENCE:		1	
SEQUENCE ID:		ALL SEC	UENCES
INITIAL FREQ.:		1.000E-	00

******* OUEST Q-TYPE/TIMES AS BRANC

REALIZED SP

****** QUEST

Q-TYPE/TIMES AS BRANC REALIZED SP

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 1.000E+00 1 1 NoBYPASS 7.720E-01 2.280E-01	
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	2 0.000E+00 OTHERWISE 0.000E+00 0.000E+00	

T CORE D. ******* OUES Q-TYPE/TIMES A SB OTHE BRAN 6 02 1.401 REALIZED S

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: C.SE/BRANCH SPLIT:	1 7.720E-01 2 1 INTACT 9.032E-02 0.000E+00 6.817E-01 0.000E+00 0.000E+00 0.000
CASE NUMBER/SPLIT:	2 2.280E-01
CASE NORBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	OTHERWISE S DEFAULT TO NO BRANCH 0.000E+00 0.000E+00 0.000E+00 4.435E-02 4.355E-02 1.401
******* QUESTION: Q-TYPE/TIMES ASKED:	4 PDS PARAMETER 4 INITIAL CNTMT HEAT REMOVAL WITH SUPPORT

0.

BRANCHES:	IN_PL	NO_IN_PL	
REALIZED SPLIT:	0.000E+00	2 1.000E+00	
	SUMMARY BY CASE		
DEPENDENCIES:		0.000E+00	
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	OTKIRVISE	\$ NOT A LOOP NO HVAC	
Q-TYPE/TIMES ASKED: BRANCHES	DEP. INPUT P	NOT ISOL	5
KENDLEED BEELL		1 3.101B-04	
	SUMMARY BY CASE		
CASE NUMBER/SPLIT: DEPENDENCIES: REO. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 1 SBO		
CASE NUMBER/SPLIT:			
	OTHERWISE	\$ DEFAULT TO ISOLATED 1 0.000E+00	
Q-TYPE/TIMES ASKED: BRANCHES:	DEP. INPUT P NO INJEC 1	CT RCIC HPCS NO BRANCH 2 3 4	
REALIZED SPLIT:	9.489E-01	1 2.527E-02 2.578E-02 0.000E+00	
	SUMMARY BY CASE		
REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 5 1 * 1 SBO ISOLATE 3.913E-02	ED 2 2.518E-02 2.569E-02 0.000E+00	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	3 1	4	

H.4 - 3

CASE/BRANCH SPLIT:	1.374E-04 8.846E-05 9.023E-05 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 4
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 4
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	UTHER*136
Q-TYPE/TIMES ASKED: BRANCHES:	7 PDS PARAMETER 7 OFFSITE FOWER RECOVERY TIME DEP. INPUT PROB. 20 PRIOR RV CNTMT LIM NO RECOV NO BRANCH 1 2 3 4 4.132E-02 3.171E-02 9.270E-01 0.000E+00
REALIZED SPLIT:	4.132E-02 3.171E-02 9.270E-01 01500E-00
	SUMMARY BY CASE
DEPENDENCIES: REO. BRANCHES:	1 * 1 SBO NO INJECT
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 6 1 * 2 SBO RCIU
CASE NUMBER/SPLIT DEPENDENCIES REQ. BRANCHES DESCRIPTION CASE/BRANCH SPLIT	3 6 1 * 3 3 BO HPCS
CASE NUMBER/SPLIT DESCRIPTION CASE/BRANCH SPLIT	1 OTHERVISE
******* QUESTION Q-TYPE/TIMES ASKEI BRANCHES	DEP. INPUT PROB.

-

-

REALIZED SPLIT: 4.297E-01 0.000E+00 5.703E-01

20.00

1

	SUMMARY	BY CASE
CASE NUMBER/SPLIT:	1	3.161E-04
DEFENDENCIES:		5
REQ. BRANCHES:		
DESCRIPTION:		
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00 3.161E-04
CASE NUMBER/SPLIT:		2,406E-02
the second product second reserves to the second second second	3	6 7
		* 1 * 1
DESCRIPTION:		NO INJECT PRIOR RV
CASE/BRANCH SPLIT:		1.999E-02 0.000E+00 4.061E-03
CASE NUMBER/SPLIT:	3	1.396E-02
DEPENDENCIES:	3	6 7 * 1 * 2
REQ. BRANCHES:		
DESCRIPTION:		NO INJECT CNTMT LIM
CASE/BRANCH SPLIT:		1.156E-02 0.000E+00 2.395E-03
CASE NUMBER/SPLIT:		6.256E-03
DEPENDENCIES:	3	6 7
REQ. BRANCHES:		* 2 * 1
DESCRIPTION:	SBO	ACIC PRIOR RV
CASE/BRANCH SPLIT:		5.930E-02000E+00 3.259E-04
CASE NUMBER/SPLIT:	5	1.764E-02
DEPENDENCIES:		6 7
REQ. BRANCHES:	1 1	* 2 * 2
DESCRIPTION:	SBO	RCIC CNTMT LIM
CASE/BRANCH SPLIT:		RCIC CNTMT LIM 1.638E-02 0.000E+00 1.265E-03
CASE NUMBER/SPLIT:	6	1.087E-02
DEPENDENCIES:		6 7
REQ. BRANCHES:	1	* 3 * 1
DESCRIPTION:		HPCS PRIOR RV
CASE/BRANCH SPLIT:		9.880E-03 0.000E+00 9.891E-04
CASE NUMBER/SPLIT:		6.817E-01
DEPENDENCIES:		
REQ. BRANCHES:	3	
DESCRIPTION	OTHER	
CASE/BRANCH SPLIT:		3.525E-01 0.000E+00 3.292E-01
CASE NUMBER/SPLIT:		4.435E-02
DEPENDENCIES	3	2
REQ. BRANCHES	4	* 2
DESCRIPTION	CRIT	ATWS FAILED
CASE/BRANCH SPLIT		1.341E-02 0.000E+00 3.093E-02
CASE NUMBER/SPLIT	. 9	0.000E+00
DEPENDENCIES	: 3	2

4.

4

	REQ. BRANCHES:	4	* 1 ATWS INTACT
	CASE/BRANCH SPLIT:	CRII	0.000E+00 0.000E+00 0.000E+00
	CASE NUMBER/SPLIT:	10	2.0096-01
	DESCRIPT 'ON:		OTHERWISE
	CASE/BRANCH SPLIT:		0.000E+00 0.000E+00 2.009E-01
	CHORE PROVIDENCE		
-	****** QUESTION:	9	PDS PARAMETER 9 CONTAINMENT HEAT REMOVAL WITH VENT DEP. INPUT PROB. 34 VENT NO VENT
1	-T7PE/TIMES ASKED:		DEP. INPUT PROB. 34
	BRANCHES:		VENT NO VENT
			1
	REALIZED SPLIT:		2.987E-01 7.013E-01
		SUMMA	RY BY CASE
	CASE NUMBER/SPLIT:	1	4.145E-03
	DEPENDENCIES	3	6 7 8 * 1 * 1 * 3
	RED. BRANCHES:	1	* 1 * 1 * 3
	DESCRIPTION	SBO	NO INJECT PRIOR RV NU RHR
	CACE / REANCH SPLIT:	NORT W.	4.145E-03 0.000E+00
	CASE/ BRANCH STUIT.		
	CASE NUMBER/SPLIT:	2	2.444E-03
	DEPENDENCTES	3	6 7 8
	REO. BRANCHES:	1	* 1 * 2 * 3
	DESCRIPTION:	SBO	NO INJECT CNTMT LIM NO_RHR
	CASE/BRANCH SPLIT:		2.444E-03 0.000E+00
	CUDDI DIGUIÇII CENEET		
	CASE NUMBER/SPLIT:	3	1.119E-03
	DEPENDENCIES:	3	6 7 * 1 * 3
	REO. BRANCHES:	1	* 1 * 3
	DESCRIPTION:	SBO	NO INJECI NO RECOV
	CASE/ERANCH SPLIT:		9.709E-04 1.482E-04
	CASE NUMBER/SPLIT:	4	3.479E-04
	DEPENDENCIES.	3	6 7 8
	REQ. BRANCHES:	1	* 2 * 1 * 3
	DESCRIPTION:		RCIC PRIOR RV NO_RHR
	CASE/PRANCH SPLIT:		3.479E-04 0.000E+00
	THE HUNDER (CELTE.	5	1.327E-03
	CASE NUMBER/SPLIT:		6 7 8
	DEP 'N ENCIES:		* 2 * 2 * 3
	REQ. BRANCHES:		RCIC CNTMT LIM NO_RHR
	DE_CRIPTION:		1.327E-03 0.000E+00
	CASE/BRANCH SPLIT:		112515-03 01000100
	CASE NUMBER/SPLIT:	6	1.289E-03
	DEPENDENCIES:		6 7
	REQ. BRANCHES:		* 2 * 3
	DESCRIPTION:	SBO	RCIC NO RECOV
	CASE/BRANCH SPLIT:		2.351E-04 1.054E-03
	VILLE PRIME PRIME		방법 방법 방법 전에 가지 않는 것이 같은 것이 같은 것이 없는 것이 없다.
	CASE NUMBER/SPLIT:	7	1.027E-03

DEPENDENCIES:	3 6 7 8	
PEO BRANCHES:	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	
DECORTPTION.	BO HPCS PRIOR RV NO RHR	
CACE/DEANCH CELTT.	1.027E-03 0.000E+00	
CASE/BRANCH SPELLI	110671-03 010070000	
CACE NUMBER /SPLTT.	8 1.487E-02	
CASE NUMBER/ STELLS	3 6 7	
DEPENDENCIES:		
REQ. BRANCHES:		
DESCRIPTION:	SBO HPCS NO RECOV	
CASE/BRANCH SPLIT:	1.186E-02 3.010E-03	
OLOR MUNDED (CDI TT.	0 0 2028 01	
CASE NUMBER/SPLIT	3 0	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:		
REQ. BRANCHES:		
DESCRIPTION:	OTHER TYP NO P.dR	
CASE/BRANCH SPLIT:	2.763E-01 5.287E-02	
CASE NUMBER/SPLIT:	10 0.0005-00	
CASE NIMBER/SPLIT:	0.00000000	
DEPENDENCIES:	3 2	
REQ. BRANCHES:	4 * 1	
	CRIT ATWS INTACT	
CASE/BRANCH SFLIT:	0.000F;+00 0.000E+00	
OLON MUMORD (CDI TO.	11 6 4428 01	
CASE NUMBER/SPLIT:	11 6.447E-01 OTHERWISE S VENTING UNNECESSA	ARY OR
DESCRIPTION:	OTHERWISE S VENTING UNNECESSA 0.000E+00 6.442E-01	ana va
CASE/BRANCH SPLIT:	0.0002+00 0.4422+01	
UNTTANK OUTSTION.	10 PDS PARAMETER 10 LATE IN-VESSEL INJECT & PEDESTAL (CAVITY
O WUDD /TTMPE ACVED.	DEP. INPUT PROB. 53	
BRANCHES:	DDL 1 LING A FROM	
BRANCHEST	1 2	
SELLYNES OF TH.	7.8685-01 2.132E-01	
REALIZED SPLIT	1.0001-01 5.1355-01	
	SUMMARY BY CASE	
CASE NUMBER/SPLIT:	1 1.999E-02	
DEPENDENCIES:	3 6 7 8	
REA RRANCHES.	1 * 1 * 1 * 1	
DI CORIDTION.	SBO NO INJECT PRIOR RV RHR SPRY	
CARD (DDANC) CDI T'F.	1.973E-02 2.679E-04	
CASE/BRANCE SPLIT:	1.2/30-04 4.0/24-04	
CASE NUMBER/SPLIT:	2 4.145E-03	
DEPENDENCIES:		
REQ. BRANCHES:	1 * 1 * 1 * 1	
REQ. BRANCHES:	SBO NO INJECT PRIOR RV VENT	
	4.1342-03 1.119E-05	
CASE/BRANCH SPLIT:	4.1342-03 1.1196-03	
CACE NUMPER (CDI TT.	3 1.156F-02	
DEPENDENCIES:	3 6 7 8	
REQ. BRANCHES:		
	SBO NO INJECT CNTMT LIM RHR_SPRY 3.923E-03 7.639E-03	
CASE/BRANCH SPLIT:	3.4735-03 1.0345-03	

.

1

8

0

4

 $\mathcal{O}\mathcal{O}$

•

ASE NUMBER/SPLIT: DEPENDENCIE:	3	6 7 8
REO. BRANCHES:	1	* 1 * 2 * 3
DESCRIPTION:	SBO	NO INJECT CNTMT LIM NO RHR
CASE/BRANCH SPLIT:		NO INJECT CNTMT LIM NO_RHR 1.683E-03 7.608E-04
CASE NUMBER/SPLIT:	5	9.709E-04 6 7 9
DEPENDENCIES:	3	6 / 9
REQ. BRANCHES:	1	6 7 9 * 1 * 3 * 1
DESCRIPTION:	SBO	NO INJECT NO RECOV VENT 9.090E-04 6.184E-05
CASE/BRANCH SPLIT:		9.090E-04 6.184E-05
CASE NUMBER/SPLIT:	6	1.4822-04 6 7 9
DEPENDENCIES:	3	F 7 9
REQ. BRANCHES:	1	* : * 3 * 2
DESCRIPTION:	SBO	T NO RECOV NO VENT
CASE/BRANCH SPLIT.		1.4822-04 6 7 9 * 3 * 2 * 0.000 NO VENT 1. 04 0.000E+00
CASE NUMBER/SFLIT:	7	5.930E-03 6 7 8 * 2 * 1 * 1 RCIC PRICK RV RHR_SPRY 5.930E-03 0.000E+00
DEPENDENCIES:	3	6 7 8
REQ. BRANCHES:	1	* 2 * 1 * 1
DESCRIPTION:	SBO	RCIC PRICE RV RHR_SPRY
CASE/BRANCH SPLIT:		5.930E-03 0.000E+00
CASE NUMBER/SPLIT:	8	3.479E-04 6 7 9 * 2 * 1 * 1
DEPENDENCIES;	3	6 7 9
REQ. BRANCHES:	1	* 2 * 1 × 1
DESCRIPTION:	SBO	RCIC PRIOR RV VENT
CASE/BRANCH SPLIT:		RCIC PRIOR RV VENT 3.4795-04 0.000E+00
CASE NUMBER/SPLIT:	9	1.771E-02 6 7 * 2 * 2 POIG
DEPENDENCIES:	3	6 7
REQ. BRANCHES:	1	* 2 * 2
DESCRIPTION:	SBO	KCIC UNIMI LIM
CASE/BRANCH SPLIT:		0.000E+00 1.771E-02
CASE NUMBER/SPLIT:	10	2.351E-04
DEPENDENCIES:	3	6 7 9
REQ. BRANCHES:	1	* 2 * 3 *
DESCRIPTION:	SBO	RCIC NO RECOV VL.
COSE/BRANCH SPLIT:		0.COOE+00 2.351E-04
CASE NUMBER/SPLIT:	11	1.054E-03
DEPENDENCIES:	3	6 7 9
REQ. BRANCHES:	1	* 2 * 3 * 2
DESCRIPTION:	SBO	RCIC NO RECOV NO VENT
CASE/BRANCH SPLIT:		0.000E+00 1.054E-03
CASE NUMBER/SPLIT:	12	9.880E-03 6 7 8
DEPENDENCIES		6 7 8
REQ. BRANCHES:	: 1	* 3 * 1 * 1
DESCRIPTION	SBO	HPCS PRIOR RV RHR_SPRY
CASE/BRANCH SPLIT		9.8805-03 0.000E+00

9

13

.

	6	á	ŝ	2	6
NUMBER	1				
	1	ą			ş

CASE NUMBER/SPLIT:	13 1.0275-03	
DEPENDENCIES:	3 6 7 9	
REQ. BRANCHES:	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	
DESCRIPTION .	SEO HPCS PRIOR RV VENT	
CASE/BRANCH SPLIT:	1 027E-03 0.000E+00	
CASE/ DRANOR SPLIT.	1.9272-03 010002100	
CASE NUMBER/SPLIT:	14 1.1868-02	
DEPENDENCIES:	3 6 7 9	
REQ. BRANCHES:	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	
DESCRIPTION:		
CASE/BRANCH SPLIT:	1.0008-02 1.8606-03	
	16 2 0100 02	
CASE NUMBER/SPLIT:	15 3.010E-03 3 6 7 9	
DEPENDENCIES:		
REQ. BRANCHES:		
DESCRIPTION:	SBO HPCS NO RECOV NO VENT	
CASE/BRANCH SPLIT:	2.245E-03 7.645E-04	
CASE NUMBER/SPLIT:	16 0.000E+00	
DEPENDENCIES:	3 5	
REQ. BRANCHES:	1 * 2	
DESCRIPTION:	SBO NOT ISOL	
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00	
CASE NUMBER/SPLIT:	17 3.525E-01	
DEPENDENCIES:		
REQ. BRANCHES:		
DESCRIPTION	'ER TYP RHR SPRY	
CASE/BRANCH SPLIT	3.514E-01 1.093E-03	
CASE/ BRANCH STELL		
CASE NUMBER/SPLIT:	18 2.763E-01	
DEPENDENCIES	9 9	
REQ. BRANCHES:	3 * 1	
DESCRIPTION .	OTHER TYP VENT	
CASE/BRANCH SPLIT:	2.685E-01 7.847E-03	
CASE/ DRANCH STELL		
CASE NUMBER/SPLIT:	19 5.287E-02	
DEPENDENCIES:	3 9	
REQ. BRANCHES:		
REU, BRANCHES:	OTHER TYP NO VENT	
CASE/BRANCH SPLIT:	1.1036-05 5.2006-02	
	20 0.0005.00	
CASE NUMBER/SPLIT:	20 0.0006+00	
DEPENDENCIES:		
REQ. BRANCHES:		
	CRIT ATWS INTACT	
CASE/BRANCH SPLIT:	U.JOOE+00 0.000E+00	
	01 4 4355 00	
CASE NUMBER/SPLIT:		
	3 2	
REQ. BRANCHES:	4 2	
DESCRIPTION:	CRIT ATVS FAILED	
CASE/BRANCH SPLIT:	4.213E-02 2.217E-03	

CASE NUMBER/SPLIT:	22	4.3556-02
DEPENDENCIES: REQ. BRANCHES:	2	
REQ. BRANCHES:	- Z	
		D LOOP & SB 2.089E-02 2.266E-02
CASE/BRANCH SPLIT:		2.0042-02 2.2002-02
CASE NUMBER/SPLIT:		
DEPENDENCIES:	2	이 같은 것 같은
REQ. BRANCHES:		
DESCRIPTION:		
CASE/BRANCH SPLIT:		4.395E-02 9.616E-02
CASE NUMBER/SPLIT:	24	0.000E+00
DESCRIPTION:		OTHERWISE
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00
ATTACT OUPCTION.	11	PDS PARAMETER 11 RPV DEPRESSURIZED DURING CORE DAMAGE
		DEP. INPUT PROB. 76
BRANCHES:		LOW PRES HI PRES
PPALTZED SPITT.		1 2 9.745E-01 2.553E-02
KENLIGED STELL.		
	SUMMAR	Y BY CASE
CASE NUMBER/SPLIT:		
DEPENDENCIES:	3	6 7 9 10
REQ. BRANCHES:	1	* 1 * 1 * 1
		NO INJECT PRIOR RV VENT LAT INJ
CASE/BRANCH SPLIT:		1.922E-03 2.212E-03
CASE NUMBER/SPLIT:	2	1.119E-05
DEPENDENCIES:	3	6 7 9 10
REO. BRANCHES:	1	* 1 * 1 * 1 * 2
DESCRIPTION:	SBO	NO INJECT PRIOR RV VENT NO LT INJ
CASE/BRANCH SPLIT:		1.119E-05 0.000E+00
CASE NUMBER/SPLIT:	3	1.683E-03
DEPENDENCIES:	3	6 7 9 10
REQ. BRANCHES:	1	* 1 * 2 * 1 * 1
DESCRIPTION:	SBU	NO INJECT CNTMT LIM VENT LAT INJ
CASE/BRANCH SPLIT:		3.844E-04 1.299E-03
CASE NUMMER/SFLIT:	4	9.09CE-04
DEPENDENCIES:	3	6 7 9 10
REQ. BRANCHES:	1	* 1 * 3 * 1 * 1
DESCRIPTION:	SBO	NO INJECT NO RECOV VENT LAT INJ
CASE/BRANCH SPLIT:		9.003E-04 8.727E-06
CASE NUMBER/SPLIT:		
DEPENDENCIES:		6 7 9 10
REQ. BRANCHES:		* 1 * 3 * 1 * 2
OESCRIPTION:		NO INJECT NO RECOV VENT NO LT INJ
CASE/BRANCH SPLIT:		6.184E-05 0.000E+00

CASE NUMBER/SPLIT:	6	1.482E-04
the second se	3	6 7 9 10
the second rate of the second ra	1	* 1 * 3 * 2 * 1
DESCRIPTION:		NJ INJECT NO RECOV NO VENT LAT INJ
CASE/BRANCH SPLIT:	000	1.482E-04 0.000E+00
GRODI DIGROCH OF DATE		114020-04 010000100
CASE NUMBER/SPLIT:	7	1.054E-03
	3	6 7 9 10
REQ. BRANCHES:	ĩ	* 2 * 3 * 2 * 2
	SBO	RCIC NO RECOV NO VENT NO LT INJ
CASE/BRANCH SPLIT:	000	0.000E+00 1.054E-03
ONDER DIMENSION DI DI LI I		
CASE NUMBER/SPLIT:	8	1.0002-02
DEPENDENCIES:	3	6 7 9 10
REQ. BRANCHES:	1	* 3 * 3 * 1 * 1
DESCRIPTION:	SBO	HPCS NO RECOV VENT LAT INJ
CASE/BRANCH SPLIT:	500	8.015E-03 1.986E-03
CASE/ DRANCH STLIII		0.0155-05 1.9005-05
CASE NUMBER/SPLIT:	9	1.860E-03
DEPENDENCIES:	3	6 7 9 10
REQ. BRANCHES:	1	* 3 * 3 * 1 * 2
DESCRIPTION:	SBO	HPCS NO RECOV VENT NO LT IN.I
	SDU	1.433E-03 4.270E-04
CASE/BRANCH SPLIT:		1.4336-03 4.2706-04
CASE NUMBER/SPLIT:	10	2.2458-03
DEPENDENCIES:	3	6 7 9 10
REQ. BRANCHES:	í	* 3 * 3 * 2 * 1
DESCRIPTION:	SBO	HPCS NO RECOV NO VENT LAT INJ
CASE/BRANCH SPLIT:	500	2.193E-03 5.210E-05
CASE/ DRANCH SELIT		2.1730-03 3.6100-03
CASE NUMBER/SPLIT:	11	7.646E-04
DEPENDENCIES:	3	6 7 9 10
REQ. BRANCHES:	1	* 3 * 3 * 2 * 2
DESCRIPTION:	SBO	HPCS NO RECOV NO VENT NO LT INJ
CASE/BRANCH SPLIT:		7.6461-04 0.000E+CO
UNDER DIGHTON OF DEET		
CASE NUMBER/SPLIT:	12	6.015E-05
DEPENDENCIES:	3	5 10
REQ. BRANCHES:		* 2 * 1
DESCRIPTION:		NOT ISOL LAT INJ
CASE/BRANCH SPLIT:	500	4.169E-05 1.845E-05
ONDER DIGITION OF DELLI		411070 03 110430 03
CASE NUMBER/SPLIT:	13	7.805E-05
DEPENDENCIES:		5 10
REQ. BRANCHES:		* 2 * 2
DESCRIPTION:	1	NOT ISOL NO LT INJ
CASE/BRANCH SPLIT:		7.8052-05 0.000E+00
oupprovined pretti		
CASE NUMBER/SFLIT:	14	6.730E-02
DEPENDENCIES:		
REQ. BRANCHES:		
DESCRIPTION:		
CASE/BRANCH SPLIT:		6.730E-02 0.000E+00
CHORA DIVISION OF PILL		MIT SVELVE MINVERIUS

]

n

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 8 10 3 * 1 * 1 OTHER TYP RHR_SPRY LAT INJ
	16 2.685E-01 3 8 9 10 3 * 3 * 1 * 1 OTHER TYP NO RHR VENT LAT INJ 2.671E-01 1.342E-03
DESCRIPTION:	17 1.163E-05 3 8 9 10 3 * 3 * 2 * 1 OTHER TYP NO RHR NO VENT LAT INJ 1.163E-05 0.000E+00
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	18 5.286E-02 3 8 9 10 3 * 3 * 2 * 2 OTHER TYP NO RER NO VENT NO Lf IN. 4.892E-02 3.938E-03
REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	19 0.0003+00 3 2 4 * 1 CRIT ATWS INTACT 0.000E+00 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	20 1.341E-02 2 3 8 2 * 4 * 1 FAILED CRIT ATVS RHR SPRY 1.330E-02 1.100E-04
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:	21 3.093E-02 2 3 8 2 * 4 * 3 FAILED CRIT ATWS NO_RHR
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	22 2.089E-02 2 3 10 2 * 5 * 1 FAILED LOOP & SB LAT INJ 2.088E-C2 1.253E-05
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	23 2.266E-02 2 3 10 2 * 5 * 2 FALLED LOOP & SB NO LT INJ 2.013E-02 2.533E-03

d.



CASE NUMBER/SPLIT: DEPENDENCIES:	24 1.490E-01 2 2	
REQ. BRANCHES:	2 + 1	
	FAILED INTACT	
CASE/BRANCH SPLIT:	1.490E-01 0.000E+00	
DESCRIPTION:	25 0.000E+00 OTHERWISE	
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00	
ALLELILL AUDONTON	10 THE LOU BERAURE BUT ENTROPENT ANTELED	
	12 LATE LOW PRESSURE RPV INJECTION AVAILABLE DEP. INPUT PROB. 76	
BRANCHES:		
DRAWONES:	1 2 3	
REALIZED SPLIT:	7.447E-01 2.132E-01 4.213E-02	
THE DECK CONTRACT		
	SUMMARY BY CASE	
	1 2.132E-01	
DEPENDENCIES:		
REQ. BRANCHES:		
DESCRIPTION:		
CASE/BRANCH SPLIT:	0.000E+00 2.132E-01 C.000E+00	
CASE NUMBER. PLYT:	2 4.2156-02	
DEPENDENCIES:	3	
REQ. ERANCHES:		
DESCRIPTION:	CRIT ATWS	
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00 4.213E-02	
CASE NUMBER/SPLIT:	3 7.447E-01	
DEPENDENCIES:		
REQ. BRANCHES: DESCRIPTION:		
CASE/BRANCH SPLIT:	7.447E-01 0.000E+00 0.000E+00	
CAOD/ BIOMON SELLI	1.447E-01 0.000E+00 0.000E+00	
CASE NUMBER/SPLIT:	4 0.000E+00	
DESCRIPTION:		S
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00 0.000E+00	
	AN ANY APPRICATION AND AND AND ALLAS	
	13 RPV DEPRESSURIZED DURING CORE DAMAGE DEP. INPUT PROB. 76	
Q-TYPE/TIMES ASKED:		
BRANCHES:	LOW_PRES HI_PRES	
REALIZED SPLIT:		
REALIZED SELIT:	3.1430-01 E.1330-05	
	SUMMARY BY CASE	
CASE NUMBER/SPLIT:		
DEPENDENCIES:		
REQ. BRANCHES:		

DESCRIPTION:	LOW PRES
	9.745E-C1 0.000E+C0
CASE NUMBER/SPLIT:	2 2.5535-02
DESCRIPTION:	OTHERWISE S RPV HAS NOT BEEN DEPRES
CASE/BRANCH SPLIT:	0.000E+00 2.553E-02
ATTACT OUPOTION	14 DEBRIS MASS MOLTEN AT RPV FAILURS
	DEP. INPUT PROB. 152
FRANCHES:	
, anone ,	1 2
REALIZED SPLIT:	4.228E-02 9.577E-01
	SUMMARY BY CASE
	1 2.304E-01
DEPENDENCIES:	12 13
	2. + 2
DESCRIPTION:	NO_INJECT HI PRES 2.304E-02 2.073E-01
CASE/BRANCH SPLIT:	2.304E-02 2.073E-01
CASE NUMBER / SPLIT:	2 7.696E-01
DESCRIPTION:	OTHERWISE S WATER INJECTION AVAILAB
CASE/BRANCH SPLIT:	1.924E-02 7.504E-01
	15 DEBRIS COOLED IN-VESSEL - INV_COOL
the second	DEP. INPUT PROB. 202
BRANCHES:	
REALIZED SPLIT:	3.467E-01 4.533E-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT:	1 4.213E-02
DEPENDENCIES:	
	3 * 2
	CRITICAL FAILED
CASE/BRANCH SPLIT:	0.000E+00 4.213E-02
CASE NUMBER/CDITT.	2 0.000E+00
DEPENDENCIES:	
REQ. BRANCHES:	
DESCRIPTION:	
CASE BRANCH SPLIT:	
Onothin breation of barri	
	3 1.838E-02
	12 13 14
	1 * 1 * 1
	WATER INJ LOW PRES LG DEB
CASE/BRANCH SPLIT:	9.189Ē-03 9.189Ē-03
	7 1670 01
CASE NUMBER/SPLIT:	4 7.167E-01

	12 13 14 1 * 1 * 2 WATER_INJ LOW PRES SM DEB 5.375E-01 1.792E-01
	5 2.228E-01 OTHERWISE \$ ALL OTHER CASES 0.000E+00 2.228E-01
	16 HYDROGEN IGNITION SYSTEM AVAILABLE DEP. INPUT PROB. HIS_OFP HIS_ON 1 2 1.382E-01 8.618E-01
	SUMMARY BY CASE
REQ, BRANCHES: DESCRIPTION:	
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	2 1.339E-01 OTHERWISE \$ LOSS OF AC POWER 1.339E-01 0.000E+00
******* QUESTION: Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT:	ISOLATED NOT_ISOL 1 2
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 9.997E-01 5 1 ISOLATIZE 9.997E-01 0.000E+00
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	2 3.161E-04 OTHERWISE SBO WITH CNTMT VENT NOT 0.000E+00 3.161E-04
******* QUESTION: Q-TYPF/TIMES ASKED: BRANCHES:	18 MODE OF RHR SPRAY OPERATION EARLY DEP. INPUT PROB. CONTROLD SPRAY NO SPRAY 1 2 3
REALIZED SPLIT:	0.000E+00 4.017E-01 5.983E-01

SUMMARY BY CASE

CASE NUMBER/SPLIT:	1	5.703E-01
DEPENDENCIES:	8	
REQ. BRANCHES:		
DESCRIPTION:		NRV
CASE/BRANCH SPLIT:	/ KIIK_SI	0.000E+00 0.000E+00 5.703E-01
CASE/BRANCH SPLIT:		0.0006+00 0.0002+00 2.7036-01
CACE NUMBER / SPLIT.	2	2 7948-02
CASE NUMBER/SPLIT: DEPENDENCIES:	2	7
REQ. BRANCHES:		* /1
	c 10.0	(PPTOP BY
DESCRIPTION:	SBU	/PRIOR RV 0.000E+00 0.000E+00 2.794E-02
CASE/BRANCH SPLIT:		0.0006+00 0.0006+00 2.7946-02
CASE NUMBER/SPLIT:	3	3.6595-01
DEPENDENCIEC.	2	8
DEPENDENCIES:	19	
REQ. BRANCHES:		
DESCRIPTION:	/SBO	RHR SPRY
CASE/BRANCH SPLIT:		0.000E+00 3.659E-01 0.000E+00
CASE NUMBER/SPLIT:	4	3.580E-02
DEPENDENCIES:	3	7 8
REQ. BRANCHES:	1	
REU. DRANCHES;	CRO	DETAD DU DUD COBV
DESCRIPTION:	SBU	PRIOR RV RHR SPRY
CASE/BRANCH SPLIT:		0.000E+00 3.580E-02 0.000E+00
CASE NUMBER/SPLIT:	5	0.000E+00
DESCRIPTION:		
		0.000Z+00 0.000E+0C 0.000E+00
UNDER DIGHTEN OF BLUE		
		사람이 지도 그 가장 공격을 알려야 한 것은 것 같 것 같 것 같 것 같 것 같 것 같 것 같 것 같 것 같
******* QUESTION:	19	CONTAINMENT STEAM CONCENTRATION BEFORE RPV FAILURE
Q-TYPE/TIMES ASKED:		DEP. INPUT PROB. 270
BRANCHES:		0-15% 15-25% 25-35% 35-45% 45-55% > 55
		1 2 3 4 5 6
REALIZED SPLIT:		7.502E-01 9.865E-03 9.478E-03 0.000E+00 0.000E+00 2.305
	SUMMA	RY BY CASE
CASE NUMBER/SPLIT:	1	4.017E-01
DEPENDENCIES:		4.01.0.V
REQ. BRANCHES:		
DESCRIPTION:		
CASE/BRANCH SPLIT:		4.017E-01 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000
CASE NUMBER/SPLIT:	2	1.927E-02
DEPENDENCIES:		6
REO. BRANCHES:		* 1
DESCRIPTION:		NO INJECT
		1.927E-02 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000
CASE/BRANCH SPLIT:		1.9276-02 0.0006+00 0.0006+00 0.0006+00 0.0006+00 0.000
CASE NUMBER/SPLIT	3	1.934E-02
DEPENDENCIES		6
REQ. BRANCHES		* 2
NEW? DIGINOTED		이 방법 수 있는 것 같은 것 같아요. 그는 것 같아요. 그는 것 같아요. 가지 않는 것 같아요.

4

T

ł

en 1

DESCRIPTION: CASE/BRANCH SPLIT:			9.865E-03	9.478E-03	0.000E+00	0.000E+00 0.000
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	3 1	6 * 3 HPCS				
CASE/BRANCH SFLIT:		0.000F+00	0.000E~00	0.000E+00	0.000E+00	0.000E+00 1.590
DESCRIPTION:	2 2 FAIL	ED				
CASE/BRANCH SPLIT:		0.00UE+00	0.000E+00	0.000E+00	0.000E+00	0.000E+00 2.146
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:		OTHERWISE				
******* QUESTION: Q-TYPE'TIMES ASKED: BRANCHES:		DEP. INPUT PH	ROB. 22%	11%		
REALIZED SPLIT:						
	SUMMA	RY BY CASE				
CASE NUMBER/SPLIT:	1	3.926E-02				
DEPENDENCIES: REQ. BRANCHES:	3	+ 1				
REQ. BRANCHES: DESCRIPTION:	SBO	NO TRUE	CT			
CASE/BRANCH SPLIT:		0.000E+00	0.000E+00	3.926E-02		
CASE NUMBER/SPLIT:	2	2.527E-02				
DEPENDENCIES:	3	6				
REQ. BRANCEES:						
DESCRIPTION:						
CASE/BRANCH SPLIT:		0.000E+00	3.285E-03	2.199E-02		
CASE NUMBER/SPLIT:	3	2.378E-02				
DEPENDENCIES:						
REQ. BRANCHES:		* 3				
DESCRIPTION:		HPCS				
CASE/BRANCH SPLIT:		0.000E+00	0.0002+00	2.578E-02		
CASE NUMBER/SPLIT:	4	9.097E-01				
DESCRIPTION:					S BOUND O	THERS WITH DISTR
CASE/BRANCH SPLIT:			1.183E-01	7.914E-01		
	21	SMALL HYDROG	EN BURNE A	T 100 82 0	ONCENTRATI	ON
******** QUESTION: Q-TYPE/TIMES ASKED: BRANCHES:		DEP. INPUT P			OHOTHI CALL	546

REALIZED SPLIT:	1 2 3.042F-01 6.958E-01	•
	SUMMARY BY CASE	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	19 6	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	2 6.916E-01 16 2 HIS ON	
CASE/BRANCH SPLIT:		
DEPENDENCIES: REQ. BRANCHES:		
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	3 7 1 * 1 SBO PRICR RV	
	5 3.412E-02 3 7 1 * /1 SBO /PRIOR RV	
	6 0.000E+00	S SHOULD NEVER GO THIS PA
******** OUESTION: Q-TYPE/TIMES ASKED: BRANCHES:	22 LARGE H2 BUKN DURING CORE DAMAGE DEP. INPUT PROB. INPUT PARM. MO_BURN LG_BURN 1 2	761
REALIZED SPLIT:	9.790E-01 2.098E-02	
	SUMMARY BY CASL	
CASE NUMBER/SFLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	2 FAILED	•

		a second second	
CASE NUMBER/SPLIT:		6.824E-01	
DEPENDENCIES:	21		
	2		
DESCRIPTION:		RN	
CASE/BRANCH SPLIT:	STITLED_D		0.000E+00
CADE/ DRAHOH STELL.		010240-01	010000100
CACU NUMPER (CDI TT.		1.590E-02	
CASE NUMBER/SPLIT:	3	1.3906-02	
	19		
REQ. BRANCHES:			
DESCRIPTION:	> 55%		
CASE/BRANCH SPLIT:		1.590E-02	0.000E+00
CASE NUMBER/SPLIT:	4	0.000E+00	
DEPENDENCIES:	19	20	
REQ. BRANCHES:	1	* 1	
DESCRIPTION:			
CASE/BRANCH SPLIT:			0.000E+00
CASE NUMBER/SPLIT:	5	8.2081-04	
DEPENDENCIES:	19	20	
REQ. BRANCHES:			
DESCRIPTION:		22%	
	0-12%		
CASE/BRANCE SPLIT:		4.254E-04	4.2545-04
CASE NUMBER/SPLIT:		5.3483-02	
DEPENDENCIES:	10	20	
REQ. BRANCHES:		* 3	
DESCRIPTION:	0-15%	11%	
CASE/BRAMCH SPLIT:		3.850E-02	1.497E-02
		0.0005.00	
CASE NUMBER/SPLIT:	/	0.0005+00	
DEPENDENCIES:	19	20	
REQ. BRANCHES:	2	* 1	
DESCRIPTION:	15-25%	33%	
CASE/BRANCH SPLIT:		G.000E+00	0.000E+00
CASE NUMBER/SPLIT:	8	1.282E-03	
DEPENDENCIES:	19	20	
REO. BRANCHES:	2	* 2	
DESCRIPTION:	15-25%	2.2%	
CASE/BRANCH SPLIT:			6.408E-04
GROD/ DRAHOH DI HILL		0.4001.04	014002 04
CASE NUMBER/SPLIT:	9	6.576E-03	
DEPENDENCIES:	19	20	
	2	* 3	
REQ. BRANCHES:	the second second		
DESCRIPTION:	15-25%	11%	0 1015 00
CASE/BRANCH SPLIT:		6.175E-03	2.401E-03
CASE NUMBER/SPLIT:	10	0.000E+00	
DEPENDENCIES:		20	
	3	* 1	
REQ. BRANCHES:		228	
DESCRIPTION:	22-32%		0.0005.00
CASE/BRANCH SPLIT:		0.0008+00	0,000E+00

CASE NUMBER/SPLIT: DEFENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	11 1.231E-03 19 20 3 * 2 25-35% 22% 7.511E-04 4.802E-04
CASE NUMBER/SPLIT:	12 8.240E-03
DEPENDENCIES:	19 20
REQ. BRANCHES:	3 * 3
DESCRIPTION:	25-35% 11%
CASE/BRANCH SPLIT:	3 * 3 25-35% 11% 6.180E-03 2.060E-03
CAGE NUMBER/SPLIT:	13 0.000E+00
CAGE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:	19 20
REQ. BRANCHES:	4 * 1
DESCRIPTION:	33-45% 33%
CASE/BRANCH SPLIT:	0.0001+00 0.000E+00
CASE NUMBER/SPLIT:	14 0.000E+00
DEPENDENCIES:	19 20
REO. BRANCHES:	4 * 2
DESCRIPTION:	35-45% 22%
CASE/BRANCH SPLIT:	
	15 0.000E+00
DEPENDENCIES:	19 20
REQ. BRANCHES:	
DESCRIPTION:	35-45% 11%
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00
CASE NUMBER/SPLIT:	16 0.000E+00
DEPENDENCIES: REQ. BRANCHES:	5 * 1
DESCRIPTION:	45-55% 33%
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00
CASE NUMBER/SPLIT:	17 0.000E+00
DEPENDENCIES:	
REQ. BRANCHES:	5 * 2
	45-55% 22%
CASE/BRANCH SPLIT:	
CASE NUMBER/SPLIT:	18 0.000E+00
DEPENDENCIES:	19 20
REQ. BRANCHES:	5 * 3
DESCRIPTION:	
CASE/BRANCH SPLIT.	
CASE NUMBER/SPLIT:	19 0.000E+00
DESCRIPTION:	
CASE/BRANCH SPLIT:	

S SHOULD NEVER GO THIS PA

T

.

-

******* QUESTION: 23 H2 DETONATION CONTAINMENT FAILURE

Q-TYPE/TIMES ASKED: BRANCHES:	DEP. INPUT PROB. DET_CF NO 1 2	806
REALIZED SPLIT:	1.195E-04 9.999E-01	
	SUMMARY BY CASE	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCE SPLIT:	22 1	
CASE NUMBER/SFLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	35-45% 45-55% > 55%	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3	
		7 18 6 1 * 2 * /1 PRIOR RV SPRAY /NO INJECT
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	19 20 3 * 2	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	$\begin{pmatrix} 1 & + & 2 \end{pmatrix} * & 2 \\ 0-15\% & 15-25\% & 22\% \end{pmatrix}$	
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	1 * 1 * 1 *	PRIOR RV SPRAY /NO INJECT
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:		

CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	19 20 3 * 1 25-35% 33% 0.COOE+00 0.000E+00	s
Q-TYPE/TIMES ASKED: BRANCHES:	DEP. CALC. PROB. 824	
REALIZED SPLIT:	2.295F-01 7.705E-01	
	SUMMARY BY CASE	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	2 2	
CASE/BRANCH SPLIT:		
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1)
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	3 7.719E-01 OTHERWISE \$ CONTAINMENT INTACT PRI 3.417E-03 7.705E-01	0]
Q-TYPE/TIMES ASKED: BRANCHES:	1 2	
REALIZED SPLIT:		
	SUMMARY BY CASE	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	2 FAILED	
CASE NUMBER/SPLIT: WEPENDENCIES: REQ. BRANCHES:)

DESCRIPTION: CASE/BRANCH SPLIT:	DET_CF 0.000E+00 1.195E-04
CASE NUMBER/SPLIT: DEPENDENCIES:	3 7.705E-01 24
PEO. BRANCHES:	2
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.0008400 7.7038-01
CASE NUMBER/SPLIT:	4 1.417E-03
DESCRIPTION:	OTHERWISE S CONTAINMENT FAILED BY H. 5.686E-04 8.486E-04
CASE / BRANCH SPLIT:	3.0002-04 0.4002-04
******* OUESTION:	26 CNTMT FAILURE BEFORE RPV FAILURE IMPACT ON ECCS INJECTION /
Q-TYPE/TIMES ASKED:	
BRANCHES:	NO_FAILUR FAILUR
PEALTZED SPITT.	9.935E-01 6.499E-03
NERELEED SEELL	
	SUMMARY BY CASE
CASE NUMBER/SPLIT:	1 7.221E-03
DEPENDENCIES:	25 2 3
	1 *(1 + 4) ANCHORAGE INTACT CRIT ATWS
	7.221E-04 6.499E-03
CASE NUMBER/SPLIT: DESCRIPTION:	2 9.928E-01 OTHERWISE \$ - NOT ANCHORAGE CNTMT
CASE/BRANCH SPLIT:	9.928E-01 0.000E+00
	회사님, 영상, 영국, 영국, 영국, 영국, 영국, 영국, 영국, 영국, 영국, 영국
******* QUESTION:	27 CNTMT FAILURE BEFORE RPV FAILURE IMPACT ON ECCS INJECTION
Q-TYPE/TIMES ASKED:	DEP. INPUT PROB. 1763
	DEP. INPUT PROB. 1763 NO FAILUR FAILUR
Q-TYPE/TIMES ASKED: BRANCHES:	DEP. INPUT PROB. 1763
Q-TYPE/TIMES ASKED: BRANCHES:	DEP. INPUT PROB. 1763 NO_FAILUR FAILUR 1 2 9.654E-01 3.462E-02
Q-TYPE/TIMES ASKED: BRANCHES:	DEP. INPUT PROB. 1763 NO_FAILUR FAILUR 1 2
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT:	DEP. INPUT PROB. 1763 NO_FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT:	DEP. INPUT PROB. 1763 NO_FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:	DEP. INPUT PROB. NO_FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 + 4)
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	DEP. INPUT PROB. 1763 NO_FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	DEP. INPUT PROB. NO FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 + 4) FAILURE NO FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES:	DEP. INPUT PPOB. NO FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 + 4) FAILURE NO FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02 2 2.966E-01 9 5
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:	DEP. INPUT PPOB. NO_FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 + 4) FAILURE NO_FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02 2 2.966E-01 9 5 1 + 2
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	DEP. INPUT PROB. NO FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 + 4) FAILURE NO FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02 2 2.906E-01 9 5 1 + 2 VENT NOT ISOL
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	DEP. INPUT PROB. NO FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 * 4) FAILURE NO FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02 2 2.906E-01 9 5 1 * 2 VENT NOT ISOL 2.837E-01 1.493E-02
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	DEP. INPUT PROB. NO FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 + 4) FAILURE NO FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02 2 2.906E-01 9 5 1 + 2 VENT NOT ISOL
Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	DEP. INPUT PROB. NO FAILUR FAILUR 1 2 9.654E-01 3.462E-02 SUMMARY BY CASE 1 3.938E-02 24 26 2 3 1 * 1 *(1 * 4) FAILURE NO FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02 2 2.906E-01 9 5 1 * 2 VENT NOT ISOL 2.837E-01 1.493E-02

	OTHERWISE 6.620E-01 0.000E+00 \$ NO CF, NO VENTING AND 6.620E-01 0.000E+00
Q-TYPE/TIMES ASKED: BRANCHES:	1 2
REALIZED SPLIT:	9.504E-01 4.955E-02
	SUMMARY BY CASE
REQ. BRANCHES: DESULIDITION:	1 3.938E-02 24 26 2 3 1 * 1 *(1 4) FAILURE NO FAILUR INTACT CRIT ATWS 1.969E-02 1.969E-02
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	VENT NOT ISOL
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	OTHERWISE S NO CF, NO VENTING AND N
	29 INJECT & SPRAY FAILURE DUE TO CONTAINMENT FAILURE BEFORE R DEP. INPUT PROB. 2935 NO_FAILUR INJ&SFY_F
REALIZED SPLIT:	9.822E-01 1.784E-02
	SUMMARY BY CASE
CASE JUMBER/SPLIT: DEPENDENCIES: REQ. BRANGHES: DESCRIPTION: CASE/BRANCH SPLIT:	2
DEPENDENCIES: REQ. BRANCHES:	2 1.134E-02 27 28 2 * 2 FAILUR FAILUR 0.000E+00 1.134E-02
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	

	이 가지 못했다. 정말 것 같은 것이 같은 것이 같은 것이 같은 것이 같이 많이 많이 많이 많이 많이 많이 없다.
******* GUESTION:	30 ALPHA MODE TEAM EXPLOSION DRYWELL AND CONTAINMENT FAILURE
Q-TYPE/TIMES ASKED:	DEP. INPUT PROB. 4379
BRANCHES:	ALPHA NO ALPHA
	1 2
REALIZED SPLIT:	9.770E-03 9.902E-01
	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
	SUMMARY BY CASE
CASE NUMBER/SPLIT:	1 9.745E-01
DEPENDENCIES:	13
REQ. BRANCHES:	
DESCRIPTION:	LOW PRES
CASE/BRANCH SPLIT:	9.745E-03 9.647E-01
CASE NUMBER/SFLIT:	2 2.553E-02
DESCRIPTION:	OTHERWISE \$ REACTOR VESSEL NOT DEPR
CASE/BRANCH SPLIT:	2.546E-05 2.550E-02
	그 같은 것 같은 것 같은 것이 같아. 동안 같은 것 같은 것 같은 것 같은 것 같이 있다.
	이 같은 것은 것은 것 같아요. 정말 것 같은 것 같은 것 것 같은 것이다. 것
****** QUESTION:	31 MODE OF IN-VESSEL STEAM EXPLOSION BOTTOM HEAD FAILURE
Q-TYPE/TIMES ASKED:	DEP. INPUT PROB. 7864
BRANCHES:	
	1 2 3 4
REALIZED SPLIT:	9.770E-03 9.322E-01 3.290E-02 2.516E-02
	방법을 통하는 것은 것은 것은 것을 것을 것을 위해 전체에 가지 않는 것을 했다.
	SUMMARY BY CASE
	1 9.770E-03
DEPENDENCIES:	
REG. BRANCHES:	
DESCRIPTION:	
CASE/BRANCH SPLIT:	9.770E-03 0.000E+00 0.000E+00 0.000E+00
	2 9.647F-01
DEPENDENCIES:	
REQ. BRANCHES:	1
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.000E+00 9.069E-01 3.280E-02 2.508E-02
	a
	3 2.550E-02
	OTHERWISZ S NO ALPHA FAILURE & RPV 1
CASE/BRANCH SPLIT:	0.000E+00 2.532E-02 1.019E-04 7.643E-05
+++++++ OURCTION.	32 RFV FAILURE MODE AND SIZE J. RPV FAILURE
Q-TYPE/TIMES ASKED:	
Q-IIPE/IIMES ASKED: BRANCHES:	
DRANCHES:	1 $2$ $3$
REALIZED SPLIT:	the second se
REALIGED SPLIT:	A'110P-02 2'010P-01 1'220P-01 4'012P-01
	SUMMARY BY CASE
	Symmetry D1 0400
CASE NUMBER/SPLIT:	1 0 7705-03
OUSP HOUDPUL SERTI:	
DEPENDENCIES:	

REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	31 3
CASE NUMBER/SPLIT:	31 4
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	15 29
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	5 4.2460-01 OTHERWISE \$ CORE DPREIS CAUSES LOWE 0.000E+00 0.000E+00 4.246E-02 3.821E-01
Q-TYPE/TIMES ASKED: BRANCHES:	33 WATER IN PEDESTAL AT RPV FAILURE DEP. INPUT PROB. FLD+INJ RPV+INJ FLD RPV WTR 1 2 3 4 3.3185-02 7.371E-01 3.460E-03 2.262E-01
CONTRACTOR OF STATES	SUMMARY BY CASE
DEPENDENCIES: REQ. BRANCHES:	1 3.318E-02 12 29 22 3 6 /2 * 1 *( 2 +( 1 * 3)) /NO_INJECT NO FAILUR LG BURN SBO HPCS 3.318E-02 0.000E+00 0.000E+00 0.000E+00
DEPENDENCIES: REQ. BRANCHES:	2 3.46CE-03 ?9 22 3 6 2 * 7 +( 1 * 3) INJ&SPY_F LG BURN SB0 HPCS 0.000E+00 0.000E+C0 3.460E-03 0.000E+00
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	3 7.371E-01 12 29 /2 * 1 /NO INJECT NO FAILUR
	0.000F+00 7.371E-01 0.000E+00 0.000E+00
CASE NUMBER/SPLIT	: 4 2.262E-01

DESCRIPTION: CASE/BRANCH SPLIT:	OTHERWISE \$ RESIDUAL RV WATER ONLY 0.000E+00 0.000E+00 0.000E+00 2.262E-01
-TYPE/TIMES ASKED:	34 PEDESTAL FAILURE DUE TO OVERPRESSURE AT RPV FAILURE DEP. INPUT PROB. 9763 PED_FAIL NO 1 2
REALIZED SPLIT:	7.859E-03 9.921E-01
S	UMMARY BY CASE
CA & NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	32 2
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIFTION: CASE/BRANCH SPLIT:	2 3.468E-03 13 33 33 2 *( 1 + 3) HI_PRES FLD+INJ FLD 3.468E-03 0.000E+00
CASE NU JER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 2.2762.03 13 33 33 32 2 *( 2 + 4) * 3 HI_PPES RPV+1NJ RPV VTR LARGE_VF 2.276E-03 0.000E+00
REQ. BRANCHES: DESCRIPTION:	4 1.9763-02 13 33 33 32 2 *( 2 + 4) * 4 HI_PRES RPV+INJ RPV WTR SMALL_VF 0.000E+00 1.976E-02
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	5 2.115E-03 13 33 33 32 1 *( 1 + 3) * 3 LOW_PRES FLD+INJ FLD LARGE_VF 2.115E-03 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REO. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	13 1
	7 2.201E-05 OTHERWISE \$ SHOULD NEVER GO THIS 0.000E+00 2.201E-05

F

******* QUESTION: 35 PEDESTAL CAVITY STEAM EXPLOSTION

Q-TYPE/TIMES ASKED: BRANCHES:	DEP. INPUT PROB. STM_EXP NO_EXP	10634
REALIZED SPLIT:	1.154E-02 9.885E-01	
	SUMMARY BY CASE	
CASE NUMBER/SPLIT: DEFENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	32 2	
DESCRIPTION:	2 4.766E-01 33 33 2 4 4 RPV+INJ RPV WTR 0.000E+00 4.766E-01	
DEPENDENCIES:		
DESCRIPTION:	4 1.342E-02 OTHERWISE 1.154E-02 1.879E-03	S WATER IN CAVITY
	1 2	TEAM EXPLOSION 12283
	SUMMARY BY CASE	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 LARGE_VF	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	2	
CASE/BRANCH SPLIT:	The second secon	
	3 1.154E-02 OTHERWISE 5.770L 04 1.097E-02	\$ EX-VESSEL STEAM EXP

	37 DRYWELL FAILURE DUE TO PEDESTAL FAILURE DEP. INPUT PROB. DW_FAIL NO 1 2
REALIZED SPLIT:	1.719E-03 9.983E-01
	SUMMARY BY CASE
OLOD MUMBER (ADI TR	1 0 0000 00
CASE NUMBER/SPLIT: DEPENDENCIES:	
REQ. BRANCHES:	
CASE/BRANCH SPLIT:	PED_FAIL PED_FAIL 1.719E-03 8.109E-03
CASE/ DRANCH SELIT	1.7196-03 0.1096-03
CASE NUMBER/SPLIT:	2 9.902E-01
DESCRIPTION:	OTHERWISE S PEDESTAL FAILURE HAS NO
	0.000E+00 9.902E-01
	30 SEWIELL WITERERADER ELTIVER IN SEU ELTIDE
	38 DRYWELL OVERPRESSURE FAILURE AT RPV FAILURE DEP. INPUT PROB. 15272
Q-TIPE/TIMES ASKED: BRANCHES:	
BRANCHES:	1 2
REALTZED SPLIT:	2.612E-05 1.000E+00
THETHER DECK OF ALL &	
	SUMMARY BY CASE
CASE NUMBER/SPLIT:	1 5.076E-01
DEPENDENCIES:	32
REQ. BRANCHES:	2
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.000E+00 5.076E-01
CLOP NUMBER (CDI TT.	2 2 62/5 02
CASE NUMBER/SPLIT:	13 32
REQ. BRANCHES:	
REV. BRANCHES:	HI PRES LARGE VF
CASE/BRANCH SPLIT:	2.612E-05 2.607E-03
UNDER DIANON OF DEER	
CASE NUMBER 'SPLIT:	3 4.898E-01
DESCRIPTION:	OTHERWISE
CASE/BRANCH SPLIT:	0.000E+00 4.898E-01
	DO DEVELOU NATIO AT AVEAD TIME OF DEV FATLIDE
	39 DRYWELL FAILS AT/NEAR TIME OF RPV FAILURE DEP. INPUT PROB. 15272
Q-TYPE/TIMES ASKED: BRANCHES:	state i atte bit strept
BRANCHESI	1 2
DEALTZED COLTT.	1.151E-02 9.885E-01
REMAINED DIFTI:	
	SUMMARY BY CASE
CASE NUMBER/SPLIT:	1 5.076E-01

DEPENDENCIES:	100 CT						
REQ. BRANCHES:	2						
DESCRIPTION:	NO_FAIL						-
CASE/BRANCH SPLIT:		0.000E+00 !	5.076E-01				
CASE NUMBER/SPLIT:	2	1.1512-02					
DEPENDENCIES:		37	38				
REQ. BRANCHES:	1 +	1 +	1				
DESCRIPTION:		DW FAIL					
CASE/BRANCH SPLIT:		1.15ĨE-02	0.000E+00				
CASE NUMBER/SPLIT:							
DESCRIPTION:					\$ NO DRYWE	ELL FAILURE	
CASE/BRANCH SPLIT:		0.000F+00	4.809E-01				
****	10 000	IT A TABLES IS	TRAN CONT	APPEN APPEND	T (NEW) D D D	. PARLING	
******* QUESTION: O-TYPE/TIMES ASKED:		TAINMENT S P. INPUT PR		INTRATION A	SITNEAR RPV	7 FAILURE 18163	
Q-TYPE/TIMES ASKED: BRANCHES:	DEI	0-15%		25-35%	35 / 58	45-55%	> 55
DRANCHES!			2	22-35%	30-40%	40-00% 5	6
REALIZED SPLIT:		7.5025-01		and the second se		the second s	
	SUMMARY H	BY CASE					
CASE NUMBER/SPLIT:	1	4.017E-01					
	18	TOTIE-OI					
	2						6
DESCRIPTION:							
CASE/BRANCH SPLIT:		4.017E-01	0,000E+00	0.000E+00	0.000E+00	0.000E+00	0.000
CASE NUMBER/SPLIT:	2	1.927E-02					
DEPENDENCIES:	3	6					
REQ. BRANCHES:	1	* 1					
DESCRIPTION:	SBO	NO INJEC				0.000	
CASE/BRANCH SPLIT:		1.9271-02	0.000E+00	0.000E+00	0.000E+00	0.000E+00	0.000
CASE NUMBER/SPLIT:	3	1.934E-02					
DEPENDENCIES:	3	6					
REQ. BRANCHES:		* 2					
DESCRIPTION:		RCIC			a sector de		
CASE/BRANCH SPLIT:		0.000E+00	8.510E-03	1.083E-02	0.000E+00	0.000E+00	0.000:
CASE NUMBER/SPLIT:	4	1.590F-02					
DEPENDENCIES:		6					
REQ. BRANCHES:		* 3					
DESCRIPTION:		HPCS		1.1.2.4			
CASE/BRANCH SPLIT:		0,000E+00	0.000E+00	0.000E+0(	0.000E+00	0.000E+0(	1.590
CASE NUMBER/SPLIT:	5	2.146E-01					
DEPENDENCIES:							
REQ. BRANCHES:	2						
DESCRIPTION							(A)
CASE/BRANCH SPLIT:		0.000E+00	0.000E+00	0.000E+00	0 0.000E+00	0 0.000E+00	0 2006

CASE NUMBER/SPLIT:	6	3.292E-01
DESCRIPTION:		OTHERVISE \$ OTHER NON-SBO TYPE EVEN
CASE/BRANCH SPLIT:		3.292E-01 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000
******* OUESTION:	45	FRACTION ZIRCONIUM INVENTORY REACTED AT/NEAR RPV FAILURE
O-TYPE/TIMES ASKED:		DEF. INPUT PROB. 28853
BRANCHES:		33% 22% 11%
		1 2 3
REALIZED SPLIT:		0.000E+00 2.953E-01 7.048E-01
	STMMA	RY BY CASE
		알 가장 이 것 같은 것
CASE NUMBER/SPLIT:	1	3.926E-02
DEPENDENCIES: REQ. BRANCHES:	3	
REQ. BRANCHES:	000	* I
CASE / BRANCH CRITT.	580	NO INJECT 0.000E+00 0.000E+00 3.926E-02
CASE/ DRANCH SPLIT:		0,0000000 0,000000 0,0000002
CASE NUMBER/SPLIT:	2	2.527E-02
DEPENDENCIES:	3	6
REQ. BRANCHES:	1	* 2
DESCRIPTION:	SBO	RCIC
CASE/BRANCH SPLIT:		0.000E+00 7.833E-03 1.744E-02
CASE NUMBER/SPLIT:	3	2.578E-02
DEPENDENCIES:	3	6
REQ. BRANCHES:	1	* 3
DESCRIPTION:	SBO	HPCS
CASE/BRANCH SPLIT:		0.000E+00 5.4°3E-03 2.037E-02
CASE NUMBER/SPLIT:	4	9.0978-01
DESCRIPTION:		OTHERWISE \$ BOUND OTHERS WITH DISTR
CASE/BRANCH SPLIT:		0.000Z+00 2.820E-01 6.277E-01
		이 것 같은 것 같은 것 같은 것 것 같은 것 같은 것 같은 것 같은 것
******* OURCTION.	1.2	HYDROGEN IGNITION SOURCES AVAILABLE AT/BEFORE RPV FAILURE
Q-TYPE/TIMES ASKED:		
BRANCHES:		NO IG SRC IGNIT SRC
		1 2
REALIZED SPLIT:		1.120E-01 8.881E-01
		ANY NY CLOS
	SUMM	ARY BY CASE
CASE NUMBER/SPLIT:	1	8.618E-01
DEPENDENCIES:		
REQ. BRANCHES:		
DESCRIPTION:		
CASE/BRANCH SPLIT:		0.000E+60 8.618E-01
CASE NUMBER/SPLIT:	2	4.328E-03
DEPENDENCIES:	16	3 3
REQ. BRANCHES:	1	* /1 * /5
DESCRIPTION:	HIS	OFF /SBO /LOOP & SB

10 **B** 

C	ASE/BRANCH SPLIT:	4.3205-04 3.896E-03	•
С	DEPENDENCIES:	3 2.2332-02 21 22 2 + 2 SMALL BRN LG BURN	
¢	ASE/BRANCH SPLIT:	0.000E+00 2.233E-02	
	DESCRIPTION:	4 1.115E-01 OTHERVISE 1.115F-01 0 000E+00	\$ NO CONTINUOUS IGNITION
		43 HIGH PRESSURE MELT EJECTION AT DEP. INPUT PROB. HPME NO_HPME 1 2	RPV FAILURE 35093
	REALIZED SPLIT:	2.042E-02 9.796E-01	
		SUMMARY BY CASE	
1	INRER/SPLIT:	1 5.076E-01	
	DEPENDENCIES:		
	REQ. BRANCHES:		
	DESCRIPTION:	NO FAIL	
C	ASE/BRANCH SPLIT:	- 0.000E+00 5.076E-01	•
C	ASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:		•
	DESCRIPTION:		
C	CASE/BRANCH SPLIT:		
(	ASE NUMBER/SPLIT:	3 2.5528-02	
	DESCRIPTION:	OTHERWISE	S RPV FAILURE AT HIGH PRE
(	CASE/BRANCH SPLIT:	2.042E-02 5.104E-03	
**	****** QUESTION:	44 LARGE H2 BURN IGNITED AT/NEAR B	RPV FAILURE
Q-	TYPE/TIMES ASKED: BRANCHES:	DEP. INPUT PROB. INPUT PARM. NO_BRN_IG LG_BRN_IG	37679
	REALIZED SPLIT:	9.655E-01 3.453E-02	
		SUMMARY BY CASF	
	CASE NUMBER/SPLIT:	1 8.8802-01	
	DEPENDENCIES:		
	REQ. BRANCHES:		
	DESCRIPTION:		
(	CASE/BRANCH SPLIT:	100	
1	CASE NUMBER/SPLIT:	2 5.954E-02	
	DEPENDENCIES:		

REQ. BRANCHES:	6		
DESCRIPTION:	> 55%		
CASE/BRANCH SPLIT:		5.954E-02 0.000E+00	
CASE NUMBER/SPL11:	10	0.000E+00 41 39 1 *( 1 +	7
DEPENDENCIES:	40	41 59	15
REQ. BRANCHES:	1 *	1 *( 1 *	1)
DESCRIPTION:	0-15%	33% DW FAIL	PRIOR KV
CASE/BRANCH SPLIT:		0.0005+00 0.000E+00	
CASE NUMBER/SPLIT:	4	0.000E+00	
DEPENDENCIES	40	0.000E+00 41 43	
PEO BRANCHES:	1 *	41 43 1 * 1 33% HPME	
DESCRIPTION.	0-15%	332 HPME	
CACE (BRANCH CRITT:	0-194	0.000E+00 0.000E+00	
CASE/BRANCH SPLIT:		0.0000000 0.0000000	
CASE NUMBER/SPLIT:	5	0.000E+00	
DEPENDENCIES · REQ. BRANCHES :	40	41	
REO. BRANCHES:	1 *	1	
DESCRIPTION:	0-152	3.3%	
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00	
CASE NUMBER/SPLIT:			
CASE NUMBER/SPLIT:	0	0.000000000	7
DEPENDENCIES:	40	41 39 * 1 *( 1 +	12
REQ. BRANCHES:	2	* 1 *( 1 +	1)
DESCRIPTION:	15-25%	33% DW FAIL	PRIOR RV
CASE/BRANCH SPLIT:		0.000E+30 0.000E+00	
CASE NUMBER/SPLIT:	7	0.000F+00	
DEPENDENCIES:	40	41 43 * 1 * 1	
PPO BRANCHES	2	* 1 * 1	
DESCRIPTION .	15-25%	33% HPME	
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00	
CASE/ DRANCH SPEIL:		010002100 010002100	
CASE NUMBER/SPLIT: DEPENDENCIES:	8	0.000E+00	
DEPENDENCIES:	40	41	
REQ. BRANCHES:	2	* 1	
DESCRIPTION:	15-252	33%	
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00	
CASE NUMBER/SPLIT:	0	0.0008+00	
CASE NUMBER/SPLIT:	40	41 39	7
DEPENDENCIES:	40	41 39 * 1 *( 1 +	1)
REQ. BRANCHES:	3	33% DW_FAIL	DETOR PI
DESCRIPTION:	25-35%	33% DW FAIL	LUTON N
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00	
CASE NUMBER/SPLIT:	10	0.000E+00	
DEPENDENCIES:	40	41 43 * 1 * 1	
REO. BRANCHES	3	* 1 * 1	
DESCRIPTION	25-35%	33% HPME	
CASE/BRANCH SPLIT		0.000F.00 0.000E+00	
CUORI DIVINOU DI DI LI I			
CASE NUMBER/SPLIT	11	0.0005+00	
DEPENDENCIES	40	41	
AP BEA APATOR BEAT WHEN AP BO SP			

REQ. BRANCHES: 3 * 1 DESCRIPTION: 25-35% 33% CASE/BRANCH SPLIT: 0.000CT+00 0.000E+00 CASE NUMBER/SPLIT: 12 0.000E+00 DEPENDENCIES: 40 41 39 REQ. BRANCHES: 4 * 1 *( 1 
 DEPENDENCIES:
 40
 41
 39
 7

 EQ. BRANCHES:
 4
 1
 *(
 1
 +
 1)

 DESCRIPTION:
 35-45%
 33%
 DW_FAIL
 PRIOR RV
 CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 13 0.000E+00 DEPENDENCIES: 40 41 REQ. BRANCHES: 4 * 1 * 43 1 DESCRIPTION: 35-45% 33% HPME CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 14 0.000E+00 DEPENDENCIES: 40 41 REQ. BRANCHES: 4 * 1 DESCRIPTION: 35-45% 33% CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 15 0.000E+00 DEPENDENCIES: 40 41 39 7 REQ. BRANCHES: 5 * 1 *( 1 + 1) DESCRIPTION: 45-55% 33% DW FAIL PRIOR RV CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 16 0.000E+00 DEPENDENCIES: 40 41 REQ. BRANCHES: 5 * 1 * 43 1 DESCRIPTION: 45-55% 33% HPME CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 17 0.000E+00 40 41 DEPENDENCIE REQ. BRANCHES: 5 * 1 DESCRIPTION: 45-55% 33% CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 18 2.655E-03 DEPENDENCIES: 40 41 39 REQ. BRANCHES: 1 * 2 *( 1 39 7 *( 1 + 1) DESCRIPTION: 0-15% 22% DW FAIL PRIOR RV CASE/BRANCH SPLIT: 0.000E+00 2.655E-03 CASE NUMBER/SPLIT: 19 9.105E-07 DEPENDENCIES: 40 41 43 REQ. BRANCHES: 1 * 2 * 1 DESCRIPTION: 0-15% 22% HOME CASE/BRANCH SPLIT: 3.977E-07 5.1263-07 CASE NUMBER/SPLIT: 20 1.050E-04 DEPENDENCIES: 40 41

REQ. BRANCHES:	1 4	2	
DESCRIPTION:	0-15%	22%	
CASE/BRANCH SPLITT		6.516E-05 3.988E-05	
CLOBA PRANOB STORY		111100 00 011000 00	
CASE NUMBER/SPLIT:	21	5 2218-05	
CASE NUMBER PILLI	40	216635-02	7
DEC BANCIESI	40	41 39	4.4
REU, INAMURESI	6		4.7
DESCRIPTION	10-20%	22% DW FAIL	PRIOR RV
CASE/BRANCH SPLIT:		0.000E+00 5.22IE-05	
	5 a	at data dat	
CASE NUMBER/SPLIT: DEPENDENCIES: REO. BRANCHES:	22	8.013E-05	
DEPENDENCIES:	40	41 43	
TRECPTOTION (	15_258	2.2% HPMP	
CASE/BRANCH SPLIT:		3.526E-05 4.487E-05	
CASE NUMBER/SPLIT:	2.3	1.743E-03	
DEPENDENCIES:	40	41	
BEG BBANCHEE.	- 13	4 9	
DESCRIPTION:	15-25%	22%	
CASE/BRANCH SPLIT:		22% 1.080E-03 6.67.5-04	
CASE NUMBER/SPLIT:	24	6,6488-05	
DEPENDENCIES	40	41 39	7
PEO BRANCHES	3	* 2 *( 1 )	1.1
DECORTPTION.	25-359	22 DV FATI	PRTOR RV
CACE (BRANCH CRITT,	22-220	0 0000,00 6 6480.05	ERAVE ET
CASE/BRANCH SPLIT:		6.6482-05 41 39 * 2 *( 1 + 22- DW FAIL 0.000E+00 6.648E-05	
CACE MINUED (CDI TT.	05	1.020E-04 41 43 * 2 * 1 22% HPME 5.813E-05 4.385E-05	
CASE NUMBER SPELLI	20	41 43	
DEPENDENCIES	40	43 43	
REQ. BRANCHES:	3	* <u>6</u> * .	
DESCRIPTION:	22-33%	22% HPME	
CASE/BRANCH SPLIT:		5.813E-05 4.385E-05	
CASE NUMBER/SPLIT:	26	2.218E-03	
DEPENDENCIES:	40	41	
REQ. BRANCHES:			
DESCRIPTION:	25-35%		
CASE/BRANCH SPLIT:		1.597E-03 6.209E-04	
CASE NUMBER/SPLIT:		0.000E+00	a faith a faith
DEPENDENCIES:	40	41 39	7
REQ. BRANCHES:		× 2 ×( 1 +	1)
DESCRIPTION:	35-45%	22% DW FAIL	PRIOR RV
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00	
(SSE NUMBER/SPLIT:	28	0.000E+00	
DEPENDENCIES:		41 43	
REQ. BRANCHES:		* * 1	
DESCRIPTION:		22% HPME	
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00	
Contract Contractions and and a second			
CASE NUMBER/SPLIT:	20	0.000£+00	
DEPENDENCIES:		41	
DET ENDERGIEGTEG	40		

C

0

٦

. .

FFQ, BRANCHES: 4 * ? DESCRIPTION: 35-45% 224 0.000E+00 7.000E+00 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 30 0.000E+00 DEPENDENCIES: 40 41 REQ. BRANCHES: 5 * 2 * 41 39 7 * 2 *( 1 + 1) DESCRIPTION: 45-55% 22% DW FAIL PRIOR RV CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 31 0.000E+00 DEPENDENCIES: 40 41 REQ. ERANCHES: 5 * 2 * 43 . 1 DESCRIPTION: 45-55% 22% HPME CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 32 0.000E DEPENDENCIES: 40 41 REQ. BRANCHES: 5 * 2 0.000E+U0 DESCRIPTION: 45-55% 22% CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 33 2.492E-02 DEPENDENCIES: 40 41 39 7 REQ. BRANCHES: 1 * 3 *( 1 * 1) DESCRIPTION: 0-1:: 11% DW FAIL PRIOR RV CASE/BRANCH SPLIT: 0.000E+00 2.492E-02 CASE NUMBER/SPLIT: 34 7.402E-04 DEPENDENCIES: 40 41 43 DEPENDENCIES: 40 41 43 REQ. BRANCHES: 1 * 3 * 1 DESCRIPTION: 0-15% 11% HPME 4.219E-04 3.183E-04 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 35 1.007E-02 DEPENDENCIES: 40 41 REQ. BRANCHES: 1 * 3 DESCRIPTION: 0-15% 11% BRANCH SPLIT: 7.391E-03 2.874E-03 CASE/BRANCH SPLIT: CAS: BER/SPLIT: 36 1.164E-04 ?9 7 *( 1 + 1) DEPENDENCIES: 40 41 REQ. BRANCHES: 2 * 3 *( DESCRIPTION: 15-25% 11% DW FAIL PRIOR RV 0.000E+00 1.164E-04 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 37 1.784E-04 DEPENDENCIES: 40 41 43 REQ. BRANCHES: 2 * 3 * 1 DESCRIPTION: 15-25% 11% HPME CASE/BRANCH SPLIT: 1.267E-04 5.172E-05 CASE NUMBER/SPLIT: 38 3.879E-03 DEPENDENCIES: 40 41

REQ. BRANCHES:	2 *	3	
DESCRIPTION:	15-25%	11%	
CASE/BRANCH SPLIT:		3.064E-03 8.145E-04	
CASE NUMBER/SPLIT:	39	1.482E-04	
DEPENDENCIES:	40	41 39 3 *( 1 +	7.
REQ. BRANCHES:	3 *	3 *( 1 +	1)
DESCRIPTION:	25-35%	11% DV FAIL	PRIOR RV
CASE/BRANCH SPLIT:		0.000E+00 1.482E-04	
CASE NUMBER/SPLIT:	40	2.270E-04	
DEPENDENCIES:	40	41 43	
REQ. BRANCHES:	3 *	3 * 1	
DESCRIPTION:	25-35%	11% HPME	
CASE/BRANCH SPLIT:		1.612E-04 6.583E-05	
CASE NUMBER/SPLIT: DEPENDENCIES:	40	41	
REQ. BRANCHES:	40	41	
REQ, BRANCHES:	75 755	334	
DESCRIPTION:	22-32%	11% 3.9006 03 1.037E-03	
CASE/BRANCH SPLIT:		3.9006-03 1.057E-05	
CASE NUMBER /SPLITA	42	0.000E+00	
DEPENDENCIES	40	41 39	7
DEA BRANCHES	40 4	0.000E+00 41 39 * 3 *( 1 +	1)
DESCRIPTION	35-45%	11% DW FAIL	PRIOR RV
CASE / BRANCH SPLIT:	221421	0,0002+00 0.000E+00	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:	43	0.000F.+00	
DEPENDENCIES:	40	41 43	
REO, BRANCHES:	4	* 3 * 1	
DESCRIPTION:	35-45%	11% HPME	
CASE/BRANCH SPLIT:		0.000F+00 0.000E+00	
CASE NUMBER/SPLIT: DEPENI NCIES:	44	0.000E+00	
DEPENI NCIES:	40	41	
REQ. BRANCHES:	4	* 3	
DESCRIPTION:	35-45%		
CASE/BRANCH SPLIT:		0.000E+00 0.000E+00	
		0.0000.00	
CASE NUMBER/SPLIT:			
DEPENDENCIES:		41 39	1
REQ. BRANCHES:		* 3 *( 1 +	1)
DESCRIPTION:			PRIOR RV
CASE/BRANCH SPLIT:		0.00+3000.0 00+3000.0	
CASE NUMBER/SPLIT:	46	0.0008+00	
DEPENDENCIES:			
REQ. BRANCHES:			
DESCRIPTION:		11% HPME	
		0.007E+00 0.000E+00	
CASE/BRANCH SPLIT:		0100 10400 010000400	
CASE NUMBER/SPLIT:	47	0.000E+00	
DEPENDENCIES		41	
APRIL BILTERESTOR A SPOT	Carlos and		

ŧ,

.

	5 * 3 45-55% 11% 0.000E+00 0.000E+00
WARD DISTURD AT ME	
	48 0.000£:00 OTHERWISE \$ SHOULD NEVER GO THIS PA 0.000E+00 0.000E+00
Q-TYPE/TIMES ASKED: BRANCHES:	45 CONTAINMENT FAILURE DUE TO H2 DETOLATION AT/NEAR RPV FAILU DEP. INPUT PROB. DET_CF NO 1 2
REALIZED SPLIT:	6.489E-05 9.999E-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 9.655E-01 44 1 NO_BRN_IG 0.000E+00 9.655E-01
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	2 0.000E+00 40 40 40 4 + 5 + 6 35-45% 45-55% > 55% 0.000F+00 0.000E+00
ASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 0.000E+00 41 3 7 18 6 1 * 1 * 1 * 2 * /1 33% SB0 PRIOR RV SPRAY /NO INJECT 0.000E+00 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	: 0.000E+00 40 41 1 * 1 0-15% 33% 0.000E+00 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	( 2 + 3) * 1
CASE NUMBER/SPLIT: CEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3
CASE NUMBER/SPLIT:	7 2.654E-03

DESCRIPTION:	2 * 1 * 1 * 2 * /1
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	8 1.490E-03 40 40 41 (2 + 3) * 2 15-25% 25-35% 22% 0.000E+00 1.490E-03
DEPENDZ*CIES: REQ. BRANC'ES: DESCRIPTION:	9 4.135E-05 40 41 1 * 2 0-15% 22% 6.506E-06 3.485E-05
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	CONTERVISE SHOULD NEVER REACH THIS 0.000E+00 0.000E+00
Q-TYPE/TIMES ASKED: BRANCHES:	46 CONTAIMENT FAILURE AT/NEAR RPV FAILURE DEP. CALC. PROB. FAILURE NO FAILUR 1 2 1.389E-02 9.861E-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIE3: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BKANCH SPLIT:	2 6.416E-05 45 1 DET_CF 6.416E-05 0.000E+00
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT.	3 9.902E-01 OTHERWISE 4.0542-03 9.861E-01
******* QUESTION: Q-TYPE/TIMES ASKED: BLANCHES: REALIZED SPLIT:	DEP. CALC. PROB. 39093 ANCHORAGE PN-D/NoCF 1 2
A CONTRACTOR OF	

SUMMARY BY CASE

H.4 - 39

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BKANCHES: DESCRIPTION: CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: DEPENDENCIRS: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 9.861E-01 46 2 NO_FAILUR 0.000F+00 9.861E-01 2 9.934E-03 45 30 1 * 1 DET_CF ALPHA 0.000E+00 9.834E-03
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	3 4.054E-03 OTHERWISE 2.449E-03 1.605E-03
******* QUESTION: Q-TYPE/TIMES ASKED: BRANCHES:	48 DRYWELL FAILURE DUE TO CONTAINMENT H2 BURN BEFORE/NEAR RPV DEP. CALC. PROB. DW_FAIL NO_DW_FL 1 2
REALIZED SPLIT:	4.175E-03 9.958E-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 2.098E-02 22 2 LG_BURN 9.573E-04 2.002E-02
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	2 3.452%-02 44 2 LG_BRN_IG 3.217E-03 3.131E-02
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BEANCH SPLIT:	3 9.445L-01 OTHERWISE 0.000L+00 9.445E-01 S NO LARGE BURNS IN CNTMT
******* QUESTION: Q-TYPE/TIMES ASKED: BRANCHES:	49 POOL BYPASS BEFORE/NEAR RPV FAILURE DEP. INPUT PROB. POOL BP NO_PL_BP 1 2
REALIZED SPLIT:	5.184E-02 9.482E-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:	1 1.151E-02

DESCRIPTION: CASE/BRANCH SPLIT:	DV_FAIL 1.151E-02 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	2 4.086E-03 48 1 DW_FAIL 4.086E-03 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	3 3.440E-02 25 47 1 + 1 ANCHORAGE ANCHORAGE 3.440E-02 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	4 3.528E-02 22 44 3 3 3 3 3 (2 + 2) *((3 + 6 + 6) *(1 + 5) LG_BURN LG BRN LG OTHER TYP CRIT ATWS OTHERS SB0 L00. 1.763E-03 3.351E-02
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	5 9.148E-01 OTHERWISE 9.081E-05 9.147E-01 \$ BYPASS FOR SEQUENCES VI
Q-TYPE/TIMES ASKED: BRANCHES:	50 CNTMT FAILURE AT/NEAR RPV FAILURE IMPACT ON ECCS INJECTION DEP. INPUT PROB. 48566 NO_FAILUR FAILUR 1 2
REALIZED SPLIT:	9.978E-01 2.203E-03
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	
	2 9.976E-01 OTHERWISE \$ NOT ANCHORAGE 9.976E-01 0.000E+00
	51 CNTMT FAILURE AT/NEAR RPV FAILURE IMPACT ON ECCS INJECTION DEP. INFUT PROB. 52777 NO FAILUP FAILUR
REALIZED SPLIT:	9.942E-01 5.840E-03
	SUMMARY BY CASE
CASE NUMBER/SPLIT:	1 1.168E-02

REO. BRANCHES: DESCRIPTION:	46 50 1 * 1 FAILURE NO FAILUR 5.840E-03 5.840E-03
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	2 9.883E-01 OTHERWISE \$ NO CNTMT FAILURE 9.883E-01 0.000E+00
	52 CNTMT FAIL AT/NEAR RFV FAILURE STEAM/RADIATION RELEASE IMP DEP. INPUT PROB. 59189 NO_FAILUR FAILUR 1 2
REALIZED SPLIT:	9.942E-01 5.839E-03
	SUMMARY BY CASE
	CONTRACT DA CALCO
REQ. BRANCHES: DESCRIPTION:	46 50
	2 9.883E-01 OTHERWISE 9.883E-01 0.000E+00 S NO CNTMT FAILURE
	53 INJECT & SPRAY FAILURE DUE TO CNTMT FAILURE AT/NEAR RPV FA DEF. INFUT PROB. 59189 NO_FAILUR INJ&SPY_F
RFALIZED SPLIT:	9.949E-01 5.123E-03
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEF3NDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 2.203E-03 50 2 FAILUR 0.000E+00 2.203E-03
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	2 2.919E-03 51 52 2 * 2 FAILUR FAILUR 0.000E+00 2.919E-03
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	3 9.949E-01 OTHERWISE 9.949E-01 0.000E+00 S ALL INJECT NOT FAILED A

******** QUESTION: Q-TY"E/TIMES ASKED:	DEP. INPUT PROB.	21191
BRANCHES:	DRY-CCI FAST-VET SLOV-VET NO-CCI 1 2 3 4	
REALIZED SPLIT:	2.284V-01 8.772E-02 1.256E-01 5.585E-01	
	SUMMARY BY CASE	
DEPENDENCIES:	2	
DEPENDENCIES:	4 +( 2 * 2)	
DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	3 3.,46E-04 33 33 53 43 ( 3 +( 1 * 2)) * 1 FLD FLD+INJ INJ&SPY F HP:'E 0.000E+00 6.540E-05 1.828E-04 1.264E-04	
DEPER. 1	( 3 +( 1 * 2)) * 2 * 1 FLD FLD+JNJ INJ&SPY_F NO_HPME LG_DEB	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DFSCRIPTION: CASE/BRANCH SPLIT:	( 3 +( 1 * 2)) * 2 * 2 FLD FLD+INJ INJ&SPY_F NO_HPME SM_DEB	
DEPENDENCIES: REQ. BRANCHES:	6 9.182E-03 33 53 43 (2 * 1) * 1 RFV+INJ NO_FAILUR HPME 0.000E+00 2.892E-03 4.384E-03 1.905E-03	
DEPENDENCIES: REQ. BRANCHES:		
DEPENDENCIES: REQ. BRANCHES:	8 2.398E-'' 33 53 43 (1 * 1) * 1 FLD+INJ NO_FAILUR HPME	

H.4 - 43

CASE/BRANCH SPLIT:	0.000E+00 4.194E-04 1.169E-03 8.092E-04
CASE NUMBER/SPLIT: DEPENDINCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	9 4.462E-04 3 53 43 14 (1 * 1) * 2 * 1 FLD+INJ NO FAILUR NO HPME LG DEB 0.000E+00 1.249E-04 2.144E-04 1.070E-04
DEPENDENCIES	10 9.0575-03 33 53 43 14 (1 * 1) * 2 * 2 FLD+INJ NO FAILUR NO HPHE SM DEB 0.000E+00 2.536E-03 4.348E-03 2.173E-03
DESCRIPTION:	11 0.000E+00 OTHERWISE \$ SHOULD NEVER TAKE THIS 0.000E+00 0.000E+00 0.000E+00 0.000E+00
Q-TYPE/TIMES ASKED: BRANCHES:	55 PEDESTAL FAILURE DUE TO CORE DEBRIS CONCRETE INTERACTION DEP. INFUT PROB. AT_VB AFTER_VB NO_FAILUR 1 2 3
REALIZED SPLIT:	1,558E-02 1.509E-01 8.336E-01
	SUMMARY BY CASE
DEPENDENCIES: REQ. BRANCHES:	1 1.558E-02 39 48 1 + 1 DV_FAIL DV_FAIL 1.558E-02 0.000E+00 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCH.'.: DESCRIPTION: CASE/BRANCH SPLIT:	32 2
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	54 1
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIFTION: CASE/BRANCH SPLIT:	54 2 FAST-WET
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES:	54

	· · · · · · · · · · · · · · · · · · ·
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.000E+00 3.040E-02 9.121E-02
A state of the second second	동생 방법은 가지가 많은 것이 같이 다니 것은 것이 집에서 가지 않는 것이 것을 얻어?
	6 4.9078-02
DEPENDENCIES:	54
REQ. BRANCHES:	4
DESCRIPTION:	NO-CCI
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00 4.907E-02
ORDER DEGREE OF DEELS	0.0000+00 0.0000+00 4.9076-02
CASE NUMBER/SPLTT:	7 0.000E+00
CACE/BRANCH CDITT.	OTHERVISE SHOULD NEVER GO THIS PA 0.000E+00 0.000E+00 0.000E+00
GASE/ BRANCH STULL	0.000E+00 0.000E+00 0.000E+00
******* QUESTION:	56 MODE OF RHR SPRAY OPERATION LATE
	DEP. INPUT PROB. 114790
BRANCHES:	CONTROLD SPRAY NO SPRAY
PRODUCT PRODUCT	1 2 3
REALTZED SPLTT:	0.000E+00 4.297Z-01 5.704E-01
NUMBER DECEMBER	0.0001400 4.2772-01 3.7042-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT:	1 5.704E-01
DEPENDENCIES:	8
REQ. BRANCHES:	
DESCRIPTION:	/RHR SPRY
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00 5.704E-01
SHOW STREET	0.0000000000000000000000000000000000000
CALE NUMBER/SPLITT:	2 3.660E-01
DEPENDENCIES:	3 8
	/1 * 1
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.000Ē+00 3.660E-01 0.000E+00
CASE NUMBER/SPLIT:	3 3.581E-02
DEPENDENCIES:	
	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$
REQ. BRANCHES:	
DESCRIPTION:	SBO PRIOR RV RHR_SPRY
CASE/BRANCH SPLIT:	0.000E+00 3.581E-02 0.000E+00
CASE NUMBER (CDU TT	2 2040 02
CASE NUMBER/SPLIT:	4 2.794E-02
DEPENDENCIES:	
REQ. BRANCHES:	
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.000E+00 2.794E-02 0.000E+00
CACE NUMBER (CDLTR.	E 0.0000.00
CASE NUMBER/SPLIT:	
DESCRIPTION:	O DHOOPD HEADY ON IUTS NY
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00 0.000E+00
******* QUESTION:	57 HYDROGEN IGNITION SOURCES AVAILABLE LATE
Q-TYPE/TIMES ASKED:	In the second se
	TODIAC
BRANCHES :	NO_SOURCE IGN_SOURC

REALIZED SPLIT: 1.136E-01 8.865E-01

SUM			

	1 8.619E-01 16 2 HIS_ON 0.0005+00 8.619E-01
REQ. BRANCHES:	2 4.314E-03 16 3 3 1 * /1 * /5 HIS_OFF /SB0 /LOOP & SB 4.276E-04 3.887E-03
DEPENDENCIES:	3 4.131E-02 3 7 1 * 1 SBO PRIOF RV 2.C66E-02 2.066E-02
DEPENDENCIES: REO. BRANCHES:	4 3.171E-02 3 7 1 * 2 SB0 CNTMT LIM 3.171E-02 0.000E+00
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	5 6.083E-02 OTHERWISE 6.083E-02 0.000E+00 \$ LOSS OF AC POWER NO REC
******** QUESTION: Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT:	DEP. INPUT PROB. 0-15% 15-25% 25-35% 35-45% 45-55% > 55 1 2 3 4 5 6 1 2 3 4 5 6
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 4.297E-01 56 2 SPRAY 4.297E-01 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES. DESCRIPTION: CASE/BRAMCH SPLIT:	2 3.013E-04 5 2 NOT ISOL 7.333E-05 2.280E-04 0.000E+00 0.000E+00 0.000E+00 0.000E+00



CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRII SON: CASE/BRANCH SPLIT:	3 7.568E-03 3 6 1 * 1 SB0 NO INJECT 7.494E-03 7.418E-05 0.000E+00 0.000E+00 0.000E+00 0.000.
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	4 2.847E-03 3 6 1 * 2 SB0 RCIC 0.000E+00 0.000E+00 8.217E-04 2.026E-03 0.000E+00 0.000
CASE NUMBER/SPLIT: DEPEN, ENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	5 1.581E-02 3 6 1 * 3 SBO HPCS 0.00CE+00 0.000E+00 0.000E+00 0.000E+00 1.581
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	6 2.146E-01 2 FAILED 0.000E+00 0.000E+00 0.000E+00 0.000E+00 2.146
CASE NUMBER/SPLIT:	<pre>7 3.292E-01 )THERWISE \$ NON-SBO TRANSIENTS WITH 3.292E-01 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E</pre>
******* QUESTION: Q-TYPE/TIMES ASKED: BRANCHES: REALIZED SPLIT:	59 H2 COMBUJTION BEFORE/AT RPV FATL RE DEP. INPUT PLOB. EARLY_BRN NO_ERLY_B 1 2 7.513E-01 2.488E-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 7.513E-01 44 22 21 2 + 2 + 2 LG_BRN_IG LG_BURN SMALL BRN 7.513E-01 0.000E+00
CASE NUMBER/ JPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	2 2.488E-01 OTHERWISE 0.000E+00 2.488E-01
******* QUESTION: 0-TYPE/TIMES ASKED: BRANCHES:	60         CONTAINMENT H2 CONCENTRATION LATE           DEP         INPL1 PROB.         302752           < 4 %
REALIZED SPLIT:	2.630E-01 2.917E-01 5.930E-02 6.685E-02 3.151E-01 4.355

SUMMARY BY CASE

CASE NUMBER/SPLIT: DEPENDENCIES:	1 4.939E-01 59 54
REQ. BRANCHES:	
DESCRIPTION: CASE/BRANCH SPLIT:	EARLY_BRN NO-CCI 2.470E-01 2.470E-01 0.000E+00 0.000E+00 0.000E+00 0.000
UNDER DRANGH OF MARY	
CASE NUMBER/SPLIT:	2 1.024E-01
DEPENDENCIES:	59 54 1 * 3
REQ. BRANCHES: DESCRIPTION:	EARLY BRN SLOV-WET
CASE/BRANCH SPLIT:	1.024E-02 2.561E-02 3.073E-02 2.561E-02 1.024E-02 0.000
SIDE HUNDED (ADI TO.	2 2 2102 02
CASE NUMBER/SFLIT: DEPENDENCIES:	3 7.210E-02 59 54
REQ. BRANCHES:	1 * 2
DESCRIPTION:	EARLY_BPN FAST-WET
CASE/BRANCH SPLIT:	0.000E+00 7.207E-03 1.442E-02 2.524E-02 2.524E-02 0.000
CASE NUMBER/SPLIT:	4 4.339E-04
DEPENDENCIES:	59 54 56 3 6
REQ. BRANCHES:	1 * 1 * 3 * 1 * 1 EARLY BRN DRY CCI NO SPRAY SBO NO INJECT
DESCRIPTION: CASE/BRANCH SPLIT:	0.000E+00 1.52IE-04 3.018E-05 2.583E-05 2.000
CASE DRANCA STRATT	
CASE NUMBER/SPLIT:	5 1.217E-03
DEPENDENCIES: REQ. BRANCHES:	59 54 56 3 6 1 * 1 * 3 * 1 * 2
DESCRIPTION:	EARLY BRN DRY-CCI NO SPRAY SBO RCIC
CASE/BRANCH SPLIT:	U.000E+00 4.567E-05 7.336E-04 4.376E-04 0.000E+00 0.000
CAPP ANNDED COLTTA	6 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES:	59 54 56 3 6
REQ. BRANCHES:	1 * 1 * 3 * 1 * 3
DESCRIPTION:	EARLY BRN DRY CCI NO SYRAY SBO HPCS
CASE/BRANCH SPLIT:	0,000E+00 0,000E+00 0,000E+00 0,000E+00 0,000E+00 0,000
CASE NUMBER/SPLIT:	7 4.032E-03
DEPENDENCIES:	
REQ. BPANCHES:	64.6 91110/PP
DESCRIPTION: CASE/BRANCH SPLIT:	
CASE/ NE MACE OF LL :	
CASE NUMBER/SPLIT:	
DEPENDENCIES:	
REQ. BRANCHES: DESCRIPTION:	I I I I I I I I I I I I I I I I I I I
CASE/BRANCH SPLIT:	DATE AND DE A TAR AL & CODE CO & 2035 03 1 05/5 03 7 /67
	약상 : 2011 N. C.
CASE NUMBER/SPLIT:	
DEPENDENCIES: REQ. BRANCHES:	
DESCRIPTION	

0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 10 6.650E-04 3 59 54 56 6 DEPENDENCIES: 3 * 1 REQ. BRANCHES: 2 * 4 1 NO ERLY B NO-CCI NO SPRAY SBO NO INJECT DESCRIPTION: 0.000E+00 6.650E-04 0.00LE+00 0.000E+00 0.000E+00 0.000 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 11 0.000E+00 3 59 54 56 6 DEPENF CIES: 3 * 1 2 2 * 4 * **REO. BRANCHES:** 黄 NO ERLY B NO-CCI NO SPRAY SBO RCIC DESCRIPTION: 0.000E+63 0.000E+00 0.000E+00 0.000E+00 C.000E+00 0.000 CASE/BRANCH SPLIT: 9.892E-03 CASE NUMBER/SPLIT: 12 59 54 58 3 6 DEPENDENCIES: 3 * 1 2 * 4 3 REQ. BRANCHES: NO ERLY B NO-CCI NO SPRAY SBO HPCS DESCRIPTION: 5.836E-03 4.056E-03 0.000E+00 0.000E+00 0.000E+00 0.000 CASE/BRANCH SPLIT: 1.5228-03 13 CASE NUMBER/SPLIT: 56 3 59 54 6 DEPENDENCIES: 2 * 2 * 1 1 **REQ. BRANCHES:** 4 NO ERLY B NO-CCI SPRAY SBO NO INJECT DESCRIPTION: 0,000E+00 1.522E-03 0.000E+00 0.000E+00 0.000E+00 0.000 CASE/BRANCE CPLIT: 0.000E+00 CASE NUMBER/SPLIT: 14 DEPENDENCIES: 59 54 56 3 6 * 1 2 * 2 2 **REQ. BRANCHES:** 4 SPRAY SBO RCIC NO ERLY B NO-CCI DESCRIPTION: 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000 CASE/BRANCH SFLIT: 15 0.000E+00 CASE NUMBER/SPLIT: 59 54 56 3 6 DEPENDENCIES: 1 - 3 2 * **REQ. BRANCHES:** 2 * 4 de l NO ERLY B NO-CCI SPRAY SBO HPCS DESCRIPTION: 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000 CASE/BRANCH SPLIT: 2.312E-02 CASE NUMBER/SPLIT: 16 54 59 DEPENDENCIES: 2 3 * **REO. BRANCHES:** NO ERLY B SLOW-VET DESCRIPTION: 0.000E+00 2.311E-03 3.468E-03 5.781E-03 1.156E-02 0.000 CASE/BRANCH SPLIT: 17 1.561E-02 CASE NUMBER/SPLIT: 54 59 DEPENDENCIES: 2 2 REQ. BRANCHES: NO ERLY B FACT-WET DESCRIPTION: 0.000E+00 0.000E+00 1.560E-03 2.340E-03 1.171E-02 0.000 CASE/BRANCH SPLIT: 18 4.2795-04 CASE NUMBER/SPLIT: 3 54 6 56 59 DEPENDENCIES: 1 2 * 1 * 3 * 1 * REO. BRANCHES: NO SPRAY SBO NO INJECT DESCRIPTION: NO ERLY B DRY-CCI

CASE/BRANCH SPLIT: 0.000E+00 1.2E4E-04 2.990E-05 2.563E-05 2.563E-05 2 CASE NUMBER/SPLIT: 19 1.319E-03 50 54 56 3 DEPENDENCIES: 6 3 * 1 2 * 1 * 2 REQ. BRANCHES: DESCRIPTION: NO ERLY B DRY-CCI NO SPRAY SBO RCIC 0.000E+00 0.000E+00 7.923E-04 4.749E-04 5.203E-05 0.000 CASE/BRANCH SPLIT: 20 0.000E+00 59 54 2 * 1 * CASE NUMBER/SPLIT: 56 3 3 * 1 3 DEPENDENCIES: 6 * 3 **RFO. BRANCHES:** NO_ERLY_B DRY-CCI NO SPRAY SBO HPCS DESCRIPTION: 0.0002+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000 CASE/BRANCH SPLIT: 21 3.921E-03 CASE NUMBER/SPLIT: * 1 * 56 2 54 DEPENDENCIES: 59 6 2 * 1 * **REQ. BRANCHES:** 1 DESCRIPTION: NO_ERLY_B DRY-CCI SPRAY SBO NO INJECT CASE/BRANCH SPLIT: 0.000E+00 1.216E-03 2.745E-04 2.353E-04 2.353E-04 1.960 CASE NUMBER/SPLIT: 22 8,704E-03 3 6 1 * 259 2 * 54 DEPENDENCIES: 56 2 * 1 REQ. BRANCHES: * NO EFLY B DRY-CCI SPR.Y SBO RCIC DESCRIPTION: CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 3.743E-03 3.656E-03 1.219E-03 8.701 23 0.000E+00 CASE NUMBER/SPLIT: * 1 54 56 DEPENDENCIES: 59 6 2 * 1 * 2 REQ. BRANCHES: 3 DESCRIPTION: NO ERLY B DRY-CCI SPRAY SBO HPCS CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E+00 0.000E CASE NUMBER/SPLIT: 24 2.535E-01 DESCRIPTION: OTHERWISE S SHOULD NOT TAKE THIS PA CASE/BRANCH SPLIT: 0.000U+00 0.000E+00 0.000E+00 0.000E+00 2.535E-01 0.000 ******* QUESTION: 61 AC POWER AVAILABLE LATE Q-TYPE/TIMES ASKED: DEP. INFUT PROB. 302752 AC LATE NO AC LAT BRANCHES: 2 1 REALIZED SPLIT: -9.828E-01 1.726E-02 SUMMARY BY CASE CASE NUMBER/SPLIT: 1 1.726E-02 7 DEPENDENCIES: 3 REQ. BRANCHES: 1 3 DESCRIPTION: SBO NO RECOV 0.000E+00 1.726E-02 CASE CRANCH SPLIT: CASE NUMBER/SPLIT: 2 9.828E-01 DESCRIPTION: OTHERWISE \$ AC POWER AVAILABLE 9.828E-01 0.000E+00 CASE/BRANCH SPLIT:

	1 2				
SUMMARY BY CASE					
CASE NUMBER/SPLIT: DEPENDENCIES: REO. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	2 IGN_SOURC				
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	6 > 55%				
CASE NUMBER/SPLIT: DFPENDENCIES: RE BRANCHES: L CRIPTION: CASE/BRANCH SPLIT:	1				
DEPENDENCIES: REO, BRANCHES:	0-15% 4-8 % NO_AC_LAT				
DESCRIPTION:	5 5.494E-05 58 60 61 1 * 3 * 2 0-15% 8-12 % NO_AC_LAT 0.694E-05 1.800E-05				
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. PRANCHES: DESCR.PTION: CASE/BRANCH SPLIT:	58 60 61 1 * 4 * 2 0-15% 12-16 % NO_AC_LAT				
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	58 60 61 1 * 5 * 2 0-15% 16-20 % NO_AC_LAT				
CASE NUMBER/SPLIT: DEPENDENCIES:					

REQ. BRANCHES: 1 * 6 * 2 DESCRIPTION: 0-15% > 20 % NO AC LAT CASE/BRANCH SPLIT: 1.566L 05 1.630E-05 CASE NUMBER/SPLIT: 9 1.808L-05 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 2 * 2 * 2 2 DESCRIPTION: 15-25% 4-8 % NO AC LAT 1.2948-05 5.1428-06 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 10 3.213E-06 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 2 * 3 * 2 DESCRIPTION: 15-25% 8-12 % NO AC LAT CASE/BRANCH SPLIT: 2.2565-06 9.565E-07 CASE NUMBER/SPLIT: 11 3.8581-06 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 2 * 4 * 2 DESCRIPTION: 15-25% 12-16 % NO AC LAT 2.295D-06 1.563E-06 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 12 8.940E-06 DEPENDENCIES: 58 60 REQ. BRANCHES: 2 * 5 * 61 2 DESCRIPTION: 15-25% 16-20% NO AC LAT CASE/BRANCH SPLIT: 4.3735-06 4.568E-06 CASE NUMBER/SPLIT: 13 3.227E-07 DEPENDENCIES: 58 60 61 REQ. : ANCHES: 2 * 6 * 2 DESCRIPTION: 15-25% > 20 % NO AC LAT CASE/BRANCH SPLIT: 1.581E-07 1.646E-07 CASE NUMBER/SPLIT: 14 8.020E-06 DEPENDENCIES: 58 60 61 3 * 2 * 2 REO. BRANCHES: DESCRIPTION: 25-35% 4-8 * NO AC LAT CASE/BRANCH SPLIT: 5.9367-06 2.084E-06 15 2.154F-04 CASE NUMBER/SPLIT: DEPENDENCIES: 58 60 61 REQ. BRANCHES: 3 * 3 * 2 25-35% 8-12 % NO AC LAT DESCRIPTION: 1.448E-04 7.063E-05 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 16 1.287F-04 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 3 * 4 * 2 DESCRIPTION: 25-35% 12-16 % NO AC LAT CASE/BRANCH SPLIT: 7.486E-05 5.380E-05 CASE NUMBER/SPLIT: 17 7.364E-06 DEPENDENCIES: 58 60 61

REQ. BRANCHES: 3 * 5 * 2 DESCRIPTION: 25-35% 16-20 % NO_AC_LAT CASE/BRANCH SPLIT: 3.608E-06 3.756E-06 CASE NUMBER/SPLIT: 18 0.000E+00 DEPENDENCIES: 58 60 REQ. BRANCHES: 3 * 6 DESCRIPTION: 25-35% > 20 % NO AC LAT CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 19 2.170E-05 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 4 * 2 * 2 DESCRIPTION: 35-45% 4-8 % NO AC LAT CASE/BRANCH SPLIT: 1.576E-05 5.936E-06 5.322E-04 CASE NUMBER/SPLIT: 20 60 61 DEPENDENCIES: 58 REQ. BRANCHES: 4 * DESCRIPTION: 35-45% 8-12 % NO AC LAT CASE/BRANCH SPLIT: 3.573E-04 1.749E-04 CASE NUMBER/SPLIT: 21 3.1931-04 DEPENDENCIES: 58 60 REO. BRANCHES: 4 * DESCRIPTION: 35-45% 12-16 % NC AC LAT CASE/BRANCH SPLIT: 1.855E-04 1.338E-04 CASE NUMBER/SPLIT: 22 1.886E-05 DEPENDENCIES: 58 REQ. BRANCHES: 4 * 60 REO. BRANCHES: DESCRIPTION: 35-45% 16-20 % NO AC LAT 9.229E-06 9.629E-06 CASE/BRANCH 3PLIT: CASE NUMBER/SPLIT: 23 0.000E+00 DEPENDENCIES: 58 60 60 * 6 * REQ. BRANCHES: 4 35-45% > 20 % NO AC LAT DESCRIPTION: CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 24 0.000E+00 58 60 61 DEPENDENCIES: 5 * 2 **REQ. BRANCHES:** DESCRIPTION: 45-55% 4-8% NO : LAT CATE/BRANCH SPLIT: 0.0005+00 0.000E+00 CASE NUMBER/SPLIT: 25

0.000E+00 DEPENDENCIES: 58 60 61 REQ. ERANCHES: 5 * 3 * 2 **REQ. ERANCHES:** DESCRIPTION: 45-55% 8-12 % NO AC LAT CASE/BRANCH SPLIT: 0.000E+00 0.000E+00

CASE NUMBER/SPLIT: 26 0.000E+00 DEPENDENCIES: 58 60 61

H.4 - 53

61 2

2

61

2

61

2

61

2

* 2

*

*

3

4

5 *

REQ. BRANCHES: 5 * 4 * 2 DESCRIPTION: 45-55% 12-16 % NO AC LAT CASE/BRANCH SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 27 0.000L+00 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 5 * 5 * 2 DESCRIPTION: 45-55% 16-20 % NO AC LAT CASE/BRANCE SPLIT: 0.000E+00 0.000E+00 CASE NUMBER/SPLIT: 28 0.000E+00 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 5 * 6 * 2 REQ. BRANCHES: 5 * 6 * 2 DESCRIPTION: 45-55% > 20 % NO AC LAT 0.000E+00 0.000E+00 CASE/BRANCH SPLIT: 1.4548-02 CASE NUMBER/SPLIT: 29 60 61 DEPENDENCIES: 58 REQ. BRANCHES: 1 2 1 * DESCRIPTION: 0-15% 4-8 % AC LATE CASE/BRANCH SPLIT: 0.000E+00 1.454E-02 CASE NUMBER/SPLIT: 30 9.415E-03 DEPENDENCIES: 58 60 61 REO, BRANCHES: 1 * 3 * 1 DESCRIPTION: 0-15% 8-12 % AC LATE CASE/BRANCH SPLIT: 0.000E+00 9.415E-03 9.0565-03 CASE NUMBER/SPLIT: 31 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 1 * 4 * 1 DESCRIPTION: 0-15% 12-16 % AC LATE 0.000E+00 9.056E-03 CASE/BP. NCH SPLIT: CASE NUMBER/SPLIT: 32 4.750E-03 DEPENDENCIES: 58 REQ. BRANCHES: 1 00 61 5 * - 1 DESCRIPTION: 0-15% 16-20 % AC LATE CASE/BRAMCH SPLIT: 0.000E+00 4.750E-03 CASE NUMBER/SPLIT: 33 4.237E-03 61 60 DEPENDENCIES: 58 1 * 6 * 1 REO. BRANCHES: DESCRIPTION: 0-15% > 20 % AC_LATE CASE/BRANCH SPLIT: 0.000E+00 4.237E-03 CASE NUMBER/SPLIT: 34 4.381E-05 DEPENDENCIES: 58 60 61 REQ. BRANCHES: 2 * 2 * 1 DESCRIPTION: 15-25% 4-8 % AC LATE E/BRANCH SPLIT: 0.000E+00 4.381E-05 CASE/BRANCH SPLIT: CASE NUMBER/SPLIT: 35 4.049E-05 DEPENDENCIES: 58 60 61

REQ. BRANCHES:	2 * 3 * 1
COSCRIPTION:	15-25% 8-19 V 10 1100
CASE/BRANCH SPLIT:	0.000E+00 4.049E-05
CASE NUMBER/SPLIT:	36 3.188E-05
DEPENDENCIES:	36 3.188E-05 58 60 61 2 * 4 * 1
REQ. BRANCHES:	2 * 4 * 1
DESCRIPTION:	15-25% 12-16 % 10 1100
CASE/ JRANCH SPLIT:	0 000E+00 3,188E-05
CASE NUMBER/SPLI	37 1.968E-05
DEPENDENCIES:	58 60 61
REQ. BRANCHES:	58 60 61 2 * 5 * 1 15-25% 16-20 % AC_LATE
REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	15-25% 16-20 % AC LATE
CASE/BRANCH SPLIT:	0.000E+00 1.968E-05
	The second
CASE NUMBER/SPLIT:	38 9.276E-06
DEPENDENCIES:	38 9.276E-06 58 60 61 2 * 6 * 1
REQ. BRANCHES:	2 * 6 * 1
DESCRIPTION:	15-25% 5 20 % 10 1100
CASE/BRANCH SPLIT:	0.000E+00 9.276E-06
CASE NUMBER/SPLIT:	39 2.602E-05
DEPENDENCIES	58 60 63
DESCRIPTION:	2 3 - 3 3 2 4 . H Y API TAMP
CASE/BRANCH SPLIT:	0.000E+00 2.602E-05
CASE NUMBER/SPLIT:	40 2.172E-04
DEPENDENCIES:	58 60 61
REQ. BRANCHES:	
DESCRIPTION:	20-30% 8-12 % AC LATE
CASE/BRANCH SPLIT:	0.000F+00 2.172E-04
CLOB MUNICIPAL CONTRACT	
CASE NUMBER/SPLIT:	41 1.316E-04
DELEVDENCIES:	58 60 61
REQ. BRANCHES:	3 * 4 * 1
DESCRIPTION:	25-35% 12-16 % AC LATE
CASE/BRANCH SPLIT:	0.000E+00 1.316E-04
0101 mm	
CASE NUMBER/SPLIT:	42 1.008E-05
DEPENDENCIES:	58 60 61
REQ. BRANCHES:	3 * 5 * 1
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.000E+00 1.008E-05
CASE NUMBER/SFLIT:	
CASE NUMBER/SFLIT:	43 0.000E+00
DEPENDENCIES:	58 60 61
REQ. BRANCUTSI	3 * 6 * 1
DESCRIPTION:	
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00
CASE NUMBER/SPLIT:	
DEPENDENCIES:	20
VET ENDERGIES!	58 60 61

REQ. BRANCHES: 4 * 2 * 1 DESCRIPTION: 35-45% 4-8% AC_LATE 0.000E+00 6.606E-05 CASE/BRANCH SPLIT: 45 5.351E-04

CASE NUMBER/SPLIT: 58 60 4 * 3 * DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:

CASE NUMBER/SPLIT: DZPENDENCIES: REO. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: 45-55% 8-12 % AC LATE CASE/BRANCH SPLIT:

CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:

0.000E+00 52 CASE NUMBER/SPLIT: 61 60 58 DEPENDENCIES: EQ. BRANCHES: 5 * 5 * 1 DESCRIPTION: 45-55% 16-20 % AC_LATE REQ. BRANCHES: 0.00CE+00 0.000E+00 CASE/BRANCH SPLIT:

0.0001400 53 CASE NUMBER/SPLIT: 61 60 58 DEPENDENCIES:

61

1

61

61

61

1

61

61

61

1

1

1

1

35-45% 8-12 % AC LATE

3.251E-04

60

4

2.583E-05

60

0.000E+00

60

35-45% > 20 % AC LATE

60

0.000E-00

3

60

4

45-55% 12-16 % AC LATE

60

51 0.000E+00

? *

45-55% 4-8 % AC LATE

0.00CE-00 0.000E+00

0.000E+00 0.000E+00

0.000E+00 0.000E+00

0.000E+00 0.000E+00

58 * 6

49 0.000E+00

35-45% 16-20 % AC LATE

35-45% 12-16 % AC LATE

46

58

47

58

4

48

58

5

50

58

58

5

5 *

4

0.000E-00 5.351E-04

*

0.000E+00 3.251E-04

5 * 1


0.000E+00 2.583E-05

*



DESCRIPTION:	5 * 6 * 1 45-55% > 20 % AC_LATE	
CASE/BRANCH SPLIT:	0,0007+00 0.000E+00	
CASE NUMBER/SPLIT: DESCRIPTION:		
	0.000E+00 0.000E+00	1
	63 H2 DETONATION LATE CONTAINMENT FAILURE DEF. INPUT PROB. DET_CF NO	
REALIZED SPLIT:	1 2 7.223E-04 9.994E-01	
NUMBEDDD ST 6441		
	SUMMARY BY CASE	
CASE NUMBER/SPLIT:		
DEPENDENCIES:	62	
REQ. BRANCHES:		
DESCRIPTION:		
CASE/BRANCH SPLIT:	0.000E+00 9.558E-01	
ONDER DIGITION DE DATA		
CACE NUMBER (CBI TT.	3 3 9720 03	
CASE NUMBER/ SPLIT:	2 1.2702-03	
DEPENDENCIES:	2 1.276E-03 58 58 58 4 + 5 + 6	
	4 + 5 + 6	
DESCRIPTION:		
CASE/BRANCH SPLIT:	0.000E+00 1.276E-03	
CASE NUMBER/SPLIT.	3 2.457E-02	
CASE NUMBER STELL	5 EINSTE-0E ED ED ED	
DEFENDENCIES:	60 60 60	
REQ. BRANCHES:	1 + 2 + 3	
	< 4 % 4-8 % 8-12 %	
CASE/BRANCH SPLIT:	0.000E+00 2.457E-02	
CASE NUMBER/SPLIT:	4 7.1268-03	
	60 3 7 56	
DEPENDENCIES:	4 * 1 * 2 * 2	
REQ. BRANCHES:		
	12-16 % SBO CNTMT LIM SPRAY	
CASE/BRANCH SPLIT:	1.558E-04 6.973E-03	
CLOP NUMBER (PDITT.	5 0 1740 00	
	5 2.174E-03	
DEPENDENCIES:	60	
REQ. BRANCHES:	4	
DESCRIPTION:	12-16 %	
CASE/BRANCH SPLIT:	0.000E+00 2.174E-03	
	4 4 0307 03	
	6 6.939E-03	
DEPENDENCIES:		
REQ. BRANCHES:	(5 + 6) * 1 * 2 * 2	
DESCRIPTION:	16-20 % > 20 % SBO CNTMT LIM SPRAY	
CASE/BRANCH SPLIT:	1.724E-04 6.767E-03	
	7 1.697E-03	
And then a particular for and 5 a		

DEPENDENCIES:	60	
REQ. BRANCHES:	5	
DESCRIPTION: CASE/BRANCH SPLIT:	16-20 % 2.687E-04 1.428E-03	
CHOB/ DIVINION DI LITT	2.00/2-04 1.4202-03	
CASE NUMBER/SPLIT:	8 4.650E-04	
DEPENDENCIES:	60	
REQ. BRANCHES:	6	
DESCRIPTION:		
CASE/BRANCH SPLIT:	1.254E-04 3.396E-04	
CACE NUMBED/CFLITT.	9 0.000E+00	
	OTHERWISE S SHOULD NEVER GO THIS P	A
CASE/BRANCH SPLIT:	0.000E+00 0.000E+00	0
	64 HYDROGEN BURN LATE CONTAINMENT FAILURE	
Q-TYPE/TIMES ASKED:		
BRANCHES:	FAILURE NO_FAILUR	
REALIZED SPLIT:	2.012E-02 9.799E-01	
ALANDADAD DA MART	EIVIED-06 311330-01	
	SUMMARY BY CASE	
A STATE OF	1 7.223E-04	
DEPENDENCIES:	63	
REQ. BRANCHES: DESCRIPTION:	DET CE	0
CASE/BRANCH SPLIT:	7.223E-04 0.000E+00	
CASE/ DRANCH STELL	1.2238-04 0.0005+00	
CASE NUMBER/SPLIT:	2 9.993E-01	
DESCRIPTION:	OTHERWISE	
CASE/BRANCH SPLIT:	OTHERWISE 1.940E-02 9.799E-01	
	65 CONTAINMENT STATUS AT ACCIDENT PROGRESSION COMPLETION	
Q-TYPE/TIMES ASKED:	DEF. INPUT PROB. INPUT PARM. 338583	
BRANCHES:	EARLY CF LATE CF VENT NO LAT CF	
	1 2 3 4	
REALIZED SPLIT:	2.415F-01 5.869E-02 2.952E-01 4.049E-01	
	SUMMARY BY CASE	
CASE NUMBER/SPLAT:	1 2.281E-01	
DEPENDENCISS:	2	
REQ. BRANCHES:	2	
DESCRIPTION:	FAILED	
CASE/BRANCH SPLIT:	2.281E-01 0.000E+00 0.000E+00 0.000E+00	
	0 0.0510.04	
CASE NUMBER/SPLIT: DEPENDENCIES:	2 2.851E-04 5	
REQ. BRANCHES:	2	
DESCRIPTION:		1
CASE/BRANCH SPLIT:	2.8515-04 0.000E+00 0.000E+00 0.000E+00	



CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	12 5.239E-02 8 6 6 3 *( 1 + 2) NO_RHR NO INJECT RCIC 0.000E+00 5.239E-02 0.000E+00 0.000E+00
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	13 0.000F+00 8 3 NO_RHR 0.000E+00 0.000E+00 0.000E+00
	14 0.000E+00 OTHERWISE \$ SHOULD NEVER GO THIS PA 0.000E+00 0.000E+00 0.000E+00 0.000E+00
	66 MODE OF LATE HYDROGEN AND OVERPRESSURE CONTAINMEN [®] FAILURE DEP. CALC. PROB. 375044 ANCHORAGE PN-D/NoCF 1 2
REALIZED SPLIT:	2.138E-02 9.787E-01
	SUMMARY BY CASE
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	65 2
	2 9.229E-01 64 2
CASE NUMBER/SPLIT: DEFENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	63 1
CASE NUMBER/SPLJT: DESCRIPTION: CASE/BRANCH SPLIT:	OTHERWISE
******* QUESTION: Q-TYPE/TIMES ASKED: BRANCHES:	
REALIZED SPLIT:	1.727E-02 9.829E-01

## SUMMARY BY CASE


CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION: CASE/BRANCH SPLIT:	1 4.420E-02 62 LG_BURN 1.727E-02 2.693E-02	
CASE NUMBER/SPLIT: DESCRIPTION: CASE/BRANCH SPLIT:	2 9.559E-01 OTHERVISE 0.000E+00 9.559E-01	S NO LARGE BURNS IN CNTMT
******** OUESTION: Q-TYPE/TIMES ASKED: BRANCHES:	68 POOL BYPASS LATE DEF. INPUT PROB. LAT_PL_BP NO_LAT_BP 1 2	418904
REALIZED SPLIT:	2.877E-01 7.125E-01	
	SUMMARY BY CASE	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	1 1.727E-02 67 1 DV FAIL	
CASE/BRANCH SPLIT:	1.727F, 02 0.000E+0C	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTION:	1	
CASE/BRANCH SPLIT:	9.808E-03 0.000E+00	
DEPENDENCIES: REQ. BRANCHES:	3 1.405E-01 55 2 AFTER VB	
DESCRIPTION: CASE/BRANCH SPLIT:	1.405E-01 0.000E+00	
CASE NUMBER/SPLIT: DEPENDENCIFS: REQ. BRANCHES: DESCRIPTION:	4 1.194F-01 54 1 DRY-CCI	
CASE/BRANCH SPLIT:	1.194E-01 0.000E+00	
CASE NUMBER/SPLIT: DEPENDENCIES: REQ. BRANCHES: DESCRIPTYON: CASE/BRANCH SPLIT:	5 1.266E-02 62 3 3 3 2 *(( 3 + 4 + 6) LG_BURN OTHER TYP CRIT ATWS OTHER 5.271E-04 1.203E-02	3 3 7 +( 1 + 5) *( 1 S SBO LOOP & SB PRI
CASE NUMBER/SPLIT: DESCRIPTION:	6 7.006E-01 OTHERVISE	\$ BYPASS PROB FOR SEQUENC

CASE/BRANCH SPLIT: 6.793E-05 7.005E-01



APPENDIX H.5

## PNPP IPE MAAF PARAMETER FILE



**			USE OF THIS SET POINT IS QUESTIONABLE FOR CURRENT
**			MAAP 3.0B REV 7 BECAUSE THE WAY FEEDWATER FLOW IS
**			CALCULATED ENSURES THE WATER LEVEL TO STAY AT THE
**			NORMAL OPERATING LEVEL, 'ZWSHO'
** .			
	RVCU		
**			
22		NRVCU	NUMBER OF REACTOR WATER CLEANUP PUMPS, 0.0 - 4.0, 3.0 )
23	0.43	WVRWCU	CONST'NT RWCU VOLUMETRIC FLOW RATE FOR EACH PUMP
**			(0.41 - 0.44, 0.43)
24	0.0	TDRWCU	TIME DELAY FOR RWCU ON ATION ONCE AN INITIATION SIGNAL RECEIVED( 0.0 - 30.0, 0.0 )
**	1000	NTRCHX	NUMBER OF TUBES IN ONE RWCU HEAT EXCHANGER
**	1000.	HINGHA	( 0.0 - 3000.0, 1000. )
26	10.	NBRCHX	NUMBER OF BAFFLES IN ONE RWCU HEAT EXCHANGER
**			( 0.0 - 15.0, 10. )
27	0.0165	6 XIDTRC	AWCU HEAT EXCHANGER TUBE INNER DIAMETER
**			( 0.0 - 0.0254, 0.01656 )
28	0.0012	45 XTTRC	RWCU HEAT EXCHANGER TUBE WALL THICKNESS
**	0.0354	VTODO	( 0.0 - 1.65D-3, 1.245D-3 ) RWCU HEAT EXCHANGER TUBE CENTER TO CENTER SPACING
29	0.0234	XTCRC	( 0.0 - 0.032, 0.0254 )
30	6.518	XSRC	RWCU HEAT EXCHANGER SHELL LENGTH( 0.0 - 16.2, 6.518 )
31		-4 RGFRC	RWCU HEAT EXCHANGER FOULING FACTOR
**			( 0.0 - 1.0D-3, 3.522D-4 )
32	17.3	KTRC	RWCU HEAT EXCHANGER TUBE WALL THERMAL CONDUCTIVITY
**			(0.0 - 3.0, 17.3)
33		XBCRC	RWCU HEAT EXCHANGER FFLE CUT LENGTH( 0.0 - 0.5, 0.31 )
34	1.1.494	XIDSRC	RWCU HEAT EXCHANGER SHELL INNER DIAMETER ( 0.0 - 2.0, 1.5494 )
35	0.0.	XSTRC	RWCU HEAT EXCHANGER BUNDLE TO SHELL GAP LENGTH
>> **	0.0.	ASTRO	( 0.0 - 0.05, 0.02 )
36	0.0	NTURC	NTU FOR HEAT EXCHANGER( 0.0 - 1.5, 0.0 ) **
37		FRCHX	TYPE OF RWCU HEAT EXCHANGER( 1.0 - 2.0, 2.0 )
**			1 = STRAIGHY TUBE, 2 = U TUBE
38	0.0	ZLRWCU	RWCU TRIP OFF LEVEL
**			
**			
	DRYWELL		
**		NOODEN.	
**			
39	3.0	NFN	NUMBER OF DRYWELL COOLERS ( 3 )
40	20.0	WVFNO	VOLUMETRIC FLOW RATE OF EACH DRYWELL COOLER ( 20 )
41	5.0	TDFAN	TIME DELAY FOR DRYWELL COOLERS ( 5 )
42	1200.	NTFC	
43			OUTSIDE AREA OF ALL TUBES IN EACH DRYWELL COOLER ( 180 )
44	1500.	AFINFC	AREA OF ALL FINS IN EACH DRYWELL COOLER ( 1500 ) DRYWEJ! COOLER FIN EFFICIENCY ( 0.5 )
45 46	0.5	FFINFC RGFLHX	
40			DRYWELL COOLER FIN DIAMETER ( 0.05 )
	The R. The sec.	515C5 576 W	and the second of the second o

DRYWELL COOLER THERMAL CONDUCTIVITY ( 240 ) 49 240. KTFC MINIMUM FLOW AREA THROUGH DRYWELL COOLER ( 10 ) 50 10. AFLMNF DRYWELL COOLLER TUBE INSIDE DIAMETER ( 0.015 ) 51 0.015 XIDTFC NUMBER OF NODES USED TO MODEL EACH DRYVELL COOLER ( 5 ) 52 5.0 NREGFC INLE? COOLING WATER. I.E. SERVICE WATER TEMPERATURE TO 53 310. TCVHX DRYWELL COOLER ( 310 ) 44 INLET COOLING WATER FLOW RATE TO EACH DRYWELL COOLER 110. WCWFC 54 (110)44 HIGH DRYWELL PRESSURE TO TRIP DRYWELL COOLER( 8.D5 ) 55 PHDWDC 8.D5 ** ************* *AUX BLDG/REACTOR B'DG INPUT ***************************** ******** ** **A MAXIMUM OF 9 NODES CAN BE REPRESENTED -- THE NO. OF NODES INODRE IS GIVEN **IN THE *CONTROL SECTION -- NOTE THAT NODE INODRB+1 IS THE FMUIRONMENT BUT **NO INFORMATION NEED BE ENTERED FOR IT **THE FOLLOWING ARE MODELED AT PRESENT: ** WATER OVERFLOWS -- THE SAME JUNCTIONS ARE USED AS IN THE GAS TRANSFERS ** 1. AND ARE SPECIFIED IN THE *TOPOLOGY SECTION BELOW: NOTE THAT ENTERING ** A ONE IN THE APPROPRIATE SFOT MODELS FLOOR DRAINS WHICH INSTANTLY ** DRAIN ALL ACCUMULATED WATER AWAY ** 2. H2 BURNS ** 3. CO2 FIRE SUPPRESSION SYSTEMS ** SFRAYS ** 4. 5. NATURAL CIRCULATION, BOTH UNIDIRECTIONAL AND COUNTER-CURRENT ** 6. TWO HEAT SINKS/NODE -- ONE HEAT SINK REPRESENTS AN "OUTER" WALL WHICH ** HAS THE NODE IN QUESTION ON ONE SIDE AND A USER-SPECIFIED NODE ON ** THE OTHER SIDE; THE OTHER HEAT SINK REPRESENTS AN "INNER" WALL WHICH ** HAS THE NODAL GAS TEMPERATURE ON BOTH SIDES. ** ** 01 03359. VOLRB(I) VOLUME OF NODE 1 VOLRB(I) VOLUME OF NODE 2 68440. 02 VOLRB(I) VOLUME OF NODE 3 03 59780. 735800. VOLRB(I) VOLUME OF NODE 4 04 05 629200. VOLRB(I) VOLUME OF NODE 5 300800. VOLRB(I) VOLUME OF NODE 6 06 VOLRB(I) VOLUME OF NODE 7 07 281500. VOLRB(I) VOLUME OF NODE 8 08 153400. 09 5096200. VOLRB(I) VOLUME OF NODE 9 ** FLOOR AREA ARE USED BOTH FOR WATER DEPTH AND TO REPRESENT CHARACTERISTIC ** DIMENSION OF COMPT FOR BURN TIMES ** ** 11 1600. FLOOR AREA FOR NODE 1 FLOOR AREA FOR NODE 2 12 1600. FLOOR AREA FOR NODE 3 13 1920. 14 17100. FLOOR AREA FOR NODE 4 FLOOR AREA FOR NODE 5 15 9800. 9200. FLOOR AREA FOR NODE b 16 6000. FLOOK AREA FOR NODE 7 17 FLOOR AREA FOR NODE 8 18 6850. FLOOR AREA FOR NODE 9 19 32600.

**		TE MATERIAL PROPERTIES	
21	3510.		
22	3150.	OUTER WALL AREA FOR NODE 2	
	1000.	OUTER WALL AREA FOR NODE 3	
24 25	19780.	OUTER WALL AREA FOR NODE 4 OUTER WALL AREA FOR NODE 5	
26		OUTER WALL AREA FOR NODE 6	
		OUTER WALL AREA FOR NODE 7	
28	57040.	CUTER WALL AREA FOR NODE 8	
29	59700.	OUTER WALL AREA FOR NODE 9	
**			
31	3.2	THICKNESS OF OUTER WALL IN NODE 1	
32	3.2	THICKNESS OF OUTER WALL IN NODE 2	
	0.021	THICKNESS OF OUTER WALL IN NODE 3	
	2.0	THICKNESS OF OUTER WALL IN NODE 4	
35	3.0	THICKNESS OF OUTER WALL IN NODE 5	
36	2.43		
27		THICKNESS OF OUTER WALL IN NODE 7	
		THICKNESS OF OUTER VALL IN NODE 8	
39	1.0	THICKNESS OF OUTER VALL IN NODE 9	
41	0.92	THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 1	
42	0.92	THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 1	
43		THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 3	
44		THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 4	
	0.92	THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 5	
46	0.92	THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 6	
47	0.92	THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 7	
48	27.0	THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 8	
	0.032	THERMAL CONDUCTIVITY OF OUTER WALL IN NODE 9	
**			
51	0.1.5	SPECIFIC HEAT OF OUTER WALL IN NODE 1	
52	0.156	SPECIFIC HEAT OF OUTER WALL IN NODE 2	
53	0.12		
54 55	0.156		
56	0.156		
57	0.156		
58	0.130	SPECIFIC HEAT OF OUTER WALL IN NODE 8	
59	0.123		
**			
61	25.1	OUTER WALL HEIGHT IN NODE 1	
62	25.7	OUTER WALL HEIGHT IN NODE 2	
63	30.0	OUTER WALL HEIGHT IN NODE 3	
64	43.0	OUTER WALL HEIGHT IN NODE 4	
65	16.0	OUTER WALL HEIGHT IN NODE 5	
66	16.7		1
67 68	25.3		
	110.0	OUTER WALL HEIGHT IN NODE 8	



٩

69	67.1	OUTER WALL HEIGHT IN NODE 9
**		
		OUTER WALL DENSITY IN NODE 1
		OUTER WALL DENSITY IN NODE 2
73	490.0	OUTER WALL DENSITY IN NODE 3
		OUTER WALL DENSITY IN NODE 4
		OUTER WALL DENSITY IN NODE 5
		OUTER WALL DENSITY IN NODE 6
		OUTER WALL DENSITY IN NODE 7
		OUTER WALL DENSITY IN NODE 8
	22.1	OUTER WALL DENSITY IN NODE 9
**		
**		ATION (OR "SGTS") SYSTEM IS MODELED BY SUPPLYING
**		UT FLC" AND/OR A FORCED IN FLOWIF AC POWER IS AVAILABLE,
**		IS ON UNTIL THE FIRE DAMPER SETPOINT(SEE BELOW) IS
**	REACHED IN	A COMPARTMENTTHIS SHUTS FLOW DOWN IN THAT COMPT
**		ULATING FLOWS, ENTER THE APPROPRIATE NODE ON THE SUCTION
**	SIDE IN FI	ELDS 161-169
**		
81	0 0	VENTILATION FLOW OUT OF NODE 1
82	0.0	VENTILATION FLOW OUT OF NODE 2 VENTILATION FLOW OUT OF NODE 3
83	0.0	VENTILATION FLOW OUT OF NODE 3
84	33.33	VENTILATION FLOW OUT OF NODE 4
85	33.33	VENTILATION FLOW OUT OF NODE 5
86	0.0	VENTILATION FLOW OUT OF NODE 5 VENTILATION FLOW OUT OF NODE 6 VENTILATION FLOW OUT OF NODE 7 VENTILATION FLOW OUT OF NODE 8 VENTILATION FLOW OUT OF NODE 9
87	0.0	VENTILATION FLOW OUT OF NODE 7
88	33.33	VENTILATION FLOW OUT OF NODE 8
89	0.0	VENTILATION FLOW OUT OF NODE 9
**		WENNET LETAN FLAN THEA NARE 1
91	0.0	VENTILATION FLOW INTO NODE 1
92	0.0	VENTILATION FLOW INTO NODE 2
93		VENTILATION FLOW INTO NODE 3
94	0.0	VENTILATION FLOW INTO NODE 4
95	0.0	VENTILATION FLOW INTO NODE 5
96	0.0	VENTILATION FLOW INTO NODE 6 VENTILATION FLOW INTO NODE 7
97		
98		VENTILATION FLOW INTO NODE 8 VENTILATION FLOW INTO NODE 9
99 **	0.0	VENILLATION FLOW INTO NODE 5
101	2200 0	AEROSOL SETTLING AREA I' NODE 1
		AEROSOL SETTLING AREA IN NODE 2
102		AEROSOL SETTLING AREA IN NODE 3
103		AEROSOL SETTLING AREA IN NODE 4
		AEROSOL SETTLING AREA IN NODE 5
		AEROSOL SETTLING AREA IN NODE 6
		AEROSOL SETTLING AREA IN NODE 7
100	12000.0	AEROSOL SETTLING AREA IN NODE 8
109		AEROSOL SETTLING AREA IN NODE 9
**	03200.0	ADROSOL SETTETING AREA IN HODE >
**	APPOSOL T	MPACTION DATA; IF IMPACTION IS MODELED IN A NODE, THE
**	TMPACTION	AREA, DIAMETER (EG., GRATE THICKNESS), AND FLOW AREA MUST
**	ALL BE GI	
**	APP 05 01	
	135 5	AEROSOL IMPACTION AREA IN NODE 1
111	20000	THAT WE ALL THAT AND THE ALL THAT AND

AEROSOL IMPACTION AREA IN NODE 2 112 135.5 AEROSOL IMPACTION AREA IN NODE 3 0.0 113 AEROSOL IMPACTION AREA IN NODE 4 114 0.0 AEROSOL IMPACTION AREA IN NODE 5 115 110.0 AEROSOL IMPACTION AREA IN NODE 6 116 0.0 AEROSOL IMPACTION AREA IN NODE 7 117 0.0 AEROSOL IMPACTION AREA IN NODE 8 118 0.0 AEROSOL IMPACTION AREA IN NODE 9 119 0.0 ** **CHECK--THESE DIAMETERS ARE TOO LARGE FOR GRATING AND WON'T REMOVE VERY **EFFICIENTLY AEROSOL IMPACTION DIAMETER IN NODE 1 .0324 121 AEROSOL IMPACTION DIAMETER IN NODE 2 122 .0324 AEROSOL IMPACTION DIAMETER IN NODE 3 123 0.0 AEROSOL IMPACTION DIAMETER IN NODE 4 124 0.0 AEROSOL IMPACTION DIAMETER IN NODE 5 125 .0324 AEROSOL IMPACTION DIAMETER IN NODE 6 126 0.0 AEROSOL IMPACTION DIAMETER IN NODE 7 127 0.0 AEROSOL IMPACTION DIAMETER IN NODE 8 128 0.0 AEROSOL IMPACTION DIAMETER IN NODE 9 129 0.0 +* FLOW AREA AT GRATING ELEV. IN NODE 1 133 429.5 FLOW AREA AT GRATING ELEV. IN NODE 2 132 429.5 FLOW AREA AT GRATING ELEV. IN NODE 3 133 0.0 FLOW AREA AT GRATING ELEV. IN NOCE 4 134 0.0 FLOW AREA AT GRATING ELEV. IN NODE 5 135 1320.0 FLOW AREA AT GRATING ELEV. IN NODE 6 136 0.0 FLOW AREA AT GRATING ELEV. IN NODE 7 137 0.0 FLOW AREA AT GRATING ELEV. IN NODE 8 138 0.0 FLOW AREA AT GRATING ELEV. IN NODE 9 139 0.0 ** SPRAYS (EG FIRE SPRATS) -- THESE ARE TURNED ON AND CFF MANUALLY USING ** EVENT CODE 240; THEY WILL ALSO COME ON IF THE NODAL TEMPERATURE ** EXCEEDS THE SETPOINT VALUE INPUT BELOW ** ** SPRAY MASS FLOW RATE IN NODE 1 141 0.0 SPRAY MASS FLOW RATE IN NODE 2 142 0.0 SPRAY MASS FLOW RATE IN NODE 3 143 0.0 SPRAY MA3S FLOW RATE IN NODE 4 144 0.0 SPRAY MASS FLOW RATE IN NODE 5 145 4812.4 **NON-SPRAY FLOW POURED ON CABLE TRAYS NEGLECTED FOR CONSERVATISM SPRAY MASS FLOW RATE IN NODE 6 146 0. SPRAY MASS FLOW RATE IN NODE 7 147 4812.4 SPRAY MASS FLOW RATE IN NODE 8 148 0.0 SPRAY MASS FLOW RATE IN NODE 9 149 24062. ** SPRAY FALL HEIGHT IN NODE 1 151 0.0 SPRAY FALL HEIGHT IN NODE 2 0.0 152 SPRAY FALL BEIGHT IN NODE 3 153 0.0 SPRAY FALL HEIGHT IN NODE 4 154 0.0 SPRAY FALL L'EIGHT IN NODE 5 155 16.0 SPRAY FALL HEIGHT IN NODE 6 156 0.0 [SMALLEST USED] SPRAY FALL HEIGHT IN NODE 7 157 22.6 SPRAY FALL HEIGHT IN NODE 8 158 0.0

	SPRAY FALL HEIGHT IN NODE 9
** INLET VENT ** NO. OF NOD	E NODE NO. THAT THE VOL IN NODE 1, 2, ETC., RECEIVES ITS FLOW FROM; USE INODRB+1 FOR ENVIRONMENT WHERE INODRB IS ES IN THE MODEL; USE SMALLER NOS. IF A RECIRCULATING SYSTEM TAKES FROM NODE 1 AND PUTS INTO NODE 4)
161 10. 162 10. 163 10. 164 10. 165 10. 166 10. 167 10. 168 10. 169 10. ** ** ENTER A ON	INLET VENT FLOW SOURCE NODE FOR NODE 4 INLET VENT FLOW SOURCE NODE FOR NODE 5 INLET VENT FLOW SOURCE NODE FOR NODE 6 INLET VENT FLOW SOURCE NODE FOR NODE 7 INLET VENT FLOW SOURCE NODE FOR NODE 8 INLET VENT FLOW SOURCE NODE FOR NODE 9 VE TO INSTANTLY DRAIN ALL WATER FROM NODE; THIS IS CONVENIENT
** IF THE BLU ** A LARGE SU **	OG HAS AN EFFICIENT DRAIN SYSTEM THAT PUTS ALL THE WATER INTO JMP (EG SEQUOYAH)
171 C.0 172 O.0 173 O.0 173 O.0 174 O.0 175 O.0 176 O.0 177 O.0 178 O.0 179 O.0 ** 181 -29.5 182 -29.5 182 -29.5 183 18.0 184 18.0	INSTANT DRAIN PARAMETER FOR NODE 1 INSTANT DRAIN PARAMETER FOR NODE 2 INSTANT DRAIN PARAMETER FOR NODE 3 INSTANT DRAIN PARAMETER FOR NODE 4 INSTANT DRAIN PARAMETER FOR NODE 5 INSTANT DRAIN PARAMETER FOR NODE 6 INSTANT DRAIN PARAMETER FOR NODE 7 INSTANT DRAIN PARAMETER FOR NODE 8 INSTANT DRAIN PARAMETER FOR NODE 9 ELEV. OF FLOOR OF NOD3 1 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 2 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 3 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 4 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 5 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 4 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 5 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 7 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 6 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 7 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 8 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 9 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 8 WITH RESPECT TO GROUND LEVEL ELEV. OF FLOOR OF NODE 9 WITH RESPECT TO GROUND LEVEL
** ** CO2 MASS	FLOWRATE FROM FIRE SUPPRESSION SYSTEM, IF ANY; THIS SYSTEM IS D IF THE NODAL GAS TEMP EXCEEDS THE SETPOINT SPECIFIED BELOW
** 191 0.0 192 0.0 193 0.0 194 0.0 195 0.0 196 0.0 197 0.0	CO2 MAS: FLOW RATE FOR NODE 1 CO2 MASS FLOW RATE FOR NODE 2 CO2 MASS FLOW RATE FOR NODE 3 CO2 MASS FLOW RATE FOR NODE 4 CO2 MASS FLOW RATE FOR NODE 5 CO2 MASS FLOW RATE FOR NODE 6 CO2 MASS FLOW RATE FOR NODE 7



198	0.0	CO2 MASS FLOW RATE FOR NODE 8 CO2 MASS FLOW RATE FOR NODE 9
199 **		
201	9135.0	AREA OF INTERNAL WALLS FOR NODE 1
202	9135.0	AREA OF INTERNAL WALLS FOR NODE 2
203	5550.0	AREA OF INTERNAL WALLS FOR NODE 3
204	10500.0	AREA OF INTERNAL WALLS FOR NODE 4
205	58660.0	AREA OF INTERNAL WALLS FOR NODE 5
206	5700 0	AREA OF INTERNAL VALLS FOR NODE 6
207	14600.0	AREA OF INTERNAL WALLS FOR NODE 7
208	40600.0	AREA OF INTERNAL WALLS FOR NODE 8
209	229750.0	AREA OF INTERNAL WALLS FOR NODE 9
**		
211	1.64	THICKNESS OF INTERNAL WALLS FOR NODE 1
212	1.64	THICKNESS OF INTERNAL WALLS FOR NODE 2
213	2.12	THICKNESS OF INTERNAL WALLS FOR NODE 3
214	1.50	THICKNESS OF INTERNAL WALLS FOR NODE 4
215	2.01	THICKNESS OF INTERNAL WALLS FOR NODE 5
216	1.72	THICKNESS OF INTERNAL WALLS FOR MODE O
217	1.62	THICKNESS OF INTERNAL VALLS FOR NODE 7
	1.76	THICKNESS OF INTERNAL WALLS FOR NODE 8
219	2.30	THICKNESS OF INTERNAL WALLS FOR NODE °
**	0.00	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 1
221	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 2
222	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 3
223	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 4
224	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 5
	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 6
220	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 7
228	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 8
220	0.92	THERMAL CONDUCTIVITY OF INTERNAL WALLS IN NODE 9
**	0.75	
	0.156	SPECIFIC HEAT OF INTERNAL WALLS IN NODE 1
222	0.156	SPECIFIC HEAT OF INTERNAL WALLS IN NODE 2
233	0.156	SPECIFIC HEAT OF INTERNAL WALLS IN NODE 3
	0.156	SPECIFIC HEAT OF INTFRNAL WALLS IN NODE 4
235	0.156	SPECIFIC HEAT OF INTERNAL WALLS IN NODE 5
236	0.156	SPECIFIC HEAT OF INTERNAL WALLS IN NODE 6
237		SPECIFIC HEAT OF INTERNAL WALLS IN NODE 7
238	0.156	SPECIFIC HEAT OF INTERNAL WALLS IN NODE 8
	0.156	SPECIFIC HEAT OF INTERNAL WALLS IN NODE 9
**		A A A A A A A A A A A A A A A A A A A
	22.5	HEIGHT OF INTERNAL WALLS IN NODE 1
242		HEIGHT OF INTERNAL WALLS IN NODE 2
	41.9	HEIGHT OF INTERNAL WALLS IN NODE 3
	43.0	HEIGHT OF INTERNAL WALLS IN NODE 4
245		HEIGHT OF INTERNAL WALLS IN NODE 5
246		HEIGHT OF INTERNAL WALLS IN NODE 6
247		HEIGHT OF INTERNAL WALLS IN NODE 7 HEIGHT OF INTERNAL WALLS IN NODE 8
248		A REAL PROPERTY AND A REAL
249		UPTAUL OF THIPTHAP AVERS TH HODE 2
		DENSITY OF INTERNAL WALLS IN NODE 1
6.41		

- 1	ē				
13	12				
	3				20
		10	16	e	5

252	145.0	DENSITY OF INTERNAL WALLS IN NODE 2
253	145.0	DENSITY OF INTERNAL WALLS IN NODE 3
254	145 0	DENSITY OF INTERNAL VALUE IN NODE 4
255	145.0	DENSITY OF INTERNAL WALLS IN NODE 5 DENSITY OF INTERNAL WALLS IN NODE 6
256	145.0	DENSITY OF INTERNAL VALLS IN NODE 6
257	145.0	DENSTTY OF INTERNAL WALLS IN NODE 7
258	145.0	DENSITY OF INTERNAL WALLS IN NODE 7 DENSITY OF INTERNAL WALLS IN NODE 8 DENSITY OF INTERNAL WALLS IN NODE 9
259	145.0	DENSITY OF INTERNAL WALLS IN NODE 9
**		
** 1	USE INODER.	+1 FOR ENVIRONMENT WHERE INODRB IS NO. OF NODES IN THE MODEL;
		R NOS. IF AN OUTER WALL IN NODE 1 HAS A DIFFERENT NODE ON THE
** 1	OTHER SIDE	: NOTE FOR WALLS THICKER THAN ROUGHLY 1-2 FEET, THE THERMAL
		AYER DOESN'T PENETRATE THE WALL OVER THE TIME OF TYPICAL
		AND ONE CAN FREELY LUMP WALLS WITH DIFFERENT NODES ON THEIR
	OTHER SIDF	
**		
261	8.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 1
262	8.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 2
263	9.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 3
264	10.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 4 NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 5
265	10.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 5
266	9.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 6
267	9.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 7
268	10.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 6 NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 7 NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 8
269	10.0	NODE # ON OTHER SIDE OF OUTER WALLS OF NODE 9
**		
271	1.D10	TOTAL INIT. MASS OF H20 AVAILABLE FOR FIRE SPRAYS [LAKE]
272	0.0	TOTAL INIT. MASS OF CO2 IN FIRE SUPP. SYSTEM
273	90.0	INITIAL CEMPERATURE OF AUX. BLDG.
274	90.0	AUX BLDG. SPRAY WATER TEMPERATURE [ASSUMED=LAKE]
275	.003	AUX BLDG. SPRAY DROPLET DIAMETER
276	.50	INITIAL REL. HUMIDITY IN AUX. BLDG. COMPARTMENTS
211	90.0	ENVIRONMENT TEMPERATURE [ASSUMED] ENVIRONMENT/AUX BLDG. PRESSURE FIRE DAMPER ACTIVATION TEMPERATURE [NONE] FIRE SPRAY ACTIVATION TEMPERATURE [HIGHEST USED]
278	14.7	ENVIKONMENT/AUX BLDG, FRESSURE
279	1.010	FIRE DAMPER ACTIVATION TEMPERATURE [NUME]
280	212.	FIRE SPRAY AUTIVATION TEMPERATURE [HIGHEST USED]
281	1.010	CO2 INJECTION ACTIVATION TEMPERATURE TOTAL AEROSOL MASS TO TEAR OUT SGTS FILTERS
		SGTS FILTER DF
		DITION FOR HYDROGEN COMBUSTION (TEMPORARY INPUT)
	6.2 G.2	XRBRRB(1) CHARACTERISTIC RADIUS OF NODE 1 FOR H2 BURNS
	7.8	NODE 2
	4.2	NODE 3
	20.8	NODE 4
	14.7	NODE 6
		NODE 7
	7.5	
	24.2	NODE 9
****		
		XHBRRB(1) CHARACTERISTIC HEIGHT OF NODE 1 FOR H2 BURNS
****		THIS IS FLOOR TO CEILING (NOT IGNITER TO CEILING)
		NODE 2
	25.7	NODE 3


297	17.3	NODE 4	
	and a second	NODE 5	
299	1997 B. 199	NODE 6	
300	1988 ( R. 1988)	NODE 7	
20.00		NODE 8	
Carlor and the	14.2	NODE 9	
****		WRODD AUED	AGE DISTANCE FROM IGNITERS TO CEILING
	0.D0		AGE DISTANCE THON TONLEDND TO TELEVIS
	0.D0	NODE 2	
	0.D0	NODE 3	
	0.D0	NODE 4 NODE 5	
	0.D0	NODE 6	
	0.D0 0.D0	NODE 7	
and the second second	0.D0	NODE 8	
	0.D0	NODE 9	
1			
****	*******	******	******************
1.000	CHARTER CALLER TO TO TO	TT NTODIE U	ETUELL COMPARTMENT)
***	********	*******	*******************
01	620.5	ZCAF	ELEVATION OF KCU DECK
02	170900.	VOLCA	VOLUME OF COMPARIMENT A
	.50	RELHCA	RELATIVE HUMIDITI IN COMPL. A
04	4000.	ACAF	AREA OF COMPT. A FLOOR
05	2534.	ACACB	FLOW AREA BETWEEN COMPT. A AND COMPT. B
06	1900.	AVUCA	FLOW AREA BETWEEN WEIWELL AND COLLAR OF
07	620.5	ZWCAWW	CURB HEIGHT ON MIDDLE DECK
08	3.060		HYDROGEN MIXING COMPRESSOR FLOW CURVE:
09			- PRESSURE
	4.941	PPUR(3)	
	6.149	PPUR(4)	
	6.668	PPUR(5)	
13	7.159	PPUR(6) PPUR(7)	
14		PPUR(8)	
15	7.412		- FLOW
16 17		. WVPUR(2)	성격 전쟁에는 것 같은 것 같
18		. WVPUR(3)	
19		. WVPUR(4)	
20		. WVPUF(5)	
21		. W/1 R(6)	
22		. WVPUR(7)	
23		. WVPUR(8)	UTWING CONTRECCORS
24		NPURP	NUMBER OF HYDROGEN MIXING COMPRESSORS
25			LOW WATER (LOCA) SIGNAL FOR DRYWELL PURGE
26	1.E10	POWPUR	HIGH DRYWELL PRESSURE (LOCA) FOR DRYWELL PURGE
27	1.E10		PRESSURE DIFFERENTIAL SET POINT FOR DRYWELL PURGE
28	.0083	3 TDPUR	TIME DELAY FOR DRYWELL PURGE
29			NUMBER OF IGNITERS IN THE COMPT A AVERAGE DISTANCE FROM FLOOR TO IGNITER
30			NUMBER OF IGNITERS IN WETWELL SEEN BY COMPT. A
	1 10		AEROSOL SEDIMENTATION AREA
3			COMPT A TOTAL IMPACTION AREA
3		. AIMPCA	COMPT A MINIMUM GRATE DIAMETER (OR THICKNESS)
3	5 .02	08 XDIMCA	COULT & LITUTION OF CALLS



36	2260.	AGRACA	COMPT A FLOW AREA THRU GRATE
37			NUMBER OF TENDONS IN HOOP DIRECTION
38		XTREHA	VOLUME OF REBAR PER UNIT AREA OF OUTER WALL
39	.0	XTREZA	VOLUME OF REBAR PER UNIT AREA OF OUTER WALL
40		XDHOPA	DIAMETER OF HOOP TENDONS
	.0	ZACYL	HEIGHT OF THE CYLINDRICAL PART OF COMPT A WALL
	.0	XDZFA	DISPLACEMENT IN AXIAL DIRECTION
43		XDR 7A	
			CHARACTERISTIC RADIUS OF COMP A FOR H2 BURNS
			CHARACTERISTIC HEIGHT OF COMP A FOR H2 BURNS
**			THIS IS FLOOR TO CEILING
++			
**	*******	********	*****************
*00	TR (MARKI	TT-UPPER WE	TVFLL COMPARTMENT)
****	*******	*******	*********
			ELEVATION OF OPERATING DECK
			VOLUME OF COMPT. B
03	.50	RELHCB	RELATIVE HUMIDITY IN COMPT.B
04	689.5	ZVCBVV	ELEVATION AT THE TOP OF THE UPPER DECK CURB
05	3427.	AVCB	UPPER POOL WATER SURFACE APEA
06	.0	PCPUR(1)	CONTAINMENT PURGE FAN CURVE:
07	.0	PCPUR(2)	VVIAILATION & VIVE SANT VALUET
	.0		
09	.0	PCPUR(4)	
10	.0	PCFUR(5)	
11	.0	PC UR(6)	
12	.0	PCPUR(7)	
13		PCPUR(8)	
14		WVCPUR(1)	
15	.0	WVCPUR(2)	
16		WVCPUR(3)	
17		WVCPUR(4)	
18	.0	WVCPUR(5)	
		WVCPUR(6)	
20	.0	WVCPUR(7)	
		WVCPUR(8)	
	32830.	VOLUPD	VOLUME OF WATER IN UPPER POOL DUMP
	636.483	ZLUFD	LOW WATER LI (LOCA) SIGNAL FOR UPPER POOL DUMP
		PDWUPD	
	.1445		
	.5088		TIME DELAY FOR UPPER POOL DUMP
	667.343		
	39960.	VLAUPD	THE REPORT OF A DESCRIPTION OF A DESCRIP
2.9		NIGCB	a second
30			
31		NIGBCB	
33		ASEDCB	
1		AIMPCB	
		XDIMCB	
			The second s
	.0		the second se
38			and the second
39			the second se
40	.0	XDHOPB	
4.9		and the second	

HEIGHT OF THE CYLINDRICAL PART DISPLACEMENT IN AXIAL DIFECTION .0 ZBCYL 41 XDZFB 42 . C XDRFB SAME AS 42 FOR THE RADIAL DIRECTION .0 43 CHARACTERISTIC RADIUS OF COMP B FOR H2 BURNS 44 61.6 XRBRCB CHARACTERISTIC HEIGHT OF COMP B FOR H2 BURNS 67.5 45 XHBRCB THIS IS FLOOR TO CEILING ** ** ************************ ************* *CONCRETE PROPERTIES 2420. TCNMP CONCRETE AVERAGE MELTING TEMF (SOLIDUS - LIQUIDUS) 01 REACTION ENERGY FOR CONCRETE DECOMPOSITION 501. LHDEC 02 215. LHCN LATENT HEAT FOR CONCRETE MELTING 03 MFCN(1) SIO2 04 .35800 05 .31300 MFCN(2) CAO MFCN(3) AL203 .03600 06 K20 .01220 MFLN(4) 07 08 .00082 MFCN(5) NA20 MFCN(6) MG0+MN0+TI02 MFCN(7) FE203 -> FE0+02 09 .00690 10 .01440 11 .0 MFCN(8) FE MFCN(9) CR203 .00014 12 MFCN(10) H20 .04700 13 MFCN(11) CO2 14 .21154 15 0 16 18. MFCN(12) 02 DENSITY OF REBAR IN CONCRETE DCSRCN CPCNO SPECIFIC HEAT OF CONCRETE .20 17 **REMAINDER OF THE QUANTITIES ARE USED IN THE MARK II1 CONTAINMENT FAILURE **MODEL AND NEED NOT BE SUPPLIED IT THE "SIMPLE" MODEL IS USED **(SEE WETWELL SECTION) ELASTIC YOUNGS MODULUS FOR TENDONS 18 .0 PTEN .0 ELASTIC YOUNGS MODULUS FOR REBAR 19 PEREB .0 PEPTEN PLASTIC YOUNGS MODULUS FOR TENDONS 20 PEPREB PLASTIC YOUNGS MODULUS FOR REBAR PSSPH PRESTRESS ON HOOP TENDONS PSSPZ PRESTRESS ON AXIAL TENDONS .0 21 22 .0 .0 23 .0 .0 PSSYHT TENDON YIELD STRESS .0 PSSYHR REBAR YIELD STRESS .0 PSSFHT TENDON ULTIMATE STRESS PSSYHT JENDON YIELD STRESS 24 25 PSSFHR REBAR ULTIMATE STRESS PEL ELASTIC YOUNGS MODULUS PEPL PLASTIC YOUNGS MODULUS 26 .0 27 .0 ELASTIC YOUNGS MODULUS FOR LINER 28 PLASTIC YOUNGS MODULUS FOR LINER .0 29 LINER YIELD STRESS 30 .0 PSSYHL PSSFHL LINER FAILURE STRESS 31 ** ***************** *CONTROL CARDS ******* 3 IBWR CONTAINMENT TYPE (MARK 1,2, OR 3) 01 UNIT NUMBER TO WRITE RESTART FILE (MAIN) 02 41 IRSTV 03 56 IHUW UNIT NUMBER TO WRITE RESTART FILE (HEATUP) IPOUT UNIT NUMBLE TO WRITE PROGRAM OUTPUT FILE .40 04 OPTION FOR PLTMAP VARIABLE LABEL LENGTH IN PLOT FILES 05 1 IPLT1 =1, USE AU FORMAT (AS HAS BEEN IN THE PAST) **

**			=2, USE A15 FORMAT - MAX LENGTH OF ANY MAAP
**			COMMON BLOCK NAME.
06	1000	IPTSM	X MAXIMUM NUMBER OF PLOTTED POINTS K MAXIMUM NUMBER OF PLOT POINTS TRACED FOR FULL
07	10	IPTSP	K MAXIMUM NUMBER OF PLOT POINTS TRACED FOR FULL
**			SCALE SPIKE
08	150	IPTSA	V NUMBER OF POINTS SAVED FOR NON-CHANGING PLOT [DUMMY]
09	0	ISUMM	SUMMARY DATA(O=ALL EVENTS, 1=SHORTER LIST)
10	14	ISUM	SUMMARY FILE NUMBER
11	1	IRUNG	1=1ST ORDER R-K, 2=2ND ORDER R-K
12	1	IFREE	Z 1=D0 FREEZE FRONT CALC, (0=N0 CALC.)
13	12	INPGR	P NUMBER OF TRACE G'S TYPES (FISSION PRODUCTS)
14	0	TRET	WRITE RETAIN PLOT FIL: (NOT USED)
15	10	IFPPL	T RETAIN PLOT FILE UNIT NUMBER (NOT USED)
25	5	IH	NUMBER OF RADIAL NODES
			NUMBER OF AXIAL NODES
153	0	IINER	T O=CONTAINMENT NOT INERTED, 1=CONTAINMENT INERTED
154	1	IILPC	I LPCI INJECTION: 1=LOWER PLENUM, O=DOWNCOMER
155	0	INODR	B NUMBER OF REACTOR BLDG NODES
			FILE TO WRITE AUX CODE INFO
157	0	IAUXR	FILE TO READ AUX CODE INFO
327	1	JNTGR	T = 1 : UTILIZE CONSISTENT TIMESTEPS BETWEEN
**			DIFFUN (ICALL=3) AND INTGRT &
**			DIFFP (ICALL=3) AND INTEGFP
**			= 0 : UTILIZE THE SMALLER TIMESTEP OF
**			DIFFUN (ICALL=3) AND LIMITING VALUES IN INTGRT &
			DIFFP (ICALL=3) AND LIMITING VALUES IN INTGFP
328	0	ITDLIM	= 1 : UTILIZE USER-INPUT CRITICAL PARAMETERS
**			IN DETERMINING THE LIMITING TIMESTEP
**			= 0 : UTILIZE ORIGINAL HARD-WIRED CRITICAL PARAMETERS = 1 : SORT OUT INTEGRATION DIAGNOSTIC FIGURES OF MERIT
329	0	ISORT	= 1 : SORT OUT INTEGRATION DIAGNOSTIC FIGURES OF MERIT
**			FUR ALL INE INERMAL HIUKAULIC VARIABLES IN INIGRI
**			IN AVERAGE FRACTIONAL CHANGES OF STATE VARIABLES &
**			FREQUENCY OF SIGN CHANGES OF THEIR RATES
**			= 0 : NO SORTING
336	0	IEMBAL	= 1 : DO & PRINT OUT PRIMARY SYSTEM / CONTAINMENT
**			MASS / ENERGY BALANCES
1.4			= 0 : NO BALANCE
337	0	ICRBAL	= 1 : DO & PRINT OUT CORE MODE ENERGY BALANCE
**			= 0 : NO BALANCE
**			
****	******	*******	****************
	YWELL		
			***************************************
			W RELATIVE HUMIDITY IN DRYWELL
			VOLUME OF DRYWELL
			ELEVATION AT DRYWELL FLOOR
			AREA OF DRYWELL FLOOR
			W ELEVATION OF WEIR WALL BETWEEN DRYWELL AND WETWELL
			NUMBER OF INGITERS IN THE DRYWELL
			AVERAGE DISTANCE FROM FLOOR TO IGNITER
			W AEROSOL SEDIMENTATION AREA
			K DRYVELL LEAK AREA - FOR MJ, MII & MIII
11	96	18. AIMP	DW DRYWELL TOTAL IMPACTION AREA
12	.02	08 XDIME	DRYWELL MINIMUM GRATE DIAMETER (OR THICKNESS)



14 15 16 17	3.080-5 .0 .0 33.9	XDDROP XHSPDW PCFAIL XRBRDW XHBRDW	DRYWELL FLOW AREA THRU GRATE SPRAY DROFLET DIAMETER FOR CONTAINMENT SPRAYS SPRAY FALL HEIGHT IN DRYWELL CONTAINMENT FAILURE PRESSURE ONLY FOR MI & MIT CHARACTERISTIC RADIUS OF DRYWELL FOR H2 BURNS CHARACTERISTIC HEIGHT OF DRYWELL FOR H2 BURNS THIS IS FLOOR TO CEILING
**			***********
*RIN	INEERED SA	IFEGUARUS	*********
****	(#1.)*******	NI ACTI	NUMBER OF RHR PUMPS IN LPCI LOOP 1
01	1	NLPCI1	NUMBER OF RHR PUMPS IN LPCI LOOP 2
02	1	NLFC12	NUMBER OF RHR FUMPS IN LPCI LOOP 3
03	1	NLPCID	NUMBER OF RHR PUMPS IN LPCI LOOP 3 NUMBER OF LPCS PUMPS
04	1	NLPCSP	NUMBER OF LIGS FORTS
05	.0	NUT USED	MIN. WATER VOLUME IN CST FOR HPCS/RCIC XFER
06	7980	VMNCSI	SPECIFIC VOLUME OF CST WATER HPCI PUMP FLOW CURVE - N/A AT PY
07	.01627	VWCS1	UPOT DIMP FLOU CHRUE _ N/A AT PY
80	.0	PHPCI(I)	HECT FORT FLOW COLVE
09	.0	rHrGI(2)	
10	.0	PHPCI(3)	
11	.0	PHPCI(4)	
	.0	PHPCI(5) PHPCI(6)	
	.0	PHPCI(7)	
		PHPCI(8)	
15			
10	.0	WVHPCI(1) WVHPCI(2)	
		WVHPC1(2)	
		WVHPCI(4)	
20	.0	WVHPCI(5)	
		WVHPCI(6)	
22	.0	WVHPCI(7)	
		WVHPCI(8)	
20	201	PLPCT(1)	RHR PUMP FLOW CURVE:
25		PLPCI(2)	- PRESSURE
26	277.	PLPCI(3)	
27	260.	PLPCI(4)	
20	238.	PLPCI(5)	
29	217.	PLPCI(6)	
30	191.	PLPCI(7)	
31	126.	PLPCI(8)	
32	.0	WVLPCI(1)	- VOLUMETRIC FLOW
33	9023.	WVLPCI(2)	
34	16040.	WVLPCI(3)	
35	24060.	WVLPCI(4)	
36	32080.	WVLPCI(5)	
37	40100.	WVLPCI(6)	
38	48120.	WVLPCI(7)	
39	63360.	WVLPCI(8)	
40	499.	PLPCS(1)	LPCS PUMP CURVE:
41	498.	PLPCS(2)	- PRESSURE
42	450.	PLPCS(3)	
43	429.	PLPCS(4)	




44	390.	PLPCS(5)	
45	346.	PLPCS(6)	
46	381.	PLPCS(7)	
47	249.	PLPCS(8)	
48	.0	WVLPCS(1)	- VOLUMETRIC FLOW
49	9624.	WVLPCS(2)	
50	24060.	WJLPCS(3)	
51	32080.	WVLPCS(4)	
52		WVLPCS(5)	
53		WVLPCS(6)	
54		WVLPCS(7)	
55		WVLPCS(8)	
56	1387.		HPCS PUMP CURVE:
57	1386.	PHPCS(2)	- PRESSURE
58	1212.		
59	1104.		
60	996.		
61			
62	541.		
63	271.		
64	.0		- VOLUMEIRIC FLOW
65	4812.	WVHPCS(2)	
66	16040.		
67	24060.		
68	32080.		
69	40100.	WVHPCS(6)	
70	48120.	WVHPCS(7)	
71	56140.		
72	1514.7		RCIC PUMP 700 GPM FLOW CURVE:
73	1192.	PRCIC(2)	- PRESSURE
74	165.	PRCIC(3)	
75		PRCIC(4)	
76		PRCIC(5)	
77		PRCLC(6)	
78	14.7	PRCIC(7)	
79	14.7	PRCIC(8)	11. C 10. (1990) # 10 [ 10 [ 01 ]
80	5614.	WVRCIC(1)	- VCLUHETRIC FLOW
81	5614.	WVRCIC(2)	
82		WVRCIC(3)	
83	0.		
84	0.	WVRCIC(5)	
85	0.	WVRCIC(6)	
86	0.	WVRCIC(7)	
87	0.	WVRCIC(8)	TOU NAMED ANTALATION FOR HOUT N/A FOR PERRY
88	-1.E10	ZLHPCI	LOW WATER INITIATION FOR HPCI - N/A FOR PERRY
89	1.E10	FSHPCI	HIGH DRYWELL PRESSURE SET POINT FOR HPCI
90	1.E10	TDHPCI	TIME DELAY FOR HPCI MINIMUM PRESSURE FOR HPCI TURBINE
91	1.E10		LOW WATER LEVEL L2 INITIATION FOR HPCS
92	645.925	LHPCS	HICH DRYWELL PRESSURE SET POINT FOR HPCS
93	16.58		
94	.0075		TIME DELAY FOR HPCS LOW WATER LEVEL L1 INITIATION FOR LPCI
95	636.483	ZLLPCI	HIGH DRYWELL PRESSURE SET POINT FOR LPCI
96		PSLPCI	TIME DELAY FOR LPCI
97	.0103	TDLPCI	time needs for proc

99 100	636.483 16.58	ZLLPCS PSLPCS	RFV-WETWELL PRESS DIFFERENCE TO KEEP ADS OPEN LOW WATER INITIATION FOR LPCS HIGH DRYWELL PRESSURE SET POINT FOR LPCS
101	.0103	TDLPCS	TIME DELAY FOR LPCS
102	-J.E10	PULPCS	RPV-W2TWELL PRESS DIFFERENCE TO CLOSE ADS VALVES
			LOW WATER LEVEL 2 INITIATION FOR RCIC
104	1.E10	FSRCIC	HIGH DRYWELL PRESSURE SET POINT FOR RCIC
105	.0083	TDRCIC	TIME DELAY FOR RCIC
106	44.7	PHRCIC	TIME DELAY FOR RCIC MINIMUM VESSEL PRESSURE FOR RCIC TURBINE
107	68.	HCST	ENTHALPY OF OST
108	3.64E6	WSWHX	EMERG SERVICE WATER FLOW RATE THRU RHR HTXs
			ES MUST BE ENTERED IN ORDER OF INCREASING
** P	RESSURE AC	TUATION SET	FOINTS
109	1151	SRVI	FLOW AFTA OF RELIEF VALVE TYPE #1
			FLOW AREA OF RELIEF VALVE TYPE #2
111	,1151	ASRV3	FLOW AREA OF RELIEF VALVE TYPE #3
			FLOW AREA OF RELIEF VALVE TYPE #4
			5 IS INPUT AS A NEGATIVE NUMBER THEN THE VALVE
			Y INTO THE DRYWELL, IF POSITIVE IT WILL
			PRESSION POOL
			FLOW AREA OF RELIEF VALVE TYPE #5
			NUMBER OF TYPE #1 RELIEF VALVES
115	4	NSRV2	NUMBER OF TYPE #2 RELIEF VALVES
116	4	NSRV3	NUMBER OF TYPE #3 RELIEF VALVES
117	9	NSRV4	NUMBER OF TYPE #4 RELIEF VALVES
118	1	NSRV5	NUMBER OF TYPE #5 RELIEF VALVES
110	1 A A A A A A A A A A A A A A A A A A A	MADC1	NUMBED OF AGE VALUES IN CROUD 1
120	1	NADS2	NUMBER OF ADS VALVES IN GROUP 2
121	2	NADS3	NUMBER OF ADS VALVES IN GROUP 3
122	1	NADS4	NUMBER OF ADS VALVES IN GROUP 4
**	REIT	FF VALVES A	NUMBER OF ADS VALVES IN GROUP 2 NUMBER OF ADS VALVES IN GROUP 3 NUMBER OF ADS VALVES IN GROUP 4 ARE GROUPED WITH NSRV VALVES IN EACH GROUP
**	PARA	METERS 270.	-127 ARE THE HIGH END TRIP PRESSURES -274 ARE THE LOW END TRIP PRESSURES -168 ARE THE DEAD BANDS
**	PARA	METERS 164.	168 ARE THE DEAD BANDS
			PRESSURE SETPOINT FOR #1 RELIEF VALVE
124	1120 7	PSRV2	PRESSURE SETPOINT FOR #2 RELIEF VALVE
195	1120 7	PCRV2	PRESSURE SETPOINT FOR #3 RELIEF VALVE
			PRESSURE SETPOINT FOR #4 KELIEF VALVE
120	1110 7	PCPUS	PRESSURE SETPOINT FOR #5 RELIEF VALVE
128	636 483	71.405	LOW WATER LEVEL L1 FOR INITIATION OF ADS
			HIGH DRYWELL PRESSURE SET POINT FOR ADS
130	0325	TDADS	TIME DELAY FOR ADS ACTUATION
130	1.E10	TCHPCT	INLET TEMP LIMIT FOR HPCI - N/A FOR PERRY
132	571 56	7CLHPS	PUMP CENTER LINE ELEVATION FOR HPCS
133	571.56	ZCLIPT	PUMP CENTER LINE ELEVATION FOR LPCI
			PUMP CENTER LINE ELEVATION FOR LPCS
			INLET TEMP LIMIT FOR RCIC
120	85	TUCU	EMERG SERVICE WATER TEMP (RHT HEAT EXCHANGERS, TCOLD)
			HPCS LOAD PELAY TIME FOR DIESEL
120	.00278	10001	LPCI LOAD DELAY TIME FOR DIESEL
138	.00139	10062	LPCS LOAD DELAY TIME FOR DIESEL
**	.00417	10003	PLED PAUL FERT FILE LAU DIEDEP
	THEFT	upeu ever	EM CAN BE USED TO MODEL ANY INJECTION MODE SUCH AS
			OR FIRE WATER, THE SYSTEM IS TOTALLY DEFINED BELOW
	261	ATON AUTON	on the second the stated to totally because show

.4

**	FOR	THE FIRE W	ATER ALTERNATE INJECTION
**	4.0	UUUDEU	ENTHALPY OF FIRE WATER
143			SPEC VOL OF FIRE WATER
145	135.7	PHPSV(1)	DIESEL DRIVEN FIRE WATER PUMP CURVE:
146	134.7	PHPSV(2)	- PRESSURE
	14.7	(HPSV(3)	
148	14.7	PHPSV(4)	
149	14.7	PHPSW(5)	
150	14.7	PHPSV(6)	
10 au 01 -	the second se	and the second of the second	
152	14.7	PHPSV(8)	- VOLUMETRIC FLOW DRYWELL PRES SET PT FOR MARK III CONTAINMNT SPRAYS
153	0.	WVHPSW(1)	- VOLUMETRIC FLOW
154	1604.	WVHPSW(2)	
155	2074.	WVHPSW(3)	
156	7074.	WVHPSW(4)	
157	/074.	WVHPSW(5)	
158	7074.	WVHPSW(6)	
159	7074.	WVHPSW(7)	
160	7074.	WVHPSW(8)	
162	23.55	PWWSPR	WETWELL PRES SET PT FOR MARK III CONTAINMNT SPRAYS
	.1908	TDSPR	TIME DELAY FC. MARK III CONTAINMENT SPRAYS
164	137	PDSRV1	DEAD BAND FOR CLOSURE OF SRV#1
165	167	PDSRV2	DEAD BAND FOR CLOSURE OF SRV#2
166	100	PDSRV3	DEAD BAND FOR CLOSURE OF SRV#3
167	100	PDSRV4	DEAD BAND FOR CLOSURE OF SRV#4
168			DEAF BAND FOR CLOSURE OF SRV#5
185			PPS-PWW VS. STEAM FLOW TO RCIC TURBINE
186		PTURRI(2)	
		PTURRI(4) PTURRI(5)	
109	74.7	PTURRI(5) PTURRI(6)	
		PTURRI(0)	
191	74.7	PTURRI(8)	
193	41490	WSTRCI(1)	
195	34200	WSTRCI(2)	
195	11000	WSTRCI(2)	
196	6957	WSTRCI(4)	
197	6957	WSTRCI(5)	
198	6957	WSTRCI(6)	
199	6957	wSTRCI(7)	
200	6957	WSTRCI(8)	
201		PHTURH	HIGH TURBINE EXHAUST PRESSURE FOR HPCI
202	34.7	PHTURR	HIGH TURBINE EXHAUST PRESSURE FOR RCIC
203	.0		NOT USED
204	481.3	PHLPCI	LOW RPV PRESSURE PERMISSIVE FOR LPCI
205	497.4	PHLPCS	LOW RPV PRESSURE PERMISSIVE FOR LPCS
206	593.242	ZHISP	HIGH SUPP. POOL LEVEL TRIP FOR HPCS/RCIC SUCT XFER
207	-1.E10	ZLSPR	LOW VESSEL WATER LEVEL FOR CONTAINMENT SPRAYS
208	750	NTHX	NUMBER OF TUBES IN RHR HTX
209	8	NBHX	NUMBER OF BAFFLES IN RHR HTX
210	.0725	XIDTHX	TUBE ID FOR RHR HTX



211	.00542	XTCHX	TUBE CENTER TO CENTER SPACING FOR RHR HTX
212	1047	XTCHX	TUBE CENTER TO CENTER SPACING FOR RHR HTX
213	10 42	YSHY	SHELL LENGTH FOR RHR HTX
214	0025	RCFOUL	FOULING FACTOR FOR RHR HTX
215		KTHX	THERMAL CONDUCTIVITY FOR TUBE WALL (RHR HTX)
210	7.0	NID'	BAFFLE CUT LENGTH FOR RHR HTX
210	1.70	ABCHY	DATFLE CUI LENGIN FUR KNR NIX
217	4.007	XIDSHX	SHELL ID FOR RHR HTX
218	,0729	XSTHX	BUNDLE TO SHELL GAP LENGTH FOR RHR HTX
219	.0	NTUHX1	NTU FOR RHR HTX #1
220	.0	NTUHX2	NTU FOR RHR HTX #2 NUMBER OF RHR LOOP #1 HTX
221	2	NHX1	NUMBER OF RHR LOOP #1 HTX
222	1	NHX2	NUMBER OF RHR LOOF #2 HTX
223	2	FHX	TIPE OF REA HIX(I=STRAIGHT TUBE, Z=U TUBE)
224	24.8	TDBATT	BATTERY OPERATION TIME FOR STATION BLACK-OUT
233	.0	ZHDLPI1	LPCI NPSH FOR GIVEN FLOWS
234	1.3	ZHDLPI2	
235			
236			
237		ZHDLP15	
238		ZHDLPI6	
	.5		
	.5		
			I DOG NDCH LOD OTVEN FLOUR
	.0		LPCS NPSH FOR GIVEN FLOWS
	5.5		
	3.2		
	2.5		
	2.0		
	1.7		
	1.5		
	1.5	ZHDLPS8	
			PUMP CENTER LINE ELEVATION FOR RCIC
		ZCLHPI	PUMP CENTER LINE ELEVATION FOR HPCI
251	.0		NOT USED
252	.0		NOT USED
253	.0		NOT USED
254		TGDWHX(1)	COOLING CURVE FOR DRYWELL COOLERS
255	.0	TGDWHX(2)	TEMP IN DRYWELL VS. HEAT LOSS RATE
256	.0	TGDWHX(3)	
257	.0	TGDWHX(4)	
258	.0	TGDWHX(5)	
259	.0	TGDWHX(6)	
260	.0	TGDWHX(7)	
	.0		
261		TGDWHX(8)	HEAT LOSS RATE FOR DRYWILL CCOLERS
262	.0	QGDWHX(1)	HEAT LUSS RATE FOR DRIVAGE COUDRS
263	.0	QGDWHX(2)	
264	.0	QGDWHX(3)	
265	.0	QGDWHX(4)	
266	.0	QGDWHX(5)	
267	.0	QGDWHX(6)	
268	+0	QGLWHX(7)	
269	.0	QGDWHX(8)	
270	1125.7	PSRVL1	LOW END PRESSURE SETPOINT FOR #1 RELIEF VALVE
271	1125.7	PSRV12	LOW END PRESSURE SETPOINT FOR #2 RELIEF VALVE
272	1125.7	PSRVLL	LOW END PRESSURE SETFOINT FOR #3 RELIEF VALVE



```
273 1135.7 PSRVL4 LOW END PRESSURE SETPOINT FOR #4 RELIEF VALVE
274 1115.7 PSRVL5 LOW END PRESSURE SETPOINT FOR #5 RELIEF VALVE
**
****
                           ***********
**
**@@@ REV 5 ADDITION, THIS EVIMES SECTION IS NEW
**
** THIS EVIMES SECTION DEFINES THE MAAP EVENT MESSAGES FOR EVENT CODES
   1 THRU 250 IN THE PWR CODE, AND 1 THRU 300 IN THE BWR CODE.
**
**
** EXPECTED FORMAT OF THIS SECTION 15;
**
   <NUMBER> <FLAG> <MESSAGE>
**
**
** WHERE <NUMBER> IS THE EVENT CODE NUMBER
             <FLAG> IS THE EVENT FLAG
**
          (MESSAGE> IS THE SVENT CODE MESSAGE
**
**
** EVENT FLAG TOKENS "1", "O", "T", "F", "TRUE", AND "FALSE" ARE
** ACCEPTABLE. BE SURE TO END THIS SECTION WITH THE KEYWORD "END".
** ** COMMENTING ARE ALLOVED, AND THE FOLLOWING EVENT MESSAGES ARE THE
** DEFAULT MAAP MESSAGES, AS PRESENT IN MAAP BLOCK DATA. HENCE, THIS
** SECTION IS NOT NECESSARY IF YOU LEAVE EVENT MESSAGES UNMODIFIED.
** NOTE THAT THE CHARACTER "!" IS TREATED AS A END OF LINE DELIMITOR,
** AND EVERYTHING ATTER "!" IS IGNORED.
**
********************************
*EVTMES
**
    1 THR. 199 SET BY MAAP NOT SETTABLE BY THE USER (INTERNAL CODES)
**
** 200 THRU 399 EITHER SET BY MAAP UR THE USER (EXTERNAL CODES)
** 400 THRU 699 USER DEFINED EVENT CODES
** THEREFORE, CHECK THE NEW LIST PROVIDED IN THIS FILE.
** YOU MAY NEED TO RENUMBER SOME OF YOUR PREVIOUS USER-1 FINED CODES
** TO AVOID COLLISIONS WITH NEW EXTERNAL CODES.
**
** EXPECTED FORMAT OF THIS SECTION 1S;
**
** <NUMBER> <FLAG> <MESSAGE>
**
** WHERE <NUMBER> IS THE EVENT CODE NUMBER
             <FLAG> IS THE EVENT ...G
**
          <MESSAGE> IS THE EVENT CODE MESSAGE
**
**
** EVENT FLAG TOKENS "1", "O", "T", "F", "TRUE", AND "FALSE" ARE
** ACCEPTABLE. BE SURE TO END THIS SECTION WITH THE KEYWORD "END".
** ** COMMENTING ARE ALLOWED, AND THE FOLLOWING EVENT MESSAGES ARE THE
** DEFAULT MAAP MESSAGES, AS PRESENT IN MAAP BLOCK DATA. HENCE, THIS
** SECTION IS NOT NECCESSARY IF YOU LEAVE EVENT MESSAGES UNMODIFIED.
** NOTE THAT THE CHARACTER "!" IS TREATED AS A END OF LINE DELIMITOR,
** AND EVERYTHING AFTER "1" IS IGNORED.
**
  1 T 1 SRV (1113/1073 - 936) OPEN (Gr.P. 1)
  1 F 1 SRV (1113/1073 - 936) CLOSED (GRP 1)
```

2 T 4 SRVs (1113 - 946) OPEN (GRP 2)	
2 F 4 SRVs (1113 - 946) CLUSED (GRP 2)	
5 T ADS PERMISSIBLE-LP PUMP ON	
6 T ADS SILNAL-LOW WATER, HIGH DW PRESSURE	
7 T HPCI ON	
7 F HPCI OFF	
8 T VESSEL FAILED 9 T HIGH VESSEL PRESSURE SCRAM	
12 T LOWER PLENUM WATER SATURATED 12 F LOWER PLENUM WATER SUBCOOLED	
13 T LPCI LOOP 2 ON	
13 F LPCI LOOP 2 OFF	
14 T RHR HTX. #1 ON	
14 F RHR HTX, #1 OFF 15 T RHR HTX, #2 ON	
15 F RHR HTX. #2 OFF 16 T CORE PLATE FAILURE	
17 T CALL HEATUP	
17 F NO LONGER CALLING HEATUP	
18 T HIGH WATER LEVEL IN SUPP. POOL	
18 F NO LONGER HIGH LEVEL IN SP	
19 T FEEDWATER PUMP TRIPPED	
19 F FEEDWATER ON	
20 T ADS ON	
20 F ADS OFF	
21 T CORIUM CONTACTING PEDESTAL FLOOR	
22 T EX-VESSEL STEAM EXPLOSION IN PEDESTAL	
23 T INITIATION SIGNAL RECVD FOR LPCI #2	
23 F INITIATION SIGNAL LOST FOR LPCI #2	
24 T SUCTION PRESS LIMIT REACHED ON LPCI #2	
25 T DIESEL LOADING PERMISSIBLE FOR HPCS	
26 T HPCS ON	
27 F HPCS OFF	
27 T LPCI LOOP 1 ON	
27 F LPCI LOOP 1 OFF	
28 T LPCS ON	
28 F '.PCS OFF	
29 T RCIC ON	
29 F RCIC OFF	
30 T CORE UNCOVERED	
30 F CURE COVERED	
31 T SHROUD WATER LEVEL < ELEVATION AT TOP	OF JET FUMP
31 F SHROUD WATER LEVEL > ELEVATION AT TOP	OF JET PUMP
32 T DIESEL LOADING PERMISSIBLE FOR LPCI	
33 T DIESEL LOADING PERMISSIBLE FOR LPCS	
34 T HP INJECTION SUCTION FROM SUPPRESSION	POOL
34 F HP INJECTION SUCTION FROM CST	

-


4

.

•



35	Т	CORIUM IN LOVER PLENUM QUENCHED
35	F	CORIUM IN LOWER PLENUM NOT QUENCHED
36	T	CORIUM PRESENT IN LOWER PLENUM
36	F	CORIUM NOT PRESENT IN LOVER PLENUM
37	Т	LOW WATER LEVEL IN CST
37	F	NORMAL WATER LEVEL IN CST
38	Т	CORIUM AND WATER PRESENT IN LOWER PLENUM
38	F	CORIUM AND WATER NOT PRESENT IN LOWER PLENUM
39	T	LEVEL 8 HIGH WATER LEVEL
	F	RESET LEVEL 8 TRIP
	T	INITIATION SIGNAL RECVD FOR HPCI
	F	INITIATION SIGNAL LOST FOR HPCI
41		INITIATION SIGNAL RECVD FOR HPCS
41		INITIATION SIGNAL LOST FOR HPCS
42		INITIATION SIGNAL RECVD FOR LPCI #1
42		INITIATION SIGNAL LOST FOR LPCI #1
43		INITIATION SIGNAL RECVD FOR LPCS
43		INITIATION SIGNAL LOST FOR LPCS
44		INITIATION SIGNAL RECVD FOR ACIC
44		INITIATION SIGNAL LOST FOR RCIC
45		HPCI TURBINE PUMP TRIPPED
45		HPCI TURBINE PUMP NOT TRIPPED
46		SUCTION PRESS LIMIT REACHED ON HPCS
47	T	SUCTION PRESS LIMIT FEACHED ON LPCI #1
48	T	SUCTION PRESS LIMIT REACHED ON LPCS
49	T	RCIC TURBINE PUMP TRIPPED
	F	RCIC TURBINE PUMP NOT TRIPPED
50	T	LPCI #1 TO DRYWELL SPRAYS - OPEN
50	F	LPCI #1 TO DRYWELL SPRAYS - CLOSED
51	T	LPCI #2 TO DRYWELL SPRAYS - OPEN
51	F	LPCI #2 TO DRYWELL SPRAYS - CLOSED
52	T	LPCI #1 TO WETWELL SPRAYS - OPEN
	F	LPCI #1 TO WETWELL SPRAYS - CLOSED
53		LPCI #2 TO WETWELL SPRAYS - OPEN
		LPCI #2 TO WETWELL SPRAYS - CLOSED
54	Т	LPCI #1 TO VESSEL - OPEN
54	F	
		LPCI #2 TO VESSEL - OPEN
	F	LPCI #2 TO VESSEL - CLOSED
	Т	LPCI #1 TO SUPPRESSION POOL - OPEN
56		LPCI #1 TO SUPPRESSION POCL - CLOSED
		LPCI #2 TO SUPPRESSION POOL - OPEN
		LPCI #2 TO SUPPRESSION POOL - CLOSED
		LPCI LOOP 3 ON
		LPCI LOOP 3 OFF
		INITIATION SIGNAL RECVD FOR LPCI #3
59	F	INITIATION SIGNAL LOST FOR LPCI #3
60	T	SUCTION PRESS LIMIT REACHED ON LPCI #3
61	Т	1 SRV (1103/1033 - 926) OPEN (GRP 5)
61	F	1 SRV (1103/1033 - 926) CLOSED (GRP 5)
	Т	
		MSIV OPEN
		LOSS OF AC POWER (LOCKED)
		REACTOR SCRAMMED



65 T RECIRC PUMP TRIPPED TURBINE STOP VALVES CLOSED 66 T 66 F TURBINE STOP VALVES OPEN LP FUMP PERMISSIBLE FOR VETVELL SPRAYS 67 T 68 T WETWELL SPRAYS(MARKIII) ON 68 F WETWELL SPRAYS(MARKIII) OFF 69 T HPSW INJECTION ON HPSV INJECTION OFF 69 F PERMISSIBLE FOR RPT 70 T 71 T CRD PUMP ON 71 F CRD PUMP OFF 75 WATER IN CORE SATURATED T 75 WATER IN CORE SUBCCOLED F T CORIUM ENTRAINED IN PEDESTAL 76 76 F CORIUM NO LONGER ENTRAINED IN PEDESTAL WATER ENTRAINED IN PEDESTAL 77 T F WATER NO LONGER ENTRAINED IN PEDESTAL 77 78 T LOW LEVEL TRIP FOR HPCI 78 F RESET LOW LEVEL TRIP FOR HPCI T HIGH DRYWELL PRESSURE FOR HPCI 79 F RESET HIGH DV PRESS. FOR HPCI 79 80 T LOW LEVEL TRIP FOR HPCS F RESET LOW LEVEL TRIP FOR HPCS 80 T HICH DRYWELL PRESSURE FOR HPCS 81 F RESET HIGH DW PRESS. FOR HPCS 81 T LOW LEVEL TRIP FOR RCIC 82 F RESET LOW IEVEL TRIP FOR RCIC 82 T HIGH DRYWELL PRESSURE FOR RCIC 83 F RESET HIGH DW PRESS FOR RCIC 83 LOW LEVEL TRIP FOR LPCI 84 T F RESET LOW LEVEL TRIP FOF LPCI 84 T HIGH DRYWELL PRESSURE FOR LPCI 85 F PESET HIGH DW PRESS. FOR LPCI 85 86 T LPCI FLOW > U F LPCI FLOW = 0 86 195 LPCS FLOW > 0 87 87 F LPCS FLOW = 0T DRYWELL VENT OPEN 88 88 F DRYVELL VENT CLOSED T FIRST CALL TO ICRUST 89 90 T LOW LEVEL TRIP FOR LPCS F RESET LOW LEVEL TRIP FOR LPCS 90 T HIGH DRYWELL PRESSURE FOR LPCS 91 RESET HIGH DV PRESS. FOR LPCS F 91 92 T HIGH RCIC TURBINE EXHAUST F NO LONGER HIGH RCIC TURB. EXHAUST 92 T LOW WATER TRIP FOR ADS 93 RESET LOW WATER TRIP FOR ADS 93 F T HIGH DRYWELL PRESSURE TRIP FOR ADS 94 RESET HIGH DRYWELL PRESSURE TRIP FOR ADS 94 F PEDESTAL DOWNCOMER HAS FAILED 95 T F PEDESTAL DOWNCOMER NOT FAILUD 95 96 T AUX CONDENSER ON 96 F AUX CONDENSER OFF





97	Т	HIGH RPV PRESS INTTIATION FOR ISO COND
97	F	NO HIGH RPV PRES MITIATION FOR ISO COND
- 98	T	RX BLDG FIRE SPRAYS ON
98	F	RX BLDG FIRE SPRAYS OFF
99	Т	RX BLDG CO2 FIRE SUPPRESSION ON
99	F	RX BLDG CO2 FIRE SUPPRESSION OFF
100	Т	H2 BURNING IN RX BLDG
100	F	H2 NOT BURNING IN RX BLDG
101	Т	BURNING IN PEDESTAL
101	F	BURNING OVER IN PEDESTAL
102	Т	CORIUM TEMP. ABOVE CONCRETE MELTING IN PD
102	F	CORIUM TEMP. BELOW CONCRETE MELTING IN PD
103	T	WATER IN PEDESTAL
103	F	NO WATER IN PEDESTAL
104	Т	WATER SATURATED IN PEDESTAL
104	T	WATER NO LONGER SATURATED IN PEDESTAL
105	Т	CORIUM QUENCHED IN PEDESTAL
105	F	CORIUM NOT QUENCHED IN PEDESTAL
106	Т	CORIUM AND WATER PRESENT IN PEDESTAL
106		NO CORIUM OR NO WATER PRESENT IN PD
107	Т	CORIUM TEMP < CORIUM MELTING POINT IN PD
107	F	CORIUM TEMP > CORIUM MELTING POINT IN PD
108	T	FIRST CALL TO FACEZE
109	Т	VETWELL VENT OPEN
109	F	WETWELL VENT CLOSED
110	T	RCIC SUCTION FROM SUPPRESSION POOL
110	F	RCIC SUCTION FROM CST
111	T	PRIMARY SYSTEM COUPLED
111		PRIMARY SYSTEM NOT COUPLED
112	T	MWLP G.T. MWMIN
112	F	MWLI L.E. MWMIN
113	T	ADS VALVES OPEN DUE TO LOW DRYWFLL PRESSURE
113	F	ADS VALVES CLOSED DUE TO HI DRYWELL PRESSURE
114		
		ADS VALVES CLOSED DUE TO LOW RPV PRESSURE
		START TO CALL FISSION PRODUCT MODELS
		FISSION PRODUCT MODELS NOT CALLED
		BURNING IN DRYWELL
116		
		CORIUM TEMP. ABOVE CONCRETE MELTING IN DW
		CORIUM TEMP. BELOW CONCRETE MELTING IN DW
		REVERSE FLOW THROUGH SUPPRESSION POOL VENTS
118		
119		
119		
120		PDW > PPD
120		
121		
121		
122		
122		
123		CORIUM AND WATER PRESENT IN DRYWELL
123		CORIUM AND WATER NOT IN DRYWELL
		CORIUM TEMP < CORIUM "ELTING POINT IN DW

124 F CORIUM TEMP > CORIUM MELTING POINT IN DV 125 T LOW DWNCMR - L PLEN PATH OPEN FOR CIRC 125 F LOW DWNCMR - L PLEN PATH NOT OPEN FOR CIRC T UP DWNCMR - SEP PATH OPEN FOR CIRC 126 F UP DWNCMR - SEP PATH NOT OPEN FOR CIRC 126 T RECIRC LOOP OPEN FOR CIRC 127 F RECIRC LOOP NOT OPEN FOR CIRC 127 TEMP LIMIT REACHED ON HPCI SUCT G 128 T F TEMP LIMIT NOT REACHED ON HPCI SUCTION 128 129 T HIGH TURB EXHAUST FOR HPCI 129 F RESET HIGH TURB EXHAUST FOR HPCI 130 T LOW REV PRESSURE FOR HPCI 130 F RESET LOW RPV PPESSURE FOR HPCI 131 T BURNING IN WETWELL BURNING OVER IN WETWELL 131 F T CORIUM TEMP > CONCRETE MELTING IN VETWELL 132 F CORIUM TEMP < CONCRETE MELTING IN WETWELL 132 133 T VACUUM BREAKERS OPEN 133 F VACUUM BREAKERS CLOSED 134 T WATER IN SUPP. POOL 135 T SUPPRESSION POOL SATURATED 135 F SUPPRESSION FOOL NO LONGER SATURATED 136 T CORIUM QUENCHED IN WETWELL 136 F CORIUM TEMP. ABOVE WATER SATURATION IN WW 137 T CORIUM AND WATER PRESENT IN WETWELL 138 T CORIUM TEMP < CORIUM MELTING POINT IN WW CORIUM TEMP > CORIUM MELTING POINT IN WW 138 F 139 T RX BLDG FIRE WATER DEPLETED RX BLDG FIRE WATER NOT DEPLETED 139 F SUPP POOL LEVEL BELOW VENT PIPE 140 T SUPP POOL LEVEL ABOVE VENT PIPE 140 F 141 T TOP VENT OPEN (MIII) 142 T TOP VENT COVERED (MIII) TOP VENT OPEN & MID VENT COVERED (MIII) 143 T MID VENT OPEN & BOTTOM VENT COVERED (MIII) 144 T BOTTOM VENT OPEN (MIII) 145 T MWCA > O KG. 146 T 146 F MWCA = 0 KG. 147 T BURNING IN MIDDLE CONTAINMENT (MIII) F BURNING OVER IN MIDDLE CONTAINMENT (MIII 147 148 T MWCB > 0 KG. 148 F MWCB = 0 KG. 149 T BURNING IN UPPER CONTAINMENT (MIII) 149 F BURNING OVER IN UPPER CONTAINMENT (MIII) 150 T RX BLDG CO2 SUPPRESSION DEPLETED RX BLDG CO2 SUPPRESSION NOT DELETED 150 F RX BLDG DAMPERS CLOSED 151 T RX BLDG DAMPERS OPEN 151 F T HYDROGEN MIXING SYSTEM ON 152 HYDROGEN MIXING SYSTEM ON 152 F 153 T LOCA SIGNAL FOR UPPER POOL DUMP 154 T UPPER POOL DUMP ACTIVATED 155 T CONTAINMENT PURGE ON 155 F CONTAINMENT FURGE OFF





.

- 78

156	T	1 JNITERS HAV2 POWER
156		IGNITERS DO NOT HAVE POWER
		HYDROGEN MIXING SYSTEM PERMISSIBLE
157	F	HYDROGEN MIXING SYSTEM NO PLRMISSIBLE
		END OF UPPER POOL DUMP
		BATTERY POWER UNALLABLE
159		
160		LOW LEVEL FOR SCRAM
161		HIGH DRYWELL PRESSURE FOR SPRAYS
162		HIGH WETWELL PRESSURE FOR SPRAYS
163		
164		HIGH SUPP. POOL TEMP. FOR RCIC
165		LOW RPV PRESSURE FOR RCIC
166		CORIUM IN VETWELL
166		CORIUM NOT IN WETWELL
168		DRYWELL LEAK K-S PLUGGED
168		DRYWELL LEAK NOT PLUGGED
169		PLUGGED LEAK PATH BLOWN OPEN
169	F	PLUGGED LEAK PATH NOT BLOWN OPEN
170	Т	CORE RADIAL REGION 1 HAS BLOCKED
170	F	CORE RADIAL REGION 1 NOT BLOCKED
171	Т	CORE RADIAL REGION 2 HAS BLOCKED
171		CORE RADIAL REGION 2 NOT BLOCKED
172	T	CORE RADIAL REGION 3 HAS BOUCKED
172		CORE RADIAL REGION 3 NOT BLOCKED
173	Т	CORE RADIAL REGION 4 HAS BLOCKED
173	F	CORE RADIAL REGION 4 NOT BLOCKED
174		CORE RADIAL REGION 5 HAS BLOCKED
174	F	CORE RADIAL REGION 5 NOT BLOCKED
175	T	INITIATION SIGNAL RECEIVED FOR LRYVELL COOLERS
175	F	INITIATION SIGNAL LOST FOR DRYWELL COOLERS
176	1	REACTOR WATER CLEANUP SYSTEM( RVCU ) ON
176	0	REACTOR WATER CLEANUP SYSTEM! RWCU ) OFF
177	1	INITIATION SIGNAL RECEIVED FOR RWCU
177	0	INITIATICN SIGNAL LOST FOR RWCU
178	1	TRIGGER SIGNAL RECEIVED FOR HPCI
178	0	TRIGGER SIGNAL LOST FOR HPCI
179	T	SGTS FILTER AEROSOL LOADING EXCEEDED
		SGTS FILTER AEROSOL LOADING NOT EXCEEDED
180	) 1	TPIGGER SIGNAL RECEIVED FOR HPCS
180	) ()	7 GER SIGNAL LOST FOR HPCS
181	1	GGER SIGNAL RECEIVED FOR RC1.
181	0	) ": IGGER SIGNAL LOST FOR RCIC
182	2 1	HIGH LEVEL TRIP FOR FEED WATER
182	2 0	RESET HIGH LEVEL TRIP FOR FEED WATER
	3 1	L LPCI #1 TO RAD WASTE - OPEN
	3 (	
	4 1	
18		D LPCI #2 TO RAD WASTE - CLOSE
18		HIGH WATER LEVEL RESET SIGNAL RECEIVED FOR HPCI
18		O HIGH WATER LEVEL RESET SIGNAL NOT RECEIVED FOR HPCI
18		1 HIGH WATER LEVEL RESET SIGNAL RECEIVED FOR RCIC
18	2	G HIGH WATER LEVEL RESET SIGNAL NOT RECEIVED FOR RCIC
	7	
all the said		

2 ~

O HIGH WATER LEVEL RESET SIGNAL NOT RECEIVED FOR HPCS 187 DRYWELL COOLERS ON 188 1 DRYVELL COOLERS OFF 188 0 CONT FAILED IN WW DUE TO STRAIN 190 T CONT FAILED IN WW DUE TO OVERPRESSURE 191 T CONT FAILED IN CA DUE TO STRAIN 192 T CONT FAILED IN CA DUE TO OVERPRESSURE 193 T CONT FAILED IN CB DUE TO STRAIN 194 T CONT FAILED IN CB DUE TO OVERPRESSURE 195 T SHUTDOWN COOLING ON 196 T 196 F SHUTDOWN COOLING OFF ** NOTE EVENT CODE 197 IS SET ONLY FOR ONE TIMESTEP IN WHICH ** EITHER THE REACTOR VESSEL OR CONTAINMENT FAILED. 197 T EITHER REACTOR VESSEL OR CONTAINMENT JUST FAILED AUTOMATIC PLOT SCALING IS ON 198 T EQUALLY SPACED PLOT SCALING IS ON 198 F CONTAINMENT FAILUPE OR VENT OPEN 199 T 200 T HPCI MAN ON HPCI NOT MAN ON 200 F 201 Τ HPCI LOCKED OFF 201 F HPCI NOT LOCKED OFF 202 T LPCI LOOP 1 MAN ON LPCI LOOP 1 NOT MAN ON 202 F LPCI LOOP 1 LC KED OFF 203 T F LPCI LOOP 1 NOT LOCKED OFF 203 204 T HPCS MAN ON 204 F HPCS NOT MAN ON T HPCS LOCKED OFF 205 F HPCS NOT LOCKED OFF 205 T LPCS MAN ON 206 F LPCS NOT MAN ON 206 207 T LPCS LOCKED OFF 207 F LPCS NOT LOCKED OFF 208 T FEEDWATER MAN ON 208 F FEEDWATER NOT MAN ON T FEEDWATER MAN OFF 209 F FEEDWATER NOT LOCKED OFF 209 T RCIC MAN ON 210 F RCIC NOT MAN ON 210 211 T RCIC LOCKED OFF 211 F RCIC NOT LOCKED OFF TURBINE STOP VALVE CLOSED 212 T TURBINE STOP VALVE OPEN 212 F TURBINE BYPASS CLOSED T 213 TURBINE BYPASS OPEN 213 F 214 T MSIVS MAN OPEN 214 F MSIVS NOT MAN OPEN MSIVS LOCKED CLOSED 215 T 215 F MSIVS NOT LOCKED CLOSED PEDESTAL DOWNCOMER FAILED 216 T 216 F PEDESTAL DOWNCOMER NOT FAILED T 1 SRV (1113/1073 - 936) MAN OPEN (GRF 1) 217 217 F 1 SRV (1113/1073 - 936) NOT MAN OPEN (GRP 1) 218 T 1 SRV (1113/1073 - 936) LOCKED CLOSED (GRP 1)





218	F	1 SRV (1113/1073 - 936) NOT LOCKED CLOSED	(GRP )	)
219	Т	4 SRVs (1113 - 946) MAN OPEN	(GRP 2	2)
219	F	4 SRVs (1113 - 946) MAN OPEN 4 SRVs (1113 - 946) NOT MAN OPEN	(GRP 2	2)
220	T	4 SRVs (1113 - 946) LOCKED CLOSED	(GRP 2	2)
		4 SRVs (1113 - 946) NOT LOCKED CLOSED		
221	75	4 SRVs (1113 - 1013) MAN OPEN	(GRP )	1
221	P	4 SRVs (1113 - 1013) MAN OPEN 4 SRVs (1113 - 1013) COT MAN OPEN	(CRP 1	6
200	Ŧ	4 SRVs (1113 - 1013) LOCKED CLOSED	(CRP )	15
322		4 SRVs (1113 - 1013) NOT LOCKED CLOSED	(CRP )	21
293	1	9 CDU2 (1123 - 1013) MAN OPEN	(CPD )	27.
000	1	9 5045 (1123 - 1013) MAN VIEN	(ORF +	17
223	E	9 SNVS (1123 - 1013) NOT MAN UTEN	(unr ·	12
269	1	9 SKVS (1123 - 1013) LOUKED CLOSED	(GRP 6	17
224	1	9 SRVs (1123 - 1013) MAN OPEN 9 SRVs (1123 - 1013) NOT MAN OPEN 9 SRVs (1123 - 1013) NOT MAN OPEN 9 SRVs (1123 - 1013) LOCKED CLOSED 9 SRVs (1123 - 1013) NOT LOCKED CLOSED ADS MAN OPEN	(GRP 4	12
220	T	ADS MAN OPEN		
223	E.	ADS NOT MAN OPEN		
226	T	ADS LOCKED CLOSED ADS NOT LOCKED CLOSED		
226	F	ADS NOT LOCKED CLOSED		
227	Т	RHR HTX #1 MAN ON RHR HTX #1 NOT MAN ON		
227	F	RHR HTX #1 NOT MAN ON		
		RHR HTX #1 LOCKED OFF		
228		RHR HTX #1 NOT LOCKED OFF		
229	T	RHR HTX #2 MAN ON		
		RHR HTX #2 NOT MAN ON		
230	Τ	RHR HTX #2 LOCKED OFF		
		RHR HTX #2 NOT LOCKED OFF		
231	Т	LPCI LOOP 2 MAN ON		
231		LPCI LOOP 2 NOT MAN ON		
232		LPCI LOOP 2 LOCKED OFF		
232		LPCI LOOP 2 NOT LOCKED OFF		
233		LPCI LOOP 1 TO DRYWELL SPRAYS-MAN ON		
233		LPCI LOOP 1 TO DRYWELL SPRAYS-NOT MAN ON		
234		LPCI LOOP 1 TO DRYWELL SPRAYS-LOCKED OFF		
234		LPCI LOOP 1 TO DRYWELL SPRAYS-NOT LOCKED (		
		LPCI LOOP 2 TO DRYWELL SPRAYS-MAN ON		
235	F	LPCI LOOP 2 TO DRYWELL SPRAYS-NOT MAN ON		
236	Т	LPCI LOOP 2 TO DRYWELL SPRAYS-LOCKED OFF		
236	F	LPCI LOOP 2 TO DRYWELL SPRAYS-NOT LOCKED (	DFF	
237				
237	F	LPCI LOOP 1 TO WETWELL SPRAYS-NOT MAN ON		
238	Т	LPCI LOOP 1 TO WETWELL SPRAYS-LOCKED OFF		
238	F	LPCI LOOP 1 TO WETWELL SPRAYS-NOT LOCKED (	OFF	
239	Т	LPCI LOOP 2 TO VETWELL SPRAYS-MAN ON		
239		LPCI LOOP 2 TO WETWELL SPRAYS-NOT MAN ON		
240		LPCI LOOP 2 TO WETWELL SPRAYS-LOCKED OFF		
240		LPCI LOOP 2 TO WETWELL SPRATS-NOT LOCKED (	OFF	
241		LPCI LOOP 1 ALIGNED TO VESSEL		
241		LPCI LOOP 1 NOT ALIGNED TO VESSEL		
242		LPCI LOOP 1 TO VESSEL-LOCKED OFF		
242		LPCI LOOP 1 TO VESSEL-NOT LOCKED OFF		
243				
243		LPCI LOOP 2 NOT ALIGNED TO VESSEL		
244		LPCI LOOP 2 TO VESSEL-LOCKED OFF		
244				
215				
6.64		MARY MONT I IN DOLLURDDING LOOP-MAN ON		

245 F LPCI LOOP 1 TO SUPPRESSION FOOL-NOT MAN ON 246 T LPCI LOOP 1 TO SUPPRESSION POOL-LOCKED OFF F LPCI LOOP 1 TO SUPPRESSION POOL-NOT LOCKED OFF 246 LPCI LOOP 2 TO SUPPRESSION POOL-MAN ON 247 T F LPCI LOOP 2 TO SUPPRESSION POOL-NOT MAN ON 247 T LPCI LOOP 2 TO SUPPRESSION POOL-LOCKED OFF 248 F LPCI LOOP 2 TO SUPPRESSION POOL-NOT LOCKED OFF 248 T SUCTION FOR HPCS MAN LINED UP TO SUPP POOL 249 249 F SUCTION FOR HPCS NOT MAN LINED TO SUPP POOL 250 T LOSS OF AC POWER F AC POWER RESTORED 250 251 T LOSS OF DIESEL POWER F DIESEL POWER RESTORED 251 T AUX BLDG DAMPERS SHUT 252 F AUX BLDG DAMPERS NOT SHUT 252 T NO H2 OR CO BURNING ALLOWED 233 F 52 AND CO BURNING ALLOWED 253 T SUCTION FOR RCIC MAN LINED UP TO SUPP POOL 254 254 F SUCTION FOR RCIC NOT MAN LINED TO SUPP POOL 255 T REACTOR MAN SCRAMMED T BREAK IN PRIMARY SYSTEM (LOCA) 256 256 F NO BREAK IN PRIMARY SYSTEM 257 T ATWS RUN T SLC INJECTION BEGUN 258 259 T LPCI LOOP 3 MAN ON 259 F LPCI LOOP 3 NOT MAN ON 260 T LPCI LOOP 3 LOCKED OFF F LPCI LGOP 3 NOT LOCKED OFF 260 T 1 SRV (1103/1033 - 926) MAN OPEN (GRP 5) 261 261 F 1 SRV (1103/1033 - 926) NOT MAN OPEN (GRP 5) 1 SRV (1103/1033 - 926) LOCKED CLOSED (GRF 5) T 262 26.2 F 1 SRV (1103/1033 - 926) NOT LOCKED OFF (GRP S) 263 T VACUUM BREAKERS-MAN OPEN VACUUM BREAKERS-NOT MAN OPEN 263 F 264 T VACUUM BREAKERS-LOCKED CLOSED 264 F VACUUM BREAKERS-NOT LOCKED CLOSE HYDROGEN MIXING SYSTEM MAN ON 265 T HYDROGEN MIXING SYSTEM NOT MAN ON 265 F HYDROGEN MIXING SYSTEM LOCKED OFF 266 T HYDROGEN MIXING SYSTEM NOT LOCKED OFF 266 F UPPER POOL DUMP MAN OPEN 267 T UPPER POOL DUMP NOT MAN OPEN 267 F UPPER POOL DUMP LOCKED CLOSED 268 T UPPER POOL DUMP NOT LOCKED CLOSED 268 F CONTAINMENT PURGE MAN OPEN 269 T CONTAINMENT PURGE NOT MAN OPEN 269 F CONTAINMENT PURGE LOCKED CLOSED 270 T CONTAINMENT PURGE NOT LOCKED CLOSED 270 F O LPCS PUMPS ON 271 T DEFAULT LPCS PUMPS ON 271 F 2 LPCS PUMPS ON 272 T 272 F DEFAULT LPCS PUMPS ON 273 T 4 LPCS PUMPS ON 273 F DEFAULT LPCS PUMPS ON





274	Т	HPSW INJECTION MAN ON
274	F	HPSV INJECTION NOT MAN ON
275	T	HPSW INJECTION LOCKED OFF
275	F	HPSW INJECTION NOT LOCKED OFF
276	Τ	AUX BLDG SPRAYS ON
276	F	AUX BLAS SPRAYS OFF
277	T	CRD PUMP MAN ON
277	F	CRD PUMP NOT MAN ON
278	Τ	CRD PUMP LOCKED OFF
278	F	CRD PUMP NOT LOCKED OFF
279	Т	OPEN DRYWELL VENT
280	T	CLOSE DRYWELL VENT
281	T	LOCA OUTSIDE OF CONTAINMENT - OPEN
281	F	LOCA OUTSIDE OF CONTAINMENT - CLOSED
282	Т	OPEN VETVELL VENT
283	T	CLOSE WETWELL VENT
284	Т	DRYWELL COOLERS ON
284	F	DRYWELL COOLERS OFF
285	T	AUX CONDENSER MAN ON
285	F	AUX CONDENSER NOT MAN ON
286	Т	AUX CONDENSER MAN OFF
286	F	AUX CONDENSER NOT MAN OFF
287	Т	AUX BLDG CO2 ON
287	F	AUX BLDG CO2 OFF
288	T	SHUTDOWN COOLING MAN ON
288	F	SHUTDOWN COOLING NOT MAN ON
289	Τ	SHUTDOWN COOLING MAN OFF
289	F	SHUTDOWN COOLING NOT MAN OFF
290	Т	IGNITORS FORCED ON
290	F	IGNITORS NOT FORCED ON
291	1	MECHANISTIC DRYWELL COOLER MAN ON
291	0	MECHANISTIC DRYWELL COOLER NOT MAN ON
292	1	MECHANISTIC DRYWELL COOLER LOCKED OFF
292	0	MECHANISTIC DRYWELL C TR. NOT LOCKED OFF
293	1	RVCU MAN ON
293	0	RWCU NOT MAN ON
294	1	FEEDWATER NOT TRIPPED BY MSIV CLOSURE
294		FEEDWATER TRIPPED BY MSIV CLOSURE
295	1	RCIC FLOW CONTROL ON
295	0	RCIC FLOW CONTROL OFF
296	Т	BAR GRAPH DISPLAYS ON
296	F	BAR GRAPH DISPLAYS OFF
297	Т	HEAT-UP DISPLAY STATUS ON
297		HEAT-UP DISPLAY STATUS OFF
298		VESSEL DISPLAY STATUS ON
		VESSEL DISPLAY STATUS OFF
299		CONTAINMENT DISPLAY STATUS ON
		CONTAINMENT DISPLAY STATUS OFF
		THIS FLAG IS SIMILIAR TO 197, IE., THAT IT IS AUTOMATICALLY SET
		VF OR CF IS TRUE ONLY FOR ONE TIMESTEP. HOWEVER, THIS FLAG IS FOR RESETTING CUMULATIVE FIGURE OF MERITS MONITORED BY TOPSRT.
300		RESET CUMULATIVE FIGURE OF MERITS
301		LPCI LOOP 1 TO RADVASTE - MAN ON
301	0	LPCI LOOP 1 TO RADWASTE - NOT MAN ON

302	1	LPCT LOOP	1 TO RADWASTE - LOCKED OFF
302			1 TO RADWASTE - NOT LOCKED OFF
	1		2 TO RADWASTE - MAN ON
-	õ		2 TO RADWASTE - NOT MAN ON
303	1		2 TO RADVASTE - LOCKED OFF
304	- G		2 TO RADWASTE - NOT LOCKED OFF
	0		CONDENSER TUBE RUPTURED
	1		CONDENSER TUBE NOT RUPTURED
305			
309			MIXING CLOSES UPON CONT. ISOLATION
309			DOES NOT CLOSE UPON CONT. ISOLATION
310	1		YWELL PURGE LINE AVAILABLE
310			WELL PURGE LINE NOT AVAILABLE
311	1		CITY TEMPERATURE LIMIT (HCTL) - ON
311			CITY TEMPERATURE LIMIT (HCTL) - OFY
312	1		. MAREUP WATER - MAN ON
312	0		. MAKEUP WATER - MAN OFF
320	T		RESTART THIS TIMESTEP BURNING IN CA - FLAG ON
400	1		BURNING IN CA - FLAG OFF
400	0		BURNING IN CA - FLAG OFF
401	1		BURNING IN CB - FLAG OFF
401	0	a second the second	
402	1		BURNING IN DRYWELL - FLAG ON BURNING IN DRYWELL - FLAG OFF
402	0		
403	1		BURNING IN PEDESTAL - FLAG ON
403	0		BURNING IN PEDESTAL - FLAG OFF BURNING IN WETVELL - FLAG ON
404	1		
404	0	TIME SIEP	BURNING IN WETWELL - FLAG OFF
END **			
			**************
		ON PRODUCTS	
			, ************************************
			ON PRODUCT MASSES IN CORE REGION
01	TIAT	935.82	Xe Xe
02		62.15	Kr
		40.12	
04		56.44	Rb
05		500.44	Cs
06		151.68	Sr
07		253.97	Ba
08		87.52	Y
09		237.65	La
10		645.72	Zr
11		.24	Nb
12		573.19	Mo
13		142.20	Tc
14		416.00	Ru
15		.24	Sb
16		84.44	Te
17		503.09	Ce
18		194.44	Pr
19		655.20	Nd
20		130.07	Sm
21		.24	Np

```
22
      1796.74
                   Pu
26
      2253.04
                   SN
27
                   MN
      1358.14
28
      2530.86
                   B4C
     FOR DF VALUES ENTER A VALUE GE 1 OR SET EQUAL TO O TO HAVE CODE
**
**
     CALCULATE THEM
**
  DF=1 ASSUMED FOR NOBLE GASES
** DF=1000 ASSUMED FOR ALL OTHER VAPORS
               FDFSP DRYWELL VENTS DECONTAMINATION FACTOR
31
               FDFRV SRV DECONTAMINTION FACTOR
32
         0.
33
    0.028
               FP GRP #1.
                           NOBLES
               FP GRP #2.
                            CSI
34
     0.151
               FP GRP #3.
35
     0.0194
                            TE02
               FP GRP #4,
                           SRO
36
     0.062
37
    0.05
              FP GRP #5,
                           M002
              FP GRP #6,
                           CSOH
38
    0.1
               FP GRF #7,
                          BAO
39
    0.
               FP GRP #8, LA203
40
    0.
    0.
               FP GRP #9, CEO2
41
               FP GRP #10, SB
42
    0.
              FP GRP #11, TE2
     0.0194
43
              FP GRP #12, U02
44
     0.
**
                                ***************
*****
*HEATUP
                         ********
*********
                       LENGTH OF ACTIVE FUEL
01
    12.57
               XZFUEL
     .0174
                        RADIUS OF FUEL PELLET [TO THE CLAD WITH NO GAP]
               XRFUEL
02
                         THICKNESS OF CLADDING
03
       .00267
               XTCLAD
                          TOTAL MASS OF ZR IN ASSEMBLY CAN
               MZRCAN
04
     72987.2
                          NOT USED
05
     0.0
               MBCR
                      CAN WALL IHICKNESS
      .0100
               XZRCAN
06
** NODE 1,1 IS BOTTOM-CENTER, 1,10 IS TOP-CENTER, 2,1 IS SECOND RADIAT.
** RING OUT FROM CENTER AT THE BOTTOM OF THE CORE, ETC
              FFEAK(1, 1) PEAKING FACTOR FOR NODE (1, 1)
07
     .772
      .796
               FPEAK(2, 1)
                            PEAKING FACTOR FOR NODE (2, 1)
80
               FPEAK(3, 1)
                            PEAKING FACTOR FOR NODE (3, 1)
09
     .930
                             PEAKING FACTOR FOR NODE (4, 1)
               FPEAK(4, 1)
10
     .647
                             PEAKING FACTOR FOR NODE (5, 1)
      .308
               FPEAK(5, 1)
11
               FPEAK(1, 2)
                             PEAKING FACTOR FOR NODE (1, 2)
15
     1.384
                             PEAKING FACTOR FOR NODE (2, 2)
     1.400
               FPEAK(2, 2)
16
                             TEAKING FACTOR FOR NODE (3, 2)
17
     1.649
               FPEAK(3, 2)
                             PEAKING FACTOR FOR NODE (4, 2)
     1.244
               FPEAK(4, 2)
18
     ,566
               FPEAK(5, 2)
                             PEAKING FACTOR FOR NODE (5, 2)
19
                             PEAKING FACTOR FOR NODE (1, 3)
               FPEAK(1, 3)
23
     1,459
                             PEAKING FACTOR FOR NODE (2, 3)
24
     1.402
               FPEAK(2, 3)
               FPEAK(3, 3)
                             PEAKING FACTOR FOR NODE (3, 3)
25
     1.573
                             PEAKING FACTOR FOR NODE (4, 3)
     1.364
               FPEAK(4, 3)
26
                             PEAKING FACTOR FOR NODE (5, 3)
               FPEAK(5, 3)
27
     .669
                             PEAKING FACTOR FOR NODE (1, 4)
     1.378
               FPEAK(1, 4)
31
                             PEAKING FACTOR FOR NODE (2, 4)
               FPEAK(2, 4)
32
     1,369
                             PEAKING FACTOR FOR NODE (3, 4)
               FPEAK(3, 4)
33
     1.442
                             PEAKING FACTOR FOR NODE (4, 4)
               FPEAK(4, 4)
34
     1.260
                             PEAKING FACTOR FOR NODE (5, 4)
               FPEAK(5, 4)
35
     .689
```

39	1.290	FPEAK(1, 5)	PEAKING FACTOR FOR NODE (1, 5)
40	1.270	FPEAK(2, 5)	PEAKING FACTOR FOR NODE (2, 5)
41	1.332	FPEAK(3, 5)	PEAKING FACTOR FOR NODE (3, 5)
42	1.156	FPEAK(4, 5)	PEAKING FACTOR FOR NODE (4, 5)
43	.668	FPEAK(5, 5)	FEAKING FACTOR FOR NODE (5, 5)
47	1.238	FPEAK(1, 6)	PEAKING FACTOR FOR NODE (1, 6)
48	1 207	FPEAK(2, 6)	PEAKING FACTOR FOR NODE (2, 6)
49	1 250	FPEAK(3, 6)	PEAKING FACTOR FOR NODE (3, 6)
50	1 082	PPEAK(4, 6)	PEAKINC FACTOR FOR NODE (4, 6)
51	6/5	EPEAK(S. 6)	PEAKING FACTOR FOR NODE (5, 6)
21	1 010	EDEAR(1 7)	PEAKING FACTOR FOR NODE (1, 7)
55	1.210	FFERN(1, 7)	PEAKING FACTOR FOR NODE (2, 7)
	1,1/0	EFERN(4, 7)	PEAKING FACTOR FOR NODE (3, 7)
57	1.207	PERAN(J, 7)	PEAKING FACTOR FOR NODE (4, 7)
58	1.020	FFERK(4) //	PEAKING FACTOR FOR NODE (5, 7)
	.621	TPEAK(D, /)	PEAKING FACTOR FOR NODE (5, 7) FEAKING FACTOR FOR NODE (1, 8)
63	1,168	FFEAR(1, 0)	PEAKING FACTOR FOR NODE (2, 8)
64	1.220	FPEAK(2, 8)	PEAKING FACTOR FOR NODE (2, 8)
	1.136	FPEAK(3, 8)	PEAKING FACTOR FOR NODE (4 8)
66	-926	FPEAK(4, 8)	PEAKING FACTOR FOR NODE (4, 8)
67	.573	FPEAK(D, 6)	PEAKING FACTOR FOR NODE (5, 8) PEAKING FACTOR FOR NODE (1, 9)
71	1.049	FPEAK(1, 9)	PEAKING, FACTOR FOR NODE (1, 7)
72	1.059	FPEAK(2, 9)	PEAKING FACTOR FOR NODE (2, 7)
73	.919	FPEAK(3, 9)	PEAKING FACTUR FTR NODE (5, 7)
74	.729	FPEAK(4, 9)	PEAKING FACTOR FOR NODE (4, 7)
75	.465	FPEAR(5, 9)	PEAKING FACTOR FOR NODE (5, 9)
79	.544	FPEAK(1,10)	PEAKING FACTOR FOR NODE (1,10)
80	.519	FPEAK(2, 10)	PEAKING FACTOR FOR NODE (2,10)
81	.438	FPEAK(3,10)	PEAKING FACTOR FOR NODE (1, 9) PEAKING FACTOR FOR NODE (2, 9) PEAKING FACTOR FOR NODE (3, 9) PEAKING FACTOR FOR NODE (4, 9) PEAKING FACTOR FOR NODE (5, 9) PEAKING FACTOR FOR NODE (5, 9) PEAKING FACTOR FOR NODE (2,10) PEAKING FACTOR FOR NODE (2,10) PEAKING FACTOR FOR NODE (3,10) PEAKING FACTOR FOR NODE (4,10) PEAKING FACTOR FOR NODE (5,10) UNHEATED FUEL LENGTH ABOVE TAF INITIAL CLADDING OXIDE THICKNESS MASS OF B4C IN ALL CONTROL BLADES MASS OF STAINLESS STEEL IN ALL CONTROL BLADES FRACTION OF FE IN STAINLESS STEEL FRACTION OF CR IN STAINLESS STEEL.
82	.344	FPEAK(4, 10)	PEAKING FACTOR FOR NODE (4,10)
83	.228	FPEAK(5,10)	PEAKING FACTOR FOR NODE (3,10)
87	0	XCHIM	UNHEATED FUEL LENGTH ADOVE TAF
88	.000125	XIZROX	INITIAL CLADDING OXIDE THICKNESS
89	2531.	MBCBLA	MASS OF B4C IN ALL CONTROL BLADES
90	36370.	MSSB! A	MASS OF STAINLESS STEEL IN ALL CONTROL BLADES
91	.74	MFFESS	FRACTION OF FE IN STAINLESS SIEEL
92	.18	MFCRSS	FRACTION OF CR IN STAINLESS STEL.
93	.08	MFNISS	FRACTION OF NI IN STAINLEYS SILEL
94	2600.	TCBMP	MELTING POINT OF CONTROL BLADE
**			
***	********	*****	*****************
*HT	SINKS		
***	********		**********
	1600.		A OF WALL #1
02	9313.	AHS2 AREA	A OF WALL #2
03	6086.		A OF WALL #3
04	10372.	AHS4 ARE	A OF WALL #4
05	15637.		A OF WALL #5
06			A OF WALL #6
07		8 AHS7 ARE	A OF WALL #7
08		AHS8 ARE	A OF WALL #8
09		KHS1 THE	RMAL CONDUCTIVITY OF WALL #1
10		KHS2 THE	RMAL CONDUCTIVITY OF WALL #2
11		KHS3 THE	RMAL CONDUCTIVITY OF WALL #3
12	26.0		RMAL CONDUCTIVITY OF WALL #4



1	3	26.0		THERMAL CONDUCTIVITY OF WALL #5
1	4	26.0	KHS6	THERMAL CONDUCTIVITY OF WALL #6
1	5	26.0		THERMAL CONDUCTIVITY OF WALL #7
- 1	6	.80	KHS8	THERMAL CONDUCTIVITY OF #ALL #8
1	7	6.0	XHS1	THICKNESS OF WALL #1
. 1	8	5.0	XHS2	THICKNESS OF WALL #2
1	9	5.0		THICKNESS OF WALL #3
2	0	.125	XHS4	THICKNESS OF WALL #4
2	1	.125		THICKNELS OF WALL #5
	22	.125	XHS6	THICKNESS OF WALL #6
	13	.125	XHS7	THICKNESS OF WALL #7
	14	3.6	XHS8	THICKNESS OF WALL #8
2	25	.0833	XLHSI1	INNER LINER THICKNESS FOR WALL #1
	26	.0208	XLHSI2	INNER LINER THICKNESS FOR WALL #2
	27	.041	XLHS13	INNER LINER THICKNESS FOR WALL #3
	8	.00067	XLHSI4	INNER LINER THICKNESS FOR WALL #4
	29	.00067	XLHSI5	INNER LINER THICKNESS FOR WALL #5
	30	.00067	XLHSI6	INNER LINER THICKNESS FOR WALL #6
	31	.00067	XLHSI7	INNER LINER THICKNESS FOR WALL #7
	32	.0	XLHSI8	INNER LINER THICKNESS FOR WALL #8
	33		XLHS01	OUTER LINER THICKNESS FOR WALL #1
	34	.0	XLHS02	the second
	35		XLHS03	OUTER LINER THICKNESS FOR WALL #3
	36	.0		OUTER LINER THICKNESS FOR VALL #4
	37	.0	XLHS05	OUTER LINER THICKNESS FOR WALL #5
	38	.0	XLHS06	OUTER LINER THICKNESS FOR WALL #6
	39	.0	XLHS07	OUTER LINER THICKNESS FOR VALL #7
	40	.0	XLHS08	OUTER LINER THICKNESS FOR WALL #8
	41	162.	DHS1	DENSITY OF WALL #1
1	42	150.	DHS2	DENSITY OF WALL #2
	43	154.	DHS3	DENSITY OF WALL #3
- 4	44	490.	DHS4	
	45	490.	DHS5	DENSITY OF WALL #5
1.1.4	46	490.	DHS6	DENSITY OF WALL #6
	47	490.	DHS7	DENSITY OF WALL #7
	48	150.	DHS8	DENSITY OF WALL #8
1	49	.190	CPHS1	SPECIFIC HEAT FOR WALL #1
1.1.4	50	.193	CPHS2	SPECIFIC HEAT FOR WALL #2
	51	.191	CPH53	SPECIFIC HEAT FOR WALL #3
	52	.110	~1 784	SPECIFIC HEAT FOR WALL #4
	53	.110	rh. 5	SPECIFIC HEAT FOR WALL #5
	54	.110	PHS	SPECIFIC HEAT FOR WALL #6
	55	.110	CPHS7	SPECIFIC HEAT FOR WALL #7
	56	.193	CPHS8	SPECIFIC HEAT FOR WALL #8
	**AL	L OF THESE	EQUIPME	NT HEAT SINKS ARE LOCATED IN GAS VOL. OF COMPARTMENT
	57	. 0	HEQPD	MASS OF EQUIPMENT IN PEDESTAL
	58	3420000.	MEQDW	MASS OF EQUIPMENT IN DRYWELL
	59	100000.	MEQWW	MASS OF EQUIPMENT IN WETWELL
	60	439000.	MEQCA	MASS OF EQUIPMENT IN COMPT A
	61	3900000.	MEQCB	MASS OF EQUIPMENT IN COMPT B
	62	.0	AEQPD	AREA OF EQUIPMENT IN PEDESTAL
	63	46000.	AEODW	AREA OF EQUIPMENT IN DRYWELL
	64	85782.	AEQWW	AREA OF EQUIPMENT IN WETWELL
	65	60600.	AEQCA	AREA OF EQUIPMENT IN COMPT A

Page H.5 - 33

66		AEQCB	
67	.0	HTOUTW	HEAT TRANSFER COEFF. AT OUTER VALL
68	.0	RGAPI1	INNER LINER TO WALL GAP RESISTANCE #1
69	.0	RGAP12	INNER LINER TO WALL GAP RESISTANCE #2
70	.0	RGAPI3	INNER LINER TO WALL GAP RESISTANCE #3
71	.0	RGAPI4	INNER LINER TO VALL GAP RESISTANCE #4
72	.0	RGAP15	INNER LINER TO WALL GAP RESISTANCE #5
73	.0	RGAF16	INNER LINER TO WALL GAP RESISTANCE #6
74	-0	RGAPI7	INNER LINER TO WALL CAF RESISTANCE #7 INNER LINER TO WALL GAP RESISTANCE #8
75	,0	RGAPI8	OUTER LINER TO WALL GAP RESISTANCE #0
76	.0	RGAP01	OUTER LINER TO WALL GAP RESISTANCE #2
77	.0	RGAPO2	OUTER LINER TO WALL GAP RESISTANCE \$2
78	.0	RGAP03	OUTER LINER TO WALL GAP RESISTANCE #4
79	.0	RGAP04	OUTER LINER TO WALL GAP RESISTANCE #5
80	.0	RGAP05	OUTER LINER TO WALL GAP RESISTANCE #6
81	.0	RGAP06	OUTEP LINER TO VALL GAP RESISTANCE #7
82	.0	RGAP07	OUTER LINER TO WALL GAP RESISTANCE #8
83	.0	RGAP08	MASS OF EQUIP. HEAT SINK WETVELL (SUBMERGED)
84	.0	MEQVWS	AREA OF EQUIP. HEAT SINK WETWELL (SUBMERGED)
85 86	.0	AEQWWS XTGAP1	GAF THICKNESS FROM LINER TO WALL FOR #1
87	.0	XTGAP1 XTGAP2	GAP THICKNESS FROM LINER TO WALL FOR #1
88	.0	XTGAP3	GAP THICKNESS FROM LINER TO WALL FOR #3
89	.0	XTGAP4	GAP THICKNESS FROM LINER TO WALL FCA #4
90	.0	XTGAP5	GAP THICKNESS FROM LINER TO WALL FOR #5
91	.0	XTGAP6	GAP THICKNESS FROM LINER TO WALL FOR #6
92	.0	XTGAF7	GAP THICKNESS FROM LINER TO WALL FOR #7
93	.0	XTGAP8	GAP THICKNESS FROM LINER TO WALL FOR #8
94	.0	ZEGPD	
95	49.	ZEODY	
96	14.	ZEQVW	
97	13.7		AVERAGE HEIGH" OF WETWELL EQUIPMENT - SUBMERGED
98	21.	ZEQCA	AVERAGE HEIGPT OF COMPT A EQUIPMENT
99	48.	ZEQCB	AVERAGE HEIGHT OF COMPT B EQUIPMENT
**			
****	*******	*****	*******************************
*INI	TIAL CONDI	ITIONS	
****	*******	********	************
01			CORE POWER
02	1039.6	PPSO	
03	14.7	PPDO	INITIAL PRESSURE IN PEDESTAL
04	14.7	PDWO	INITIAL PRESSURE IN DRYWELL
05	14.7	PWWO	INITIAL PRESSURE IN WETWELL
06	593.083		the second se
0.7		ZSPWWO	
08	145.	TPDO	INITIAL TEMPERATURE IN PEDESTAL
09	144.		INITIAL TEMPERATURE IN DRYWELL
10	89.	TWWO	INITIAL TEMPERATURE IN WETWELL
11	89.	TWSPO	
12	651.615	ZWSHO	INITIAL ELEVATION OF WATER IN THE SHROUD
		MWCBO	MASS OF WATER IN UPPER POOL (MARKIII ONLY)
14	33343.	VCSTO	VOLUME OF WATER IN CONDENSATE STORAGE TANK
**			
***	********	********	************



**@@@ REV 5/6 ADDITION, NEW SECTION FOR USER-INPUT TIMESTEP CONTROL ** ** INTEGRATION CONTROL ** ** SI units only alloved ** ** ALLOWED SYNTAXES: ** ** 1. Fractional change limitation: ** INDEX R X-NAME F-NAME F-CHANGE X-MIN X-MAX TRUE #1 FALSE #2 ** where: ** INDEX = index 6. limiting variable ** R = a fractional change (ie, a rate) limitation ** X-NAME = state or aux variable name ** F-NAME = rate of change variable name ** F-CHANGE = fractional change ** X-MIN = minimum x value for limitation ** X-MAX = maximum x value for limitation ** The "TRUE #1" & "FALSE #2" are optional: ** TRUE #1 = used when event #1 true ** FALSE #2 = used when event #2 false ** when code #1 is true the control is on ** when code #2 is false the control is on ** either "TRUE" or "FALSE", or both "TRUE" & "FALSE" conditions ** can be used ** Example: FMWCOR 0.04 J.E3 1.E10 FALSE 8 ** 1 R MWCOR ** timestep limiting variable 1 is MWCOR, rate of change FMWCOR ** its fractional change is 4% maximum during a timest p ** if MWCOR < 1.e3 kg it is not used to limit the timestep ** if MWCOR > 1.e10 kg it is not used to limit the timestep ** it is used when event code 8 is false, ie reactor vessel intact ** ** 2. Threshold specified explicitly: ** INDEX T X-NAME F-NAME THRESH ** INDEX T+ X-NAME F-NAME THRESH ** INDEX T- X-NAME F-NAME THRESH ** where: ** T = a threshold limitation both uscending and descending ** T+ = an ascending threshold limitation ** T- = a descending threshold limitation ** THRESH = the threshold value ** Example: ** 2 T+ PPS FPPS 7.75E6 ** timestep limiting variable 2 is PPS, rate of change is FPPS ** the timestep will be limited if PPS attempts to cross 7.75 MPa ** in an ascending manner (ie, as if a relief valve were to open) ** ** 3. Threshold specified by reference to parameter input: ** INDEX T X-NAME F-NAME T-NAME ** where: ** T-NAME = the variable name for the threshold ** Example:

```
T+ PPS FPPS PSRV1
** 3
** timestep limiting variable 3 is PPS, rate of change is FPPS
** the timestep will be limited if PPS attempts to cross PSRV1
   in an ascending manner (ie, as if a safety valve were to open)
**
    and PSRV1 is input in the parameter file already as the
**
   safety valve setpoint
**
**
*INTEGRATION
**
** CRITICAL QUANTITIES FOR TIME LOST INFORMATION
**
   CATEGORY 1 -- GAS MASSES & TEMPERATURES
**
                          0.04
                                 1.E1
                                        1.E10
                FMGPS
1
   R
       MGPS
                                 1.E2
                          0.05
                                        1.E4
                FTGPS
2
    R
       TGPS
                                1.E1
                                        1.E10
3
       MGPD
                FMGPD
                         0.04
    R
                                1.E2
                                        1.E4
                FTGPD
                          0.05
4
    R
       TGPD
                          0.04
                                1.E1
                                        1.E10
5
                FMGDW
    R
       MGDW
              FTGDW
                          0.05
                                1.E2
                                       1.E4
6
    R
       TGDW
                                1.E1
                                        1.E10
7
       MGWW
                FMGWW
                          0.04
    R
                          0.05
                                 1.E2
                                        1.E4
8
    R
       TGWW
                FTGWW
                                        1.E10
                                1.E1
9
                FMGCA
                          0.04
    R
       MGCA
                          0.05
                                1.E2
                                        1.E4
10
       TGCA
                FTGCA
   R
                                        1.E10
                                1.E1
   R
       MGCB
                FMGCB
                          0.04
11
                FTGCB
                          0.05
                                1.12
                                        1.E4
12
   R TGCB
** CATEGORY 2 -- WATER MASSES, ETC.
                FMWPD
                          0.04
                                1.E4
                                        1.E10
13 R MWPD
14 R MWDW
                FMVDV
                          0.04
                                 1.E4
                                        1.E10
**15 MSPDW = mass of water in wetwell downcomers (not used)
                               1.E2
                                        1.E10
16 R MSPWW
                FMSPWW
                          0.04
                                                 FALSE 8
                                1.E3
                                        1.E10
17
   R
       MWCOR
                FMWCOR
                          0.04
18
   R
       MWOSH
                FMWOSH
                          0.04
                                1.E3
                                       1.E10
                FMWJET
                          0.04
                               1.E2
                                        1.E10
19
   R
       MWJET
20 R
       XROF
                FXROF
                          0.04
                                 1.E-3 1.E3
                                 1.E10 1.E15
             FMWAC
                          0.04
21 R MWAC
** CATEGORY 3 -- CRUST THICKNESSES
**22 XUCPD = upper debris crust thickness in pedestal (not used)
**23 XLCPD = lower debris crust thickness in pedestal (not used)
**24 XUCDW = upper debris crust thickness in dryvell (not used)
      XLCDW = lower debris crust thickness in drywell (not used)
**25
      XUCWW = upper debris crust thickness in wetwell (not used)
**26
      XLCWW = lower debris crust thickness in vetwell (not used)
**27
** CATEGORY 4 -- HARDWIRED AS IN ORIGINAL INTGRT
**28 DEBRIS INTERNAL ENERGY IN PEDESTAL
      DEBRIS INTERNAL ENERGY IN DRYWELL
 **29
**30 GAS MASS IN AUX BLDG
 **31 GAS TEMP IN AUX BLDG
      SUBROUTINE HEATUP REQUIRED TIME STEP
 **32
 **33 RPV CIRCULATION REQUIRED TIME STEP
 **
 END
 **
                         **************
 *ISOLATION CONDENSER
 **************
```

01	-1.	VOLIC	VOLUME OF ISOLATION CONDENSER
**			SPECIFY A NEGATIVE VOLUME TO INDICATE ABSENCE OF
**			ISOLATION CONDENSER IN THE PLANT
02	0.		INITIAL MASS OF WATER IN ISOLATION CONDENSER
03	0.	TWICI	INITIAL WATER TEMPERATURE IN ISOLATION CONDENSER
04	0.	PPSIC(1)	
05	0.	PPSIC(2)	TABLE OF
06	0.	PPSIC(3)	
07	0.	PPSIC(4)	ISOLATION CONDENSER HEAT REMOVAL RATE
08	0.		
09	0.		VS.
10	0.	PPSIC(7)	
11	0.	PPSIC(8)	PARTIAL PRESSURE OF STEAM IN PRIMARY SYSTEM
12	0.	QIC1(1)	
13	0.	QIC1(2)	
14	0.	01C1(3)	THE HEAT REMOVAL RATE BECOMES ZERO WHEN THE TUBES
15	0.		ARE UNCOVERED OR WHEN TUBES RUPTURE.
16			
17	0.	QIC1(6)	
18	0.	QIC1(7)	
19	Ŏ.	QIC1(8)	
20		ZWMAKE	WATER LEVEL TO WHICH THE MAKE-UP WATER FILLS THE IC
21			FLOW RATE OF MAKE-UP WATER
22	0.		ENTHALPY OF MAKE-UP WATER
24		PICI	INITIAL PRESSURE INSIDE THE ISOLATION CONDENSER
25		ARUPIC	TUBE RUPTURE AREA
26		XZRUP	HEIGHT OF THE TUBE RUPTURE ABOVE THE FLOOR OF IC
27	ŏ.		AREA OF THE ISOLATION CONDENSER VENT
**		NY DIT	THIS VENT IS OPEN TO AMBIENT
28	0	XWIC1(1)	THE THIS IS STOLET IN THE STOLET
29		XWIC1(2)	TABLE OF
30		XWIC1(3)	
31		XVIC1(4)	WATER HEIGHT IN ISO. COND.
32		XWIC1(5)	
**		**********	VS.
33	0	FWIC1(1)	
34	0.	FWIC1(2)	FRACTION OF TUBE H.T. AREA COVERED
35		FWIC1(3)	and a set of the set o
36		FWIC1(4)	
37			
**	0.	LHIOI(S)	
38	0.	XWIC2(1)	
		XWIC2(1)	TABLE OF
39		XWIC2(3)	A CANADA V.A
40	0.	XWIC2(3) XWIC2(4)	WATER HEIGHT IN ISO. COND.
41	0.	XWIC2(5)	BUTTLE DET THE ALL REAL PROPERTY.
42 **	0.	ARIUG(2)	VS.
	0	VOLW2(1)	
43	0.	VOLW2(1) VOLW2(2)	and a second of the second secon
44	0.	VOLW2(2)	
45	0.	VOLW2(3)	
46 47	0.	VOL W2(5)	<this 'volic'<="" as="" be="" must="" same="" td=""></this>
4/ **	0.	*UD#2(2)	
***	******	*****	************
A		COLUMN TALE ANALY OF STREET, THE STREET, S	



Page H.5 - 37


*MOD	EL PARAMET	ERS FOR B	***********
01	.00500	FRCOEF	FRICTION CUEFFICIENT FOR CORIUM DISCHARGED
**	.00200	1	FROM VESSEL AS CALCULATED IN SUBROUTINE VFAIL
02	.10D0	FMAXCP	ONCE THE CORE FRACTION MELTS TO A VALUE BELOW
**			FMAXCP, THE REMAINDER OF THE CORE SLUMPS TO THE
**			LOWER PLENUM TO FAIL THE CORE PLATE
03	8.8D0	HTBLAD	FUEL CHANNEL TO CONTROL BLADE HEAT TRANS. COEFF
	52.8D0		NON-RADIATIVE FILM BOILING HEAT TRANS. COEFF.
05	10.D0	FDF1	DF FOR WATER POOLS OVER CORE DEBRIS (EXCLUDING
**			SUPPRESSION POOL) OF 1 METER DEPTH
06	0.02D0	FEFFDR	DROP COLLECTION EFFICIENCY FOR SPRAY SWEEP-OUT
07	2240.D0	TCLMAX	CLAD FAILURE TEMP TO BEGIN FISSION PRODUCT REL
12	.1D0	FTENUR	UNOXIDIZED ZR MASS FRACTION LIMIT.
**			THIS APPLIES TO NUREG-0772/KELLY FISSION PRODUCT
**			RELEASES CALC'S ONLY. (SEE MODEL PARAMETER
**			FPRAT #41 BELOW) IF CALC'D UNOXIDIZED ZR NODAL
**			MASS IS GREATER THAN THIS LIMIT, THEN THE TE
**			RELEASE RATE IS LIMITED, OTHERWISE THE TE RELEASE
**			RATE IS NOT AFFECTED AS RECOMMENDED IN NUREG-0956.
大大			EXPERIMENTAL EVIDENCE HAS SHOWN THAT SIGNIFICANT AMOUNT RELEASED TE TENDS TO BIND WITH UNOXIDIZED ZR.
**			THIS PARAMETER IS NOT TO BE CONFUSED WITH MODEL
**			PARAMETER FTFREL (#43) BELOW.
**	100 100 100		FISSION PRODUCT RELEASE RATES DIVIDED BY THIS VALUE
13	1,0D	SCALFP	IN FPRATB
**		TERONOR	CORIUM-CRUST HEAT TRANSF. COEFF. USED IN DECOMP
14	176.DO		
15	0.16D0	XCMX	FLOOR (MARK II ONLY) [DUMMY]
**	0.0300	XDCMSP	THE REPORT OF THE ACTOR OF THE ACTOR OF THE PATTE
16 **	0.03D0	ADCHAF	INTO SUPPRESSION POOL (MARK II ONLY) [DUMMY]
17	2.78D-5	TDSTX	
1/	2.700-3	TROTA	STEAM EXPLOSION
18	5300	FCHTUR	The second s
19	3 700	FDROP	DROPLET CRITICAL FLOW PARAMETER
20	3.D0	FFLUOD	FLOODING FLOW PARAMETER
21	1.35	FSPAR	PARAMETER FOR BOTTOM-SPARGED STEAM VOID FRACTION
22	3.D0	FVOL	PARAMETER FOR VOLUME SOURCE VOID FRACTION MODEL
23	1.4D-4		ENTRATNMENT EFFECTIVE EMPTYING TIME
**			GIVEN THAT CORIUM AND WATER ARE ENTRAINED FROM PEDESIAL
**			HOW LONG WILL IT TAKE TO EXPELL ENTIRE MASS
24	.90D0	EV	EMISSIVITY OF WATER
25			EMISSIVITY OF WALL
26	.85D0		EMISSIVITY OF CORIUM
27	.6D0	EG	EMISSIVITY OF GAS
28	.85D0	EEQ	EMISSIVITY OF EQUIPMENT
29	0.5D0	FOVER	FRACTION OF CORE SPRAY FLOW ALLOWED TO BYPASS CORE
**	THIS PARA	METER IS	USED TO COMPUTE THE FRACTION OF CORE SPRAY THAT GOES
**			GION AND REFLOODS THE CORE FROM THE BOTTOM NUMBER OF PENETRATIONS FAILED IN LOWER HEAD AT TIME
30		NPF	NUMBER OF FENEIRALIONS FRIEDD IN DORER HEAD AT THE
**			OF VESSEL FAILURE DOWNCOMER PERIMETER PER METER FROM PEDESTAL DOOR
31		FCDCDW	(MARK II ONLY) [DUMMY]
**	a com	moure.	COEFFICIENT FOR CHF CORRELATION IN PLSTM
32	0.10D0	FCHF	CODIFICIDATI FOR OUR CONTRACT AN AN AND AND



33	.7000	FCDBRK	DISCHARGE CUEFFICIENT FOR PIPE BREAK
34	.13D0	FENTR	NUMBER TO MULTIPLY KUTATELADZE CRITERION BY TO
			REPRESENT DIFFICULTY (GT 1.DO) OR EASE (LT 1.DO)
**			FOR MATERIAL TO BE BLOWN OUT OF CAVITY
35		SCALU	SCALING FACTOR FOR ALL BURNING VELOCITIES
36	1.00	SCALH	SCALING FACTOR FOR HT COEFFICIENTS TO PASSIVE
**	Con Provident		HEAT SINKS
37	1.5D0	FUMIN	CLADDING SURFACE MULTIPLIER TO ACCOUNT FOR POTENTIAL
**	1.2.2		CLAD RUPTURE
38	2.5		PARTICLE COLLISION GAMMA SHAPE FACTOR
39		FSHAPE	CHI SETTLING SHAPE FACTOR
40	8.0	FAERDC	RATIO OF AIRBORNE AEROSOL MASS TO THE MASS WHICH
**			WOULD LEAVE YOU IN STEADY-STATE WITH THE CURRENT
**			SOURCE STRENGTH. THIS IS USED TO CONTROL THE SELECTION
		TO PO PO A MY	OF DECAY VS STEADY-STATE AEROSOL SETTLING CORRELATIONS
41	-1	FFRAT	FISSION PRODUCT RELEASE CORRELATION & CONTROL
**			ENTER A VALUE TO SELECT CORRELATIONS:
**			+1 OR -1 NUREG-0772 MODEL
**			+2 OR -2 IDCOR/EPRI STEAM OXIDATION MODEL
**			ENTER A SIGN TO SELECT RELEASE LIMITATIONS:
**			+ SIGN: RELEASE RATES DEFINED BY CORRELATIONS
**			- SIGN: RELEASES FURTHER LIMITED BY SATURATION
**			VAPOR FRESSURE FOR NONVOLATILES AND STRUCTURE THE + SIGN IS USEFUL WHEN THE IDCOR BLOCKAGE MODEL
**			IS SELECTED, SINCE FLOW IN CORE NODES CAN GO TO
**			ZERO DURING BLOCKAGE, THUS STOPPING RELEASES.
**			THE - SIGN IS USEFUL WHEN NO BLOCKAGE IS
**			ALLOWED AND THERE IS ALWAYS BULK FLOW.
**			THE + SIGN ALSO IS USEFUL FOR SENSITIVITY.
**			THE - SIGN ALLOWS THE PHYSICAL MECHANISM OF
**			SATURATION TO BE CONSIDERED FOR RELEASE.
**			HOWEVER, DIFFUSION COEFFICIENTS, VAPOR
**			PRESSURES AND GEOMETRY ARE QUITE UNCERTAIN .
42	1.0	PCSIVP	GROUP 2 (CSI) & GROUP 6 (CSOH) VAPOR PRESSURE
**			MULTIPLIER
**			NEG NUMBER USES ANL CSOH VAP PRESS,
**			POS NUMBER USES SANDIA CSOH VAP PRESSURE
43	0	FTEREL	O=TE BOUND UP IN ZIRCALOY, 1=NOT BOUND UP
**			THIS APPLIES TO CUBICOITTI FISSION PRODUCT
**			RELEASES CALC'S ONLY. (SEE MODEL PARAMETER
44	7 96	DIVERS	FPRAT #41 ABOVE)
**	1.20	PFLUG	PRESSURE DIFFERENCE TO BLOW OPEN PLUG IF LEAK PATH HAS
	0.066	VUIDAR	PLUGGED AS A RESULT OF AEROSOLS WIDTH OF LEAK PATH
**	MAAP ACCIN	ARLIGAN	PDEVUELL EATLINE OF LEAVAGE OPENING TO A LONG FLEE
**	WITH AREA	EQUAL TO	HE DRYWELL FAILURE OR LEAKAGE OPENING IS A LONG SLIT ADWLEK(SEE DRYWELL INPUT) AND AN EFFECTIVE WIDTH EQUAL
**	TO XHLEAK	BASED UPON	N THESE TWO VALUES THE LENGTH OF THE SLIT CAN BE
**	CALCULATED	)	A ANALO AND
			MOREVITZ COEFF FOR PLUGGING
47	4040.	TEUTEC	CORE NODE EUTECTIC TEMPERATURE FOR MELTING NODE
48	107.	LHEU	LATENT HEAT OF FUSION OF EUTECTIC
	1.D-6	XRSEED	SEED RADIUS FOR HYGROSCOPIC FORMATION
50	0.00	TIDCF	IF EVENT CODE 216 IS SET TO 1 TO FAIL PEDESTAL
**			DOWNCOMERSTHEN THE DOWNCOMERS WILL FAIL TIDCF

a

11,16 -



.0

11

,0 12 NDCPD NUMBER OF PEDESTAL DOWNCOMERS (MARK II) NOT USED 12 .0 301. 14 ASEDPD AEROSOL SEDIMENTATION AREA 15 AIMPPD PEDESTAL TOTAL IMPACTION AREA PEDESTAL MINIMUM GRATE DIAMETER (OR THICKNESS) 16 XDIMPD 17 PEDESTAL FLOW AREA THRU GRATE .0 AGRAPD PEDESTAL-VETVELL OVERFLOW ELEVATION 18 1.E10 ZVPDWW PEDESTAL SUMP TOTAL AREA 19 4.0 APSUMP ELEVATION AT BOTTOM OF PEDESTAL SUMP 20 573.35 ZPSUMP XRBRPD CHARACTERISTIC RADIUS OF PEDESTAL CAVITY FOR H2 BURNS 9.8 21 22 28.3 XHBRPD CHARACTERISTIC HEIGHT OF PEDESTAL CAVITY FOR H2 BURNS THIS IS FLOOR TO CEILING ** 法安 **** *********** ** MAAP BWR PLOT FILES ******** ** **000 REV 5 ADDITION, THIS PLTMAP SECTION IS NEW ** ** YOU CAN HAVE UP TO 25 PLOT FILES AND UP TO 99 VARIABLES. ** BEGIN EACH PLOT FILE SECTION WITH THE WORK "PLOTFIL" FOLLOWED BY ** THE UNIT NUMBER YOU WANT THE FILE WRITTEN TO. A NEGATIVE UNIT NO. ** WILL FORCE BINARY OUTPUT. ** ** NEXT. SELECT THE VARIABLES YOU WANT TO BE PLOTTED BY SIMPLY ** SPECIFYING THE VARIABLE NAMES. PLOT FILES 41 THRU 48 DEFINED BELOW ** ARE IDENTICAL TO THE "OLD" HARDWIRED MAAP PLOT FILES. ** ** FOR THE CASE OF A VARIABLE NOT PRESENT IN THE MAAP COMMON BLOCK BUT ** YOU WANT TO PLOT IT OUT (OR USE IT IN USER DEFINED EVENTS CODES), ** COMMON/XPLTX/ PLT(500) WAS PROVIDED EXPRESSLY FOR THAT PURPOSE. ** INSERT THE LINE "COMMON/XPLTX/ PLT(500)" INTO THE ROUTINE THAT ** HAS THE LOCAL VARIABLE YOU WANT TO SAVE, AND ASSIGN THE VALUE OF ** THE VARIABLE TO ONE OF THE ARRAY PLT INDICES. THEN SELECT THAT ** ARRAY INDICE TO BE PLOTTED IN THE PLOTFIL SECTION. ** ** BE SURE TO END THIS SECTION WITH THE KEYWORD "END", AND ** ** COMMENTING IS ALLOWED. ** ** A NEW ADDITION TO THE OLD PLTFIL SCHEME IS THE CONSTRAINTS TO ** THE MINIMUM/MAXIMUM PLOT DT AS DETERMINED BY THE AUTODT PLOT SCALER. ** PREVIOUSLY UNDER THE OLD AUTODT SCHEME, THE PLOT SPACING BETWEEN THE ** PLOTTED DATA POINTS CAN BE AS SMALL AS MAAP TIMESTEP OR AS LARGE AS ** THE MAAP RUN TIME. THIS ADDITION WILL PROVIDE REASONABLE CONTROL OF ** THE WAY PLOTTING DATA POINTS MAY TURN OUT, EG., ELIMINATION OF ** VERY NOISY (IE., MANY DATA POINTS OVER SMALL TIME INTERVAL) AND ** VERY COARSE (IE., FEW DATA POINTS SPREAD OVER LARGER TIME INTERVAL) ** PLOTS. PRESENTLY, THE PLOT FREQUENCY IS SET TO A MINIMUM OF 1 SEC. ** AND MAXIMUM OF 5 MINUTE AS SPECIFIED BELOW. SOME MAY FIND THIS ** UNSUITABLE AND MAY WANT TO ALLOW LARGER OR SMALLER FREQUENCY. THE ** FORMAT TO SPECIFY THE PLOT FREQUENCY CONSTRAINTS IS 大大 FREQ <MINIMUM PLOT DT> <MAY!MUM PLOT DT> ** **

```
** WHERE THE MAX/MIN PLOT DT IS SUPPLIED IN SECONDS. NOTE THAT PLOT
** FREQUENCY CONSTRAINTS APPLIES TO ALL PLOT FILES.
**
** PLOT FILES CAN ALSO BE SETUP VIA INPUT DECK THROUGH LOCAL PARAMETER
** CHANGE. SIMPLY SPECIFY 25,0,0 FOLLOWED BY THE SYNTAX EXPLAINED,
** PRACTICALLY IDENTICAL TO THE SETU? BELOW BUT WITHOUT THE *PLTMAP
** LINE) AND BE SURE TO FND PLIMAP INPUT WITH THE KEYWORD END.
大大
*PLTMAP
**
PLOTFIL 41 / PERRY PLOT FILE . PL1
**
XCNDVP
XCNPDP
ZCMDV
ZCMPD
ZWPD
WVHPS.
WVLPS
WVRCI
WVLP1
WVLP2
XHCMLP
XWCOR
XWSH
XVJET
XWDW
XSPDW
XSPWW
WCRD
PDW
PPD
PPS
PCB
PDVVV
QCORE
T15P
T110P
 TCMDW
 TGDV
 TGCA
 TCMPD
 TGPD
 TGPS
 TWSP
 TGCB
 TGWW
 VLCSTP
 MGLODE
 MU2CT
 MCOGLO
 MH2GLO
 MO2DWP
 MSTDVP
```

MU2DWP				
MCRUST				
MLCMLP				
MU2PDP				
WH2COR WSTBRK				
WWBRK				
WSTCFW				
NFCODV				
NFC2DW				
NFH2DV				
NF02DW NF3TDW				
NFCOCA				
NFC2CA				
NFH2CA				
NF02CA				
NFSTCA				
NFCOPD NFC2PD				
NFH2PD				
NF02PD				
NFSTPD				
NFCOCB				
NFC2CB				
NFH2CB NF02CB				
NFSTCB				
NFCOVV				
NFC2WW				
NFH2VV				
NF02VV NFSTVV				
WLDIKM #*				
	. 42 / PERRY P	LOT FILF . PL2		
**				
FMCSIP				
FMC2.0				
FMCSIV FMCSIR				
FREL(1	,			
FREL(2				
FREL(3	)			
FREL(4				
FREL(5 FREL(6				
FREL(7				
FREL(8				
PREL(9				
FREL(1				
FREL(1				
FREL(1) MFPTC	•)			
MFPTP				


MEPE	REX(3)		
MFPF	REX(4)		
	REX(5)		
	REX(6)		
	REX(7)		
	REX(8) REX(9)		
	REX(10)		
	REX(11)		
	REX(12)		
**			
ENC	7015		
**			
***	*****	******	***************************************
	IMARY SYSTEM		****
	*****		***************************************
01	79.01	AFLCOR	FLOW AREA OF REACTOR CORE
02	0/.1/	ALISE	FLOW AREA IN LOWER SHROUD CORE BYPASS FLOW AREA
03	34.77	ALCH	FLOW AREA IN UPPER SHROUD
	47.72	HCRD	SPECIFIC ENTHALPY OF FLOW IN CRD TUBES
06	395,96	HFW	SPECIFIC ENTHALPY OF FEEDWATER
07	343761.	MU2PS	TOTAL MASS OF UO2 IN CORE
	748		NUMBER OF FUEL ASSEMBLIES IN REACTOR CORE
09	64	NPINS	NUMBER OF FUEL RODS IN A FUEL ASSEMBLY
			NUMBER OF CRD TUBES
	5.63	NOFPS	ETNRIBLE ENERGY STORED IN FUEL (FULL POWER SECONDS)
			DELAY TIME FOR MSIV CLOSURE
		TDSCRM	DELAY TIME FOR FULL SCRAM TOTAL EFFECTIVE IRRADIATION TIME FOR CORE
14	11828.	TIRRAD	CRD PUMP CURVE:
15	1400.	WUCRDII	- VOLUMETRIC FLOW
17	2166.	WVCRDT3	- VODORDINIO I DOM
18	2166.	WVCRDI4	
		WVCRDI5	
20		WVCRDI6	
21	2166.	WVCRDI7	
22	2166.	WVCRD18	
23	1047.7	PCRD1	- PRESSURE
24	14.7	PCRD2	
25	14.7	PCRD3	
26	14.7	PCRD4	
27	14.7	PCRD5	
28 29	14.2 14.7	PCRD6 PCRD7	
30	14.7	PCRD8	
31	1.778E7	WEWMAX	MAXIMUM FEEDWATER FLOW RATE (RUN OUT FLOW)
32	5.389E6	WBPMAX	MAXIMUM TURBINE BYPASS FLOW RATE
33	.1437	NXCORE	EXIT CORE QUALITY AT TIME ZERO
34	16.158	XDCORE	REACTOR CORE DIAMETER TO INNER SHROUD WALL
35	70.305	XHRV	INTERIOR HEIGHT OF REACTOR VESSEL
36		XRRV	INTERIOR RADIUS OF REACTOR VESSEL
37		ZBJET	
38	609.016	ZBRDT	ELEVATION AT POTTOM OF CRD TUBES

	4				ь.
	8			18	
3					
	3	şa			
	9	-	24	20	e

39	647.844	ZBSEP	ELEVATION AT BOTTOM OF STEAM SEPARATORS
			ELEVATION AT BOTTOM OF REACTOR VESSEL
			ELEVATION AT CORE PLATE
42	631,171	ZTIET	ELEVATION AT TOP OF JET PUMPS
42	12 056	AIPT	TOTAL AREA OF JET PUMPS
44	635 202	TTOAT	ELEVATION AT TOP OF ACTIVE FJEL
	657.785	STORE	ELEVATION AT TOP OF STEAM SEPARATORS
	651 615	2135F	ELEVATION AT TOP OF STEAM SEPARATORS ELEV AT NORMAL SHROUD LVL (SAME AS INITIAL COND: ZWSHO)
	651.615	ZWINORM	ELEV AT NORMAL SHRUUD LVL (SAME AS INITIAL COND: ZWSHO)
	619.206	ZLOCA	ELEVATION AT BREAK
	2.702	ALOCA	AREA OF BREAK
	653.574	ZWL8	ELEVATION AT LEVEL L8 TRIP
	619.206	ZSRR	ELEVATION ON RPV WALL FOR RECIRC PUMP SUCTION PIPE
51	650.040	ZSCRAM	LOW WATER LEVEL L3 SCRAM
52	1094.4	PSCRAM	HIGH PRESSURE SCRAM SETPOINT
53	19500	MCSPT	MASS OF COLE SUPPORT PLATE
54	.734	TOSLC	TIME FOR SCRAM WITH SLC - 1 PUMP
55			RECIRC PUMP COAST DOWN CURVE:
			- TIME AFTER TRIP
		TIRR(3)	3.6.1785 (333.3.578) 8.87.6.8
58	.001667		
59		TIRR(5)	
60		TIRR(6)	
61	.004167		
62	.01111	TIRR(8)	
	1.00		
	.76		
	.58		
	.44		
67	.33	FWRR(5)	
68	.25	FWRR(6)	
	.13		
70	.00	FWRR(8)	
71	113.	HSLC	INLET ENTHALPY OF SLC
72	14.7	PSLC(1)	SLC FLOW CHRUE.
73	214.7	PSLC.2)	- PRESSURF
74	414.7	Delegal	- IRDSOURT
75	614.7		
76	814.7	PSLC(4)	
77		PSLC(5)	
	1014.7	PSLC(6)	
78	1214.7	PSLC(7)	
79	1414.7	PSLC(8)	
80	352.9	WVSLC(1)	- FLOW
81	352.9	WVSLC(2)	
82	352.9	WVSLC(3)	
83	352.9	WVSLC(4)	
84	349.7	WVSLC(5)	
85	349.7	WVSLC(6)	
86	349.7	WVSLC(7)	
87	349.7	WVSLC(8)	
88	1.2E-5		DELAY TIME FOR RECIRC PUMP TRIP
89	636.474	ZLMSIV	LOW WATER LEVEL L1 FOR MSIV CLOSURE
90	645.915	ZLRPT	100 VATER LOVE: 10 FOR RECTRO NUMBERS
91	1.E10	PHRPT	LOW WATER LEVEL L2 FOR RECIRC PUMP TRIP
92	16.58	PDWSCM	HIGH VESSEL PRESSURE FOR RECIRC PUMP TRIP
20	10.00	PDWSUM	HIGH DRYWELL PRESSURE FOR SCRAM

93	.031	FENRCH	NORMAL FUEL ENRICHMENT
94	23121.2	EXPO	AVERAGE BURNUP IN MVD/TONNE
95	.655	FCR	PRODUCTION OF U239 TO ABSORPTION IN FUEL
96	1.13	FFAF	RATIO OF FISSILE ABSORPTION TO TOTAL FISSION
97	.70	FQFR1	FISSION POWER FRACTION OF U235 AND PU241
98	.266	FOFR2	FISSION POWER FRACTION OF PU239
99	.08	FQFR3	FISSION POWER FRACTION OF U238
100		XPCRDT	PITCH OF CRU TUBES
		XDCRDT	OUTER DIAMETER OF CRD TUBE
101	54	NINST	NUMBER OF INSTRUMENT TUBES
102	.0120	XTHCPD	THICKNESS OF CRD TUBE WALL
103		XDINST	OUTER DIAMETER OF INSTRUMENT TUBE
104	.1692	XDRIVE	LOVER CRD DRIVE OUTER DIAMETER
105	.500	VWCRD	SPECIFIC VOLUME OF CRD WATER
106	.01627		SPECIFIC VOLUME OF SLC WATER
107	.01632	VWCST	DRYWELL PRESS WHICH WILL CLOSE ADS VALVES
108	64.7	PADSC	DW PRESS WHICH WILL ALLOW ADS TO RE-OPEN IF CLOSED
109	64.7	PADSO	THICKNESS OF LOWER VESSEL HEAD
110	.750	XTRV	INIUKNESS UP DUNE COACT DOWN
111	.000000		FEEDWATER PUMP COAST DOWN:
112	.0000278	A A A A A A A A A A A A A A A A A A A	- TIME
113		TIFWCD3	
114	.001111	TIFWCD4	
115	.001444	TIFWCDS	
116	.001944	TIFWCD6	
117	.002333	TIFWCD7	
118		TIFWCD8	
119		WFWCD1	- MASS FLOW
120		WFWCD2	
123			
122			
123		WFWCD5	
124		WFWCD6	
12		WFWCD7	
12		WFWCD8	
12		PLMSIV	LOW RPV PRESSURE FOR MSIV CLOSURE
12		ZMSL	FIRVATION AT CENTER LINE OF MAIN STEAM LINE
12		XATWS()	1) NSAC 70 ATVS POWER VS RPV LEVEL REFERENED TO DAF
13		XATVS(	1 ( 1 ( 1 ( 1 ( 1 ( 1 ( 1 ( 1 ( 1 ( 1 (
13		XATWS (	
		XATWS(	
13		FQATWS	
1.			
	.206		
	39 .13	FQATVS	
	40 .08		
	41 .0	FQATWS	
	42 .0	FQATW	
	43 .0	FQATV	
	44 .0	FQATV	MASS OF CORE SHROUD FROM TAF TO BOTTOM OF CORE
	45 5570		MASS OF CORE TOP QUIDE
1	46 3180	O MTG	MADD UT COMD LOT GOLDE

- 24			
8			
6			
ы			
1			
	-	85	87



*TIMING DATA **** *** MAXIMUM ALLOWED TIME STEP 01 20.DO TDMAX TDMIN MINIMUM ALLOVED TIME STEP 02 1.D-3 MAXIMUM MASS CHANGE (%) FOR INTEGRATION 2.5D-2 FMCHMX 03 MAXIMUM GAS TEMP CHANGE FRACTION FOR INTEGRATION 04 2.5D-2 FUCHMX MIN FISS PROD MASS ALLOWED TO CONTROL TIME STEP 05 2.5D-2 MDFPMN ** ***** *TOPOLOGY ***************** ***** ** **THIS SECTION DEFINES THE WAYS THAT THE VARIOUS AUX NODES ARE CONNECTED **TOGETHER--THERE ARE THREE FORMATS FOR ENTERING DATA THAT ARE DESCRIBED **BELOW; THE LAST CARD IN THIS SECTION MUST BE "END" 青水 1. "JUNCTION" CARDS -- THIS IS DEFINED BY A CARD WITH A "J" IN COLUMN 大大 1 FOLLOWED BY A CARD WITH THE FOLLOWING INFORMATION: ** A. NODE NO. OF THE VOLUME ON THE UPSTREAM SIDE OF JUNCTION; ** 大伙 B. NODE NO. OF DOWNSTREA LUME: ** USE O IF JUNC"ION IS IN A VERTICAL WALL): ** D. ELEVATION OF THE BOTTOM OF THE JUNCTION ABOVE THE FLOOR 大方 OF THE UPSTREAM NODE; ** E. FACING THE HOLE, THE WIDTH OF JUNCTION; 北安 F. FACING THE HOLE, THE HEIGHT OF JUNCTION: ** G. LENGTH OF JUNCTION: 黄连 H. AREA OF JUNCTION ** ** NOTE: IF WIDTH=HEIGHT, THE JUNCTION IS ASSUMED CIRCULAR, OTHERWISE ** RECTANGULAR (USE WIDTH SLIGHTLY DIFFERENT THAN HEIGHT FOR SQUARE) 黄素 EVEN IF THE JUNCTION IS RECTANGULAR, THE ARE & CAN BE DIFFERENT 作素 THAN THE PRODUCT OF LENGTH AND WIDTH IF THE JUNCTION REPRESENTS THE 1.8 SUM OF SEVERAL HOLES WHICH HAVE THE SAME ELEVATION, ETC. ** ** 2. "FAILURE" CARDS -- THIS IS DEFINED BY A CARD WITH AN "F" IN COLUMN ** 1 FOLLOWED BY A CARD WITH THE FOLLOWING INFORMATION: ** A. NODE NO. OF NODE WHICH CAN FAIL (UPSTREAM NODE); 黄素 B. NODE NO. THAT THE FAILED VOLUME BLOWS DOWN INTO: ** C. 1 IF THE JUNCTION IS HORIZ (O IF VERTICAL): ** D. ELEVATION OF THE BOTTOM OF THE OPENING ABOVE THE FLOOR OF ** THE FAILED NODE: ** E. FACING THE HOLE, THE WIDTH OF JUNCTION: ** F. FACING THE HOLE, THE HEICHT OF JUNCTION; 大方 G. LENGTH OF JUNCTION; ** H. AREA OF JUNCTION; ** I. DIFFERENTIAL PRESSURE REQUIRED TO FAIL THE NODE IF THE UPSTREAM 法法 NODE FAS THE HIGHEST PRESSURE ** J. DIFFERENTIAL PRESSURE REQUIRED TO FAIL THE NODE IF THE DOWNSTRM ** NODE HAS THE HIGHEST PRESSURE ** ** NOTE: IF WIDTH=HEIGHT, THE JUNCTION IS ASSUMED CIRCULAR, OTHERWISE 安大 RECTANGULAR (USE WIDTH SLIGHTLY DIFFERENT THAN HEIGHT FOR SQUARE) ** EVEN IF THE JUNCTION IS RECTANGULAR, THE AREA CAN BE DIFFERENT 六六



THAN THE PRODUCT OF LENGTH AND WIDTH IF THE JUNCTION REPRESENTS THE 法法 SUM OF SEVERAL HOLES WHICH HAVE THE SAME ELEVATION, ETC. ** ** 法法 3. "CONTAINMENT INTERFACE" CARD- ONE SUCH SET OF TWO CARDS SHOULD BE 黄素 PROVIDED THE FIRST CARD SHOULD HAVE & "C" IN COLUMN ONE; ** THE SECOND CARD GIVES: ** A. THE NODE NO. WHICH RECEIVES FLUID FROM THE CONTAINMENT (OR 云云 PRIMARY SYSTEM FOR V SEQUENCES) AND 法士 B. ELEVATION ABOVE THE FLOOR OF THIS NODE OF THE TOP OF THE ** JUNCTION THROUGH WHICH THE PRI SYS OR CONTMT EFFLUENT IS ISSUING 素音 ** **IMPORTANT NOTE: **THE MODEL WILL NOT RELIABLY FIND A **SOLUTION FOR THE AUX BLDG FLOWS IN ONE SPECIFIC CIRCUMSTANCE: ** 1. TWO VOLUMES ONE ABOVE THE OTHER 2. PARALLEL FLOW PATHS CONNECTING THE TWO VOLUMES THROUGH ** THE FLOOR OF THE UPPER VOLUME ** ** **IT APPEARS THAT SUCH A SITUATION IS NUMERICALLY ILL-POSED **TO AVOID PROBLEMS, IT IS RECOMMENDED IN SUCH A SITUATION TO **LUMP THE TWO FLOWPATHS TOGETHER ** JUNCTION 1-8 1 8 1 25.5 .17 13.12 4.0 8.07 JUNCTION 2-8 2 8 0 29.5 .17 34.35 3.5 7.86 JUNCTION 8-5 8 5 0 29.5 .17 44.94 3.0 7.86 JUNCTION 8-3 8 3 1 42.5 .17 33.41 5.0 11.36 JUNCTION 1-8 1 8 0 54.5 .17 34.64 3.5 5.89 JUNCTION 2-8 2 8 0 54.5 .17 34.64 3.5 5.89 JUNCTION 1-3 1 3 0 47.5 .17 39.65 5.0 6.74 JUNCTION 2-3 2 3 0 47.5 .17 39.65 5.0 6.74 JUNCTION 8-4 8 4 0 54.5 .17 69.18 3.0 11.76 JUNCTION 5-4 5 4 1 43.0 64.76 18.0 1.0 1428.94 JUNCTION 5-4 5 4 1 43.0 7.75 12.33 1.0 95.56 JUNCTION 9-10 9 10 0 25.0 14.0 20.0 2.0 280.0 FAILURE 21 1 7 1 29.5 8.1 7.9 2.67 64.0 3.1 3.1 FAILURE 22 1 7 0 30.17 3.0 7.17 10.5 21.5 3.9 3.9 FAILURE 23 1 8 0 30.17 3.0 7.17 3.0 21.5 3.9 2.2 FAILURE 24



2 7 0 30.17 3.0 7.17 10.5 21.5 3.9 .9 FAILURE 25 2 8 0 30.17 3.0 7.17 3.0 21.5 3.9 2.2 FAILURE 26 2 7 1 29.5 8.1 7.9 2.67 64.0 3.1 3.1 FAILURE 27 5 10 1 25.0 8.0 22.0 101.0 352.0 5.0 5.0 FAILURE 28 5 10 0 25.0 3.0 7.17 18.0 21. 3.9 3.9 FAILURE 29 7 5 0 29.5 3.0 7.17 55.0 100.2 3.9 3.9 FAILURE 30 7 9 0 29.5 3.0 7.17 3.0 64.5 2.2 3.9 FAILURE 31 1 6 0 55.17 3.0 7.17 9.0 21.5 3.9 3.9 FAILURE 32 2 6 0 55.17 3.0 7.17 9.0 21.5 3.9 3.9 FAILURE 33 1 10 1 92.5 13.17 12.0 3.0 158.0 3.3 3.3 FAILURE 34 2 10 1 92.5 13.17 12.0 3.0 158.0 3.3 3.3 FAILURE 35 6 4 0 0.0 3.0 7.17 14.0 43.0 3.9 3.9 FAILURE 36 3 9 0 0.0 20.2 20.1 250.0 406.5 0.4 0.4 FAILURE 37 9 10 0 94.92 44.6 44.8 1.0 2000.0 0.7 0.7 FAILURE 38 6 9 0 0.0 8.0 7.83 4.0 125.3 2.2 3.9 FAILURE 39 9 10 0 88.0 3.0 7.17 4.0 43.0 2.2 3.9 FAILURE 40 6 9 0 19.0 6.0 7.83 3.0 94.0 2.2 3.9 FAILURE 20 7 6 1 29.5 3.0 7.17 25.0 43.0 3.9 2.2 FAILURE 41 8 10 1 92.5 .167 408.4 63.0 68.2 0.7 0.7 FAILURE 43 8 7 1 28.3 8.10 7.90 1.17 128. 1.31 1.31 CONTAINMENT INTERFACE 1 10.00 END ** *************** *USEREVT ********* ** ** THIS DEFINES TE- USER DEFINED EVENT CODES. THE FOLLOWING SYNTAX ** SHOWN BELOW ARE "HAT IS NORMALLY EXPECTED IN THE *USEREVT PARAMETER ** SECTION. ANYTHING ELSE IS IGNORED AND THE USER IS WARNED. ** ** 1) ** / COMMENTING ** 2) END / END OF SECTION 'EYWORD

** 3) <NUMBER> <EXPRESSION> / USER DEFINED EVENT CODE




	<pre><false> <message> / USER SUPPLIED TRUE MESSAGE 5) SELECT <number1> <number2> ETC. SELECT ALL</number2></number1></message></false></pre>					
**						
**	VIIIVUNAL USER DEFINED FUENT MECCASE EXample					
**	THE EVENT CODE EXPRESSION. THE ONLY RESTRICTION IS THAT SUCH					
**	THE EVENT CODES THE MESSAGES ARE DEFINED FOR.					
**						
**	ANUS / FALSE"> CUSER DEFINED MECCACES					
**						
**	DITE DULD INUE AND FAISE MECCACE OF THEM AND					
**	TOKENS "TRUE", "T", "FALSE", AND "F" ARE ACCEPTABLE. NOTE THAT THE					
**	CODE VILL CENERATE THE FURNITY AND "F" ARE ACCEPTABLE. NOTE THAT THE					
**	CODE WILL GENERATE THE EVENT MESSAGE FROM THE USER DEFINED EVENT CODE					
**	EXPRESSION, AND SUPERSEDE IT WITH USER'S IF SUPPLIED.					
**						
**	THE SELECT PERMANE TO MARK					
**	A HAD DDUDUI KETWURU IS HEED TO HEED DOWN WHEN					
**	NUMBERS TO BE WRITTEN TO THE SUMMRY FILE AND LOG FILE IF NEGATIVE					
**	WHEN THE CORRESPONDING EVENT CODE NUMBER STATUS HAS CHANGED. IF					
**						
	THE SUMMRY FILE. NOTE THAT NO MESSAGE IS WRITTEN TO THE LOG FILE					
**	UNLESS YOU SELECTED A NUMBER WITH A NEGATIVE SIGN. NOTE THAT WHEN					
**	AN MAAP OPERATOR EVENT CODE STATUS CH'NGED DUE TO USER DEFINED EVENT					
**	CODE STATUS CHANGE, IT IS REPORTED TO THE LOG FILE ALWAYS.					
**	THE LUG FILE ALWAYS.					
**						
**	AN VALID "SER LEFINED EVENT CODE EXPRESSION FORMAT CONSISTS OF AN					
**	EVENT CODE NUMBER AND ORRESPONDING DUCINE FORMAT CONSISTS OF AN					
**	EVENT CODE NUMBER AND _ORRESPONDING EVENT CODE EXPRESSION, EG.,					
**	<event code="" number=""> <defining code="" event="" expression=""></defining></event>					
**	CODE EXPRESSION>					
**	EVENT CODE NUMBERS AND					
**	EVENT CODE NUMBERS 400-699 ARE ALLOCATED FOR USER DEFINED EVENT CODE					
**						
**						
**						
**						
**						
**	MAAP OPERATOR CODES.					
**	AN UATID DURING SUBSECT					
**	AN VAILD EVENT EXPRESSION FORMAT IS EXPECTED TO CONFORM TO ONE OF THE FOLLOWING FORMATS:					
**	FOLLOWING FORMATS:					
**	1.5 UPDEPENDE					
**	1) "EVENT" <num_er> &lt;"TRUE"/"FALSE"&gt; &lt;"LOCKOUT"&gt;</num_er>					
**	2) <v:riable1 re'=""> <real_operator> <variable2 real2=""> &lt;"LOCKOUT"&gt;</variable2></real_operator></v:riable1>					
**						
**	3) <format1 format2=""> <logical_operator> <format1 format2=""> &lt;"LOCKOUT"&gt;</format1></logical_operator></format1>					
**	LOCKOUT">					
**	WHERE "EVENT" = THE KEYWORD "EVENT"					
**	SNUMBER> - THE CORDECTONISTIC FORMER					
**	<"TRUE"/"FALSE"> = THE KEYWORD "TRUE" OR "FALSE"					
	THE REINVAD "INUE" OR "FALSE"					

Page H.5 - 51

<VARIABLE1> = THE MAAP COMMON BLOCK VARIABLE NAME <REAL1> = THE NUMBERIC REAL VALUE ** <REAL OPERATOR> = SELF EXPLANATORY (SEE BELOW) ** <VARIABLE2> - THE MAAP COMMON BLOCK VARIABLE NAY & ** <REAL2> = THE NUMBERIC REAL VALUE ** ** <FORMAT1> = IS THE FORMAT DEFINED ABOVE ** <FORMAT2> = IS THE FORMAT DEFINED ABOVE ** <LOGICAL OPERATOR> = SELF EXPLANATORY (SEE BELOW) ** 告告 <"LOCKOUT"> = OPTIONAL "LOCKOUT" KEYWORD 4.4 THE FIRST FORMAT TYPE IS DEFINED AS A LOGICAL EXPRESSION, THE ** SECOND FORMAT TYPE IS DEFINED AS A REAL EXPRESSION, AND THE THIRD ** FORMAT TYPE IS DEFINED AS AN MULTIPLE EXPRESSION CONSISTING OF A ** ** COMBINATIONS OF FORMAT1 AND/OR FORMAT2. ** NOTE THAT "/" USED ABOVE IN DEFINING THE FORMATS IS EXPRESSED AS 安卡 "EITHER". THUS THERE ARE TWO LOGICAL EXPRESSION, FOUR REAL ** EXPRESSION, AND FOUR MULTIPLE EXPRESSION POSSIBLE COMBINATIONS. 长六 ** OPTIONAL REYWORD "LOCKOUT" TOKE' COULD BE ADDED AT END OF LINE. ** THIS WILL PERMANETLY LOCK THE EVENT CODE TO TRUE ALWAYS ONCE THE ** DEFINING EXPRESSION IS SATISFIED. TOKENS "L", "LKO", & "LO" ARE ** ** ACCEPTABLE. ** ** ALLOWABLE <REAL OPERATOR> TOKENS ARE ++ ** (GREATER THAN) > or GT ** (LESS THAN) < or LT >= or GE or => (GREATER THAN OR LOUAL TO) ** ** <= or LE or =< (LESS THAN OR EQUAL TO) ** (EQUAL TO) = or EQ 安安 (NOT EQUAL TO) <> or NE ** ** AND ALLOWABLE <LOGICAL OPERATOR> TOKENS ARE ** ** AND or A ** OR or O ** ** WE WILL NOW SHOW SOME EXAMPI'S OF USER DEFINED EVENT CODES, AND ** WE'LL START WITH A SIME F PRESSION AND END WITH A MULTIPLE ** ** EXPRESSION EXAMPLE. ** LET'S SAY WE HAVE THE FOLLOWING SIMPLE EXPRESSION; ** ** ** 401 PPS > 1.E6 ** EVENT CODE 401 IS TRUE WHEN PPS. THE REACTOR VESSEL PRESSURE, IS ** GREATER THAN 1.E6 PASCALS, OTHERWISE IT IS FALSE. * ** 素水 44

法法

	THE SECOND	EXAMPLE I	NVOLVING MULTIPLE EXPRESSION, AS SHOWN IS;		
**					
**	402 TGP	S > 450 AN	ID EVENT 301 TRUE LOCKOUT		
**	PUPUT SODE	200 70 00	T PERMANETLY TRJE WHEN TGPS, THE REACTOR GAS		
**			ATER THAN 450 KELVINS AND WHEN EVENT CODE 401		
**	IS TRUE.	area to rave	WIEW INVE ADD REPAINS NAD AUEN EVENT CODE ADT		
**	TO THOP:				
*1					
**	TWO IMPORT	ANT NOTES	MUST BE MADE. THE FIRST IS THAT ALL NUMBERS		
**	ARE EXPECTED TO BE IN SI UNITS. THIS IS DONE TO PREVENT CONFUSION AS TO WHAT MAAP COMMON BLOCK VARIABLES HAVE DEFINING UNITS NUMBERS ASSIGNED. THOSE THAT DO, CAN BE EASILY CONVERETED TO/FROM SI AND				
**					
**					
**	BRITISH UNITS. THOSE THAT DO NOT ARE ALVAYS IN SI UNITS. SINCE NOT ALL MAAF COMMON BLOCK VARIABLES HAVE DEFINING UNIT NUMBERS, THE POTENIAL TO CONFUSE WHAT TYPE OF NUMBERS TO INPUT IS GREAT AND VE				
**					
**					
**	WANT TO AVOID THIS SITUATION. HOPEFULLY THIS WOULD BE RECIFIED IN				
**	THE NIAR FUTURE.				
**		sines and a	NUT HERE SECTION FUELS CONSE AND SUCCESSION		
**	EVENT CODES ARE EVALUATED SEQUENTIALLY FROM 400 TO 699 FIRST, AND				
**					
** :					
**	and the second				
**	THIS IS IMPORTANT TO NOTE SINCE IF THE EVALUATION OF AN EVENT CODE				
**					
**	The second s				
**					
+ +			CODES CAN ALSO BE DEFINED IN THE INPUT DECK VIA		
**			NGE. SPECIF 28,0,0 FOLLOVED BY THE SYNTAX		
**	EXPLAINED	ABOVE. I	BE SURE TO END WITH THE KEYWORD END.		
**			THE REPORT OF THE REAL PRIME TO THE PARTY OF		
			ABOVE DESCRIPTIONS SHOULD BE MORE THAN ADQUATE		
**	IN EXPLAI	NING THE P	PURPOSE OF USER DEFINED EVENTS.		
END					
	*********	*******	*******		
AUE	PUPII				
***	******	*****	*************		
	574.83	ZVVF	ELEVATION AT WETWELL FLOOR		
02	.267	AVB	FLOW APEA THROUGH A DETWELL VACUUM BREAKER		
03	2	NVB	T' MBER OF DRYWELL VACUUM BREAKERS		
04	.5	PSETVB	PLESSURE SETTOINT FOR VACUUM BREAKERS		
05	1.1	PDVB	DEAD BAND FOR VACUUM BREAKERS		
	265023.	VOLWW	TOTAL VOLUME OF WETWELL (PLUS SUPP POOL)		
07	.5	RELHWW	RELATIVE HUMIDITY IN VETWELL		
08	10	NIGVV	NUMBER OF IGNITERS IN THE VETVELL		
09	11.5	XIGWW	AVERAGE DISTANCE FROM SUPR PL WATER LEVEL TO IGNITERS		
11	.0	AWWF	AREA OF WETWELL FLOOR (MARK II) AEROSOL SEDIMENTATION AREA		
12	1 25 25	a 2785 2 8112 8 191	PRATEXTAINED TO THE ADDA (EDCC VENT)		
13	743	ALMENI	WETVELL TOTAL IMPACTION AREA		
14	,0208	VDTMUU	WETTELL MINIMUM GRATE DIAMETER (OR THICKNESS)		
40	10200	VENTURE	ENTERING HEITERSTERLE STRATES STRATES AND FALL STREETENST		



16 17 18 19	2796. 53.2 633. 579.42	ZCFAIL ZSRVD	ELEVATION OF CONTAINMENT VENT IN WETWELL AVERAGE ELEVATION OF SRV DISCHARGE IN SUPP POOL
	114.7	PCFM3	
21	.0	XRCONT	CONTAINMENT RADIUS
22	.0	NHOOPV	NUMBER OF TENDONS IN HOOP DIRECTION
23	.0	XTREHV	VOLUME OF REBAR PER UNIT AREA OF OUTER WALL
24	.0.	XTREZV	VOLUME OF REBAR PER UNIT AREA OF OUTER WALL
25	.0	XDHOPV	DIAMETER OF HOOP TENDONS
26	.0	ZWCYL	HEIGHT OF THE CYLINDRICAL PART OF THE VETVELL VALL
27	.0	XDZFV	DISPLACEMENT IN AXIAL DIRECTION
28	.0	XDRFW	SAME AS 29 FOR THE RADIAL DIRECTION
29	.0	NTENZ	NUMBER OF TENDONS IN AXIAL DIRECTION
30		XDTENZ	DIAMETER OF TENDONS IN AXIAL DIRECTION
31	9.	XRBRWW	CHARACTERISTIC RADIUS OF WETWELL FOR H2 BURNS
	27.4	XHBRVV	CHARACTERISTIC HEIGHT OF VETVELL FOR H2 BURNS
**			THIS IS FLOOR TO CEILING
**			

** UNITS SYSTEM CLARIFICATION

** AS WAS PREVIOUSLY STATED, PLACING A *SI AT THE END OF THE ** PARAMETER FILE WOULD MAKE THE CODE EXPECT THE INPUT DECK TO BE IN SI ** UNITS FOR INPUT NUMBERS, AND ALL OUTPUT FILES WOULD BE IN SI UNITS. ** CONVERSLY, IF *BR WAS PLACED AT THE END OF THE PARAMETER FILE, INPUT ** UNITS WOULD BE EXPECTED TO BE IN ERITISH UNITS, AND ALL OUTPUT FILES ** WOULD BE IN BRITISH UNITS.

** *BR

**

.