



State of New Jersey
Department of Environmental Protection and Energy
Division of Environmental Safety, Health and Analytical Programs
CN 415
Trenton, NJ 08625-0415

Scott A. Weiner
Commissioner

Gerald P. Nicholis, Ph.D.
Director

July 10, 1992

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Hope Creek Generating Station
Docket No. 50-354
License Change Request 92-02
Exceptions to Technical Specification 4.0.4 for
Intermediate and Source Range Monitors

On July 19, 1992, Public Service Electric and Gas Company (PSE&G) submitted the subject license change request to the Nuclear Regulatory Commission (NRC). This change request proposes to allow an exception to Specification 4.0.4 for the Intermediate Range Monitors (IRMs) and Source Range Monitors (SRMs) when Operation Condition 2 or 3 is entered from Operation Condition 1. The circuitry of the SRMs and IRMs precludes functional testing in Operation Condition 1.

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) reviewed the above amendment in accordance with the requirements of 10CFR50.91(b). Based on this review, BNE does not have any comments on the proposed amendment request.

If you have any questions, please contact Suren Singh at (609) 987-2039.

Sincerely,

Kent Tosch / D3

Kent Tosch, Manager
Bureau of Nuclear Engineering

77023
9207270227 920710
PDR ADOCK 05000354
P PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

ADD 1/0

c: J. Lipoti
Assistant Director, Radiation Protection Programs
N.J. DEP&E

S. Dembeck
Project Manager
U.S. NRC

T. Johnson
Artificial Island Senior Resident Inspector
U.S. NRC

F. Thomson
Manager, Licensing and Regulation
PSE&G