

July 22, 1992

DISTRIBUTION

See attached page

Docket No. 50-395

Mr. John L. Skolds
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
P.O. Box 88
Jenkinsville, South Carolina, 29065

Dear Mr. Skolds:

SUBJECT: VIRGIL C. SUMMER STATION, UNIT NO. 1, RESPONSE TO
BULLETIN 88-02 - RAPIDLY PROPAGATING FATIGUE CRACKS IN
STEAM GENERATOR TUBES (TAC NO. 67327)

By letter dated March 24, 1988, South Carolina Electric & Gas Company documented compliance with paragraphs A and B of Bulletin 88-02. By letter dated June 13, 1990, South Carolina Electric & Gas Company submitted a supplementary response to the Bulletin. In this supplementary response, you described your enhanced primary-to-secondary leak rate monitoring program as required by paragraph C1 of the Bulletin, and you proposed long-term corrective actions as required by paragraph C2 of the Bulletin. By letter dated February 6, 1991, you submitted WCAP-12592, "V. C. Summer Evaluation for Tube Vibration Induced Fatigue," as a supplement to your June 13, 1990, letter.

The staff has reviewed your submittal and WCAP-12592, and finds your proposed long-term corrective actions to be acceptable. This completes the staff's effort on TAC No. 67327.

Sincerely,

Original signed by:

George F. Wunder, Project Manager
Project Directorate II-1
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

cc: See next page

*See previous concurrence

LA:PD21:DRPE	PM:PD21:DRPE	D:PD21:DRPE	EMCA
PAnderson	GWunder:dt	EAdamsam	*WBateman
7/13/92	07/13/92	7/22/92	7/16/92

Document Name:SUM67327.LTR

9207270287 920722
PDR ADOCK 05000398
P PDR

NRC FILE CENTER COPY

Mr. John L. Skoids
South Carolina Electric & Gas Company

Virgil C. Summer Nuclear Station

cc:

Mr. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
c/o Virgil C. Summer Nuclear Station
P. O. Box 88 (Mail Code 802)
Jenkinsville, South Carolina 29065

J. B. Knotts, Jr., Esq.
Bishop, Cook, Purcell
and Reynolds
1400 L Street, N.W.
Washington, D. C. 20005-3502

Resident Inspector, Summer NPS
c/o U.S. Nuclear Regulatory Commission
Route 1, Box 64
Jenkinsville, South Carolina 29065

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W.,
Suite 2900 Atlanta, Georgia 30333

Chairman, Fairfield County Council
P. O. Box 293
Winnsboro, South Carolina 29180

Mr. Hayward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

South Carolina Electric & Gas Company
Mr. A. R. Koon, Jr., Manager
Nuclear Licensing
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, South Carolina 29065

DISTRIBUTION

Docket File

NRC & Local PDRs

PD21 Reading File

S. Varga

G. Lainas

E. Adensam

J. Wiggins

G. Wunder

P. Anderson

OGC

ACRS (10)

L. Reyes 1.1