

December 5, 1983

Note to Bob Lee

SUBJECT: ARKANSAS 2 PERIODIC TESTING OF MOTOR DRIVEN EFW PUMP  
(OELD # 839 718)

Bob, why don't you come and talk to me about this package. The justification in the cover letter in the bottom paragraph of the page doesn't seem to make a lot of sense to me; maybe I don't understand the problem. If you can deliver 485 at 1200 psig, what does that have to do with the delivery rate at 1100 psig? And if 485 is all anybody needs, why did our tech spec say 560 in the first place?

*Joe Scinto*  
for Joe Scinto

8502090045 840518  
PDR FOIA  
ADAT084-166 PDR

98