

POWER REACTOR

EVENT NUMBER: 23886

FACILITY: COMANCHE PEAK		REGION: 4		NOTIFICATION DATE: 07/16/92		
UNIT: [1] [2] []		STATE: TX		NOTIFICATION TIME: 17:25 [ET]		
RX TYPE: [1] W-4-LP, [2] W-4-LP				EVENT DATE: 05/18/92		
				EVENT TIME: 12:00 [CDT]		
				LAST UPDATE DATE: 07/16/92		
NRC NOTIFIED BY: JIM AGLES				NOTIFICATIONS		
HQ OPS OFFICER: JOHN MacKINNON						
EMERGENCY CLASS: NOT APPLICABLE						
10 CFR SECTION:						
CDEF 21.21(b) (2) DEFECTS/NONCOMPLIANCE						
UNIT	SCRAM CODE	RX CRIT	INIT PWR	INIT RX MODE	CURR PWR	CURR RX MODE
1	N	Y	100	POWER OPERATION	100	POWER OPERATION
2	N	N	0		0	

EVENT TEXT

QUALITY ASSURANCE PROGRAM BREAKDOWN OF KRANCO, INC. - HOUSTON, TEXAS., SUPPLIER OF UNIT 1 AND UNIT 2 POLAR CRANES.

"DURING A PERIODIC VENDOR AUDIT OF KRANCO, INC. - HOUSTON, TEXAS, IT WAS DETERMINED THAT KRANCO IS NO LONGER IMPLEMENTING THEIR 10CFR50 APPENDIX B QA PROGRAM. FURTHERMORE, A UNIT 2 PURCHASE ORDER INVOKING 10CFR2' AND 10CFR50 APPENDIX B REQUIREMENTS WAS FILLED BY KRANCO WITHOUT NOTIFYING TEXAS UTILITY ELECTRIC THAT THE PARTS WERE NOT BEING SUPPLIED UNDER AN APPENDIX B QA PROGRAM. THE PARTS WERE SUBSEQUENTLY INSTALLED IN THE UNIT 2 POLAR CRANE. TEXAS UTILITY HAS CONFIRMED THAT UNIT 1 IS NOT IMPACTED BY THE PROBLEM. THE ADEQUACY OF THE PARTS INSTALLED IN UNIT 2 WILL BE ESTABLISHED PRIOR TO THE CONDUCT OF CRITICAL LIFTS." THE LICENSEE WILL INFORM THE NRC RESIDENT INSPECTOR.

76001

9207280168 920716
PDR APOCK 05000446
S PDR

JE19/10