

December 7, 1983

Note to Bill Shields

SUBJECT: POINT BEACH 1 CONTAINMENT INTEGRATED LEAK RATE TESTING
(OELD # 839 746)

This package proposes to allow some "containment purge supply and exhaust valves to be treated as type "B" valves rather than type "C" valves under Appendix J". As to treat that change as "administrative". It strikes me that treatment is inconsistent with the words of Appendix J - the definition of type "B" and type "C" tests in subsection 2 of Appendix J. If that's it then I'm going to make them treat it as something other than administrative. Probably make them analyze the three standards test rather than just treat it as an administrative change.

AMB
for Joe Scinto

8502090085 840518
PDR FOIA
ADAT084-166 PDR

102