


September 1, 1983

Note to G. Rivenbark

SUBJECT: HATCH 1 - REPORTING RESULTS OF TYPE B&C LEAK TEST (OELD # 836 564)

I don't have any problems with the package you want. I, in passing, just happened to note that the incoming amendment is somewhat ambiguous. You may want to think about it when you finally get around to taking action. The incoming amendment permits the combined leakage test to be reported "within 30 days of the end" of an outage. I can't tell whether "30 days of the end" of an outage is 30 days before the outage is scheduled to end or 30 days after the outage has ended. It doesn't matter to me which one you mean, but whatever it is the technical specifications as issued ought to be clear.


Joe Scinto

8502070248 840518
PDR FOIA
ADAT084-166 PDR

19