

FEB 26 1985

In Reply Refer To:
Docket: 50-458/84-3L

Gulf States Utilities
ATTN: William J. Cahill, Jr.
Senior Vice President
River Bend Nuclear Group
P. O. Box 2951
Beaumont, Texas 77704

Gentlemen:

Thank you for your letter of January 28, 1985, in response to our letter and the attached Notice of Deviation dated December 27, 1984. As a result of our review, we find that additional information, as discussed with your Mr. W. Reed during a telephone call on February 13, 1985, is needed. Specifically, we need additional information on the test program to demonstrate that the emergency diesels will function correctly if called upon in an emergency condition, when already paralleled and running for surveillance. Please include identification of the test procedure and when these procedures are scheduled to be accomplished. If there are two procedures (one each for ESF initiation and for blackout), please provide the information for both. Please provide the supplemental information within 30 days of the date of this letter.

Sincerely,

Original Signed By
E. H. Johnson

E. H. Johnson, Chief
Reactor Project Branch 1

cc:
Gulf States Utilities
ATTN: J. E. Booker, Manager-
Engineering, Nuclear
Fuels & Licensing
P. O. Box 2951
Beaumont, Texas 77704

bcc distrib. by RIV:

RPB1	Resident Inspector	R. D. Martin, RA
RPB2	Section Chief (RPB1/A)	C. Wisner, PAC
EP&RPB	R. Denise, DRS&P	D. Weiss, LFMB (AR-2015)
RIV File	S. Stern, NRR	
LOUISIANA STATE UNIV., GOV'T DOC. DEPT.		
LOUISIANA NUCLEAR ENERGY DIVISION		

RPB1/A
JPJaudon/lk
2/25/85

RPB1
EHJohnson
2/25/85

8503040320 850226
PDR ADOCK 05000458
Q PDR

TEO 1
/