

The Light company

Houston Lighting & Power P.O. Box 1700 Houston, Texas 77001 (713) 228-9211

February 25, 1985
ST-HL-AE-1197
File Number: G9.17

Mr. Hugh L. Thompson, Jr. Director
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Thompson:

South Texas Project
Units 1 & 2
Docket Nos. STN 50-498, STN 50-499
Fracture Prevention of Containment Boundary (GDC-51)

As a result of a meeting between the NRC and HL&P on January 24, 1985, Houston Lighting & Power Company (HL&P) committed to provide an evaluation of the containment pressure boundary for fracture prevention in accordance with NRC General Design Criteria (GDC)-51. In response to that commitment, attached is the subject evaluation. Also attached are the CMTR's and Code Data Reports for the limiting items.

If you should have any questions concerning this submittal, please contact Mr. Michael E. Powell at (713) 993-1328.

Very truly yours,

M. R. Wisenburg
M. R. Wisenburg
Manager, Nuclear Licensing

MEP/yd

Attachments: (1) Evaluation of Fracture Prevention of Containment Boundary
(2) CMTR's and Code Data Reports for Limiting Items

8503040427 850225
PDR ADDCK 05000498
A PDR

Boo/
1/1

CC:

Robert D. Martin
Regional Administrator, Region IV
Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Prasad N. Kadambi, Project Manager
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20814

D. P. Tomlinson
Resident Inspector/South Texas Project
c/o U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

Dan Carpenter
Resident Inspector/South Texas Project
c/o U.S. Nuclear Regulatory Commission
P. O. Box 2010
Bay City, TX 77414

M. D. Schwarz, Jr., Esquire
Baker & Botts
One Shell Plaza
Houston, TX 77002

J. R. Newman, Esquire
Newman & Holtzinger, P.C.
1615 L Street N.W.
Washington, DC 20036

Director, Office of Inspection
and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

E. R. Brooks/R. L. Range
Central Power & Light Company
P. O. Box 2121
Corpus Christi, TX 78403

H. L. Peterson/G. Pokorny
City of Austin
P. O. Box 1088
Austin, TX 78767

J. B. Poston/A. vonRosenberg
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Brian E. Berwick, Esquire
Assistant Attorney General for
the State of Texas
P. O. Box 12548, Capitol Station
Austin, TX 78711

Lanny A. Sinkin
Room 401
1346 Connecticut Avenue, N.W.
Washington, D.C. 20036

Oreste R. Pirfo, Esquire
Hearing Attorney
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Charles Bechhoefer, Esquire
Chairman, Atomic Safety & Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dr. James C. Lamb, III
313 Woodhaven Road
Chapel Hill, NC 27514

Judge Ernest E. Hill
Hill Associates
210 Montego Drive
Danville, CA 94526

Mr. Ray Goldstein, Esquire
1001 Vaughn Building
807 Brazos
Austin, TX 78701

Citizens for Equitable Utilities, Inc.
c/o Ms. Peggy Buchorn
Route 1, Box 1684
Brazoria, TX 77422

Docketing & Service Section
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, DC 20555

SOUTH TEXAS PROJECT UNIT - 1 & 2
EVALUATION OF FRACTURE PREVENTION OF CONTAINMENT BOUNDARY
(GDC-51)

1. Lowest Service Metal Temperature (LSMT)

The lowest service metal temperature (LSMT) for the containment liner, including the equipment hatch, personnel airlock, auxiliary airlock and sleeves, is identified as +70°F during normal operation and maintenance.

2. Containment Pressure Boundary Materials

The materials of the containment pressure boundary reviewed within the context of GDC51 are the equipment hatch, personnel airlock and auxiliary airlock, sleeves, penetrations, piping and valves up to and including the first isolation valves. Limiting combinations of materials and heat treated conditions are described below and listed in the attached tables.

3. Equipment Hatch

The equipment hatch bolt flange, 6" thick SA516 Grade 70, quenched and tempered, is identified as a limiting item. The Summer 1977 (S77) Addenda of the ASME Code, Subsection NC assigns a T_{NDT} of -10°F. With the thickness correction per the Code Figure NC2311(a)-1, the resulting Permissible Lowest Service Metal Temperature (PLSMT) is +52°F.

The hatch shell, 3.5" thick SA537 Class 1, normalized, is identified as a limiting material. The ASME Code, S77 Addenda Table NC2311(a)1, assigns a T_{NDT} of -30°F ; allowing for the thickness correction per the Code, Figure NC2311(a)-1, the resulting PLSMT is $+17^{\circ}\text{F}$.

Insert Plate, 1" thick SA516 Grade 60, normalized is identified as a limiting material. The ASME Code, S77 Addenda, Table NC2311(a)1 assigns a T_{NDT} of 0°F and a PLSMT of $+30^{\circ}\text{F}$.

4. Personnel Airlock

The Reactor End Shell Collar, 6" thick SA516 Grade 70, normalized is identified as a limiting material. The ASME Code, Subsection NC, assigns a T_{NDT} of 0°F . Allowing for a thickness correction in accordance with the Code Figure NC2311(a)-1, the PLSMT is 62°F .

5. Auxiliary Equipment Hatch

The collar piece 3" thick SA516 Grade 70, normalized is identified as a limiting material. The T_{NDT} based on the ASME Code, Table NC2311(a)-1 is 0°F . Correcting for the thickness in accordance with the Code, Subsection NC, S77 Addenda, the PLSMT is $+40^{\circ}\text{F}$.

Boss, 3 7/8" SA350 LF2, quenched and tempered, is identified as a limiting material. NUREG 0577, Table 4.4 assigns an average value for this material in the normalized condition of -28°F . It is reasonable to

estimate a T_{NDT} for this material at or below -28°F in the quenched and tempered condition. Allowing for thickness correction in accordance with the ASME Code Subsection NC, S77 Addenda, the PLSMT is $+22^{\circ}\text{F}$.

6. Penetration Sleeves

SA333 Grade 6, normalized, 1.031" thick is identified as a limiting material (Penetrations E23, E24). NUREG 0577 would categorize this material as a C-Mn steel with a $T_{NDT} + 1.3$ standard deviation value of -5°F . Allowing for thickness correction per the Code, S77 Addenda, Figure NC2311(a)-1 the PLSMT value is $+25^{\circ}\text{F}$.

SA516 Grade 60, 2.5" thick, normalized is identified as a limiting material (penetrations M1 thru M4). Because the material was cold formed and stress relieved, an estimate of T_{NDT} is made. The Summer 1977 Addenda to the ASME Code, Subsection NC assigned a T_{NDT} of 0°F to the normalized plate.

According to the discussion on "Effects of Cold Work" in Welding Research Council Bulletin Number 158, January 1971, when this type of material is cold worked up to 5% and then stress relieved, its transition curve mid-height temperature increases 20°F . Based on the estimated strain for this forming of less than 5%, a conservative assumption of a 20° increase in T_{NDT} can be made. Based on a T_{NDT} of $+20^{\circ}\text{F}$, and thickness correction in accordance with the ASME Code, Subsection NC (S77 Addenda) the PLSMT is $+50^{\circ}\text{i}$.

SA106 Grade B, normalized, 0.968" thick is identified as a limiting material (Penetrations 20, 21, 22). NUREG 0577 Table 4.4 and Figure B7 would assign a T_{NDT} at or below + 40°F. Allowing for thickness in accordance with the ASME Code, Subsection NC, S77 Addenda, the PLSMT is +70°F.

7. Flued Head Penetrations

SA350 LF-2, quenched and tempered, with an axial thickness of 9 5/8" is a limiting material in flued head penetrations (main steam system, penetrations M1 through M4). The average T_{NDT} for this material in the normalized condition, per NUREG 0577, Table 4.4 is -28°F. It is reasonable to estimate a T_{NDT} for this material at or below -28°F in the quenched and tempered condition. Assuming a T_{NDT} of -28°F, Code Subsection NC, S77 Addenda would assign a PLSMT of +50°F.

SA350LF2, normalized, with an axial thickness of 6 5/8" is used in the feedwater system flued heads (Penetrations M5-M8). NUREG 0577 Table 4.4 would assign a T_{NDT} +1.3 standard deviations value of -5°F. The S77 Addenda to the Code, Subsection NC would assign a PLSMT of +62°F.

The main steam and feedwater penetrations are integral with the process pipe.

8. Cap Type Penetrations

SA420 WPL6 (SA516 Grade 70), normalized, 1 3/4" thick is identified as a limiting material in cap type penetrations. Code Subsection NC, S77 Addenda would assign a T_{NDT} of 0°F and a PLSMT of +30°F.

9. Multiple Penetration Header Plates

The limiting material identified is SA516 Grade 70 plate, normalized, and 1" thick. The T_{NDT} for this material in accordance with the ASME Code, Subsection NC, Table NC2311(a)1 is 0°F. The thickness correction in accordance with the Code, Subsection NC, S77 Addenda results in a PLSMT of +30°F.

10. Electrical Penetrations

Weld neck flange, 20" diameter, 1.69" thick, SA350 Grade LF1, normalized is determined to be the limiting material. NUREG 0577, Table 4.4 would assign this material a T_{NDT} at 1.3 standard deviation of -5°F. The PLSMT adjusted for thickness in accordance with Code, Figure NC 2311(a)1 is +25°F.

11. Main Steam Process Pipe and Header

(MK 2G369P-MS-1003-GA2-08-H and MK 2G369P-MS-1003-GA2-08-J, Typ.)

Process Pipe

(Part of MK 2G369P-MS-1003-GA2-08-H typical, 31 1/8" OD X 2 1/8" max. wall thickness)

SA 155 KCF 70 Class 1 (SA516 Grade 70) material is used, the finished pipe being in normalized condition. The T_{NDT} value for this material in the normalized condition is 0°F in accordance with the ASME Code Table NC2311(a)1. With thickness correction in accordance with the Code, the PLSMT is +30°F.

Extruded Header Assembly

(MK 2G369P-MS-1003-GA2-08-J typical, 33 7/8" OD X 3 1/2" wall thickness)

The material is SA234 WPBW fabricated from SA516 Grade 70, normalized plate, normalized after welding the longitudinal seam and hot forming outlets, and stress relieved after welding the fittings. The T_{NDT} value for this material in accordance with the ASME Code Table NC-2311(a)1 is 0°F. With thickness correction in accordance with the Code subsection NC, S77 Addenda, the PLSMT value is +48°F.

Branch Pipe (16" X 0.844" thickness)

The pipe is SA333 Grade 6, seamless, normalized, 0.844" maximum thickness. NUREG 0577 Table 4.4 would categorize the material as a C-Mn steel with a T_{NDT} +1.3 standard deviations value of -5°F. The ASME Code Subsection NC, S77 Addenda assigns a PLSMT of +25°F.

6", 1500 #LWN Flange

The material is SA350LF2, normalized, less than 2 1/2" thick. NUREG 0577 would categorize the material as a C-Mn steel to which Table 4.4 would assign a T_{NDT} value at 1.3 standard deviations of -5°F. The ASME, Subsection NC, Summer 77 Addenda assigns a PLSMT of +25°F.

Socket Weld Pipets, Bosses and Plugs (Fittings)

The limiting material in this category is SA350LF2 quenched and tempered, 2 1/2" maximum thickness. The average value for the material in the normalized condition is -28°F per Table 4.4 of NUREG 0577. It is reasonable to estimate a T_{NDT} in the quenched and tempered condition at or below -28°F. Allowing for thickness correction in accordance with the Code, Subsection NC, S77 Addenda, the PLSMT is +2°F.

Branch Pipe Cap

The material is a 16" Schedule 80 (0.844" wall) Butt Weld Cap. The material specification is SA420 WPL6 supplied as SA350LF2 material in the quenched and tempered condition. Based on NUREG 0577, the average T_{NDT} in the normalized condition is -28°F, and it is reasonable to assume that T_{NDT} in the quenched and tempered condition is -28°F or below. Assuming a T_{NDT} of -28°F and allowing for thickness correction in accordance with the Code, the PLSMT is +2°F.

12. Feedwater Process Pipe and Fittings (FW-1012-GA2-02-L typical)

The pipe material is SA333 Grade 6, normalized, 0.938" thick categorized as C-Mn steel by NUREG 0577. Table 4.4 assigns a T_{NDT} value at 1.3 standard deviations of -5°F. Applying a thickness correction in accordance with the Code Figure NC-2311(a)1, the PLSMT is +25°F.

The Pipet 18" S/120 X 3" S/160 BW is SA350LF2, normalized, less than 2 1/2" thick. The T_{NDT} value at 1.3 standard deviations based on NUREG 0577 is -5°F. Allowing for a thickness correction in accordance with the Code, Figure NC2311(a)1 the PLSMT is +25°F.

Pipet 18" X 1", 3M# SW, less than 2 1/2" wall is 350 LF2 quenched and tempered. NUREG 0577 would categorize the material as a C-Mn steel to which Table 4.4 would assign an average NDT temperature of -28°F in the normalized condition. It is reasonable to assume the T_{NDT} in the quenched and tempered condition of -28°F or below. Assuming a T_{NDT} of -28°F. The ASME Code, Summer 77 Addenda assigns a PLSMT of +2°F.

13. Main Steam Isolation Valves (FSV 7414 Typ.)

The body is 2 3/16" design thickness, SA216WCB, normalized and tempered. NUREG 0577 Figure B2 would assign a T_{NDT} at or below the +35°F average T_{NDT} given in Table 4.4. Assuming a T_{NDT} of +35°F conservatively, the Code Subsection NC, S77 addenda assigns a PLSMT of +65°F.

The bonnet (cover) is 12 1/4" thick SA-105, quenched and tempered. The average value of T_{NDT} for this material in accordance with NUREG 0577 Table 4.4 is -28°F in the normalized condition. It is reasonable to estimate a T_{NDT} for this material in the quenched and tempered condition at or below -28°F. Assuming a T_{NDT} of -28°F, the Code Subsection NC, S77 Addenda would assign a PLSMT of +59°F.

The disc (poppet) is 10.2" max. thickness SA-105 quenched and tempered. A reasonable T_{NDT} for this material is -28°F or below, as discussed above. Thickness correction in accordance with the Code, Subsection NC, S77 Addenda results in a PLSMT of +52°F.

The pilot poppet is SA182 F6 quenched and tempered with a maximum thickness of 2 1/4". The material was quenched and tempered at a relatively high temperature of 1300°F. Republic Steel Izod impact data indicates that with relatively high tempering temperatures, the properties are in the upper shelf energy range. It can reasonably be assumed that while the material cannot be characterized in terms of NDT, assurance of adequate fracture toughness is available at the LSMT of 120°F.

Bolting: The bolting is SA540 B23, quenched and tempered. This material is categorized in Table 4.6 of NUREG 0577 as having least susceptibility to brittle fracture.

14. Feedwater Check Valves (FW0067 Typ.)

Body: The body is SA216 WCB with a thickness of 2.2", normalized and tempered. NUREG 0577 Figure B2 would assign a T_{NDT} at or below the +35°F average T_{NDT} given in Table 4.4. Assuming a T_{NDT} of +35°F conservatively, the Code Subsection NC, S77 Addenda, would assign a PLSMT of +65°F.

Bonnet: The cover is SA-105, 4.53" thick quenched and tempered, (based on referenced heat treat procedure). NUREG 0577, Table 4.4 assigns an average T_{NDT} in the normalized condition of -28°F, based on which it is

reasonable to estimate T_{NDT} in the quenched and tempered condition of -28°F or below. The thickness correction per Code, subsection NC results in a PLSMT of +24°F.

Disc: The disc is SA216 WCB with a minimum thickness of 2.36", normalized and tempered. NUREG 0577 Figure B2 would assign a T_{NDT} at or below the +35°F average given in the Table 4.4. Assuming a T_{NDT} of +35°F, the Code Subsection NC, S77 Addenda, would assign a PLSMT of +65°F.

Bolting: The bolting is SA193 Grade B7. This material is categorized in Table 4.6 of NUREG 0577 as having least susceptibility to brittle fracture.

15. Feedwater Isolation Valves (FV 7143 Typ.)

Body, Lower Sections: These are SA350LF2 with a wall thickness of 2 3/4", quenched and tempered. NUREG 0577, Table 4.4 would assign an average T_{NDT} of -28°F based on which it is reasonable to estimate T_{NDT} with quenched and tempered condition of -28°F or below. The thickness correction per Code, Subsection NC results in a PLSMT of +7°F.

Body, Upper Section: This is SA350LF2, normalized and tempered, with a thickness of 2 3/4". NUREG 0577 assigns a T_{NDT} at 1.3 standard deviations of -5°F. Using the thickness correction of Code, Subsection NC results in a PLSMT of +30°F.

Body, Center Section: This is SA216 WCC with a design thickness of 2 1/4", normalized and tempered. NUREG 0577, Figure B2 would assign a T_{NDT} at or

below the +35°F average T_{NDT} given in Table 4.4. Assuming a T_{NDT} of +35°F conservatively, the Code Subsection NC, S77 Addenda, would assign a PLSMT of +65°F.

Bonnet: The bonnet is SA350 LF2, 4 3/4" quenched and tempered. NUREG 0577 Table 4.4 assigns an average T_{NDT} in the normalized condition of -28°F, based on which it is reasonable to estimate T_{NDT} in the quenched and tempered condition of -28°F or below. The thickness correction per Code, Subsection NC results in a PLMST of +26°F.

Gate And Segments: The material is SA487 Grade CA 6 NM in the normalized and tempered condition, with an estimated maximum thickness of 3". ASME publication MPC-13 "Fracture Toughness of Wrought and Cast Steels" Table 3 reports NDT temperatures for 5", 3", and 1" materials of at least -67°F. Conservatively assuming an upper bound T_{NDT} of -50°F, and correcting for thickness per Code, Subsection NC (S77 Addenda), the PLSMT is -10°F.

Bolting: The bolting is SA193 Grade B7. This material is categorized in Table 4.6 of NUREG 0577 as having least susceptibility to brittle fracture.

ATTACHMENT 1 - TABLE 1
SOUTH TEXAS PROJECT UNIT - 1 & 2
EVALUATION OF FRACTURE PREVENTION OF CONTAINMENT BOUNDARY
(GDC-51)

Page 1 of 3

Component/ System	Item	Max. Thickness (In.)	Material	Heat Treatment	ASME III Subsection NC- Summer 77 Addenda	NUREG 0577	T _{NDT} (°F)	PLSMT (°F)	LSMT (°F)
Equip. Hatch	Bolt Flange	6	SA-516 Gr. 70	Q&T	Table NC-2311(a) -1		-10	52	70°F
	Hatch Shell	3.5	SA-S37 Class 1	Normal- ized	Table NC-2311(a) -1		-30	17	70°F
	Insert Plate	1	SA-516 Gr. 60	Normal- ized	Table NC-2311(a) -1		0	30	70°F
Personnel Airlock	Reactor End Shell Collar ~	6	SA-516 Gr. 70	Normal- ized	Table NC-2311(a) -1		0	62	70°F
Aux. Airlock	Collar Piece	3	SA-516 Gr. 70	Normal- ized	NC-2311(a) -1 Table		0	40	70°F
	Boss	3 7/8	SA-350 Gr. LF2	Q&T		Table 4.4	-28	22.	70°F
Penetra- tion Sleeves	Penetra- tion E 23, E24	1.031	SA-333 Gr. 6	Normal- ized		Table 4.4	-5	25	70°F
	Penetra- tion M1 - M4	2.5	SA-516 Gr. 60	Normal- ized Cold formed & stress relieved	Table NC-2311a(1)		20	50	70°F
	Penetra- tion 20, 21, 22	.968	SA-106 Gr. B	Normal- ized		Table 4.4	40	70	70°F
Flued Head Penetra- tions	Main Steam M1 - M4	9 5/8	SA350 LF2	Q&T		Table 4.4	-28	50	120°F
	Feed Water M5 - M8	6 5/8	SA-350 LF2	Normal- ized		Table 4.4	-5	62	120°F

SOUTH TEXAS PROJECT UNIT - 1 & 2
EVALUATION OF FRACTURE PREVENTION OF CONTAINMENT BOUNDARY
(GDC-51)

Component/ System	Item	Max. Thickness (In.)	Material	Heat Treat- ment	ASME III Subsection NC- Summer 77 Addenda	NUREG 0577	T _{NDT} (°F)	PLSMT (°F)	LSMT (°F)
Cap Type Penetra- tions		1 3/4	SA420 WPL6 (SA516 Gr. 70)	Normal- ized	Table NC-2311(a) -1		0	30	70°F
Multiple Penetra- tion Plates		1	SA-516 Gr. 70	Normal- ized	Table NC-2311(a) -1		0	30	70°F
Electri- cal Pene- trations	Weld Neck Flange	1.69	SA-350 Gr. LF1	Normal- ized		Table 4.4	-5	25	70°F
Main Steam	Process Pipe	2 1/8	SA-155 KCF70 CL1 (SA-516 Gr. 70)	Normal- ized	Table NC-2311(a) -1		0	30	120°F
	Extruded Header Assembly	3 1/2	SA-234 WPBW (SA-516 Gr. 70)	Normal- ized	Table NC-2311(a) -1		0	48	120°F
	Branch Piping	.844	SA333 Gr. 6	Normal- ized		Table 4.4	-5	25	120°F
	6" 1500# LWN	2 1/2	SA350 LF2	Normal- ized		Table 4.4	-5	25	120°F
	Fittings	2 1/2	SA350 LF2	Q&T		Table 4.4	-28	2	120°F
	Branch Pipe Cap.	.844	SA420 WPL6 (SA350 LF2)	Q&T		Table 4.4	-28	2	120°F
Feedwater	Pipe	.938	SA333 Gr. 6	Normal- ized		Table 4.4	-5	25	120°F
	Pipet	2 1/2	SA350 LF2	Normal- ized		Table 4.4	-5	25	120°F
	Pipet	2 1/2	SA350 LF2	Q&T		Table 4.4	-28	2	120°F

ATTACHMENT 1 - TABLE 1
 SOUTH TEXAS PROJECT UNIT - 1 & 2
 EVALUATION OF FRACTURE PREVENTION OF CONTAINMENT BOUNDARY
 (GDC-51)

Page 3 of 3

Component/ System	Item	Max. Thickness (In.)	Mater- ial	Heat Treat- ment	ASME III Subsection NC- Summer 77 Addenda	NUREG 0577	T _{NDT} (°F)	PLSMT (°F)	LSMT (°F)
Main Steam Isolation Valve	Body	2 3/16	SA216 WCB	N&T		Table 4.4	35	65	120°F
	Bonnet	12 1/4	SA105	Q&T		Table 4.4	-28	59	120°F
	Disc.	10.2	SA105	Q&T		Table 4.4	-28	52	120°F
	Pilot Poppet	2 1/4	SA182 F6	Q&T		Upper			
	Bolting		SA540 B23	Q&T		Least Susceptibility to brittle fracture			
Feed Water Check Valve	Body	2.2	SA216 WCB	N&T		Table 4.4	35	65	120°F
	Bonnet	4.53	SA105	Q&T		Table 4.4	-28	24	120°F
	Disc.	2.36	SA216 WCB	N&T		Table 4.4	35	65	120°F
	Bolting		SA-193 Gr. B7			Least Susceptibility to brittle			
Feed Water Isolation Valve	Body Lowest Section	2 3/4	SA350 LF2	Q&T		Table 4.4	-28	7	120°F
	Body Upper Section	2 3/4	SA350 LF2	N&T		Table 4.4	-5	30	120°F
	Body Center Section	2 1/4	SA216 WCC	N&T		Table 4.4	35	65	120°F
	Bonnet	4 3/4	SA350 LF2	Q&T		Table 4.4	-28	26	120°F
	Gate & Gate Segments	3	SA487 Gr. CA 6NM	N&T			-50 See Text	-10	120°F
	Bolting		SA193 Gr. B7			Least Susceptibility to brittle fracture			

N&T - Normalized and Tempered

Q&T - Quenched and Tempered

W6B/R /jj

SOUTH TEXAS PROJECT UNIT - 1
EVALUATION OF FRACTURE PREVENTION OF CONTAINMENT BOUNDARY
(GDC-51)

INDEX of CMTRS & CODE DATA REPORTS FOR LIMITING ITEMS

Equipment Hatch (4 pages)
Personnel Airlocks (7 pages)
Auxiliary Airlocks (12 pages)
Penetration Sleeves (5 pages)
Flued Heads (7 pages)
Cap Type Penetrations (5 pages)
Multiple Penetration Header Plates (6 pages)
Electrical Penetrations (1 page)
Main Steam Process Pipe and Header (21 pages)
Feedwater Pipe (4 pages)
Main Steam Isolation Valve (16 pages)
Feedwater Check Valve (6 pages)
Feedwater Isolation Valve (9 pages)

Equipment Hatch

PURCHASER:

PITTSBURGH-DES MOINES
STEEL CO.
MR. JACK McCARTHY
NEVILLE ISLAND
PITTSBURGH, PA. 15225

LUKENS STEEL COMPANY

COALSVILLE, PA. 15230

TEST CERTIFICATE

MILL ORDER NO.

CUSTOMER P.O.

70841 1

11-15679-656

6476 JW

DATE:

6/08/76 FILE NO. 6368-03-06

CONSIGNEE:

PC #53

PITTSBURGH-DES MOINES STEEL CO
NEVILLE ISLAND
PENNSYLVANIA 15225

8

THIS MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATIONS.

KODAK EX-XXXXXXMINXXXXX PDM MS 7.26 REV. B 9/26/75 SA-316 GR. 70 ASME CODE SECTION II &
III SUR NE 1971 EDITION THRU WINTER 1973 ADDENDA N-1160 8/4/76

BEND TEST

D.K. HOMOGENEITY TEST

O.K.

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	RE	RE	BRAIN SIZE
C6297	.27 ✓	.92 ✓	.005 ✓	.022 ✓		.23 ✓						AL. TREATED		7-8 ✓
THIS REPORT HAS BEEN CHECKED AND FOUND TO COMPLY WITH APPLICABLE SPECIFICATIONS														
15679														
15680														

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	BHN	IMPACTS ✓ LV-25 F	FRACTURE APPEARANCE ✓ % SHEAR	DESCRIPTION	
C6297	1	540 555	800 800	27✓ 28✓			✓ 26 LATERAL EXPANSION IN INCHES .022	✓ 24 .020	✓ 24 .019	✓ 20-20-20 = = = 2- 6" x 90 x 135 Iron ①
<u>Plates and tests heated to 1625°F./1675°F., held 1/2 hr. per inch min., and water quenched, then tempered 1220°F., held 1/2 hr. per inch min., and water quenched.</u>										
<u>Tests stress relieved by heating within a rate of 100°F. per hr. to 1100°F./1150°F., held 6 hrs. and furnace cooled within a rate of 100°F. per hr. to 800°F.</u>										

We hereby certify the above information is correct.

SUPERVISOR-SIGNING

H. A. Klein

12-011-48

CERTIFICATE OF TESTS			SHIPPED VIA			CAR/INITIAL AND NO.			DATE SHIPPED			SHIP/REF. NO.			IMPACT TYPE A NOTCH Y SIZE F		
OUR ORDER NO.	CUST. ORDER NO.	RAIL	NO. PCS.	YIELD PSI	MP 6500777	1/1/75			BEND TEST	FRACT. TEST	BHN	ORIENT.	TEMP.	1	2	3	Avg.
HS 5937	894	DESCRIPTION	BAR OR PLATE NO.	TENSILE PSI	% ELONG.	% REDUCT.						85					
PLTS FOR PV NORM ASME SA537 CL 1 MOD TO THICK PER CODE CASE 1646 MOD TO LO S (.010") REM TREAT & P-EM SPEC ME-10-9 REV A(4/1/74) +S1 VAC DEGAS +S3 SWRT TEST CPMS @ 1125°F OR 25°F FOR 15 HRS PER HB +620 +S5 CVMT 50 FT LBS & 35 MILS L.E. @ +20F RPT % SHEAR +S6 DWT PER E208 NO BRK G -40F PER PLT +S12 UT PER A578-63+S1 100% SCAN +S2 ACCEPTANCE STD PER NB-2532 1(B) RECALLED +S53 APP RESIDUALS. ALL TO MEET B&PV CODE SECT II III S/73 ADDENDA. TYPE P3 DWT SPECIMENS. HEAT: 56464 3-1/2 x 64 x 217" 4892I <i>Item C 14676 ID 7227</i>			2	50600	78700	33.0	2"	OK				THIS REPORT HAS BEEN CHECKED AND FOUND TO COMPLY WITH THE ABOVE SPECIFICATIONS Signed <i>J. D. Roberts</i> Date <u>4-21-75</u> <i>Sold to West 10.5 Gal C so Ex HR PQD-2</i>	82	8-27-76			
HEAT: 47111 3-1/2 x 64 x 217" 4894I <i>Item C 14676 ID 7229</i>			2	50900	77600	33.0	1650°F, TIME 8 TE	OK				T +20°F 61 70 76 69 LE IN MILS 54 60 64 59 % SHEAR 20 80 85 82	2 D. PT-40°F NO BREAK - LONGITUDINAL P: 75 MINUTES & AIR COOLED. ** T +20°F 50 53 63 55 LE IN MILS 42 50 57 50 % SHEAR 40 40 40 40				
CONTINUED PG. 2			2	50900	77600	33.0	1650°F, TIME 8 TE	OK				2 D. PT-40°F NO BREAK - LONGITUDINAL					

HEAT	C	Mn	P	S	Si	Cr	Ni	Mo	Cu	Ti	V	B	Cb	Al	N	GRAIN
56464	.19	1.33	.010	.006	.31	.25	.15	.07	.14							8
47111	.19	1.39	.010	.010	.34	.23	.16	.05	.17							8
47201	.18	1.37	.011	.006	.37	.20	.16	.06	.11							8
47123	.18	1.39	.010	.010	.40	.25	.16	.06	.12							8
47239	.20	1.35	.010	.008	.39	.22	.15	.07	.12							8

THE CHEMICAL, PHYSICAL OR MECHANICAL TESTS REPORTED HEREWITH ARE CORRECT AS CONTAINED IN THE RECORDS OF THE CORPORATION

SIGNED *J. D. Roberts* METALLURGICAL DEPT.

"THIS CERTIFIED TEST REPORT HAS BEEN DELIVERED TO A CONSIGNEE OF MATERIAL PURCHASED FROM ARMCO STEEL CORPORATION. TO AVOID THE POSSIBILITY OF ITS MISUSE, ON THE REDELIVERY OF THIS REPORT TO A THIRD PARTY IT MUST BE RECERTIFIED BY AND UNDER THE NAME OF SUCH CONSIGNEE."

17011050060

ITEM ORDER NO	CUST. ORDER NO.	SHIPPED VIA	CAR/INITIAL AND NO		DATE SHIPPED		SHIP HLF. NO.	DATE REC.	BY	
			KID 4500777		1-7-75					
DESCRIPTION	BAR OR PLATE NO.	NO. PCS.	YIELD PSI	TENSILE PSI	% ELONG.	% REDUCT.	BEND TEST	FRACT TEST	BRINELL	IMPACT TYPE A NOTCH V SIZE F
SEE HEADING, PG. 1				2"						
HEAT: 47201 3-1/2 x 64 x 217	6181I	1	50700	80400	28.0		ok			T +20°F 83 84 87 85 LE IN MILS 75 75 77 76 % SHEAR 70 70 70 70 2 DLT-40°F NO BREAK - LONGITUDINAL
AC 14676 D 7254										
AC 14676 D 7228	6183I	2	50400	74900	34.0		ok			T +20°F 90 93 96 93 LE IN MILS 76 78 78 77 % SHEAR 60 70 70 67 2 DLT-40°F NO BREAK - LONGITUDINAL
HEAT: 47123 3-1/2 x 64 x 217	4896I	1	50900	79700	30.0		ok			T +20°F 52 55 57 55 LE IN MILS 51 51 57 53 % SHEAR 35 35 40 37 2 DLT-40°F NO BREAK - LONGITUDINAL
AC 14676 D 7226										
PLTS & TEST CPSNS WERE NORMALIZED @ 1650°F, TIME @ TEMP: 70 MINUTES & AIR COOLED. TEST CPSNS WERE STRESS RELIEVED @ 1125°F, TIME @ TEMP: 15 HRS & FURNACE COOLED.* MAX HEATING RATE ABOVE 600°F: 114°F/HR MAX COOLING RATE DOWN TO 600°F: 143°F/HR										
 3C 8-27-76										
CONTINUED PG. 3										
HEAT	C	Mn	P	S	Si	Cr	Ni	Mo	Cu	Ti V B Cb Al N GRAIN
										THIS REPORT HAS BEEN CHECKED AND FOUND TO COMPLY WITH APPLICABLE SPECIFICATIONS
										Signed <u>J. D. Roberts</u> Date <u>4-24-75</u>
										Plated to Prod 10.9 Rev C
										SEE ECAH PQR-2.
										THE CHEMICAL, PHYSICAL OR MECHANICAL TESTS REPORTED HEREWITH ARE CORRECT AS CONTAINED IN THE RECORDS OF THE CORPORATION

-2- of 4

PITTSBURGH-DES MOINES STEEL CO

Naeville Island Pa

SIGNED J. D. Roberts METALLURGICAL DEPT

"THIS CERTIFIED TEST REPORT HAS BEEN DELIVERED TO A CONSIGNEE OF MATERIAL PURCHASED FROM ARMCO STEEL CORPORATION. TO AVOID THE POSSIBILITY OF ITS MISUSE, ON THE REDELIVERY OF THIS REPORT TO A THIRD PARTY IT MUST BE RECERTIFIED BY AND UNDER THE NAME OF SUCH CONSIGNEE."

8701105000

Rev

PURCHASED
PITTSBURGH-DES MOINES
STEEL CO.
MR. JACK McCARTHY
NEVILLE ISLAND
PITTSBURGH, PA. 15225

15679
15680

LUKENS COMPANY

COATERSVILLE, PA. 19320
TEST CERTIFICATE

DATE
CONSIGNEE

8/27/76
FISH-BEDS IRONIES STEEL CO.
NEVILLE ISLAND
PENNSYLVANIA 15225

FILE 58-03-06

MILL ORDER NO.
71774-1

CUSTOMER P.O.
11-15679-346

280/6 BT

REVISED COPY 9-7-76

PRINT NO. A-29 REV. D 1110 1/1/76

SA-514 GR. 60 ANNE. COLD STR. 1/2 IN. THK. ME 1971 ED. II. THK. 1
WINTER 1973 APPENDIX

SA-1140 8/4/78

BC 9-24-76

BEND TEST

HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NH	CR	MO	V	II	AL	R	GRANITE SIZE
E/185	.025	.025	.003	.021		.23								1/4

Please destroy other test report previously sent.
This is a revised copy.
Reason: Error in spec.
Sorry we caused you an inconvenience.

AS

9-23-X

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PP X100	TENSILE PP X100	% BOND IN 100	% E.A.	BHN	IMPACTS			TEMP. C/F 400°F 400°C	TIME HR. 400°F 400°C	DESCRIPTION
							CU	OF	CU			
E/185	12	494	654	76	LATERAL EXPANSION .099	166 .099	168 .098	170 .099	99-99-99	2-	ID 13391 1 X 84 X 247	
E/185	14	461	650	59	LATERAL EXPANSION .096	176 .096	185 .083	183 .092	99-99-99	2-	ID 13393 1 X 84 X 247	
E/185	6A	449	644	26	LATERAL EXPANSION .098	162 .094	188 .094	180 .096	99-99-99	2-	ID 13392 1 X 84 X 219	

COPY

of A. Kline

PLATES AND TESTS NORM. 1625 F-11675-F. HELD 1/2 HR. PER INCH W.G. AND AIR COOLED.

ID-A3391 THRU ID-A3393

We hereby certify the above information is correct.

10111090010

Personnel Airlocks

FORM N-1A MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS
Alternate Form for Single Chamber Completely Shop-Fabricated Vessels Only
As required by the Provisions of the ASME Code Rules

1. Manufactured by	W.J. WOOLLEY CO., RIVER FOREST, ILLINOIS 60305 (Name and address of Manufacturer)								
2. Manufactured for	PITTSBURGH-DES MOINES STEEL CO. - PITTSBURGH, PA (Name and address of Purchaser)								
3. Type Horiz.	Vessel No. (1073-1) (Horiz. or Vert.)	N/A (Mfrs. Serial)	Natl. Bd. No. (State & State No.)	N/A	Year Built	1980			
4a. Applicable ASME Codes: Section III, Edition	1974	Addenda date	Hinter '75	Case No.	N/A	Class MC			
4. Shell: Material	SA516 Gr.70	T.S. 70,000	Nonm. 1/2	Cart.	12	4-1/4			
				In. Allow.	18	3			
5. Seams: Long	Welded Butts	R.T.	Yes	R.T.	Yes	Efficiency 100%			
	Welded Butts	H.T.	Yes	R.T.	Yes	No. of Courses 3			
6. Heads: (a) Material	SA516 Gr.70	T.S. 70,000	(b) Material	SA516 Gr.70	T.S. 70,000				
Location (Top, bottom, ends)	React.	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flange Diameter	Side to Pressure (Convex or Concave)	
(a) Shell Ends Cont.	React.	2-1/2"	1-3/4"	Rib Reinforced			138"		
(b) Doors	React.	1-3/4"	Rib Reinforced				50" x 30"		
If removable, bolts used	1"	Other fastening							
(Material, Spec. No., T.S., Size, Number)									
7. Design Pressure	56.5	psi at max. temp.	225°F	at temp. of	-20	°F.	Charpy Impact 20 ft-lb	Pneumatic or	Test Press 55.0 psi.
8. Safety or Relief Valve Outlets: Number		Size		Location	None Supplied				
9. Nozzles:	Number	Dia. or Size	Type	Material	Thickness	Manufacture Materials	Flow Attached		
<u>Unit to ship without appurtenances</u>									
10. Inspection Manholes, No.		Size		Location					
Draining Handholes, No.		Size		Location					
Glass	Threaded, No. 2	Size 7"	Diaphragm	1 each door					
11. Supports: Skirt	Lugs	Legs	3/4" THK	Other	Attached				
(Yes or No)	(Number)	(Number)	(Describe)	(Where & How)					
12. Remarks:	This Data Report covers one personnel airlock only as listed in Brown & Root design specification 2C269SS006 Rev. G as a code stamped MC component. See attached manufacturer's partial Data Report (Form N-2) issued and approved by Murdock, Inc.								

(Brief description of purpose of the vessel--late contents.)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.

Date 2-21-1980 Signed W.J. WOOLLEY CO. By J. P. H. S. D. J. S. /
(Manufacturer)

Certificate of Authorization Expires May 3, 1980 Certificate of Authorization No. N-1733

CERTIFICATION OF DESIGN

Design information on file at Brown & Root, Inc., Houston, Texas

Design analysis report on file at W.J. Woolley Co., River Forest, Illinois

Design specifications certified by H.S. Cameron, Jr. Prof. Eng. State TX-15 Reg. No. 26694

Service analysis report certified by R.A. Maffei Prof. Eng. State Illinois Reg. No. 62-36033

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY W.J. Woolley Co. at River Forest, Illinois

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of California, and employed by HSRIAL of Hartford, Connecticut

Have inspected the pressure vessel described in this Manufacturer's Data Report on 11-30-1979, and state that to the best of my knowledge and belief, the Manufacturer has constructed the pressure vessel in accordance with the ASME Code Section III.

By signing this certificate neither the Inspector nor his firm nor makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12-14-1980 Inspector W.H. Schleifer

Commissioner O.H. 1250

National Board, State, Province and No.

*Supplemental sheets in form of lists, sketches or diagrams may be used provided (1) area is 10" x 13", (2) information on single sheet is in one data report or contained on each sheet, and (3) each sheet is numbered and number of sheet is recorded in item 12, "Remarks".
This form (Ed. 2) is obtainable from the ASME, 225 E. 47th St., New York, N.Y. 10017
Printed in U.S.A. (4/72)

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. I

(a) Manufactured by MURDOCK, INC., 15300 S. Avalon Blvd., Compton, CA 90220
(Name and address of NPT Certificate Holder)

(b) Manufactured for W.J. WOOLLEY CO., 7425 W. Lake St., River Forest, Illinois 60305
(Name and address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holder's Serial No. of Part MI 084 Nat'l Bd. No. N/A

73-1PLA-01 Rev. 4 Drawing Prepared by W.J. WOOLLEY CO.

(c) Description of Part Inspected PERSONNEL AIR LOCK

Winter

(c) Applicable ASME Code: Section III, Edition 1974, Addenda date 1975, Case No. N/A Class MC

3. Remarks: Personnel air lock for concrete containment vessel.

(Brief description of service for which component was designed)

Part not pressure tested by this manufacturer for Code acceptance.

(See attachment #1, 1 sheet)

NOTE: See amended data, Page 2 of 2.

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
 (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the equipment Design Specification and Stress Report.)

are February 13, 1980 Signed MURDOCK, INC. By C. D. Callahan
(NPT Certificate Holder)

Certificate of Authorization Expires January 5, 1982 Certificate of Authorization No. N-1290

CERTIFICATION OF DESIGN FOR APPURTEANCE (when applicable)

Design information on file at Brown & Root, Inc., Houston, Texas

Stress analysis report on file at W.J. Woolley Co., River Forest, Illinois

Design specifications certified by H.S. Cameron, Jr. Prof. Eng. State Texas Reg. No. 26694

Stress analysis report certified by R.A. Maffei Prof. Eng. State Illinois Reg. No. 62-36033

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of California and employed by LIC** of Long Grove, Illinois have inspected the part of a pressure vessel described in this

Partial Data Report 2-13 1980, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date Feb. 27 13 1980

C. D. Callahan
Inspector's Signature

Commissions

Dec 975
National Board, State, Province and No.

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA516 Gr.70 Nominal T.S. 70,000 Corrosion N/A in. Thickness 1/2 in. Allowance 0 in. Dia. 12 ft. 3 in. (Kind & Spec. No.) (Min. of Range Specified)

Seams: Long Welded Butts H.T. Yes R.T. Yes Efficiency 100%

Girth Welded Butts H.T. Yes R.T. Yes No. of Courses 3

6. Heads: (a) Material SA516 Gr.70 T.S. 70,000 (b) Material SA516 Gr.70 T.S. 70,000

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
Reactor	<u>2-1/2</u>						<u>123"</u>	
(a) Shell Ends	<u>2-1/4"</u>	<u>1-1/2"</u>	<u>1-1/2"</u>	<u>1-1/2"</u>	<u>1-1/2"</u>	<u>1-1/2"</u>	<u>50" x 90"</u>	
(b) Doors	<u>Cont.</u>	<u>1-3/4"</u>	<u>1-3/4"</u>	<u>1-3/4"</u>	<u>1-3/4"</u>	<u>1-3/4"</u>		

If removable, bolts used N/A Other fastening N/A
(Material, Spec. No., T.S., Size, Number) (Describe or attach sketch)

7. Jacket Closure: N/A
(Describe edge and weld, bar, etc. If bar give dimensions, if bolted, describe or sketch)

8. Design pressure³ 56.5 psi at 226 °F Drop Weight N/A
Charpy Impact 20 ft-lb at temp. of -20 °F

Items 9 and 10 to be completed for tube sections

9. Tube Sheet: Stationary, Material N/A Dia. in. Thickness in. Attachment Welded, Bolted
(Kind & Spec. No.) (Subject to pressure)

Floating, Material N/A Dia. in. Thickness in. Attachment

10. Tubes: Material N/A O.D. in. Thickness inches Number Type
(S.I. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material N/A Nominal T.S. Thickness in. Corrosion N/A in. Allowance 0 in. Dia. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long H.T. Yes R.T. Yes Efficiency %

Girth H.T. Yes R.T. Yes No. of Courses

13. Heads: (a) Material N/A T.S. (b) Material T.S.

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
----------	-----------	-----------------	-------------------	---------------------	-----------------------	-------------------------	------------------	------------------------------------

(a) Top, bottom, ends

(b) Channel

If removable, bolts used (a) (b) (c) Other fastening
(Describe or attach sketch)

Drop Weight

Charpy Impact ft-lb

at temp. of °F

14. Design pressure³ psi at °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Cutters: Number = 0 = Size Location None supplied

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Size or Size	Type	Material	Thickness	Reinforcement Material	How Attached
-----------------------------------	--------	--------------	------	----------	-----------	---------------------------	--------------

(See attachment #1, 1 sheet)

17. Inspection Manholes, No. = 2 = Size 60" x 90" Location Shell ends (Doors Item 6(b))

Openings: Handholes, No. = 0 = Size Location

Glass: Threaded, No. 2 Size 2" dia. 3/4" thick Location Leach door

18. Supports: Skirt No Lugs = 0 = Lugs = 0 = Other N/A Attached N/A
(Yes or No) (Number) (Number) (Describe) (Check & Initial)

1. (a) Manufactured by MURDOCK, INC., 15800 S. Avalon Blvd., Compton, CA 90220
(b) Manufactured for W.J. WOOLLEY CO., 7425 W. Lake St., River Forest, Ill. 60305
2. Identification-Certificate Holder's Serial No. of Part MI 084 Nat'l Bd. No. N/A
(a) Constructed According to Drawing No. 73-1PLA-01 Rev. 4
Drawing Prepared by W.J. WOOLLEY CO.
(b) Description of Part Inspected PERSONNEL AIR LOCK
(c) Applicable ASME Code: Section III, Edition 1974, Addenda date Winter 1975,
Case No. N/A Class MC

ITEM NO. 16 NOZZLES:

<u>Purpose</u>	<u>Number</u>	<u>Dia. or Size</u>	<u>Material</u>	<u>How Attached</u>
Elect. Penet.	2	6"	SA350 LF 2	Welded
Emer. Air	1	3"	SA333 Gr. 6	Welded
Mech. Hub	2	4-1/2"	SA350 LF 2	Welded
Gauge Coupling	17	1/2"	SA105	Welded
Equalizing Coupling	2	1"	SA350 LF 2	Welded
Over Press. Relief Coupling	1	2"	SA350 LF 2	Welded

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. I

(a) Manufactured by MURDOCK, INC., 15800 S. Avalon Blvd., Compton, CA 90220
(Name and address of NPT Certificate Holder)

(b) Manufactured for W.J. WOOLLEY CO., 1315 West 22nd St., Oak Brook, Illinois 60521
(Name and address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holder's Serial No. of Part MI 084 Nat'l Bd. No. N/A
73-1PLA-01 Rev. 4

(a) Constructed According to Drawing No. _____ Drawing Prepared by W.J. Woolley Co.

(b) Description of Part Inspected Personnel Air Lock

(c) Applicable ASME Code: Section III, Edition 1974, Addenda date _____, Case No. N/A Class MC.

3. Remarks: To accomodate Detail Drawing Revisions after date of original
(Brief description of service for which component was designed)
N-2 Form signatures, and to change address as noted in item 1. (b).

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
 (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Aug 12 1982 Signed MURDOCK, INC. By W.B. Parker
(NPT Certificate Holder)

Certificate of Authorization Expires January 5, 1985 Certificate of Authorization No. N-1290

CERTIFICATION OF DESIGN FOR APPURTEANCE (when applicable)

Design information on file at BROWN & ROOT, INC., HOUSTON, TEXAS

Stress analysis report on file at W.J. WOOLLEY CO., OAK BROOK, ILLINOIS

Design specifications certified by H.S. Cameron Prof. Eng. State Texas Reg. No. 26624

Stress analysis report certified by R.A. Maffei Prof. Eng. State Illinois Reg. No. 62-35083

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of California and employed by LMC** of Long Grove, Illinois have inspected the part of a pressure vessel described in this Partial Data Report FEB 12 1982 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 1/15/82 19 82

John L. Davis
Inspector's Signature

Commission No. CA-1256
National Board, State, Province and No.

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA516 Gr.70 Nominal T.S. 70,000 Thickness 1/2 in. Corrosion N/A in. Allowance 1/2 in. Dia. 12 ft. 1 in. Length 18 ft. 3 in. (Kind & Spec. No.) (Min. of Range Specified)

Seams: Long Welded Butt S.H.T.¹ Yes R.T. Yes Efficiency 100 %

Girth Welded Butts H.T.¹ Yes R.T. Yes No. of Courses 3

5. Heads: (a) Material SA516 Gr.70 T.S. 70,000 (b) Material SA516 Gr.70 T.S. 70,000

Location (Top, bottom, ends)	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
(a) <u>Shell Ends</u> Cont.	<u>2-1/2"</u>	<u>1-3/4"</u>	<u>Rib Reinforced</u>			<u>138"</u>	
(b) <u>Doors</u> Cont.	<u>1-3/4"</u>	<u>1"</u>	<u>Rib Reinforced</u>			<u>60" x 90"</u>	
If removable, bolts used	<u>N/A</u>			Other fastening	<u>N/A</u>		(Describe or attach sketch)

6. Jacket Closure: N/A
(Describe as ogee and weld, har, etc. If bolted, describe or sketch)

Drop Weight _____

Charpy Impact 20 ft-lb

at temp. of -20 °F

7. Design pressure² 56.5 psi at 225 °F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary, Material N/A Dia. _____ Thickness _____ in. Attachment _____ (Welded, Bolted)
(Kind & Spec. No.) (Subject to pressure)

Floating, Material N/A Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material N/A O.D. _____ in. Thickness _____ inches/in. Number _____ Type _____ (Spiral or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

Shell: Material N/A Nominal T.S. Thickness in. Corrosion in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long N/A H.T.¹ Yes R.T. Yes Efficiency 100 %

Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material N/A T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
----------	-----------	-----------------	-------------------	---------------------	-----------------------	-------------------------	------------------	------------------------------------

(a) Top, bottom, ends _____

(b) Channel _____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____

(Describe or attach sketch)

Drop Weight _____

Charpy Impact _____ ft-lb

at temp. of _____ °F

14. Design pressure² N/A psi at °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number -0- Size _____ Location None Supplied

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
(See attachment #1, 1 sheet)							

Inspection Manholes, No. 2 Size 60" x 90" Location Shell ends [Doors Item 6(b)]

Openings: Handholes, No. -0- Size _____ Location _____

Sight Sight Threaded, No. 2 Size 2-1/2" dia, 3/4" thick Location 1 each door

18. Support Skirt 10 Legs -0- Legs -0- Distr. 1/4" Attatched N/A
(Type or Not) (Number) (Number) (Describe)

¹If not welded heat treated.

²At other ratings - internal pressure with sufficient temperature when applied.

LUCKEN'S STEEL COMPANY
COATESVILLE 13230

DATE 3-3-78
CONSIGNEE

Murdock, Inc.
Compton, CA

TEST CERTIFICATE

MILL ORDER NO. 77072-12 CUSTOMER # 22510-M MP 3178 VS

THIS HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATIONS
516 Gr. 70 ASME Code SECT. II & III Sub NE 1974 Edition thru Winter 1975 Addenda N-1160 8/4/78

BEND TEST												HOMOGENEITY TEST											
												CHEMICAL ANALYSIS											
MELT NO.	C	MN	P	I	S	Cu	Si	Ni	T	Cr	Mo	V	Ti	Al	S	Grain Size							
325	.27	1.13	.009	.008			.25								VIP Steel	7-8							

SEP 09 1980

PHYSICAL PROPERTIES												DESCRIPTION														
MELT NO.	SLAB NO.	YIELD PSI 2100	TENSILE PSI 2100	% ELONG IN 2	% E.A.	XXX IMPACTS	Fracture Appearance																			
325	1	508	813	29		XXX V-Notch -20°F.	% Shear																			
												Loc.														
												T 30	23	20	1 - 6" x 120 x 150											
												L 32	30	30												
												Lateral Expansion in Inches														
												T .017	.020	.027												
												L .029	.026	.028												
late and tests norm. 1625-1675°F., held 1/2 hr. per inch min. and air cooled.																										
Tests stress relieved by heating within a rate of 100°F. per hr. to 1100-1150°F., held 15 hrs. and furnace cooled within a rate of 100°F. per hr. to 800°F.												<div style="border: 1px solid black; padding: 5px; display: inline-block;"> MURDOCK INC. LOI # A2B409 WOL 3-3007-05 JOB # WOL 3-3008-05 DATE 3-18-78 </div>														
All information contained in this document is confidential and is the sole property of LUCKEN'S STEEL COMPANY. It is to be used only for the purpose intended by the company and is not to be reproduced or distributed without written permission.												IPC 6 x 120 x 150 BECHTEL NOV 13 1978 281														

Auxiliary Airlocks

FORM N-1A N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR VESSELS*

Alternate Form for Single Chamber Completely Shop-Fabricated Vessels Only

As Required by the Provisions of the ASME Code Rules, Section III, Div. 1

1. Manufactured by W. J. Woolley Co., 4955 Spring Grove Ave., Cincinnati, Ohio 45232
(Name and address of N Certificate Holder)

2. Manufactured for Pittsburgh-Des Moines Steel Co., Pittsburgh, PA
(Name and address of Purchaser)

3. Type Horiz. Vessel No. (73-1ELA-01) CRN No. N/A Nat'l Bd. No. N/A Yr. Built 1984
(Mfrs. Serial No.)

3a. Applicable ASME Code: Section III, Edition 1974; Addenda date Winter '75; Case No. N/A Class MC

4. Shell: Material SA516 Gr. 70 T.S. 70,000 Nom. Thk 1/2 in. Corr. Allow. N/A in. Diam. 5 ft. 6 in. Length 10 ft. 0 in.
(Kind & Spec. No.) (Min. of range specified)

5. Seams: Long Welded Butt H.T.¹ yes R.T. yes Efficiency 100 %
Girth Welded Butt H.T.¹ yes R.T. yes No. of Courses 2

6. Heads: (a) Material SA516 Gr. 70 T.S. 70,000 (b) Material SA516 Gr. 70 T.S. 70,000
Location (top, (bottom, ends) Crown Knuckle Elliptical Conical Hemispherical Flat Side to Pressure
(bottom, ends) Thickness Radius Radius Ratio Apex Angle Radius Diam. (convex or concave)
(a) Shell ends Reactor Outer 2" Rib Reinforced 55°
(b) Doors Reactor Outer 2" 36°
If removable, bolts used N/A Other fastening N/A
(Material, Spec. No., T.S., Size, Number) (Describe or attach sketch)

7. (a) Design Pressure 56.5 psi at Max. Temp. 286 °F (b) Min. Pressure-Test Temp. -20 °F
(c) Hydrostatic, Pneumatic, or Combination Test Pressure 65 psi

8. Safety or Relief Valve Outlets: Number None Size None Location Supplied

9. Nozzles:
Purpose (inlet, outlet, drain) Number Diam. or Size Type Material Thickness Reinforcement Material How Attached
N/A

10. Inspection Manholes: No. 2 Size 36" dia. Location Shell Ends (door item 6(B))
Openings: Handholes: No. 0 Size Location
Threaded: No. 2 Size 7" dia. x 3/4" thk. Location Shell Ends (One each end)

11. Supports: Skirts No Lugs 0 Legs 0 Other N/A Attached N/A
(Yes or no) (Number) (Number) (Describe) (Where & how)

12. Remarks: 1) This data report modified to accomodate detail drawing revisions after date of original N-1A Form signature (See attachment A for listing of applicable manufacturers data reports).
2) This data report outlines one (1) emergency airlock, listed in Bechtel Power Corp. Spec. 2C269SS0006 - Rev. 3, as a ASME Code stamped N-Class MC-Component.
(Brief description of purpose of the vessel. State contents.)

We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code.
Section III.

Date 11-20 19 84 Signed W. J. Woolley Company By Tom Frandsen
(In Certificate Holder)

Certificate of Authorization Expires May 3, 1986 Certificate of Authorization No. N-1733

¹If postweld heat-treated. ²List other internal or external pressures with coincident temperature when applicable.

*Supplemental sheets in form of lists, sketches, or drawings may be used provided: (1) size is 8½ in. x 11 in.; (2) information in Items 1 through 3 of this Data Report is included on each sheet; and (3) each sheet is numbered and the number of sheets is recorded in Item 12, Remarks.

FORM N-1A MANUFACTURERS' DATA REPORT FOR NUCLEAR VESSELS*
Alternate Form for Single Chamber Completely Shop-Fabricated Vessels Only
As required by the Provisions of the ASME Code Rules

1. Manufactured by W.J. WOOLLEY CO., River Forest, Illinois 60305
(Name and address of Manufacturer)

2. Manufactured for PITTSBURGH-DES MOINES STEEL CO., Pittsburgh, Pa.
(Name and address of Purchaser)

3. Type HORIZ. Vessel No. 73-1ELA-Q1 N/A Natl. Bd. No. N/A Year Built. 1980
(Name or Vessel) (Mfrs. Serial No. State & Year No.)

3a. Applicable ASME Code: Section III, Edition 1974, Addenda date Winter '75 Case No. N/A Class MC
SA516 Gr.70

4. Shell: Material SA516 Gr.70 T.S. 70,000 Nom. 1/2 Corr. N/A In. Dia. 5 Ft. 6 In. Length 10 Ft. 0 In.
(Kind & Spec. No.) (Matl. of Range specified)

5. Seams: Long Welded Buttst. Yes R.T. Yes Efficiency 100 %
 Girth Welded Buttst. Yes R.T. Yes No. of Courses 2

6. Heads: (a) Material SA516 Gr.70 T.S. 70,000 (b) Material SA516 Gr.70 T.S. 70,000

Location (Top, bottom, end)	Crown Radius	Knuckle Radius	Eccentric Ratio	Conical Apex Angle	Concave Radius	Flat Diameter	Bids to Pressure (Convex or Concave)
(a) <u>Shell Ends Outer</u>	<u>1"</u>	<u>Rib Reinforced</u>				<u>55"</u>	
(b) <u>Doors</u>	<u>Outer</u>	<u>2"</u>				<u>36"</u>	

If removable, bolts used N/A Other fastening N/A
(Material, Spec. No., T.S., S.S. Number) (Describe or Attach Sketch)

Drop Weight. N/A Hydrogen MC

Charpy impact. 20 ft-lb Pneumatic or -20 °F. Conventional Press 65 psi

7. Design Pressure 56.5 psi at max. temp. 286 °F. at temp. of 65 psi

8. Safety or Relief Valve Outlets: Number None Supplied Size None Supplied Location None Supplied

9. Nozzles:

Purpose (Inlet, Outlet, Drain) Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached

10. Inspection Manholes, No. 2 Size 36" Dia. Location Shell Ends [Doors Item 6(b)]
 Openings: Handholes, No. 0 Size None Location None
 SIGHT GLASS Threaded, No. 2 Size 7" Dia. X 3/4" N.P.T. Location Shell Ends [One each end]

11. Supports: Skirt NO Lugs 0 Legs 0 Other N/A Attached N/A
(Yes or No) (Number) (Number) (Describe) (Where & How)

12. Remarks: This data report covers one emergency air lock for Unit #1 listed in Brown & Root design specification 2C26955006, Rev. G as a Code stamped MC component. See attached Manufacturer's Partial Data Report (Form N-2) issued and approved by Murdock, Inc., MI #086.
(Brief description of purpose of the vessel—See Comments.)

If Passivated Heat-Treated.
 List other internal or external pressure with coincident temperature when applicable.
 We certify that the statements made in this report are correct and that this nuclear vessel conforms to the rules of construction of the ASME Code, Section III.
 Date DEC 11 1980 Signed W.J. WOOLLEY CO. By J.F. McManion
(Manufacturer)

Certificate of Authorization Expires May 3, 1983 Certificate of Authorization No. N-1733

CERTIFICATION OF DESIGN			
Design information on file at	Brown & Root, Inc., Houston, Texas		
Stress analysis report on file at	W.J. Woolley Co., River Forest, Illinois		
Design specifications certified by	H.S. Cameron, Jr.	Prof. Eng. State	Texas Reg. No. 26694
Stress analysis report conducted by	R.A. Maffei	Prof. Eng. State	Illinois Reg. No. 62-36083

CERTIFICATE OF SHOP INSPECTION			
VESSEL MADE BY	W.J. Woolley Co.	at	River Forest, Illinois
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of	California	and employed by	Hartford, Connecticut
Have inspected the pressure vessel described in this Manufacturer's Data Report on <u>12-11-1980</u> , and			
state that to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with the ASME Code Section III.			
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.			
Date	<u>12-11-1980</u>	Commissioner	<u>CALIF 1187</u>
Inspector's Signature		National Board, State, Province and No.	

*Supplemental sheets in form of lists, schedules or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1-3 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 12 "Remarks".
 Printed in U.S.A. (4/72) This item (Data) is obtainable from the ASME, 345 E. 47th St., New York, N.Y. 10017

1. (a) Manufactured by WOOLLEY MANUFACTURING DIVISION, 1545 WHIPPLE ROAD S.W., CANTON, OHIO
 (Name and address of NPT Certificate Holder)

(b) Manufactured for W. J. WOOLLEY CO., 4955 SPRING GROVE AVE., CINCINNATI, OHIO
 (Name and address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holder's Serial No. Part P-2254 Nat'l Bd. No. N/A CRN No. N/A
 (a) Constructed According to Drawing No. 73-1ELA-01 REV. 5 Drawing Prepared by W. J. WOOLLEY CO.

(b) Description of Part Inspected MODIFICATIONS TO AUXILIARY AIRLOCK

(c) Applicable ASME Code: Section III, Edition 1974; Addenda date WINTER 75; Case No. N/A Class NC

3. Remarks: WORK PERFORMED BY WOOLLEY MANUFACTURING DIVISION ON THE AUXILIARY AIRLOCK MANUFACTURED BY
 (Brief description of service for which component was designed.)

MURDOCK, INC., COMPTON, CA. S/N MI 086. SEE PAGE 3 OF 3 FOR SCOPE OF WORK PERFORMED.

Item 4-8 inclusive to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers. N/A

4. Shell: Material -- T.S. -- Nom. Thk. -- in. Corr. Allow. -- in. Diam. -- ft. -- in. Length -- ft. -- in.
 (Kind & Spec. No.) (Min. of range specified)

5. Seams: Long -- H.T. -- R.T. -- Efficiency -- %
 Girth -- H.T. -- R.T. -- No. of Courses --

6. Heads: (a) Material -- T.S. -- (b) Material -- T.S. --

Location (top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diam.	Side to Pressure (convex or concave)
(a) <u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>
(b) <u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>

If removable, bolts used -- Other fastening -- (Material, Spec. No., T.S., Size, Number) (Describe or attach sketch)

7. Jacket Closure: -- (Describe as ogee and weld, bar, etc. If bar, give dimensions, if bolted, describe or sketch)

8. (a) Design Pressure² -- psi at -- °F (b) Min. Pressure-Test Temp. -- °F

Items 9 and 10 to be completed for tube sections. N/A

9. Tube Sheets: Stationary: Material -- Diam. -- in. Thk. -- in. Attachment -- (Welded, Bolted)
 (Kind & Spec. No.) (Subject to pres.)

Floating: Material -- Diam. -- in. Thk. -- in. Attachment --

10. Tubes: Material -- O.D. -- in. Thk. -- in. or gage Number -- Type --
 (Straight or U) (Describe or attach sketch)

Items 11-14 inclusive to be completed for inner chambers of jacketed vessels or channels of heat exchangers. N/A

11. Shell: Material -- T.S. -- Nom. Thk. -- in. Corr. Allow. -- in. Diam. -- ft. -- in. Length -- ft. -- in.
 (Kind & Spec. No.) (Min. of range specified)

12. Seams: Long -- H.T. -- R.T. -- Efficiency -- %
 Girth -- H.T. -- R.T. -- No. of Courses --

13. Heads: (a) Material -- T.S. -- (b) Material -- T.S. --

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diam.	Side to Pressure (convex or concave)
(a) Top, bottom, ends	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>
(b) Channel	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>	<u>--</u>

If removable, bolts used (a) -- (b) -- (c) -- Other fastening -- (Describe or attach sketch)

14. (a) Design Pressure² -- psi at -- °F (b) Min. Pressure-Test Temp. -- °F

¹If postweld heat-treated. ²List other internal or external pressures with coincident temperature when applicable.

*Supplemental sheets in form of lists, sketches, or drawings may be used provided: (1) size is 8½ in. x 11 in.; (2) information in Items 1 and 2 of this Data Report is included on each sheet; and (3) each sheet is numbered and number of sheets is recorded in Item 3, Remarks.



Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets:	Number	N/A	Size	N/A	Location	N/A				
16. Nozzles:										
Purpose (inlet, outlet, drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material				
-	-	-	-	-	-	-				
-	-	-	-	-	-	-				
-	-	-	-	-	-	-				
17. Inspection Manholes:	No.	N/A	Size	N/A	Location	N/A				
Openings:	Handholes:	No.	N/A	Size	N/A	Location	N/A			
Threaded:	No.	N/A	Size	N/A	Location	N/A				
18. Supports:	Skirt	N/A (Yes or no)	Lugs	N/A (Number)	Legs	N/A (Number)	Other	N/A (Describe)	Attached	N/A (Where & how)

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code, Section III.

(The applicable Design Specification and Design Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Design Report if the appurtenance is not included in the component Design Specification and Design Report.)

Date 11 - 16, 19 84 Signed WOOLLEY MFG. DIV. By Gary S Ridolfi
(NPT Certificate Holder)

Certificate of Authorization Expires 6-16-84 * Certificate of Authorization No. N-1112
* EXPIRATION DATE EXTENDED TO 12-16-84 BY ASME

CERTIFICATION OF DESIGN FOR APPURTEANCE (when applicable) N/A

Design information on file at ****

Stress analysis report on file at ****

Design specifications certified by **** Prof. Eng. State **** Reg. No. ****

Stress analysis report certified by **** Prof. Eng. State **** Reg. No. ****

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of OHIO and employed by H.S.B.I. & I. CO. of HARTFORD, CONNECTICUT have inspected the part of a pressure vessel described in this

Partial Data Report on 11-16, 19 84 and state that, to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11 - 16, 19 84

Dale A. Morgan
Inspector's Signature

Commission Ohio Comp.
National Board, State, Province and No.

WMD S.O. #13402-N SOUTH TEXAS PROJECT UNIT #1

BECHTEL P.O. NO. 14924-C-0011
WMD S.O. NO. 13402-N
SECTION 2 PAGE 4 DE 5

1. (a) MANUFACTURED AND CERTIFIED BY: WOOLLEY MANUFACTURING DIVISION
1545 WHIPPLE ROAD S.W.
CANTON, OHIO
- (b) MANUFACTURED FOR: W. J. WOOLLEY CO.
4955 SPRING GROVE AVE.
CINCINNATI, OHIO

2. IDENTIFICATION - CERTIFICATE HOLDER'S SERIAL NO. PART P-2254

NAT'L BD. NO. N/A CRN NO. N/A

3. REMARKS: (CONTINUATION)

SCOPE OF WORK PERFORMED:

A. PERFORMED THE FOLLOWING WELDING

DWG. #73-1ELA-21 REV. 11 WELDS #5 THRU 8
DWG. #73-1ELA-40 REV. 4 WELDS #9 THRU 23
DWG. #73-1ELA-33 REV. 2 WELDS #31 THRU 38

B. SUPPLIED THE FOLLOWING MATERIAL

DWG. #73-1ELA-02 REV. 10 PC. #18, 22, & 40
DWG. #73-1ELA-04 REV. 9 PC. #17
DWG. #73-1ELA-07 REV. 5 PC. #1, 5, 7, & 15
DWG. #73-1ELA-08 REV. 8 PC. #27
DWG. #73-1ELA-22 REV. 9 PC. #11 & 12
DWG. #73-1ELA-25 REV. 6 PC. #33
DWG. #73-1ELA-29 REV. 9 PC. #56
DWG. #73-1ELA-30 REV. 9 PC. #33
DWG. #73-1ELA-31 REV. 9 PC. #39
DWG. #73-1ELA-36 REV. 6 PC. #31
DWG. #73-1ELA-43 REV. 2 PC. #1, 5, 7, & 15

C. DRILLED AND TAPPED TWO (2) HOLES 1/2"-13 UNC X 3/4" DEEP IN REACTOR END COLLAR
(PC. #20-3) PER DRAWING #73-1ELA-20 REV. 10

D. PERFORMED WELD REPAIR PER MATERIAL AND WELD REPAIR REPORT #679

Jay S Rudolph 11-16-84
Dale A Morgan 11-16-84

RECHTE
606

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. I

1. (a) Manufactured by	MURDOCK, INC., 15800 S. Avalon Blvd., Compton, CA 90220 <small>(Name and address of NPT Certificate Holder)</small>		
(b) Manufactured for	W.J. WOOLLEY CO., 7425 W. Lake St., River Forest, Illinois 60305 <small>(Name and address of NPT Certificate Holder for completed nuclear component)</small>		
2. Identification-Certificate Holder's Serial No. of Part	MI 086	Nat'l Brd. No.	N/A
(a) Constructed According to Drawing No.	73-1ELA-01 Rev. 3	Drawing Prepared by	W.J. Woolley Co.
(b) Description of Part Inspected	Emergency Air Lock		
(c) Applicable ASME Code: Section III, Edition	1974	Winter 1975	
(d) Addenda date		Case No.	N/A
Class	MC		
3. Remarks:	Emergency air lock for concrete containment vessel. <small>(Brief description of service for which component was designed)</small> Part not pressure tested by this manufacturer for Code acceptance.		
See Attachment #1, 1 sheet.			

NOTE: See amended data, Page 2 of 2.

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
 (The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date December 2, 1980 Signed MURDOCK, INC. By R. L. Smith
(NPT Certificate Holder)
 Certificate of Authorization Expires January 5, 1982 Certificate of Authorization No. N-1290

CERTIFICATION OF DESIGN FOR APPURTEANCE (when applicable)			
Design information on file at	BROWN & ROOT, INC., HOUSTON, TEXAS		
Stress analysis report on file at	W.J. WOOLLEY CO., RIVER FOREST, ILLINOIS		
Design specifications certified by	H.S. Cameron	Prof. Eng. State	Texas Reg. No. 26694-
Stress analysis report certified by	R.A. Maffei	Prof. Eng. State	Illinois Reg. No. 62-36083

CERTIFICATE OF SHOP INSPECTION			
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of <u>California</u> and employed by <u>LMC**</u> of <u>Long Grove, Illinois</u> have inspected the part of a pressure vessel described in this Partial Data Report on <u>12/1/80</u> and state that to the best of my knowledge and belief the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.			
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.			
Date <u>12/1/80</u> <small>Inspector's Signature</small>	Commissions <u>Coring 475</u> <small>National Board, State, Province and No.</small>		

*Supplemental sheet in form of lists, schedules or drawings may be used provided all data is fully set forth in the information on items 1-12 on this form. If so used, it must be signed by the Inspector and the number of sheets must be indicated in item 12.

**Lumbermen's Mutual Casualty Company
 110-771 This form 16000-401 may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

FORM N-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA516 Gr. 70 Nominal T.S. 70,000 Corrosion N/A Thickness 1/2 in. Allowance 0 in. Dia. 5 ft. 6 in. Length 10 ft. 0 in. (Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long Welded Butts H.T.¹ Yes R.T. Yes Efficiency 100 %

Girth Welded Butts H.T.¹ Yes R.T. Yes

6. Heads: (a) Material SA516 Gr. 70 T.S. 70,000 (b) Material SA516 Gr. 70 T.S. 70,000 No. of Courses 2

Location (Top, bottom, ends)	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side in Press. (Conv. or Conc.)
(a) Shell Ends <u>Reactor 2"</u> Outer <u>1"</u> Rib Reinforced						<u>55"</u>	
(b) Doors <u>Outer 5/8"</u>						<u>36"</u>	
If removable, bolts used <u>N/A</u>					Other fastening <u>N/A</u>		

(Material, Spec. No., T.S., Size, Number) (Describe or attach sketch)

7. Jacket Closure: N/A (Describe as gage and weld, bar, etc. If bargage dimensions, if bolted, describe or sketch)

8. Design pressure² 56.5 psi at 286 °F Drop Weight N/A
Charpy Impact 20 ft-lb at temp. of -20 °F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary, Material N/A Dia. _____ Thickness _____ in. Attachment _____ (Kind & Spec. No.) (Subject to pressure) (Welded, Bolted)

Floating, Material N/A Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material N/A O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____ (Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material N/A Nominal T.S. Thickness in. Corrosion N/A Allowance 0 in. Dia. ft. in. Length ft. in. (Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long N/A H.T.¹ Yes R.T. Yes Efficiency _____ %

Girth N/A H.T.¹ Yes R.T. Yes No. of Courses _____

13. Heads (a) Material N/A T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side in Press. (Conv. or Conc.)
(a) Top, bottom, ends								
(b) Channel								

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)

14. Design pressure² N/A psi at 0 °F Drop Weight _____ Charpy Impact _____ ft-lb at temp. of 0 °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number 0 Size _____ Location None Supplied

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
(See Attachment #1, 1 sheet)							

17. Inspection: Manholes, No. 2 Size 36" dia. Location Shell Ends [Doors Item 5(b)]

Openings: Handholes, No. 0 Size _____ Location _____

Sight Glass, Threaded, No. 2 Size 1/2" dia. x 3/4" Thk Location Shell Ends [1 each end]

18. Supports: Skirt No Lugs 0 Legs 0 Other N/A Attached N/A (Where & How)

¹ If Passivated Heat-Treated:

² List other internal or external pressure with coincident temperature when applicable.

AMENDED
Page 2 of 2

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. I

1. (a) Manufactured by	MURDOCK, INC., 15800 S. Avalon Blvd., Compton, CA 90220	(Name and address of NPT Certificate Holder)
(b) Manufactured for	W.J. WOOLLEY CO., 1315 West 22nd St., Oak Brook, Illinois 60521	(Name and address of N.P.T. Certificate Holder for completed nuclear components)
2. Identification-Certificate Holder's Serial No. of Part	MI 086	Nat'l Bd. No. N/A
(a) Constructed According to Drawing No.	73-1ELA-01 Rev. 4	Drawing Prepared by W.J. Woolley Co.
(b) Description of Part Inspected	Emergency Air Lock	
(c) Applicable ASME Code: Section III, Edition	1974	Addenda date Winter 1975 Case No. N/A Class MC
3. Remarks:	To accomodate an As Constructed Drawing Revision after date of original (Brief description of service for which component was designed) N-2 Form signatures, and to change address as noted in item 1. (b).	

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
(The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date Aug 12 1982 Signed MURDOCK, INC. By W.B. Parker
(NPT Certificate Holder)

Certificate of Authorization Expires January 5, 1985 Certificate of Authorization No. N-1290

CERTIFICATION OF DESIGN FOR APPURTEANCE (when applicable)

Design information on file at BROWN & ROOT, INC., HOUSTON, TEXAS

Stress analysis report on file at W.J. WOOLLEY CO., OAK BROOK, ILLINOIS

Design specifications certified by H.S. Cameron Prof. Eng. State Texas Reg. No. 26694

Stress analysis report certified by R.A. Maffei Prof. Eng. State Illinois Reg. No. 62-36083

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of California and employed by LMC** have inspected the part of a pressure vessel described in this

of Long Grove, Illinois Partial Data Report on DEC - 2 1980 and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Aug 18 1982

E.G. Lee
Inspector's Signature

Commissioner C.R. 1256
National Board, State, Province and No.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) they fit SW-1 & SW-2, (2) information in items 1-2 on this

**Lumbermen's Mutual Casualty Company This form (1500040) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017
(10/77)

PURCHASER:

3rd Murdock, Inc.
Compton, CALUKENS STEEL COMPANY
COATESVILLE, PA 19320

TEST CERTIFICATE

DATE 3-3-78
CONSIGNEE

FILE NO. J-0-01-95

MILL ORDER NO. 77072-10 CUSTOMER PO. 22510-M MP 3178 VS

(THIS MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATIONS)

SA-516 Gr. 70 ASME Code Sect. II & III Sub NE 1974 Edition thru Winter 1975 Addenda N-1160 8/4/78

BEND TEST

HARDNESS TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	Grain-Size
c9044	.24	1.07	.011	.022		.26								7-8

NUCLEAR

PNPP
UNITS 122
CEI P 1251

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG	% RA	XXX XXX	IMPACT			Fracture Appearance % Shear	DESCRIPTION	
							V-Notch	-20°F.	Loc.			
c9044	2	460	766	30	30	A	T	22	20	22	20-20-20	1 - 3" x 160 x 200
						SEP 00 1980	L	28	32	29	30-30-30	

Verified records from continuous furnace show that this plate and tests were normalized 1625-1675°F., held 1/2 hr. per inch min. and air cooled.

Tests stress relieved by heating within a rate of 100°F. per hr. to 1100-1150°F., held 15 hrs. and furnace cooled within a rate of 100°F. per hr. to 800°F.

WPA
04 MAR 1981

1 PC 3 X 160 X 200

PDM
DOCUMENT
REVIEW
05N.J.W.
01
MAR 15 1978

We hereby certify the above information is correct.

A.I. REVIEW

SUPERVISOR TESTING

COPY

LOS ANGELES

EARLE M. JORGENSEN CO.

DELIVERY RECEIPT TEST REPORT

INVOICE NO.
4283 FL

CUSTOMER ORDER REF. NO.
31682 M

STEEL FORGE DIVISION

10650 SO ALAMEDA STREET • PHONE 567-1122 (Area Code 213)
MAILING ADDRESS P O Box 54633
LOS ANGELES, CALIFORNIA 90054

S 2-158140-1
O MURDOCK INC
D P O BOX 4249
T COMPTON CA 90224
O

SHIP SAME
TO 15800 SO AVALON

OUR TRUCK	WILL CALL	SHIP VIA CARRIER	F	DEST FREIGHT FWD.	OUR PLANT FREIGHT COLL.	O/P PREPAID CHARGE FRT.	O/P COLLECT ALLOW FRT.
X		COOK	O	X			
QUANTITY AND DESCRIPTION							
SA-350 LF-2 ASME SECT III. DIV 1 SUBSECTION NE CL-4C AND SUBSECTION NA, PARA NA-3767-4B/NA 3767-5 1974 EDITION WITH WINTER 75 ADDENDA FORGED OVERSIZE TO ALLOW FOR FINISH EQUALIZED QUENCHED AND DRAWN SAW CUT ENDS BLUE RED AND YELLOW 21106							
8 PCS 6 RD X 4-1/2							
MECHANICAL TESTING INCLUDED IN PRICE							
TOTAL WEIGHT							
BHN 153 ON 1 PALLET							
408# 25#							
433#							
HEAT NO. 02-215812							
MAR 19 1980							
WJM 09							
FDE DOCUMENT REVIEW 05							

NUCLEAR

BAY 9

C	MN	P	S	SIL	NI	CR	MO	V	CU	G/S	MILL	HEAT NO.
.25	.23	.011	.016	20						6/7	SHARON	215812

OP INVOICE NO.
1-15-80
SHIPPED
TYPED BY GILDA
TIME

4283 FL OK

CERTIFIED TEST REPORT

We certify that the material covered by this report has been inspected and tested in accordance with the applicable requirements described herein and test results are on file subject to examination.

By Ilverne Peice
TEST REPORT CLERK

SUBSCRIBED AND SWEARN TO BEFORE ME THIS

15 DAY OF JANUARY 19 80

Michael Morrione

NOTARY PUBLIC



NUCLEAR ORDERS ONLY

ASME Quality System Certificate Number N 1707

Expires APRIL 15, 1980
Low Budget 1-16-80

HEAT NO.	YIELD	TENSILE	ELONG. % IN INCHES	% RED. IN AREA
----------	-------	---------	--------------------	----------------

MURDOCK INC. 3-3008-4401
LOT # A 45497 1-18-80
MECHANICAL CERTS ATTACHED.

HARDENABILITY - ROCKWELL "C"

1	4	8	10	16	20	32
---	---	---	----	----	----	----

HEAT TREAT CERTS ATTACHED

A.I. REVIEW 1/22/80

COPY

COPY

FORM 80-FL-PAR 2-18

EARLE M. JORGENSEN CO.

STEEL

FORGE DIVISION

10650 S. ALAMEDA ST. • BOX 54633 TERMINAL ANNEX • PHONE 567-1122 (AREA 213)
LOS ANGELES, CALIFORNIA 90054

CERTIFIED TEST REPORT

Date 1-15-80

Cust. Order No. 31682-M

Our Invoice No. 4283-FL

Material SA 350 LF-2

Specification ASME SECT 111, DIV 1
SUBSECTION NE CL MC &
AND SUBSECTION NA, PARA NA 3767-
4B/NA 3767-5 1974 EDITION WITH

ITEM: 8 PCS 6" RD X 4-1/2

MECHANICAL PROPERTIES SINCE 75 ADDENDA

HEAT NO	DIRECTION OF TEST	YIELD PSI	ULTIMATE PSI	ELONG %	RED OF AREA %	FT LBS	IMPACTS	SL. EXP
102-215812	LONG	49400	70600	22	73.6	72 70 58		
REQUIREMENTS		36000	70/95000	22	30	15 AVG.		

Remarks: CHARPY V NOTCH @ MINUS 20 DEG'S F.

MURDOCK INC.

LIT # 144-5447


ND # WOL 3-3008 OH-07

DATE 1-18-80

SUBSCRIBED AND SWEARN TO BEFORE ME

THIS 15 DAY OF JANUARY 1980
Florence Reese - NOTARY PUBLIC
STATE OF CALIFORNIA LOS ANGELES COUNTY

COMMISSION EXPIRES 1-15-81



WITNESSED BY

We certify that the material covered by this report has been inspected and tested in accordance with the applicable requirements described herein and test results are on file subject to examination.

EARLE M. JORGENSEN CO.

BY Pat Brattier

COPY

EARLE M. JORGENSEN CO.

FORGE DIVISION

CERTIFICATION OF HEAT TREATMENT

CUSTOMER MURDOCK INC.
ADDRESS COMPTON, CALIF.

MURDOCK INC.

LUT # A 45497

DATE 12 20 74

JOB # 1WOL 3-3008-06-07

L-18-80 ²⁰⁰/₁₄

73-1-2 E.L.A. 108113


THIS IS TO CERTIFY THAT YOUR MATERIAL SHOWN BELOW WAS PROCESSED AS FOLLOWS:

PURCHASE ORDER NO.	PUR FD NO.	MATERIAL GRADE	DESCRIPTION
ART NUMBER		QUANTITY	HEAT NO.
31682 M	4283 FL	LF-2	6" Ø X 4½"
		8 + TEST	102 - 215812

TREATMENT	TEMPERATURE	TIME AT TEMPERATURE	COOLING METHOD	RESULTS
NORMALIZE	1650°F	8 HOURS	AIR	26-317-79
REVERSE	1550°F	8 HOURS	WATER	26-319-79
STRESS RELIEF OR TEMPER	1300°F	8 HOURS	AIR	26-321-79

REMARKS

MAR 19 1981



SUBSCRIBED AND SWEARN TO BEFORE ME

15 DAY OF JANUARY 80
By Earle M. Jorgensen, Notary Public

STATE OF CALIFORNIA, LOS ANGELES COUNTY

MY COMMISSION EXPIRES

Form 52-7

A.I. REVIEW 1/19/80

EARLE M. JORGENSEN CO.

By Earle M. Jorgensen

HJ

Penetration Sleeves



United States Steel Corporation

20" S/80 M6

National

WORKS

STANDARD SWORN TEST REPORT
TUBULAR PRODUCTS

MATERIAL

Seamless Pressure Pipe

TREATMENT

Normalized 1600°F for 128 minutes (Aircooled)

GRADE

6 ASME SA333

DATE

6 ASTM A333

CUSTOMER'S ORDER NO.

77223-00

U.S. SHEET ORDER NO.

KC 18185

INVOICE NO.

356-00777 - 356-00779

Longitudinal tensile tests

C U S T O M E R	NAME	
	ADDRESS	TELEPHONE
	Capitol Pipe and Steel Products, Inc.	

C O D E N O .	CONE OR L.D. NO.	SIZE O.D.	WALL THICKNESS	HEAT NUMBER	HYDRO- TEST PRESSURE MIN. P.S.I.	MECHANICAL PROPERTIES			CHEMICAL ANALYSIS (%)					
						YIELD STRENGTH P.S.I.	TENSILE STRENGTH P.S.I.	ELONG. % 1½"	C	Mn	P	S	Si	Mo
01	5032	20"	1.031	A20385	2200	45560	69820	52.5	.19	1.07	.017	.011	.18	check
				A20385	2200	46700	70630	50.0	.19	1.10	.018	.009	.18	check

Penetration
E-23
E-24

Flattening Tests Satisfactory

Full size longitudinal Charpy V-Notch impacts at minus - 50°F

Ft. Lbs.% Shear Lat. Exp.

A20385	34	36	.034	Pittsburgh Des-Moines
	50	39	.047	P.O.# 15579-229
	42	30	.040	S.O.# DN-5489-A

Ch# P-33475
Item# 6

THIS REPORT HAS BEEN CHECKED
AND FOUND TO COMPLY WITH AP-
PLICABLE SPECIFICATION.
Date 7-13-76 By A. Roberts

STATE OF _____
COUNTY OF _____Searched and sworn before me this
17th DAY OF March 1976

NOTARILY SWORN

BEING DULY SWORN ACCORDING TO
LAW, I DEPOSE AND SAY, THAT THE FIGURES SET FORTH ABOVE ARE
TRUE AND CORRECT IN ALL RESPECTS AND ARE
HERE AFFIRMED AND FILED IN THE RECORDS OF THE COMPANY.

MY CERTIFICATE IS EXPIRED

THIS IS A STANDARD FORM, NO. 5400, PRINTED IN U.S.A.

6 8 0 5 6 5 0 0 0 1

FC 8-20-76

LUKENS STEEL COMPANY
COATESVILLE, PA. 19320
TEST CERTIFICATE

MILL ORDER NO.	CUSTOMER P.O.	
70758 1	11-15679-616	61176 JW

DATE: 6/15/76 ID - A2774 THRU ID - A2777
CONSIGNEE: PGH-DES MOINES STEEL CO.
NEVILLE ISLAND PENNSYLVANIA 15225
6568-03-06

Meet Main steam line gage.

M1 to M4.

MAXX88XX8RXXX8XMXMXXX PDG MS 7.29.2 REV. 0 SA-516 GR. 60 ASME CODE SECTION II & III SUB NE

1971 EDITION THRU WINTER 1973 ADDENDA AND PROPOSED SECT III DIV. 2 DTD 4/73 N-1160 8/4/78

END TEST O.K. HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	GRAIN SIZE
A5280	.13	.93	.006	.020		.19								7-8
THIS REPORT HAS BEEN CHECKED AND FOUND TO COMPLY WITH APPLICABLE SPECIFICATIONS														
15679	Signed <u>J. J. Bushnell</u> Date <u>6-28-76</u>													
15280														

PHYSICAL PROPERTIES

MELT NO.	SLAB. NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2	% R.A.	BHN	IMPACTS LU OF	FRACTURE APPEARANCE	DESCRIPTION				
A5280	2	463	632	35		LATERAL EXPANSION IN INCHES	138 .097	140 .098	140 .098	99-99-99	1-	2-1/2 X 112 X 390	I.D. A2775 Item ①
A5280	4	470	640	34		LATERAL EXPANSION IN INCHES	100 .094	98 .093	96 .092	90-90-90	1-	2-1/2 X 107 X 390	A2777 Item ②
A5280	3	475	635	30		LATERAL EXPANSION IN INCHES	186 .099	200 .099	220 .099	99-99-99	1-	"	A2776 Item ③
A5280	1	480	640	33		LATERAL EXPANSION IN INCHES	168 .094	170 .096	164 .097	99-99-99	1-	2-1/2 X 112 X 390	A2774 Item ④

Plates and tests norm. 1625°F./1675°F., held 1/2 hr. per inch min., and air cooled.

Tests stress relieved by heating within a rate of 160°F. per hr. to 1100°F./1150°F., held 1/2 hr. and furnace cooled within a rate of 160°F. per hr. to 600°F.

We hereby certify the above information is correct.

TD-A2774 THRU TD-A2777



PITTSBURGH TESTING LABORATORY

ESTABLISHED 1881

850 POPLAR STREET, PITTSBURGH, PA. 15220

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS
ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION
FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING
OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

FOR INFORMATION ONLY
A-24
PLEASE REPLY TO:
P. O. BOX 1646
PITTSBURGH, PA. 15230

AREA CODE 412 TELEPHONE 922-4000

LABORATORY NO. 767420

ORDER NO. PG-15672

DATE: 8/10/76

CLIENT'S NO. 11-00000-47206 E-8

REPORT

Report of: Charpy Impact Test
"V" Notch, Plus 20°F

Report to: Pittsburgh Des-Moines Steel Corporation
Neville Island
Pittsburgh, Pennsylvania 15225

Code #8 <u>Specimen Identification</u>	<u>Size of Specimen</u>	<u>Shear %</u>	<u>Cleavage %</u>	<u>Lateral Expansion Inches</u>	<u>Impact Foot Pounds</u>
Pc. No. 137-12 A2776	10.125x10.21	5	95	.047	51
Pc. No. 137-12 A2776	10.125x10.21	10	90	.050	61
c. No. 137-12 A2776	10.125x10.21	5	95	.044	46

Specimens were removed .025" to .030" below outer surface of the plate.

Material: ASME SA516 Gr. 60

Thickness: 2½"

PWHT - 9 Hrs. Hold at 1100°F

Pc. No. - 137-12=8

I. D. - A2776=8

Contract: 15679

SAMPLES SUBMITTED BY THE CLIENT FOR MACHINING AND TESTING.

PITTSBURGH TESTING LABORATORY

Earl Gallagher
Earl Gallagher, Manager
Physical Testing Department

cc: 3-client
mls

APPENDIX D

D.L. Fisher-Pres. Eng.



PITTSBURGH TESTING LABORATORY

ESTABLISHED 1881

850 POPLAR STREET, PITTSBURGH, PA. 15220

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS
ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION
FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING
OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

Form 407 REV. PG

PLEASE REPLY TO:
P. O. BOX 1646
PITTSBURGH, PA. 15223

CLIENT'S No. 15679-226A

AREA CODE 412 TELEPHONE 922-4000

LABORATORY No. 764677

ORDER No. PG-15672

REPORT

DATE: 6-2-76

Report of : Tensile, Impact and Flattening
Test of SA106 Grade B Pipe

Report to : Pittsburgh Des-Moines Steel Company
Neville Island
Pittsburgh, Pennsylvania
Attn: J. Billisits

TENSILE TEST

Specimen Identification	Ht. N12979
Diameter In Inches	.504
Original Area Sq. In.	.1995
Yield Strength Pounds	6,910
Yield Strength PSI	34,600
Maximum Load Pounds	13,700
Tensile Strength PSI	68,700
Elongation in 2 Inches	.68
Elongation Per Cent	34.0
Reduced Diameter	.305
Reduced Area Sq. In.	.0731
Reduction of Area Per Cent	63.4
Location of Fracture	M/3
YIELD STRENGTH DETERMINED AT 0.2% OFFSET.'	

COPY

CHARPY IMPACT TEST "V" Notch, 0° F

SPECIMEN IDENT.	SIZE OF SPECIMEN	SHEAR %	CLEAVAGE %	LAT. EXP. INCHES	IMPACT FT. LBS.
N12979	10MMx10MM	10	90	9	8
N12979	10MMx10MM	10	90	11	10
N12979	10MMx10MM	10	90	13	11

THIS REPORT HAS BEEN CHECKED AND
FOUND TO COMPLY WITH APPLICABLE
SPECIFICATION.

PAGE 1 of 3

Date 1-17-77 BY RK

5 9 * 0 * 8 5 0 0 0 1

PITTSBURGH TESTING LABORATORY

ESTABLISHED 1881
850 POPLAR STREET, PITTSBURGH, PA. 15220AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS
ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS, AND AUTHORIZATION
FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING
OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.CLIENT'S NO. 15679-226APLEASE REPLY TO:
P. O. BOX 1646
PITTSBURGH, PA. 15222

LABORATORY No. 764677

AREA CODE 412 TELEPHONE 922-4000

ORDER No. PG-15672

REPORT

DATE: 6-2-76

FLATTENING TEST

A portion of the sample was flattened and revealed no rejectable defects.

Material : SA106 Grade B-24" OD Schedule 60

Heat Treatment: Normalized by Pittsburgh Metal Processing Co. Inc.

Penetration No: M-21

Heat No. N12979

Contract 15679

Lab. No. 764677A

RETESTTENSILE TEST OF STEEL

Specimen Identification	As Received	Nominalized
Diameter In Inches	.508	.508
Original Area Sq. In.	.2027	.2027
Yield Strength Pounds	7,890	9,500
Maximum Load Pounds	14,200	14,450
Yield Strength PSI	38,950	46,850
Tensile Strength PSI	70,050	71,300
Elongation in Inches	.66	.69
Elongation Per Cent	33.0	34.5
Reduced Dia.	.310	.304
Reduced Area	.0755	.0726
Reduction of Area Per Cent	62.8	64.1
Location of Fracture	M/3	M/3

YIELD STRENGTH DETERMINED AT 0.2% OFFSET.

COPY

THIS REPORT HAS BEEN CHECKED AND
FOUND TO COMPLY WITH APPLICABLE PAGE 2 OF 3
SPECIFICATION.

Date 1-17-77 Rev. BL

9 9 8 0 5 8 5 0 0 0 1

Flued Heads



NATIONAL FORGE COMPANY
QUALITY CONTROL DEPARTMENT

MATERIAL CERTIFICATION REPORT NO. 0 3 4 4 4

NFC SHOP NO. 60-5908 SERIAL NO. 01-001,002

CUSTOMER GULF & WESTERN

CUSTOMER ORDER NO.

20367-P

HEAT NO	CHEMICAL ANALYSIS											
	C	Mn	P	S	Ni	C _r	Mo	V	Al	Cu	Co	T _i
4-7988	.20	1.21	.014	.008	.22	.22	.06	.04	.07	.006		
CHECK	.21	1.23	.014	.008	.21							

LEGEND	SPECIMEN IDEN	NC	MECHANICAL PROPERTIES			IMPACT DATA		
			TENSILE psi	YIELD psi @ .2	% ELONG	% R/A	GRAIN SIZE	*F
L = LONG	01-001,002	L	76,100	50,700	31.0	70.1	9-11	149-156-156
R = RAD								
X = TRAN								
Y = TANG								

OPERATION	TO *F	HRS HOLD	SPCMN IDNT. NO	IMPACT DATA	
AUSTENITIZED	1550	14	1	+50	61.0 20
QUENCHED IN WATER				+50	64.0 20
AUSTENITIZED	1460	14		+50	23.0 18
QUENCHED IN WATER				+40	179.0 0.70
TEMPERED	1180	7		+40	157.0 0.021
NORMALIZED	1680	14		+40	217.0 0.077

ULTRASONIC INSPECTED PER APPROVED PROCEDURE AND FOUND TO BE SATISFACTORY

WITH NO REPORTABLE INDICATIONS

MAGNETIC PARTICLE INSPECTED PER

REVIEW

DATE 11/17/77

INITIAL

Plated

6-2

MAP 9-10-3

IFLS 16

ENSILE SPECIMEN SIZE = 505"

ROUND FLUTED INGOT MOLD

PIECE ONE ACTUAL TEST DATA AVAILABLE FOR REVIEW


RIP#3117

COPY

DO NOT SCALE DRAWING

ELEVATIONS	
#	DESCRIPTION
A	1. DIA. 4"
B	2. DIA. 4"
C	3. DIA. 4"
D	4. DIA. 4"
E	5. DIA. 4"
F	6. DIA. 4"
G	7. DIA. 4"

- Notes:
1. Design Per ASME Sect III Cl. 2: 1605 Pmax
 2. Gage F.
 3. FABR. Per WPS Blg
 4. Hydro @ 1765 PSIG
 5. Mach Char. Sg. For Holes
 6. All Surfaces ZERO R's



AS-BUILT DRAWING

MSP. 87 Kline Mar. 3-20-87
After repair

6 VQ4-12
167030
600-CONT'D

600-CONT'D
600-CONT'D

BECHTEL
605

ITEM		ITEM		ITEM	
Z 4	Core Navel Re.	S 4			
1	Friction Lin. 11-4-4	2			
ITEM	ITEM	ITEM	ITEM	ITEM	ITEM

ITEM	ITEM	ITEM	ITEM	ITEM
1	2	3	4	5

RIP#3117

GW**Taylor Forge Engineered Systems**CUSTOMER Bachtel Energy CorporationP.O. Box #
Phone # 43-4301
913/234-4331South Texas Project Electric Gen. StationCUSTOMER ORDER NO. 35-1197-4036 OUR ORDER NO. 802185TFES Item No. 25A, Penetration No. M-1
CERTIFIED MATERIAL TEST REPORTThe following products were produced in the U.S.A.
Material manufactured/fabricated and tested in accordance
with purchase order requirements and specifications)Certificate N-1936, Exp. 11/25/86
CHEMICAL ANALYSIS**PHYSICAL PROPERTIES**

HEAT NUMBER	YIELD POINT OR YIELD STRENGTH AT _____% OFFSET PSI.	TENSILE STRENGTH PSI	ELONG. IN ____% _____	RED OF AREA %	DESCRIPTION							
					C	MN	P	S	Si	Mo	CR	Ni
KLWV					See attached CMTR from National Forge Company							

RIP # 4060**BECHTEL
655****ENCL**REMARKS: Pen. Tag No. (Unit 1) 2C091NPN001A
P.T. per E.S. 3.12.3 Rev. 0 - Acceptable**SUBSCRIBED AND SWEORN TO BEFORE ME**

GW011

THIS 19 DAY OF NOTARY PUBLIC
[Signature]

The undersigned certifies that the contents of this report are correct and accurate
and that all above test results and operations performed are in compliance with
requirements of the applicable sections of the above stated specifications and purchase
order.

For Quality Assurance Manager.
[Signature]

COPY



NATIONAL FORGE COMPANY

* CORRECTED 9-14-79

MATERIAL NOTARIZATION DOCUMENTATION PACKAGE

Customer: GULF & WESTERN ENERGY COMPANY

Forge Div. Irvine Erie

Purchase Order No.: **12-0622**

Foundry Div.

Drawing No.: 802185-25-A1, Rev. 0

NFC Order No.: 61-A-5882-01

Nomenclature: Tubular Product

NFC Serial No.: 001

Specification: ASME SA-350 LF2, 1974 Edition with Addenda thru Summer 1976, Subsection NC for Class 2 Components.
Charpy V-notch per NC-2330 at +40°F.

NATIONAL FORGE COMPANY DOCUMENTS APPROVED AND USED ON THIS CONTRACT
PAOLA

Ultrasonic Procedure:

Magnetic Particle Procedure:

Heat Treat Procedure:


Impact Test Procedure:

Forging Test Drawing:

Other:

802185

Sep 1



DOCUMENTATION PACKAGE TABLE OF CONTENTS


- 3 Chemistry/Mechanical/NDT Data
- Transition Curve
- Heat Treatment Charts/Table IV Form
- Dimensional Data
- Forging Material Log
- Heat Stability Data

- Photomicrographs
- Test Material (Sep. Cover)
- U-1A Form
- U-2 Form
- Other

- 3 Heat Treatment

COMMONWEALTH OF PENNSYLVANIA,
COUNTY OF *ss.*

NUCLEAR



R. L. Hofer, an authorized representative of National Forge Company, being
duly Sworn, deposed and says that the inspection and test results set forth in the attached reports and documentations
are ~~Entirely dependent on results of inspection and tests made by the company and recorded in its records.~~
Erie, Erie County, Pennsylvania

Notary Public Seal
My Commission Expires July 25, 1981

LENA FILIPPO

Subscribed and sworn to before me
this 20 day of August 1979

Lena Filippo
NOTARY PUBLIC

R. L. Hofer

BECHTEL
605

RIP # 4060



NFC SHOP NO. 61A-5882-01 SERIAL NO. 001
CUSTOMER GULF & WESTERN ENERGY

MATERIAL CERTIFICATION REPORT NO. 0-05957

CUSTOMER ORDER NO. 12-0622

Page of

CHEMICAL ANALYSIS

HEAT NO.	C	Mn	P	S	Ni	Cr	Mn	V	Al	Cu	Co	Ti	
21-4675	.30	.15	.010	.014	.27	.25	.12	.06	.04				
R 12:00	.30	.33	.010	.014	.28	.28	.14	.07	.04				

MECHANICAL PROPERTIES

SPECIMEN IDENT. NO.	TENSILE PSI	YIELD PSI @ .2% ELONG	% R/A	GRAIN SIZE	HOLD	IMPACT DATA
L	73,500	47,500	34.5	68.3	15	FT. LBS
R = RAD					L	*F
X = TRAN					L	80.0
V = TANG					L	062
					L	.054
					L	.043
					L	.052
					L	.063
					L	.055
					L	.067
					L	.065
					L	.057

MANUFACTURING NOTES AND HEAT TREATMENT DATA

OPERATION	TO	% HOLD	SPCMN. IDNT. NO.	IMPACT DATA
Air cool	1700° F	15	L	FT. LBS
Water quench	1550° F	15	L	*F
Air cool	1460° F	15	L	80.0
Water quench	1190° F	15	L	64.0
Air cool	1210° F	15	L	44.0
Air cool	1220° F	15	L	69.0
Air cool	1220° F	10	L	81.0
AIR COOLED			L	75.0
AIR COOLED			L	91.0
AIR COOLED			L	81.0
AIR COOLED			L	65.0

No reportable indications
ULTRASONIC INSPECTED PER UT-61-A-5882

MAGNETIC PARTICLE INSPECTED PER

RECHTEL
655

NUCLEAR

Sep 24 2

A. N. I. REVIEW

By John Date 10-1-77

INITIAL FINAL

TENSILE SPECIMEN SIZE = .505"

ROUND FLUTED INGOT MOLD


COPIES OF ACTUAL TEST DATA AVAILABLE FOR REVIEW

RIP # 4060

COPY

REVISONS	
A	1/30/1984
B	1/30/1984
C	1/30/1984
D	1/30/1984

DO NOT SCALE DRAWING


NOTES:

1. Drawing per ASME Sec. I, Cl. 2 USES PSD
2. 600°F.
3. FAB. FOR MPS 100
4. Mach. Encls. Sq. Part No. 600

AS-SENT DRAWINGS

19731 Khos - 1977/27/84

OK



DETAIL A


47.712

2.210

OK



DETAIL B



DETAIL C

BECHEL
655

25A

NUCLEAR60702
6V04-12
167029

ITEM #	DESCRIPTION	QUANTITY	W.T.
1	14 FORCE CYL 1A 100	1	4
2	4 CODE NAME 12	1	4

ITEM #	DESCRIPTION	QUANTITY	W.T.
1	11 HIGH ENERGY PARTICLE ACCELERATOR 14.4A	1	1

ITEM #	DESCRIPTION	QUANTITY	W.T.
<small>ITEM #11: HIGH ENERGY PARTICLE ACCELERATOR ITEM #14: FORCE CYL 1A 100 ITEM #1: 14 CODE NAME 12 ITEM #2: 4 FORCE CYL 1A 100 ITEM #3: 11 HIGH ENERGY PARTICLE ACCELERATOR ITEM #4: 4 CODE NAME 12 ITEM #5: 11 HIGH ENERGY PARTICLE ACCELERATOR ITEM #6: 4 CODE NAME 12 ITEM #7: 11 HIGH ENERGY PARTICLE ACCELERATOR ITEM #8: 4 CODE NAME 12 ITEM #9: 11 HIGH ENERGY PARTICLE ACCELERATOR ITEM #10: 4 CODE NAME 12 ITEM #11: 11 HIGH ENERGY PARTICLE ACCELERATOR ITEM #12: 4 CODE NAME 12 ITEM #13: 11 HIGH ENERGY PARTICLE ACCELERATOR ITEM #14: 4 CODE NAME 12 ITEM #15: 11 HIGH ENERGY PARTICLE ACCELERATOR ITEM #16: 4 CODE NAME 12</small>			
NAME	UNIT	NAME	UNIT
1	1	1	1
2	1	2	1
3	1	3	1
4	1	4	1
5	1	5	1
6	1	6	1
7	1	7	1
8	1	8	1
9	1	9	1
10	1	10	1
11	1	11	1
12	1	12	1
13	1	13	1
14	1	14	1
15	1	15	1
16	1	16	1

RIP # 406

Cap Type Penetrations

Massey

COPYCUSTOMER South Texas Project

Taylor Forge Engineered Systems

P.O. Box 8
Paola, KS 66071
913/294-5331CUSTOMER ORDER NO. 35-1197-4036PACKING LIST NO. 02322

The finished product shown was produced in the U.S.A.

HEAT NUMBER	PHYSICAL PROPERTIES				CHEMICAL ANALYSIS								DESCRIPTION
	YIELD POINT OR YIELD STRENGTH AT % OFFSET, PSI	TENSILE STRENGTH PSI	ELONG. IN %	RED OF AREA %	C	MN	P	S	SI	Mo	CR	NI	
	ITEM #	20A			STP#	2C091MPN033A							
* KLDX	43,300	68,200	37.5		.24	.67	.005	.017	.16		SA-106-B		16" Standard Pipe x 6'-4-1/2" long
					*UT Pipe per NC-2552 - Acceptable								
* KSL	49,400	76,400	28		.22	1.04	.201	.020	.224		SA-420-WPL6		24" OD x 1-7/16" minimum 2:1 S.E.
TFES Testing	48,004	75,291	32	58.1	Charpy V+40° F Ft. Lbs.								HD 2" S.F.
					MLE:								
					% Shear								

REMARKS: Fabricated per MPS B3 R/0 3-7-77 - Acceptable

Hydrotested per MPS C7 and ES 3.16.1 R/0 12-8-76 at 225 PSIG - Acceptable

PT Welded joint per ES 3.12.2 R/3 9-13-76 & Amend. 2 R/0 1-20-77 - Acceptable

* SEE VENDOR CERTIFICATION

GW011

SUBSCRIBED AND SWORN TO BEFORE ME

THIS DAY OF 19

NOTARY PUBLIC

SPECIFICATION NO. ASME Section III Class 2
Summer 76HEAT TREATMENT *KSL Normalize temp.
1700 F ± 25°F. with hold time at temp.
(1) hr/inchThe undersigned certifies that the contents of this report are correct and accurate
and that all above test results and operations performed are in compliance with
requirements of the applicable sections of the above stated specifications and purchase
order.

For Quality Assurance Manager.

COPY

BETHLEHEM STEEL CORPORATION
METALLURGICAL DEPARTMENT
REPORT OF TESTS AND ANALYSES

BURNS HARBOR PLANT

attn: T.L. Miller

DATE SHIPPED

CAR OR VEHICLE NO.

803-06969

4-26-78

PAGE 2

FLINT INDUSTRIES INC
FLINT STEEL CO DIV
SCX 1289
TULSA CK 74101

FLINT INDUSTRIES INC
FLINT STEEL CO DIV
TULSA CK

ITEM NUMBER	PAT NO.	HEAT NUMBER	SIZE AND QUANTITY					YIELD POINT PSI	TENSILE STRENGTH PSI	ELONG. IN %	RED. %
			NO. PCS.	THICKNESS INCHES	WIDTH OR DIA. INCHES	LENGTH INCHES	WEIGHT POUNDS				
PLATES -			ASTM A516-76 GR 70 PVC	G ASME SAS16							
			GR 70 PVC WINTER 74 ACC	EE GAS CUT 4							
			SIDES NORMALIZED FLATTENED TO STD	TCL							
COS E-81384W	GH 223-42220										
PLATES HEAT TREATED WITH TEST SPECIMENS ATTACHED AND YIELD STRENGTH 8 .5% E.U.L.											
C 32961	802C43220	2	1 3/4	96	240	22870	45400	76400	2	26	
			N 1650	DEG F -	55 MIN						
			ASL								
PLATES -			ASTM A516-76 GR 70 PVC	G ASME SAS16							
			GR 70 PVC WINTER 74 ACC	EE							
COS E-81398 W	GH 223-4974A										
YIELD STRENGTH 8 .5% E.U.L.											
C120042	802C47700	1	3/4	120	300	7657	47200	72600	8	23	
C123075	802C42230	1	3/4	120	300	7657	54400	82700	8	25	

Q=QUENCH TEMPERATURE

T=TEMPER TEMPERATURE

N=NORMALIZE TEMPERATURE

ITEM NUMBER	PAT NO.	HEAT NUMBER	NAME	SND	THICKNESS INCHES	TYPE	SIZE	OHL	TEST TEMP F	CHARPY IMPACT			SHEAR (%)	LAT EXP	MIL	
										ENERGY FT. LBS.	1	2	3			

note: Add to
qualify for
802 185
Nuclear

HEAT NUMBER	CHEMICAL ANALYSIS												MICRO GRAIN SIZE		
	C	Mn	P	S	N	Cr	Ni	O	Mo	V	N	S	O	H	
802C43820	.22	1.04	.021	.022	.224										5-
802C47700	.24	1.09	.012	.018	.226										5-
802C48230	.24	1.13	.014	.015	.294										5-

SUBSCRIBED AND SWEORN TO BEFORE ME
THIS 27 DAY OF April 1978

R.L. Miller
NOTARY PUBLIC
PORTER COUNTY INDIANA
MY COMMISSION EXPIRES JULY 26, 1980

BECHTE
008

COP

Bill of Draft



88
BECOME

1/22/19


28
1/42

NOTES:

1. DESIGN PER AVE Sect. III CL. 2
2. FABR. PER N-25-N-3
3. HYDRO @ 225
4. DESIGN PRESS. 150 PSIG 250°F
5. MACH. ENDS SQ. FOR HYDRO



26.50
26.90



UNIT #1 P.O. 35-1197-4036

UNIT #2 P.O. 35-1197-1036

Detail "A"

MAN-CONTROLLED

10

MANUAL

MAN

MAN



UNCONSTROLLED copy

ITEM	DESCRIPTION	ITEM QTY	SCALE	INCHES	PISTON DIAMETER ASSY	INCHES	ITEM
3	CAKE NAME PL.	4					
2	202D X 1/16 INCH 2 1/2 E.H.D.	4					
1	4. SURFACE G. 4 1/2 LG.	1					

ITEM	DESCRIPTION	ITEM QTY	SCALE	INCHES	PISTON DIAMETER ASSY	INCHES	ITEM
1	35 CM-34	20					B

FORM N-2 MANUFACTURERS DATA REPORT FOR NUCLEAR POWER PLANTS AND APPURTENANCES

COPY

As required by the Provisions of the ASME Code Rules

Energy Products Group; Plant 12

1. (a) Manufactured by Gulf+Western Manufacturing Co., 1st & Iron Streets, Paola, Kansas
(Name and address of Manufacturer of part)(b) Manufactured for Brown & Root, Inc. Houston, Texas
(Name and address of Manufacturer of completed nuclear component)2. Identification-Manufacturer's Serial No. of Part 802185 - 20A Nat'l Bd. No. Gulf+Western(a) Constructed According to Drawing No. 802185 - 20 Drawing Prepared by Energy Products Group
Rev. B(b) Description of Part Inspected 28" OD x 6'-4-1/2" lg. Penetration
Summer* (c) Applicable ASME Code: Section III, Edition 74, Addenda date 76, Case No. N-242-1 Class 2* 3. Remarks: Moderate Energy Penetration Ass'y #M-33 Unit #1(Brief description of service for which component was designed)
We certify that the corrections made in this report are correct and that
the component conforms to the correction described herein.Signed S. Ned Taylor Forge Engineered Systems by S. Ned Taylor date 8-9-83
Our ASME Certificate of Authorization N-1937 expires 11-25-80* (Applies) Signed Ricardo B. Silva Date 8-9-83
Commission NB U.S. 170 HSBI & I Co.

Nat'l Board, State Province & No.

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.

(The applicable Design Specification and Stress Report are not the responsibility of the part Manufacturer. An appurtenance Manufacturer is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 1-24 1979 Signed Energy Products Group By Heller
(Manufacturer)Certificate of Authorization Expires 11-25-80 Certificate of Authorization No. 1937

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at _____

Stress analysis report on file at _____

Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____

Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Arkansas (Factory Mutual System) and employed by Philadelphia Mfg. Mutual Ins. Co. of Philadelphia, Pa. have inspected the part of a pressure vessel described in thisManufacturer's Partial Data Report on 1124179 1979, and state that to the best of my knowledge and belief, the Manufacturer has constructed this part in accordance with the ASME Code Section III.

* By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Manufacturer's Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11/24/79 1979R. L. Costa
Inspector's SignatureCommissions Arkansas 627
National Board, State, Province and No.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information is item 1-2 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 3, "Remarks".

COPY

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Pipe: Material SA-106-B T.S. 60000 Nominal .375 Corrosion 0 in. Allowance 0 in. Dia. 2 in. Length 4 ft. 6 ft. 4-1/2 in. (Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %

Girth Single H.T.¹ _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material SA-420-WPL6 T.S. 60000 (b) Material _____ T.S. _____

Location SA-333-CR6 Crown SA-316-70 Knuckle _____ Elliptical _____ Conical _____ Hemispherical _____ Flat _____ Side to Press. _____
(Top, bottom, ends) Thickness .00 Radius _____ Ratio _____ Apex Angle _____ Radius _____ Diameter _____ (Conv. or Conc.)

(a) _____ (b) _____

If removable, bolts used _____ Other fastening _____ (Material, Spec. No., T.S., Size, Number) (Describe or attach sketch)

7. Jacket Closure: _____ (Describe as ages and weld, bar, etc. If bar give dimensions, if bolted, describe or sketch)

Drop Weight _____

Charpy Impact _____ ft-lb

at temp. of _____ °F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary. Material _____ Dia. _____ Thickness _____ in. Attachment _____ (Welded, Bolted)
(Kind & Spec. No.) (Subject to pressure)

Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gauge. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal _____ Corrosion _____ in. Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in. (Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %

Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location _____ Thickness _____ Crown _____ Knuckle _____ Elliptical _____ Conical _____ Hemispherical _____ Flat _____ Side to Press. _____
(Top, bottom, ends) Radius _____ Ratio _____ Apex Angle _____ Radius _____ Diameter _____ (Conv. or Conc.)

(a) Top, bottom, ends _____ (b) Channel _____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)

Drop Weight _____

Charpy Impact _____ ft-lb

14. Design pressure² _____ psi at _____ °F at temp. of _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

Inspection Manholes, No. _____ Size _____ Location _____

Openings: Handholes, No. _____ Size _____ Location _____

Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____ (Where & How)
(Yes or No) (Number) (Number) (Describe)

¹ If Postweld Heat-Treated.
² List other internal or external pressure with coincident temperature where applicable.

BECHTEL
698

Multiple Penetration Header Plates

CORRECTED REPORT 2-14-83

CUSTOMER South Texas Project



Taylor Forge Engineered Systems

P.O. Box 8

Post Office KS 66071

913/294-5331

ASME Section III

Class 2 Summer 76

SPECIFICATION NO.

CUSTOMER ORDER NO. 35-1197-4036

OUR ORDER NO. 802185-17A

YOUR PENETRATION NO. M-29, Unit #1

CERTIFIED MATERIAL TEST REPORT

Material manufactured/fabricated and tested in accordance
with purchase order requirements and specification(s)

The finished product shown was produced in the U.S.A.

HEAT NUMBER	PHYSICAL PROPERTIES				CHEMICAL ANALYSIS								DESCRIPTION	
	YIELD POINT OR YIELD STRENGTH AT % OFFSET, PSI	TENSILE STRENGTH PSI	ELONG. IN %	RED OF AREA %	C	MN	P	S	SI	Mo	CR	NI		
* KKEJ	50,300	92,000	2"	61	.045	1.80	.019	.004	SA-376-TP316	.66	2.69	17.0	13.0	1" S/160 Pipe x 5'-6" long
					*Corrosion tests found to be satisfactory per ASTM-A-262, Practice A, Para. 5.3.2 (Fig 2)									
* KLAU	52,200	77,100	8"	29	.23	1.03	.014	.017	SA-516-70	.233				1" Plate x 12.75" Ø
					*Charpy V +40° F Size (Full) Ft. Lbs. 52-53-48									
					MILS: 46-47-42 %Shear 67-72-63									
* KLAU	52,200	77,100	8"	29	.23	1.03	.014	.017	SA-516-70	.233				1" Plate x 11.845" Ø
					*Charpy V +40° F Size (full) Ft. Lbs. 52-53-48									
					MILS: 46-47-42 % shear 67-72-63									

REMARKS: Fabricated per MPS B2 R/O 3-7-77 - Acceptable

PT per ES 3.12.2 R/3 9-13-76 and Amend. 2 R/O 1-20-77 - Acceptable

Hydrotested per MPS C7 and ES 3.16.1 R/O 12-8-76 at 3750 PSIG - Acceptable

*UT pipe per NB-2552

*SEE VENDOR CERTIFICATION

GW011

SUBSCRIBED AND SWORN TO BEFORE ME

THIS DAY OF 19

The undersigned certifies that the contents of this report are correct and accurate
and that all above test results and operations performed are in compliance with
the requirements of the applicable sections of the above stated specifications and purchase
order.

For Quality Assurance Manager.

NUCLEAR

SHIPMENT NO

DATE SHIPPED

CAR OR VEHICLE NO

102-11194

4-29-78

SOLD TO
GULF & WESTERN MFG CO
 ENGINEERED SYSTEMS DIV
 P.O. BOX 66671
 PAOLA KS

SHIPPED TO
GULF & WESTERN MFG CO
 ENGINEERED SYSTEMS DIV
 THEIR SIDING
 PAOLA KS

NOTE	SERIAL NUMBER	PAT NO	HEAT NUMBER	SIZE AND QUANTITY					YIELD POINT PSI	TENSILE STRENGTH PSI	ELONG %
				NO PCS	THICKNESS INCHES	WIDTH OR DIA INCHES	LENGTH INCHES	WEIGHT POUNDS			
	PLATES		ASME SA516 GR 70 PVQ SUMMER 76 ADD CH-V NC2300 PLATE 25MILS AT +40F INFO T FTL ESHR A1 +40F & MILL TEST PCS NO KALAZED								
C 6894	6894	822C43840	C-11034 GH 323-3301 REP 2	1	1	65	113	2083	32200	77100	8 29

Released
Q.C.TFES
16

OCT 31 1981

KLAU

NUCLEAR

NOTE Q=QUENCH TEMPERATURE

T=TEMPER TEMPERATURE

N=NORMALIZE TEMPERATURE

N 1700 DEG F FOR 1 HR/IN

IN ACCORDANCE WITH Q.A. PROGRAM DTD 12-1-77 PER ASME SECT III NCA 3800

SERIAL NUMBER	PAT NO	HEAT NUMBER	HARD	BEND	CHARPY IMPACT												
					THICKNESS INCHES	TYPE	SIZE	DIA	TEST TEMP	ENERGY	T	I	S	SHEAR (IN)	LAT EXP	I	
1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	1	2	
C 6894	822C43840				1.000	V	FULL	T	+40	52	53	48	67	72	63	46	47

HEAT NUMBER	CHEMICAL ANALYSIS																
	C	Mn	P	S	N	Cu	Ni	Cr	Mo	V	B	M	S	Co	N	M	Si
822C43840	.23	1.03	.014	.017	.233												

RIP#A599

CORRECTIVE COPY 10-16-81

48587 (REV. A 12-77)

BURNS HARBOR PLANT

BETHLEHEM STEEL CORPORATION
METALLURGICAL DEPARTMENT
REPORT OF TESTS AND ANALYSES

DATE SHIPPED 4-20-78 CAR OR VEHICLE NO.

303-00194

4-20-78

PAGE 2

GULF & WESTERN MFG CO
ENGINEERED SYSTEMS DIV
BUX 8
PAOLA KS 66071

GULF & WESTERN MFG CO
ENGINEERED SYSTEMS DIV
THEIR STUDIO
PAOLA KS

SERIAL NUMBER	PAT NO	HEAT NUMBER	SIZE AND QUANTITY					TEST POINT PSI	YIELD STRENGTH PSI	ELONG IN	RED %
			NO PCS	THICKNESS INCHES	WEIGHT OR DIA INCHES	LENGTH INCHES	WEIGHT POUNDS				
PLATES		ASME SA516 GR 70 PVQ SUMMER 76 ADD C-H-V NC2300 PLATE 1/25 MILS AT +40F INFO T FTL ESHR AT +40F LL MILL TEST PCS NOT CALIBRATED									
C 3294	6894	822C43840	1	1	65	113	4033	52200	77100	8	29

Released
Q.C.

TEES
16

OCT 31 1981

KLAU
NUCLEAR

A = ANNEALING TEMPERATURE

T = TEMPERING TEMPERATURE

R = NORMALIZE TEMPERATURE

N 1700 DEG F FOR 1 HR/IN

IN ACCORDANCE WITH Q.A. PROGRAM DTD 12-1-77 PER ASME SECT III NCA 3800

SERIAL NUMBER	PAT NO	HEAT NUMBER	HARD	BEND	CHARPY IMPACT													
					THICKNESS INCHES	TYPE	SIZE	DIA	TEST TEMP	ENERGY	1	2	3	1	2	3	1	
C 3294	6894	822C43840			1.000	V	FULL	T	+40	52	53	48	67	72	63	45	47	42
CHEMICAL ANALYSIS																		
822C43840			C	-	P	S	N	Co	M	G	Mn	V	N	M	S	Cr	H	Si
			.23	1.03	.014	.017	.233											5.48

BETHTEL
655

I CERTIFY THAT THE ABOVE RESULTS ARE A TRUE AND CORRECT COPY
OF RECORDS PREPARED AND MAINTAINED BY BETHTEL IN ACCORDANCE
WITH THE REQUIREMENTS OF THE SPECIFICATION CITED ABOVE.

CHIEF METALLURGIST R. L. MILLER REC'D JV

FORM N-2 MANUFACTURERS DATA REPORT FOR NUCLEAR PART AND APPURTENANCE

As required by the Provisions of the ASME Code Rules

Energy Products Group; Plant 12

1. (a) Manufactured by Gulf Western Manufacturing Co., 1st & Iron Streets, Paola, Kansas
(Name and address of Manufacturer of part)(b) Manufactured for Brown & Root, Inc. Houston Texas

(Name and address of Manufacturer of completed nuclear component)

2. Identification-Manufacturer's Serial No. of Part 802185 - 17A Nat'l Bd. No. _____Fluid Systems Division
Energy Products Group(a) Constructed According to Drawing No. 802185 - 17 Drawing Prepared by _____(b) Description of Part Inspected Multiple Penetration Ass'y M-29 x 5'-6" lg. (REF.)
Summer(c) Applicable ASME Code: Section III, Edition 74, Addenda date 76, Case No. ----- Class 23. Remarks: Multiple Penetration Ass'y. M-29

(Brief description of service for which component was designed)

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.

(The applicable Design Specification and Stress Report are not the responsibility of the part Manufacturer. An appurtenance Manufacturer is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Date 10/11 1978 Signed Energy Products Group By S. Griggs
(Manufacturer) _____ S. GriggsCertificate of Authorization Expires 11-25-80 Certificate of Authorization No. 1937

CERTIFICATION OF DESIGN FOR APPURTEANCE (when applicable)

Design information on file at _____

Stress analysis report on file at _____

Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____

Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Arkansas (Factory Mutual System) and employed by Philadelphia Mfg. Mutual Ins. Co. of Philadelphia, Pa. have inspected the part of a pressure vessel described in theManufacturer's Partial Data Report on 10/14/78 1978, and state that to the best of my knowledge and belief, the Manufacturer has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Manufacturer's Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10/14/78 _____

D. McRae Inspector's Signature _____ Commissions _____

Arkansas 627

National Board, State, Province



27

RECHTEK
655

Supplemental sheets in form of notes, sketches or drawings may be used provided that each sheet is numbered 1/2, information in items 1 through 5 of this data report is repeated on each sheet, and a check sheet is numbered 1 and number of sheets is recorded in item 1 "Remarks".

NUCLE

Items 5-10 to be completed for each wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

Attachment Weld Yes H.T. No R.T. No Efficiency 100 %

Pipe Material SA-376-316 Nominal .250 Corrosion 0 in. Allowance 0 in. Dia. 1 in. Length 5 ft. 6 in.

xxxxx Min. of Range Specified

Plate Grade H.T. R.T. No. of Courses
6. ~~xxxxx~~ SA-516-70 T.S. 70000 (b) Material SA-516-70 T.S. 70000

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side-to-Press. (Conv. or Conc.)
(a) _____	_____	_____	_____	_____	_____	_____	_____	_____
(b) _____	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used _____ (Material, Spec. No., T.S., Size, Number) Other fastening _____ (Describe or attach sketch)

7. Jacket Closure: _____ (Describe as cage and end, bar, etc. If bar give dimensions, if bolted, describe or sketch)
Drop Weight _____ Charpy Impact _____ ft-lb at temp. of _____ °F

8. Design pressure² _____ psi at _____ °F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary, Material _____ Dia. _____ in. Thickness _____ in. Attachment _____ Welded, Bolted
(Kind & Spec. No.) (Subject to pressure)

Floating, Material _____ Dia. _____ in. Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches _____ gage. Number _____ Type _____ S.E. or U

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Solid Material _____ Nominal _____ Corrosion _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in. (inches)
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long H.T. _____ R.T. _____ Efficiency _____ %

Corr. _____ H.T. _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side-to-Press. (Conv. or Conc.)
(a) Top, bottom, ends	_____	_____	_____	_____	_____	_____	_____	_____
(b) Channel	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)

Drop Weight _____ Charpy Impact _____ ft-lb at temp. of _____ °F

14. Design pressure _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Port Number	Size	Type	Material	Thickness	Reinforcement Material	Side-to-Press. (Conv. or Conc.)
_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____

17. Inspection Manholes: Number _____ Size _____ Location _____

18. Drainage Manholes: Number _____ Size _____ Location _____

19. Other Portholes: Number _____ Size _____ Location _____

20. Other Outlets: Number _____ Size _____ Location _____



BECHTEL
655

Electrical Penetrations

S O T L Valley McLeod, Inc.
 151 East Fifth St.
 D Elmira, N. Y. 14902
 S Westinghouse Klec. Corp.
 H T Ind. & Govt. Tube Div.
 I O West Cir
 P Horseheads, N. Y. 14845

DETAILED ANALYSIS REPORT

Tube Turns Division

Chemetron Corporation

HOUSTON, TX

4/21/80 - lh **

TUBE TURNS
ORDER NO

II 4 91339

CUSTOMERS
ORDER NO

MD 60804

Replaced DAR dated 3/26/80

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS								HEAT OR LOT NO	SPECIFI- CATION OF MATERIAL FROM WHI- CH MADE																
	# HEAT TREAT- MENT	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	PERCENT ELONGA- TION IN 2 IN.	PERCENT REDUCTION IN AREA	C	MN	P	S	SI	NI	CR	MO	XMM CU																	
Item 001 4 Pieces		48,000	79,000	31.0	65.4	.26	.84	.007	.026	.22	.02	.04	.01	.02	6021151	A-350															
" PT. 30 R.F. Bore 18.156"	Charpy	"V" Notch @ 0°F.	45-32-52 Ft. Lbs./.042-.035-.046 Mills L.E./60-60-60% Shear																												
(.922" Wall) per Dwg. 42-40130-1 dated 6/30/78. 20"150# Weld Neck Flg. per SA350 LFL, with end protectors.	The material furnished on this order was produced in accordance with Tube Turns Quality System Program that meets the applicable requirements of NCA3800 of ASME Sect. III.																														
This program meets the applicable sections of our Quality Assurance Program approved under certificate of authorization N1807, expires 7/15/80																															
Forgings were normalized by heating to 1650°F, holding 5 hours and cooling in still air.																															
** Revised	7 March, 1984														<i>S. D. Vitale</i> S. D. Vitale, Quality Assurance																

* STANDARD ROUND TEST SPECIMEN

- ** 1 ANNEALED
- 2 NORMALIZED
- 3 NORMALIZED AND STRESS RELIEVED
- 4 STRESS RELIEVED
- 5 QUENCHED AND TEMPERED
- 6 SHOT PEENED
- 7 HEAT TREAT PER ORDER SPECIFICATION

SUBSCRIBED AND SWORN TO BE TRUE ME THIS

1980 JUN 21
J. R. Alton
COPY

J. R. Alton
J. R. Alton, Asst. Q. C. Mgr.

Main Steam Process Pipe and Header

APPENDIX V

COPY
P.3

FORM NPP-I DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES*
(As Required by the Provisions of the ASME Code Rules)

SOUTHWEST FABRICATING & WELDING CO., INC. 7525 SHERMAN, HOU. TX 77011 Order No. S.O. # 02657-MS
 L. Fabricated by _____
 (Name and Address of Fabricator)

2. Fabricated for HOUSTON LIGHTING & POWER CO., HOUSTON, TX Order No. P.O. # 35-1197-6014,
HOUSTON LIGHTING & POWER CO.,
 3. Owner SOUTH TEXAS NUCLEAR UNIT I 4. Location of Plant WADSWORTH, TX.

5. Piping System Identification Main Steam, Serial #39722
 (Brief description of intended use, main coolant etc.)
 (a) Drawing No. 02657-MS #608 Prepared by SOUTHWEST FAB. & WELDING CO., INC.
 (b) National Board No. N/A

6. The material, design, construction, and workmanship complies with ASME Code Section III, Class 2
 Edition 1974**, Addenda Date WINTER 1975 **, Case No. _____

Remarks: Manufacturers' Data Reports properly identified and signed by Commissioned Inspectors have been furnished for
 the following items of this report EXT. HDR. - TAYLOR FORGE - ITEM (A) S/N 803450-2A1,
(Name of Part - Item number, Manufacturer's name, and identifying stamp)
ITEM (B) S/N 803450-2B2 & ITEM (C) S/N 803450-2B3.

7. Shop Hydrostatic Test N/A psi.

RIP#5075

8. Description of piping inspected MK: 2G369P-MS-1003-GA2-Q8-J: SA-333 Gr. 6 Sml's, 16" (.844" W)
 (Include - name no. - material spec. - nom. pipe size - schedule or thickness - length

3'-2 3/4" lg.; SA-234 WPB Wld'd, 33.875" O.D. (1.183" MW) X 33.875" O.D.

**
 (1.621" MW) EXT. HDR W/(3) outlets-16" O.D. (.738" MW), 9" O.D. (1.500" MW)

& 4.5" O.D. (.295" MW); SA-234 WPB Wld'd, 33.875" O.D. (1.621" MW) EXT. HDR.

W/(2) outlets-9" O.D. (1.500" MW); SA-234 WPB Wld'd, 33.875" O.D. (1.621" MW)

X 31.125" O.D. (1.746" MW) EXT. HDR. W/(3) outlets-(1) 12.750" O.D. (.602" MW)

& (2) 9" O.D. (1.500" MW); SA-350 LF2, 6" 1500# LG. WN RF Flg. (5); SA-420

WPL6 Sml's., 16" S/80 Weld Cap; SA-350 LF2, 16" X 2" 3000# S-O-L; SA-350 LF2,

1 1/2" 6000# S/W Bosset (2); SA-350 LF2, 33 7/8" O.D. X 1" 3000# S-O-L (5);

SA-350 LF2, 16" X 1" 3000# S-O-L (2); SA-350 LF2, 1" 3000# FL. S-O-L

**Material in accordance with 1980 Edition, Summer 1980.

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms
 with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 11-16-84 Signed SFSWCO

(Fabricator)

By (1h) Morris Lenny

Certificate of Authorization Expires JULY 23, 1985 Certificate of Authorization No. H-1459

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors
 and/or the State or Province of TEXAS and employed by H.S.B.I.L.C., HARTFORD, CT

have inspected the piping described in this Data Report on 11-16-84, and state that to the best of my knowledge
 and belief, the Manufacturer has constructed this piping in accordance with the applicable Subsections of ASME Code,
 Section III.

By signing this certificate, neither the Inspector nor his employer make any warranty, expressed or implied, concerning
 the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner
 for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-16-84, 1984

A. F. Lenny
 (Inspector)

Commissioner Ted 370
 National Board, State, Province and No.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8½" x 11", (2) information in items 1, 2 and 5
 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 7, "Remarks".

COPY

Coff Corporation / Flange Division

4444 Center St. Houston, Texas 77007 (713) 868-4421

MILL TEST REPORT

(82)
CUSTOMER

SOUTHWEST FABRICATING

(21)
P.O. No.

2657N-348

COFFER W/O No.

40556-N

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
1	40	6" 1500# RF LWN X14" LONG A.S.M.E. SECTION III CLASS 2 ✓ 1974 Edition through Winter 1975 Addenda 10CFR21 applies.	SA-350 LF-2	ZVA RIP# 5075

SPECIAL REQUIREMENT

MATERIALS ON THIS ORDER WERE PRODUCED UNDER A QUALITY SYSTEM PROGRAM MEETING THE REQUIREMENTS OF A.S.M.E. SECTION III, NCA 3800 and COFFER CORPORATION QUALITY SYSTEM EFFECTIVE FEBRUARY 17, 1984 REV. E; APPROVED BY SOUTHWEST FAB., MARCH 28, 1984.
MATERIALS ON THIS REPORT WERE NORMALIZED AT 1650 DEG.F., FOR TWO HOURS AND AIR COOLED.

✓ CHEMICAL ANALYSIS

ITEM	HEAT CODE	MILL	HEAT NO.	CAR.	MAN.	PHOS.	SUL.	SIL.	NI	CR	MO	CU
1	ZVA			.22	1.20	.006	.024	.19				
2												
3												
4												

✓ PHYSICALS

✓ CHARPY RESULTS

ITEM	TENSILE	YIELD	ELONG	REDUCTION	1ST	2ND	3RD	AVG.	TEMP.
1	79,500	53,000	36.0	68.0	49	123	146		-50 DEG.F.
2					30	90	90		% SHEAR
3					39	86	79		M.L.E.
4									

I HEREBY CERTIFY THAT THE REPORTED FIGURES ARE CORRECT,
AS CONTAINED IN THE RECORDS OF THE CORPORATION.

CERTIFICATION

Rosalie A. Haas

BECHTEL

743

15

34



NUCLEAR PRODUCTS INC.

4405 HAYGOOD 4407 HAYGOOD
 P.O. BOX 7303 P.O. BOX 7303
 HOUSTON, TEXAS 77248 HOUSTON, TEXAS 77248
 (713) 695 3633 (713) 695 2835

SOLD
TOSOUTHWEST FABRICATING AND WELDING
 P.O. BOX 9449
 HOUSTON, TEXAS 77281*Law Long*

16" S/80 Weld Caps

CUSTOMERS ORDER NO.

2657N-419

WF INO. N1812

DATE SEPTEMBER 19, 1984

CERTIFIED MATERIAL TEST REPORT

THIS MATERIAL IS FURNISHED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME SECTION II, PART "A"
 MATERIAL SPECIFICATION REFERENCED AND ASME SECTION III, CLASS II 1974 EDITION THRU WINTER
 1975 ADDENDA. THIS MATERIAL WAS MANUFACTURED AND PROCESSED IN ACCORDANCE WITH THE QUALITY
 SYSTEM REQUIREMENTS OF ASME SECTION III, SUBSECTION NCA3800/NA3700. 10 CFR 21 APPLIES

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
1	8	16" S/80 B/W WELD CAPS	ASME SA420WPL6 SA350LF2	132BN
		-50°F CHARPYS 107/100/104 FT.LBS. 60/60/70 % SHEAR .062/.057/.059 M.L.E.		RIP#5075

CHEMICAL COMPOSITION

HEAT CODE	MILL NO.	C	MN	P	S	SI	Ni	CR	MO
132BN	214881	.24	1.19	.015	.027	.18			
	SHARON								
132BN	PRODUCT	.26	1.26	.018	.024	.20			
	ANALYSIS								

MECHANICAL PROPERTIES

HEAT CODE	TENSILE PSI	YIELD PSI	ELONG %	RA %	HARDNESS
132BN	83,266	56,012	32.3	59.8	152HBN
	CHARPY "V" NOTCH IMPACT TESTS IN ACCORDANCE				
	WITH ASME SECTION III, SUBSECTION NC-2342				
	-140°F 252/228/228 FT.LBS.				
	100/100/100 % SHEAR				
	.094/.087/.086 MLE				

We certify that the material furnished on this order complies in all respects with the specifications as stated and that this correct information is as contained in our records.


WFI, Inc.

Charles V. Claypool Q.A. DEPT.

Subscribed before me this 19TH

day of SEPTEMBER, 1984

NOTARY PUBLIC - HARRIS COUNTY, TEXAS

QSC #425
Expiration Date 1-16-1987BECHTEL
743

116

84

WFI

NUCLEAR PRODUCTS, INC.

INTERNATIONAL NUCLEAR PRODUCTS

4405 HAYGOOD P.O. BOX 7303 HOUSTON, TEXAS 77248 (713) 695-3633

4407 HAYGOOD P.O. BOX 7303 HOUSTON, TEXAS 77248 (713) 695-2835

SOLD
657N-341

L

CUSTOMERS ORDER NO. 2657N-341

WF1 NO. N-1705 DATE MAY 18, 1984

SA-350/LF2

CERTIFIED MATERIAL TEST REPORT

THIS MATERIAL IS FURNISHED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME SECTION II, PART II, MATERIAL SPECIFICATION REFERENCED, AND ASME SECTION III, CLASS 2, 1974 EDITION, THRU WINTER 1975 ADDENDA. THIS MATERIAL WAS MANUFACTURED AND PROCESSED IN ACCORDANCE WITH THE QUALITY SYSTEMS REQUIREMENTS OF ASME SECTION III, SUBSECTION NCA3800/ NA3700: 10 CFR 21 APPLIES.

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
4	8	16" O.D. X 2" 3M# SOCKET WELD PIPE	ASME SA-350-LF2	976AN

CHEMICAL COMPOSITION

HEAT CODE	MILL NO.	C	MN	P	S	SI	NI	CR	MO.		
976AN	LADLE	.24	.93	.010	.032	.26				RIP# 5075	
976AN	PRODUCT	.26	1.00	.011	.026	.29					
	ANALYSIS										

MECHANICAL PROPERTIES

HEAT CODE	TENSILE PSI	YIELD PSI	ELONG %	RA %	HARDNESS
976AN	81,563	54,709	35.2	72.4	143
	CHARPY -50°F	109/111/99 FT. LBS.			

We certify that the material furnished on this order complies in all respects with the specifications as stated and that this correct information is as contained in our records.

WFI, Inc.

Virgil Killogy Q.A. DEPT.

18TH

Subscribed before me this

MAY

day of

19

Virgil Killogy
ROBERT PUBLIC - MARSH COUNTY, TEXAS

✓ Q.S.C. # 425
Expiration Date 1-16-1987

BECHTEL
743



HEAT TREATMENT
976AN - AUSTENITIZED AT 1625°F FOR 5
HOURS AND WATER QUENCHED: TEMPERED AT
1150°F FOR 4 HOURS AND AIR COOLED IN STILL
AIR.

84



NUCLEAR PRODUCTS, INC.

INTERNATIONAL

4405 HAYGOOD
P.O. BOX 7303
HOUSTON, TEXAS 77248
(713) 695-3633

NUCLEAR PRODUCTS

4407 HAYGOOD
P.O. BOX 7303
HOUSTON, TEXAS 77248
(713) 695-2835

SOUTHWEST FABRICATION & WELDING COMPANY
SUITE 100, P.O. BOX 9449
TO HOUSTON, TEXAS 77011

Law Corp

5A-350/LF-21

(42)

2657N-341

CUSTOMERS ORDER NO.

WF NO. N-17051

DATE MAY 18, 1984

CERTIFIED MATERIAL TEST REPORT

THIS MATERIAL IS FURNISHED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME SECTION II, PART "A", MATERIAL SPECIFICATION REFERENCED AND ASME SECTION III, CLASS 2, 1974 EDITION, THRU WINTER 1975 ADDENDA. THIS MATERIAL WAS MANUFACTURED AND PROCESSED IN ACCORDANCE WITH THE QUALITY SYSTEMS REQUIREMENTS OF ASME SECTION III, SUBSECTION NCA3800/NA 3700: 10 CFR 21 APPLIES:

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
1	32	1-1/2" 6MM SOCKET WELD BOSSET (XXH BORE)	ASME SA350-LF2	1148N

CHEMICAL COMPOSITION

HEAT CODE	MILL NO	C	MN	P	S	SI	NI	CR	MO	
1148N	LADLE	.27	.92	.011	.022	.27				RIP# 5075
1148N	PRODUCT	.26	.85	.006	.019	.23				
	ANALYSIS									

MECHANICAL PROPERTIES

HEAT CODE	TENSILE PSI	YIELD PSI	ELONG %	RA %	HARDNESS
1148N	77,662	53,766	36.4	73.6	140
					CHARPY S -50°F 204/180/213 FT. LBS.

HEAT TREATMENT 1148N- AUSTENITIZED AT 1640°F to 1650°F

FOR 3 1/4 HOURS AND WATER QUENCHED. TEMPERED AT 1250°F

FOR 3 1/4 HOURS AND AIR COOLED.

We certify that the material furnished on this order complies in all respects with the specifications as stated and that this correct information is as contained in our records.

WFI, Inc.

Virgil Kellogg Q.A. DEPT.
Subscribed before me this 18TH

day of MAY 1984

Q.S.C. # 425
Expiration Date 1-16-1987



BECHTEL
743



4405 HAYGOOD
P.O. BOX 7303
HOUSTON, TEXAS 77248
(713) 695-3633

4407 HAYGOOD
P.O. BOX 7303
HOUSTON, TEXAS 77248
(713) 695-2835

SOUTHWEST FABRICATING AND WELDING COMPANY
P.O. BOX 9449
HOUSTON, TEXAS 77011

Low Temp
SA-350 LF-2

SOLD TO
69A
CUSTOMERS ORDER NO.

N-1705
WF INO.

2657N-341

MAY 18, 1984

CERTIFIED MATERIAL TEST REPORT

THIS MATERIAL IS FURNISHED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME SECTION II, PART "A", MATERIAL SPECIFICATION REFERENCED, AND ASME SECTION III CLASS 2, 1974 EDITION, THRU WINTER 1975 ADDENDA. THIS MATERIAL WAS MANUFACTURED AND PROCESSED IN ACCORDANCE WITH THE QUALITY SYSTEMS REQUIREMENTS OF ASME SECTION III, SUBSECTION NCA3800/NA3700: 10 CFR 21 APPLIES:

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
2	40	33-7/8" O.D. X 1" 3M# SOCKET WELD PIPE	ASME SA350-LF2	106BN
3	16	16" O.D. X 1" 3M# SOCKET WELD PIPE	ASME SA350-LF2	106BN
			RIP#5075	

CHEMICAL COMPOSITION

HEAT CODE	MILL NO.	C	MN	P	S	SI	NI	CR	MO		
106BN	LADLE	.21	1.04	.017	.030	.16					
106BN	PRODUCT	.21	1.08	.016	.029	.15					
	ANALYSIS										

MECHANICAL PROPERTIES

HEAT CODE	TENSILE PSI	YIELD PSI	ELONG %	RA %	HARDNESS
106BN	92,231	75,341	27.3	70.0	179
	CHARPY S -50°F	50/59/70 FT.LBS.			

We certify that the material furnished on this order complies in all respects with the specifications as stated and that this correct information is as contained in our records.

WFI, Inc.

Virgil Kellogg Q.A. DEPT.
Subscribed before me this 18TH

day of MAY 1988

Donda R. May ROTARY PUBLIC - HARRIS COUNTY, TEXAS
Q.S.C. # 425
Expiration Date 1-16-1987

BECHTEL
743





NUCLEAR PRODUCTS, INC.

INTERNATIONAL

4405 HAYGOOD

P.O. BOX 7303

HOUSTON, TEXAS 77248

(713) 695-2833

NUCLEAR PRODUCTS

4407 HAYGOOD

P.O. BOX 7303

HOUSTON, TEXAS 77248

(713) 695-2835

69

SOLD
TO

L

SOUTHWEST FABRICATING & WELDING
PO BOX 9449
HOUSTON, TEXAS 77011

CUSTOMERS ORDER NO.

2657N-392

WFN NO.

N-1794

DATE 8/17/84

COPY

CERTIFIED MATERIAL TEST REPORT

THIS MATERIAL IS FURNISHED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME SECTION II, PART A, MATERIAL SPECIFICATION REFERENCED AND ASME SECTION III, CLASS 2, 1974 EDITION THRU WINTER 1975 ADDENDA. THIS MATERIAL WAS MANUFACTURED AND PROCESSED IN ACCORDANCE WITH THE QUALITY SYSTEM'S REQUIREMENTS OF SECTION III, SUBSECTION NCA3800/NA3700. 10 CFR PART 21 APPLIES.

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
1.	8	✓ FLAT X 1" 3M# SW PIPET	✓ SA350-LF2	✓ 106BN RIP# 5075

✓ CHEMICAL COMPOSITION

HEAT CODE	MILL NO	C	MN	P	S	SI	NI	CR	MO		
106BN	WFI ANALYSIS	21	1.08	.016	.029	15					
	TABLE	21	1.04	.017	.030	16					

MECHANICAL PROPERTIES

HEAT CODE	TENSILE PSI	YIELD PSI	ELONG %	RA %	HARDNESS
106BN	92,771	75,841	27.3	70.0	179
	CUW -50°F	50/59/70			

We certify that the material furnished on this order complies in all respects with the specifications as stated and that this correct information is as contained in our records.

WFI, Inc.

Charles F. Clayton DEPT

Subscribed before me this 17th

day of AUGUST 1981

Signature: Sandra D. H. Kyle
ROBERT PUBLIC LIBRARY, HOUSTON, TEXAS

BECHTEL

743

Q.S.C. #425

Expiration Date: 1/16/87



120

COPY

PHOENIX STEEL CORPORATION

TUBE DIVISION
PHOENIXVILLE, PENNA.

(84)

(11)

CERTIFICATE OF INSPECTION AND TESTS

DATE: 7-21-82	DATE SHIPPED: 6-24-82	ITEM UNDER NO. T-6881-8-30	SHIPPING LIST 226E			
Capitol Pipe & Steel P Co.		CUSTOMER ORDER NO. I 26878 00C				
<i>SA 333 / 25-6 SMLS</i>		CAR NO. CR 582039	MATERIAL: SEAMLESS <input type="checkbox"/> PIPE <input checked="" type="checkbox"/> TUBE, HOT FINISHED			
		SPECIFICATION: ASTM A-333-79, ASME SA-333 Gr. 6				
<i>16" (.844" w) Pipe</i>						
Q. PCS.	OD. PCS.	WALL	LENGTH	TOTAL FT.	TOTAL WT.	HEAT NO.
	00					52407
	16.000" x .844"					

Longitudinal Vee Notch Charpy at Minus 50°F. (10mm x 10mm)
Ft. Lbs. Lateral Expansion Per Cent Shear
 64-90-80 .058-.083-.072 40-50-50

RIP#5075

HEAT NO.	C	Mn.	P.	S.	Si.	Cu.	Ni.	Cr.	Mo.
52407	.13	1.05	.012	.019	.25	Ladle Analysis			
52407	.13	1.06	.012	.019	.26	Product Analysis			
52407	.14	1.08	.012	.019	.25	Product Analysis			

This material was manufactured in accordance with our Quality Program revised 2-1-80 which was audited by Capitol Pipe on 7-30-81 and approved as meeting the requirements of ASME Section III, Subarticle NCA-3800.

HEAT NO.	TENSILE (KSI)	YIELD (KSI)	% ELONG. IN 2"	% RA	HARDNESS ROCKWELL	BRINELL	GRAIN SIZE
52407	67.5	44.0	41.00	Normalized at 1650°F. Held for 2 hours and air cooled.			



JOMINY DISTANCE - 18TH ROCKWELL C FLATTENING OK HYDROSTATIC PSI 2300

1 2 4 6 8 10 12 14 16 20 24 28 32

THE PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH METHODS PRESCRIBED IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY RECORDS ARE AS SHOWN ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTION OR TESTING ARE PRESCRIBED IN THE SAID SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. BASED UPON SUCH INSPECTION AND TESTS, THE ABOVE MATERIALS HAVE BEEN APPROVED AS FULFILLING THE REQUIREMENTS OF SAID SPECIFICATION.

Wayne Rieder
ENGINEER OF TESTS

BECHTEL
743



Capitol

PIPE & STEEL PRODUCTS CO.
Division of BOWLINE Corporation

COPY

ALLOY PIPING MATERIALS FOR HIGH TEMPERATURE AND LOW TEMPERATURE APPLICATIONS

ADDRESS ALL REPLIES TO
SAN ANTONIO & ORANGE STREETS
P.O. BOX 6
PEARLAND, TEXAS 77581
(713) 485-3246

301 CITY LINE AVENUE • AREA CODE 215 • TE 8-4300
BALA-CYNWYD, PENNSYLVANIA 19004

CAPITOL PIPE CERTIFICATE OF CONFORMANCE

ASME QUALITY SYSTEMS CERTIFICATE (MATERIALS) NUMBER QSC-206-1

EXPIRATION DATE: MAY 6, 1984 —

MATERIAL MANUFACTURER'S CERTIFICATION: 16" S/80 SA333 GR. 6 SMLS PIPE

HEAT NUMBER: 52407

REFERENCE: SOUTHWEST FAB. & WELDING

P/O# 2657N-242

Capitol S/O# 45A-5069N

Capitol Chg# H31826 45A

Item 1

MANUFACTURER: PHOENIX STEEL

Capitol Pipe certifies that the certified Mill Test Report supplied for the material described above, is a true copy of the material manufacturer's original as contained in our files. We further certify that this material was procured under and controlled by the Quality Systems Program covered by the ASME Certificate shown above.

Based upon Capitol's review of the Material Manufacturer's Certified Mill Test Report and the requirements of the purchase order, this material is supplied in accordance with the specifications checked below.

RIP# 5075

- ASTM Specification _____
- ASME Specification SA333 GR. 6, 1974 Edition, Winter 1975 Addenda.
- ASME Section III, Class 2, 1974 Edition, Winter 1975 Addenda, paragraphs N.C. 2000. (including the provisions of N.C. 26101).
- Additional Requirements NOTES 1 AND 3 OF QA-20 DTD 10/11/74 APPLY
NCA-3800 APPLIES. 10 CFR PART 21 APPLIES.

Capitol Pipe certifies that the following tests, examinations or treatments were performed in accordance with and meet the requirements of the specifications shown above. Reports containing the results of these operations are included as attachments.



BECHTEL
743

Sabella Bailey DATE: 2/16/84
QUALITY ASSURANCE REPRESENTATIVE
Approved Pursuant to Contract #LIC-14

122

CUSTOMER Southwest Fabricating & Welding Co.
P.O. Box 9449
Houston, TEXAS 77261-9449



Taylor Forge Engineered Systems

P.O. Box 8
Phone #5-8881
913/764-4321

CUSTOMER ORDER NO. 2657N-214

PACKING LIST NO.

The finished product shown was produced in the U.S.A.

HEAT NUMBER	PHYSICAL PROPERTIES				CHEMICAL ANALYSIS							DESCRIPTION	
	YIELD STRENGTH AT % OFFSET PSI	TENSILE STRENGTH PSI	ELONG. %	RED OF AREA %	C	MN	P	S	SI	MO	CR	NI	

Designed Per ASME Section III Cl. 2 (W75) 1285 psig @ 600°F w/1/16" C.A.

Fab. Per MPS-B1 R/ 1

Material SA-516-70 w/Impacts Per NC-2300

MT bevel per QSP 4.2.2 R/3 results acceptable

After welding Tong seam normalized per MPS-C3 R/0
Normalized 1700 +25°F held at temp. 1 hr per inch A/C

After hot forming outlet normalized per MPS-C3 R/0
Normalized 1700 +25°F held at temp. 1 hr per inch A/C

RT Tong seam per QSP 4.1.4 R/5 results acceptable

After machining, MT bevels per QSP 4.2.2 R/3 results acceptable

N-PWHT per MPS-C4 R/0

PWHT temperature 1125 - 1175°F Holding Time At Temperature 2-1/2 hrs

Rate of heating above 800°F did not exceed 114 °/Hr

Rate of cooling down to 800°F did not exceed 114 °/Hr
From 800°F downward A/C

R
-P

5075

This fitting is certified to meet the requirements
of Para. 2.2 of ANSI B16.9-1978.

7/23
BECHTEL



SCRIBED AND SWORN TO BEFORE ME

STATE NOTARY PUBLIC 3rd DAY OF August 19 84

Margaret Maisch
NOTARY PUBLIC

The undersigned certifies that the contents of this report are correct and accurate
and that all above test results and operations performed are in compliance with
requirements of the applicable sections of the above stated specifications and purchase
order.

For Quality Assurance Manager

Southwest Fabricating & Welding Co., Inc.



Customer No. SA-234-MP8W

Heat Treatment

P.O. Box 9849
Houston, Texas 77261-9449
913-794-6351

Customer Order No. 2657N-214

Our Order No. 803450

CERTIFIED MATERIAL TEST REPORT

Material manufactured, fabricated and tested in accordance
with purchase order, request reports and specification(s)

NUCLEAR

DESCRIPTION

CHEMICAL ANALYSIS

PHYSICAL PROPERTIES

Heat Number	Yield Point (in lb/in²) at Offset 0.2%	Tensile Strength lb/in²	Elong. %	Red of Area %	C	Mn	P	S	Si	Mo	Cr	Ni	Item 2A	PC. 1	—
KOPV	SEE ATTACHED CMTR FROM BETHLEHEM STEEL COMPANY														

OUR SERIAL NO. HE-20 —

RIP# 5075

REMARKS:

BECHTEL
743

MARGARET MAISCH,
STATE NOTARY PUBLIC
Whitney County Sheriff
City Attorney
120 E. Main Street
P.O. Box 300
Whitehouse, TX 75691
1984

The undersigned certifies that the contents of this report are correct and accurate
and that all above test results and operations performed are in compliance with
requirements of the applicable sections of the above stated specifications and purchase
order.

For Quality Assurance Manager.

Shelly

MARGARET MAISCH,
STATE NOTARY PUBLIC
Whitney County Sheriff
City Attorney
120 E. Main Street
P.O. Box 300
Whitehouse, TX 75691
1984

13

*Added

FORM N-2 MANUFACTURER'S DATA REPORT FOR NUCLEAR PARTS AND APPURTENANCES*

As required by the Provisions of the ASME Code Rules

1. (a) Manufactured by Taylor Forge Engineered Systems G+W Manufacturing Company
First & Iron Streets Paola, Kansas 66071

(Name and address of Manufacturer of part)
 1. (b) Manufactured for Southwest Fabricating & Welding Co., Inc. P.O. Box 9449 Houston, Texas
 (Name and address of Manufacturer of completed nuclear component)

2. Identification-Manufacturer's Serial No. of Part 803450 2A1 Part No. -----

(a) Constructed According to Drawing No. 803450 - 2 Drawing Prepared by Taylor Forge Engineered Systems

Sheet 01 Rev. 4 *SA-234-WPBW

(b) Description of Part Inspected Main Steam Ext. Header 11' 3" lg. E Exch 1 X-25-2

(c) Applicable ASME Code Section III, Edition 1974, Addenda date W75, Case No. ----- Class -----

3. Remarks: (Brief description of service for which component was designed)

Southwest Fabricating & Welding Co., Inc. Approved Material to S 80 Addenda

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
 (The applicable Design Specification and Stress Report are not the responsibility of the part Manufacturer. An appurtenance Manufacturer is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Taylor Forge

Date 8-31 1984 Signed Engineered Systems By D. J. G.

(Manufacturer)


N-1937

Certificate of Authorization Expires 11-25-86 Certificate of Authorization No. -----

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at --

--



Stress analysis report on file at --

--

Design specifications certified by -- Prof. Eng. State -- Reg. No. -----

--

Stress analysis report certified by -- Prof. Eng. State -- Reg. No. -----

--

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Kansas and employed by Hartford Steam Boiler Insp. & Ins. Co. of Hartford, Conn. have inspected the part of a pressure vessel described in this

Manufacturer's Partial Data Report on 8-31 1984, and state that to the best of my knowledge and belief, the Manufacturer has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Manufacturer's Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-31 1984

Edmund Finsin
 Inspector's Signature

Commission No. NC 9989 KS 263
 (National Board, State, Province and No.)

RIP# 5075

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8½" x 11", (2) information in Items 1-2 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 8, "Remarks".

BECHTEL
 743

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA-516-70 T.S. 70000 Nominal 3.346 Corrosion 1/16 Thickness in. Allowance in. Dia. 2 ft. 9-7/8 in. Length 11 ft. 3 in. (Kind & Spec. No.) (Min. of Range Specified) 3.76

5. Seams: Long Dbl Butt H.T.¹ Yes R.T. Yes Efficiency 100 %

Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____ one
 6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
(a) _____	_____	_____	_____	_____	_____	_____	_____	_____
(b) _____	_____	_____	_____	_____	_____	_____	_____	_____

 If removable, bolts used _____ Other fastening _____ (Describe or attach sketch)
 (Material, Spec. No., T.S., Size, Number)

7. Jacket Closure: _____ (Describe as ogee and weld, bar, etc. If bolted, describe or sketch)
 Drop Weight _____ ft-lb
 Charpy Impact _____ ft-lb
 at temp. of _____ °F

8. Design pressure² _____ psi at _____ °F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary, Material _____ Dia. _____ Thickness _____ in. Attachment _____ (Welded, Bolted)
 (Kind & Spec. No.) (Subject to pressure)

Floating, Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____ (S. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal _____ Corrosion _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in. (Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %

Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
(a) Top, bottom, ends	_____	_____	_____	_____	_____	_____	_____	_____
(b) Channel	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)

Drop Weight _____ ft-lb
 Charpy Impact _____ ft-lb
 at temp. of _____ °F

14. Design pressure² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

RIP#5075

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet, Outlet, Drain)	Number	Dis. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

BECHTEL

743

17. Inspection Manholes, No. _____ Size _____ Location _____
 Openings: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____ (Where & How)
 (Yes or No) (Number) (Number) (Describe)

¹ W Postweld Heat-Treated

² List other internal or external pressure with coincident temperature when applicable.

FORM NPP-1 DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES*
(As Required by the Provisions of the ASME Code Rules)

SOUTHWEST FABRICATING & WELDING CO. INC. 7525 SHERMAN, HOU. TX 77011 Order No. S.O.#Q2657-MS

1. Fabricated by _____
(Name and Address of Fabricator)

2. Fabricated for HOUSTON LIGHTING & POWER CO., HOUSTON, TX. Order No. P.O.#35-1197-6014
HOUSTON LIGHTING & POWER CO.,
3. Owner SOUTH TEXAS NUCLEAR UNIT I 4. Location of Plant WADSWORTH, TX.

5. Piping System Identification Main Steam, Serial #39721
(Brief description of intended use, main coolant etc.)
(a) Drawing No. 02657-MS #59 Prepared by SOUTHWEST FAB. & WELDING CO., INC.
(b) National Board No. N/A

6. The material, design, construction, and workmanship complies with ASME Code Section III, Class 2
Edition 1974, Addenda Date WINTER 1975, Case No. ---

Remarks: Manufacturers' Data Reports properly identified and signed by Commissioned Inspectors have been furnished for
the following items of this report PIPE - Item (A) Taylor Forge S/N 803450-3A.
(Name of Part - Item number, Manufacturer's name, and identifying stamp)

7. Shop Hydrostatic Test N/A psi.

8. Description of piping inspected MK: 2G369P-MS-1003-GA2-08-H; SA-155 KCF-70 CL. I Wld'd,
(include - mark no. - material spec. - nom. pipe size - schedule or thickness - length
31 1/8" O.D. (1.746" MW) X 11'-11 9/16" lg; SA-350 LF2, 1 1/2" 6000# S/W
- fittings - flanges, etc.)

Bosset.

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms
with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 9-21-84 Signed SF&WCO By (lh) Mans Lenny
(Fabricator)

Certificate of Authorization Expires JULY 23, 1985 Certificate of Authorization No. N-1459

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors
and/or the State or Province of TEXAS and employed by H.S.B.I.L.C., HARTFORD, CT
have inspected the piping described in this Data Report on 9-21-1984, and state that to the best of my knowledge
and belief, the Manufacturer has constructed this piping in accordance with the applicable Subsections of ASME Code,
Section III.

By signing this certificate, neither the Inspector nor his employer make any warranty, expressed or implied, concerning
the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner
for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 9-21-84, 1984
H.S.B.I.L.C., HARTFORD, CT
(Inspector)

Commission No. 704 370
National Board, State, Province and No.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8½" x 11", (2) information in items 1, 2 and 5
on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheet is recorded in item 7, "Remarks".

Southwest Fabricating & Welding Co.



Taylor Forge Engineered Systems

CUSTOMER

P.O. Box 9449
Houston, TEXAS 77261-9449

P.O. Box 9
Posto, KS 66071
913/294-5331

CUSTOMER ORDER NO.

2657N-214

OUR ORDER NO. 803450

COVER SHEET

CERTIFIED MATERIAL TEST REPORT

Material manufactured/fabricated and tested in accordance
with purchase order requirements and specification(s)

PACKING LIST NO.

The finished product shown was produced in the U.S.A.

HEAT NUMBER	PHYSICAL PROPERTIES				CHEMICAL ANALYSIS						DESCRIPTION	
	YIELD POINT OR YIELD STRENGTH AT _____% OFFSET PSI	TENSILE STRENGTH PSI	ELONG. %	RED OF AREA %	C	MN	P	S	SI	MO	CR	

Designed Per ASME Section III Cl. 2 (W75) 1285 psig @ 600°F w/1/16" C.A.

Fab. Per MPS-B2 R/ 1

Material SA-516-70 w/Impacts Per NC-2300

MT bevels per QSP 4.2.2 R/3 results acceptable

Normalized Per MPS-C3 R/0 (including tabs)

Normalized 1700 +25°F held at temp. 1 hr per inch A/C

Tested Per MPS-D1 R/0 acceptable results attached

tests per thk. per heat per ht. trt procedure

check analysis (parent) per SA-155 Para. 7.1

crossweld tensile per SA-155 Para. 10.3

transverse bend tests per SA-155 Para. 9.0

RT long seam per QSP 4.1.4 R/5 results acceptable

MT bevels per QSP 4.2.2 R/3 results acceptable

PWHT Per MPS-C4 R/0

PWHT temperature 1125 - 1175°F Holding Time At Temperature 2-1/2 hrs -

Rate of heating above 800°F did not exceed 114 °/hr

Rate of cooling down to 800°F did not exceed 114 °/hr

From 800°F downward A/C

BECHTEL
743

SCRIBED AND SWORN TO BEFORE ME



14th DAY OF August 1984

MARGARET MAISCH
NOTARY PUBLIC

The undersigned certifies that the contents of this report are correct and accurate
and that all above test results and operations performed are in compliance with
requirements of the applicable sections of the above stated specifications and purchase
order.

For Quality Assurance Manager.



D. J. May

*Added

FORM N-2 MANUFACTURER'S DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provisions of the ASME Code Rules

Taylor Forge Engineered Systems G+W Manufacturing Company
First & Iron Streets Paola, Kansas 66071

1. (a) Manufactured by _____
(Name and address of Manufacturer of part)
(b) Manufactured for _____
(Name and address of Manufacturer of completed nuclear component)

2. Identification-Manufacturer's Serial No. of Part _____ 803450 3A Nat'l Id. No. _____


(a) Constructed According to Drawing No. 803450 - 3 Drawing Prepared by Taylor Forge Engineered Systems
Sheet B1 Rev. 3 TFE3 8/26/84 9-17-84
(b) Description of Part Inspected Main Steam Piping 11' 11-9/16" lg. *SA-155 KCF70 C1. 1 NH
C. Emiss. 8-26-84
(c) Applicable ASME Code: Section III, Edition 1974 Addenda date W75 Class _____

3. Remarks: _____
(Brief description of service for which component was designed)

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code conforms to the rules of construction of the ASME Code Section III.
(The applicable Design Specification and Stress Report are not the responsibility of the part Manufacturer. An appurtenance Manufacturer is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report.)

Taylor Forge

Date 8-24 1984 Signed Engineered Systems By S. D. Higginson
(Manufacturer) N-1937
Certificate of Authorization Expires 11-25-86 Certificate of Authorization No.



CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at _____

--

--

Stress analysis report on file at _____

--

--

Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____

--

Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Kansas and employed by Hartford Steam Boiler Insp. & Ins. Co. of Hartford, Conn., have inspected the part of a pressure vessel described in this

Manufacturer's Partial Data Report on 8-24 1984, and state that to the best of my knowledge and belief, the Manufacturer has constructed the part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Manufacturer's Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-24 1984

Edward Ermis
Inspector's Signature

Commission No. 4029889 NS263
National Board, State, Province and No.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8W" x 11", (2) information in Items 1-2 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3, "Remarks".

BECHTEL
743

32

Items 4-8 incl. to be completed for single wall vessels, jackets of jacketed vessels, or shells of heat exchangers.

4. Shell: Material SA-516-70 T.S. 70000 Nominal 787 Corrosion 1/16 in. Allowance 2 ft. in. Dia. 7-1/8 in. Length 11 ft. in. (Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long Dbl Butt H.T.¹ Yes R.T. Yes Efficiency 100 %

Girth _____ H.T.¹ _____ R.T. _____ No. of Courses one

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
 Location (Top, bottom, ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Conv. or Conc.)

(a) _____ (b) _____

If removable, bolts used _____ Other fastening _____ (Describe or attach sketch)

7. Jacket Closure: (Describe as ogee and weld, bar, etc. If bar give dimensions, if bolted, describe or sketch)

Drop Weight _____ Charpy Impact _____ ft-lb
at temp. of _____ °F

8. Design pressure² _____ psi at _____ °F

Items 9 and 10 to be completed for tube sections

9. Tube Sheets: Stationary, Material _____ Dia. _____ Thickness in. Attachment _____ (Welded, Bolted)
 (Kind & Spec. No.) (Subject to pressure)

Floating, Material _____ Dia. _____ Thickness in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ inches or gage. Number _____ Type _____ (Siz. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness in. Corrosion Allowance in. Dia. ft. in. Length ft. in. (Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long H.T.¹ _____ R.T. _____ Efficiency _____ %

Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Conv. or Conc.)

(a) Top, bottom, ends _____ (b) Channel _____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____ (Describe or attach sketch)

Drop Weight _____, Charpy Impact _____ ft-lb
at temp. of _____ °F

14. Design pressure³ _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:


Purpose (Inlet, Outlet, Drain)	Number	Size or Size	Type	Material	Thickness	Reinforcement Material	How Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Manholes, No. _____ Size _____ Location _____ 743
 Openings: Handholes, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____

18. Supports: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____ (Where & How)
 (Yes or No) (Number) (Number) (Describe)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.



Feedwater Pipe

FORM NPP-1 DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES*
(As Required by the Provisions of the ASME Code Rules)

Q3H

1. Fabricating & Welding Co. Inc. 7525 SHERMAN, HOU. TX 77011 Order No. S.O.#Q2657-FW
 (Name and Address of Fabricator)

2. Fabricated for HOUSTON LIGHTING & POWER CO., HOUSTON, TX. Order No. P.O.#35-1197-6014
 HOUSTON LIGHTING & POWER CO.
 SOUTH TEXAS NUCLEAR UNIT I

3. Owner WADSWORTH, TX.

4. Location of Plant

5. Piping System Identification Feedwater, Serial #38885
 (Brief description of intended use, main coolant etc.)

(a) Drawing No. Q2657-FW #17 Prepared by SOUTHWEST FAB. & WELDING CO., INC.
 (b) National Board No. N/A

6. The material, design, construction, and workmanship complies with ASME Code Section III, Class 2
 Edition 1974, Addenda Date WINTER 1975, Case No. ---

Remarks: Manufacturers' Data Reports properly identified and signed by Commissioned Inspectors have been furnished for
 the following items of this report N/A
 (Name of Part - Item number, Manufacturer's name, and identifying stamp)

7. Shop Hydrostatic Test N/A psi.

8. Description of piping inspected MK: 2G369P-FW-1012-GA2-02-L; SA-333 Gr. 6 Sml's,
 (Include - mark no. - material spec. - nom. pipe size - schedule or thickness - length
 18" (.938" W) 2'-8 5/16" long; SA-350 LF2, 18" (Sch. 80) X 3" (Sch. 160)
 - fittings - flanges, etc.)
 W-O-L; SA-350 LF2, 18" X 1". 3000# S-O-L.

RIP # 4278

COPY

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 8-17-84 Signed SF&WCO By (lh) *Mauris Penney*
 (Fabricator)

Certificate of Authorization Expires JULY 23, 1985 Certificate of Authorization No. N-1459

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of TEXAS and employed by H.S.B.I.&I.C. HARTFORD, CT have inspected the piping described in this Data Report on 8-17-84, and state that to the best of my knowledge and belief, the Manufacturer has constructed this piping in accordance with the applicable Subsections of ASME Code, Section III. By signing this certificate, neither the Inspector nor his employer make any warranty, expressed or implied, concerning the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-17-84 Commissions Tex. 985
Glenn Costa (Inspector) National Board, State, Province and No.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8W" x 11", (2) information in items 1, 2 and 5 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 7, "Remarks".

JOB., CONTRACT NO.

92940-00N

SHIPPER'S NO.

MILL ORDER NO.

INVOICE NO.

GT 79445

356-07106

National

18

VEHICLE
IDENTITY

YES AND/OR TEST RESULTS SHOWN IN THIS REPORT ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

Capitol Pipe and Steel Products

Seamless Pressure Pipe

Normalized 1600°F for 118 Minutes, Air Cooled

2752 Longitudinal Tensile Tests

18" 80 H. G

Pipe : 18" S/30

low temp

SA 333-GR. 6.

SIGNATURE

DATE October 23, 1978

SHIP TO

STATE OF PENNSYLVANIA

COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME

THIS 23rd DAY OF October 1978

Emanuel Gallegos

NOTARY PUBLIC

E. GALLEGOS, Notary Public
Monaca, Pa. County

MY COMMISSION EXPIRES

IN 2-1919

MATERIAL DESCRIPTION			MATL	HEAT/ LOT NO.	MIN. HYDRO PSI	YIELD STR. PSI	TENSILE STR. PSI	ELONG. % IN 2"	CAGE WIDTH IN.	FLAT BEND
SIZE	WALL	SPECIFICATION & GRADE								
18"	.938"	ASTM A-333 ASME SA-333 ✓	6 ✓	Smis.	A63121 A63121 ✓	2200 2200	47780 44570 ✓	72910 72360 ✓	53.0 52.0	1½" ✓ 1½" ✓

CAPITOL PIPE
QUALITY
ASSURANCE

ACCEPTED


86
3
10/12/78FULL SIZE LONGITUDINAL CVN
IMPACTS AT MINUS 50°F ✓

FT. LBS. 7. SHEAR LA

A63121 ✓	52	48	.045
	48	43	.046
	27	36	.052
	96	85	.082
	101	100	.084
	102	100	.085


"This material was manufactured in accordance with the Quality Assurance Program as audited by A63121, Capitol Pipe and Steel Products on 9/9/77

RIP# 4228



COPY

United States Steel Corporation, National-Duquesne Works
PAGEChief Metallurgist
OF



SOLD TO
SOUTHWEST FABRICATING & WELDING
PO BOX 9449
HOUSTON, TEXAS 77011
SA-350/LF-2

L / " 6000# S-O-L
CUSTOMERS ORDER NO. 2657N-279

WFN NO. N-1677 DATE 3/29/84

CERTIFIED MATERIAL TEST REPORT

IS MATERIAL IS FURNISHED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME SECTION II, PART A,
MATERIAL SPECIFICATION REFERENCED AND ASME SECTION III, CLASS 2, 1974 EDITION THRU WINTER
75 ADDENDA. THIS MATERIAL WAS MANUFACTURED AND PROCESSED IN ACCORDANCE WITH THE QUALITY
SYSTEMS REQUIREMENTS OF SECTION III, SUBSECTION NCA3800/NA3700. 10 CFR PART 21 APPLIES.

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
	16	18" x 1" 3M# SW PIPE	SA350-LF2	863AN
	16	3" x 1" 6M# SW PIPE	SA350-LF2	863AN

RIP # 4278

CHEMICAL COMPOSITION

AT CODE	MILL NO.	C	MN	P	S	SI	NI	CR	MO
3AN	WET ANALYSIS	.28	1.02	.010	.018	.25			

COPY

MECHANICAL PROPERTIES

AT CODE	TENSILE PSI	YIELD PSI	ELONG %	RA %	HARDNESS
53AN	90,449	65,689	33.9	70.8	179
	CVN -50°F	99/134/136	FT LBS.		

HEAT TREATMENT: 863AN - AUSTENITIZED AT 1650°F FOR 2-1/2 HOURS AND WATER QUENCHED. TEMPERED AT 1100°F FOR 1 HOUR AND COOLED IN STILL AIR.


We certify that the material furnished on this order complies in all respects with the specifications as stated and that this correct information is as contained in our records.

WFI, Inc.

Virgil Kellogg O.A. DEPT.
Subscribed before me this 3RD
day of APRIL, 1984

NOTARY PUBLIC - HARRIS COUNTY, TEXAS

Q.S.C. #425
Expiration Date: 1/16/87



L. Hough
Eichleay & Hough
3/22/84

84



NUCLEAR PRODUCTS, INC.

INTERNATIONAL NUCLEAR PRODUCTS

 4405 HAYGOOD
 P.O. BOX 7303
 HOUSTON, TEXAS 77248
 (713) 695-3633

NUCLEAR PRODUCTS

 4407 HAYGOOD
 P.O. BOX 7303
 HOUSTON, TEXAS 77248
 (713) 695-2835

 SOLD TO SOUTHWEST FABRICATING & WELDING
 PO BOX 9449
 HOUSTON, TEXAS 77011

A 350/4F-2

L 3" W-O-L

CUSTOMERS ORDER NO. 2657N-279

WF1 NO. N-1677

DATE 3/29/84

CERTIFIED MATERIAL TEST REPORT

HIS MATERIAL IS FURNISHED IN ACCORDANCE WITH THE REQUIREMENTS OF ASME SECTION II, PART A, MATERIAL SPECIFICATION REFERENCED AND ASME SECTION III, CLASS 2, 1974 EDITION THRU WINTER 1975 ADDENDA. THIS MATERIAL WAS MANUFACTURED AND PROCESSED IN ACCORDANCE WITH THE QUALITY SYSTEMS REQUIREMENTS OF SECTION III, SUBSECTION NCA3800/NA3700. 10 CFR PART 21 APPLIES.

ITEM	QUANTITY	DESCRIPTION	MATERIAL	HEAT CODE
	8	18" (S/120) x 3" S/160 BW PIPE	/	SA350-LF2 /
	8	18" (S/80) x 3" S/160 BW PIPE	/	SA350-LF2 /

RIP # 4278**CHEMICAL COMPOSITION**

HEAT CODE	MILL NO.	C	MN	P	S	SI	NI	CR	MO
40AN	WFI ANALYSIS	.30	.82	.008	.039	.16			

COPY**MECHANICAL PROPERTIES**

HEAT CODE	TENSILE PSI	YIELD PSI	ELONG %	RA %	HARDNESS
40AN	75,089	45,662	33.7	57.9	137
CVN -50°F	32/28/30 FT	LBS.			

We certify that the material furnished on this order complies in all respects with the specifications as stated and that this correct information is as contained in our records.

WFI, Inc.

Virgil Kelley

O.A. DEPT.

29th

day of MARCH


1984

 Notary Public in and for the State of Texas
 SANORA L. WYLIE
 My Commission Expires July 13, 1985

 Q.S.C. #425 ✓
 Expiration Date: 1/16/87 ✓

 N/A sample
 F.G.H. + F.W.G.

3/22/84



8

Main Steam Isolation Valve

R1R878

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
 (As Required by the Provisions of the ASME Code, Section III, Div. 1)

1. Manufactured by Atwood & Morrill Co., Inc. Salem, MA
 (Name and Address of Manufacturer)

2. Manufactured for Westinghouse Electric Corp. Pittsburgh, PA
 (Name and Address of Purchaser or Owner)

3. Location of Installation South Texas Project 1 Palacios, Texas
 (Name and Address)

4. Pump or Valve Valve Nominal Inlet Size 30¹¹
 (inch) Outlet Size 30¹¹

(a) Model No., Series No. or Type	(b) Manufacturers' Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1) 30 ¹¹ Main Steam Isolation Valve	1-13839	N/A	13839-01-H	2	N/A	1978
(3)			Rev. 6			
(4)						
(5)						
(6)						
(7)						
(8)						
(9)						
(10)						

5. For service in Main Steam Piping System
 (Brief description of service for which equipment was designed)

6. Design Conditions 1300 psi 600 °F or Valve Pressure Class (1)
 (Pressure) (Temperature)

7. Cold Working Pressure 1500 psi at 100°F.

6. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
Body	SA 216, GR. WCB	Atwood & Morrill LTD	S/N 1-13839
HT #162			
RT #J1866			
(b) forgings			
Poppet	SA 105	Cann & Saul	S/N 1-13839
HT #216057			
Cover	SA 105	Cann & Saul	S/N 1-13839
HT #6016006			
Pilot Poppet	SA 182, GR. F-6	Cann & Saul	S/N 1-13839
HT #3034496			

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM NPV-1 (Back)

RIR 878

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting Cover Studs	SA 540, GR. B-23	Jos. Dyson & Sons	HT #114908 Code C-105A1
Cover Nuts	SA 540, GR. B-23	Jos. Dyson & Sons	HT #114908 Code C-87A
(d) Other Parts			

9. Hydrostatic test Shell 2250 psi.
Disc. 1300

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components. Section III, Div. I., Edition 1974
Addenda Summer 1975, Code Case No. N/A Date N/A
 (Date)
 Signed Atwood & Morrill Co., Inc. by *Walter F. Emerson QC Mgr 20 Apr 78*
 (Manufacturer)
 Our ASME Certificate of Authorization No. N1766 to use the N symbol expires 5/20/80
 (N) (NFV) (Date)

CERTIFICATION OF DESIGN

Design information on file at Westinghouse Electric Corp., Pittsburgh, PA
 Stress analysis report (Class 1 only) on file at N/A

Design specifications certified by (1) Henry P. Leonard
 PE State Penn. Reg. No. 23938-E
 Stress analysis certified by (1) N/A
 PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by H.S.B.I. & I. CO. of Hartford, CT have inspected the pump, or valve, described in this Data Report on April 21st 1978, and state that to the best of my knowledge and belief, the Manufacturer has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Apr. 1 25th 1978
John L. Lane

Commissioner
 B.C.I.B.

Mass. 1196
 (Nat'l Bd. State, Prov. and No.)



ATWOOD & MORRILL LTD.

manufacturers of large high-integrity steel castings

CANADA, C.J.L. INC.
(506)466-3000

BODY for 30"

Customer	Purchase Order No.	A&M Ltd. Sales No.
Atwood & Morrill Co., Inc.	6617	176-1107-74
Pattern No.	Serial No.	Part Name
16674	8	30" MSIV Body
Material Spec. & Grade	Heat No.	RT. No.
ASME SA216 WCB	162	
Nuclear Class	No. of pieces	DWG. No.
2	1	30148-007 H Rev. 1
Source Inspection		

MATERIAL TEST REPORT

HEAT NO.	C	Mn	Si	P	S	Cr	Ni	Mo	
162	.25 ✓	.76 ✓	.42 ✓	.026 ✓	.012 ✓				
Yield P.S.I.	Tensile P.S.I.	Elong. %		Red. of Area %		Brinnell Hardness			
46,907 ✓	75,515 ✓	31 ✓		61.3 ✓					

REMARKS: CHARPY V NOTCH IMPACT TEST

Test Temp. (°F)	Energy Absorption (Ft.-Lbs)	Lateral Expansion (In)	Shear Fracture (%)
60	38, 30, 40	.035, .027, .035	10

REPORT OF
CHEMICAL & PHYSICAL
ACCEPTED

BY

DE Sharp

DATE

9/19/77

ATWOOD & MORRILL CO. INC.

Quality Assurance

"I CERTIFY THE ABOVE INFORMATION IS CORRECT"

ATWOOD & MORRILL LTD.



9-1-77

BY

R. L. Lewis
METALLURGIST



DATE 10/14/77

BY N. Dulles O.A.

ATWOOD & MORRILL CO. INC.

EARL 4/3/78



ATWOOD & MORRILL LTD.

manufacturers of large high-integrity steel castings

INFORMATION ONLY
Ref. 13839-7

ST. STEPHEN, NEW BRUNSWICK

CANADA E3L 1M5
(506)466-3000

Customer	Purchase Order No.		A&M Ltd. Sales No.
Atwood & Morrill Co., Inc.	6617		176-1107-04
Pattern No.	Serial No.	Part Name	
16674	8	30" MSIV Body	
Material Spec. & Grade		Heat No.	RT. No.
ASME SA216 WCB		162	
Nuclear Class	No. of pieces	DWG. No.	
2	1	30148-007 H Rev. 1	
Source Inspection			

HEAT TREATMENT RECORD

PROCESS*	N	T
	4-1107-00	4-1107-00
PROCEDURE	3-23-77	3-23-77
DATE	6-5-77	6-5-77
FURNACE	1	1
CHARGE NO.	126	126
CHARGE TEMP.	70°F	200°F
TIME TO EQUIL. TEMP.	9 1/2 hrs.	8 1/2 hrs.
HOLDING TEMP. (RANGE)	1660 - 1685	1130 - 1165
TIME AT TEMP.	9 hrs.	8 hrs.
COOLING DATA	Air Cool to 400°F	Air Cool

REMARKS: _____

* ACTUAL HEAT TREAT CHARTS ARE RETAINED IN FILE FOR THE ABOVE.

- *N = Normalize or homogenize
- Q = Quench or harden
- T = Temper
- SA = Solution Anneal
- PWHT = Post Weld Heat Treat (Stress relieve)

PREPARED BY R. Lewis
ATWOOD & MORRILL LTD

TITLE Metallurgist

DATE September 1, 1977

FOR INFORMATION ONLY
A & M S/N 1-4

CA'N & SAUL STEEL CO.

ROYERSFORD, PA. 19468

Report of Physical Tests and/or Chemical Compositions

Date 3/21/78 REVISED REPORTS FROM REPORTS DATED 3/11/77
 Customer's Order No. Cann & Saul Order No.
 Customer ATWOOD & MORRILL CO., INC. AM-4837 39285
 Address 285 CANAL ST. REF.#13839-01-002
 SALEM, MASS. 01970

Attention PURCHASING DEPT.

CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB
216057	.27	.91	.014	.018	.17				

Lab. No.

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square In Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
FORGING	39285	1	.505	YS 8,700	43,500	16,400	83,000	34.0	.074	63.0 167/1
CHARPY IMPACTS "V" NOTCH			45 40 45 MILS LAT. 50 45 49 FT. LBS. 40 40 40 PERCENT SHEAR		EXP. @ +60°F					

OTHER TESTS

SONIC A388, REV. 23 (7/9/75) & ADD. FOR POPPETS (6/8/76) ACCEPTABLE
 MAG. PART. B&PV #15 (9/9/75) ACCEPTABLE HEAT TREAT. PROC. #5D(3/5/76) & ADD.
 WE CERTIFY THAT THE CONTENTS OF THIS REPORT ARE CORRECT AND ACCURATE AND THAT
 ALL OPERATIONS PERFORMED BY OUR COMPANY OR SUBCONTRACTORS ARE IN COMPLIANCE
 WITH MATERIALS SPECIFICATIONS AND THE ASME CODE, SECTION III JULY 1, 1974
 EDITION AND THROUGH AND INCLUDING 1975 SUMMER ADDENDA.

Customer's Specifications: ASME SA105	XK	36,000	YS.2%
CHARPY "V" IMPACT 25 MILS LAT. EXP. @ +60°F	T.	70,000	
	E.	22%	
B.H.N. 187 MAX.	R.	30%	

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

4 - POPPET FORGINGS PER DRAWING 30521-805D, REV. 1 ON DRAWING 21595-F, REV. 2

FORGINGS SERIALIZED #1,2,4 & 6

A & M

Inspection

Inspector



CANN & SAUL STEEL CO.

Eng. of Tests

*C. Bowers*Reviewed by H E A & E
5-25-75 AP 3/23/75

SHARON STEEL CORPORATION
METALLURGICAL TEST REPORT
CUSTOMER

FOR INFORMATION ONLY
September 10, 1978

Cann & Saul Steel Company

STREET ADDRESS	CITY & STATE	ZIP CODE
MILL ORDER	0785-28-3796-00	
CUST. ORDER	9843 A	
SIZE	26,000 x 26,000 x 167.00"	
DESCRIPTION	Semi-Finish C PQ	
SPECIFICATION	A-105 C 1029 M	
HEAT NO.	216057	
CARBON	.27	
MANGANESE	.91	
PHOSPHORUS	.014	
SULPHUR	.018	
SILICON	.17	
NICKEL	.07	
CHROMIUM	.10	
MOLYBDENUM	.01	
VANADIUM	nil	
COPPER	.18	
GRAIN SIZE	7-8	
MACRO		
JOMINY		
ROCKWELL		
BRINELL		
LSEN		
BEND		
YIELD PSI		
ULTIMATE PSI		
ELONGATION %		
REDUCTION AREA %		

88-3164

METALLURGIST



3-9-77

FOR CHIEF METALLURGIST
SHARON STEEL CORPORATION

SEP 10 1978

Elmer G. Myers

10/11/76 H.T. Proc. #5D(3/5/76) & Add.
 1550° F - 16 hrs. Quench in Water
 Atwood & Morrell Co., Inc.
 AM-4837
 4 - Poppet Forgings per Dwg. 30521-805D, Rev. 1 on Dwg.
 21595-F. Rev. 2

Forgings serialized #1, 2, 4 & 6
 Heat No. 216057


Gann & Saul Steel Co.

MCS
 Eng. of Test



3-9-77

AM-4835
 2 - Poppet Forgings per Dwg.
 D, Rev. 1 on Ref. Dwg. 21
 Rev. 2 for Code 30521-805D
 Forgings serialized #13



14008

MIDNIGHT

10/12/76 H.T. Proc. #5D(3/5/76) add.
1100°F - 16 Hrs. Cool slow in furnace
Atwood & Morrill Co. Inc.
AM-4837
4 - Poppet Forgings per Dwg. 30521-805D.
Rev. 1 on Dwg. 21595-F, Rev. 2.

Forgings serialized #1, 2, 4 & 6
Heat No. 2160571

Cann & Saul Steel Co.

~~MES~~ *[Signature]*
Eng. of Test

A&M
PCB
B

2-9-77

A&M 4836

2 - Poppet, Forgings per Dwg. 30521-8
D, Rev. 1 on Ref. Dwg. 21595-F,
Rev. 2 for Code 30521-805-2974
Forgings serialized #13 & 15



N 1008

CA-N & SAUL STEEL CO.

A&M S/N 1-4

ROYERSFORD, PA. 19468

Report of Physical Tests and/or Chemical Compositions

Date 1/27/78 REVISED REPORTS FROM REPORTS DATED 12/16/76

Customer ATWOOD & MORRILL CO., INC. AM-4837
Address 285 CANAL ST.
SALEM, MASS. 01970Customer's Order No.
REF. #13863-01-005(402)
#13839-01-005(204)Cann & Saul Order No.
39284

Attention PURCHASING DEPT.

RECEIVED

JAN 30 1978

ATWOOD & MORRILL

CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB
6016006	.30	1.05	.015	.020	.30				

Lab. No.

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square In Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
FORGING	39284	1	.505	YS 11,500	YS.2% 57,500	18,200	91,000	30.0	.068	66.0
CHARPY IMPACTS "V" NOTCH			47 46 52 56 30 30	48 MILS LAT. EXP. @ +60°F 56 FT. LBS. 30 PERCENT SHEAR					REPORT OF CHEMICAL & PHYSICAL ACCEPTED By <u>W. Francis</u> DATE 2-1-78 ATWOOD & MORRILL CO. INC. Quality Assurance	174/1

OTHER TESTS

SONIC A388, REV. 23 (7/9/75) + ADD. FOR COVERS (6/8/76) ACCEPTABLE
MAG. PART. B&PV #15 (9/9/75)

HEAT TREAT. PROC. #5D (3/5/76) & ADDENDUM

WE CERTIFY THAT THE CONTENTS OF THIS REPORT ARE CORRECT AND ACCURATE AND THAT
ALL OPERATIONS PERFORMED BY OUR COMPANY OR SUBCONTRACTORS ARE IN COMPLIANCE
WITH THE MATERIALS SPECIFICATION AND THE ASME CODE SECTION III, JULY 1, 1974
EDITION THROUGH AND INCLUDING 1975 SUMMER ADDENDA.

Customer's Specifications: ASME SA105 XXX 36,000 YS.2%

CHARPY "V" IMPACT 25 MILS LAT. EXP. @+60°F T. 70,000

22/35 CARBON E. 22% R. 30%

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

6 - COVER FORGINGS PER DWG. 30429-002-D, REV. 0 ON DRAWING 21714-F, REV. 0
FORGINGS SERIALIZED #1 THRU 6

A & M

Inspection

Inspector



CANN & SAUL STEEL CO.

C. Bemus
Eng. of Tests

A.M. Reviewed
2/2/78

Republic steel

	CONTROL CARD	REQ	JOB CONTRACT NO.
52552	052554		

PURCHASE ORDER DATE	PURCHASE ORDER NO		RELEASE		
03/17/75	98241				
DMS RATING	RENGO	CUSTOMER IDENTIFICATION		REPUBLIC ORDER NO	ITEM NO
				17-1108A-001328	
T E A M I L	M	OFFICE DIST	INVOICE DATE	INVOICE NUMBER	
	A	73	0	503-11398	
LE		ACCOUNT NUMBER	TERMS		
C		12564001	30-1/2-10		

**CERTIFICATE
OF TESTS**

SCANNIA SAUL STEEL CO
LROYERSFORD PA 19468

SHIP TO

DATE SHIPPED	FROM	ROUTE/VEHICLE IDENTIFICATION
11/17/65	SU 6430	WILSON FREIGHT

I HEREBY CERTIFY THAT THE MATERIAL LISTED HEREIN HAS BEEN INSPECTED AND
TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE GOVERNING
SPECIFICATIONS AND BASED UPON THE RESULTS OF SUCH INSPECTION AND TESTING
HAS BEEN APPROVED FOR CONFORMANCE TO THE SPECIFICATIONS

ITEM NO.	MATERIAL DESCRIPTION	%	QUANTITY SHIPPED
	SEMI FINISH CARBON GRADE-1029 MOD SI 15/30 FINE GRAIN FORGING Q NO GUAR SOUND CENTERS RAG PRODUCT DIAMOND SECTION UP TO 2-1/2 TO 3 IN OUT OF SQUARE		
04	23-7/8 X 23-7/8 X INGOT RUNOUT 2 PCS 5016006 3'2" x 3'7"	P	33530*
01	SEMI FINISH CARBON GRADE-1029 MOD SIL 15/30 FINE GRAIN FORGING Q 16 X 16 X INGOT RUNOUT 1 PCE 5016006 25'4"	P	22000*

1/2

R. Matijević

5/8-7

10/13/76 H.T. Proc. #66(8/15/75)
 1550°F - 11 Hrs. Quench in Water
 Atwood & Morrill Co., Inc.

AM-1635 G.E. 205-AF-779
 8 - Poppet Forgings per Dwg. 30521-604-D (No Rev.) for
 Code 30521-604-2974
 Forgings serialized #10 thru 17
 Heat No. 215217

Cann & Saul Steel Co.

M E Baltzmar
 Eng. of Test



12-13-76

10-13
1550

Heat Treat Proc. #SD(3/5/76)
 Atwood & Morrill Co., Inc.
 AM-4837 Ref. #13863-01-005(4) 13869-01-005(2)
 6 - Cover Forgings per Dwg. 30429-002-D, Rev. 0 on Dwg.
 21714-F, Rev. 0
 Forgings serialized #1 thru 6
 Heat No. 6016006

M E Baltzmar



12-14-76

5 AM

10/15/76 Heat Treat. Proc. #5D(3/5/76)
1100°F - 10 Hrs. Cool Slow in Furnace

Atwood & Morrill Co., Inc.

AM-4837 Ref. #13863-01-005(4) 13869-01-005(2)

6 - Cover forgings per Dwg. 30429-002-D, Rev. 0
on Dwg. 21714-F, Rev. 0

forgings serialized #1 thru 6
Heat No. 6016006

Cann & Saul Steel Co.

M. R. Battaglia
Eng. of Test

A&M
R.C.8
A

12-14-76

BN 14036 19

6 AM

12/15/76

1300

1400

1500

CH-N & SAUL STEEL FOR INFORMATION ONLY

ROYERSFORD PA 19468

Report of Physical Tests and/or Chemical Compositions

Customer Atwood & Morrill Co., Inc. Customer's Order No. AI-4837 Conn & Saul Order No. 39275
Address 235 Canal St. Ref. #13839-01-007(4)
 Salem, Mass. 01970 13863-01-007(2)

Attention Purchasing Dept. 1-31-77
 8571

CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	Ni	MO	CB
8034496	.112	.52	.016	.005	.12	11.85	.34		

Lab. No.

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square in Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
Forging	39275 1	.505	YS 14,400	YS .2% 72,000	18,800	94,000	26.0	.060	70.0	197/26
Charpy Impacts "V" Notch		/ / /	48 64 59 Mils Lat. Exp. @ -40°F 79 82 77 Ft. Lbs. 25 30 30 percent shear					CHEMICAL & PHYSICAL REPORT CHECKED by J. S. Francis		

OTHER TESTS

DATE 12-28-76

ATWOOD & MORRILL CO. INC.

Sonic A383, Rev. 23(7/9/75)

M.P. B&PV #15(9/9/75)

Heat Treat. Proc. #F-6B(8/25/75) and Addendum

We certify that the contents of this report are correct and accurate and that

all operations performed by our company or subcontractors are in compliance with materials specification and the ASME Code Section III, July 1, 1974 Ed. through including 1975 Summer addenda.

Customer's Specifications: ASME SA182, Gr. F-6

XW 55,000 YS .2%

Charpy "V" Impact 25 Mils Lat. Exp. @ -40°F

T. 85,000

Type 410 SS B.H.N. 223 Max.

E. 25%

R. 50%

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

6 - Pilot Poppet Forgings for Dwg. 24545-B, Rev. 1 for Code 15902-301-0097 Forgings serialized #1 thru 6

REVIEWED BY
 ANI *N.W.*
 DATE SEP. 19 1977
 HUBER CO.

A&M

H.F. Palmer
 Inspection
 N.C.P.A.
 Inspector
 12-14-76

CANN & SAUL STEEL CO.

M.E. Saltusovich
 Eng. of Tests

RepublicsteelFOR INFORMATION ONLY
Cleveland OH 44101

76

CONTROL CARD REQ. JOB NO. / CONTRACT NO.
057042PURCHASE ORDER DATE PURCHASE ORDER NO.
02/17/76 49571A

OMS RATING			RENEGOTIATED	CUSTOMER IDENTIFICATION	REPUBLIC ORDER NO.		
DISP	NUMBER	MFG	NO.	DISP	NUMBER	MFG	NO.
T	J1	A	2	OFFICE DIST	0542	INVOICE DATE	315- 206
E	A	I		ACCOUNT NUMBER	SU-1/2-1U	TERMS	
A	I	L		C	12564001		

**CERTIFICATE
OF TESTS**S CANN & SAUL STEEL CO
L ROVERS FORD, PA. 19468
D
T
ODATE SHIPPED FROM 97 CTN SOU ROUTE/VEHICLE IDENTIFICATION B&F
2/23/76I HEREBY CERTIFY THAT THE MATERIAL LISTED HEREIN HAS BEEN INSPECTED AND
TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE GOVERNING
SPECIFICATIONS AND BASED UPON THE RESULTS OF SUCH INSPECTION AND TESTING
HAS BEEN APPROVED FOR CONFORMANCE TO THE SPECIFICATIONS.

EDM

ITEM NO.	MATERIAL DESCRIPTION	%	QUANTITY SHIPPED
	H FIN BARS ENDURO STNL TYPE 410 FORGING Q ANN DISTRESSED MATL		
05	RDS 6-1/2 X 12 FT 10 IN 1 PC HT 8034496 #5 MND BB	C	1420*
	SHIPT COVD BY INV 315-202 TO 07 INC		

REISSUED 12/10-76 ADDING
NI & MOLY.B.C. HUGHES
DIVISIONAL CHIEF METALLURGISTBY R.L. King
R.L. KING, CONTROL TECHNICIAN

ANALYSIS	ITEM NO.	HEAT NO.	GRAIN	CARBON	MANG	PHOS	SUL	SIL	COPPER	NICKEL	CHROME	MOLY	VAN	CB
	5	8034496		.112	.52	.016	.005	.12		.34	11.85	.06		

TEST RESULTS	ITEM NO.	HEAT NUMBER	TEST OR PIECE IDENTITY NO.	YIELD PSI	TENSILE STRENGTH PSI	ELONG.	S. MPN. AREA	SECT. TEST	HARDNESS				
										Z	B	1	2

DEC 15 1976

Wd 9 5
H.T. Proc. #F-6B(8/2. 5) and Addendum

10/4/76

1760 F - 4 Hrs. Quench in Oil

Atwood & Morrill Co., Inc.

AM-4835

4 - Pilot Poppet Forgings per Dwg. 24545-B, Rev. 1

for Code 15902-052-0097

Forgings serialized #1 thru 4

Heat No. 72613

AM-4837

6 - Pilot Poppet Forgings for Dwg. 24545-B, Rev. 1 for Code

15902-301-0097

Forgings serialized #1-thru 6

Heat No. 8034496


Cann & Saul Steel Co.

M.S. Battman

Eng. of Test

ASME
R.C.B.
A

12-14-76



H.T. Proc. #F- 8/25/75 and Addendum
10/9/76
1300° F - 6 Hrs. Cool Slow in Furnace
Atwood & Morrill Co., Inc.

AM-4835

4 - Pilot Poppet Forgings per Dwg. 24545-B, Rev. 1
for Code 15902-052-0097
Forgings serialized #1 thru 4
Heat No. 72613

AM-4837

6 - Pilot Poppet Doegings for Dwg. 24545-B, Rev. 1 for Code
15902-301-0097
Forgings serialized #1 thru 6
Heat No. 8034496


Cann & Saul Steel Co.

M. S. Batterson

Eng. of Test

12-14-76

12-14-76



Feedwater Check Valve

CUSTOMER
Anchor/Darling Valve Co.
701 First Street
Williamsport, Pa. 17701

SHIP TO
Same

E5288-19

CUST. CODE 050

MARK FOR P.O.

PREPAID	COLLECT	XX	VIA	Truck	TERMS	Net 30 days		
CUSTOMER Anchor/Darling Valve Co. - Pa.				SHIP DATE	D.F. ORDER NO.			
QUANTITY	C.S.	PATTERN NO. 2561-5-4 (18" 900# TDC Disc)			CUSTOMER ORDER NO. P-2425			
WT. PER	MOLDS	Q/P NO. D-7491, Rev. C			UNIT WGT.	TOTAL WGT.	OPER.	
1	4				325	1300	24	
ORD. ENTERED 10/25/78				CUSTOMER SPECIFICATION SA216-WCB, VT-MSS-SP55 No weld - Nucl.		MATERIAL	M.T. CODE	ROUTING CODE
SALISBURY 04						Spec.	C10	128
OUTER Loudon CUST. REG. DEL.				INSTRUCTIONS (2) 3 copies T.R. & Docu., Subm. 4 rgh TB/heat (3) Melt & Lab use Melt Procedure MP 1.20, use 120 for gates, Charpy @40°F, 25 M.L.E., Arc air visual defects as per Dodge's no weld specification. No weld - Nucl. H.T. 2NET, H.T. chart req. PWHT 12 hrs. @1150°F		TEST BARS		5 K.B.
1/79								

CERTIFICATION OF CHEMICAL & PHYSICAL TESTS - HEAT TREATMENT - N.D.E. TESTS

BLAT NO.	4284	SERIAL NO.	75K-2461	SN-2464	QUANTITY IN HEAT	2	DATE POURRED	12/5/78		
CHEMICAL ANALYSIS - MAT. SPEC.				SA216-WCB						
C	MN	SI	P	S	CR	NI	MO	AL	CU	
.16	.91	.49	.022	.014	.32	.262	.15	.068	.10	
WELD METAL CHEMICAL ANALYSIS					WELDING PROCEDURE NUM.: R					
Filler Metal Spec.	Lot Number	C	MN	SI	CR	NI	MO	Welder's I.D.		
TENSILE PROPERTIES OF CASTING					HEAT TREATMENT					
T.S. P.S.I.	V.P. P.S.I.	V.S. P.S.I.	EL. %	R.A. %	HHN RANGE	TYPE	TEMP. °F	TOT HRS.	LOADING	
83,200	58,400		36%	640	179	HOMOGENIZE	1650°F	3 1/2	3163	
TENSILE PROPERTIES OF WELDING ELECTRODE					NORMALIZE 1600°F 3 1/2 3165 ✓					
T.S. P.S.I.	V.P. P.S.I.	V.S. P.S.I.	EL. %	R.A. %	HHN RANGE	TEMPER	1250°F	3 3/4	3004 ✓	
IMPACT TEST					WATER QUENCH					
TEMP. °F	1	2	3	Avg.	Specification	OIL QUENCH	H.T. Procedure 48.03, Rev. 1			
(I.F.T. LUS.)	68	79	71	73			is applicable			
(M.L.E.)	56	66	58	60	TYPE DEG. AGE No.		PWHT 161/1150°F 12			
J.SHEAR. %	50	70	60	60	RESULTS					
CORROSION TEST					Ferrite Content %	REPORTS ATTACHED				
SPEC.	TYPE	Measured by								
TEMP.	RESULTS					HEAT TREATMENT CHART				
N.D.E. SPECIFICATIONS			SET. NO.	APPRO	DATE	RT FILM & READER & SHOOTING SKETCH				
WT. PER	2461			OK	12/78	WELD REPAIR MAP				
MSS-SP55			2464			SNT-TC-IA CERTIFICATE				
WT-LPT PER	A/DV Cert 11/27/78					WELDING PROCEDURE - QUALIFICATION TEST				
RT PER	Review Date 1/15/79					WELDER'S QUALIFICATION TEST				

REMARKS:
Castings were manufactured in accordance
with A/DV SPI PUR-2, ASME Section III
1974 Edition and Winter 1975 Addenda
23801, 23805-C7
SEE ATTACHED REPORT
RAMBALL TESTLAB

We hereby certify that the above material has been
tested in accordance with the listed specifications
and conforms to all applicable requirements thereof.

Don. Yoder 1/3/79
Quality Assurance Date

DODGE FOUNDRY & MACHINE CO.
6501 STATE ROAD., PHILA., PA. 19135

4 ROUGH TEST BARS



BECHTEL
636

Ramball Testlab

6501 STATE ROAD - PHILADELPHIA, PA. 19135

(215) 332-4011

LABORATORY REPORT

Date: December 22, 1978
P.O.# M-2129Anchor/Darling Valve Co.
701 First Street
Williamsport, PA 17701Heat # 4310 PO# P-2425
Material: ASME-SA-216, WCBTENSILE TEST
Lab # 23936YIELD STRENGTH 46,300 psi
TENSILE STRENGTH 75,300 psi
ELONGATION 33 %
REDUCTION OF AREA 72 %0.505" diameter tensile
specimen, 2" gauge length.

CHARPY IMPACT TEST

LAB #	FOOT POUNDS	MILS EXPANSION	% SHEAR
23937	112	85	60
23938	86	72	60
23939	142	81	80
Average	113	79	67

1.0 cm x 1.0 cm Charpy Specimen.

The above test specimens were heat treated similar to production castings. The test bars only were given an additional stress relief heat treatment at 1150 degrees F for 15 hours. The Charpy V-Notch Impact Test was performed at +40 degrees F.

Metallurgist



66288-19

Anchor/Darling Valve Co. 701 First Street Williamsport, Pa. 17701				S H I P T O	Same
				CUST. CODE	050
PREPAID		COLLECT	XX	VIA	Truck
TERMS Net 30 days					
CUSTOMER Anchor/Darling Valve Co. - Pa.				SHIP DATE	O.R. ORDER NO.
QUANTITY 4	C.I.B. 2	PATTERN NO. 2561-5-1 (18" 900# TDC Body)		CUSTOMER ORDER NO. P-2425	
ITEM NO. 1	MULDS 4	S/P NO. F-4629		UNIT WGT. 2625	TOTAL WGT. 10500
ORD. ENTERED 10/25/78				CUSTOMER SPECIFICATION SA216-WCB, VT-MSS-SP55 No weld - Nucl.	
SALEMAN 04				MATERIAL Spec.	M.T. CODE C10
				ROUTING CODE 128	TEST BARS
BUYER Louden CUST. REC'D. DEL.				(2) 3 copies T.R. & Docu., Subm. 4 rjh TB/heat (8) Melt & Lab use Melt Procedure MP 1.20, use 120 for gates, Charpy @40°F, 25 M.L.E., Arc air visual defects as per Dodge's no weld specification, no weld - Nucl. H.T. 2N&T, H.T. chart req. PWHT 12 hrs. @1150°F, Min. wall 1.75	
1/79				5 K.3	

CERTIFICATION OF CHEMICAL & PHYSICAL TESTS - HEAT TREATMENT - N.D.E. TESTS

HEAT NO.	4310	SERIAL NO.	SW 2473 SX-2474	QUANTITY IN HEAT	2	DATE Poured	12/8/78							
CHEMICAL ANALYSIS - MAT. SPEC. SAZ10-WCB														
C	MN	SI	P	S	CH	Ni	Mn	AL	CU					
.16	.88	.37	.020	.015	.36	.26	.15	.037	.10					
WELD METAL CHEMICAL ANALYSIS								WELDING PROCEDURE NUMBER						
Filler Metal Spec.	Lot Number	C	MN	SI	CR	Ni	Mo	Welder's I.D.						
TENSILE PROPERTIES OF CASTING								HEAT TREATMENT						
T.S. P.S.I.	V.P. P.S.I.	Y.S. P.S.I.	E.L. %	R.A. %	BHN RANGE	TEMP				TEMP. I.Q.	TEST TYPE	QUENCH	CHART	
75,300	46,300		33%	72.0	156	HOMOGENIZE								
TENSILE PROPERTIES OF WELDING ELECTRODE								NO. 1 ALLOY				1650°F 4 1/2	3189	
T.S. P.S.I.	V.P. P.S.I.	Y.S. P.S.I.	E.L. %	R.A. %	BHN RANGE	NORMALIZE				1600°F 4 1/2	3191			
						TEMP. II				1250°F 4 3/4	3022			
IMPACT TEST								WATER QUENCH						
TEMP. 40°F	1	2	3	Avg.	Specification	OIL QUENCH								
(FT. LBS.)	112	86	142	113		H.T. Procedure 48.03, Rev. 1								
(M.L.E.)	85	72	81	79	TYPE REG. AVE. No.	IS applicable								
SHRINK %	60	60	80	67	RESULTS	PWHT TB 1150°F 12								
CORROSION TEST								REPORTS ATTACHED						
SPEC.	TVPL	TESTED Content						HEAT TREATMENT CHART						
TEMP.	RESULTS	Measured by						RT FILM & READER & SHOOTING SKETCH				RT		
N.D.E. SPECIFICATIONS				SER. NO.	APPROV.	DATE	WELD REPAIR MAP				RE			
WT PER	MSS-SP55	2473		OK	12/78		SNT-TG CERTIFICATE				RE			
SAT-LPT PLH				ANCHOR/DARLING VALVE CO.				WELDING PROCEDURE - QUALIFICATION TEST						
WT HR	L. B. SNYDER	2474					WELDING'S QUALIFICATION TEST							
	QA. 81	DATE: 12-12-79												

REMARKS:
Castings were manufactured in accordance
with A/DV SPI FUR-2, ASME Section III,
1974 Edition and Winter 1975 Addenda

SEE ATTACHED REPORT
RAMBELL TESTLAB

We hereby certify that the above material has been
tested in accordance with the listed specifications
and conforms to all applicable requirements thereof.

DODGE VALVE & MACHINE CO.
6601 STATE ROAD, PHILA., PA. 19135



Quality Assurance Date

4 ROUGH TESTBARS

CANN & SAUL STEEL CO.

ROYERSFORD PA 19468

Report of Physical Tests and/or Chemical Compositions

Date 2/14/78

Customer's Order No.

Cann & Saul Order No.
45667Customer ANCHOR/DARLING VALVE COMPANY N-1942
701 FIRST STREET S.O.#E-6288-19
Address WILLIAMSPORT, PA. 17701

Attention PURCHASING DEPT.

RECEIVED

FEB 17 1978

CHEMICAL COMPOSITIONS


HEAT NO.	C	MN	P	S	SI	CR	BL	H	Ni	Mo	CS
216394	.28	.77	.012	.021	.23						

Lab. No.

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square in Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
Forging	45667	1	.505	YS 12,100	YS .2% 60,500	20,000	100,000	25.0	.079	60.5
Charpy Impacts "V" Notch				28 31 29 Mils Lat. Exp. @ +40°F 28 30 28 Ft. Lbs. 10 10 10 percent shear						

OTHER TESTS



BRINELL 170/174

Heat Treat. Proc. 1007 (Rev. 1) (11/9/77)

We certify that the contents of this report are correct and accurate and that all operations performed by our company or subcontractors are in compliance with the materials specification and the ASME Code Section III '74 Ed. thru '75

Customer's Specifications: ASME SA105

XXX 36,000 YS 2% Winter Add

T. 70,000

E. 22%

R. 30%

Charpy "V" Impact 25 Mils Lat. Exp. @ +40°F

26/35 CARBON

B.H.N. 187 MAX.

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

4 - 18" 900 TDC BONNET FORGINGS FOR DRAWING D-7492

Forgings serialized #1 thru 4

A/DV

Inspection

CANN & SAUL STEEL CO.



Inspector

End of Test

Dechler
636

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
(As Required by the Provisions of the ASME Code, Section III, Div. 1)

1. Manufactured by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(Name and Address of Manufacturer)

2. Manufactured for Houston Lighting & Power Co., Electric Tower P.O. Box 1700, Houston, TX
(Name and Address of Purchaser or Owner)

3. Location of Installation Houston Lighting & Power Co., Matagorda County, Wadsworth, TX 77001
(Name and Address)

4. Pump or Valve Valve Nominal Inlet Size 18" Outlet Size 18"
(inches)

(a) Model No.. Series No. or Type	(b) Manufacturers' Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1) <u>Tilt Disc Ck.E-6288-19-5</u>	<u>N/A</u>	<u>93-14831 R/E</u>	<u>2</u>	<u>N/A</u>	<u>1979</u>	
(3)						
(4)						
(5)						
(6)						
(7)						
(8)						
(9)						
(10)						

5. 18" 900# PRESSURE SEAL TILT DISC CHECK

(Brief description of service for which equipment was designed)

6. Design Conditions 1285 psi 600 °F or Valve Pressure Class 900 (1)
(Pressure) (Temperature)

7. Cold Working Pressure 2160 psi at 100°F.

8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
BODY HT. # 4310 S/N R6226	SA216-WCB	DODGE FOUNDRY AND MACHINE CO.	
DISC HT. # 4284 S/N R5951	SA216-WCB	DODGE FOUNDRY AND MACHINE CO.	
(b) forgings			
BONNET HT. # 216394 S/N 3	SA105	CANN & SAUL STEEL CO.	
HINGE PIN COVER HT. # 81673	SA105	CANN & SAUL STEEL CO.	

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information items 1, 2 and 5 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

BECHTE
636



FORM NPV-1 (Back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting COVER STUDS HT. # 396344	SA193-B7	R.E.C. CORPORATION	
COVER NUTS HT. # 6020568	SA194-2H	NUTS, INCORPORATED	

9. Hydrostatic test 3250 psi

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this ~~pressure~~ valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. I, Edition 1974 Addenda Winter 1975, Code Case No. 1567, 1677 & 1744 Date 10-12-79
 Signed Anchor/Darling Valve Co. by H. Yoon
 Our ASME Certificate of Authorization No. N1712 to use the N symbol expires 4/15/80
 (Date)

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co. 701 First St., Williamsport, PA
 Stress analysis report (Class 1 only) on file at N/A


Design specifications certified by (1) James L. Hawks
 PE State Texas Reg. No. 37441
 Stress analysis certified by (1) N/A
 PE State _____ Reg. No. _____

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Pennsylvania and employed by Commercial Union Ins. Co. of Boston, Mass. have inspected the ~~pressure~~ valve, described in this Data Report on 2-22-78 th 10-13-79 and state that to the best of my knowledge and belief, the Manufacturer has constructed this ~~pressure~~ valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.


 Russell E. Montgomery
 Commissions Pennsylvania WC972
 (Natl Bd., State, Prov. and No.)


 BECHTEL
 636


 BECHTEL
 636

Feedwater Isolation Valve

FORM NPF-1 IN CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

As Required by the Provisions of the ASME Code, Section III, Div. 1

S/O 10788

1. Manufactured by	W-K-M Div., ACF Ind. Inc., 16500 S. Main, Missouri City, Texas (Name and Address of Certificate Holder)					
2. Manufactured for	Houston Lighting & Power, P.O. Box 308, Bay City, Texas 77414 (Name and Address of Purchaser or Owner)					
3. Location of Installation	South Texas Project, HL&P Co., Matagorda County, FM 521 (Name and Address)					
4. Pump or Valve	Valve	Nominal Inlet Size	18 (inch)	Outlet Size	18 (inch)	
		(a) Model No.	(b) N Certificate Holder's	(c) Canadian		
Series No. or Type	Serial No.	Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1) Gate Valve	536740	N/A	RS259313	2	1996	1983
(2)						
(3)						
(4)						
(5)						
(6)						
(7)						
(8)						
(9)						
(10)						

5. Feedwater Isolation

(Brief description of service for which equipment was designed)

Tag: 1-S13-FV-7143

6. Design Conditions 1285 psi 600 °F or Valve Pressure Class 900 (1)
(Pressure) (Temperature)
7. Cold Working Pressure 2250 psi at 100°F.
8. Pressure Retaining Pieces

Mark No	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
Bdy Cntr Sec.	SA216, WCC	PRL Ind.	Heat 1648(K1141)
(b) forgings			
Bdy Upr Sec	SA-350, LF2	Energy Prod.	Heat 217990-5
Bdy Lwr Sec	SA-350, LF2	Energy Prod.	Heat 217089-4
Bonnet	SA-350, LF2	Coulter Steel	Heat 722248-7

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

BECHTEL

489

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Studs	SA-193, B7	R.E.C. Corp.	Heat 54615
Nuts	SA-194, 2H	R.E.C. Corp.	Heat Y731961
(d) Other Parts			
Gate	SA-487, CA6NM	PRL Ind. Inc.	Heat 2640 (K1108)
Segment	SA-487, CA6NM	PRL Ind. Inc.	Heat 568 (K1105)

9. Hydrostatic test 3375 psi. Disk Differential test pressure 2200 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. I, Edition 1974, Addenda Winter '75, Code Case No. 1781, Date February 27, 1984

(Date)

Signed W-K-M Div., ACF Ind. Inc.

(N Certificate Holder)

by John B. Hasty

Our ASME Certificate of Authorization No. N-1942 to use the N symbol expires 11-18-83.

(Expiration date extended to 5-18-84)

CERTIFICATION OF DESIGN

Design information on file at W-K-M Division, ACF Ind. Inc.

Stress analysis report (Class T only) on file at N/A

Design specifications certified by (1) James L. Hawks

PE State Texas Reg. No. 37441

Stress analysis certified by (1) N/A

PE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by H.S.B. I&I Co. of Connecticut have inspected the pump, or valve, described in this Data Report on 3-19 1984, and state that to the best of my knowledge and belief, the N Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 3-19 1984

D.L. Freeman
(Inspector)

Commissions NB 4893

(Nat'l Bd., State, Prov. and No.)

PECHT
489

CHEMICAL ANALYSIS & MECHANICAL TEST REPORT

DATE: 10/26/83

MATERIAL
SPECIFICATIONS

3277

METCAST:

MIL

FEDERAL:

ASTM - A

ASME SA

487-75-GR CA 6 NM

COML:

M E T C A S T401 Worthington Ave. Harrison, New Jersey 07029
(201) 482-5700

Metcast Order MII 501743

TO: PRL Industries

Customer Order 5521

Cornwall, PA 17016

Pattern No. 264811 Rev. N390

Name of Part 16" Gate

CHEMICAL ANALYSIS

LINE	QTY.	PATTERN No.	HEAT No.	SER. No.	C	S	P	SI	MN	CR	NI	MO	CU	CB	V	W	SB	FE
1	1	REV. N390 264811	2640		.04	.013	.029	.60	.51	12.60	3.93	.57			.013			
2																		
3		CHECKED																
4																		
5		23 Feb-74																
		UOTN																

TEST BARS-- NORM. 1900°F 2HRS. AC TEM. 1125°F 2HRS. AC
TEM. 1250°F 2HRS. AC

MECHANICAL TEST

LINE	Yield PSI	Tensile PSI	% Elong.	% Red. of Area	Hardness BHN	Weld Test	Weld Bend Test	Macro. Etch	REMARKS				
1	87,000	112,500	22	56					CHARPY V NOTCH IMPACT TEST - TEST TEMP. + 40°F	IMPACT VALUE	LATERAL EXPANSION	% SHEAR	
2									1113.78		R		
3									Q	P	I		
4									LA	2	P		
5									MAI	K1108	#		

We certify this is a true copy of the original test report now on file.

12092

J. Bremer

CHEMICAL ANALYSIS & MECHANICAL TEST REPORT

DATE: 11/13/78

MATERIAL
SPECIFICATIONS

3277

METCAST

401 Worthington Ave. Harrison, New Jersey 07029
(201) 402-5700

Metcast Order NH 501744
Customer Order 5520
Pattern No. 264809 Rev. N390
Name of Part 16" Segment

TO: PRL Industries, Inc.

P.O. Box 142
Cornwall, PA 17016

METCAST:
MIL
FEDERAL:
ASTM - A
ASME SA 487 75 CA 6 NM
COML.:

CHEMICAL ANALYSIS

QTY.	PATTERN No.	HEAT No.	SER. No.	C	S	P	SI	MN	CR	NI	MO	CU	CB	V	W	SB	FE
5	Rev. N390 264809	568	S 4 S 8	.06	.020	.028	.46	.49	12.30	3.91	.60			.010			

CHECKED

OK

2320079

TEST BARS-- NORM. 1925° F, TEM. 1250° F, TEM. 1125° F

MECHANICAL TEST

Yield PSI	Tensile PSI	% Elong.	% Red. of Area	Hardness BHN	Weld Test	Weld Bend Test	Macro. Etch		REMARKS					
82,000	110,500	22	56	241					CHARPY V NOTCH TEST - TEST TEMP.+ 40°F					
									IMPACT VALUE	LATERAL EXPANSION	% SHEAR			
									71 Ft. Lbs.	54 Mils	50 %			

11/13/78 K1102 A/P 2 K1103 K1104 K1105 K1106

MAL

BECHTEL

532

I certify this is a true copy of the original test report now on file.

J. Brechler

Metallurgist

Segment



Forged Products Division

6505 N. HOUSTON-ROSSLYN ROAD

HOUSTON, TEXAS 77091

GULF-WESTERN MANUFACTURING COMPANY

~~FOR INFORMATION ONLY~~ SECTION
CERTIFIED TEST REPORT

NUCLEAR

P4.7

SOLD TO
VACA VALVE
P.O. BOX 2117
HOUSTON, TEXAS 77007

SHIPPED TO
SAME
MISSOURI CITY, TEXAS

DATE SHIPPED

11/20/78

CUSTOMER'S ORDER NO

95206

SHIPPED VIA

 COLLECT
 PREPAID

P/C

BOTT LOWER SECTION

QTY	JOB #	PC #	HEAT CODE	DESCRIPTION			
					COLLECT	PREPAID	
2	29423	I-2	217089	ROUGH MACHINED TO FINISH: HEMI-HEAD PER F.P. DIV. J/O 29423 MATERIAL: A350 LF2 NORMALIZED, QUENCHED & TEMPERED PART NO.: 265658 S/O 10788 & 10790 MATERIAL MANUFACTURED IN ACCORDANCE WITH ASME SECT. II & III 1974 EDITION THRU AND INCLUDING 1975 SUMMER ADDENDA, CLASS 2 MATERIAL TO COMPLY WITH NA-3700 CHEM. & MECHANICAL TESTING PER SPECIFICATION SA350 LF-2, WITH IMPACT REQUIREMENTS PER NC-2300 & 2331 @+40°F WITH 25 MILS LATERAL EXPANSION MINIMUM. N.R.C. REGULATION 10 CFR PART 21 APPLIES TO THIS ORDER.			

RIP#2912

CHECKED
 OK
 BY 6
 11-30-78

CHEMICAL ANALYSIS										
HEAT NO	MILL SOURCE	C	MN	PHOS	SUL	SIL	NI	CR	CU	MO
217089	SHARON	.29	.02	.013	.015	.21				
CHEM. ANAL.		.30	.02	.009	.016	.19				

PHYSICAL PROPERTIES										
YIELD STRENGTH (PSI)	TENSILE STRENGTH (PSI)	% ELONG.	RED OF AREA %	HARDNESS	TYPE CHARPY	TEMP °F	ABSRB ENERGY FT /LBS	LATERAL EXP. (MILS)	\$ SHEAR	
56,000	81,500	31.8	68.8	156-179	V-NOTCH	-40	136.0-108.0-156.0	.066	80	
								.071	70	
								.090	100	

MISCELLANEOUS TESTING

TYPE OF TEST	<u>BECHTEL</u>	G/S
	480	

I SWEAR AND SWEAR TO BEFORE ME

20th DAY OF NOVEMBER 19 78

Monna M. Hendon B. J. Ferneyhough P. J. Kennedy

Notary Public in Harris County, Texas

My Commission Expires June 19, 1980

I CERTIFY THAT THIS IS A TRUE COPY OF ORIGINAL TEST SHEET NOW ON FILE AT THE OFFICE OF FORGED PRODUCTS, INC. AND THAT THIS STEEL WAS MANUFACTURED AND FORGED IN THE UNITED STATES OF AMERICA

QUALITY ASSURANCE

COULTER STEEL & FORGE COMPANY
Special Metals in Bars and Forgings

 MAILING ADDRESS P.O. BOX 8008
 1314 - 67TH STREET EMERYVILLE CALIFORNIA 94662
 415 - 653-2512 TELEX 33-6406 TWX 910-366-7293

 1228 RIO VISTA AVENUE 334 WEST 8TH SOUTH 2715 6TH AVENUE SOUTH
 LOS ANGELES CALIF 90023 SALT LAKE CITY UTAH 84101 SEATTLE WASH 98134
 TELEX 67-7340 TELEX 38-8330 WESTERN UNION FAX
 PHONE 213-261-6115 PHONE 801-322-3533 PHONE 206-622-6086

48913


A C F INDUSTRIES, INCORPORATED
 W-K-M Valve Division
 P.O. Box 2117
 Houston, Texas 77001

CUSTOMER ACCT NO

418244

INV REQD SPEC CLAUS

TAXABLE NON-TAXABLE

X

CALL OUR TRUCK

95130

24 JAN 78

PREPAY COLLECT

VIA X

DATE SHIPPED

PARTIAL COMPLETE

METALLURGICAL REPORT
BONNET

Item No.	Heat No. or Ident.	C	Mn.	P.	S.	Si.	Cr.	Ni	Mo	G.S
	722248	.21	1.18	.015	.016	.23	.15	.10	.05	
										V
										.029

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS)

NUMBER N-1189

EXPIRATION DATE OF CERTIFICATE 8-4-78

Item No.	Hardness of Material Supplied	Tensile	Yield -% Offset	EI.	R.A.	BNH.	Size of Raw Stock	M
		72,900	53,900	36	76.0	156	13-1/2"	
	Charpy V-Notch +40°F:	ft-lbs	lat. exp. %shear				RCS : AR'100	
	83	.071	61				Avg. Freq/Avg. Sev	
	106	.074	65				.051 .032	
	52.5	.044	38					

HT: Nom 1750°F + 25°F 2 hours A.C.

1st Aust. 1750°F + 25°F 5 hours W.Q.

2nd Aust 1575°F + 25°F 5 hours W.Q.

1st Temper 1250°F + 25°F 12 hours W.Q.

2nd Temper 1250°F + 25°F 12 hours W.Q.

Forged CARBON STEEL, Liquid Quenched & Tempered; in accord with SA-350, Grade LF2, except CVN Impact Tests 25 Hils Lateral Expansion at PLUS 40°F in lieu of MINUS 50. ASME Boiler & Pressure Vessel Code Sections II & III, Class 2, 1974 with Addenda thru Winter 1975 applies.

8 PCS: DWG C264021 with 20-3/16"OD

AS FORGED: +3/4", -0 & HUB MACHINED TO DWG

CHECKED

DK

5-1-78

DW

0

RIP #2912

 BECHTEL
480

We certify that the contents of this report are correct and accurate, and that all operations performed by us and our subcontractors are in compliance with the requirements of all specifications listed in the material description.

We certify that the material described herein has been inspected and/or tested for conformance to the applicable specifications. Our warranty of quality provides for replacement only of any part of this material which subsequent inspection, test or use shows non-conformance with the specification. Inspection records, certifications, chemical and/or physical test reports are on file for your examination at EMERYVILLE, CALIFORNIA.

COULTER STEEL & FORGE COMPANY

 By *Frank Reina*

MGR. QUALITY CONTROL

MARKING AND PACKAGING REQUIREMENTS

 CSP STD PLUS SA 350, Gr. LF1
 +40

METALLURGICAL REPORT REQUIREMENTS		
NOTARIZE	W/SHIPMENT	W/B LADING
MAIL - 2 COPIES TO		
V. Kucera		



Forged Products Division

6505 N. HOUSTON-ROSSLYN ROAD
HOUSTON, TEXAS 77091
GULF-WESTERN MANUFACTURING COMPANY

CERTIFIED TEST REPORT

P4.7

SOLD TO
WFM VALVE DIVISION
P.O. BOX 2117
HOUSTON, TEXAS 77001

SHIPPED TO
SAME
MISSOURI CITY, TEXAS

~~READY FOR SHIPMENT SECTION 1~~

DATE SHIPPED	CUSTOMER'S ORDER NO.	SHIPPED VIA	COLLECT PREPAID		
QTY.	JOB #	PC #	HEAT CODE	DESCRIPTION	P/C
8 ✓	29417	1-8	217990	ROUGH MACHINED TO FINISH: 31"OD X 19"ID X 18"LG MATERIAL: A350 LF2 ASME SEC. III CL. 2 PART NO.: 285656 S/O 10788/10790 ITEM 1 MATERIAL MANUFACTURED PER ASME SECT. III CLASS 2, 1974 EDITION THRU AND INCLUDING ADDENDA THROUGH WINTER 1975. MATERIAL IS IN COMPLIANCE WITH NA 3700, NC-2300 & 2311, NC 2130 & 2150 OF THE ASME NUCLEAR CODE. NRC REGULATION 10CFR PART 21 APPLIES. MATERIAL IS IN NORMALIZED AND TEMPERED CONDITIONS.	1
				W.M. DIV. OF NUC. IND., INC. 112-10790	

NOTE:
 THIS DOCUMENT CONTAINS EXCLUSIVELY FRAUDULENT STATEMENTS AND THIS DOCUMENT MAY BE
 HELD AS A FRAUDULENT DOCUMENT BY ANY GOVERNMENTAL
 OR PRIVATE ENTITY THAT RECEIVES IT.

RIP#2912

CHEMICAL ANALYSIS								
HEAT NO.	MILL SOURCE	C	MN	PHOS	SUL	SIL	NI	CR
1 217990	SHARON	.27	1.17	.009	.022	.27		
2 CHECK ANALYSIS		.29	1.30	.011	.028	.30		
3								

CHECKED
OK
7-26-78
W

PHYSICAL PROPERTIES								
YIELD STRENGTH (PSI)	TENSILE STRENGTH (PSI)	% ELONG	RED OF AREA %	HARDNESS	TYPE CHARPY	TEMP °F	ABSRB ENERGY FT-LBS	LATERAL EXP. (MILS)
1 51,400 ✓	82,000	32.7	59.6	143-149	V-NOTCH	-10°	58.0-60.0-56.0	34.0
2								38.0
3								33.0

MISCELLANEOUS TESTING		G/S
TYPE OF TEST		
1		
2		

SUBSCRIBED AND SWEARN TO BEFORE ME

THIS 17 DAY OF July 1978

I CERTIFY THAT THIS IS A TRUE COPY OF ORIGINAL TEST SHEET NOW ON FILE AT
 THE OFFICE OF FORGED PRODUCTS, INC., AND THAT THIS
 MANUFACTURED AND FORGED IN THE UNITED STATES OF AMERICA.

Monna M. Hendon
 Notary Public in Harris County, Texas
 My Commission Expires June 19, 1980

Edward J. Bak
 Quality Assurance

489

BECHTEL

P4.7

**LINDBERG/COOK
HEAT TREATING
COMPANY**


Division of

**LINDBERG
CORPORATION**

P. O. BOX 24147 • HOUSTON, TEXAS 77029 • 713/672-6601

CERTIFICATION OF HEAT TREATMENT

FORGED PRODUCTS

TO THE BEST OF OUR KNOWLEDGE THE INFORMATION CONTAINED
HEREIN IS TRUE AND CORRECT. WE HEREBY CERTIFY THAT THE
PARTS DESCRIBED WERE TREATED AS STATED.

WE HEREBY CERTIFY THAT THE PARTS DESCRIBED WERE GIVEN THE FOLLOWING HEAT TREATMENT


		TIME AT HEAT	COOLANT
ANNEALED	°F		
NORMALIZED	1675 °F	8HRS	AIR
QUENCHED	°F		
DRAWN	1175 °F	10HRS	AIR
NITRIDED	°F		
STRESS RELIEVED	°F		

HARDNESS TEST	143-149 BHN	% OF PCS. TESTED	50%
---------------	-------------	------------------	-----

We further certify that heat treatment described above is true and correct and that temperatures and test results were obtained with standard approved methods.

Subscribed and sworn to before me this


24TH day of MAY, 19 78


 Notary Public
in and for the County of Harris, State of Texas

8/31/78

My Commission Expires _____

LINDBERG COOK HEAT TREATING COMPANY



STEVE COOK

ASST. PLANT SUPERINTENDENT

 BECHTEL
592

Customer, P.O. 37012				TO	PA 2	K 1141	P4.7
		490	MAIL FOR P.O.		MAIL		
PREPAID	COLLECT	XX	VIA	TRUCK	TERMS		
Customer PRL Industries, Inc.				SHIP DATE	Net 30 days		
STOCK	C.R.	PATTERN NO.		CUST. ORDER NO.		D.P. ORDER NO.	
8	3	254308 (18" x 16" 900# Body)		5519		See Below 8-05701	
ITEM	QUANTITY	UNIT WGT.		TOTAL WGT.		QTY.	
1	A	E-263187 Rev. N492 (WKM)		3500#	28000	28	
DATE ENTERED		CUSTOMER SPECIFICATION		MATERIAL	H.T. CODE	ROUTING CODE	
5/26/78		ASME SA216 WCC		Spec.	C10	128	
SALESMAN	04					TEST CARD	
BUYER		INSTRUCTIONS				5 Z.B.	
Zimmerman		(2) H.T. charts - Charpy 25 MIL @ 400°F, 4 TB/ht. (3) Melt & Lab use MP 120, no weld, Ni Integ. spec. H.T. charts req. Submit 4 rgh tb/heat HSS-SP55 Submit sample					
		Upon approval of sample will advise delivery					
RIP#2912							

CERTIFICATION OF CHEMICAL & PHYSICAL TESTS-HEAT TREATMENT-N.D.E. TESTS

HEAT # 1648 SERIAL NO.: TN-1811 QUANTITY IN HEAT 1 DATE POURRED 9/22/78

CHEMICAL ANALYSIS-MAT. SPEC

C	MN	SI	P	D's	CR	Ni	Mo				
.16	.85	.38	.020	.015	.28	.29	.16				

WE METAL CHEMICAL ANALYSIS

WELDING PROCEDURE NUMBER

Met Spec.	Lot Number	C	MN	SI	CR	Ni	Mo		Welders I.D.

TENSILE PROPERTIES OF CASTING

T.S. P.S.I.	Y.P. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	Ferrite Content %	Measured By
70,700	50,500	347.	640	156			

TENSILE PROPERTIES OF WELDING ELECTRODE

HEAT TREATMENT

T.S. P.S.I.	Y.P. P.S.I.	Y.S. P.S.I.	EL. %	R.A. %	BHN RANGE	TYPE	TEMP. F	TOT. HRS.	LOAD NO.	CHART ATT.
						HOMOGENIZED				
						NORMALIZE	1650°F	6 1/2	2881	✓
						NORMALIZE	1600°F	6 3/4	2883	✓

IMPACT TEST

BEND TEST

TEMP. °F	1	2	3	AVG.	Specification	WATER QUENCH
FT.-LBS.	77	64	64	69		OIL QUENCH
(M.L.E.)	65	60	64	63	Degrees	STRESS RELIEVE
HEAR-%	80	7	70	73	Age	ANNEAL

CORROSION TEST

REMARKS

TYPE	RESULTS	REMARKS
		21958 2195739

NON-DESTRUCTIVE TESTS AND RELEASE REPORT

N.D.E. SPECIFICATIONS		SER. NO.	APP'D.	DATE	REPORTS ATTACHED
VT PER		1811	OK	8/78	VT-V.I.R.
MT-L. PER	1755-SP55				DIMENSIONAL LAYOUT
RT PER			BECHTEL		DIMENSIONAL CONFORMANCE CERT.
UT PER			592		MT-LPT WELD REPAIR MAP
					SNT-TC-1A CERTIFICATES
					RT WELD REPAIR MAP
					WELDING PROCEDURE
					WELDERS QUALIFICATION TEST