

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power Corporation
Crystal River Unit 3

Docket No. 50-302
License No. DPR-72

The following violation was identified during an inspection conducted on October 27 - November 9, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

Technical Specification 4.11.2.1.2 requires in Table 4.11-2 that a release from the Auxiliary Building and Fuel Handling Area Exhaust Monitor (RMA-A2) be analyzed for dose rate between 2 to 6 hours after a change in power level that exceeds 15% of rated thermal power in one hour.

Contrary to the above:

On November 2, 1984, a power level change in excess of 15% rated thermal power occurred in one hour at 11:00 p.m. and the RMA-A2 sample was not taken and analyzed until 5:41 p.m. on November 3, 1984.

This violation is similar to a violation described in Licensee Event Report 84-17. This previous violation was not cited in a Notice of Violation in accordance with 10 CFR 2 Appendix C Criteria.

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: DEC 3 1 1984