

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

February 27, 1985
5211-85-2034

Office of Nuclear Reactor Regulation
Attn: J. F. Stolz, Chief
Operating Reactor Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Stolz:


Three Mile Island Nuclear Station Unit 1 (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Post Eddy Current Inspection Report

Following the completion of the Eddy Current Inspection of TMI-1 A and B Steam Generator tubes, Technical Specification 4.19.5a requires a report to be submitted of the number of tubes repaired or removed from service.

No tubes were repaired by the kinetic expansion process in either steam generator. In Steam Generator A, 93 tubes were removed from service for a total number of tubes removed from service since fabrication of 1009. In Steam Generator B, 10 tubes were removed from service for a total number of tubes removed from service since fabrication of 300. Tube plugging was completed on February 16, 1985. The criteria used by GPUN to determine which tubes should be removed from service is contained in the GPUN submittal of January 31, 1985, letter no. 5211-85-2023.

Assuming approval of the January 31st submittal and consequently no additional tubes removed from service, this letter will fulfill the requirement of T.S. 4.19.5a.

Sincerely,


H. D. Hukill
Director, TMI-1

8503050242 850227
PDR ADOCK 05000289
G PDR

HDH/SMO/spb

cc: R. Conte
T. Murley
H. Silver

A001
1/0