

CONTAINMENT SYSTEMSPRIMARY CONTAINMENT AIR LOCKSLIMITING CONDITION FOR OPERATION

3.6.1.3 The primary containment air lock shall be OPERABLE with:

- a. Both doors closed except when the air lock is being used for normal transit entry and exit through the containment, then at least one air lock door shall be closed, and
- b. An overall air lock leakage rate of less than or equal to $0.05 L_a$ at P_a , 49 psig.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2* and 3.

ACTION:

- a. With either one primary containment air lock door inoperable or the primary containment air lock door interlock inoperable:
 1. Maintain at least the OPERABLE air lock door closed and either restore the inoperable air lock door/air lock door interlock to OPERABLE status within 24 hours or lock the OPERABLE air lock door closed.
 2. Operation may then continue until performance of the next required overall air lock leakage test provided that the OPERABLE air lock door is verified to be locked closed at least once per 31 days.
 3. Otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
 4. The provisions of Specification 3.0.4 are not applicable.
- b. With the primary containment air lock inoperable, except as a result of an inoperable air lock door or an inoperable air lock door interlock, maintain at least one air lock door closed; restore the inoperable air lock to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

8503050317 850227
PDR ADOCK 05000324
P PDR

* See Special Test Exception 3.10.1.

CONTAINMENT SYSTEMSPRIMARY CONTAINMENT AIR LOCKSLIMITING CONDITION FOR OPERATION

3.6.1.3 The primary containment air lock shall be OPERABLE with:

- a. Both doors closed except when the air lock is being used for normal transit entry and exit through the containment, then at least one air lock door shall be closed, and
- b. An overall air lock leakage rate of less than or equal to $0.05 L_a$ at P_a , 49 psig.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2* and 3.

ACTION:

- a. With either one primary containment air lock door inoperable or the primary containment air lock door interlock inoperable:
 1. Maintain at least the OPERABLE air lock door closed and either restore the inoperable air lock door/air lock door interlock to OPERABLE status within 24 hours or lock the OPERABLE air lock door closed.
 2. Operation may then continue until performance of the next required overall air lock leakage test provided that the OPERABLE air lock door is verified to be locked closed at least once per 31 days.
 3. Otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
 4. The provisions of Specification 3.0.4 are not applicable.
- b. With the primary containment air lock inoperable, except as a result of an inoperable air lock door or an inoperable air lock door interlock, maintain at least one air lock door closed; restore the inoperable air lock to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

* See Special Test Exception 3.10.1.