

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER

February 15, 1985

RECEIVED
NRC

FEB 25 AM 10 17

SECURITY

SCE

TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - January 1985
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, J. G. Haynes (SCE) to J. B. Martin (NRC),
dated January 15, 1985

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in January 1985.

Fire doors found inoperable during the January routine surveillances are identified in the Attachment and include: 15 latching mechanism failures; 3 closure mechanism failures; and 5 doors blocked open typically for construction or maintenance activities. An investigation was conducted to determine the person or persons responsible for the blocked open fire doors, but the investigation was unsuccessful in identifying the responsible party. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established. We also are continuing the corrective actions to upgrade door latches and closure mechanisms.

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in February 1985 will be submitted by March 20, 1985.

8503050381 850215
PDR ADOCK 05000361
S PDR

1/1 IE-28

Mr. J. B. Martin

-2-

If you require any additional information, please so advise.

Sincerely,

J. G. Hayes

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 15, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-219	1/07	-----
AC-305	1/12	1/13
AC-314	1/30	-----
AC-340	1/29	-----
AC-345	1/03	1/14
AC-415	1/06	1/07
AC-442	1/21	1/29
AR-101	1/01	1/18
AR-504	1/01	-----
AR-104	1/03	1/12
AR-314	1/16	1/18
C3-405	1/09	1/10
FH2-101	1/12	1/17
FH2-403	1/ 6	1/07
FH2-403	1/16	1/17
FH3-302	1/10	1/17

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 3, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-127	1/16	1/18
FH3-302	1/06	1/07
FH3-302	1/20	1/22

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

III. Doors Blocked Open:

Number of doors inoperable - 5, as follows:

<u>Door Number</u>	<u>Date Found Inoperable (fire watches established within one hour)</u>
AC-125	1/14
AC-239	1/13
AC-303	1/14
AR-204	1/01
C2-405	1/16