



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 409 838 6631

February 15, 1985
RBG- 20,162
File Nos. G9.5, G9.19.2,
G9.20.8

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

River Bend Station - Unit 1
Docket No. 50-458

To assist the Nuclear Regulatory Commission's (NRC) Equipment Qualification Branch (EQB) reviewer in developing Section 3.11 of the River Bend Station (RBS) Safety Evaluation Report (SER) and to address in part SER Open Item No. (5), changes to the RBS Environmental Qualification Document (EQD) are enclosed (Attachment 1). Revised System Component Evaluation Worksheets (SCEWs) and temperature and pressure profiles are provided in Attachment 2. Several of these changes address questions from the January 29-31, 1985 NRC Environmental Qualification Audit. The enclosed revisions to the EQD will be included in a future amendment.

In accordance with 10CFR50.49(4) Gulf States Utilities Company (GSU) is providing justification for interim operation (JIO's) for Class 1E electrical components located in a harsh environment for which qualification is not complete (Attachment 3). As a result of recent analyses and tests, further review is required on a few electrical components. The EQB reviewer will be appraised on the status of these reviews by February 28, 1985.

On September 10, 1984 GSU submitted it's master list for safety-related mechanical equipment located in a harsh environment as requested in SER Section 3.11.3(6). Representative mechanical equipment qualification (MEQ) packages were provided to the NRC reviewer on January 11, 1985.

Sincerely,

fr J. E. Booker
Manager-Engineering
Nuclear Fuels & Licensing
River Bend Nuclear Group

8503060512 850215
PDR ADOCK 05000458
E PDR

A049
1/40

JEB
JEB/RJK/je

Attachments

ATTACHMENT 1

REVISED ENVIRONMENTAL
QUALIFICATION DOCUMENT TEXT

RBS EQD

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1	INTRODUCTION	1-1
2	ENVIRONMENTAL CONDITIONS	2-1
2.1	TEMPERATURE, PRESSURE, HUMIDITY ENVIRONMENT	2.1-1
2.2	RADIATION ENVIRONMENT	2.2-1
2.3	CHEMICAL ENVIRONMENT	2.3-1
2.4	SUBMERGENCE	2.4-1
3	FUNCTIONAL PERFORMANCE REQUIREMENTS	3.1-1
3.1	ACCIDENT/SYSTEM MATRIX	3.1-1
3.2	POST-ACCIDENT OPERABILITY TIME	3.2-1
4	QUALIFICATION METHODOLOGY	4.1-1
4.1	HARSH ENVIRONMENT	4.1-1
4.1.1	BOP Equipment	4.1-1
4.1.1.1	Electrical	4.1-1
4.1.1.2	Mechanical	4.1-4
4.1.2	NSSS Equipment	4.1-6
4.1.2.1	Electrical	4.1-6
4.1.2.2	Mechanical	4.1-8
4.2	MILD ENVIRONMENT	4.2-1
4.2.1	BOP Equipment	4.2-2
4.2.2	NSSS Equipment	4.2-2
5	QUALIFICATION DOCUMENTATION	5.1-1
5.1	MASTER LISTS (ML)	5.1-1
5.2	SYSTEM COMPONENT EVALUATION WORK (SCEW) SHEET	5.2-1
6	MAINTENANCE/SURVEILLANCE PROGRAM	6-1
7	REFERENCES	7-1
APPENDIXES		
A	ENVIRONMENTAL QUALIFICATION DATA MASTER LISTS	
A.1	SAFETY-RELATED ELECTRICAL EQUIPMENT - BOP	
A.2	SAFETY-RELATED ELECTRICAL EQUIPMENT - NSSS	
A.3	SAFETY-RELATED MECHANICAL EQUIPMENT -BOP	

RBS EQD

LIST OF TABLES

<u>Table Number</u>	<u>Title</u>
2-1	HARSH ENVIRONMENTAL ZONE DESCRIPTIONS
2-2	MILD ENVIRONMENTAL ZONE DESCRIPTIONS
2-3	DELETED
2.4-1	DELETED
3.1-1	SYSTEMS AND SUBSYSTEMS REQUIRED TO MITIGATE ACCIDENT
3.1-2	ACCIDENT/SYSTEM MATRIX
3.1-3	SWEC/GE SYSTEM CROSS REFERENCE
3.1-4	SYSTEMS ASSOCIATED WITH CONTAINMENT ISOLATION
3.1-5	SYSTEMS INCLUDED IN THE STANDBY POWER SYSTEM
4.1-1	DELETED
5.1-1	ENVIRONMENTAL QUALIFICATION DATA MASTER LIST LEGEND
5.1-2	MANUFACTURER NAMES AND MANUFACTURER CODES
5.1-3	OPERABILITY CODES
5.1-4	DELETED
5.1-5	DELETED

RBS EQD

LIST OF FIGURES

<u>Figure Number</u>	<u>Title</u>
2-1	ENVIRONMENTAL ZONE MAP
2-2	ENVIRONMENTAL ZONE MAP
2-3	ENVIRONMENTAL ZONE MAP
2-4	ENVIRONMENTAL ZONE MAP
5.1-1	RBS EQD MASTER LIST HEADING FORMAT

SECTION 2

ENVIRONMENTAL CONDITIONS

The indoor environmental design conditions which have been used to establish the design basis for RBS are specified for normal, abnormal, and accident conditions. The environmental data for temperature, pressure, humidity, and radiation are defined for each building zone.

Environmental zones are classified as either harsh or mild. The classification of mild environmental zones is in compliance with 10CFR50.49(c). There is no significant change in environmental conditions, except radiation, in these zones. Additionally, for a zone to be classified as mild, the total integrated dose for 40 yr plus 180 days post-accident service is no more than 10^4 rads.

Tables 2-1^{and} 2-2, ~~and 2-3~~ list and describe the harsh and mild environmental zones. Illustrations of the physical zones are provided on the environmental zone maps, Figures 2-1 through 2-4.

2.1 TEMPERATURE, PRESSURE, HUMIDITY ENVIRONMENT

The plant ventilation/air-conditioning system is designed to maintain maximum normal operating temperature and pressure conditions for all normal reactor operating modes, including startup, power range, hot standby, shutdown, and refueling. The humidity is generally uncontrolled. Normal conditions are assumed to prevail until an abnormal or accident condition occurs, in which case the abnormal or accident condition prevails for the specified duration. Following the abnormal or accident condition, normal conditions are again assumed to exist.

Abnormal operating conditions are any reasonably expected or anticipated deviations from normal conditions (excluding accident conditions). Abnormal operating conditions include:

1. Transients that result from main steam line isolation (loss of condenser vacuum, turbine trip, and MSIV closure including a stuck open relief valve).
2. Transients caused by a single failure of one division of redundant essential HVAC equipment.
3. Transients caused by the loss of nonessential drywell HVAC equipment as the result of a loss of offsite power.

The abnormal temperatures calculated for the auxiliary building under condition 2 above envelop conservative design maxima that have a low probability of occurrence since they are associated with normal plant operating modes that prevail for less than 1 percent of the plant operating time (i.e., residual heat removal, steam condensing, and shutdown cooling). Equipment in the auxiliary building will not be qualified for these temperatures since the plant can be shut down using redundant equipment that is not affected by the postulated abnormal event. The drywell temperatures associated with condition 3 above are enveloped by the applicable accident conditions; however, their effect on the qualified life of equipment generally is not considered. Following the occurrence of abnormal temperatures in the auxiliary building or the drywell, a review will be performed to ensure that equipment remains qualified. Requalification may be based on actual temperatures recorded during the event.

| Accident conditions, defined as the failure of high-energy and moderate-energy piping, are postulated in accordance with NRC Regulatory Guide 1.46, Branch Technical Positions MEB 3-1 and APCS 3-1.

RBS EQD

TABLE 2-1

HARSH ENVIRONMENTAL ZONE DESCRIPTIONS

<u>Zone</u>	<u>Description</u>
<u>Drywell</u>	
DW-1	Outside RPV Shield Wall, Outside DW-2 (El 81'-3/4" to 162'-3")
DW-2	Outside RPV Shield Wall, to a radius of 17'-0" from RPV centerline (El 110'-0" to 122'-0")
DW-3	Under RPV (El 73'-1/4" to 102'-0")
DW-4	Drywell Dome (El 162'-3" to 175'-3 3/4")
DW-5	Outside RPV Skirt (El 100'-8" to 108'-6")
DW-6	Between RPV Insulation and Primary (Biological) Shield Wall (El 108'-6" to 147'-6")
<u>Containment</u>	
CI-1	Upper Containment Dome (El 235'-0" to 256'-3")
CT-2	Immediately Above Suppression Pool (El 90'-0" to 114'-0")
CT-3	HCU Floor (El 114'-0" to 141'-0")
CT-4	SLCS Areas (El 141'-0" to 162'-3")
CT-5	WCS Area - Backwash Receiving Tank and Pump Cubicles (El 141'-0" and 162'-3")
CT-5A	Walkway Adjacent to Zone CT-5
CT-6	Drywell Personnel Hatch Area (El 130'-7")
CT-7	WCS Heat Exchanger Cubicle (El 147'-3" to 181'-10")
CT-7A	Walkway Adjacent to Zone CT-7
CT-8	Fuel Transfer Tube, Isolation Valve Room (El 128'-1 3/4")
CT-9	Inside Main Steam Tunnel (El 114'-0")
CT-10	SFC Pipe and Valve Room (El 130'-7" and El 162'-3")
CT-11	WCS - Filter Cubicles (El 162'-3")
CT-SP	Suppression Pool (El 70'-0" to 90'-0")
CT-G*	General Area (El 114'-0", 141'-0", 162'-3", and 186'-3")
<u>Annulus</u>	
AN-1	All Areas El 114'-0" and Above
AN-2	All Areas Immediately Below El 114'-0"
AN-3	Vicinity of SFC Piping (El 114'-0" to 141'-0", AZ-155° to 185°)

RBS EQD

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Auxiliary Building</u>	
Elevation: 70'-0"	
AB-070-1	CSL Area
AB-070-2	RHS-P1A Pump Room
AB-070-3*	ICS Pump Room
AB-070-4	RHS-P1C Pump Room
AB-070-5	RHS-P1B Pump Room
AB-070-6	HPCS Pump Room
AB-070-7	Elevator Area
AB-070-8	RPCCW Area
AB-070-G	General Area
Elevation: 95'-9"	
AB-095-1	CSL Hatch Area
AB-095-2	RHS Heat Exchanger Area (West)
AB-095-3*	WCS Area
AB-095-4	Hoist Area
AB-095-5	RHS Heat Exchanger Area (East)
AB-095-6	HPCS Hatch Area
AB-095-7	Elevator Area
AB-095-8	RPCCW Area
AB-095-9	CRD Work Area
AB-095-10*	Main Steam Tunnel
AB-095-G	General Area
Elevation: 114'-0"	
AB-114-1	MCC Area (West)
AB-114-2*	Main Steam Tunnel (North)
AB-114-3	MCC Area (East)
AB-114-4	Post Accident Sampling Station
AB-114-5	Elevator Room
AB-114-6	RPCCW Area
AB-114-7*	Main Steam Tunnel (Loops)
AB-114-8	RHS Equipment Removal Cubicle
AB-114-G	General Area
Elevation: 141'-0"	
AB-141-1	Equipment Area (West)
AB-141-2	Equipment Area (East)
AB-141-3	Elevator Area

RBS EQD

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
AB-141-4	RPCCW Area
AB-141-5	Standby Gas Treatment Filter (West)
AB-141-6	Standby Gas Treatment Area (East)
AB-141-G	General Area
Elevation: 170'-0"	
AB-170-1	Annulus Mixing System Fan Area
AB-170-2	Continuous Filter Room
AB-170-3	Elevator Machine Room
<u>Fuel Building</u>	
Elevation: 70'-0"	
FB-070-1	Fuel Pool Cooling Pumps and Heat Exchanger
FB-070-2	SFT Drain Tank Area
FB-070-3	Backwash Receiving Room
FB-070-4	Fuel Pool Purification
Elevation: 95'-0"	
FB-095-1	Fuel Pool Demineralizer Filter and Tank Rooms
FB-095-2	SFC Heat Exchanger Cubicles
FB-095-G	General Area
Elevation: 113'-0"	
FB-113-1	Cask Loading and Shipping Area
FB-113-3	Pipe Chase
FB-113-4	Fuel Transfer Tube Mid-Support Room
FB-113-G	General Area
Elevation: 131'-3"	
FB-131-1	Pipe Chase
Elevation: 148'-0"	
FB-148-1	Charcoal Filter Rooms
FB-148-G	General Area

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Radwaste Building</u>	
Elevation: 65'-0"	
RW-065-1	Tank Rooms
RW-065-2	Valve and Pump Rooms
RW-065-G	General Area
Elevation: 90'-0"	
RW-090-1	Tank Area
RW-090-2	Valve and Pump Rooms
Elevation: 106'-0"	
RW-106-4	Cask Fill and Storage Area
RW-106-5	Valve and Pump Area
RW-106-6	Waste Sludge Tank Area
RW-106-G	General Area
Elevation: 117'-0", 120'-0", and 128'-6"	
RW-117-1	Valve and Pump Area
RW-117-2	Filter and Demineralizer Cubicles
RW-120-1	Valve and Pump Room
RW-128-1	Clean Cask Storage
Elevation: 136'-0"	
RW-136-1	Bridge Crane Area
RW-136-2	Evaporator and Reboiler Areas
RW-136-3	Laundry Room
RW-136-4	Flat Bed Filter and Pump Area
Elevation: 166'-0"	
RW-166-1	HVW Filter Room
RW-166-2	Evaporator Area
<u>Turbine Building Including Off-Gas Area</u>	
Elevation: 67'-6"	
TB-067-1	Heater Bay Cubicles
TB-067-3	Turbine and Condenser Area

RBS EQD

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
Elevation: 95'-0"	
TB-095-1	Heater Bay Cubicles
TB-095-2	Moisture Separator and Reheat Area
TB-095-3	Turbine and Condenser Area
TB-095-4	Air Ejector Cubicle
TB-095-5	Decontamination Area
TB-095-6	Steam Packing Exhauster Area
Elevation: 123'-6" and 180'-0"	
TB-123-1	Moisture Separator and Reheat Area
TB-123-2	Turbine Shield Wall Well Area
TB-123-3	Steam Seal Evaporator Cubicle
TB-123-4	Radwaste Reboiler Cubicle
TB-123-5	HVT Filter Room
TB-123-G	General Area
TB-180-G	Area Immediately Below Turbine Building Roof
Elevation: 67'-6"	
OG-067-1	Condensate Demineralizer Regeneration Area
Elevation: 95'-0"	
OG-095-1	Condensate Demineralizer Area
OG-095-G	General Area
Elevation: 123'-6"	
OG-123-1	Sample Rooms
OG-123-2	Off-Gas Equipment Areas
OG-123-3	Charcoal Adsorber Cubicle
Elevation: 148'-6"	
OG-148-1	Charcoal Adsorbers
OG-148-2	Holdup Pipe Room
OG-148-3	Filter Area

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Piping Tunnels</u>	
PT-1	Standby Service Water Tower Tunnel
PT-2	Tunnel Bordered by AB, RB, and RW Buildings
PT-3	AB Tunnel
PT-4	Tunnel Bordered by AB, CB, and DG Buildings
PT-6	Tunnel Bordered by TB and NJ Buildings
PT-7	Tunnel Bordered by RW and AC Buildings
PT-8	Tunnel Bordered by FB Building
PT-9	Tunnel Bordered by FB and RB Buildings

*Contains high-energy piping; failure is postulated.

TABLE 2-2

MILD ENVIRONMENTAL ZONE DESCRIPTIONS

<u>Zone</u>	<u>Description</u>
<u>Auxiliary Building</u>	
AB-170-G	General Area
<u>Fuel Building</u>	
Elevation:	70'-0"
FB-070-G	General Area
Elevation:	113'-0"
FB-113-2	Fuel Handling - Operating Floor
Elevation:	148'-0"
FB-148-2	Equipment Area
<u>Control Building</u>	
Elevation:	70'-0"
CB-070-1	Cable Vault Area
CB-070-2	HVAC Rooms
CB-070-G	General Area
Elevation:	98'-0"
CB-098-1	Switchgear Area
CB-098-2	Mechanical Equipment Room
CB-098-G	General Area
Elevation:	115'-0"
CB-115-1	HVAC Rooms
CB-115-G	General Area
Elevation:	116'-0"
CB-116-1	Battery Room
CB-116-2	Cable Vent and Switchgear, Inverter Rooms
CB-116-G	General Area

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
Elevation:	136'-0"
CB-136-1	Control Room
CB-136-G	General Area
<u>Radwaste Building</u>	
Elevation:	90'-0"
RW-090-G	General Area
Elevation:	106'-0"
RW-106-1	Solid Waste Treatment Area
RW-106-2	Solid Waste Compacting and Storage Area
RW-106-3	Sample Room
Elevation:	117'-0"
RW-117-G	General Area
Elevation:	136'-0"
RW-136-G	General Area
Elevation:	166'-0"
RW-166-G	General Area
<u>Turbine Building Including Off-Gas Area</u>	
Elevation:	67'-6"
TB-067-2	Sample Room
TB-067-4	Reactor Feed Pump Area
TB-067-G	General Area
Elevation:	95'-0"
TB-095-G	General Area

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
Elevation: 123'-6"	
TB-123-6	Passageway
Elevation: 67'-6"	
OG-067-G	General Area
Elevation: 123'-6"	
OG-123-G	General Area
Elevation: 148'-6"	
OG-148-G	General Area
<u>Diesel Generator Building</u>	
Elevation: 70'-0"	
DG-070-1	Diesel Fuel Tank Area
Elevation: 98'-0"	
DG-098-1	Diesel Operating Area
DG-098-2	Diesel Generator Control Rooms
DG-098-G	General Area
Elevation: 126'-0"	
DG-126-1	
<u>Normal Switchgear Building</u>	
Elevation: 67'-6", 98'-0", and 123'-6"	
NS-067-1	Cable Tray Room
NS-098-1	Normal Switchgear and Load Center
NS-098-2	Passageway - Normal Switchgear
NS-123-1	Battery Rooms
NS-123-2	Computer Rooms
NS-123-3	Mechanical Equipment and Switchgear Rooms
NS-123-4	Passageway - Normal Switchgear

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Auxiliary Boiler Building</u>	
Elevation: 95'-0" and 123'-6"	
BA-095-1	Auxiliary Boiler Area
BA-095-2	Switchgear Area
BA-123-1	Deaerator Area
<u>Auxiliary Control Building</u>	
Elevation: 95'-0"	
AC-095-1	Hot Machine Shop
AC-095-2	Passageway
AC-095-3	Decontamination Room
AC-095-4	I & C Electrical Hot Shop
Elevation: 123'-6"	
AC-123-1	Mechanical Equipment
AC-123-2	Passageway
AC-123-3	Auxiliary Control Room
<u>Standby Service Water Pumphouse</u>	
SW-1	Standby Service Water Pump Rooms
SW-2	Transformer Rooms
SW-3	Remote Air Intake Room
SW-4	Fan Deck Area
<u>Administration Complex</u>	
AD-1	Office Building
AD-2	Warehouse
AD-3	Cafeteria/Lockers/Offices
AD-4	Lab/Health Physics/Decontamination Areas
AD-5	Mechanical Room
AD-6	Machine Shops
AD-7	Electrical Load Center
AD-8	Primary Access Point
AD-9	Auxiliary Access Point
AD-10	Technical Support Center (TSC)

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Fire Pumphouse Building</u>	
FP-1	Fire Pumphouse
<u>Makeup Water Intake Structure</u>	
MK-1	Battery Rooms
MK-2	Pump Room
MK-3	Switchgear Room
<u>Circulating Water Pumphouse</u>	
CW-1	Circulating Water Pumphouse
<u>MG Set Building</u>	
MG-1	MG Set
<u>Water Treatment Building</u>	
WT-1	Water Treatment
<u>Transformer Yard 2A</u>	
TY-1	Fire Protection Sprinkler Building
<u>Hypochlorite Area</u>	
HA-1	Switchgear House
<u>Blowdown Area</u>	
BP-1	Blowdown Pit
<u>Cooling Tower</u>	
CL-1	Switchgear House (1A)
CL-2	Switchgear House (1B)
CL-3	Switchgear House (1C)
CL-4	Switchgear House (1D)
<u>Clarifier Area</u>	
CA-1	Switchgear House
CA-2	Tank Room

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Demineralized Water Building</u>	
DI-1	Demineralized Water Pumphouse
<u>Piping Tunnels</u>	
PT-5	Tunnel Bordered by NS and CB Buildings

2.3 CHEMICAL ENVIRONMENT

Engineered Safety Feature (ESF) systems are designed to perform their safety functions in the temperature, pressure, and humidity conditions.

River Bend Station does not utilize any chemical additives to the water recirculated by the ECCS during normal or accident conditions.

Following an accident, the containment and drywell atmospheres are maintained below 4 percent (by volume) hydrogen, as discussed in FSAR Section 6.2.5.

The water in these systems is not chemically inhibited. The maximum limits for the suppression pool water are compatible with those of the primary coolant and are listed as follows:

<u>Parameter</u>	<u>Reactor Water Limits Shutdown Condition</u>	<u>Pressure Suppression Pool Water Quality Expected</u>	<u>Suppression Pool Water Maximum Limit</u>
Conductivity	≤10 umho/cm @ 25°C	≤3 umho/cm @ 25°C	≤10 umho/cm @ 25°C
Chlorides (as Cl ⁻)	≤0.5 ppm	≤0.2 ppm	≤0.2 ppm
pH	5.3 to 8.6 @ 25°C	5.3 to 8.6 @ 25°C	5.3 to 8.6 @ 25°C
Total suspended solids		≤1 ppm	≤5 ppm

During reactor shutdown cooling, the RHR system is lined up with the reactor coolant pressure boundary (RCPB). The shutdown cooling piping and equipment in the RHR system are flushed with demineralized water from the condensate storage tank prior to commencing shutdown cooling.

2.4 SUBMERGENCE

The approach to the design of RBS is to locate devices above expected submergence levels. Flood levels have been determined for the buildings, and for compartments within the buildings, for the natural phenomena and accident conditions that could cause flooding.

Equipment located inside the drywell and containment that will be submerged during normal plant operation and as a result of a design basis accident is identified in the Equipment Qualification Master List in Appendix A and the corresponding System Component Evaluation Work (SCEW) sheets in Appendix B. Equipment located inside the containment is designed and qualified to perform its intended function while submerged. Equipment located inside the drywell that is subjected to submergence is not required to perform an active safety function. Evaluation has demonstrated that subsequent failure of this equipment is without significant consequences.

Equipment located in the containment below elevation 109 ft will be submerged for a duration of up to 7 sec during suppression pool swell following a LOCA. This equipment is qualified to withstand the submergence conditions to which it is exposed.

For areas outside the containment, flooding analyses were performed as described in FSAR Appendix 3C. These analyses demonstrate that electrical equipment required for safe shutdown of the plant either is located above submergence levels or protective measures (e.g., curbs) are provided to prevent submergence.

Non-Class 1E electrical equipment supplied from Class 1E power sources are identified in FSAR Table 8.3-7. This equipment, as described in FSAR Section 8.3.1.4.3, is electrically separated. Redundant Class 1E systems are not degraded as a result of submergence of non-Class 1E electrical equipment.

RBS EQD

TABLE 3.1-2

ACCIDENT/SYSTEM MATRIX

Accidents	Systems Required to Mitigate Accident														
	C-1 HPCS	C-2 LPCS	C-3 PCI	C-4 ADS	C-5 RCIC	C-6 CIS	C-7 RPS	C-8 MSI	C-9 LSV	C-10 RPCS	C-11 NMS	C-12 SPCM	C-13 SWP	C-14 SLS	C-15 ASCM
1. Steam Line Break Outside Containment	X	X	X	X	X	X	X						X	X	X
2. Feedwater Line Break Outside Containment	X	X	X	X	X	X	X						X	X	X
3. LOCA	X	X	X	X		X	X	X	X			X	X	X	
4. High Energy Line Break Outside Containment (RWCU/RCIC)						X	X						X		
5. Rod Drop	X	X	X	X	X	X	X			X	X		X	X	X
6. Fuel Handling													X		
7. Recirculation Pump Seizure	X	X	X	X	X		X						X	X	X
8. Recirculation Pump Shaft Break	X	X	X	X	X		X						X	X	X
9. Main Condenser Gas Treatment System failure				X	X		X						X	X	X

RBS EQD

TABLE 3.1-2 (Cont)

Accidents	Systems Required to Mitigate Accident																
	C-16 GTS	C-17 HVR	C-18 CMS	C-19 CPM	C-20 H2R	C-21 SFC	C-22 EGF	C-23 EGA	C-24 SPS	C-25 HVK	C-26 HVC	C-27 HVF	C-28 HVP	C-29 HVY	C-30 RMS	C-31	C-32
LDS PAM																	
1. Steam Line Break Outside Containment	X	X	X			X	X	X	X	X	X	X	X	X	X		
2. Feedwater Line Break Outside Containment						X	X	X	X	X	X	X	X	X	X		
3. LOCA	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		X
4. High Energy Line Break Outside Containment (RWCU/RCIC)	X	X				X	X	X	X	X	X			X	X	X	
5. Rod Drop	X	X	X			X	X	X	X	X	X	X	X	X	X		
6. Fuel Handling						X	X	X	X	X	X	X	X	X	X		
7. Recirculation Pump Seizure	X	X	X			X	X	X	X	X	X	X	X	X	X		
8. Recirculation Pump Shaft Break	X	X	X			X	X	X	X	X	X	X	X	X	X		
9. Main Condenser Gas Treatment System Failure		X	X			X	X	X	X	X	X	X	X	X	X		

RBS EQD

TABLE 3.1-2 (Cont)

<u>Accidents</u>	<u>Systems Required to Mitigate Accident</u>				
	<u>C-33</u> <u>HVN</u>	<u>C-34</u> <u>CCP</u>	<u>C-35</u> <u>SSR</u>	<u>C-36</u> <u>CPP</u>	<u>C-37</u> <u>GES</u>
1. Steam Line Break Outside Containment					X
2. Feedwater Line Break Outside Containment					X
3. LOCA	X	X	X	X	X
4. High Energy Line Break Outside Containment (RWCU/FCIC)					X
5. Rod Drop					X
6. Fuel Handling					X
7. Recirculation Pump Seizure					X
8. Recirculation Pump Shaft Break					X
9. Main Condenser Gas Treatment System Failure					X

TABLE 3.1-2 (Cont)

RBS BOP ELECTRICAL EQUIPMENT
EMRGC CROSS-REFERENCE CODES

Due to a field length limitation in the computerized equipment master list, the following shall be used.

<u>EMRGCN</u>	<u>EQUIVALENT EMRGCN</u>
C-6 and 34	C-101
C-6 and 18	C-102
C-3 and 15	C-103
C-12 and 15	C-104
C-3, 6, 12, and 15	C-105
C-6 and 24	C-106
C-3, 6, and 15	C-107
C-3, 12, and 15	C-108
C-2 and 6	C-109
C-6 and 33	C-110
C-6, 9, and 33	C-111
C-9 and 33	C-112
C-6 and 17	C-113
C-6 and 9	C-114
C-6 and 21	C-115
C-4 and 6	C-116
C-6 and 13	C-117
C-6 and 8	C-118
C-6, 12 and 15	C-119
C-3 and 6	C-120

3.2 POST-ACCIDENT OPERABILITY TIME

Equipment must be qualified for the length of time it is required to perform its safety function and must remain in a safe mode after the function is performed. The length of time the equipment is required to function following the onset of an accident is its post-accident operability time (PAOT).

The required PAOT is determined by an analysis of the functional performance requirements for each applicable event. For each device, the required active function time, based upon the intended safety function, is determined. The determined operability time ranges from very short periods, where safety functions are performed early in the event and subsequent actions are not called for, to longer periods of time where process variables are stabilized. For long periods of required operability, the parameters selected to environmentally qualify needed products assure the capability to bring the reactor to, and maintain a safe shutdown condition.

The PAOT is stated in the EQD Master List (Appendix A).

SECTION 4

QUALIFICATION METHODOLOGY

4.1 HARSH ENVIRONMENT

4.1.1 BOP Equipment

4.1.1.1 Electrical

The methodology established for the RBS equipment qualification program is in accordance with the guidelines provided in NUREG-0588 for Category I plants, and in compliance with the regulation of 10CFR50.49. The methodology consists of developing the temperature, pressure, humidity, and radiation dose levels for normal, abnormal, and accident conditions. Post-accident operability time is developed to assure that the equipment will be qualified to maintain a safety function during a post-accident event.

These requirements are included in the procurement specification for the electrical equipment important to safety. The specification mandates that the qualification will be accomplished in accordance with IEEE 323-1974 and in accordance with the quality assurance program referenced in 10CFR50 Appendix B.

Based on these requirements the equipment manufacturer develops an equipment qualification program.

The environmental qualification documents for the equipment are obtained for engineering evaluation from equipment vendors, equipment manufacturers and/or testing facilities. These documents, in the form of qualification procedures, reports, and supplementary information, are evaluated in accordance with NUREG-0588 and IEEE 323-1974. Review of these documents includes assurance that they are technically adequate and conform to the environmental qualification requirements of the applicable emergency conditions, operability times, and service conditions.

Each reviewed vendor qualification document is referenced on the System Component Evaluation Work (SCEW) sheet.

Aging

The effects of age are documented as part of the qualification program.

Arrhenius aging methodology is the preferred method for evaluating equipment aging and in general is used as a basis for determining qualified life. When other methods are used, appropriate justification is provided. The thermal aging methodology used for qualifying BOP safety-related devices is described in the qualification test reports referenced in the SCEW sheets.

Prior to simulating seismic and DBA event, equipment or its age-sensitive components were preconditioned to their end-of-qualified life condition.

If it was known that aging improved performance capability, new or partially aged devices were used in testing.

Advanced life conditioning was accomplished by applying an appropriate combination of operational and environmental cycling to simulate the expected service listed in the equipment specification and by subjecting the device to physical and chemical stresses that are known to degrade the device. Normal cycling of in-plant conditions was performed in any combination aging procedure.

In the case where accelerated aging was used, the procedure employed considered the expected application and design life of the device being tested.

Synergistic effects were considered when these effects were known to have a significant effect on equipment performance.

Where required, a maintenance or replacement schedule consistent with qualified life is provided as part of the support documentation and is referenced on the SCEW sheets.

When type testing was selected as the qualification method, the type test was run on the device(s) in a specified sequence that was set down as part of the written test procedure. All sequential testing was performed on the same

unit(s), including aging. The sequence recommended in IEEE 323-1974, paragraph 6.3.2, is used where an alternate sequence can be justified technically; this justification can be documented in the qualification reports. The test specimen has been subjected to all normal manufacturing and QA procedures and is representative of the devices supplied.

Margin

Margins are not included in the parameters given in the equipment specifications. However, the specification does include an insert which requires that margin be added to comply with IEEE 323-1974 requirements.

Qualification type test results were reviewed to verify that adequate margin exists between the most severe specified service conditions for the equipment and the conditions used in type testing. Margins are in addition to any conservatism applied during the derivation of local environmental conditions of the equipment. Margin accounts for production variations of equipment and inaccuracies in test instrumentation. Increased levels of testing, number of test cycles, and test duration are among the methods used for ensuring adequate margin.

Some equipment is required by the design to perform its safety function only within the first 10 hrs of an accident. For this equipment in general, a time margin of at least 1 hr in excess of the time assumed in the accident analysis was used.

Dose Rate and Synergistic Effects

Qualification for radiation was based on the calculated total integrated dose. Safety-related electrical equipment qualified for use in a nuclear radiation environment was exposed to radiation which simulated the conservatively calculated integrated dose (normal and accident) that the equipment is expected to withstand prior to completion of its intended safety function. In general, a gamma radiation source, typically CO-60, is used to simulate expected radiation exposure. Where beta and gamma radiation exposure is expected, beta radiation is taken into account either during simulated exposure (directly or as a gamma equivalent) or during evaluation of the results. Reduction in the total beta dose was allowed only after considering appropriate shielding factors. If the beta radiation dose

contribution to the equipment or component was calculated to be less than 10 percent of the total gamma radiation dose to which the equipment or component had been qualified, then the equipment or component was considered qualified for the beta and gamma radiation environment.

Dose rate effects were considered when these effects were known to have a significant effect on equipment performance.

The dose rate, energy spectrum, or particle type was addressed to arrive at a gamma equivalent total dose to which the equipment must be exposed. Actual testing using dose rate, energy spectrum, or particle type as qualification parameters was not considered.

Therefore, synergistic effects involving dose rate are not addressed. However; where synergistic effects of radiation and temperature were identified prior to the initiation of qualification, they are included in the program.

4.1.1.2 Mechanical

The Mechanical Equipment Qualification (MEQ) Program provides a documented analysis of the nonmetallic materials, used in active safety-related mechanical equipment, to demonstrate that the environmental effects due to plant operation and postulated accidents would not degrade these materials in such a way as to prevent this equipment from performing its required safety function.

The MEQ Program details the environmental design conformance review of active safety-related mechanical equipment located in the harsh environment identified in Table 2-1. The conformance review includes nonmetallic subcomponents of active mechanical equipment.

Active safety-related mechanical equipment is detailed in Appendix A.3. Environmental conditions listed in the EDC are used as the basis for the MEQ review.

Generally, mechanical equipment has not been shown to be as sensitive to radiation exposure as electrical components. Metallic portions of the equipment are particularly resistant to radiation. Nonmetallic parts of mechanical equipment, while more sensitive to radiation and temperature, are used in the equipment so that the degradation of mechanical properties will not substantially affect the required active safety function of the component.

Methodology

The review consists of the following five-step process.

1. Identification of active safety-related mechanical equipment
2. Identification of nonmetallic components
3. Identification of environmental design conditions
4. Identification of nonmetallic material capabilities
5. Evaluation of environmental effects

The MEQ Program consists of analyses of active safety-related equipment located in systems required for the following functions:

1. Emergency reactor shutdown
2. Emergency core cooling (short term)
3. Reactor core cooling (long term post accident)
4. Primary containment isolation
5. Containment integrity
6. Prevention of release of radioactive material

To accomplish the above functions, complete systems and portions of systems are included in the MEQ Program.

Category I active mechanical equipment within those systems that are located in a harsh environment, and required for performance of the above functions, are included in the MEQ Program. The review is performed by using the specifications, SWEC drawings, vendor drawings, and manuals.

Each material identified is examined to determine the effect of the environmental conditions on the material

properties. For initial screening, it is conservatively chosen to use the threshold radiation level and maximum service temperature. Materials handbooks, textbooks, and industry and government reports are researched to obtain material data. In some cases vendor data are utilized to supplement the above sources.

A conservative initial screening of the nonmetallic components was made by the comparison of the material capabilities (threshold radiation level and maximum service temperature) with the maximum postulated environmental conditions. Those items which are not shown to be acceptable based on the comparison are evaluated in further detail considering:

1. Degree of material degradation.
2. Material properties affected.
3. Equipment/component function.
4. Degree of functional degradation.

Acceptance Criteria

In order to be considered acceptable, nonmetallic portions of mechanical equipment must either be shown to be acceptable for the plant environment by:

1. Exhibiting threshold radiation values and maximum service temperatures above the maximum postulated environmental conditions.
2. Demonstrating that the safety function of the component is not compromised and noted as "Justified."

4.1.2 NSSS Equipment

4.1.2.1 Electrical

The approach taken by General Electric to environmentally qualify safety-related equipment within the NSSS Scope of Supply for RBS to a level consistent with NUREG-0588 is described in the GE Licensing Topical Report NEDE-24326-1-P⁽⁴⁾. This report has been approved by the NRC. The methodology described in this report is consistent with applicable Regulations (10CFR50 Appendix A); applicable Regulatory Guides; and with applicable consensus national standards (ANSI and IEEE). The work performed under this guidance is controlled in a manner consistent with the commitments contained in the NRC-approved GE Licensing Topical Report on Quality Assurance.

The approach to qualification described in NEDE-24326-1-P⁽⁴⁾ is predicated on type testing being the preferred approach. Depending upon either the unique characteristics of the specific devices or on the availability of other sources of qualification data, other approaches such as partial type test with justification by analysis, operating experience, analysis or combination of the above mentioned approaches may be used. For any of these approaches the eventual approach used is justified in the accompanying qualification report. This justification is based on the demonstrated ability of the product to meet its intended safety function.

Where type testing is performed, the approach taken is to assure the device is functional under normal conditions as well as under extremes of such conditions; the devices next age to an end-of-qualified life condition, next the device is subjected to dynamic simulation; next the device is subjected to design basis event conditions and post design basis event conditions; and lastly the device is inspected for failures which may not have been apparent during the operational testing which occurs during each exposure to an environmental extreme. When a product is tested, where practical, the interface associated with the product is included in the test. The specific sequences of environments applied during the testing are determined, using engineering judgment, to best select the sequence to which the product would be subjected during actual installation. Furthermore, where synergisms between environments are known, these effects are taken into consideration during the planning and conducting of the

RBS EQD

Using the RBS specific ambient environmental conditions, a qualification evaluation is performed as follows:

1. Define the environment that exists locally to all nonmetallic parts.
2. Examine part capability relative to the threshold for degradation. Parts for which the environmental exposure is less than the threshold require no further evaluation.
3. Parts that cannot be exempted by the evaluation under paragraph 2 are evaluated in detail. If failure can be tolerated, no further evaluation is required. If failure cannot be tolerated, acceptability is demonstrated by analysis or test data, or a combination of both, that proves the part will support the equipment safety function when exposed to normal, abnormal, and accident environments.

For each item shown on the ML a qualification evaluation report is prepared which includes the following information:

1. Summary statement of the results of the evaluation and qualification status.
2. Definition of any recommended maintenance or other conditions necessary to maintain qualification.
3. Definition of the applicable RBS environmental conditions.
4. Equipment safety function and function time.
5. Nonmetallic material lists related to the equipment item.
6. Analysis performed.
7. Reference material not commonly available.

4.2 MILD ENVIRONMENT

The RBS classification of mild environment zones complies with 10CFR50.49(c). Safety-related equipment in the zone is located outside the containment and is not subject to accident environments caused by a LOCA or pipe break. In these zones there is no significant change in environmental conditions, except radiation. Additionally, for a zone to be classified as mild, the total integrated dose for 40 yr plus 180 days post-accident service is no more than 10^4 rads. This value is conservative since organic compounds with the least radiation resistance have damage thresholds greater than 10^4 rads.

Most electronic components have a threshold damage level above 10^4 rads. Semiconductors, in particular, metal oxide semiconductor (MOS) devices, have a threshold damage level in the range of 10^3 to 10^4 rads. N-channel metal oxide semiconductor (NMOS) devices are most vulnerable to radiation damage; the failure dose can be as low as 10^3 rads (Si) (Reference 5). The damage is usually caused by total dose gamma radiation. No damage was identified due to β radiation. Semiconductor devices are resistant to β radiation since they are sealed in molded plastic, ceramic-to-metal, or glass-to-metal packages. Neutron radiation may cause damage in semiconductor devices; however, there is no neutron radiation in mild environment zones. Dose rate thresholds are higher than total dose damage threshold levels. The lowest threshold for dose rate upset is 10^5 rads (Si)/s for silicone-controlled rectifiers, and dose rate damage occurs above 10^6 rads (Si)/s (Reference 5). Since the maximum dose rate for these zones is much lower than the above threshold levels, no transient or permanent failures will occur in any mild environment zones due to dose rate effects.

Radiation effects on the above conditions in a mild environment are considered negligible because the calculated radiation doses for mild environment zones generally are less than 10^3 rads with the highest dose calculated to be 1,070 rads for the HVAC rooms.

The radiation required to produce one rad in silicon (Si) is 1.15 R in the energy range of 0.5 to 1.0 Mev (Reference 6). Therefore, semiconductor devices, including MOS devices, are considered qualified for the RBS specific radiation exposure.

Equipment located in the zones listed in Table 2-2 are not exposed to environmental conditions that may cause common mode failures due to environmental conditions during DBE. Immediate access following a DBE is not required other than normal and periodic maintenance. Therefore, these plant zones may be considered mild environment areas.

4.2.1 BOP Equipment

Safety-related equipment located in a mild environment meeting the following requirements is considered adequately qualified.

1. A Certificate of Compliance (C of C) which incorporates the qualification requirements specified and states that the functional requirements of the equipment subjected to the specified RBS environmental conditions have been met.
2. The C of C shall identify the supplied equipment by equipment mark number.
3. The equipment has been manufactured in accordance with a quality assurance program that meets the requirements of 10CFR50, Appendix B and states compliance with 10CFR21.
4. The requirements for any scheduled surveillance, maintenance calibration, periodic tests, and parts replacements necessary to maintain qualification.

4.2.2 NSSS Equipment

Safety-related NSSS vendor-supplied equipment that is located in a mild environment is considered qualified if:

1. The equipment manufacturer's design environmental parameters envelop the RBS specific environment.
2. The equipment manufacturer's design functional characteristics envelop the RBS application specific functional performance requirements.

SECTION 5

QUALIFICATION DOCUMENTATION

5.1 MASTER LIST

The master list of all equipment within the scope of the environmental qualification program is provided in Appendix A. The list is divided between electrical and mechanical equipment and between BOP and NSSS scopes of supply.

The electrical equipment master list contains all equipment requiring qualification in accordance with 10CFR50.49.

1. Equipment requiring qualification under 10CFR50.49b(1) includes all safety-related equipment required to perform its safety function in a harsh environment. Also included is equipment in any directly mechanically connected auxiliary systems with electrical components (e.g., cooling water or lubricating systems) which support the safety function of other safety-related equipment.
2. Equipment requiring qualification under 10CFR50.49b(2) includes all equipment electrically connected directly into the control or power circuitry of the safety-related equipment whose failure under postulated environmental conditions could adversely affect the safety function of other equipment. The identification of this equipment utilized, among other measures, review of applicable elementary wiring diagrams.
3. Equipment requiring qualification under 10CFR50.49b(3) includes all post-accident monitoring equipment in accordance with the RBS position to Regulatory Guide 1.97. For new and upgraded equipment with a required operation date after fuel load, qualification will be accomplished prior to the committed implementation date.

For each device, the Master List provides a summary of the key elements of the Environmental Qualification Program. Table 5.1-1 and Figure 5.1-1 contain the heading for the Master List, with a description of each entry. The first four characters of the device indicate the unit number and major system in which the device is used. The subsequent characters are used to further segregate the devices by specific type and number. Tables 5.1-2 and 5.1-3 define various codes used in the Master List.

RBS EQD


TABLE 5.1-1

ENVIRONMENTAL QUALIFICATION DATA MASTER LIST LEGEND

<u>Number</u>	<u>Title</u>	<u>Description</u>
1	MARK NO.	Indicates identifying number of SWEC equipment (the first four characters of which correspond to the unit number and major system in which the equipment is used).
2	EQUIPMENT DESCRIPTION	Brief description of equipment.
3	VENDOR	Indicates supplier filling purchase order.
4	PANEL/RACK	Mark Number of the panel/rack in which instruments are located.
5	SPEC. NO.	Indicates procurement specification number.
6	MAKE/MANUFACTURER	A four-digit code indicating the manufacturer (not necessarily the same as the vendor) (Table 5.1-2 of this document).
7	MODEL/CATALOG NO.	Manufacturer's Identification Number.
8	REMARKS	Indicates where special notes or further data may be entered concerning the device and its qualification.

TABLE 5.1-1 (Cont)

<u>Number</u>	<u>Title</u>	<u>Description</u>
9	ENV ZONE	Indicates environmental condition associated with the device.
10	SUBMRG	Indicates if equipment is subjected to submergence.
11	EMRGCN	Indicates accident(s) by column number of Table 3.1-2 through which the device must be operable to perform the safety function, or not to fail in a manner detrimental to accident mitigation or plant safety.
12	ENVTYP	Indicates type of environment (i.e., harsh, mild).
13	OPTIME	Indicates period of time following the onset of an accident during which the device must remain capable of performing its safety function (operability time).
14	OC	Indicates the operability code category associated with the device with regard to Appendix E, NUREG 0588, Item 2.
15	QRN1 QRN2 QRN3	Indicates the summary reference number of the SCEW (System Component Evaluation Worksheet) applicable to the device.



NOTE: SEE TABLE 5.1-1 FOR DEFINITION

FIGURE 5.1-1

RBS EQD
 MASTER LIST HEADING
 FORMAT

RIVER BEND STATION
 ENVIRONMENTAL QUALIFICATION DOCUMENT

5.2 SYSTEM COMPONENT EVALUATION WORK (SCEW) SHEET

A summary of qualification results for equipment within the scope of 10CFR50.49 is provided in the SCEW sheets (Appendix B). The SCEW sheet provides general information regarding the type of equipment, its function, specified environment, qualification environment, qualification method, and references to the documents that substantiate the qualification. The qualification method is designated as TEST-IDENT, TEST-SIM, EXP-AN, and AN-DATA, and corresponds to 10CFR50.49(f), 1 through 4, respectively. The SCEW sheet also identifies the specific equipment number, location (by environmental zone), and qualified life.

Associated with the SCEW sheets are graphs or tables of time-dependent environmental parameters such as temperature and pressure for both specified accident conditions and qualification test conditions. These profiles may be used for comparison of the applicable accident conditions and zones to the environment simulated in the qualification test.

The SCEW sheets are provided in Appendix B.

SECTION 6

MAINTENANCE AND SURVEILLANCE

6.1 MAINTENANCE AND SURVEILLANCE PROGRAM

The RBS Maintenance and Surveillance Program was developed to maintain Category I structures and safety-related systems and components at the quality required to perform their intended functions and withstand design basis events. The program ensures filing of documentation in an auditable and retrievable manner. The objectives of the maintenance and surveillance program, as related to qualification, are accomplished by reviewing qualification data, vendor manuals, NRC correspondence, S.E. reports, etc. This review identifies:

1. Components with a qualified life of less than 40 yr.
2. Components requiring part replacement to continue qualification.
3. Routine preventive maintenance or surveillance requirements for all equipment, regardless of qualified life.
4. Special interfaces and configurations.

The above requirements are incorporated into the existing preventive maintenance program which provides a computerized data base that includes performance frequency, assigned responsibility, applicable procedures, instructions, and requirements. The program allows access to equipment and maintenance history information. Additionally, it provides a means to identify material requirements to the Material Management System (MMS) for better inventory control. RBS has instituted a manual preventive scheduling tracking system using Visi-record cards as backup to the computer system. Based on a work order issued as a result of the preventive maintenance schedule, the appropriate department completes the required maintenance. Upon completion of each scheduled activity, a documented notification is made to indicate completion of the work; this is entered into the computer to facilitate rescheduling. The documented results are sent to the appropriate discipline for technical evaluation and possible alteration of maintenance and surveillance requirements. The initially developed maintenance and surveillance program will be modified during

RBS EQD

plant life if additional information such as corrective maintenance frequency, surveillance testing, and industry/operating experience identifies any unanticipated degradation trends. Controls are established for such activities as procurement, storage, and station modification to prevent compromising qualification. Implementation of RBS procedures accomplishes the following:

1. Procurement of qualified components for the intended safety function.
2. Procurement of qualified spare parts and replacement components.
3. Assurance that the required maintenance during storage is properly performed and documented.
4. Control of station modifications to prevent compromising qualification.
5. Review of station modification packages and procurement documents to address equipment qualification concerns.

The RBS Quality Assurance program conforms to 10CFR50, Appendix B, and requires inspections, verifications, and audits to ensure that maintenance requirements are properly implemented in a timely manner. The RBS maintenance and surveillance program is consistent with NRC requirements and ensures that safety-related equipment is maintained and monitored under controls to assure continued qualifications throughout the life of the plant.

SECTION 7

REFERENCES

1. Title 10, Code of Federal Regulations, Paragraph 50.49, Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants. Federal Register, Vol. 48, No. 15. January 21, 1983. |
2. Regulatory Guide 1.75, Physical Independence of Electric Systems, Rev. 2, September 1978. |
3. Shirley, N.C. et al. General Electric Qualification Program, Licensing Topical Report NEDE-24326-1-P, January 1983. |
4. General Electric Nuclear Energy Business Group, BWR Quality Assurance Program, NEDO-11209-04A, March 1978. |
5. Rose, M.; Herrity, J.; Ruolie, N.; and Rasmussen, K. Design Guidelines for Transient Radiation Effects on Tactical Army Systems. IRT4331-06. June 12, 1981. |
6. American Institute of Electrical Engineers (AIEE). Calculation of Absorbed Dose. December 1960. |

ATTACHMENT 2

REVISED SYSTEM COMPONENT EVALUATION WORK (SCEW) SHEETS

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 211161-1
 REV. 1
 SHEET NO. 2E
 DATE 1-15-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUTERS	QUAL. LIFE	OPTIME OC
SRN 211161-1				
SPEC 211.161				
HCS HYDROGEN RECOMBINER				
1HCS*IGN25A	NONE/UNIQUE	CT-5A	40 YEARS	7 DAYS A
1HCS*IGN25B	NONE/UNIQUE	CT-5A	40 YEARS	7 DAYS A
1HCS*IGN26A	NONE/UNIQUE	CT-5	13.4 YEARS	7 DAYS A
1HCS*IGN26B	NONE/UNIQUE	CT-5	13.4 YEARS	7 DAYS A
1HCS*IGN27A	NONE/UNIQUE	CT-5A	40 YEARS	7 DAYS A
1HCS*IGN27B	NONE/UNIQUE	CT-5A	40 YEARS	7 DAYS A
1HCS*IGN28A	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN28B	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN29A	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN29B	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN30A	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN30B	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - RUPON ENVIRONMENT ONLY

SRN 211161-1
 REV. 1
 SHEET NO. 29
 DATE 1-15-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUDIRG	QUAL. LIFE	CPTIME OC
SRN 211161-1				
SPEC 211.161				
HCS HYDROGEN RECOMBINER				
1HCS*IGN37A	NONE/UNIQUE	CT-G	40 YEARS	7 DAYS A
1HCS*IGN37B	NONE/UNIQUE	CT-G	40 YEARS	7 DAYS A
1HCS*IGN36A	NONE/UNIQUE	CT-G	40 YEARS	7 DAYS A
1HCS*IGN36B	NONE/UNIQUE	CT-3	40 YEARS	7 DAYS A
1HCS*IGN39A	NONE/UNIQUE	CT-G	40 YEARS	7 DAYS A
1HCS*IGN39B	NONE/UNIQUE	CT-G	40 YEARS	7 DAYS A
1HCS*IGN40A	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN40B	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN41A	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN41B	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN42A	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A
1HCS*IGN42B	NONE/UNIQUE	DN-1	10.2 YEARS	7 DAYS A

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 211161-1
 REV. 1
 SHEET NO. 21
 DATE 1-15-85

 MARK NO
 MODEL/CATALOG NO. ENV. ZONE QUAL. LIFE OPTIME
 REMARKS SUBMRG OC

SRN 211161-1

SPEC 211.161

HCS HYDROGEN RECOMBINER

IHCS*IGN49A

NONE/UNIQUE

DH-1

10.2 YEARS

7 DAYS
A

IHCS*IGN49B

NONE/UNIQUE

DH-1

10.2 YEARS

7 DAYS
A

IHCS*IGN50A

NONE/UNIQUE

DH-1

10.2 YEARS

7 DAYS
A

IHCS*IGN503

NONE/UNIQUE

DH-1

10.2 YEARS

7 DAYS
A

IHCS*IGN51A

NONE/UNIQUE

DH-1

10.2 YEARS

7 DAYS
A

IHCS*IGN51B

NONE/UNIQUE

DH-1

10.2 YEARS

7 DAYS
A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 211161-1

REV 2

SHEET NO. 3

DATE 11/28/84

NOTES

-
1. The abnormal conditions listed apply only to the hydrogen igniters which are located outside the drywell in the containment.
 2. Normal condition envelops abnormal condition. Hydrogen igniters are not required to operate under abnormal conditions. Time at abnormal conditions will have a negligible effect on qualified life.
 3. Test includes 6-percent margin. See Reference 2 for qualification of additional margin using Arrhenius methodology.
 4. Specified value based on 10.6-year qualified life and includes margin on accident conditions.
 5. Equipment in containment below 109 ft is subject to submergence, and between 109 ft and 120 ft is subject to spray/froth as a result of pool swell. Equipment subjected to these conditions are identified on Sheet 2. See Reference 6.

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 211161-2

REV 1

SHEET NO. 3

DATE 01/16/85

NOTES

-
1. For complete environmental conditions, see the documents referenced.
 2. Terminal head gasket must be replaced with a new gasket whenever head cover is removed in order to maintain qualification.
 3. Factory certification testing of RTDs has demonstrated accuracy of $<\pm 1.0^{\circ}\text{F}$. The qualification type testing has shown an accuracy of $\pm 1.2^{\circ}\text{F}$. A review of the setpoint calculation is in progress to determine whether $\pm 1.2^{\circ}\text{F}$ is an acceptable accuracy.
 4. PYCO Test Report No. 16346-82N is the basis for qualification of these devices. (See Reference 2.)

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 215252-2
REV 2
DATE 08-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION						MARGIN: DEMO	REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD		
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2								
SYSTEM: SEE SHEET 2	OP. TIME:	100 DAYS	>100 DAYS	3	2,4	AN+DATA	YES	NOTE-3
	TEMP (F):							NOTE-1
	NORMAL	122	140	1	2,5	AN+DATA	NA	NOTE-5
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TYPE: (DESCRIPTION)	ACCIDENT	200	212	1	2	TEST-SIM	YES	NOTE-6
UNIT COOLER MOTOR	PRESS (PSIG)							NOTE-1
	NORMAL	-0.10" H2O	-3.0	1	2	AN+DATA	NA	NOTE-2
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MANUFACTURER: WESTINGHOUSE	ACCIDENT	2.8	3.45	1	2	TEST-SIM	YES	
	RRH (%)							NOTE-1
MODEL: SEE SHEET 2	NORMAL	90	100	1	2	TEST-SIM	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
SAFETY FUNCTION: - - -	ACCIDENT	100	100	1	2	TEST-SIM	NA	
PROVIDE COOLING IN REACTOR	RADIATION:							NOTE-1
CONTAINMENT OR AUXILIARY	NORM GAMMA	3.3E7		1			NA	
BUILDING	ACC GAMMA	1.1E7	1.13E8	1	2	TEST-SIM	YES	NOTE-4
OP. CODE: SEE SHEET 2	NORM BETA	0		1				
	ACC BETA	500		1				
	NEUTRON	0		1				
	SPRAY	NA	NA	NA	NA	NA	NA	
ACCURACY - - -	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
SPEC: NA								
DEMO: NA								
ZONE NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO								
SUBMERGENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 0588,CAT I								
MAINT/SURVEILL - - -								
REFERENCE: 2								
QUALIFIED LIFE - - -								
(YEARS): SEE SHEET 2								
REFERENCE: 2,5								

- DOCUMENT REFERENCE:
- SPECIFICATION 215.252 REV.2, ADD.2
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6215.252-057-001F
 - POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV.0
 - CALCULATION NO. 12210-EDS-20
 - CALCULATION NO. 12210-EDS-26

1005 - ENVIRONMENTAL QUALIFICATION PROGRAM
 SYSTEM COMPONENT EVALUATION WORK SHEET
 EQUIPMENT NEAR CONDITIONS AND QUALIFICATION

SRN 219/11-2
 REV 1
 DATE 21-JUN-85
 SHEET 1

EQUIPMENT IDENTIFICATION	EQUIPMENT	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE	QUALIFIED	QUALIFIED METHOD	MARGIN DEMO	REMARKS
EQUIP NO.: SEE SHEET 2								
SYSTEM: SEE SHEET 2								
TYPE: DESCRIPTION:								
SOLENOID VALVE WITH POSITION SWITCHES								
MANUFACTURER: TRCF								
MODEL: SEE SHEET 2								
SAFETY FUNCTION:								
ISOLATION FROM MAIN AIR SUPPLY								
INFLATE SEALS TO PRESSURE								
BOUNDARY								
REF. CODE: SEE SHEET 2								
ACCURACY								
SPEC: NA								
DEMO: NA								
TIME NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO SUBMERGENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY:								
COLLECTABLE TO NUREG 0580,CAT 1								
MAINT/SUBCELL								
REFERENCE: SEE REFERENCE 2								
QUALIFIED LIFE								
VELOCITY: SEE SHEET 2								
REFERENCE: 2								

- ENVIRONMENT REFERENCE:
1. SPECIFICATION 219,711, REV. 3 / FSDCR NO. P-3034
 2. SOURCE ENVIRONMENTAL QUALIFICATION REPORT, SHOP # 5219,711-000-0060
 3. EQUIPMENT IDENTIFICATION REF: SEE FRAP DOCUMENT NO. 45,600, REV.0

NOTE-1

NOTE-1

NOTE-1

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 224520-2
REV 2
DATE 08-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION							REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		DUAL METHOD	MARGIN DEMO	
EQUIP NO.: SEE SHEET 2				SPECIFIED	QUALIFIED			
SYSTEM: SEE SHEET 2	OP. TIME:	100 DAYS	11 MON.	3	4	TEST-IDENT	YES	
TYPE: (DESCRIPTION)	TEMP (F):							NOTE 1
	NORMAL	90	155	1	2,5	TEST-IDENT	NA	
	ABNORMAL	140	155	1	2,5	TEST-IDENT	NA	
RECOMBINER UNIT	ACCIDENT	165	300	1	2,5	TEST-IDENT	YES	
	PRESS (PSI):							NOTE 1
	NORMAL	1.0" WG	ATMOS	1	2,5	TEST-IDENT	NA	
MANUFACTURER: WESTINGHOUSE	ABNORMAL	2.3	70	1	2,5	TEST-IDENT	NA	NOTE 2
	ACCIDENT	9.0	70	1	2,5	TEST-IDENT	YES	
MODEL: SEE SHEET 2	RRH (%):							NOTE 1
	NORMAL	50	100	1	7	AN + DATA	NA	
	ABNORMAL	100	100	1	7	TEST-IDENT	NA	
SAFETY FUNCTION: - - - REMOVE HYDROGEN FROM CONTAINMENT ATMOSPHERE	ACCIDENT	100	100	1	7	TEST-IDENT	NA	
	RADIATION:							NOTE 1
	NORM GAMMA	YES		1				
OP. CODE: SEE SHEET 2	ACC GAMMA	1.0RENTD	2EB	1	6	TEST-IDENT	YES	
	NORM BETA							
	ACC BETA							
ACCURACY - -	NEUTRON							
	SPRAY	NA	NA	NA	NA	NA	NA	
SPEC: NA	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
DEMO: NA								
ZONE NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO SUBMERGENCE OR SPRAY/FROTH CONDITIONS								
DOCUMENTATION ACCEPTABILITY: ACCEPTABLE TO NUREG 0588, CAT I								
MAINT/SURVEILL - - -								
REFERENCE: NOT REQUIRED								
DOWN TIME LIFE - - -								
(YEARS): SEE SHEET 2								
REFERENCE: 9								

- DOCUMENT REFERENCE:
- SPECIFICATION 224,520 THRU ADD.# 7 & ORDER NO. P-12,910A
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6224,520-214-001B TO 0090 & WESTINGHOUSE LTR. #PI-82-0166, DATED 4/27/80
 - POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245,600, REV. 0
 - SDDF # 6224,520-214-006B
 - SDDF # 6224,520-214-005B
 - SDDF # 6224,520-214-004B
 - SDDF # 6224,520-214-003B
 - SDDF # 6224,520-214-001B
 - NRC LETTER DATED 6/22/78 FROM J.F. STOLTZ (NSC) TO T.M. ANDERSON (W)

REP - ENVIRONMENTAL QUALIFICATION PROGRAM
 SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 225220-2
 REV 1
 DATE 08-Jan-85
 SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE	QUALIFIED	DUAL METHOD	MARGIN DEMO	REMARKS
EQUIP NO.: SEE SHEET 2	TOP TIME	100 DAYS	100 DAYS	3	2	AN + DATA	YES	NOTE 1
SYSTEM: SEE SHEET 2	TEMP (F)							
	NORMAL	172	137	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	AN + DATA	NA	
TYPE: (DESCRIPTION)	ACCIDENT	172	184	1	2	AN + DATA	YES	NOTE 1
	PRESSURE(SI)							
	NORMAL	ATMOS	ATMOS	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	AN + DATA	NA	
MANUFACTURER: CEMCO	ACCIDENT	ATMOS	ATMOS	1	2	AN + DATA	NA	NOTE 2
	IN (Z)							
	NORMAL	90	95	1	2	AN + DATA	NA	NOTE 1
	ABNORMAL	NA	NA	NA	NA	AN + DATA	NA	
	ACCIDENT	90	95	1	2	AN + DATA	NA	NOTE 1
	RADIATION							
	NORM GAMMA	5.3E6 TID	2.5E7	4	2	TEST-IDENT	YES	
	ACC BETA							
	NORM BETA							
	ACC BETA							
	NEUTRON							
	SPRAY	NA	NA	NA	NA	NA	NA	
	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
ACCURACY --								
SPEC: NA								
DEMO: NA								
ZONE NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO								
SUBMERGENCE OR SPRAY/FROTH								
CONDITIONS								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 0588, CAT I								
MAINT/SURVEILL --								
REFERENCE: 2								
OPERATIONAL LIFE --								
CYCLE(S): SEE SHEET 2								
REFERENCE: 2								

- DOCUMENT REFERENCE:
1. SPECIFICATION 225,220 THRU ADD. # 3 & EDCR NO. P-12,903A
 2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT.
 3. SDS# # 6225,220-115-026A
 4. F051 ACCIDENT OPERABILITY PERIOD: SEE F051 DOCUMENT NO. 245,600, REV.0
 4. CALCULATION NO. 1210-FR(C)-572

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 225220-3
REV 1
DATE 08-Jan-85
SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	TEMP (F):	100 DAYS	100 DAYS	3	2	AN + DATA	YES	NOTE 1
SYSTEM: SEE SHEET 2	NORMAL	122	137	1	2	AN + DATA	NA	
TYPE: (DESCRIPTION)	ABNORMAL	NA	NA	NA	NA	NA	NA	
	ACCIDENT	122	184	1	2	AN + DATA	YES	
TEMPERATURE SWITCH	PRESS (PSIG)							NOTE 1
	NORMAL	ATMOS	ATMOS	1	2	AN + DATA	NA	
MANUFACTURER: FENVAL	ABNORMAL	NA	NA	NA	NA	NA	NA	
	ACCIDENT	ATMOS	ATMOS	1	2	AN + DATA	NA	NOTE 2 NOTE 1
MODEL: SEE SHEET 2	RRH (%)							
	NORMAL	90	95	1	2	AN + DATA	NA	
SAFETY FUNCTION: LOWER TEMPERATURE AUTO RESET	ABNORMAL	NA	NA	NA	NA	NA	NA	
	ACCIDENT	90	95	1	2	AN + DATA	NA	NOTE 1
OP. CODE: SEE SHEET 2	RADIATION:							
	NORM GAMMA	9.35 STD	1.3E6	4	2	TEST-IDENT	YES	
ACCURACY	ACT GAMMA							
	NORM IOTA							
ZONE NO.: SEE SHEET 2	ACC BETA							
	NEUTRON							
SURBERGENCE OR SFRAY/FROTH	SFRAY	NA	NA	NA	NA	NA	NA	
	SURBERGENCE	NA	NA	NA	NA	NA	NA	

- DOCUMENT REFERENCE:
- SPECIFICATION 225,220 THRU ADD.# 8 & FIGUR NO. P-12,903A
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6229,220-115-0260
 - FIRST-ACCIDENT DEFERRABILITY PERIOD: SEE FOUR DOCUMENT NO. 747,600, REV.0
 - CALCULATION NO. 12210-FR(C)-552

EQUIPMENT NOT SUBJECTED TO SURBERGENCE OR SFRAY/FROTH CONDITIONS

DOCUMENTATION ACCEPTABILITY: ACCEPTABLE TO NUREG 0589,CAT I

QUALIFIED LIFE - - -
AFORES: SEE SHEET 2
REFERENCE: 2

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 225220-4
REV 1
DATE 08-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION						MARGIN: DEMO	REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD		
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	TOP. TIME:	100 DAYS	>100 DAYS	3	2	AN + DATA	YES	
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE 1
	NORMAL	122	137	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TYPE: (DESCRIPTION)	ACCIDENT:	122	184	1	2	AN + DATA	YES	
TEMPERATURE SWITCH	PRESS (PSIG):							NOTE 1
	NORMAL	ATMOS	ATMOS	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MANUFACTURER: FENVAL	ACCIDENT:	ATMOS	ATMOS	1	2	AN + DATA		NOTE 2
	IRR (Z):							NOTE 1
MODEL: SEE SHEET 2	NORMAL	90	95	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
SAFETY FUNCTION: - - -	ACCIDENT:	90	95	1	2	AN + DATA	NA	
LOWER TEMPERATURE	RADIATION:							NOTE 1
MANUAL RESET	NORM GAMMA:						NA	
	ALC GAMMA:	9.3E5 TID	1.3E6	4	2	TEST-IDENT	YES	
	NORM BETA:							
	ALC BETA:							
	NEUTRON:							
	SPRAY:	NA	NA	NA	NA	NA	NA	
ACCURACY - -	SUBMERGENCE:	NA	NA	NA	NA	NA	NA	
	SPEC: NA							
	DEMO: NA							
ZONE NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO								
SUBMERGENCE OR SPRAY/FROTH								
CONDITIONS								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 0588, CAT I								
MAINT/SURVEILL - - -								
REFERENCE: 2								
QUALIFIED LIFE - - -								
(YEARS): SEE SHEET 2								
REFERENCE: 2								

- DOCUMENT REFERENCE:
1. SPECIFICATION 225,220 THRU ADD. # 8 & E&DCR NO. P-12,903A
 2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDP # 6225,220-115-026A
 3. POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245,600, REV. 1
 4. CALCULATION NO. 12210-FR(C)-552

EBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 225220-6
REV 1
DATE 08-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION						DUAL METHOD	MARGIN DEMO	REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE					
				SPECIFIED	QUALIFIED				
EQUIP NO.: SEE SHEET 2									
SYSTEM: SEE SHEET 2	OP. TIME:	100 DAYS	100 DAYS	3	2	AN + DATA	YES		
	TEMP (F):							NOTE 1	
	NORMAL:	96	137	1	2	AN + DATA	NA		
	ABNORMAL:	NA	NA	NA	NA	NA	NA		
TYPE: (DESCRIPTION)	ACCIDENT:	124	184	1	2	AN + DATA	YES		
	PRESS (PSIG):							NOTE 1	
FLOW SWITCH	NORMAL:	-0.26" WG	ATMOS	1	2	AN + DATA	NA		
	ABNORMAL:	NA	NA	NA	NA	NA	NA		
MANUFACTURER: CEMCO	ACCIDENT:	-0.62" WG	ATMOS	1	2	AN + DATA		NOTE 2	
	RH (%):							NOTE 1	
MODEL: SEE SHEET 2	NORMAL:	55	95	1	2	AN + DATA	NA		
	ABNORMAL:	NA	NA	NA	NA	NA	NA		
SAFETY FUNCTION: - - -	ACCIDENT:	45	95	1	2	AN + DATA	NA		
INDICATE AIR FLOW THROUGH	RADIATION:							NOTE 1	
FILTER UNIT	NORM GAMMA:	7E2		1			NA		
	ACC GAMMA:	1E5 T10	2.5E7	1	2	TEST-IDENT	YES		
OP. CODE: SEE SHEET 2	NORM BETA:								
	ACC BETA:								
	NEUTRON:								
	SPRAY:	NA	NA	NA	NA	NA	NA		
ACCURACY - - -	SUBMERGENCE:	NA	NA	NA	NA	NA	NA		
SPEC: NA									
DEMO: NA									
ZONE NO.: SEE SHEET 2									
SUBMERGENCE:									
SPRAY/FROTH:									
EQUIPMENT NOT SUBJECTED TO									
SUBMERGENCE OR SPRAY/FROTH									
CONDITIONS									
DOCUMENTATION ACCEPTABILITY:									
ACCEPTABLE TO NUREG 0588, CAT 1									
MAINT/SURVEILL - - -									
REFERENCE: 2									
QUALIFIED LIFE - - -									
(YEARS): SEE SHEET 2									
REFERENCE: 2									

DOCUMENT REFERENCE:

1. SPECIFICATION 225.220 THRU ADD. # 1 & E&DCR NO. P-12,903A
2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6025.220-115-006A
3. POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV. 0

REG - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SKN 225220-7
REV 1
DATE 08-Jan-85
SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		DUAL METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	OP. TIME:	100 DAYS	>100 DAYS	3	2	AN + DATA	YES	
SYSTEM: SEE SHEET 2	TEMP (F):							
TYPE: (DESCRIPTION)	NORMAL:	96	137	1	2	AN + DATA	NA	NOTE 1
	ABNORMAL:	NA	NA	NA	NA	AN + DATA	NA	
TEMPERATURE SWITCH	ACCIDENT:	124	184	1	2	AN + DATA	YES	
	PRESS (PSIG):							
MANUFACTURER: FENVAL	NORMAL:	-0.25" WG	ATMOS	1	2	AN + DATA	NA	NOTE 1
	ABNORMAL:	NA	NA	NA	NA	AN + DATA	NA	
MODEL: SEE SHEET 2	ACCIDENT:	-0.62" WG	ATMOS	1	2	AN + DATA	NA	NOTE 2
	IRH (%):							NOTE 1
SAFETY FUNCTION: --	NORMAL:	55	95	1	2	AN + DATA	NA	
	ABNORMAL:	NA	NA	NA	NA	AN + DATA	NA	
OVER TEMPERATURE	ACCIDENT:	45	95	1	2	AN + DATA	NA	
AUTO RESET	RADIATION:							
OP. CODE: SEE SHEET 2	NORM GAMMA:	7E2		1				NOTE 1
	ACC GAMMA:	1E5 IID	1.3E6	1	2	TEST-IDENT	YES	
ACCURACY --	NORM BETA:							
	ACC BETA:							
SPEC: NA	NEUTRON:							
	DEMO: NA	SFRAY:	NA	NA	NA	NA	NA	NA
ZONE NO.: SEE SHEET 2	SURMERGENCE:	NA	NA	NA	NA	NA	NA	NA
	SFRAY/FROTH:							
EQUIPMENT NOT SUBJECTED TO	ACCIDENT:							
	SURMERGENCE OR SFRAY/FROTH							
CONDITIONS	CONDITIONS:							
DOCUMENTATION ACCEPTABILITY:	DOCUMENT REFERENCE:							
	ACCEPTABLE TO NUREG 0580, CAT 1							
MAINT/SURVEILL --	1. SPECIFICATION 225,220 THRU ADD. # B & E&DUR NO. P-12, 903A							
	REFERENCE: 2	2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT,						
QUALIFIED LIFE --	SDF # 6225,220-115-027A							
	3. POST-ACCIDENT OPERABILITY PERIOD: SEE							
REFERENCES: SEE SHEET 2	FAOF DOCUMENT 100, 245,600, REV.0							

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET
ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	TOP TIME:	100 DAYS	>100 DAYS	3	2	AN + DATA	YES	NOTE 1
SYSTEM: SEE SHEET 2	TEMP (F):							
	NORMAL	96	137	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TYPE: (DESCRIPTION)	ACCIDENT:	124	184	1	2	AN + DATA	YES	NOTE 1
TEMPERATURE SWITCH	PRESS (PSIG):							
	NORMAL	-0.25" WG	ATMOS	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MANUFACTURER: FENNAL	ACCIDENT:	-0.6" WG	ATMOS	1	2	AN + DATA	NA	NOTE 2 NOTE 1
	NRH (%):							
	NORMAL	55	95	1	2	AN + DATA	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
SAFETY FUNCTION: - - -	ACCIDENT:	45	95	1	2	AN + DATA	NA	NOTE 1
OVER TEMPERATURE	RADIATION:							
MANUAL RESET	ACC GAMMA:	7E2	1.3E6	1	2	TEST-IDENT	YES	
TOP. CODE: SEE SHEET 2	ACC BETA:							
	ACC NEUTRON:							
	SPRAY:	NA	NA	NA	NA	NA	NA	
ACCURACY - -	SUBMERGENCE:	NA	NA	NA	NA	NA	NA	
SPEC: NA								
DEMO: NA								
FORM NO.: SEE SHEET 2								
EMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO								
SUBMERGENCE OR SPRAY/FROTH								
CONDITIONS								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 0588, CAT I								
MAINT/SURVEILL - - -								
REFERENCE: 2								
EQUAL FIELD LIFE - - -								
(MARKS): SEE SHEET 2								
REFERENCE: 2								

DOCUMENT REFERENCE:
1. SPECIFICATION 225,220 (REV) ADD.# B & E/DICR NO. P-12,903A
2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT,
SDDE # 6225,220-115-026A
3. POST-ACCIDENT OPERABILITY PERIOD: SEE
FAOP DOCUMENT NO. 245,600, REV.0

228243_1
 228241_5
 228216_1
 228214_1

EEI - ENVIRONMENTAL QUALIFICATION PROGRAM
 SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 228212_1
 REV 2
 DATE 21-Jan-85
 SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION		DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	SPECIFIED			
EQUIP NO.: SEE SHEET 2							
SYSTEM: SEE SHEET 2	OP. TIME:	100 DAYS	100 days	3	2,4	TEST - SIM	YES -NOTE 3
	TEMP (F):						
	NORMAL:	140	140	1	2,4	TEST - SIM	NA
	ABNORMAL:	260	300	1	2,4	AN + DATA	NA
TYPE: (DESCRIPTION)	ACCIDENT:	330	340	1	2,4	TEST - SIM	YES
MOV-AC/RN (INSULATED) MOTOR IN-	PRESS (PSIG):						
SIDE CONTAINMENT-SEE NOTE 6	NORMAL:	.5	ATMOS	1	2,4	TEST - SIM	NA
	ABNORMAL:	5	105	1	2,4	AN + DATA	NA
MANUFACTURER: LIMITORQUE	ACCIDENT:	+25 TO -8	105	1	2,4	TEST - SIM	YES
	IRH (%):						
MODEL: SEE SHEET 2	NORMAL:	100	100	1	2,4	TEST - SIM	NA
	ABNORMAL:	100	100	1	2,4	AN + DATA	NA
SAFETY FUNCTION: - - -	ACCIDENT:	STEAM	STEAM	1	2,4	TEST - SIM	NA
VALVES MUST OPEN AND/OR CLOSE	RADIATION:						
AS REQUIRED	NORM GAMMA:						NA
	ACC GAMMA:	1.77E7	2.04E8	1	2	TEST - SIM	YES -NOTE 5
OP. CODE: SEE SHEET 2	NORM BETA:						NA
	ACC BETA:						NA
	NEUTRON:						NA
	SPRAY:	7 seconds	24 HOURS	5	6,4	TEST - SIM	NA -NOTE 1
ACCURACY - -	SURMERGENCE:	100 DAYS	SEE NOTE 2	5	2,4	AN + DATA	NA -NOTE 1, 2
SPEC: NA							
DEMO: NA							
ZONE NO.: SEE SHEET 2							
SURMERGENCE:	DOCUMENT REFERENCE:						
SPRAY/ROTH:	1. SPECIFICATIONS: 228.212, 228.214, 228.216, 228.241 & 228.243						
SEE NOTE 1, PAGE 3	2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT,						
	SDDF # 622B.212-047-068D						
	622B.214-059-010D						
	622B.216-050-017D						
	622B.241-092-009B						
	622B.243-105-001C						
DOCUMENTATION ACCEPTABILITY:	3. POST-ACCIDENT OPERABILITY PERIOD: SEE						
ACCEPTABLE TO NURCH 0588,CAT	LOOP DOCUMENT NO. 243.809, REV.0						
	4. CALCULATION NO. 12219 EDS-4						
	5. ESAR, APPENDIX 6A, FIGURE 6A-19.2						
	6. SDDF # 622B.212-047-073A						
MAINT/SURVEILL - - -							
REFERENCE: 2							
QUALIFIED LIFE -							
YEARS: SEE SHEET 2							
REFERENCE: 4 (SEE NOTE 4)							

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

228212-1 228216-1
228214-1 228241-5
SRN 228243-i
REV 1
SHEET NO. 3
DATE 01/16/85

NOTES

-
1. Equipment in the drywell below el 105 ft 3 in. is subject to submergence as a result of reverse vent clearing. The five valves subject to this condition are identified on Sheet No. 2, pages 2A, 2B, and 2C.

Equipment in containment below el 109 ft 0 in. is subject to submergence, and equipment between 109 ft 0 in. and 120 ft 0 in. is subject to spray/froth as a result of pool swell. One valve is subject to the spray/froth condition and is identified on Sheet No. 2, page 2G.

2. The valves subject to submergence have no safety function and are not required to cycle following an accident. Valve position will be unaffected by submergence.
3. Operability period extended from 30 days of tested value to 100 days by Arrhenius calculation. See Reference 4.
4. Extension of qualified life past 2 years will be based on the results of the GE Phase 3 testing program for Limitorque actuators.
5. Combined radiation for gamma, beta, and neutron for 20 years of qualified life plus accident, including applicable beta and neutron reduction, is 177 megarads.
6. Refer to Sheet No. 2 for the motor details.

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 228218-3
REV 1
SHEET NO. 2
DATE 1-15-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCHRS	QUAL. LIFE	OPTIME OC
SRN 228218-3				
SPEC 228.218				
CSH CORE SPRAY - HIGH PRESSURE				
ICSH*SOV103	NP 8316 WITH 1E22*AOVF005 N/R FOR SAFETY FUNCTION	DW-1	11.4 YEARS	N/R B
CSL CORE SPRAY - LOW PRESSURE				
ICSL*SOV103	NP 8316 WITH 1E21*AOVF005 N/R FOR SAFETY FUNCTION	DW-1	11.4 YEARS	N/R B
ICS REACTOR CORE ISOLATION COOLING				
IICS*SOV103	NP 8316 WITH 1E51*AOVF065 N/R FOR SAFETY FUNCTION	DR-4	11.4 YEARS	N/R B
RHS RESIDUAL HEAT REMOVAL SYSTEM				
IRHS*SOV5A	NP 8316 WITH 1E12*AOVF041A N/R FOR SAFETY FUNCTION	DR1	11.4 YEARS	N/R B
IRHS*SOV5B	NP 8316 WITH 1E12*AOVF041B N/R FOR SAFETY FUNCTION	DR1	11.4 YEARS	N/R B
IRHS*SOV5C	NP 8316 WITH 1E12*AOVF041C N/R FOR SAFETY FUNCTION	DR1	11.4 YEARS	N/R C

ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SKN 241211-1
REV 1
DATE 17-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION							REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		DUAL METHOD	MARGIN DEMO	
EQUIP NO.: SEE SHEET 2	TOP TIME:	100 DAYS	100 DAYS	3	2	AN+DATA		NOTE-2
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE-1
TYPE: (DESCRIPTION) ELECTRICAL PENETRATION	NORMAL:	120	248	1	2	TEST-SIM	NA	
	ABNORMAL:	140	248	1	2	TEST-SIM	NA	
	ACCIDENT:	165	370	1	2	TEST-SIM	YES	
MANUFACTURER: CONAX	PRESS (PSIG):							NOTE-1
	NORMAL:	-3" H2O	14	1	2	TEST-SIM	NA	
	ABNORMAL:	2.3	14	1	2	TEST-SIM	NA	
MODEL: SEE SHEET 2	ACCIDENT:	9	75	1	2	TEST-SIM	YES	
	RRH (%):							NOTE-1
	NORMAL:	100	100	1	2	TEST-SIM	NA	
SAFETY FUNCTION: - - - CONTAINMENT INTEGRITY & CIRCUIT AVAILABILITY	ABNORMAL:	100	100	1	2	TEST-SIM	NA	
	ACCIDENT:	100	100	1	2	TEST-SIM	NA	
	RADIATION:							NOTE-1
OP. CODE: SEE SHEET 2	NORM GAMMA:	3.2E7		1	2	TEST-SIM	NA	
	ACC GAMMA:	1.68EB TID	2.2EB	1	2	TEST-SIM	YES	
	NORM BETA:						NA	
ACCURACY - - - SPEC: NA DEMO: NA	ACC BETA:						NA	
	NEUTRON:						NA	
	SPRAY:	NA	NA	NA	NA	NA	NA	
	SUBMERGENCE:	NA	NA	NA	NA	NA	NA	
ZONE NO.: SEE SHEET 2	DOCUMENT REFERENCE:							
SUBMERGENCE:	1. SPECIFICATION 241.211, REV. 1, ADD. 2 / E&DCR P21,756A							
SPRAY/FROTH:	2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6241.211-156-003D & 003C							
EQUIPMENT NOT SUBJECTED TO SUBMERGENCE OR SPRAY/FROTH	3. POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV. 0							
DOCUMENTATION ACCEPTABILITY: ACCEPTABLE TO NUREG 0588, CAT 1								
MAINT/SURVEILL - - - REFERENCE: NOT REQUIRED								
QUALIFIED LIFE - - - (YEARS): SEE SHEET 2 REFERENCE: 2								

KBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 237160-1
REV 1
DATE 08-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION							REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	
EQUIP NO.: SEE SHEET 2	OP. TIME:	100 DAYS	100 DAYS	3	2	TEST-IDENT	YES	
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE-1
TYPE: (DESCRIPTION) PUMP MOTOR	NORMAL	122	266	1	2	TEST-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
	ACCIDENT	200	356	1	2,4	TEST-IDENT	YES	NOTE-2
MANUFACTURER: WESTINGHOUSE	PRESS (PSIG)							NOTE-1
	NORMAL	ATMOS	ATMOS	1	2	TEST-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MODEL: SEE SHEET 2	ACCIDENT	2.1	ATMOS	1	2	TEST-IDENT	-	NOTE-3
	RRH (%)							NOTE-1
	NORMAL	90	100	1	2	TEST-IDENT	NA	
SAFETY FUNCTION: - - - TO FILL SYSTEM PUMPS & DISCHARGE PIPING TO AVOID WATER HAMMER EFFECTS	ABNORMAL	NA	NA	NA	NA	NA	NA	
	ACCIDENT	100	100	1	2	TEST-IDENT	NA	
	RADIATION:							NOTE-1
OP. CODE: SEE SHEET 2	NORM GAMMA	6ES						
	ACC GAMMA	1E7 TID	2E8	1	2	TEST-SIM	YES	NOTE-4
	NORM BETA							
	ACC BETA							
ACCURACY - - - SPEC: NA DEMO: NA	NEUTRON							
	SPRAY	NA	NA	NA	NA	NA	NA	
	SURMERGENCE:	NA	NA	NA	NA	NA	NA	
ZONE NO.: SEE SHEET 2	DOCUMENT REFERENCE:							
SURMERGENCE:	1. SPECIFICATION 237.160 ADD.6 / EMBOR P12,967							
SPRAY/FROTH:	2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6237.160-108-001F							
EQUIPMENT NOT SUBJECT TO SUBMERGENCE OR SPRAY/FROTH	3. POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV.0							
	4. CALCULATION NO. 12210-EOS-44							
DOCUMENTATION ACCEPTABILITY: ACCEPTABLE TO NUREG 0588, CAT I								
MAINT/SURVEILL - - - REFERENCE: 2								
QUALIFIED LIFE - - - (YEARS): SEE SHEET 2 REFERENCE: 2								

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 241211-1
 REV 1
 DATE 12-21-84
 SHEET 2A

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBGRG	QUAL. LIFE	OPTIME OC
SRN 241211-1				
SPEC 241.211				
RCP ELECTRICAL PENETRATIONS				
1RCP*LVC05	7437-10002	CT-G	40 YRS	1000 A
1RCP*LVC06	7437-10002	CT-5A	40 YRS	1000 A
1RCP*LVC10A	7437-10002	CT-G	40 YRS	1000 A
1RCP*LVC11A	7437-10002	CT-G	40 YRS	1000 A
1RCP*LVC13A	7437-10002	CT-G	40 YRS	1000 A
1RCP*LVC18	7437-10002	CT-G	40 YRS	1000 A
1RCP*LVC18A	7437-10002	CT-G	40 YRS	1000 A
1RCP*LVC19A	7437-10002	CT-G	40 YRS	1000 A
1RCP*LVC20A	7437-10002	CT-G	40 YRS	1000 A

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HAREN ENVIRONMENT ONLY

SRN 241211-1
 REV 1
 DATE 12-21-84
 SHEET # 2B

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCHRG	QUAL. LIFE	OPTIME OC
SRN 241211-1				
SPEC 241.211				
RCP ELECTRICAL PENETRATIONS				
1RCP=LVC21	7437-100C2	CT-G	40 YRS	1000 A
1RCP=LVP03	7437-10001	CT-G	40 YRS	1000 A
1RCP=LVP03A	7437-10001	CT-G	40 YRS	1000 A
1RCP=LVP04	7437-10001	CT-SA	40 YRS	1000 A
1RCP=LVP04A	7437-10001	CT-SA	40 YRS	1000 A
1RCP=LVP07	7437-10001	CT-G	40 YRS	1000 A
1RCP=LVP07A	7437-10001	CT-G	40 YRS	1000 A
1RCP=LVP08	7437-10001	CT-SA	40 YRS	1000 A
1RCP=LVP08A	7437-10001	CT-SA	40 YRS	1000 A

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 241211-1
 REV 1
 DATE 12-21-84
 SHEET NO. 20

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUDIRG	QUAL. LIFE	OPTIME OC
SRN 241211-1				
SPEC 241.211				
RCP ELECTRICAL PENETRATIONS				
1RCP*LVP09	7437-10001	CT-G	40 YRS	1000 A
1RCP*LVP09A	7437-10005	CT-G	40 YRS	1000 A
1RCP*LVP16	7437-10001	CT-G	40 YRS	1000 A
1RCP*LVP16A	7437-10001	CT-G	40 YRS	1000 A
1RCP*LVP22	7437-10001	CT-G	40 YRS	1000 A
1RCP*LVP22A	7437-10001	CT-G	40 YRS	1000 A

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

JAN 24/21-2
 REV 1
 DATE 12-21-84
 SHEET NO. 2A

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCIRG	QUAL. LIFE	CPTIME OC
SRN 241211-2				
SPEC 241.211				
RCP ELECTRICAL PENETRATIONS				
1RCP*LVI05A	7437-10003	CT-G	40 YRS	1000 A
1RCP*LVI06A	7437-10003	CT-5A	40 YRS	1000 A
1RCP*LVI11	7437-10003	CT-G	40 YRS	1000 A
1RCP*LVI12	7437-10003	CT-G	40 YRS	1000 A
1RCP*LVI12A	7437-10003	CT-G	40 YRS	1000 A
1RCP*LVI14	7437-10003	CT-G	40 YRS	1000 A
1RCP*LVI14A	7437-10003	CT-G	40 YRS	1000 A
1RCP*LVI15	7437-10003	CT-G	40 YRS	1000 A
1RCP*LVI15A	7437-10003	CT-G	40 YRS	1000 A

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SAN 241211-2
 REV 1
 DATE 12-2-84
 SHEET NO. 20

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBGRG	QUAL. LIFE	OPTIME OC
SRN 241211-2				
SPEC 241.211				
RCP ELECTRICAL PENETRATIONS				
IRCP#LVI17B	7437-10003	CT-G	40 YRS	1000 A
IRCP#LVI17C	7437-10003	CT-G	40 YRS	1000 A
IRCP#LVI21A	7437-10003	CT-G	40 YRS	1000 A
IRCP#NHS10	7437-10004	CT-G UNDER TRNS	40 YRS	1000 A
IRCP#NHS13	7437-10004	CT-G	40 YRS	1000 A
IRCP#NHS19	7437-10004	CT-G	40 YRS	1000 A
IRCP#NHS20	7437-10004	CT-G	40 YRS	1000 A

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 241211-3
 REV 1
 DATE 12-21-84
 SHEET NO. 2

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUSDRG	QUAL. LIFE	OPTIME OC
SRN 241211-3				
SPEC 241.211				
RCP ELECTRICAL PENETRATIONS				
1RCP#HVP01	7437-10000	CT-G	40 YRS	1000 A
1RCP#HVP02	7437-10000	CT-G	40 YRS	1000 A

ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	OP. TIME:	100 DAYS	150 DAYS	3	2	TEST-SIM	YES	
SYSTEM: SEE SHEET 2	TEMP (F):	NORMAL	RATED 194	1.5	2	TEST-SIM	NA	NOTE-1
		ABNORMAL	RATED 266	1.5	2	AN+DATA	NA	
		ACCIDENT	345	1.5	2	TEST-SIM	YES	
TYPE: (DESCRIPTION)	(PRESSURE/STG)							
600 VOLT POWER CABLE								
ETHYLENE PROPYLENE INSULA- TION (EVALON (CSFE) JACKET	NORMAL	1/2	ATMOS	1.5	2	TEST-SIM	NA	NOTE-1
MANUFACTURER: MONITE	ABNORMAL	2.3	8	1.5	2	AN+DATA	NA	NOTE-2
	ACCIDENT	25 TO -8	118 TO -11	1.5	2	AN+DATA	YES	NOTE-2
MODEL: NA	CRASH							NOTE-1
	NORMAL	100	100	1.5	2	AN+DATA	NA	NOTE-1
	ABNORMAL	100	100	1.5	2	AN+DATA	NA	NOTE-3
	ACCIDENT	100	100	1.5	2	TEST-SIM	NA	NOTE-3
SAFETY FUNCTION: -- -- -- TO CONVEY ELECTRICAL POWER TO CLASS 1E EQUIPMENT	RADIATION:							NOTE-1
	NORM GAMMA	1.65E8 T11	2E8	1.4	2	TEST-SIM	YES	NOTE-4
OP. CODE: SEE SHEET 2	ACC COSMIA							
	NORM BETA							
	ACC ALPHA							
	NEUTRON							
ACCURACY: --	SPRAY	NA	NA	NA	NA	NA	NA	
SPEC: NA	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
DEMO: NA								

- DOCUMENT REFERENCE:
1. SPECIFICATION 241.234 / EMDR P22.171A
 2. VIBRATION EQUIPMENT QUALIFICATION REPORT, SPEC # 6241.234-1.7-004A & 4B
 3. POST-QUALIFICATION PERIOD: SEE EQUIP DOCUMENT NO. 245.600, REV.0
 4. CALCULATION NO. 1.210-EDS-29
 5. CALCULATION NO. 1.210-EDS-38

EQUIPMENT NOT SUBJECTED TO SUBMERGENCE OR SPRAY/ROTH

DOCUMENTATION ACCEPTABILITY: ACCEPTABLE TO NUREG 0588, CAT 1

MAINT./SUBCELL: -- -- --
REFERENCE: NOTE-4

QUALIFIED LIFE: -- -- --
(HOURS): SEE SHEET 2
REFERENCE: 2,4

ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 241240-1
REV 2
DATE 21-Jan-85
SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	FACTOR	SPECIFIED VALUE	QUALIFIED VALUE	SPECIFIED TOLERANCE	QUALIFIED TOLERANCE	DUAL METHOD	MARGIN DFMD	REMARKS
EQUIP NO.: SEE SHEET 2	TEMP (C)	100 DAYS	150 DAYS	-	2	TEST-SIM	YES	
SYSTEM: SEE SHEET 2	RELATIVE HUMIDITY (%)	140	RATED 194	1.5	2	TEST-SIM	NA	NOTE-1
	ACCELERATION (G)	140	RATED 265	1.5	2	AN+DATA	NA	
TYPE: (DESCRIPTION) 600 GAGE CONTROL CABLE ETHYLENE PROPYLENE INSULATION HYDROLON (CSFE) JACKET	PRESSURE (PSI)	330	341	1.5	2	TEST-SIM	YES	
	MECHANICAL SHOCK (G)	2.5	ATMS	1.5	2	TEST-SIM	NA	NOTE-1
MANUFACTURER: OPONITE	ACCELERATION (G)	2.5	112	1.5	2	AN+DATA	NA	NOTE-2
	ACCELERATION (G)	25 TO -8	112 TO -11	1.5	2	AN+DATA	YES	NOTE-2
MODEL: NA	RELATIVE HUMIDITY (%)	100	100	1.5	2	AN+DATA	NA	NOTE-1
	ACCELERATION (G)	100	100	1.5	2	AN+DATA	NA	NOTE-3
SAFETY FUNCTION: - - - TO CONTROL CLASS 1E EQUIPMENT	ACCELERATION (G)	100	100	1.5	2	TEST-SIM	NA	NOTE-3
	RADIATION (MRAD)	-	-	-	-	TEST-SIM	NA	NOTE-1
OP. CODE: SEE SHEET 2	NOISE GAMMA (dB)	1.225B TID	3EB	1,4	2	TEST-SIM	NA	NOTE-4
	NOISE BETA (dB)	-	-	-	-	-	-	-
ACCURACY: - - SPEC: NA DFMD: NA	ACCELERATION (G)	NA	NA	NA	NA	NA	NA	
	SURVIVABILITY	NA	NA	NA	NA	NA	NA	

DOCUMENT REFERENCE:

1. SPECIFICATION 241,240 / EDCR F22,130A
2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT,
3. SPEC # 241,240-177-007A & 5B
4. TEST-ACCIDENT OPERABILITY PERIOD: SEE
5. VENDOR DOCUMENT NO. 245,600, REV.0
6. VENDOR DOCUMENT NO. 12710-FB-30
7. QUALIFICATION NO. 22710-EDS-39

EQUIPMENT NOT SUBMITTED TO SURVIVABILITY OR SPRAY/FROTH

DOCUMENTATION ACCEPTABILITY:
ACCEPTABLE TO NUREG 0589, CAT 1

MAIN/SUBMITTEL - - -
REFERENCE: NOTE-4

QUALIFIED DATE - - -
CYCLES: SEE SHEET 2
REFERENCE: 2,4

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 241242-1
 REV 1
 SHEET NO. 2A
 DATE 2-7-85

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

MARK NO	MODEL/CATALOG NO.	ENV. ZONE	QUAL.	LIFE	OPTIME
	REMARKS	SUBIRG			OC
SRN 241242-1					
SPEC 241.242					
NGP CABLE					
INGP61	NONE	VARIOUS	40yr	1000	A
INGP62	NONE	VARIOUS	40yr	1000	A
INGP70	NONE	VARIOUS	40yr	1000	A
INGP71	NONE	VARIOUS	40yr	1000	A
INGP72	NONE	VARIOUS	40yr	1000	A
INGP73	NONE	VARIOUS	40yr	1000	A
INGP75	NONE	VARIOUS	40yr	1000	A
INGP76	NONE	VARIOUS	40yr	1000	A
INGP77	NONE	VARIOUS	40yr	1000	A
INGP78	NONE	VARIOUS	40yr	1000	A
INGP80	NONE	VARIOUS	40yr	1000	A
INGP81	NONE	VARIOUS	40yr	1000	A

SRN 241242-1
 REV 1
 SHEET NO. 23
 DATE 1-7-85

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

 MARK NO ***** MODEL/CATALOG NO. ENV. ZONE QUAL. LIFE OPTIME
 REMARKS SUGIRG OC

SRN 241242-1
 SPEC 241.242
 NGP CABLE
 INGP02
 INGP04
 INGP05

NONE VARIOUS 40yr 1000
 NONE VARIOUS 40yr 1000
 NONE VARIOUS 40yr 1000

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 241242-1

REV 2


SHEET NO. 3

DATE 02/08/85


NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Qualification of Rockbestos cable is acceptable for River Bend Station. Documentation concerns identified in NRC notices are being rectified by a Rockbestos commitment to complete a generic requalification test. Reports are due by December 1985 (References 7 and 10).
 3. The qualified total integrated dose is 2E8 rads.
 4. Margin demonstrated by higher temperature over the 100 days of test.
 5. Use outside the primary containment in areas not subject to high energy line break. May be used in limited areas of short duration high temperature exposure. Also not used in zones FB-113-4, off-gas area, radwaste building.

TEST PROFILE 241.242/3 SDDF NO.
6241.242-158-002A/2B/3A/4A/5A/7A/8A



TEST PROFILE 241.242/3 SDDF NO.
6241.242-158-002A/2B/3A/4A/5A/7A/8A



TEST PROFILE SPEC. 241.242/3 SDDF 6241.242/3-158-002A/2B/3A/4A/5A/7A/8A

TEMPERATURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG (MIN)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
TEMP (F)	140	280	346	346	140	280	346	346	335	335	315	315	265	265	212	212	212
TIME (MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

PRESSURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG (MIN)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
PRES (PSIG)	0	70	113	113	0	70	113	113	93	93	69	69	28	28	0	0	0
TIME (MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 241242-2
 REV 1
 SHEET NO. 2
 DATE 2-7-85

 MARK NO MODEL/CATALOG NO. ENV. ZONE QUAL. LIFE OPTIIE
 REMARKS SUBIRG OC

SRN 241242-2

SPEC 241.242

NGS CABLE

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBIRG	QUAL. LIFE	OPTIIE OC
1NGS40	NONE NOTE 5	VARIOUS	40yr	1000 A
1NGS41	NONE	VARIOUS	40yr	1000 A
1NGS42	NONE	VARIOUS	40yr	1000 A
1NGS43	NONE	VARIOUS	40yr	1000 A
1NGS44	NONE NOTE 6	VARIOUS	40yr	1000 A
1NGS45	NONE	VARIOUS	40yr	1000 A
1NGS46	NONE	VARIOUS	40yr	1000 A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 241242-2

REV 1


SHEET NO. 3

DATE 02/08/85


NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Qualification of Rockbestos cable is acceptable for River Bend Station. Documentation concerns identified in NRC notices are being rectified by a Rockbestos commitment to complete a generic requalification test. Reports are due by December 1985 (References 6 and 7).
 3. Both are total integrated doses. Specified value includes margin.
 4. Used everywhere except zones DW-6, CT-8, FB-113-4, radwaste building, and off-gas area.
 5. (INGS40) Six circuits will be exposed to a TID greater than 2E8. These will have a reduced life of 36 years. They are listed in Appendix A of Reference 4 .
 6. (INGS44) Sixty-six circuits will be exposed to a TID greater than 2E8. These will have a reduced life of 32 years. They are listed in Appendix A of Reference 4.
 7. Cables are qualified for 113 psig; therefore, 2.3 psig will not have any effect on cables.
 8. Margin demonstrated by higher temperature over 100 days of test.

TEST PROFILE 241.242/3 SDDF NO.
6241.242-158-002A/2B/3A/4A/5A/7A/8A



TEST PROFILE 241.242/3 SDDF NO.
6241.242-158-002A/2B/3A/4A/5A/7A/8A



TEST PROFILE SPEC. 241.242/3 SDDF 6241.242/3-158-002A/2B/3A/4A/5A/7A/8A

TEMPERATURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG(MIN)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
TEMP(F)	140	280	346	346	140	280	346	346	335	335	315	315	265	265	212	212	212
TIME(MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

PRESSURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG(MINUT)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
PRES(PSIG)	0	70	113	113	0	70	113	113	93	93	69	69	28	28	0	0	0
TIME(MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

SRN 241242-3
 REV. 1
 SHEET NO. 2
 DATE 2-7-85

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

 MARK NO *****
 MODEL/CATALOG NO. *****
 SUBIRG *****
 ENV. ZONE *****
 QUAL. LIFE *****
 OPTIME *****
 OC *****
 REMARKS *****

SRN 241242-3

SPEC 241.242

MGP CABLE

1NGP67

1NGP68

MCS CABLE

1NGS57

NONE	VARIOUS	40 yr	1000 A
NONE	VARIOUS	40 yr	1000 A
NONE NOTE 4	VARIOUS	40 yr	1000 A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 241242-3

REV 1

SHEET NO. 3


DATE 02/08/85

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Qualification of Rockbestos cable is acceptable for River Bend Station. Documentation concerns identified in NRC notices are being rectified by a Rockbestos commitment to complete a generic requalification test. Reports are due by December 1985 (References 6 and 8).
 3. Total integrated dose with margin included.
 4. (INGP67) All but one circuit will be exposed during 40-year life plus accident plus margin to less than 200 Mrads. The test exposure of 2E8 rads will qualify this circuit initially for 36 years. See Appendix A of Reference 4.
 5. Margin demonstrated by higher temperature over 100 days of test.
 6. Cables are qualified for 113 psig; therefore, 2.3 psig will not have any effect on cables.


TEST PROFILE 241.242/3 SDDF NO.

6241.242-158-002A/2B/3A/4A/5A/7A/8A



TEST PROFILE 241.242/3 SDDF NO.

6241.242-158-002A/2B/3A/4A/5A/7A/8A



TEST PROFILE SPEC. 241.242/3 SDDF 6241.242/3-158-002A/2B/3A/4A/5A/7A/8A

TEMPERATURE																	
TIME	0	10SEC	4MIN	5HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG(MIN)	-3.00	-0.70	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
TEMP(F)	140	280	346	346	140	280	346	346	335	335	315	315	265	265	212	212	212
TIME(MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

PRESSURE																	
TIME	0	10SEC	4MIN	5HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG(MINUT)	-3.00	-0.70	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
PRES(PSIG)	0	70	113	113	0	70	113	113	93	93	69	69	28	28	0	0	0
TIME(MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 241243-1
REV 2
DATE 08-Feb-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION							
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	OP. TIME:	100 DAYS	100 DAYS	3	9	TEST-SIM	YES	NOTE 6
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE-1
	NORMAL	122	194	1	2	TEST-SIM	NA	
	ABNORMAL	145	194	1	2	TEST-SIM	NA	
TYPE: (DESCRIPTION)	ACCIDENT	260	346	1	4,8,9	TEST-SIM	YES	
THERMOCOUPLE EXTENSION WIRE	PRESS (PSIG)							NOTE-1
KC-486 NEOPRENE JACKET OVER	NORMAL	0	ATMOS	1	2	TEST-SIM	NA	
KYL 760 XLPE INSULATION	ABNORMAL	-02	ATMOS	1	4,8	TEST-SIM	NA	
MANUFACTURER: ROCKBESTOS	ACCIDENT	2.8	113	1	4,8,9	TEST-SIM	YES	
	RH (%)							NOTE-1
MODEL: NA	NORMAL	100	100	1	2	TEST-SIM	NA	NOTE-5
	ABNORMAL	45	100	1	9	TEST-SIM	NA	
SAFETY FUNCTION: - - -	ACCIDENT	100	STEAM	1	4,8,9	TEST-SIM	NA	
TRANSMISSION OF SIGNAL	RADIATION:							
ASSOCIATED WITH SAFETY SYSTEMS	NORM GAMMA	8.3E7	2E8	6	2,5	TEST-SIM	NA	
	ACC GAMMA	40		6			YES	NOTE-3
OP. CODE: SEE SHEET 2	NORM BETA	0		6			NA	
	ACC BETA	600		6			YES	
	NEUTRON	0		6			NA	
	SPRAY	NA	NA	NA	NA	NA	NA	
ACCURACY - -	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
SPEC: NA								
DEMO: NA								
ZONE NO.: SEE NOTE 4								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO								
SUBMERGENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 058B,CAT I								
(NOTE-2)								
MAINT/SURVEILL - - -								
REFERENCE: NOT REQUIRED								
QUALIFIED LIFE - - -								
(YEARS): 40								
REFERENCE: 2								

- DOCUMENT REFERENCE:
1. SPECIFICATION 241.243 REV.1, ADD.4 / E&DCR P22,194A
 2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6241.243-162-002A
 3. POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV.0
 4. SUPPLEMENTAL REPORT SDDF# 6241.243-162-003A
 5. CALCULATION NO. 12210-EQS-32 (RADIATION)
 6. CALCULATION NO. 12210-EQS-56 (ENVIRONMENTAL)
 7. LETTER# C4/12210/93/4YLWPC P.K.GUHA TO H.R.ROGUE; FEB. 5,1985
 8. 6241.243-162-004A
 9. 6241.243-162-005A

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 241243-1
 REV 1
 SHEET NO. 2
 DATE 2-7-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBHRG	QUAL. LIFE	OPTIME OC
SRN 241243-1				
SPEC 241.243				
NGS CABLE				
INGS01	NONE	VARIOUS	40yr	1000 A
INGS02	NONE	VARIOUS	40yr	1000 A
INGS03	NONE	VARIOUS	40yr	1000 A
INGS05	NONE	VARIOUS	40yr	1000 A
INGS61	NONE	VARIOUS	40yr	1000 A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM


SRN 241243-1
REV 1
SHEET NO. 3
DATE 02/08/85

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Qualification of Rockbestos cable is acceptable for River Bend Station. Documentation concerns identified in NRC notices are being rectified by a Rockbestos commitment to complete a generic requalification test. Reports are due by December 1985 (References 4 and 7).
 3. Qualified total integrated dose is $2E8$ rads.
 4. Used outside the primary containment in areas not subject to high energy line break. Also not used in zone FB-113-4 and off-gas area.
 5. Tested submerged.
 6. Margin demonstrated by higher temperatures over 100 days of test.


TEST PROFILE 241.242/3 SDDF NO.

6241.243-162-002A/2B/3A/4A/5A



TEST PROFILE 241.242/3 SDDF NO.

6241.243-162-002A/2B/3A/4A/5A



TEST PROFILE SPEC. 241.242/3 SDDF 6241.242/3-162-002A/2B/3A/4A/5A

TEMPERATURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR, 10SEC	5HR, 4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG (MIN)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
TEMP (F)	140	280	346	346	140	280	346	346	335	335	315	315	265	265	212	212	212
TIME (MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

PRESSURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR, 10SEC	5HR, 4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG (MIN)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
PRES (PSIG)	0	70	113	113	0	70	113	113	93	93	89	89	28	28	0	0	0
TIME (MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 241243-2
REV 2
DATE 08-Feb-95
SHEET 1

EQUIPMENT DESCRIPTION		ENVIRONMENTAL CONDITIONS AND QUALIFICATION						REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2								
SYSTEM: SEE SHEET 2		OP.TIME: 100 DAYS	100 DAYS	3	9	TEST-SIM	YES	
		TEMP (F):						NOTE-1
		NORMAL	140	194	1	2	TEST-SIM	NA
		ABNORMAL	140	194	6	2	TEST-SIM	NA
TYPE: (DESCRIPTION)		ACCIDENT	330	346	1	8,9,4	TEST-SIM	YES
THERMOCOUPLE EXTENSION WIRE		PRESS (PSIG)						NOTE-1
KC-486 NEOPRENE JACKET OVER		NORMAL	0.5	ATMOS	1	2	TEST-SIM	NA
KYL 760 XLPE INSUL & SHLD		ABNORMAL	2.3	ATMOS	6	8,4	AN+DATA	NOTE 6
MANUFACTURER: ROCKBESTOS		ACCIDENT	25 TO -8	113	1	8,9,4	TEST-SIM	YES
		RH (%)						NOTE-1
MODEL: NA		NORMAL	90	100	1	2	TEST-SIM	NOTE-5
		ABNORMAL	100	100	6	9	TEST-SIM	NA
SAFETY FUNCTION: - - -		ACCIDENT	STEAM	STEAM	1	8,9,4	TEST-SIM	NA
TRANSMISSION OF SIGNAL		RADIATION:						
ASSOCIATED WITH SAFETY SYSTEMS		NORM GAMMA						NA
		ACC GAMMA	1.7E8 TID	2E8	5	2	TEST-SIM	NOTE-3
OP. CODE: SEE SHEET 2		NORM BETA						NA
		ACC BETA						YES
		NEUTRON						NA
		SPRAY	NA	NA	NA	NA	NA	NA
ACCURACY - -		SUBMERGENCE	NA	NA	NA	NA	NA	NA
SPEC: NA								
DEMO: NA								
ZONE NO.: SEE NOTE-4								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO								
SUBMERGENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 0588, CAT I								
(NOTE-2)								
MAINT/SURVEILL - - -								
REFERENCE: NOT REQUIRED								
QUALIFIED LIFE - - -								
(YEARS): 40								
REFERENCE: 2								

- DOCUMENT REFERENCE:
- SPECIFICATION 241.243 REV.1, ADD.4 / E&DCR P22,194A
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6241.243-162-002A
 - POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV.0
 - SUPPLEMENTAL REPORT SDDF# 6241.243-162-003A
 - CALCULATION NO. 12210-EDS-32 (RADIATION)
 - CALCULATION NO. 12210-EDS-56 (ENVIRONMENTAL)
 - LETTER# C4/12210/93/4YLWPC P.L.BUHA TO H.R.BOGUE; FEB. 5,1985
 - 6241.243-162-004A
 - 6241.243-162-005A

SRN 241243-2
REV. 1
SHEET No. 2
DATE 2-7-85

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

MARK NO

MODEL/CATALOG NO. ENV. ZONE QUAL. LIFE SUBIRG OPTIME

REMARKS

SRN 241243-2

SPEC 241.243

M6S CABLE

1NGS06

1NGS60

VARIOUS 40yr 1000
A

VARIOUS 40yr 1000
A

NONE

NONE

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM


SRN 241243-2
REV 1
SHEET NO. 3
DATE 02/08/85

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Qualification of Rockbestos cable is acceptable for River Bend Station. Documentation concerns identified in NRC notices are being rectified by a Rockbestos commitment to complete a generic requalification test. Reports are due by December 1985 (References 4 and 7).
 3. These are total integrated dose values. Specified value includes margin.
 4. Used everywhere except zones DW-6, CT-8, FB-113-4, radwaste building, and off-gas area.
 5. Tested submerged.
 6. Cables are qualified for 113 psig; therefore, 2.3 psig will not have any effect on cables.


TEST PROFILE 241.242/3 SDDF NO.

6241.243-162-002A/2B/3A/4A/5A



TEST PROFILE 241.242/3 SDDF NO.

6241.243-162-002A/2B/3A/4A/5A



TEST PROFILE SPEC. 241.242/3 SDDF 6241.242/3-162-002A/2B/3A/4A/5A

TEMPERATURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG (MIN)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
TEMP (F)	140	200	346	346	140	280	346	346	335	335	315	315	265	265	212	212	212
TIME (MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000
PRESSURE																	
TIME	0	10SEC	4MIN	3HR	5HR	5HR,10SEC	5HR,4MIN	8HR	8.01HR	11HR	11.01 HR	15HR	15.01HR	4DAYS	4.01DAYS	30DAYS	100 DAYS
LOG (MINUT)	-3.00	-0.78	0.60	2.26	2.48	2.48	2.48	2.68	2.68	2.82	2.82	2.95	2.95	3.76	3.76	4.64	5.16
PRES (PSIG)	0	70	113	113	0	70	113	113	93	93	69	69	28	28	0	0	0
TIME (MIN)	0.001	0.1666	4	180	300	300.16	304	480	480	660	660.166	900	900.6	5760	5760.6	43200	144000

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 242132-1

REV 1

SHEET NO. 3

DATE 11/27/84

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Transformer is qualified to 165°F for more than 40 years.
 3. Reference 4 provides justification for a qualification temperature of 165°F. Actual test temperature is 149°F.

ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 24244-1
REV 1

DATE 08-Jan-85
SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	OBTAINED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEF	REMARKS
				SPECIFIED	OBTAINED			
EQUIP NO.: SEE SHEET 2	TEMP (F)	N.A.	N.A.	3	2	NA	NA	NOTE-1
SYSTEM: SEE SHEET 2	NORMAL	104	104	1	2	TEST-SIM	NA	NOTE-1
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TYPE: (DESCRIPTION) CONTROL RELAY BOARD	ACCIDENT	NA	NA	NA	NA	NA	NA	NOTE-1
	PRESSURE	NA	NA	NA	NA	NA	NA	
MANUFACTURER: EM	NORMAL	ATMOS.	ATMOS.	1	2	TEST-SIM	NA	NOTE-1
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MODEL: SEE SHEET 2	ACCIDENT	NA	NA	NA	NA	NA	NA	NOTE-1
	RR (Z)	NA	NA	NA	NA	NA	NA	
SAFETY FUNCTION: -- -- NOT REQUIRED FOR SAFETY	NORMAL	40	40	1	2	TEST-SIM	NA	NOTE-1
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TOP. CODE: SEE SHEET 2	ACCIDENT	NA	NA	NA	NA	NA	NA	NOTE-1
	RADIATION	NA	NA	NA	NA	NA	NA	
ACCURACY -- -- SPEC: NA DPMO: NA	NORM GAMMA	7E3 TID	1E4	1	2	TEST-SIM	NA	NOTE-1
	ACC GAMMA	NA	NA	NA	NA	NA	NA	
ZONE NO.: SEE SHEET 2	NORM BETA	NA	NA	NA	NA	NA	NA	NOTE-1
	ACC BETA	NA	NA	NA	NA	NA	NA	
EMERGENCE: SPRAY/FROTH:	NEUTRON	NA	NA	NA	NA	NA	NA	NOTE-1
	SFRAY	NA	NA	NA	NA	NA	NA	
EQUIPMENT NOT SUBJECT TO SUBMERGENCE OR SPRAY/FROTH	SUBMERGENCE	NA	NA	NA	NA	NA	NA	NOTE-1
	SPRAY/FROTH	NA	NA	NA	NA	NA	NA	

- DOCUMENT REFERENCE:
- SPECIFICATION 6242.444 ADD.4 / ES DER P40,746
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDR # 6242.444-275-0020, -041A AND -042A
 - POST-ACCIDENT OFFRABILITY PERIOD: SEE FOUR DOCUMENT NO. 242,600, REV.0

DOCUMENTATION ACCEPTABILITY:
ACCEPTABLE TO NUREG 0588, CAT I

MAINT/SURVILL -- --
REFERENCE: NOT REQUIRED

QUALIFIED LIFE -- --
(YEARS): SEE SHEET 2
REFERENCE: 2

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 242491-1
REV 2
DATE 13-Feb-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION							
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD	MARGIN DEMO	REMARKS
EQUIP NO.: SEE SHEET 2	OP.TIME:	100 DAYS	>100 DAYS	3	2,4	AN+DATA	YES	
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE-1
	NORMAL	122	134	1	2	TEST-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TYPE: (DESCRIPTION)	ACCIDENT	165	186	1	2,4	TEST-IDENT	YES	NOTE-2
TERMINAL CABINET	PRESS (PSIG)							NOTE-1
TERMINAL BOARDS	NORMAL	ATMOS	ATMOS	1	2	TEST-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MANUFACTURER: GE	ACCIDENT	2.8	ATMOS	1	2	AN+DATA	-	NOTE-3
	RH (%)							NOTE-1
MODEL: SEE SHEET 2	NORMAL	90	98	1	2	TEST-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
SAFETY FUNCTION: - - -	ACCIDENT	100	98	1	2	TEST-IDENT	NA	NOTE-4
LOW VOLTAGE CONTROL	RADIATION:							NOTE-1
TERMINATIONS & CKT CONTINUITY	NORM GAMMA			1	2			
	ACC GAMMA	1.2E6 TID	1.2E6	1	2	AN+DATA	YES	NOTE-5
OP. CODE: SEE SHEET 2	NORM BETA			1	2			
	ACC BETA			1	2			
	NEUTRON			1	2			
	SPRAY	NA	NA	NA	NA	NA	NA	
ACCURACY - - -	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
SPEC: NA								
DEMO: NA								
ZONE NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECT TO								
SUBMERGENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 0588,CAT I								
MAINT/SURVEILL - - -								
REFERENCE: NOT REQUIRED								
QUALIFIED LIFE - - -								
(YEARS): SEE SHEET 2								
REFERENCE: 2								

- DOCUMENT REFERENCE:
- SPECIFICATION 242.491 ADD.3 / E&DCR P22.152
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6242.491-310-002C
 - POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV.0
 - CALCULATION NO. 12210-EQS-27

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 242491-1

REV 2

SHEET NO. 3


DATE 02/14/85

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Terminal blocks are tested at 125°C for operation, and an accident temperature of 165°F will not affect its operation. 186°F (85.5°C) temperature is used for operability period of 100 days plus margin.
 3. Specified pressure will have no effect on terminal board operation.
 4. Ninety-eight percent tested RH covers the 100-percent specified value for noncondensing relative humidity. Margin is not applicable.
 5. Specified and qualified radiation values include both gamma and beta. Specified value includes margin.


SPECIFIED ACCIDENT PROFILE

SRN 242491-1,2



SPECIFIED ACCIDENT PROFILE

SRN 242491-1,2



SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 242.491 SRN NO. 242491-1,2

T E M P E R A T U R E									
TIME	0	1SEC	5SEC	60SEC	1500SEC	3000SEC	1DAY	5DAYS	100 DAYS
LOG (MINU)	-3.00	-1.78	-1.08	0.00	1.40	1.70	3.16	3.86	5.16
TEMP (F)	122	160	165	165	155	140	140	122	122
TIME (MIN)	0.001	0.016666	0.083333	1	25	50	1440	7200	144000
P R E S S U R E									
TIME	0	1SEC	5SEC	60SEC	1500SEC	3000SEC	1DAY	5DAYS	100 DAYS
LOG (MINUT)	-3.00	-1.78	-1.08	0.00	1.40	1.70	3.16	3.86	5.16
PRES (PSIG)	0	2.8	2.8	2.1	2.1	1.3	1.3	-0.018	-0.018
TIME (MIN)	0.001	0.016666	0.083333	1	25	50	1440	7200	144000

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 242491-2
REV 1
DATE 13-Feb-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION						MARGIN DEMO	REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL METHOD		
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	OP. TIME:	100 DAYS	>100 DAYS	3	2	TESY-IDENT	YES	
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE-1
	NORMAL	122	130	1	2	TESY-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TYPE: (DESCRIPTION)	ACCIDENT	165	360	1	2	TEST-IDENT	YES	
TERMINAL CABINET SPLICE SEE NOTE-2	PRESS (PSIG)							NOTE-1
	NORMAL	ATMOS	ATMOS	1	2	TEST-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MANUFACTURER: RAYCHEM	ACCIDENT	2.8	70	1	2	TEST-IDENT	YES	
	RH (%)							NOTE-1
MODEL: SEE SHEET 2	NORMAL	90	100	1	2	TEST-IDENT	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
SAFETY FUNCTION: - - -	ACCIDENT	100	100	1	2	TEST-IDENT	NA	
LOW VOLTAGE CONTROL	RADIATION:							NOTE-1
TERMINATION & CKT CONTINUITY	NORM GAMMA							
	ACC GAMMA	1.2E6 TID	2E8	1	2	TES-IDENT	YES	NOTE-3
OP. CODE: SEE SHEET 2	NORM BETA							
	ACC BETA							
	NEUTRON							
	SPRAY	NA	NA	NA	NA	NA	NA	
ACCURACY - -	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
SPEC: NA								
DEMO: NA								
ZONE NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECT TO SUBMERGENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY: ACCEPTABLE TO NUREG 0589, CAT I								
MAINT/SURVEILL - - - REFERENCE: NOT REQUIRED								
QUALIFIED LIFE - - - (YEARS): SEE SHEET 2 REFERENCE: 2								

- DOCUMENT REFERENCE:
- SPECIFICATION 242.491 ADD.3 / E&DCR P22,152
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6211.161-997-015A & 012A
 - POST-ACCIDENT OPERABILITY PERIOD: SEE PADP DOCUMENT NO. 245.600, REV.0


RBS-ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 242 491-2
 REV 1
 SHEET NO 2
 DATE 1-15-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBING	QUAL. LIFE	OPTIME OC
SRN 242491-2				
SPEC 242.491				
RCP ELECTRICAL PENETRATIONS				
IRCP#TCA05				
IRCP#TCA07	SPLICE HVT/WCSF	AD-114-6	40 YRS	100D
IRCP#TCA11	SPLICE HVT/WCSF	AB-114-5	40 YRS	A 100D
	SPLICE HVT/WCSF	AB-141-4	40 YRS	A 100D A
IRCP#TCA13				
	SPLICE HVT/WCSF	AB-141-4	40 YRS	100D A
IRCP#TCA14				
	SPLICE HVT/WCSF	AD-141-3	40 YRS	100D A
IRCP#TCA16				
	SPLICE HVT/WCSF	AD-141-3	40 YRS	100D A
IRCP#TCF02				
	SPLICE HVT/WCSF	FB-113-G	40 YRS	100D A


SPECIFIED ACCIDENT PROFILE

SRN 242491-1,2



SPECIFIED ACCIDENT PROFILE

SRN 242491-1,2



SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 242.491 SRN NO. 242491-1,2

T E M P E R A T U R E									
TIME	0	1SEC	5SEC	60SEC	1500SEC	3000SEC	1DAY	5DAYS	100 DAYS
LOG (MINU	-3.00	-1.78	-1.08	0.00	1.40	1.70	3.16	3.86	5.16
TEMP (F)	122	160	165	165	155	140	140	122	122
TIME (MIN)	0.001	0.016666	0.083333	1	25	50	1440	7200	144000
P R E S S U R E									
TIME	0	1SEC	5SEC	60SEC	1500SEC	3000SEC	1DAY	5DAYS	100 DAYS
LOG (MINU	-3.00	-1.78	-1.08	0.00	1.40	1.70	3.16	3.86	5.16
PRES (PSIG)	0	2.8	2.8	2.1	2.1	1.3	1.3	-0.018	-0.018
TIME (MIN)	0.001	0.016666	0.083333	1	25	50	1440	7200	144000

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 242 491-3

REV 1

SHEET NO 2A

DATE 1-15-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBSTRG	QUAL. LIFE	OPTIME OC
SRN 242491-3				
SPEC 242.491				
RCP ELECTRICAL PENETRATIONS				
1RCP*TCR01A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR01F	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR02A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR02F	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR03A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR03F	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR04A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR04F	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR05A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR06A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR07A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR08A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 242 491-3
 REV 1
 SHEET NO 2B
 DATE 1-15-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBSTRG	QUAL. LIFE	OPTIME OC
SRN 242491-3				
SPEC 242.491				
RCP ELECTRICAL PENETRATIONS				
1RCP*TCR09A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR10A	SPLICE HVT/WCSF	CT-G	40 YRS	1000 A
1RCP*TCR11A	SPLICE HVT/WCSF	CT-7A	40 YRS	1000 A
1RCP*TCR12A	SPLICE HVT/WCSF	CT-7A	40 YRS	1000 A
1RCP*TCR13A	SPLICE HVT/WCSF	CT-7A	40 YRS	1000 A
1RCP*TCR14A	SPLICE HVT/WCSF	CT-5A	40 YRS	1000 A
1RCP*TCR15A	SPLICE HVT/WCSF	CT-5A	40 YRS	1000 A
1RCP*TCR16A		CT-5A	40 YRS	1000 A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 242533-2
REV 1
DATE 08-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION							REMARKS
	PARAMETER	SPECIFIED	DUALIFIED	DOCUMENT REFERENCE		DUAL	MARGIN:	
		VALUE	VALUE	SPECIFIED	DUALIFIED	METHOD	DEMO	
EQUIP NO.: SEE SHEET 2	OP. TIME:	100 DAYS	180 DAYS	3	2	TEST-SIM	YES	
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE-1
	NORMAL	114	114	1	2	TEST-SIM	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
TYPE: (DESCRIPTION)	ACCIDENT	135	155	1	2	TEST-SIM	YES	
TRANSFORMER FOR 480V LOAD CENTER	PRESS (PSIG)							NOTE-1
	NORMAL	ATMOS	ATMOS	1	2	TEST-SIM	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
MANUFACTURER: SOUTHERN TRANSFORMER	ACCIDENT	2.1	0	1	2	TEST-SIM	YES	NOTE-3
MODEL: SEE SHEET 2	RH (%)							NOTE-1
	NORMAL	90	100	1	2	TEST-SIM	NA	
	ABNORMAL	NA	NA	NA	NA	NA	NA	
SAFETY FUNCTION: - - -	ACCIDENT	100	100	1	2	TEST-SIM	NA	
PROVIDE 480V POWER	RADIATION:							NOTE-1
	NORM GAMMA	7E2		1	2	EXP+AN	NA	
	ACC GAMMA	12.05E4 T1D	4E8	1	2	EXP+AN	YES	NOTE-2
OP. CODE: SEE SHEET 2	NORM BETA			1	2		NA	
	ACC BETA			1	2		NA	
	NEUTRON			1	2		NA	
ACCURACY - -	SPRAY	NA	NA	NA	NA	NA	NA	
	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
ZONE NO.: SEE SHEET 2								
SUBMERGENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECT TO SUBMERGENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY:								
ACCEPTABLE TO NUREG 0588, CAT I								
MAINT/SURVEILL - - -								
REFERENCE: NOT REQUIRED								
QUALIFIED LIFE - - -								
YEARS: SEE SHEET 2								
REFERENCE: 2								

- DOCUMENT REFERENCE:
- SPECIFICATION 242.533 REV.1, ADD.1 / EMDCR P21427A
 - VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDP # 6242.533-265-011B
 - POST-ACCIDENT OPERABILITY PERIOD: SEE RAOP DOCUMENT NO. 245.600, REV.0

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 242533-2

REV 1

SHEET NO. 3

DATE 11/29/84

NOTES

-
1. For complete environmental conditions, see documents referenced.
 2. Threshold of radiation degradation exceeds $4E8$ rads. See Reference 2.
 3. Heat dissipation and dielectric strength are pressure-dependent characteristics. Both improve with increased pressure. See Reference 2. Testing at 0 psig versus 2.1 psig is conservative and adequately accounts for margin.

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247250-1
 REV 1
 SHEET NO. 2
 DATE 1-2-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBORG	QUAL. LIFE	OPTIME OC
SRN 247250-1				
SPEC 247.250				
RHS RADIATION MONITORING				
IRHS*REX125	RD-52, RD-72	AB-170-1	40 YEARS	1000 A
IRHS*REI25	RD-52, RD-72 REG.G.1.97	AB-170-1	40 YEARS	1000 A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247250-1

REV 1

SHEET NO. 3

DATE 11/27/84

NOTES

-
1. For complete environmental conditions, see the document referenced.
All temperature sensitive electronics are located in 2 inch thick lead box.
 2. The short duration of the temperature transient will not increase device temperature beyond qualified limits. See Reference 4.
 3. The monitor has no components that are pressure sensitive. A variation of 2 psig will have no effect on them.
 4. Vendor is to provide justification that the monitor can withstand 100-percent RH.
 5. Sample pump motor qualification is incomplete. Vendor is to prepare a quote and plan for testing motors to establish a qualified life at plant operating conditions.
 6. Qualified total integrated dose exceeds specified integrated dose plus margin.
 7. In accordance with Reference 2, GA Technologies will provide the necessary maintenance and surveillance schedule needed to maintain 40 years of qualified life.

EBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 247250-2
REV 1
DATE 21-Jan-85
SHEET 1

EQUIPMENT DESCRIPTION	ENVIRONMENTAL CONDITIONS AND QUALIFICATION		DOCUMENT REFERENCE		DUAL METHOD	MARGIN DFMU	REMARKS
	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	SPECIFIED			
EQUIP NO.: SEE SHEET 2	TOP. TIME:	100 DAYS	100 DAYS	3	2	TEST-SIM	YES
SYSTEM: SEE SHEET 2	TEMP (F):						
	NORMAL	96	131	1	2	TEST-SIM	NA
	ABNORMAL	122	131	1	2	TEST-SIM	NA
	ACCIDENT	122	131	1	2	TEST-SIM	YES
TYPE: (DESCRIPTION)	PRESS (PSIG)						
RADIOACTIVITY ELEMENT	NORMAL	-0.25" H2O	ATMOS	1	2	TEST-SIM	NA
(WIDE RANGE GAS MONITOR)	ABNORMAL	-0.62" H2O	ATMOS	1	2	TEST-SIM	NA
MANUFACTURER: GA TECH.	ACCIDENT	-0.62" H2O	ATMOS	1	2	TEST-SIM	YES
MODEL: SEE SHEET 2	VRH (%)						
	ABNORMAL	50	95	1	2	TEST-SIM	NA
	ABNORMAL	30	95	1	2	TEST-SIM	NA
SAFETY FUNCTION: - - -	ACCIDENT	30	95	1	2	TEST-SIM	NA
MONITOR RADIATION	RADIATION:						
	NUB-1 GAMMA	7E2		1			NA
	ACC GAMMA	2E5	5E5	1	2	AN+DATA	YES
TOP. CODE: SEE SHEET 2	NUB-1 BETA	0		1			NA
	ACC BETA	6E2		1			YES
	NEUTRON	0		1			NA
	SPRAY	NO	NA	NA	NA	NA	NA
ACCURACY - - -	SURBERGENESS	NO	NA	NA	NA	NA	NA
SPEC: NA							
DEMO: NA							
ZONE NO.: SEE SHEET 2							
SURBERGENESS:	DOCUMENT REFERENCE:						
SPRAY/FROTH:	1. SPECIFICATION 247.250 REV.0, ADD.1 / EBCR NO. P40,957A						
EQUIPMENT NOT SUBJECTED TO	2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT,						
SURBERGENESS OR SPRAY/FROTH	SIDE # 6247.250-329-044C						
	6247.250-329-027E						
	6247.250-329-091A						
	6247.250-329-091C						
DOCUMENTATION ACCEPTABILITY:	6247.250-329-020C						
NUREG 0589, CAT	6247.250-329-019B						
ACCEPTABLE FOR ALL ITEMS	6247.250-329-091B						
EXCEPT SAMPLE PUMP MOTOR,	6247.250-329-121A						
SEE NOTE 1	6247.250-329-059B						
	3. POST-ACCIDENT OPERABILITY PERIOD: SEE						
MAINT/SURV HEL - - -	GROUP DOCUMENT NO. 247.600, REV.0						
REFERENCE: 2 (NOTE-3)							
QUALIFIED LIFE - - -							
GENCO: SEE SHEET 2							
REFERENCE: 2							

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247250-2
REV 1
SHEET NO. 2
DATE 1-2-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUB:RG	QUAL. LIFE	OPTIME OC
SRN 247250-2				
SPEC 247.250				
RHS RADIATION MONITORING				
IRHS<REXSA	RD-52, RD-72	FB-148-G	40 YEARS	1000 A
IRHS<RESA	RD-52, RD-72	FB-148-G	40 YEARS	1000 A
	REG.G.1.97			

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM
RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247250-3
REV 1
SHEET NO. 2
DATE 1-2-85

 MARK NO
 MODEL/CATALOG NO. ENV. ZONE QUAL. LIFE OPTIHE
 REMARKS SUBGRS CC

SRN 247250-3

SPEC 247.250

RHS RADIATION MONITORING

1RHS*RE11A

RD-52

AD-170-2

40 YEARS

1 HR
A

1RHS*RE11B

RD-52

AD-170-2

40 YEARS

1 HR
A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247250-3

REV 1

SHEET NO. 3

DATE 11/27/84

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Operability period of the monitor is 1 hour. TID of gamma for 6 hours is 6.8 rads; TID of gamma for 180 days is 2.2E2. The technical basis for placement of this equipment in operability Code C after 6 hours will be addressed in the EQD.
 3. Operability period of the monitor is 1 hour. TID of beta for 6 hours is 6.6 rads; TID of beta for 180 days is 4.5E2. The technical basis for placement of this equipment in operability Code C after 6 hours will be addressed in the EQD.
 4. Sample pump motor qualification is incomplete. Vendor is to prepare a quote and plan for testing motors to establish a qualified life at plant operating conditions.
 5. In accordance with Reference 2, GA Technologies will provide the necessary maintenance and surveillance schedule needed to maintain 40 years of qualified life.
 6. Specified accident conditions are for LOCA. Justification for the technical basis for placement of this equipment in operability Code C during HELB will be addressed in the EQD.

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM
 RDS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247250-4
 REV 1
 SHEET NO. 2
 DATE 1-2-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCHRG	QUAL. LIFE	OPTIME OC
SRN 247250-4				
SPEC 247.250				
RHS RADIATION MONITORING				
1RHS*PE111	RD-56	CT-6	40 YEARS	N/A C
1RHS*RE112	RD-56	CT-4	40 YEARS	N/A C

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247250-4

REV 1

SHEET NO. 3

DATE 11/27/84

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. Monitor is designed to trip at high temperature; therefore, it will not fail and degrade associated Class 1E equipment.
 3. Monitor has no components that are pressure sensitive; therefore, a variation of 2.3 psig in pressure will have no effect on it.
 4. Vendor is to provide justification that the monitor can withstand 100-percent RH.
 5. Beta radiation has no effect on the monitor since the monitor is totally enclosed. See Reference 2.
 6. Sample pump motor qualification is incomplete. Vendor is to prepare a quote and plan for testing motors to establish a qualified life at plant operating conditions.
 7. In accordance with Reference 2, GA Technologies will provide the necessary maintenance and surveillance schedule needed to maintain 40 years of qualified life.

EPB - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 247250-5

REV 1

DATE 21-Jan-85

SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUALIFIED	QUALIFIED REFERENCE	QUALIFIED	METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED						
EQUIP NO.: SEE SHEET 2	TEMP (F):	100 DAYS	100 DAYS	3	2	TEST-SIM	YES	TEST-SIM	YES		
SYSTEM: SEE SHEET 2	NORMAL	122	131	1	2	TEST-SIM	NA	TEST-SIM	NA		NOTE-1
TYPE: (DESCRIPTION)	ABNORMAL	NA	NA	NA	NA	TEST-SIM	NA	TEST-SIM	NA		
RADIOACTIVITY ELEMENT (LIQUID MONITOR)	ACCIDENT	122	131	1	2	TEST-SIM	YES	TEST-SIM	YES		
MANUFACTURER: GA TECH	NORMAL	ATMOS	ATMOS	1	2	TEST-SIM	NA	TEST-SIM	NA		NOTE-1
MODEL: SEE SHEET 2	ABNORMAL	NA	NA	NA	NA	TEST-SIM	NA	TEST-SIM	NA		
SAFETY FUNCTION: - - -	ACCIDENT	90	95	1	2	TEST-SIM	NA	TEST-SIM	NA		NOTE-1
MONITOR RADIATION	ACCIDENT	90	95	1	2	TEST-SIM	NA	TEST-SIM	NA		NOTE-2
TOP. CODE: SEE SHEET 2	NORM GAMMA	9.6E1	1.1E3	1	2	AN+DATA	YES	AN+DATA	YES		NOTE-3
ACCURACY - -	ACC GAMMA	6.5E2	1.1E3	1	2	AN+DATA	NA	AN+DATA	NA		
SPEC: NA	NORM BETA	0	0	1	1		YES		YES		
DEMO: NA	ACC BETA	4.5E2	0	1	1		NA		NA		
EQUIP NO.: SEE SHEET 2	NEUTRON	0	0	1	1		NA		NA		
EMERGENCE OR SPRAY/FROTH	EMERGENCE	NA	NA	1	1		NA		NA		
EMERGENCE OR SPRAY/FROTH	EMERGENCE	NA	NA	1	1		NA		NA		

DOCUMENT REFERENCE:
1. SPECIFICATION 247.00 REV.0, ADD.1 / EXDOR NO. P40,957A
2. VIATOR ENVIRONMENTAL QUALIFICATION REPORT,

- SHEET # 6247, 2500-329-022B
- 6247, 2500-329-023E
- 6247, 2500-329-091A
- 6247, 2500-329-091C
- 6247, 2500-329-091D
- 6247, 2500-329-091E
- 6247, 2500-329-045B, 044C

3. POST-ACCIDENT OPERATIONAL PERIOD: 54E
GROUP DOCUMENT NO. 245,600, REV.0

DOCUMENTATION ACCEPTABILITY:
NUR6 0588,CAT

ACCEPTABLE FOR ALL ITEMS
EXCEPT TABLE PUMP MOTOR.
SEE NOTE 4

MAIN/DRAW ILL - - -
REFER PAGE 2 (NOTE-5)

FORM FEED ILL - - -
VALUES: SEE SHEET 2
REFERENCES: 2

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247250-5
 REV 1
 SHEET NO. 2
 DATE 1-2-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBRG	QUAL. LIFE	OPTIME OC
SRN 247250-5				
SPEC 247.250				
RHS RADIATION MONITORING				
IRHS*RE15A	RD-56	AB-095-6	40 YEARS	1000 A
IRHS*RE15B	RD-56	AB-095-6	40 YEARS	1000 A

THE OPERATIONAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	VOLUME REFERENCE		QUAL METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED			
EQIP NO.: SEE SHEET 2	TEMP (F):	100 DAYS	100 DAYS	2	2	AN+DATA	YES	
SYSTEM: SEE SHEET 2	NORMAL	140	140	1	2	TEST-SIM	NA	NOTE-1
	ABNORMAL	140	140	1	2	TEST-SIM	NA	
TYPE: (DESCRIPTION)	ACCIDENT	370	370	1	2	TEST-SIM	YES	
	PRESSURE(S)							
RADIOACTIVITY ELEMENT (HIGH RANGE RADIATION MONITOR)	NORMAL	0.5	0.1985	1	2	AN+DATA	NA	NOTE-1
	ABNORMAL	2.3	70	1	2	AN+DATA	NA	NOTE-2
MANUFACTURER: GA TECH	ACCIDENT	8 TO 25	70	1	2	TEST-SIM	YES	
	PR (%)							
MODEL: SEE SHEET 2	NORMAL	50	97	1	2	TEST-SIM	NA	
	ABNORMAL	100	100	1	2	TEST-SIM	NA	
SAFETY FUNCTION: MONITOR RADIATION	ACCIDENT	100	100	1	2	TEST-SIM	NA	
OP. CODE: SEE SHEET 2	NORM GAMMA	1.3EB	3EB	4	2	TEST-SIM	YES	
	ACC GAMMA							
ACCURACY	NORM BETA							
	NEUTRON							
SPEC: NA	SPRAY	NO	NO	NA	NA	NA	NA	
	DEMO: NA	NA	NO	NA	NA	NA	NA	

DOCUMENT REFERENCE:

- SPECIFICATION 247,000 TO V.O. ADD.1 / EDCR NO. P40,957A
- VIENOR ENVIRONMENTAL QUALIFICATION REPORT

SIDE # 6247,250-329-0210

6247,250-329-0210

6247,250-329-0430

6247,250-329-0200

6247,250-329-0910

6247,250-329-0440

6247,250-329-0190

6247,250-329-0910

6247,250-329-0910

6247,250-329-0430

3. FIRST-ACCIDENT OPERABILITY PERIOD: SEE

PAGE DOCUMENT NO. 247,600, REV.0

4. CALCULATION NO. 12210-110-63

EQUIPMENT NOT SUBJECTED TO

SUBMERGENCE OR SPRAY/FROTH

DOCUMENTATION ACCEPTABILITY:

NURES 0580, CAT 1

ACCEPTABLE FOR ALL ITEMS

EXCEPT DETECTOR SIGNAL CABLE.

SEE NOTE 3

MAINT/SUBMIT -

REFERENCE: NOT REQUIRED

FORM USED DIFF -

CONTROL: SEE SHEET 2

REFERENCE: 2

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247250-6
 REV 1
 SHEET NO. 2
 DATE 1/2/85

MARK NO

MODEL/CATALOG NO.
 REHARNS

ENV. ZONE
 SUBORG

QUAL. LIFE

OPTIME
 OC

SRN 247250-6

SPEC 247.250

RHS RADIATION MONITORING

IRHS*RE16A

RD-23
 REG.G.1.97

CT-G

40 YEARS

1000
 A

IRHS*RE16B

RD-23
 REG.G.1.97

CT-G

40 YEARS

1000
 A

IRHS*RE20A

RD-23
 REG.G.1.97

DH-1

40 YEARS

1000
 A

IRHS*RE20B

RD-23
 REG.G.1.97

DH-1

40 YEARS

1000
 A

KRS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SN 247-50-7
REV 1
DATE 21-Jan-85
SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE		QUAL. METHOD	MARGIN DEMO	REMARKS
				SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	TOP. TIME:	100 DAYS	100 DAYS	3	2	AN+DATA	YES	NOTE-1
SYSTEM: SEE SHEET 2	NORMAL	90	160	1	2	AN+DATA	NA	
	ABNORMAL	140	160	1	2	AN+DATA	NA	
	ACCIDENT	165	265	1	2	AN+DATA	YES	
TYPE: (DESCRIPTION)	(PRESSURE/SIG)							
RADIOACTIVITY ELEMENT (AREA MONITOR)	NORMAL	-1.0"H2O	ATMOS	1	2	TEST-SIM	NA	NOTE-1
	ABNORMAL	2.5	ATMOS	1	2	AN+DATA	NA	NOTE-2
MANUFACTURER: GA TECH.	ACCIDENT	9	ATMOS	1	2	AN+DATA	NA	NOTE-1
	TRH (C)							
MODEL: SEE SHEET 2	NORMAL	50	95	1	2	TEST-SIM	NA	
	ABNORMAL	100	95	1	2	AN+DATA	NA	NOTE-3
SAFETY FUNCTION: - - -	ACCIDENT	100	95	1	2	AN+DATA	NA	NOTE-3
MONITOR RADIATION	RADIATION:							
	NORM GAMMA	8E3		1	1		NA	
	ACC GAMMA	1.6E7	1FB	1	2	AN+DATA	YES	
OP. CODE: SEE SHEET 2	NORM BETA	2E3		1	1		NA	
	ACC BETA	1.5E8		1	1		YES	
	NEUTRON	0		1	1		NA	
	SPRAY	NA	115	NA	NA	NA	NA	
ACCURACY - -	SUBSEQUENCE:	NA	NA	NA	NA	NA	NA	
SPEC: NA								
DEMO: NA								
ZONE NO.: SEE SHEET 2								
SUBSEQUENCE:								
SPRAY/FROTH:								
EQUIPMENT NOT SUBJECTED TO SUBSEQUENCE OR SPRAY/FROTH								
DOCUMENTATION ACCEPTABILITY: ACCEPTABLE TO NUREG 0588, CAT 1								
MAINT/SUBSEILL - - -								
REFERENCE: NOT REQUIRED								
QUALIFIED LIFE - - -								
REFERENCE: SEE SHEET 2								
REFERENCE: 2								

DOCUMENT REFERENCE:
 1. SPECIFICATION 247.250 REV.0, ADD.1 / EMDER NO. F40,957A
 2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT,
 SDDP # 6247.250-329-0156
 6247.250-329-0158
 6247.250-329-0434
 6247.250-329-0918
 6247.250-329-023E
 6247.250-329-024E
 6247.250-329-091A, 044C
 3. POST-ACCIDENT RELIABILITY PERIOD: SEE PAUP DOCUMENT NO. 245,600, REV.0

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HAPSH ENVIRONMENT ONLY

SRN 247250-7
 REV 1
 SHEET NO. 2
 DATE 1-2-85

 MARK NO *****
 MODEL/CATALOG NO. ENV. ZONE QUAL. LIFE OPTIME
 REMARKS SUBNO OC

SRN 247250-7
 SPEC 247.250
 RBS RADIATION MONITORING

MODEL/CATALOG NO.	ENV. ZONE	QUAL. LIFE	OPTIME
RD-8	CT-5A	40 YEARS	1000 A
RD-8	CT-5A	40 YEARS	1000 A

IRMS#RE21A
 IRMS#RE21B

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247250-7

REV 1

SHEET NO. 3

DATE 11/27/84

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. This monitor is an ion chamber, and its construction is similar to the high-range radiation monitor (RD-23). See SRN 247250-6. It has no pressure-sensitive component; therefore, specified pressure will have no effect on it.
 3. This monitor is an ion chamber, and it has no component that can be affected by humidity; therefore, 100-percent RH will have no effect on it.

RES - ENVIRONMENTAL QUALIFICATION PROGRAM
 SYSTEM COMPONENT EVALUATION WORK SHEET
 ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE	QUALIFIED	DUAL METHOD	MARGIN DEMO	REMARKS
EQUIP NO.: SEE SHEET 2	OP. TIME:	1 HR	6 HRS		2	TEST-SIM	YES	
SYSTEM: SEE SHEET 2	TEMP (°):							NOTE-1
	NORMAL	96	131		2	TEST-SIM	NA	
	ABNORMAL	122	131		2	TEST-SIM	NA	
	ACCIDENT	122	131		2	TEST-SIM	YES	
TYPE: (DESCRIPTION)	PRESS (PSIG)							NOTE-1
RADIATION ELEMENT	NORMAL	-0.25" H2O	61PHOS		2	TEST-SIM	NA	
(PLOG MONITOR)	ABNORMAL	-0.62" H2O	61PHOS		2	TEST-SIM	NA	
MANUFACTURER: GA TECH.	ACCIDENT	-0.62" H2O	61PHOS		2	TEST-SIM	YES	
MODEL: SEE SHEET 2	RH (%):							NOTE-1
	NORMAL	55	95		2	TEST-SIM	NA	
	ABNORMAL	38	95		2	TEST-SIM	NA	
SAFETY FUNCTION:	ACCIDENT	38	95		2	TEST-SIM	NA	
MONITOR RADIATION	RADIATION:							NOTE-1
	NORM GAMMA	7E2			1		NA	
	ACC GAMMA	3E2	1.1E3		2	AN+DATA	YES	
OP. CODE: SEE SHEET 2	NORM BETA	0			1		NA	NOTE-2
	ACC BETA	6E2			1		YES	
	NEUTRON	0			1		NA	NOTE-3
ACCURACY	SPRAY	NA	NA		NA	NA	NA	
	SURFERENCE	NA	NA		NA	NA	NA	
	SPEC:	NA						
	DEMO:	NA						

DOCUMENT REFERENCE:

1. SUBJECT FOR 247,250 U.V.O., ADD.1 / F&DCK NO.P40,957A
2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDR # 6-47,250-309-0491
 6-47,250-309-0428
 6-47,250-309-0498
 6-47,250-309-0458
 6-47,250-309-0914
 6-47,250-309-0471
 6-47,250-309-0414
 6-47,250-309-0414
3. FIRST-ACCIDENT OPERATIONAL PERIOD: SEE PUMP DOCUMENT NO. 247,250, REV.0

EQUIPMENT NOT SUBJECTED TO SURBURGENCE OR SPRAY/FROTH

DOCUMENTATION ACCEPTABILITY: NUREG 0588, CAT 1

ACCEPTABLE FOR ALL IIFMG EXCEPT SAMPLE PUMP MOTOR.

SEE NO.:

MAINT/SUAVELL - - -

REFERENCE: 2 (NOTE-4)

QUALIFIED LIFE - - -

YEARS: SEE SHEET 2

REFERENCE: 2

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247250-8
 REV 1
 SHEET NO. 2
 DATE 1-2-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUZ:RG	QUAL. LIFE	OPTIME OC
SRN 247250-8				
SPEC 247.250				
RHS RADIATION MONITORING				
IFHS-RESB	RD-56 REG.G.1.97	FD-148-G	40 YEARS	1 HR A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARD ENVIRONMENT ONLY

SRN - 247250-9
 REV 1
 SHEET NO. 2
 DATE 1-2-85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBGRG	QUAL. LIFE	CPTIME OC
SRN 247250-9				
SPEC 247.250				
RHS RADIATION MONITORING				
1RHS*RI21A	RL-10 N/R FOR SAFETY FUNCTION	CT-5A	40 YEARS	N/R C
1RHS*RI21B	RL-10 N/R FOR SAFETY FUNCTION	CT-5A	40 YEARS	N/R C

RBS- ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFIC. DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SKN 247411-2
 Rev. 1
 Sheet 2
 Date: 15 JAN 85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBIRG	QUAL. LIFE	OPTIME OC
SRN 247411-2				
SPEC 247.411				
JPB SUPERSTRUCTURE - PRIMARY AUXILIARY BUILDING				
1JPB*RAK1	NQB-112 Terminal Boards	AB-095-6	40 Years	1000 A
1JPB*RAK2	NQB-112 Terminal Boards	AB-095-6	40 Years	1000 A
1JPB*RAK3	NQB-112 Terminal Boards	AB-141-2	40 Years	1000 A
1JPB*RAK4	NQB-112 Terminal Boards	AB-141-1	40 Years	1000 A

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM
SYSTEM COMPONENT EVALUATION WORK SHEET

SRN 247433-2
REV 1
DATE 08-Jan-85
SHEET 1

ENVIRONMENTAL CONDITIONS AND QUALIFICATION								
EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED	QUALIFIED	DOCUMENT REFERENCE		QUAL. METHOD	MARGIN DEMO	REMARKS
		VALUE	VALUE	SPECIFIED	QUALIFIED			
EQUIP NO.: SEE SHEET 2	OP.TIME:	100 DAYS		3	2			
SYSTEM: SEE SHEET 2	TEMP (F):							NOTE-1
TYPE: (DESCRIPTION) ELECTRONICS FOR FLOW DETECTING ELEMENTS	NORMAL	122		1	2			
	ABNORMAL	140		1	2			
	ACCIDENT	165		1	2			
MANUFACTURER: FLUID COMPONENTS INC.	PRESS (PSIG)							NOTE-1
	NORMAL	ATMOS		1	2			
	ABNORMAL	2.3		1	2			
MODEL: SEE SHEET 2	ACCIDENT	9		1	2			
	IRH (%)							NOTE-1
	NORMAL	90		1	2			
SAFETY FUNCTION: - - - CONTINUING OPERATION OF SAFETY SYSTEMS	ABNORMAL	100		1	2			
	ACCIDENT	100		1	2			NOTE-1
	RADIATION:							
OP. CODE: SEE SHEET 2	NORM GAMMA			1	2			
	ACC GAMMA	.9E6 TID		1	2			NOTE-3
	NORM BETA			1	2			
ACCURACY - - SPEC: NA DEMO: NA	ACC BETA			1	2			
	NEUTRON			1	2			
	SPRAY	NA	NA	NA	NA	NA	NA	
SUBMERGENCE OR SPRAY/FROYH	SUBMERGENCE	NA	NA	NA	NA	NA	NA	
	DOCUMENT REFERENCE:							
	1. SPECIFICATION 247.433 REV.0, ADD.3							
2. VENDOR ENVIRONMENTAL QUALIFICATION REPORT, SDDF # 6247.433-315-002C (TEST PLAN)								
3. POST-ACCIDENT OPERABILITY PERIOD: SEE PAOP DOCUMENT NO. 245.600, REV.0								
DOCUMENTATION ACCEPTABILITY:	NUREG 0588, CAT I							
QUALIFICATION IN PROGRESS (SEE NOTE-2)								
MAINT/SURVEILL - - - REFERENCE:								
QUALIFIED LIFE - - - (YEARS): SEE SHEET 2 REFERENCE:								

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247461-1

REV 1

SHEET NO. 3

DATE 01/16/85

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. PAOP extended from 30 days to 100 days. See Reference 2.
 3. Abnormal temperature, pressure, and relative humidity are addressed in Reference 4.
 4. Terminal head gasket must be replaced when terminal head cover is removed in order to maintain qualification.
 5. Factory certification testing of RTDs has a demonstrated accuracy of $<\pm 1.0^{\circ}\text{F}$. The qualification type testing has shown an accuracy of $\pm 1.2^{\circ}\text{F}$. A review of setpoint calculations is in progress to determine whether $\pm 1.2^{\circ}\text{F}$ is an acceptable accuracy.

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247461-2

REV 1

SHEET NO. 3

DATE 01/16/85

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. PAOP extended from 30 days to 100 days. See Reference 2.
 3. Abnormal temperature, pressure, and relative humidity are addressed in Reference 4.
 4. Terminal head gasket must be replaced with a new gasket whenever head cover is removed in order to maintain qualification.
 5. Factory certification testing of RTDs has a demonstrated accuracy of $<\pm 1.0^{\circ}\text{F}$. The qualification type testing has shown an accuracy of $\pm 1.2^{\circ}\text{F}$. A review of the set-point calculations is in progress to determine whether $\pm 1.2^{\circ}\text{F}$ is an acceptable accuracy.
 6. Equipment in containment below 109 ft is subject to submergence and between 109 ft and 120 ft is subject to spray/froth as a result of pool swell. The Yes shown on page 2 for submergence applies to the RTD thermowell, which is always submerged to measure suppression pool water temperature. The RTD termination head cover is subjected to spray/froth for only 7 seconds.

RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247461-3

REV 1

SHEET NO. 3

DATE 01/16/85

NOTES

-
1. For complete environmental conditions, see the document referenced.
 2. PAOP extended from 30 days to 100 days. See Reference 2.
 3. Abnormal temperature, pressure, and relative humidity are addressed in Reference 4.
 4. Terminal head gasket must be replaced with a new gasket whenever head cover is removed in order to maintain qualification.
 5. Factory certification testing of RTDs has demonstrated accuracy of $<\pm 1.0^{\circ}\text{F}$. The qualification type testing has shown an accuracy of $\pm 1.2^{\circ}\text{F}$. A review of the setpoint calculations is in progress to determine whether $\pm 1.2^{\circ}\text{F}$ is an acceptable accuracy.

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247481-1
 Rev. 1
 Sheet No 2A
 Date: 7 FEB 85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCMRG	QUAL. LIFE	OPTIME OC	SPEC ACC DEMO ACC

SRN 247481-1					
SPEC 247.481					
CCP COMPONENT COOLING - PRIMARY CONTAINMENT OR REACTOR					
1CCP*PT1A	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
1CCP*PT1B	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
1CCP*PT1C	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
1CCP*PT1D	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
1CCP*PT1E	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
1CCP*PT1F	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
1CCP*PT1G	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
1CCP*PT1H	1153GB7	AB-070-8	15.5 Years	100D A	15.0% 6.5%
CHS CONTAINMENT ATMOSPHERE MONITORING					
1CHS*LT23A	1153DBEPG, 1159C6CA Notes 6,5	CT-SP V	20 Years	100D A	14.7%
1CHS*LT23B	1153DBEPG, 1159C6CA Notes 6,5	CT-SP Y	20 Years	100D A	Later 14.7%
1CHS*PDT29A	1153DB6	AB-141-1	14.7 Years	100D A	2.9% 1.4%

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247481-1
 Rev. 1
 Sheet No 2B
 Date: 7 FEB 85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	QUAL. LIFE	OPTIME CC	SPEC ACC DEMO ACC

SRN 247481-1					
CHS CONTAINMENT ATMOSPHERE MONITORING					
1CHS*PDT29B	1153DB4	AB-141-2	14.7 years	100D A	2.9% 1.4%
1CHS*PT2A	1153AB6	AB-141-1	14.7 years	100D A	N/R 1.9%
1CHS*PT2B	1153AB6	AB-141-2	14.7 years	100D A	N/R 1.9%
1CHS*PT4A	1153AB6	AB-141-1	14.7 years	100D A	N/R 1.9%
1CHS*PT4B	1153AB6	AB-141-2	14.7 years	100D A	N/R 1.9%
DFR DRAINS - REACTOR PLANT FLOOR					
1DFR*LT134	1153DB4PG, 1159C30A	AB-070-1	20 years	100D A	11.2% 10.8%
1DFR*LT135	1153DB4PG, 1159C30A	AB-070-2	16.7 years	100D A	10.8% 10.8%
1DFR*LT136	1153DB4PG, 1159C30A NOTE 5	AB-070-3	18.2 years	100D A	10.8% 16.0%
1DFR*LT137	1153DB4PG, 1159C30A	AB-070-4	20 years	100D A	11.2% 13.2%
1DFR*LT138	1153DB4PG, 1159C30A NOTE 5	AB-070-5	15.7 years	100D A	10.8% 10.8%
1DFR*LT139	1153DB4PG, 1159C30A	AB-070-6	20 years	100D A	11.2% 10.8%
HVR VENTILATION - REACTOR PLANT					
1HVR*PDT60A	1153DB3PA	AB-141-2	14.7 years	100D A	2.6% 2.6%
1HVR*PDT60B	1153DB3PA	AB-141-2	14.7 years	100D A	2.6% 2.6%
1HVR*PDT60C	1153DB3PA	AB-141-2	14.7 years	100D A	2.6% 2.6%

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247481-1
 Rev. 1
 Sheet No 2C
 Date: 7 FEB 86

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMG	QUAL. LIFE	OPTIME OC	SPEC ACC DEMO ACC

SRN 247481-1					
HVR VENTILATION - REACTOR PLANT					
1HVR*PDT60D	1153DE3PA	AB-141-2	14.7 years	1000 A	2.6% 2.6%
1HVR*PDT60E	1153DB3PA	AD-141-2	14.7 years	1000 A	2.6% 2.6%
1HVR*PDT60F	1153DB3PA	AB-141-2	14.7 years	1000 A	2.6% 2.6%
IAS INSTRUMENT AIR					
1IAS*PT39A	1153GB7 NOTE 5	AB-141-5	15.5 years	1NR A	3.0% 7.5%
1IAS*PT39B	1153GB7 NOTE 5	AB-141-6	15.5 years	1000 A	3.0% 7.5%
1IAS*PT43A	1153GB7	FB-140-G	20 years	1000 A	2.0% 2.0%
1IAS*PT43B	1153GB7	FB-148-G	20 years	1000 A	2.0% 2.0%
1IAS*PT48A	1153GB7 NOTE 5	AB-141-5	15.5 years	1000 A	6.0% 15.0%
1IAS*PT48B	1153GB7 NOTE 5	AD-141-6	13.3 years	1000 A	6.0% 16.0%
1IAS*PT49A	1153GB7 NOTE 5	FB-140-G	20 years	1000 A	2.0% 3.9%
1IAS*PT49B	1153GB7 NOTE 5	FB-148-G	20 years	1000 A	2.0% 3.9%

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247481-1
 Rev. 1
 Sheet No. 2 D
 Date: 7 FEB 85

HARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCHRG	QUAL. LIFE	OPTIME OC	SPEC ACC DEMO ACC
SRN 247481-1					
ISC					
1ISC*PT101	1153GB9PA	CT-G	20 years	N/R B	N/R 10.3%
LSV LEAKAGE CONTROL - PENETRATION VALVE					
1LSV*PT10A	1153GB6PA	AD-141-2	14.7 years	30 D A	3.4% 2.6%
1LSV*PT10B	1153GB6PA	AB-141-2	14.7 years	30 D A	3.4% 5.6%
1LSV*PT12A	1153GB6PA	AB-141-2	14.7 years	30 D A	4.4% 2.6%
1LSV*PT12B	1153GB6PA	AB-141-2	14.7 years	30 D A	4.4% 2.6%
1LSV*PT14A	1153GB6PA	AD-114-6	13.3 years	30 D A	4.4% 4.4%
1LSV*PT14B	1153GB6PA	AB-141-2	14.7 years	30 D A	2.6% 2.6%
1LSV*PT17A	1153GB6PA	AB-095-2	18 years	30 D A	4.4% 4.4%
1LSV*PT17B	1153GB6PA	AB-141-2	14.7 years	30 D A	4.4% 2.6%
1LSV*PT21A	1153GB6PA	AB-114-6	13.3 years	30 D A	4.4% 4.4%
1LSV*PT21B	1153GB6PA	AB-114-5	13.3 years	30 D A	4.6% 4.6%
1LSV*PT22A	1153GB7 NOTE 5	AB-141-2	14.7 years	30 D A	1.8% 2.7%

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM
RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247481-1
Rev. 1
Sheet No 2 E
Date: 7 FEB 85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBERG	QUAL. LIFE	OPTIME OC	SPEC ACC DAMO ACC

SRN 247481-1					
LSV LEAKAGE CONTROL - PENETRATION VALVE					
1LSV*PT2CB	1153GB7 NOTE 5	AB-114-3	17.9 years	30 D A	1.8 % 4.4 %
1LSV*PT26A	1153GB7PA	AB-141-2	14.7 years	30 D A	6.5 % 3.9 %
1LSV*PT26B	1153GB7PA	AB-114-3	15.5 years	30 D A	6.5 % 6.5 %
1LSV*PT9A	1153GB7	AB-141-2	14.7 years	30 D A	4.8 % 2.7 %
1LSV*PT9B	1153GB7	AB-114-3	15.5 years	30 D A	4.8 % 4.4 %
RHS RESIDUAL HEAT REMOVAL SYSTEM					
1RHS*FT15B	1153DB6PA	AB-095-5	15.5 years	N/R B	N/R 1.6 %
1RHS*FT15C	1153DB6PA	AB-095-6	17.7 years	N/R B	N/R 1.6 %
1RHS*LT119	1153DB6PA	CT-G	20 years	N/R B	N/R 1.8 %
SFC SPENT FUEL POOL COOLING AND CLEAN-UP					
1SFC*LT11A	1153DB4PG, 1159C10A NOTE 5	CT-5A	20 years	N/R A	3.4 % 7.0 %
1SFC*LT11B	1153DB4PG, 1159C10A NOTE 5	CT-G	20 years	N/R A	3.4 % 7.0 %

RBS ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247481-1
 Rev. 1
 Sheet No 2 F
 Date 7 FEB 85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUEHRG	QUAL. LIFE	OPTIME OC	SPEC ACC DEMO ACC

SRN 247481-1					
SFC SPENT FUEL POOL COOLING AND CLEAN-UP					
1SFC*LT28A	11530B4PG,1159C10A	FB-113-1	20 Years	100D A	7.0% 7.0%
1SFC*LT28B	11530B4PG,1159C10A	FB-113-1	20 Years	100D A	7.0% 7.0%
SNP SERVICE WATER					
1SNP*FT59A	11530B4	FB-095-G	10.7 Years	100D A	N/R 1.7%
1SNP*FT59B	11530B4	FB-095-G	10.7 Years	100D A	N/R 1.7%
1SNP*FT60A	11530B4	FB-095-G	10.7 Years	100D A	N/R 1.7%
1SNP*FT60B	11530B4	FB-095-G	10.7 Years	100D A	N/R 1.7%
1SNP*FT64A	11530B5	PT-3	18 Years	100D A	N/R 4.9%
1SNP*FT64B	11530B5	PT-3	18 Years	100D A	N/R 4.9%
1SNP*PT21A	1153GB7	PT-3	15.5 Years	100D A	3.3% 3.3%
1SNP*PT21B	1153GB7	PT-3	15.5 Years	100D A	3.3% 3.3%
1SNP*PT21C	1153GB7	PT-3	15.5 Years	100D A	3.3% 3.3%
1SNP*PT21D	1153GB7	PT-3	15.5 Years	100D A	3.3% 3.3%

RBS-ENVIRONMENTAL QUALIFICATION PROGRAM
 RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY SRN, SPEC, THEN SYSTEM - HARSH ENVIRONMENT ONLY

SRN 247481-1
 Rev 1
 Sheet No 2G
 Date 7 FEB 85

MARK NO	MODEL/CATALOG NO. REMARKS	ENV. ZONE SUEHRG	QUAL. LIFE	OPTIME OC	SPEC ALL DEMO ALL
SRN 247481-1					
SHP SERVICE WATER					
1SHP#PT21E	1153GB7	PT-3	15.5 Years	1000 A	3.3% 3.3%
1SHP#PT21F	1153GB7	PT-3	15.5 Years	1000 A	3.3% 3.3%
1SHP#PT21G	1153GB7	PT-3	15.5 Years	1000 A	3.3% 3.3%
1SHP#PT21H	1153GB7	PT-3	15.5 Years	1000 A	3.3% 3.3%


RBS - ENVIRONMENTAL QUALIFICATION PROGRAM

SRN 247481-1
REV 1
SHEET NO. 3
DATE 02/07/85


NOTES

-
1. For complete environmental conditions, see SWEC Document No. 215.150, Revision 2, 1984.
 2. See Calculation No. 12210-EQS-24, Revision 0 for qualified life at service temperatures.
 3. The transmitter is hermetically sealed and not affected by beta.
 4. Factory certification testing of transmitters shows factory-calibrated accuracies of less than 0.25 percent of calibrated span.
 5. Where demonstrated accuracies exceed specified accuracies, SWEC will reevaluate setpoint criteria. Scheduled completion is March 31, 1985. Where required accuracies still exceed demonstrated accuracies after reevaluation, the instruments will be relocated or shielded to meet requirements.
 6. Only the capillary seals are subject to submergence; transmitters are above submergence and spray/froth level.

TEST PROFILE
211.161 SDDF 211.161-997-015A



TEST PROFILE
211.161 SDDF 211.161-997-015A




TEST PROFILE DATA FOR 211.161-997-015A

TEMPERATURE					
TIME	5HRS	6HRS	24HRS	120DAYS	100DAYS
LOG(MINU)	2.48	2.56	3.16	4.24	5.16
TEMP(F)	360	320	250	221	212
TIME(MIN)	300	360	1440	17280	144000

PRESSURE					
TIME	5HRS	6HRS	24HRS	120DAYS	100DAYS
LOG(MINUT)	2.48	2.56	3.16	4.24	5.16
PRES(PSIG)	70	70	21	2.5	2
TIME(MIN)	300	360	1440	17280	144000


TEST PROFILE

215.252 SDDF 6215.252-057-001F



TEST PROFILE

215.252 SDDF 6215.252-057-001F




TEST PROFILE DATA FOR 215.252 SDDF 6215.252-057-001F

TIME	0	30 days
LOG(MIN)	-3.00	4.64
TEMP(F)	212	212
PRES(PSIG)	3.45	3.45


TEST PROFILE

215.400 SDDF 6215.400-071-0200



TEST PROFILE

215.400 SDDF 6215.400-071-0200




TEST PROFILE DATA FOR 215.400 SDDF 6215.400-071-0200

TIME	0	30 days
LOG(MIN)	-3.00	4.64
TEMP(F)	212	212
PRES(PSIG)	3.45	3.45


SPECIFIED ACCIDENT PROFILES

SRN 223311-1



SPECIFIED ACCIDENT PROFILES

SRN 223311-1




SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 223311

```

TEMPERATURE -----
TIME                0 100 days
LOG(MINUTES)       -3.00   5.16
TEMP(F)            130     130
TIME(MIN)          0.001  144000
PRESSURE -----
TIME                0 100 days
LOG(MINUTES)       -3.00   5.16
PRES(WG)           -0.62   -0.62
TIME(MIN)          0.001  144000
    
```


SPECIFIED ACCIDENT PROFILES

SRN 224520-1



SPECIFIED ACCIDENT PROFILES

SRN 224520-1




SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 224520

HELB CONDITION										
TEMPERATURE										
TIME	0	5sec	60sec	600sec	2.0hr	1day	5days	180days		
LOG(MIN)	-3.00	-2.30	0.00	1.00	2.23	3.16	3.86	5.41	ERR	ERR
TEMP(F)	114	135	135	125	120	116	114	114	110	110
TIME(MIN)	0.001	0.005	1	10	168	1440	7200	259200		
PRESSURE										
TIME	0	5sec	60sec	600sec	2.0hr	1day	5days	180days		
LOG(MINUT)	-3.00	-2.30	0.00	1.00	2.23	3.16	3.86	5.41	ERR	ERR
PRES(PSIG)	0	2.1	2.1	0.9	0.5	0	0	0	3.1	-1
TIME(MIN)	0.001	0.005	1	10	168	1440	7200	259200		
LOCA CONDITION										
TEMPERATURE										
TIME	0	5sec	60sec	600sec	2.0hr	1day	5days	180days		
LOG(MIN)	-3.00	-2.30	0.00	1.00	2.23	3.16	3.86	5.41	ERR	ERR
TEMP(F)	114	114	114	114	114	114	114	114		
TIME(MIN)	0.001	0.005	1	10	168	1440	7200	259200		
PRESSURE										
TIME	0	5sec	60sec	600sec	2.0hr	1day	5days	180days		
LOG(MINUT)	-3.00	-2.30	0.00	1.00	2.23	3.16	3.86	5.41	ERR	ERR
PRES(PSIG)	0	0	0	0	0	0	0	0		
TIME(MIN)	0.001	0.005	1	10	168	1440	7200	259200		


SPECIFIED ACCIDENT PROFILES

SRN 224520-2



SPECIFIED ACCIDENT PROFILES

SRN 224520-2





SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 224520

T E M P E R A T U R E					
TIME	0	6sec	1day	10days	180days
LOG (MINUTES)	-3.00	-2.22	3.16	4.16	5.41
TEMP (F)	90	165	165	130	85
TIME (MIN)	0.001	0.006	1440	14400	259200

P R E S S U R E						
TIME	0	6sec	3HR	1day	10days	180days
LOG (MINUTES)	-3.00	-2.22	2.26	3.16	4.16	5.41
PRES (PSIG)	0	8	9	9	0	0
TIME (MIN)	0.001	0.006	1440	1440	14400	259200

SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION:




TEST PROFILE DATA FOR 224.520 SDDF 6224.520 214-004B

T E M P E R A T U R E							
TIME	0	10SEC	4HR	4.5HR	5HR	5.5HR	6HR
LOG(MINU)	-3.00	-0.22	2.38	2.47	2.48	2.52	2.56
TEMP(F)	380	380	380	380	380	380	380
TIME(MIN)	0.001	0.6	240	270	300	330	360
P R E S S U R E							
TIME	0	10SEC	4HR	4.5HR	5HR	5.5HR	6HR
LOG(MINUT)	-3.00	-0.22	2.38	2.47	2.48	2.52	2.56
PRES(PSIG)	0	62	62	20	20	5	5
TIME(MIN)	0.001	0.6	240	270	300	330	360


TEST PROFILE

224.520 SDDF 8224.520-214-005B



TEST PROFILE


224.520 SDDF 8224.520-214-005B



TEST PROFILE DATA FOR 224.520-214-005B

TEMPERATURE							
TIME	0	10SEC	4HR	4.5HR	20HR	20.5HR	21DAYS
LOG(MINU)	-3.00	-0.80	2.38	2.43	3.08	3.09	3.10
TEMP(F)	316	316	316	259	259	155	155
TIME(MIN)	0.001	0.16	240	270	1200	1230	1260

PRESSURE							
TIME	0	10SEC	4HR	4.5HR	20HR	20.5HR	21DAYS
LOG(MINUT)	-3.00	-0.80	2.38	2.43	3.08	3.09	3.10
PRES(PSIG)	0	70	70	20	20	5	5
TIME(MIN)	0.001	0.16	240	270	1200	1230	1260




TEST PROFILE DATA FOR 224.520 SDDF 6224.520-214-001B TO 009B
LOCATION CT-6

TEST 3:		0 months
TIME		
LOG (MINUTES)	-3.00	5.68
TEMP (F)	650	650


TEST PROFILE

228.241 SDDF 6228.241-092-008B



TEST PROFILE

228.241 SDDF 228.241-092-008B




TEST PROFILE DATA FOR 228.241 SDDF 6228.241-092-008B

T E M P E R A T U R E														
TIME	0SEC	6SEC	40SEC	3HR	4HR	5HR	5HR-40SEC	8HR	8HR-18SEC	11HR	11HR-2MIN	3.5DAYS	3.5D-45MI	32DAYS
LOG (MINU	-3.00	-1.00	-0.18	2.26	2.38	2.48	2.48	2.68	2.68	2.82	2.82	3.70	3.71	4.43
TEMP(F)	140	280	340	340	140	140	340	340	320	320	270	270	200	200
TIME(MIN)	0.001	0.1	0.666	180	240	300	300.666	480	480.28	660	662	5040	5085	26880
P R E S S U R E														
P	0SEC	6SEC	40SEC	3HR	4HR	5HR	5HR-40SEC	8HR	8HR-18SEC	11HR	11HR-2MIN	3.5DAYS	3.5D-45MI	32DAYS
MINUT	-3.00	-1.00	-0.18	2.26	2.38	2.48	2.48	2.68	2.68	2.82	2.82	3.70	3.71	4.43
PRES(PSIG)	0	45	70	70	0	0	70	70	40	40	25	25	10	10
TIME(MIN)	0.001	0.1	0.666	180	240	300	300.666	480	480.28	660	662	5040	5085	26880


TEST PROFILE

241.211 SDDF 6241.211-156-003B



TEST PROFILE

241.211 SDDF 6241.211-156-003B




TEST PROFILE DATA FOR 241.211 - SDDF 6-241.211-156-003B --Penetrations -LVP/LVC

TEMPERATURE																		
TIME	0	1.5min	2min	3min	4min	5.5min	6.5min	10min	11min	12.5min	13.5min	16.5min	19min	21.5min	10hrs	100hrs	2.5days	5.7days
TIME(MIN)	0.001	1.5	2	3	4	5.5	6.5	10	11	12.5	13.5	16.5	19	21.5	610	6010	7210	12010
LOG(MINUTES)	-3.00	0.18	0.30	0.48	0.60	0.74	0.81	1.00	1.04	1.10	1.13	1.22	1.28	1.33	2.79	3.78	3.86	4.08
TEMP (F)	75	309	310	320	340	355	337	75	298	312	330	360	370	370	325	320	310	310

PRESSURE															
TIME	0	1min	2.5min	6min	10min	11min	12min	20min	30min	70min	10days	10days	10.7days		
TIME(MIN)	13210	14410	20710												
LOG(MINUTES)	4.12	4.16	4.32	0.00	0.00	0.78	1.00	1.04	1.06	1.30	1.48	1.83	4.16	4.16	4.30
TEMP (F)	320	315	315	0	71	72	70	0	74	75	71	71	63	63	62


TEST CONDITIONS

241.211 SDDF 6241.211-156-012C



TEST CONDITIONS

241.211 SDDF 6241.211-156-012C




TEST PROFILE SPEC 241.211 SDDF 6241.211-156-012C PENETRATIONS - LVI/NMS

TEMPERATURE																				
TIME	0	0.54	1.20	1.30	1.48	1.53	1.60	1.70	1.73	1.79	1.82	1.90	1.95	2.15	2.30	2.46	3.17	3.64	3.86	4.34
LOG(MINUTES)	0.00	0.54	1.20	1.30	1.48	1.53	1.60	1.70	1.73	1.79	1.82	1.90	1.95	2.15	2.30	2.46	3.17	3.64	3.86	4.34
TEMP(F)	134	322	322	316	322	339	375	122	325	328	346	355	368	393	339	339	303	303	320	320
TIME(MIN)	1	3.5	16	20	30	34	40	50	53.5	62	66	79	90	140	200	290	1490	4370	7250	21650
PRESSURE																				
TIME	0	0.54	1.08	1.30	1.60	1.70	1.71	1.73	1.76	1.87	1.89	1.95	2.15	2.46	3.17	3.34	3.64	4.34		
LOG(MINUTES)	0.00	0.54	1.08	1.30	1.60	1.70	1.71	1.73	1.76	1.87	1.89	1.95	2.15	2.46	3.17	3.34	3.64	4.34		
PRES(PSIG)	0	78	77	68	68	0	66	80	78	78	76	78	70	68	30	30	36	33		
TIME(MIN)	1	3.5	12	20	40	50	51	53.5	58	74	78	90	140	290	1490	2210	4370	21650		


TEST CONDITIONS

241.211 SDDF 6241.211-156-017B



TEST CONDITIONS

241.211 SDDF 6241.211-156-017B




TEST PROFILE SPEC 241.211 SDDF 6241.211-156-017B PENETRATIONS - MVP

T E M P E R A T U R E																			
TIME																			
LOG(MINUTES)	0.00	0.30	0.48	1.00	1.30	1.48	1.51	1.54	1.60	1.65	1.69	1.74	1.78	1.95	3.32	3.54	3.75	3.88	
TEMP(F)	77	355	365	306	214	208	77	250	363	370	405	394	356	350	366	311	311	334	334
TIME(MIN)	1	1	2	3	10	20	30	32	38	40	48	49	55	60	90	2070	3450	5610	7210
P R E S S U R E																			
TIME																			
LOG(MINUTES)	0.00	-0.60	0.48	1.00	1.18	1.48	1.54	2.52	2.65	4.27									
PRES(PSIG)	0	68	68	64	0	0	69	70	61	61									
TIME(MIN)	1	0.25	3	10	15	30	35	300	450	18766									


SPECIFIED ACCIDENT CONDITIONS

SRN 247250-1



SPECIFIED ACCIDENT CONDITIONS

SRN 247250-1




SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 247.250

T E M P E R A T U R E							
TIME	0	5sec	60sec	1000se	10AY	5day	100days
LOG (MINUTES)	-3.00	-1.08	0.00	1.22	3.16	3.86	5.16
TEMP (F)	113	131	131	120	113	113	113
TIME (MIN)	0.001	0.083	1	16.66	1440	7200	*****
P R E S S U R E							
TIME	0	5sec	60sec	1000se	10AY	5day	100days
LOG (MINUTES)	-3.00	-1.08	0.00	1.22	3.16	3.86	5.16
PRES (PSIG)	0	2	2	1	-.25*W	-.5*W6	-.5*W6
TIME (MIN)	0.001	0.083	1	16.66	1440	7200	*****


SPECIFIED ACCIDENT PROFILE

SRN 247250-3



SPECIFIED ACCIDENT PROFILE

SRN 247250-3



SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 247.250

TEMPERATURE -----


TIME	0	100days
LOG (MINUTES)	-3.00	5.16
TEMP (F)	122	122
TIME (MIN)	0.001	144000

PRESSURE -----

TIME	0	100days
LOG (MINUTES)	-3.00	5.16
PRES (PSIG)	0	0
TIME (MIN)	0.001	144000


TEST PROFILE

247.250, SDDF # 6247250-329-043A



TEST PROFILE

247.250, SDDF # 6247250-329-043A




SPECIFIED TEST CONDITIONS FOR SDDF # SDDF 6247.250-329-043A (TEST 1)

TEMPERATURE										
TIME	0sec	33sec	33sec	10.7min	144min	114.33min	154min	174min	3.4hrs	6.4hrs
LOG (MINUTES)	-3.00	-0.26	-0.26	1.03	2.16	2.16	2.19	2.24	2.31	2.58
TEMP(F)	157	390	400	400	175	411	390	330	305	260
TIME(MIN)	0.001	0.55	0.55	10.7	144	144.33	154	174	204	384
PRESSURE										
TIME	0sec	20sec	50min	51.5min	51.63min	111.23min	291.63min			
LOG(MINUTES)	-3.00	-0.48	1.70	1.71	1.71	2.05	2.42			
PRES(PSIG)	0	57	57	0	53	57	40			
TIME(MIN)	0.001	0.33	50	51.5	51.63	111.23	261.63			


TEST PROFILE

247.250, SDDF 6247.250-329-043A



TEST PROFILE







247.250, SDDF 6247.250-329-043A



SPECIFIED TEST CONDITIONS FOR SDDF # 6247.250-329-043A (TEST 2)


TEMPERATURE							
TIME	0	38sec	1.5min	5min	3hrs	6hrs	9hrs
LOG (MINUTES)	-3.00	-0.20	0.18	0.70	2.26	2.56	2.73
TEMP (F)	75	295	355	365	365	345	270
TIME (MIN)	0.001	0.63	1.5	5	180	360	540
PRESSURE							
TIME	0	50sec	9min	11hrs			
LOG (MINUTES)	-3.00	-0.08	0.95	2.82			
PRES (PSIG)	0	70	70	43			
TIME (MIN)	0.001	0.83	9	660			

IMAGE EVALUATION
TEST TARGET (MT-3)




TEST PROFILE

247.250, SDDF 6247.250-329-043A



TEST PROFILE

247.250, SDDF 6247.250-329-043A




SPECIFIED TEST CONDITIONS FOR SDDF # 6247.250-329-043A (TEST 3)

TEMPERATURE										
TIME	0sec	10sec	1.7hrs	1.7hrs	2.7hrs	3hrs	3.08hrs	14hrs	99hrs	435hrs
LOG (MINUTES)	-3.00	-0.77	2.01	2.01	2.21	2.26	2.27	2.92	3.77	4.416
TEMP (F)	78	325	318	315	105	80	315	320	205	152
TIME (MIN)	0.001	0.17	102	102	162	180	184.8	840	5940	26100

PRESSURE										
TIME	0sec	10sec	1.7hrs	2.2hrs	3hrs	3.08hrs	14hrs	99hrs	99hrs	435hrs
LOG (MINUTES)	-3.00	-0.77	2.01	2.12	2.26	2.27	2.92	3.77	3.77	4.416
PRES (PSIG)	0	78	77	0	0	77	78	46	4.5	10
TIME (MIN)	0.001	0.17	102	132	180	184.8	840	5940	5940	26100


SPECIFIED ACCIDENT PROFILE

SRN 247421-1 & 247421-2



SPECIFIED ACCIDENT PROFILE

SRN 247421-1 & 247421-2



SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 247.421

HELB CONDITION

TEMPERATURE

TIME	0 Ssec	1min	10min	2.8hrs/day	5days	100days				
LOG (MINUTES)	-3.00	-1.08	0.00	1.00	2.23	3.16	3.86	5.16		
TEMP (F)	114	135	135	125	120	116	114	114	113	136
TIME (MIN)	0.001	0.083	1	10	168	1440	7200	144000		

PRESSURE

TIME	0 Ssec	1min	10min	2.8hrs/day	5days	100days				
LOG (MINUTES)	-3.00	-1.08	0.00	1.00	2.23	3.16	3.86	5.16		
PRES (PSIG)	0	2.1	2.1	0.9	0.5	0	0	0	-0.1	2.2
TIME (MIN)	0.001	0.083	1	10	168	1440	7200	144000		

LOCA CONDITION

TEMPERATURE


TIME	0 Ssec	1min	10min	2.8hrs/day	5days	100days		
LOG (MINUTES)	-3.00	-1.08	0.00	1.00	2.23	3.16	3.86	5.16
TEMP (F)	114	114	114	114	114	114	114	114
TIME (MIN)	0.001	0.083	1	10	168	1440	7200	144000

PRESSURE

TIME	0 Ssec	1min	10min	2.8hrs/day	5days	100days		
LOG (MINUTES)	-3.00	-1.08	0.00	1.00	2.23	3.16	3.86	5.16
PRES (PSIG)	0	0	0	0	0	0	0	0
TIME (MIN)	0.001	0.083	1	10	168	1440	7200	144000


SPECIFIED ACCIDENT PROFILE

SRN 247433-1 & 247433-2



SPECIFIED ACCIDENT PROFILE

SRN 247433-1 & 247433-2




SPECIFIED ACCIDENT CONDITIONS FOR SPECIFICATION: 247.433

T E M P E R A T U R E -----						
TIME	0	6sec	1day	10days	100days	
LOG (MINUTES)	-3.00	-1.00	3.16	4.16	5.16	
TEMP(F)	90	165	165	130	124	80
TIME(MIN)	0.001	0.1	1440	14400	144000	
P R E S S U R E -----						
TIME	0	6sec	1day	10days	100days	
LOG(MINUTES)	-3.00	-1.00	3.16	4.16	5.16	
PRES(PSIG)	0	9	9	0	0	-1 10
TIME(MIN)	0.001	0.1	1440	14400	144000	


TEST PROFILE

247.411 SDDF 6247.411-296-010A



TEST PROFILE

247.411 SDDF 6247.411-296-010A




TEST PROFILE DATA FOR 247.411 SDDF 6247.411-296-010A

TIME	0	5min	3hr	3hr	4hr	4hr20min	4days	4days	100days
LOG(MINUTES)	-3.00	0.70	2.26	2.26	2.38	2.42	3.76	3.76	5.16
TEMP(F)	140	340	340	320	320	250	250	200	200
PRES(P SIG)	0	105	105	75	75	15	15	10	10


TEST PROFILE

247.411 SDDF 6247.411-296-011A



TEST PROFILE

247.411 SDDF 6247.411-296-011A



TEST PROFILE DATA FOR 247.411 SDDF 6247.411-296-011A

TIME	0	10sec	5min	8hr	11hr	15hr	4days	7days
LOG(MINUTES)	-3.00	-0.78	0.70	2.68	2.82	2.95	3.76	4.00
TEMP(F)	145	280	346	346	335	315	265	212
PRES(PSIG)	0	70	113	113	95	69	24	0

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN C01
 REV 2
 DATE 02-15-85
 SHEET 2A

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
Nuclear Boiler System					
B21-NO62A	169C8394P972203	1152GP9E22T0280PB	CT-G	100 d	11
B21-NO62B	169C8394P972203	1152GP9E22T0280PB	CT-G	100 d	11
B21-NO67C	169C8968P512203	1152AP5A22PB	CT-G	100 d	11,12
B21-NO67G	169C8968P512203	1152AP5A22PB	CT-G	100 d	11,12
B21-NO67L	169C8968P512203	1152AP5A22PB	CT-G	100 d	11,12
B21-NO67R	169C8968P512203	1152AP5A22PB	CT-G	100 d	11,12
B21-NO68A	169C8394P972203	1152GP9E22T0280PB	CT-G	4 h	
B21-NO68B	169C8394P972203	1152GP9E22T0280PB	CT-G	4 h	
B21-NO68E	169C8394P972203	1152GP9E22T0280PB	CT-G	4 h	
B21-NO68F	169C8394P972203	1152GP9E22T0280PB	CT-G	4 h	
B21-NO73C	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11
B21-NO73G	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11
B21-NO73L	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11
B21-NO73R	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11
B21-NO75A	169C8969P572203	1152AP5E22T0280PB	TB-095-3:	none	
B21-NO75B	169C8969P572203	1152AP5E22T0280PB	TB-095-3:	none	
B21-NO75C	169C8969P572203	1152AP5E22T0280PB	TB-095-3:	none	
B21-NO75D	169C8969P572203	1152AP5E22T0280PB	TB-095-3:	none	
B21-NO76A	169C8394P972203	1152GP9E22T0280PB	TB-095-3:	1 h	
B21-NO76B	169C8394P972203	1152GP9E22T0280PB	TB-095-3:	1 h	
B21-NO76C	169C8394P972203	1152GP9E22T0280PB	TB-095-3:	1 h	
B21-NO76D	169C8394P972203	1152GP9E22T0280PB	TB-095-3:	1 h	
B21-NO78A	169C8394P972203	1152GP9E22T0280PB	CT-G	100 d	11
B21-NO78B	169C8394P972203	1152GP9E22T0280PB	CT-G	100 d	11
B21-NO78C	169C8394P972203	1152GP9E22T0280PB	CT-G	100 d	11
B21-NO78D	169C8394P972203	1152GP9E22T0280PB	CT-G	100 d	11
B21-NO80A	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11
B21-NO80B	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11
B21-NO80C	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11
B21-NO80D	169C8392P472203	1152DP4E22T0280PB	CT-G	100 d	11

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN C01
 REV 2
 DATE 02-15-85
 SHEET 2B

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
:B21-NO81A	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 1 h	:
:B21-NO81B	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 1 h	:
:B21-NO81C	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 1 h	:
:B21-NO81D	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 1 h	:
:B21-NO91A	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO91B	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO91E	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO91F	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO94A	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO94B	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO94E	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO94F	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO95A	:169C8392P472203	: 1152DP4E22T0280PB	: CT-G	: 100 d	: 11
:B21-NO95B	:169C8392P472203	: 1152DP4E22T0280PB	: CT-G	: 100 d	: 11
:B33-NO14A	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:B33-NO14B	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:B33-NO14C	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:B33-NO14D	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:B33-NO24A	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:B33-NO24B	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:B33-NO24C	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:B33-NO24D	:169C8392P572203	: 1152DP5E22T0280PB	: CT-G	: 45 s	:
:	:	:	:	:	:
:Control Rod Drive Hydraulic System					
:C11-NO54A	:169C8394P772203	: 1152GP7E22T0280PB	: TB-095-2:	: none	:
:C11-NO54B	:169C8394P772203	: 1152GP7E22T0280PB	: TB-095-2:	: none	:
:C11-NO54C	:169C8394P872203	: 1152GP8E22T0280PB	: TB-095-2:	: none	:
:C11-NO54D	:169C8394P872203	: 1152GP8E22T0280PB	: TB-095-2:	: none	:
:	:	:	:	:	:
:Reactor Protection System (RPS)					
:C71-NO50A	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 45 s	:

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN C01
 REV 2
 DATE 02-15-85
 SHEET 2C

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
:C71-NO50B	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 45 s	:
:C71-NO50C	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 45 s	:
:C71-NO50D	:169C8969P572203	: 1152AP5E22T0280PB	: CT-G	: 45 s	:
:C71-NO52A	:169C8394P972203	: 1152GP9E22T0280PB	: TB-095-3:	: 12 h	:
:C71-NO52B	:169C8394P972203	: 1152GP9E22T0280PB	: TB-095-3:	: 12 h	:
:C71-NO52C	:169C8394P972203	: 1152GP9E22T0280PB	: TB-095-3:	: 12 h	:
:C71-NO52D	:169C8394P972203	: 1152GP9E22T0280PB	: TB-095-3:	: 12 h	:
:Residual Heat Removal (RHR) System					
:E12-NO07A	:169C8392P572203	: 1152DP5E22T0280PB	: AB-095-8:	: 100 d	: 11
:E12-NO07B	:169C8392P572203	: 1152DP5E22T0280PB	: AB-095-7:	: 100 d	: 11
:E12-NO15A	:169C8392P572203	: 1152DP5E22T0280PB	: AB-095-8:	: 100 d	: 11
:E12-NO15B	:169C8392P572203	: 1152DP5E22T0280PB	: AB-095-7:	: 100 d	: 11
:E12-NO15C	:169C8392P572203	: 1152DP5E22T0280PB	: AB-095-7:	: 100 d	: 11
:E12-NO52A	:169C8392P372203	: 1152DP3E22T0280PB	: AB-095-8:	: 100 d	: 11
:E12-NO52B	:169C8392P372203	: 1152DP3E22T0280PB	: AB-095-7:	: 100 d	: 11
:E12-NO52C	:169C8392P372203	: 1152DP3E22T0280PB	: AB-095-7:	: 100 d	: 11
:E12-NO55A	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-8:	: 100 d	: 11,13
:E12-NO55B	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-7:	: 100 d	: 11,13
:E12-NO55C	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-7:	: 100 d	: 11,13
:E12-NO56A	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-8:	: 1 h	: 13
:E12-NO56B	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-7:	: 1 h	: 13
:E12-NO56C	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-7:	: 1 h	: 13
:Low Pressure Core Spray (LPCS) System					
:E21-NO03	:169C8392P572203	: 1152DP5E22T0280PB	: AB-095-1:	: 100 d	: 11
:E21-NO51	:169C8392P372203	: 1152DP3E22T0280PB	: AB-095-1:	: 100 d	: 11,13
:E21-NO52	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-1:	: 1 h	: 13
:E21-NO53	:169C8394P772203	: 1152GP7E22T0280PB	: AB-095-1:	: 1 h	: 13

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN C01
 REV 2
 DATE 02-15-85
 SHEET 2D

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
<u>High Pressure Core Spray (HPCS) System</u>					
E22-NO05	169C8392P572203	1152DP5E22T0280PB	AB-095-7	100 d	11
E22-NO51	169C8394P972203	1152GP9E22T0280PB	AB-095-7	100 d	11
E22-NO56	169C8392P472203	1152DP4E22T0280PB	AB-095-7	100 d	11,13
<u>Leak Detection System</u>					
E31-NO75A	169C8392P572203	1152DP5E22T0280PB	AB-095-8	10 m	
E31-NO75B	169C8392P572203	1152DP5E22T0280PB	AB-095-7	10 m	
E31-NO76A	169C8392P572203	1152DP5E22T0280PB	CT-G	10 m	
E31-NO76B	169C8392P572203	1152DP5E22T0280PB	CT-G	10 m	
E31-NO77A	169C8392P572203	1152DP5E22T0280PB	AB-095-8	10 m	
E31-NO77B	169C8392P572203	1152DP5E22T0280PB	AB-095-7	10 m	
E31-NO83A	169C8392P572203	1152DP5E22T0280PB	AB-095-8	10 m	13
E31-NO83B	169C8392P572203	1152DP5E22T0280PB	AB-095-7	10 m	13
E31-NO84A	169C8392P572203	1152DP5E22T0280PB	CT-G	12 h	13
E31-NO84B	169C8392P572203	1152DP5E22T0280PB	CT-G	12 h	13
E31-NO85A	169C8394P772203	1152GP7E22T0280PB	CT-G	12 h	13
E31-NO85B	169C8394P772203	1152GP7E22T0280PB	CT-G	12 h	13
E31-NO86A	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO86B	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO86C	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO86D	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO87A	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO87B	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO87C	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO87D	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO88A	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO88B	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	
E31-NO88C	169C8392P772203	1152DP7E22T0280PB	CT-G	1 h	

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN C01
 REV 2
 DATE 02-15-85
 SHEET 2E

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
:E31-NO38D	:169C8392P772203	:1152DP7E22T0280PB	:CT-G	:1 h	:
:E31-NO89A	:169C8392P772203	:1152DP7E22T0280PB	:CT-G	:1 h	:
:E31-NO89B	:169C8392P772203	:1152DP7E22T0280PB	:CT-G	:1 h	:
:E31-NO89C	:169C8392P772203	:1152DP7E22T0280PB	:CT-G	:1 h	:
:E31-NO89D	:169C8392P772203	:1152DP7E22T0280PB	:CT-G	:1 h	:
:Main Steam Positive Leakage Control System					
:E33-NO01	:169C8969P672203	:1152AP6E22T0280PB	:AB-114-6:	:30 d	:11
:E33-NO02	:169C8969P672203	:1152AP6E22T0280PB	:CT-G	:30 d	:11
:E33-NO03	:169C8969P672203	:1152AP6E22T0280PB	:CT-G	:30 d	:11
:E33-NO04	:169C8969P672203	:1152AP6E22T0280PB	:AB-114-6:	:30 d	:11
:E33-NO05	:169C8969P672203	:1152AP6E22T0280PB	:AB-114-6:	:30 d	:11
:E33-NO07	:169C8392P472203	:1152DP4E22T0280PB	:AB-114-6:	:30 d	:11
:E33-NO21	:169C8969P672203	:1152AP6E22T0280PB	:AB-114-5:	:30 d	:11
:E33-NO22	:169C8969P672203	:1152AP6E22T0280PB	:CT-G	:30 d	:11
:E33-NO23	:169C8969P672203	:1152AP6E22T0280PB	:CT-G	:30 d	:11
:E33-NO24	:169C8969P672203	:1152AP6E22T0280PB	:AB-114-5:	:30 d	:11
:E33-NO25	:169C8969P672203	:1152AP6E22T0280PB	:AB-114-5:	:30 d	:11
:E33-NO27	:169C8392P472203	:1152DP4E22T0280PB	:AB-114-5:	:30 d	:11
:Reactor Core Isolation Cooling (RCIC) System					
:E51-NO03	:169C8392P572203	:1152DP5E22T0280PB	:AB-095-8:	:12 h	:
:E51-NO50	:169C8394P972203	:1152GP9E22T0280PB	:AB-095-8:	:12 h	:
:E51-NO51	:169C8392P472203	:1152DP4E22T0280PB	:AB-095-8:	:12 h	:
:E51-NO52	:169C8394P772203	:1152GP7E22T0280PB	:AB-095-1:	:12 h	:
:E51-NO53	:169C8394P572203	:1152GP5E22T0280PB	:AB-095-8:	:12 h	:
:E51-NO55A	:169C8394P672203	:1152GP6E22T0280PB	:AB-095-8:	:12 h	:13
:E51-NO55B	:169C8394P672203	:1152GP6E22T0280PB	:AB-095-7:	:12 h	:13
:E51-NO55B	:169C8394P672203	:1152GP6E22T0280PB	:AB-095-8:	:12 h	:13

: NOTES

- : 1. The maximum specified operability time is 100 days. The actual operability time for each device is
 : shown on sheet 2.
- : 2. The specified value represents the maximum of the composite envelope for environmental zones CT-G,
 : AB-095-1, AB-095-7, AB-095-8, AB-114-5, AB-114-6, TB-095-2, and TB-095-3.
- : 3. The specified value represents the 10 year total integrated dose for normal (including abnormal)
 : conditions.
- : 4. The specified value represents the 180 day total integrated dose for design basis LOCA conditions.
- : 5. All equipment located in the containment below the 120' elevation is specified as potentially
 : exposed to spray/froth resulting from suppression pool swell following a design basis event.
- : 6. Flooding applies only to locations in zone CT-G.
- : 7. Temperature vs. time history:

Specified (see Note 2 above), F		Qualified, F	
0- 1s	90-190	0 - 10m	232*
1s- 5s	190	10m- 17m	232-200
5s- 10s	190-200	17m- 1d	200
10s- 40s	200	1d-110d	200-137 (see Note 11 below)
40s- 60s	200-190		
60s-200s	190-176		
200s-530s	176-165		
530s- 1d	165		
1d- 10d	165-130		
10d-100d	130- 95		

: *rise time at the maximum capability of the test facility
 : s = seconds, m = minutes, h = hours, d = days

: NOTES (continued) :

: 8. Pressure vs. time history: :

Specified (see Note 2 above), psig		Qualified, psig	
0- 1s	0-2.1	0- 1d	18.5*
1s- 6s	2.1-8	1d-110d	18.5-0 (see Note 11 below)
6s- 3h	8-9		
3h- 1d	9		
1d- 10d	9-0		
10d-100d	0		

: *rise time at the maximum capability of the test facility :

: 9. The accuracy is expressed as percentage of the upper range of the device and for the most limiting contributor (i.e., radiation) to inaccuracy. Verification of acceptability of device applications will be covered under a separate program using the proposed methods of the Licensing Review Group II (LRG-II) Setpoint Methodology Program. The results of this separate program will be issued pending NRC (ICSB) approval of the LRG Setpoint Methodology. :

: 10. The qualified life is 8.7 years for the following equipment. :

: B21-N075A-D
: B21-N076A-D
: C71-N052A-D

: 11. This SCEW sheet establishes qualification only for devices with an operability time of less than two days and within the limits of application described in Note 9 above. The test is continuing for a total duration of 110 days and is scheduled for completion during the first quarter of 1985. :

: 12. These transmitters are scheduled to be replaced with drawing no. 169C8969P582203 (model no. 1152AP5N22T0280) per field disposition instruction (FDI) MCWT. :

SYSTEM COMPONENT EVALUATION WORK SHEET

EQUIPMENT DESCRIPTION		ENVIRONMENTAL CONDITIONS AND QUALIFICATION							
		PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE SPECIFIED	QUALIFIED	QUAL METHOD	MARGIN DEMO	NOTES (see sheet 3)
EQUIP NO: C11-N012A-D		OP. TIME:	12 hours	50 days	3	3	TEST-IDENT	YES	2
DWG NO: 184C4775		TEMP (F):							
SYSTEM: Control Rod Drive Hydraulic System		NORMAL:	90	see Note 9	1	3	N/A	N/A	9
		ABNORMAL:	140	see Note 9	1	3	N/A	N/A	9
TYPE: Level Transmitter		ACCIDENT:	165	290	1	3	TEST-IDENT	YES	3,4
		PRESS (PSIG):							
		NORMAL:	-0.1" W.G	atmospheric	1	3	N/A	N/A	
		ABNORMAL:	2.3	see Note 10	1	3	N/A	N/A	10
MANUFACTURER: Gould, Inc.		ACCIDENT:	9	17.6	1	3	TEST-IDENT	YES	3,5
		RH (%):							
MODEL: PD3218 (Note 1)		NORMAL:	50	see below	1	3	N/A	N/A	
		ABNORMAL:	100	see below	1	3	N/A	N/A	
SAFETY FUNCTION: Reactor Trip		ACCIDENT:	100	100	1	3	TEST-IDENT	N/A	
		RADIATION:							
		NORM GAMMA:	4E4	see Note 11	1	N/A	N/A	N/A	6,11
		ACC GAMMA:	4E6	2E7	1	3	TEST-IDENT	YES	7
OP. CODE: A		NORM BETA:	2E3	shielded	1	N/A	N/A	N/A	6
		ACC BETA:	3.4E7	shielded	1	N/A	N/A	N/A	7
		NEUTRON:	0	N/A	1	N/A	N/A	N/A	
		SPRAY:	7 seconds	30 hours	2	3	TEST-IDENT	YES	
ACCURACY (Note 8) NORM ACC		SUBMERGENCE:	N/A	N/A	N/A	N/A	N/A	N/A	
		SPEC:	+4%	+8%					
		DEMO:	+4%	+8%					
ZONE NO: CT-3		DOCUMENT REFERENCE:							
		1. Environmental Design Criteria (EDC) SWEC Document No. 215.150, Rev. 2 (including change notices no 2-1, 2-2 and 2-3)							
FLOOD LEVEL		2. River Bend Station FSAR, Appendix 6A, Figure 6A-10.2							
ELEVATION: 109'		3. GE Environmental Qualification Report NEDC-30372							
ABOVE FLOOD LEVEL? Yes									
DOCUMENTATION ACCEPTABILITY:									
Acceptable to NUREG 0588, Cat 1									
per NEDE-24326-1-P									
MAINTENANCE/SURVEILLANCE:									
REFERENCE: 3									
QUALIFIED LIFE									
(YEARS): 15									
REFERENCE: 3									

NOTES

1. This model replaces the originally supplied equipment as documented in Field Disposition Instruction (FDI) MCWB.
2. An operability time of 12 hours is specified to account for the postulated maximum time period from the onset of a design basis event until initiation of a reactor scram.
3. The specified value represents the maximum of the envelope for a design basis LOCA and a small break accident.

4. Temperature vs. time history:

Specified (see Note 3 above), °F		Qualified, °F	
0 - 6s	90-165	0-15m	290* (first peak)
6s- 1d	165	0-1h	260* (second peak)
1d- 10d	165-130	1h-30h	260-227
10d-100d	130- 95	30h-7d	227-215

*rise time at the maximum capability of the test facility.

5. Pressure vs. time history:

Specified (see Note 3 above), psig		Qualified, psig	
0 - 6s	0-8	0-15m	17.6* (first peak)
6s- 3h	8-9	0-30h	17.6* (second peak)
3h- 1d	9	30h-7d	17.6-14
1d-10d	9-0		
10d-100d	0		

*rise time at the maximum capability of the test facility.

GULF STATES UTILITIES
RIVER BEND STATION - UNIT 1
DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN C11
REV 2
DATE 02-15-85
SHEET 3

: NOTES :

- : 1. Flooding applies only to locations in zone CT-3. :
- : 2. The specified value represents the maximum normal value for environmental zones CT-3 and AB-070-3. :
- : 3. The devices located in zone CT-3 are not required to operate following an abnormal (isolation) event. The isolation event does not result in environmental conditions above normal in zone AB-070-3. :
- : 4. The specified value represents the value resulting in zone CT-3 from a small break accident. :
- : 5. The specified value represents the total integrated dose for design basis LOCA conditions which envelops the total integrated dose resulting in zone AB-070-3 from a control rod drop accident. :
- : 6. The specified value represents the 40 year total integrated dose for normal (including abnormal) conditions. :
- : 7. Device is required only for the mitigation of a small break accident. :
- : 8. Device is required only for the mitigation of a control rod drop accident. :
- : 9. Enveloped by accident temperature. The specified temperature for normal and abnormal conditions is considered in the aging calculation. :
- : 10. Included in accident gamma dose. :
- : 11. Qualified life for E51-N010 is 2.3 years at which time switch assembly must be replaced to re-establish qualification. :
- : 12. The stated drawing number reflects the replacement of the originally supplied equipment per Field Disposition Instruction (FDI) MCWA. :
-
-

SYSTEM COMPONENT EVALUATION WORK SHEET

ENVIRONMENTAL CONDITIONS AND QUALIFICATION

EQUIPMENT DESCRIPTION	PARAMETER	SPECIFIED VALUE	QUALIFIED VALUE	DOCUMENT REFERENCE SPECIFIED	QUALIFIED	QUAL METHOD	MARGIN DEMO	NOTES (see sheet 3)
	EQUIP NO: see sheet 2	OP. TIME:	100 days	Later		Later	Later	Later
SYSTEM: High Pressure Core Spray	TEMP (F):							
	NORMAL:	122	Later	1	Later	Later	Later	2
	ABNORMAL:	N/A	N/A	N/A	N/A	Later	N/A	
TYPE: Valve Motor Operators	ACCIDENT:	195	Later	1	Later	Later	Later	2
	PRESS (PSIG):							
	NORMAL:	atmospheric	Later	1	Later	Later	Later	2
MANUFACTURER: Limitorque/Reliance	ABNORMAL:	N/A	N/A	N/A	N/A	Later	N/A	
	ACCIDENT:	2.8	Later	1	Later	Later	Later	2
	RH (%):							
MODEL: see sheet 2	NORMAL:	90	Later	1	Later	Later	Later	2
	ABNORMAL:	N/A	N/A	N/A	N/A	Later	N/A	
	ACCIDENT:	100	Later	1	Later	Later	N/A	2
SAFETY FUNCTION: Emergency Core Cooling	RADIATION:							
	NORM GAMMA:	2E5 R	Later	1	Later	Later	Later	2,3
	ACC GAMMA:	1.1E7 R	Later	1	Later	Later	Later	2,4
OP. CODE: A	NORM BETA:	0	N/A	1	Later	Later	Later	2,3
	ACC BETA:	500 R	Later	1	Later	Later	Later	2,4
	NEUTRON:	0	N/A	N/A	N/A	Later	N/A	2
ACCURACY	SPRAY:	N/A	Later	N/A	Later	Later	Later	
	SUBMERGENCE:	N/A	Later	N/A	Later	Later	Later	
SPEC: NA								
DEMO: NA								
ZONE NO: see sheet 2	DOCUMENT REFERENCE:							
1. Environmental Design Criteria (EDC)								
SWEC Document No. 215.150, Rev. 2								
(including change notices 2-1, 2-2 and 2-3)								
FLOOD LEVEL								
ELEVATION: NA								
ABOVE FLOOD LEVEL?								
LEVEL? NA								
DOCUMENTATION ACCEPTABILITY:								
Later NUREG 0588, Cat 1								
Qualification is in progress								
MAINTENANCE/SURVEILLANCE:								
REFERENCE: Later								
QUALIFIED LIFE (YEARS):								
Later								
REFERENCE: Later								

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN S03
 REV 2
 DATE 02-15-85
 SHEET 2

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
Pressure Core Spray (HPCS) System					
:E22-F001	: 105D5007KG014	: SMB-00-10	: AB-070-6	: 24 h	
:E22-F004	: 105D5007KG008	: SMB-3-80	: AB-114-5	: 100 d	
:E22-F010	: 105D5007KG006	: SMB-4-200	: AB-070-6	: 1 h	
:E22-F011	: 105D5007KG006	: SMB-4-200	: AB-070-6	: 1 h	
:E22-F012	: 105D5007KG002	: SMB-0-25	: AB-070-7	: 100 d	
:E22-F015	: 105D5007KG016	: SMB-1-40	: AB-070-7	: 100 d	
:E22-F023	: 105D5007KG006	: SMB-3-150	: AB-070-7	: 1 h	
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:

SYSTEM COMPONENT EVALUATION WORK SHEET

EQUIPMENT DESCRIPTION		ENVIRONMENTAL CONDITIONS AND QUALIFICATION						
	PARAMETER	SPECIFIED	QUALIFIED	DOCUMENT REFERENCE		QUAL	MARGIN	NOTES
		VALUE	VALUE	SPECIFIED	QUALIFIED	METHOD	DEMO	(see sheet 3)
EQUIP NO:	see sheet 2							
SYSTFM:	Nuclear Boiler System	OP. TIME:	1 hour	7 days	2	2	TEST-SIM	YES
		TEMP (F):						
		NORMAL:	140	see Note 9	1	2	N/A	N/A
		ABNORMAL:	260	see Note 9	1	2	N/A	N/A
TYPE:	MSIV Actuator	ACCIDENT:	330	345	1	2	TEST-SIM	YES
		PRESS (PSIG):						
		NORMAL:	0.5	atmospheric	1	2	N/A	N/A
		ABNORMAL:	5	see Note 10	1	2	N/A	N/A
MANUFACTURER:	Sheffer Corp	ACCIDENT:	25	33	1	2	TEST-SIM	YES
		RH (%):						
MODEL:	see sheet 2	NORMAL:	90	see below	1	2	N/A	N/A
		ABNORMAL:	100	see below	1	2	N/A	N/A
SAFETY FUNCTION:	Containment Isolation	ACCIDENT:	steam/100	steam/100	1	2	TEST-SIM	YES
		RADIATION:						
		NORM GAMMA:	9.4E6 R	see Note 11	1	2	N/A	N/A
		ACC GAMMA:	1E6 R	3.7E7 R	1	2	TEST-SIM	YES
OP. CODE:	A	NORM BETA:	6.3E3 R	see Note 11	1	2	N/A	N/A
		ACC BETA:	1.3E7 R	see Note 11	1	2	N/A	N/A
		NEUTRON:	2.2E6 R	see Note 11	1	2	N/A	N/A
		SPRAY:	N/A	N/A	N/A	N/A	N/A	N/A
ACCURACY:		SUBMERGENCE:	N/A	N/A	N/A	N/A	N/A	N/A
	SPEC: NA							
	DEMO: NA							
ZONE NO:	see sheet 2							
		DOCUMENT REFERENCE:						
		1. Environmental Design Criteria (EDC)						
FLOOD LEVEL:		SWEC Document No. 215.150, Rev. 2						
ELEVATION:	105'-3" (Note 5)	(including change notices no. 2-1, 2-2 and 2-3)						
ABOVE FLOOD:								
LEVEL?	Yes	2. GE Environmental Qualification Report						
		NEDC-30801, SDDF# 8224.150-000-074A						
DOCUMENTATION ACCEPTABILITY:								
Acceptable to NUREG 0588, Cat 1:								
per NEDE-24326-1-P								
MAINTENANCE/SURVEILLANCE:								
REFERENCE:	2							
QUALIFIED LIFE:								
(YEAPS):	5 (Note 6)							
REFERENCE:	2							

NOTES

1. The specified value represents the maximum of the composite envelope for environmental zones DW-1 and AB-114-2.
2. The specified value represents the 5 year total integrated dose for normal (including abnormal conditions).
3. The specified value represents the 1 hour total integrated dose for design basis LOCA conditions.
4. One neutron per square-centimeter is equivalent to 8E-9 rads gamma radiation.
5. Flooding applies only to locations in zone DW-1.
6. The stated qualified life is based on the shortest qualified life of any MSIV actuator component.
7. Temperature vs. time history:

Specified (see Note 1 above), °F		Qualified, °F	
0 - 0.1s	122-230	0	135-345*
0.1 - 0.3s	230-270	0-3h	345
0.3 - 1s	270-330	3-6h	345-325
1s - 3h	330	6h-30h	325-265
3h - 6h	310	30h-7d	265-200
6h - 1d	310-250		
1d - 10d	250-160		
10d - 100d	160-140		

*rise time at the maximum capability of the test facility.

: NOTES (continued)

: 8. Pressure vs. time history:

Specified (see Note 1 above), psig		Qualified, psig	
0-1s	0-25	0	0-33
1s-40s	25	0 -40s	33
40s-60s	25-11	40s-60s	33-16.5
60s-1d	11	60s- 3h	16.5
1d-10d	11- 0	3h- 6h	16.5-15.9
		6h-24h	15.9-12.1
		24h- 7d	12.1

: *rise time at the maximum capability of the test facility.

: 9. Enveloped by accident temperature. The specified temperature for normal and abnormal environmental conditions is considered in the aging calculation.

: 10. Enveloped by accident pressure.

: 11. Included in accident gamma dose.

EQUIPMENT DESCRIPTION		ENVIRONMENTAL CONDITIONS AND QUALIFICATION						
	PARAMETER	SPECIFIED	QUALIFIED	DOCUMENT REFERENCE		QUAL	MARGIN	NOTES
		VALUE	VALUE	SPECIFIED	QUALIFIED	METHOD	DEMO	(see Sheet 3)
EQUIP NO: see sheet 2								
SYSTEM: Nuclear Boiler System		OP. TIME: 1 hour	> 7 days	2	2	TEST-SIM	YES	
TYPE: MSIV Limit Switch		TEMP (F):						
		NORMAL: 140	see Note 8	1	2	N/A	N/A	1,8
		ABNORMAL: 260	see Note 8	1	2	N/A	N/A	1,8
		ACCIDENT: 330	357	1	2	TEST-SIM	YES	1,6
		PRESS (PSIG):						
		NORMAL: 0.5	atmospheric	1	2	N/A	N/A	1
		ABNORMAL: 5	see Note 9	1	2	N/A	N/A	1,9
		ACCIDENT: 25	69	1	2	TEST-SIM	YES	1,7
		RH (%):						
		NORMAL: 90	see below	1	2	N/A	N/A	1
		ABNORMAL: 100	see below	1	2	N/A	N/A	1
		ACCIDENT: steam/100	steam/100	1	2	TEST-SIM	N/A	1
		RADIATION:						
		NORM GAMMA: 9.4E6 R	1.87E7 R	1	2	N/A	N/A	1,2
		ACC GAMMA: 1E6 R	2.97E8 R	1	2	TEST-SIM	YES	1,3
		NORM BETA: 6.3E3 R	see Note 10	1	2	N/A	N/A	1,2,10
		ACC BETA: 1.3E7 R	see Note 10	1	2	N/A	N/A	1,3,10
		NEUTRON: 2.2E6 R	see Note 10	1	2	N/A	N/A	1,2,4,10
		SPRAY: N/A	N/A	N/A	N/A	N/A	N/A	
		SUBMERGENCE: N/A	N/A	N/A	N/A	N/A	N/A	
		TEST: NA						
		DEMO: NA						
ZONE NO: see sheet 2		DOCUMENT REFERENCE:						
FLOOD LEVEL		1. Environmental Design Criteria (EDC)						
ELEVATION: 105'-3" (Note 5)		SWEC Document No. 215.150, Rev. 2						
ABOVE FLOOD LEVEL? Yes		(including change notices no. 2-1, 2-2 and 2-3)						
DOCUMENTATION ACCEPTABILITY:		2. GE Environmental Qualification Report						
Acceptable to NUREG 0588, Cat 1		NEDC-30848						
per NEDE-24326-1-P								
MAINTENANCE/SURVEILLANCE:								
REFERENCE: 2								
QUALIFIED LIFE								
(YEARS): 5								
REFERENCE: 2								

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SPN S05B
 REV 2
 DATE 02-15-85
 SHEET 2

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
:Nuclear Boiler System					
:B21-FO22A	:	: EA740, Rev. N	: DW-1	: 1 h	:
:B21-FO22B	:	: EA740, Rev. N	: DW-1	: 1 h	:
:B21-FO22C	:	: EA740, Rev. N	: DW-1	: 1 h	:
:B21-FO22D	:	: EA740, Rev. N	: DW-1	: 1 h	:
:B21-FO28A	:	: EA740, Rev. N	: AB-114-2:	: 1 h	:
:B21-FO28B	:	: EA740, Rev. N	: AB-114-2:	: 1 h	:
:B21-FO28C	:	: EA740, Rev. N	: AB-114-2:	: 1 h	:
:B21-FO28D	:	: EA740, Rev. N	: AB-114-2:	: 1 h	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:

NOTES

1. The specified value represents the maximum of the composite envelope for environmental zones DW-1 and AB-114-2.
2. The specified value represents the 5 year total integrated dose for normal (including abnormal) conditions.
3. The specified value represents the 1 hour total integrated dose for design basis LOCA conditions.
4. One neutron per square-centimeter is equivalent to 8E-9 rads gamma radiation.
5. Flooding applies only to locations in Zone DW-1.
6. Temperature vs. time history:

Specified (see Note 1 above), °F	Qualified, °F
0 - 0.1s	0 - 52m
0.1 - 0.3s	52m - 3h
0.3 - 1s	3h - 6h
1s - 3h	6h - 30h
3h - 6h	30h - 4d
6h - 1d	4d - 34d
1d - 10d	34d - 100d
10d - 100d	

*rise time at the maximum capability of the test facility.

: NOTES (continued) :

: 7. Pressure vs. time history: :

Specified (see Note 1 above), psig		Qualified, psig	
0 -1s	0-25	0 - 52m	69*
1s-40s	25	52m - 3h	69
40s-60s	25-11	3h - 1d	44
60s- 1d	11	1d - 4d	28
1d-100d	0	4d -100d	11

: *rise time at the maximum capability of the test facility. :

: 8. Enveloped by accident temperature. The specified temperature for normal and abnormal environmental conditions is considered in the aging calculation. :

: 9. Enveloped by accident pressure. :

:10. Included in accident gamma dose. :

:11. Rev. N is equivalent to Rev. K which was originally qualified. :

GULF STATES UTILITIES
 RIVER BEND STATION - UNIT 1
 DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SRN S19
 REV 2
 DATE 02-15-85
 SHEET 2

EQUIP. NO.	DRAWING NO.	MODEL NO.	ENV. ZONE	OP. TIME	NOTES
<u>Nuclear Boiler System</u>					
:B21-F041A	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F041B	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F041C	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F041D	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F041F	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F041G	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F041L	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F047A	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F047B	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F047C	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F047D	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F047F	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F051B	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F051C	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F051D	:	: IMF-3A	: DW-1	: 100 d	: 1
:B21-F051G	:	: IMF-3A	: DW-1	: 100 d	: 1
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:
:	:	:	:	:	:

NOTES

1. The equipment is only required for the mitigation of a small break accident (break area less than 0.5 square feet, Reference 2). The operability time is 2 days for active cycling and 100 days for maintaining the operator selected position.
2. The specified value represents the maximum value resulting from a small break accident (break area less than 0.5 square-feet).
3. The specified value represents the 5 year total integrated dose for normal (including abnormal) conditions. The small break accident (break area less than 0.5 square-feet) does not result in an additional dose above normal (including abnormal) conditions.

4. Temperature vs. time history:

Specified, °F	Qualified, °F
0 - 60s	140-330
60s- 3h	330
3h- 6h	310-250
1d- 10d	250-160
10d-100d	160-140

5. Pressure vs. time history:

Specified, psig	Qualified, psig
0-60s	0-11
60s- 1d	11
1d-10d	11-0

6. One neutron per square-centimeter is equivalent to 8E-9 rads gamma radiation.

ATTACHMENT 3

JUSTIFICATION FOR INTERIM OPERATION (JIO)