

Duquesne Light Company

Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077-0004

JOHN D. SIEBER  
Vice President - Nuclear Group

412 393 5255


August 31, 1992

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1 and No. 2  
BV-1 Docket No. 50-334, License No. DPR-66  
BV-2 Docket No. 50-412, License No. NPF-73  
Correction to Response to Generic Letter 92-01

Enclosed is a corrected page to our submittal responding to Generic Letter 92-01. The Unit 1 report, Table 5 (page 9), contained several typographical errors at the bottom of the page describing the heat treatment. Please replace that page with the attached.

Sincerely,

  
J. D. Sieber

cc: Mr. L. W. Rossbach, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. De Agazio, Project Manager  
Mr. M. L. Bowling (VEPCO)

9209110141 920831  
PDR ADOCK 05000334  
P PDR

*Aug 31*

Table 5

Beaver Valley Unit 1  
Materials Certification Information

Component: Lower Shell, B6903-1  
Material Specification A533 C1 1

Heat No.: C6317-1

## MILL Chemical Analysis[7]

C	Mn	P	S	Si	Ni	Mo	Cu	Al	Co
0.20	1.31	0.010	0.015	0.18	0.54	0.55	0.20	0.028	0.014

## Charpy Impact and Fracture Tests - Transverse[8]

Temp °F	Ft-Lbs	% Shear	Mils Lat. Exp.
-100	4.0	3	4
-100	2.5	3	2
-100	4.5	3	U
-50	6.0	3	2
-50	9.0	5	7
-50	9.0	5	5
10	40.0	29	31
10	20.0	21	26
10	28.5	18	19
40	33.0	28	30
40	46.5	33	37
40	34.0	28	29
110	63.5	51	54
110	64.0	53	60
110	77.0	57	63
160	76.0	100	60
160	82.0	100	67
160	82.5	100	69
210	83.0	100	70
210	82.5	100	66
210	82.0	100	69

Temp. °F	Drop Weights	NDT	RTNDT	USE
-60	F	-50°F	27°F	80 ft-lb
-50	F			
-40	2 NF			
-20	NF			
0	NF			

## Heat Treatment[7]

1550-1650°F, 4 hours. Water quenched.  
1200-1250°F, 4 hours. Air cooled.  
1125-1175°F, 40 hours. Furnace cooled.