

APPENDIX A

NOTICE OF VIOLATION

Georgia Power Company

License No.: NPF-5

Based on the results of the NRC inspection conducted during the period of November 11 - December 15, 1978, it appears that certain of your activities were not conducted in full compliance with NRC requirements as indicated below. This item has been categorized as described in our correspondence to you dated December 31, 1974.

Technical Specification 6.8.1 requires in part that written procedures be implemented. Hatch Nuclear Plant Procedure No. 12, Plant Operating Orders, requires in Section B.1 that the shift foreman be responsible for seeing that standing orders are carried out.

Contrary to the above, standing order HNP-2-78-5 dated March 13, 1978 requiring monthly readings on pressurized containment penetrations had not been performed.

This item is an infraction and is applicable to Unit 2.

7903 120393