



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-280

SURRY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 101  
License No. DPR-32


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated September 19, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-32 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 101, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: January 22, 1985



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-281

SURRY POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 100  
License No. DPR-37


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated September 19, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-37 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 100, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: January 22, 1985

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 101 FACILITY OPERATING LICENSE NO. DPR-32

AMENDMENT NO. 100 FACILITY OPERATING LICENSE NO. DPR-37

DOCKET NOS. 50-280 AND 50-281

Revise Appendix A as follows:

Remove Page

Table 4.1-2A

Insert Page

Table 4.1-2A

TABLE 4.1-2A

MINIMUM FREQUENCY FOR EQUIPMENT TESTS

<u>Description</u>	<u>Test</u>	<u>Frequency</u>	<u>FSAR Section Reference</u>
1. Control Rod Assemblies	Rod drop times of all full length rods at hot conditions	Each refueling shutdown or after disassembly or maintenance requiring the breach of the Reactor Coolant System integrity	7
2. Control Rod Assemblies	Partial movement of all rods	Every 2 weeks	7
3. Refueling Water Chemical Addition Tank	Functional	Each refueling shutdown	6
4. Pressurizer Safety Valves	Setpoint	Each refueling shutdown	4
5. Main Steam Safety Valves	Setpoint	Each refueling shutdown	10
6. Containment Isolation Trip	*Functional	Each refueling shutdown	5
7. Refueling System Interlocks	*Functional	Prior to refueling	9.12
8. Service Water System	*Functional	Each refueling shutdown	9.9
9. Fire Protection Pump and Power Supply	Functional	Monthly	9.10
10. Primary System Leakage	*Evaluate	Daily	4
11. Diesel Fuel Supply	*Fuel Inventory	5 days/week	8.5
12. Boric Acid Piping Heat Tracing Circuits	*Operational	Monthly	9.1
13. Main Steam Line Trip	Functional (1) Full closure (2) Partial closure	(1) Each cold shutdown (2) Before each startup	10