

JAN 25 1985

Docket No. 50-354

Mr. R. L. Mittl, General Manager
Nuclear Assurance and Regulation
Public Service Electric & Gas Company
P.O. Box 570, T22A
Newark, New Jersey 07101

Dear Mr. Mittl:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - TMI ITEM II.K.3.28

Staff review of TMI Action Item II.K.3.28, Qualification of Accumulators on Automatic Depressurization System (ADS) Valves, has resulted in the identification of additional information needed to proceed with our review.

This information is identified in the Enclosure to this letter. Please supply the requested information by no later than 45 days from the date of this letter. Should you have any questions, please contact us.

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Distribution:

~~Docket File~~
NRC PDR
Local PDR
NSIC
LB#2 Reading
EHylton
DWagner
LDewey
ACRS (16)
EJordan
RHeischman
JLombardo
GBagchi
RLaGrange
VNoonan

LD
LB#2/DL
DWagner:dh
01/24/85

LB#2/DL
ASchwencer
01/25/85

B502010301 B50125
PDR ADOCK 05000354
A PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JAN 25 1985

Docket No. 50-354

Mr. R. L. Mittl, General Manager
Nuclear Assurance and Regulation
Public Service Electric & Gas Company
P.O. Box 570, T22A
Newark, New Jersey 07101

Dear Mr. Mittl:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - TMI ITEM II.K.3.28

Staff review of TMI Action Item II.K.3.28, Qualification of Accumulators on Automatic Depressurization System (ADS) Valves, has resulted in the identification of additional information needed to proceed with our review.

This information is identified in the Enclosure to this letter. Please supply the requested information by no later than 45 days from the date of this letter. Should you have any questions, please contact us.

R. C. Martin
A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Hope Creek

Mr. R. L. Mittl, General Manager
Nuclear Assurance & Regulation
Public Service Electric & Gas Company
P. O. Box 570 T22A
Newark, New Jersey 07101

cc:

Troy B. Conner, Jr. Esquire
Conner & Wetterhahn
1747 Pennsylvania Avenue N.W.
Washington, D.C. 20006

Richard Fryling, Jr., Esquire
Associate General Solicitor
Public Service Electric & Gas Co.
P. O. Box 570 T5E
Newark, New Jersey 07101

Mr. R. Blough
Resident Inspector
U.S.N.R.C.
P. O. Box 241
Hancocks Bridge, New Jersey 08038

Richard F. Engel
Deputy Attorney General
Division of Law
Environmental Protection Section
Richard J. Hughes Justice Complex CN-112
Trenton, New Jersey 08625

Mr. Robert J. Touhey, Acting Director
DNREC - Division of Environmental Control
89 Kings Highway
P. O. Box 1401
Dover, Delaware 19903

Mr. R. S. Salvesen
General Manager-Hope Creek Operation
Public Service Electric & Gas Co.
P.O. Box A
Hancocks Bridge, New Jersey 08038

Mr. B. A. Preston
Project Licensing Manager
Public Service Electric & Gas Co.
P. O. Box 570 T22A
Newark, New Jersey 07101

Susan C. Remis
Division of Public Interest Advocacy
New Jersey State Department of
the Public Advocate
Richard J. Hughes Justice Complex
CN-850
Trenton, New Jersey 08625

Gregory Minor
Richard Hubbard
Dale Bidenbauh
MHB Technical Associates
1723 Hamilton Avenue, Suite K
San Jose, California 95125

Office of Legal Counsel
Department of Natural Resources
and Environmental Control
89 Kings Highway
P.O. Box 1401
Dover, Delaware 19903

Mr. K. W. Burrowes, Project Engineer
Bechtel Power Corporation
50 Beale Street
P. O. Box 3965
San Francisco, California 94119

Mr. J. M. Ashley
Senior Licensing Engineer
c/o PSE&G Company
Bethesda Office Center, Suit 550
4520 East-West Highway
Bethesda, Maryland 20814

Mr. A. E. Giardino
Manager - Quality Assurance E&C
Public Service Electric & Gas Co.
P. O. Box A
Hancocks Bridge, New Jersey 08038

REQUEST FOR ADDITIONAL INFORMATION
NINE MILE POINT, UNIT 2

MULTI-PLANT ACTION F-55 OR TMI II.K.3.28
VERIFY QUALIFICATION OF ACCUMULATOR ON ADS VALVES

- 1) Based on the requirements of NUREG-0737 Item II.K.3.28, it is necessary to demonstrate that the ADS valves, accumulators, and associated equipment and instrumentation meet the requirements specified in the plant FSAR and are capable of performing their functions during and following exposure to hostile environments, taking no credit for non-safety-related equipment or instrumentation. Additionally, air (or nitrogen) leakage through the valves must be accounted for to assure that enough inventory of compressed gas is available to cycle the ADS valves. If this cannot be demonstrated, it must be shown that the accumulator design is still acceptable. Since this system is a part of the emergency core cooling system, it must still perform its function for the long-term period of 100 days following an accident.

You are requested to address in detail (a) how you meet this long-term capability requirement of 100 days following an accident or (b) the justification as to why a shorter time frame is sufficient long-term capability for your plant, or (c) provide a commitment and schedule for upgrading to the 100 day long-term capability requirement.

- 2) Define the number of times the ADS pneumatically controlled valve is capable of cycling using only the accumulator inventory at atmospheric pressure and at a specified percent (i.e., 70%) of drywell pressure, and the length of time these accumulators are capable of performing their function following an accident.
- 3) Describe the ADS accumulator system design and operation (e.g., trains, air supply, capacity, alarms and instrumentation and their location, etc.)
- 4) Define the basis for the allowable leakage criteria for the ADS accumulator system (e.g., boundary conditions, environmental and seismic parameters, operator interface, margin, etc.).
- 5) What margin is in the allowable leakage criteria to account for possible increase in leakage in the ADS accumulator system resulting from effects of a harsh environment and/or a seismic event?
- 6) A statement that test and/or analysis performed verified that a harsh environment and/or seismic event would not increase the leakage rate in the ADS accumulator system.
- 7) A statement that verifies that no credit was taken for non-safety-related equipment and instrumentation when establishing the allowable leakage criteria for the ADS accumulator system.

REQUEST FOR ADDITIONAL INFORMATION (CONT'D.)

- 8) Provide a concise description of the tests performed on the ADS accumulator system, and backup, and their frequency.
- 9) Provide a concise description of the surveillance performed, and how frequent, on alarms and instrumentation associated with the ADS accumulator system and backup system.
- 10) Provide a statement that confirms that the ADS accumulator system, backup system, and associated equipment and control circuitry, are seismically qualified.
- 11) Provide a statement that confirms that the ADS accumulator system, backup system, and associated equipment and control circuitry are environmentally qualified for conditions associated with normal operation, maintenance, testing, and postulated accidents.
- 12) Provide a statement verifying that the ADS valves, accumulators, backup system, associated equipment and instrumentation are capable of performing their function during and following an accident situation while taking no credit for non-safety-related equipment and instrumentation.
- 13) Excerpts from the plants technical specification verifying that they specify the following:
 - ADS leak test frequency
 - Allowable leakage rate
 - Actions to be taken, in a specified time frame, should the leakage rate be exceeded.
- 14) Provide a concise description of the design and operation of the backup system and confirm that it will meet the overall requirement of the ADS system following an accident.