

CP&L
USNRC REGION II
ATLANTA
Carolina Power & Light Company

84 DEC 27 1984
ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

DEC 27 1984

Robinson File No: 13510

Serial: RSEP/84-1260

Mr. A. Gibson
Chief, Operations Branch
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 2900
Atlanta, Georgia 30323

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NC. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
RO/SRO EXAM - DECEMBER 17 - 21, 1984

Dear Mr. Gibson:

A Reactor Operator, Senior Reactor Operator (RO/SRO) examination was administered by Mr. Ed Cook during the week of December 17. The following suggestions and comments on this examination are provided per NUREG-1021.

1. It is suggested that the point value of the exam be reviewed for consistency.

Example: 1 point for AOP immediate actions
1 point for knowing a number (RCS H₂ concentration)
2. The examination included questions on actions to take per the EOP network. The new EOP network was designed so the Operator would not have to memorize these actions. It was intended to remove the burden of memorization off the Operator. Therefore, questions requiring the memorization of actions in the EOPs should not be included in the exam.
3. SRO Exam, Section 6, Question 2(b). Resin damage does not occur until the temperature increases beyond 145°F which is the setpoint for TCV-143. Please consider this point when grading this question.
4. The length of time temporary procedures and special procedures are effective is not included in our RO training program and does not appear to be in 10CFR55. This has not been considered as required RO knowledge.


Letter to Mr. A. Gibson
Serial: RSEP/84-1260
Page 2

5. When grading the exams, we suggest that you accept answers that are true even if not listed on the answer key.

Example: There may be many symptoms for primary to secondary leak other than those listed in the answer key.

Should you have any questions, please contact Mr. Steve Allen at 803-383-4524 Extension 341.

Very truly yours,



R. E. Morgan
General Manager
H. B. Robinson S.E. Plant

JCS/wp

Attachment

cc: G. P. Beatty, Jr.
C. A. Bethea
F. L. Lowery
D. R. Nelson
D. C. Stadler
A. C. Tollison
S. R. Zimmerman