JAN 28 1985

Georgia Power Company
ATTN: Mr. R. J. Kelly
Executive Vice President
P. O. Box 4545
Atlanta, Georgia 30302

Gentlemen:

SUBJECT: REPORT NOS. 50-424/84-30 AND 50-425/84-30

Thank you for your letter of December 27, 1984, responding to our Notice of Violation issued November 30, 1984, concerning activities under NRC Construction Permit Nos. CPPR-108 and CPPR-109. We have evaluated your responses and found that they meet the requirements of 10 CFR 2.201.

It is our understanding that you concur with our Violation 1 finding relative to corrections in revisions of design drawings and we will examine the implementation of your corrective actions during future inspections.

We have carefully reviewed the bases of your denial of Violation 2 regarding nonconformance procedure and Violation 3 relative to control of welding. We agree with your position with respect to Violation 3 and have deleted it from our records as a violation but have designated it as an unresolved item pending further NRC inspection. With respect to Violation 2, we have concluded that a "verbal hold" is neither adequate to satisfy the requirements of 10 CFR 50 Appendix B, Criterion XV, nor permissible under the Pullman Power Products Procedure SV-4 involved. Therefore, in accordance with 10 CFR 2.201(a), please submit to this office within 30 days of the date of this letter a written statement that, for Violation 2, describes the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further violations, and the date when full compliance will be achieved.

The response directed by this letter is not subject to the clearance procedures of the Office of Management and Budget issued under the Paperwork Reduction Act of 1980, PL 96-511.

Sincerely,

151

James P. O'Reilly Regional Administrator

cc: (See page 2)

D. O. Foster, Vice President and General Manager

J. T. Beckham, Vice President and General Manager - Operations

H. H. Gregory, III, General Manager, Vogtle Nuclear Construction

G. Bockhold, Jr., General Manager, Vogtle Nuclear Operations

C. W. Hayes, QA Manager

E. D. Groover, Q.A. Site Manager

bcc: E. Reise, ELD NRC Resident Inspector Document Control Desk State of Georgia

GAM 111strom:cdg

ARHerdt

VLBrownlee

01/13/85