

ENCLOSURE 1

NOTICE OF VIOLATION

Tennessee Valley Authority
Sequoyah

Docket Nos. 50-327 and 50-328
License Nos. DPR-327 and DPR-328

The following violations were identified during an inspection conducted on October 29 - November 2, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 20, Appendix A, foot note d-2(b) requires that the removal efficiency of air purifying respirator filters be determined with a thermally generated 0.3 micrometer dioctyl phthalate (DOP) test.

Contrary to the above, air dispersed corn oil was used to determine the removal efficiency of air purifying respirator filters prior to reuse.

This is a Severity Level V violation (Supplement IV).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: NOV 21 1984

8502010506 850123
PDR ADDCK 05000327
Q PDR