

September 2, 1992

JOHN D. SIEBER
Vice President - Nuclear Group

412) 393-5255

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555


Subject: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Correction to Proposed Operating License Change Request
No. 198
(TAC No. 84229)

Reference: Proposed Operating License Change Request
No. 198 (TAC No. 84229), dated August 18, 1992

Attachment D was provided in the above referenced request to list those surveillances for which a surveillance interval extension is requested. Several surveillances were omitted from that submittal. Therefore, please replace Attachment D with the corrected attachment which includes the following additional surveillances:

<u>Surveillance Requirement</u>	<u>Function</u>	<u>Due Date</u>
4.4.11.3	Valve Exercise	3/21/93
4.5.2.f	Valve Exercise	3/13/93
1.5.3.1	Valve Exercise	3/13/93
4.6.3.1.2.f	Valve Exercise	3/21/93
4.7.3.1.c	Valve Exercise	3/21/93
4.4.5.3	Steam Generator	1/11/93
	Category C-3 Inspection	

Sincerely,


J. D. Sieber

Attachment

cc: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. De Agazio, Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. M. L. Bowling (VEPCO)

9209140156 920902
PDR ADOCK 05000334
P PDR

ADD 1

ATTACHMENT D

Beaver Valley Power Station, Unit No. 1
Proposed Operating License Change No. 198
EXTENDED TECHNICAL SPECIFICATION SURVEILLANCES

Technical Specification - 4.3.1.1.1 Table 4.3-1 Reactor Trip System Instrumentation - Channel Calibration and Functional Test	Due 2/27/93
Technical Specification - 4.3.1.1.3 Table 3.3-2 Reactor Trip System Instrumentation - Response Times	Due 3/30/93
Technical Specification - 4.3.2.1.1 Table 4.3-2 Engineered Safety Feature Actuation System Instrumentation - Channel Calibration and Functional Test	Due 3/2/93
Technical Specification - 4.3.2.1.3 Table 3.3-5 Engineered Safety Feature Actuation System Instrumentation - Response Times	Due 3/2/93
Technical Specification - 4.3.3.1 Table 4.3-3 Radiation Monitoring Instrumentation - Channel Calibration	Due 3/4/93
Technical Specification - 4.3.3.3.1 Table 4.3-4 Seismic Monitoring Instrumentation - Channel Calibration	Due 3/11/93
Technical Specification - 4.3.3.5 Table 4.3-6 Remote Shutdown Instrumentation - Channel Calibration	Due 3/3/93
Technical Specification - 4.3.3.8 Table 4.3-7 Accident Monitoring Instrumentation - Channel Calibration	Due 3/9/93
Technical Specification - 4.4.5.3 Steam Generator Category C-3 Inspection	Due 1/11/93
Technical Specification - 4.4.9.3.1.b Overpressure Protection System - Channel Calibration	Due 3/11/93
Technical Specification - 4.4.11.1.b PORV Operability - Channel Calibration	Due 3/9/93
Technical Specification - 4.4.11.3 Valve Exercise	Due 3/21/93
Technical Specification - 4.5.1.2.b Accumulator Operability - Channel Calibration	Due 3/12/93
Technical Specification - 4.5.2.f Valve Exercise	Due 3/13/93

ATTACHMENT D (continued)
Beaver Valley Power Station, Unit No. 1
Proposed Operating License Change No. 198

Technical Specification - 4.5.3.1 Valve Exercise	Due 3/13/93
Technical Specification - 4.6.3.1.2.e Containment Isolation Valves - Check Valve Lift Test	Due 3/8/93
Technical Specification - 4.6.3.1.2.f Valve Exercise	Due 3/21/93
Technical Specification - 4.7.3.1.c Valve Exercise	Due 3/21/93
Technical Specification - 4.7.13.1.b Auxiliary River Water System Test	Due 4/21/93
Technical Specification - 4.8.1.1.1.b and 4.8.1.2 Emergency Switchgear Operation and Diesel Generator Auto Load Tests	Due 3/10/93
Technical Specification - 4.8.1.1.2.b Diesel Generator Test and Inspection	Due 4/26/93
Technical Specification - 4.8.2.3.2 DC Distribution - Battery Cell Conditions and Charger Capacity	Due 3/6/93
Technical Specification - 4.8.2.4.2 DC Distribution - Battery and Charger Service Testing	Due 3/6/93