BRAIDWOOD NUCLEAR POWER STA ION

UNIT 1 AND UNIT 2

MONTHLY PERFORMANCE REPORT

COMMONWEALTH EDISON COMPANY

NRC DOCKET NO. 050-456, LICENSE NO. NPF-72

NRC DOCKET NO. 050-457, LICENSE NO. NPF-77

- I. Monthly Report for Braidwood Unit 1
 - A. Summary of Operating Experience

Braidwood Unit 1 entered the month of August at approximately 99% reactor power. The unit operated in a routine coast down in preparation for a scheduled September 1992 refuel outage.

B. OPERATING DATA REPORT

DOCKET NO.: 50-456

UNIT: Braidwood 1 DATE: 09/10/92

COMPILED BY: P. Stanczak TELEPHONE: (815)458-2801

ext. 2486

OPERATING STATUS

1. Reporting Period: August, 1992 Gross Hours: 744

2. Currently Authorized Power Level (MWt): 3411
Design Electrical Rating (MWe-gross): 1175
Design Electrical Rating (MWe-net): 1120
Max Dependable Canacity (MWe-gross): 1175
Max Dependable Capacity (MWe-net): 1120

3. Power level to which restricted (If Any): None

4. Reasons for restriction (If Any): None

		THIS MONTH	YR TO DATE	CUMULATIVE
5.	Report Period Hours:	744.0	5855.0	35864.0
6.	Hours Reactor Critical	744.0	5789.7	28069.9
7.	RX Reserve Shutdown Hours:	0.0	0.0	0.0
8.	Hours Generator on Line	744.0	5770.5	27602.5
9.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
10.	Gross Thermal Energy (MWHt)	2086628.0	18285009.5	83269525.5
11.	Gross Elec. Energy (MWH)	701744.0	6211422.0	28533614.0
12.	Net Elec. Energy (MWH):	671287.0	5969520.0	27271444.0
13.	Reactor Service Factor:	100.0	98.9	78.3
14.	Reactor Availability Factor:	100.0	98.9	78.3
15.	Unit Service Factor:	100.0	98.6	77.0
16.	Unit Availability Factor:	100.0	98.6	77.0
17.	Unit Capacity Factor (MDC NET):	80.6	91.0	67.9
18.	Unit Capacity Factor (DER NET):	80.6	91.0	67.9
19.	Unit Forced Outage Rate:	0.0	1.4	10.5
20.	Unit Forced Outage Hours:	0.0	84.5	3236.3

21. Shutdown Schedule Over Next 6 months. Refuel Outage September 1992

22. If Shutdown at end of Reporting Period Estimated Date of Startup

C. AVERAGE DAILY UNIT NET POWER LEVEL LOG

DOCKET NO.: 50-456

UNIT: Braidwood 1

DATE: 09/10/92

COMPILED BY: P. Stanczak

TELEPHONE: (815)458-2801

ext. 2486

MONTH:	August,	1992
--------	---------	------

MONTH. MU	gust, 133c			
1	1083	17	885	
2.	1070	18.	878	
3.	1044	19.	870	
4.	1042	20.	851	
5.	1032	21,	827	
6.	1020	22.	826	
7	990	23	825	
8.	970	24	810	
9.	960	25.	796	
10.	951	26	797	
11	939	27.	789	
12.	937	28	783	
13	927	29.	783	
14	915	30.	783	
15	897	31.	776	
16.	896			

INSTRUCTIONS

On this form list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt. These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

DOCKET NO.: 50-476

UNIT: Braidwood 1 DATE: 09/10/92

COMPILED BY: P. Stanczak

TELEPHONE: (815)458-2301

ext 2486

REPORT PERIOD: August, 1992

NO DATE TYPE HOURS REASON METHOD LER NUMBER SYSTEM COMPONENT CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE

* S U M M A R Y *

F-forced S-Scheduled REASON
A-Equipment Failure Maint or Test

B-Maint or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination

F-Administration

G-Oper E-ror

H-Other

METHOD

1 - Method

2 - Manual Scram

3 - Auto Scram

4 - Continued

5 - Reduced Load

9 - Other

SYSTEM & COMPONENT

Exhibit F & H

Instructions for Preparation of

Data Entry Sheet

Licensee Event Report

(LCR) File (NUREG-0161)

E. UNIQUE REPORTING REQUIREMENTS - UNIT 1

Safety/Relief valve operations.

VALVES NO & TYPE PLANT
DATE ACTUATED ACTUATION CONDITION

DESCRIPTION OF EVENT

Licensee , nerated changes to ODCM.

None.

NONE

F. LICENSEE EVENT REPORTS - UNIT 1

The following is a tabular summary of all Licensee Event Reports submitted during the reporting period, August 1 through August 31, 1992. This information is provided pursuant to the reportable occurrence reporting requirements as set forth in 10 CFR 50.73.

Licensee Event Report Number	Report Date	Title of Occurrence
92-007	08/21/92	Fuel Mandling Building Venti- lation Charcoal Booster Fan Automatic Start on Momentary Spike of OAR-550
92-008	08/24/92	Non-Conservative Degraded Voltage Setpoints

II. Monthly Report for Braidwood Unit 2

A. Summary of Operating Experience

Braidwood Unit 2 entered the month of August 1992 at approximately 99% reactor power. On August 1, power was reduced to obtain an oil sample and vibration readings for the 2C reactor coolant pump due to an increase in the motor thrust bearing temperature. Test results were satisfactory and power was increased. On August 8, power was reduced to observe the oil levels for the reactor coolant pump motors. Results were satisfactory and power was increased. On August 15, while decreasing power per the load dispatcher, a rod drive urgent failure occurred. Power was increased after the rod drive power supply was repaired and rod drive testing completed. The unit operated routinally through the end of the month.

B. OPERATING DATA REPORT

DOCKET NO.: 50-457

UNIT: Braidwood 2 DATE: 09/10/92

COMPILED BY: P. Stanczak TELEPHONE: (815)458-2801

ext. 2486

OPERATING STATUS

1. Reporting Period: August, 1992 Gross Hours: 744

Currently Authorized Power Level (MWt): 3411
 Design Electrical Rating (MWe-gross): 1175
 Design Electrical Rating (MWe-net): 1120
 Max Dependable Capacity (MWe-gross): 1175
 Max Dependable Capacity (MWe-net): 1120

3. Power level to which restricted (If Any): None

4. Reasons for restriction (If Any): None

		THIS HONTH	YR TO DATE	CUMULATIVE
5	. Report Period Hours:	744.0	5855.0	33946.0
6	. Hour Reactor Critical	744.0	5518.4	29285.0
7	. RX keserve Shutdown Hours:	0.0	0.0	0.0
8	. Hours Generator on Line	744.0	5483.3	28023.3
9	. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
10	. Gross Thermal Energy (MWHt)	2256254.0	1/389915.0	82745466.0
11	. Gross Elec. Enerry (MWH)	757122.0	5939796.0	28297236.0
12	. Net Elec. Energy (MWH):	726163.0	5708746.0	27071641.0
13	. Reactor Service Factor:	100.0	94.3	83.3
14	. Reactor Availability Factor:	100.0	94.3	83.3
15	. Unit Service Factor:	100.0	93.7	82.6
16	. Unit Availability Factor:	100.0	93.7	82.6
17	. Unit Capacity Factor (MDC NET):	87.1	87.1	71.2
18	. Unit Capacity Factor (DER NET):	87.1	87.1	71.2
19	. Unit Forced Outage Rate:	0.0	3 3	3.9
20	. Unit Forced Outage Hours:	0.0	185.0	1132.8

21. Shutdown Schedule Over Next 6 Months.

22. If Shutdown at end of Report Period, Estimated Date of Startup

C. AVERAGE DAILY UNIT NET POWER LEVEL LOG DOCKET NO.: 50-457

UNIT: Braidwood 2

DATE: 09/10/92

COMPILED BY: P. Stanczak

TELEPHONE: (815)458-2801

ext. 2486

MONTH:	August,	1992
LIPOTA LITTA	nugust,	1225

PION I II .	nugust, 1332			
1	956	17.	780	
2	527	18.	1061	
3	975	19.	1049	
4	1040	20.	1079	
5	1026	21.	1034	
6	1091	22.	938	
7	1023	23	954	
8	1036	24.	1058	
9	761	25	1000	
10	1085	26	1097	
11	1045	27	1087	
12	978	28	1033	
13	980	29.	1035	
14	1027	30.	926	
15	962	31.	989	
16.	516			

INSTRUCTIONS

On this form list the average daily unit power level in MWe-Nei for each day in the reporting month. Compute to the nearest whole megawatt. These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

D. UNIT SHUTDOWNS/REDUCTIONS

DOCKET NO.: 50-457

UNIT: Braidwood 2

DATE: 09/10/92

COMPILED BY: P. Stanczak

TELEPHONE: (815)458-2801

ext. 2486

REPORT PERIOD: August, 1992

H-Other

No 12	DATE 920801	TYPE	HOURS	REASON B	METHOD 5	LER NUMBER	SYSTEM	COMPONENT	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE Power reduced to obtain oil sample and vibration readings for the 2C reactor coolant pump due to an increased motor thrust bearing temperature. Results were satisfactory and power was increased.
13	920808	S		В	5		RC	Р	Power was reduced to observe oil levels in the reactor collant pump motors. Results were satisfactory and power was increased.
14	920815	S		H/B	5		RD	XFMR	While decreasing power per the load dispatcher, a rod drive urgent failure occurred. Power was increased after the rod drive power supply was repaired and rod drive testing completed.

* S U M M A R Y *

TYPE	REASON	METHOD	SYSTEM & COMPONENT
F-Forced S-Scheduled	A-Equipment Failure Maint or Test B-Maint or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administration G-Oper Error	1 - Method 2 - Manual Scram 3 - Auto Scram 4 - Continued 5 - Reduced Load 9 - Other	Exhibit F & H Instructions for Preparation of Data Entry Sheet Licensee Event Report (LER) File (NUREG-0161)

(609ZD85G)13

E. UNIQUE REPORTING REQUIREMENTS - UNIT 2

Safety/Relief valve operations.

DATE

VALVES NO & TYPE ACTUATED ACTUATION

PLANT CONDITION

DESCRIPTION OF EVENT

NONE

2. Licensee generated changes to ODCM.

NONE

F. LICENSEE EVENT REPORTS - UNIT 2

The following is a tabular summary of all Licensee Event Reports submitted during the reporting period, August 1 through August 31, 1992. This information is provided pursuant to the reportable occurrence reporting requirements as set forth in 10 CFR 50.73.

Licensee Event Report Number

Report

Title of Occurrence

NONE