

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of	)	UNIT NO. 1	UNIT NO. 2
	)	Docket No. 50-334	Docket No. 50-412
Duquesne Light Company	)	License No. DPR-66	License No. NPF-73
Beaver Valley Power Station)	)		

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the technical specifications set forth in Appendix A to these licenses be amended to modify the frequency specified for Table 4.3-1 Notation (3) from "monthly" to "31 effective full power days".

The proposed technical specification changes are set forth in Attachments A to this Application. A safety analysis and no significant hazard evaluation are set forth in Attachment B. Typed replacement pages for the technical specifications are included in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to these operating licenses be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber  
J. D. Sieber  
Vice President  
Nuclear Group

Subscribed and sworn to before me  
on this 2nd day of September, 1992.

Sheila M. Fattore

Notarial Seal  
Sheila M. Fattore, Notary Public  
Shawnington Boro, Beaver County  
My Commission Expires Sept. 26, 1994  
Member, Pennsylvania Association of Notaries