



September 4, 1992

1CAN099201

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-107
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Inservice Inspection Outage Summary Report

Gentlemen:

Section 4, "Surveillance Requirements", of the Arkansas Nuclear One, Unit 1 (ANO-1) Technical Specifications requires, in part, that Inservice Inspection (ISI) of ASME Code Class 1, 2, and 3 components shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable addenda as required by 10CFR50, Section 50.55a(g).

Article IWA-6230, Section XI of the ASME Code requires the Owner to submit an ISI summary report. This report is due within 90 days of the completion of the ISIs conducted during a refueling outage. The scope of this report is for Class 1 and 2 pressure retaining components and their supports. The purpose of this submittal is to provide the required summary report.

Attachment 1 provides the summary report of the ISIs performed during the tenth refueling outage (1R10). The forms NIS-2, "Owner's Report for Repairs or Replacements" are provided in Attachment 2 and addresses repairs and/or replacements since the completion of the ninth refueling outage (1R9), January 7, 1991, through the completion of 1R10, May 9, 1992, for ANO-1. The delay in this submittal, as described in letter dated August 7, 1992 (1CAN089202), was due to an unexpected heavy workload following 1R10.

Should you have any questions regarding this issue, please contact me.

Very truly yours,

James J. Fisicaro
James J. Fisicaro
Director, Licencing

JJF/RWC/sjf
Attachments

080089

9209150237 920904
PDR ADOCK 05000313
Q PDR

*AOA7
11*

cc: Mr. James L. Milhoan
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Sheri R. Peterson
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

ATTACHMENT 1

INSERVICE INSPECTION
SUMMARY REPORT FOR ANO-1