

Donald C. Shelton
Vice President - Nuclear
Davis Besse

300 Madison Avenue
Toledo, OH 43652-0001
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 2053

September 9, 1992

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Fire Protection - Updated National Fire Protection
Association Code Compliance

Gentlemen:

By letter dated July 31, 1989, Toledo Edison (TE) submitted to the Nuclear Regulatory Commission (NRC) the National Fire Protection Association (NFPA) Code compliance status for the Davis-Besse Nuclear Power Station (TE letter Serial Number 1685). The NRC's Safety Evaluation (SE) of Fire Protection Measures at the Davis-Besse Nuclear Power Station per Appendix R to 10 CFR Part 50, dated May 30, 1991 (TE letter Log Number 3480), discussed the electrical circuits associated with the fire alarm and signaling systems which are not supervised in accordance with NFPA Standard 72D-1975 (Proprietary Protective Signaling Systems). The NRC's SE also discussed TE's plans to assess the scope and nature of modifications necessary to correct these deficiencies and TE's plan to correct them during the eighth refueling outage (scheduled for Spring 1993).

The purpose of this letter is to formally inform the NRC that TE has completed its evaluation of these deviations. The evaluation provides either: 1) the scope of the modifications to correct a noted deviation, or 2) the justification for the acceptance of the deviation without modification. The modifications to correct noted deviations are planned to be completed prior to restart from the eighth refueling outage. This evaluation was discussed at a meeting on May 14, 1992 between TE, the NRC Staff and, as discussed at the meeting, will be retained on site for NRC review.

9209150263 920909
PDR ADOCK 05000346
F PDR


Operating Companies
Cleveland Electric Illuminating
Toledo Edison

ADOCK 1/0

Docket Number 50-346
License Number NPF-3
Serial Number 2053
Page 2

If you have any questions regarding this matter, please contact
Mr. E. W. Schrauder, Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,


KBR/ed

cc: A. B. Davis, Regional Administrator, NRC Region III
J. B. Hopkins, NRC/NRR DB-1 Senior Project Manager
W. Levis, NRC Region III, DB-1 Senior Resident Inspector
Utility Radiological Safety Board