

200

SEP 4 1992

Docket No. 50-461

Illinois Power Company
ATTN: F. A. Spangenberg, III
Manager, Licensing and Safety
Clinton Power Station
P. O. Box 678
Clinton, IL 61727

Dear Mr. Spangenberg:

This acknowledges receipt of your letters dated April 27 and July 21, 1992, which transmitted changes identified as Revisions 10C, 10D, and 11 to the Clinton Station Physical Security Plan submitted under the provisions of 10 CFR 30.54(p).

We have reviewed the submitted changes and have determined that they are consistent with the provisions of 10 CFR 50.54(p) and are therefore acceptable.

Your appendix to the security plan indicated that the security system may be without an uninterruptible power supply (UPS) for a short period of time. Please advise us within 30 days after receipt of this letter of the compensatory measures that will be implemented when the system is without UPS capability to assure that personnel can respond in a timely manner through computer controlled doors in case of a power failure.

The enclosure to your letters contained Safeguards Information of a type specified in 10 CFR 73.21 and is being withheld from public disclosure.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter will be placed in the NRC Public Document Room.

Sincerely,

Cynthia D. Pederson
Cynthia D. Pederson, Chief
Reactor Support Programs Branch

146025

cc: See Attached List

RIII

[Signature]
Pirtle/jp
09/4/92

RIII

[Signature]
Belanger

RIII

[Signature]
Creed

RIII

[Signature]
Lanksbury
9/4/92

RIII

[Signature]
Pederson

2601 / 0

Illinois Power Company

2 SEP 4 1992

bcc: NRR/DRIS/RSGB
SG Case File: 0500046124WA & 0500046125WA
SG Inspector File: J. Belanger
SG Correspondence File: G. Pirtle
NRR Docket File

CLINTON

Docket No. 50-461

Mr. J. S. Perry
Vice President
Clinton Power Station
P. O. Box 678
Clinton, IL 61727

Manager-Nuclear Station Engineering Dept.
Clinton Power Station
P. O. Box 678
Clinton, IL 61727

Sheldon Zabel, Esquire
Schiff, Hardin & Waite
7200 Sears Tower
233 Wacker Drive
Chicago, IL 60606

Resident Inspector
U. S. Nuclear Regulatory Commission
RR No. 3, Box. 229A
Clinton, IL 61727

Project Manager
General Electric Company
175 Curtner Ave. N/C 395
San Jose, California 95125

Chairman of DeWitt County
c/o County Clerk's Office
DeWitt County Courthouse
Clinton, IL 61727

Illinois Department of
Nuclear Safety
Division of Engineering
1035 Outer Park Drive, 5th Floor
Springfield, IL 62704

Mr. Donald Schopfer
Project Manager
Sargent & Lundy Engineers
55 East Monroe Street
Chicago, IL 60603