



Commonwealth Edison
1400 Opus Place
Downers Grove, Illinois 60515

September 2, 1992

Dr. Thomas E. Murley, Director
Nuclear Reactor Regulations
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attn: Document Control Desk

Subject: LaSalle County Station Unit 2
Unit 2 Cycle 5 Startup Test Report
NRC Docket 50-374

Reference: July 8, 1992 letter from J. Shields to Dr. Murley transmitting the Unit 2
Cycle 5 Startup Test Report

Dear Dr. Murley;

The referenced letter contains the results of the performance of the LaSalle Unit 2 Cycle 5 Startup Tests, including test LTP-1600-17, Core Power Distribution Symmetry Analysis. The TIP signal symmetry results were shown in Table 3 of the document. Upon further review of this data, it has been determined that the data in the column titled "Absolute Difference of BASE#" is incorrect, as it reflects the difference between the BASE values for the TIP set performed on May 5, 1992. The data should represent the difference between the average BASE values from each of the two TIP sets.

Attached is a corrected Table 3, to supercede the one originally supplied. We regret any inconvenience this may have caused your staff. If you have any questions, please call this office.

Respectfully,

JoAnn Shields
Nuclear Licensing Administrator

Attachment

cc: A.B. Davis, Regional Director - RIII
B.L. Siegel, Project Manager - NRR
D.L. Hills, Senior Resident Inspector - LSCS
Office of Nuclear Safety - IDNS

NLD2119/1

9209150377 920908
PDR ADDCK 05000374
P PDR

JE26 1/1