



August 31, 1992  
LD-92-095

Docket No. 52-002

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20585

Subject: System 80+™ Distribution Systems Design Detail  
Reference: ABB-CE Letter LD-92-038, CESSAR-DC Submittal  
Schedule Update, March 25, 1992

Dear Sir:

Based on meetings held with your staff on November 26, 1991, and February 26, 1992, ABB-CE committed (Reference) to providing a greater level of detail for the design of System 80+ distribution systems (piping, HVAC duct work, and electrical cable trays). This information is provided by Enclosures I, II, and III.

Enclosure I is an engineering report containing sample analyses for piping, HVAC duct work, electrical cable tray and pipe break and LBB evaluations for preliminary designs of piping systems. Enclosure II is a sample System 80+ piping analysis specification, to which the sample piping analyses of Enclosure I is compared. Enclosure III consists of piping Design Acceptance Criteria along with supporting documentation, namely the piping portions of the previously-transmitted draft Distribution Systems Design Guide and preliminary/sample piping analyses of the Enclosure I report.

The Design Acceptance Criteria will be resubmitted in a modified form when ABB-CE provides the complete System 80+ ITAAC package. This will allow us to take into account NRC comments on the pilot ITAAC package submitted August 10, 1992.

The LBB evaluations for the main coolant loop and main steam line are complete and are presented in Enclosures I and III. The LBB methodology for the surge line, shutdown cooling line

ABB Combustion Engineering Nuclear Power

140693

Combustion Engineering, Inc.  
9209160316 920831  
PDR ADDCK 05200002  
A PDR

1000 Prospect Hill Road  
Post Office Box 560  
Windsor, Connecticut 06095-0560

Telephone (203) 688-1811  
Fax (203) 285-6512  
Telex 95297 COMBEN WSOP

D032

and direct vessel injection line are also presented, but results are not expected until October 1992. ABB-CE requests a meeting with NRC staff for the last week of October to discuss those results as well as the analyses currently being transmitted.

If you have any questions or comments on the enclosed material, please contact me or Stan Ritterbusch at (203) 285-5206.

Very truly yours,

COMBUSTION ENGINEERING, INC.



C. B. Brinkman  
Acting Director  
Nuclear Systems Licensing

/lw

Enclosures: As Stated

cc: T. Wambach (NRC)  
J. Trotter (EPRI)

## ABSTRACT

This report provides detailed analyses and results of specific distribution systems (piping, HVAC ductwork and electric cable tray/conduit) applicable to the System 80+ design. Some analyses are for sample distribution systems; piping analyses and evaluations associated with leak-before-break (LBB) are for detailed preliminary piping routing and design. This report is intended to provide additional level of detail regarding distribution systems in order to demonstrate that the final distribution system designs will be in compliance with design acceptance criteria.

## TABLE OF CONTENTS

	PAGE
PURPOSE	1
SCOPE	1
BACKGROUND	1
DESCRIPTIONS	2
LBB EVALUATIONS	2
SAMPLE CALCULATIONS	4
APPENDICES	

## LIST OF APPENDICES

- A. SURGE LINE - PRELIMINARY ROUTING AND LOADS ANALYSIS
- B. MAIN STEAM LINE - PRELIMINARY ROUTING AND LOADS ANALYSIS
- C. SHUTD/WN COOLING LINE - PRELIMINARY ROUTING AND LOADS ANALYSIS
- D. DIRECT VESSEL INJECTION - PRELIMINARY ROUTING AND LOADS ANALYSIS
- E. DESCRIPTION OF LEAK-BEFORE-BREAK METHODS
- F. LBB EVALUATION OF THE MAIN COOLANT LOOP
- G. LBB EVALUATION OF THE PRELIMINARY SURGE LINE
- H. LBB EVALUATION OF THE PRELIMINARY MAIN STEAM LINE
- I. LBB EVALUATION OF THE PRELIMINARY SHUTDOWN COOLING LINE
- J. LBB EVALUATION OF THE PRELIMINARY DIRECT VESSEL INJECTION
- K. SAMPLE ASME CLASS 1 PIPING ANALYSIS
- L. SAMPLE ASME CLASS 2/3 PIPING ANALYSIS
- M. SAMPLE HVAC DUCTWORK ANALYSIS
- N. SAMPLE CABLE TRAY ANALYSIS

#### PURPOSE

The purpose of this report is to provide detailed information pertaining to analysis and evaluation of System 80+ distribution systems (piping, HVAC ductwork and electrical cable tray) to demonstrate that the final distribution system designs will be in compliance with design acceptance criteria.

#### SCOPE

Detailed preliminary analyses and LBB evaluations of all System 80+ piping systems incorporating LBB are presented. Sample analyses and results for ASME Class 1 and Class 2/3 piping systems, postulated pipe breaks, HVAC ductwork and electrical cable trays are presented.

#### BACKGROUND

Following submittal of CESSAR-DC, the NRC staff indicated that a greater level of detail pertaining to piping design was necessary for them to complete their certification review. The staff indicated that this level of detail was particularly necessary for leak-before-break (LBB) evaluations, which the staff was required by GDC-4 to review on a case-by-case basis.

Following initial review and comment of the CESSAR-DC submittal, meetings between the NRC staff and ABB-CE were held November 26, 1991 and February 26, 1992 to discuss level of detail for piping design and the use of design acceptance criteria (DAC). The meetings resulted in a commitment by ABB-CE to provide the following additional level of detail to support the System 80+ certification effort:

- o A Distribution Systems Design Guide.
- o Design Acceptance Criteria (DAC) for piping design.
- o Preliminary detailed routing, design and LBB evaluation of each System 80+ piping system incorporating LBB.
- o A sample piping analysis specification for ASME Class 1 and Class 2/3 piping systems.
- o Sample analyses demonstrating compliance with the guidelines of the design guide for ASME Class 1 and 2/3 piping, HVAC ductwork and electrical cable tray.
- o A sample postulated pipe break analysis.

This report contains the preliminary detailed routing and design and LBB evaluations of the piping systems incorporating LBB and the

sample analyses of Class 1 and 2/3 piping, HVAC ductwork, electrical cable tray, and postulated pipe break. The Distribution Systems Design Guide and DAC are provided in separate documents.

#### DESCRIPTIONS

The sample analyses and LBB evaluations are contained in the appendices of this report. A brief description of these analyses and evaluations follow.

#### LEAK-BEFORE-BREAK EVALUATIONS

The System 80+ design incorporates leak-before-break LBB technology for five piping systems inside containment in order to eliminate the dynamic effects of postulated pipe break from those systems from the design basis. The five piping systems are:

1. Main Coolant Loop (hot leg and cold leg pipes)
2. Main Steam Line (main run inside containment)
3. Surge Line
4. Shutdown Cooling Line (main run inside containment)
5. Direct Vessel Injection (main run inside containment)

LBB evaluations have historically been performed on as-built piping systems, for which final detailed information on design, routing, components and material is available. The type of detail necessary to perform final LBB evaluations is not available at the design certification stage. In order to support the NRC staff's safety evaluation, an LBB evaluation is presented for the preliminary design of each piping system listed above. The evaluations utilize best presently available information and use methodologies described in the Distribution Systems Design Guide. The Design Guide, which is currently under review by the NRC staff, has been presented as a separate document.

Each LBB evaluation is performed on the preliminary routing and design of a specific piping system. To accomplish these piping-specific LBB evaluations, a range of acceptable piping design parameters is established for LBB for each piping system using methods described in the Design Guide, and response loads from preliminary piping analyses described below are compared to those acceptance criteria.

LBB acceptance criteria are established for each piping system in terms of curves for leakage crack length "a" and length "2a", relating the normal operation load which determines the leakage crack length to a corresponding maximum design load (eg., pipe load due to SSE or thermal stratification) necessary to maintain crack stability. By comparison of final calculated piping loads to the acceptance criteria, the final design of each piping system listed above is qualified for LBB. LBB methods generic to all piping systems incorporating LBB are presented in Appendix E.

Routing, design and seismic analysis of the main coolant loop has previously been performed as part of the CESSAR-DC submittals, and this work is used to support the LBB of that piping system. Preliminary routing, design and analysis of the other four piping systems are presented in accordance with the guidelines and methodologies of the Design Guide. Specifically, the preliminary piping analyses and associated LBB evaluations presented are as follows:

#### Main Coolant Loop (MCL)

The System 80+ MCL has been designed and seismically analyzed for CESSAR-DC. Seismic piping loads on the MCL hot leg and cold leg piping are extracted from the seismic analysis results, and maximized Safe Shutdown Earthquake (SSE) loads are established for use in the LBB evaluation. Normal operation loads for the preliminary LBB evaluation of the System 80+ MCL are conservatively established from loads from prior ABB-CE reactor coolant system designs. The LBB evaluation of the MCL is presented in Appendix F.

#### Surge Line (SL)

Thermal and seismic interface movements and seismic response spectra at the hot leg and pressurizer surge nozzles and building supports are established from System 80+ analyses of the RCS, pressurizer and reactor building. The anchors are the hot leg and pressurizer nozzles.

Design parameters affecting critical thermal stratification are established. Routing and support definition of the surge line are presented in Appendix A. Gravity, thermal, seismic and normal operation and critical thermal stratification analysis results are also presented in Appendix A. The LBB evaluation of the surge line is presented in Appendix G.

#### Main Steam Line (MSL)

Thermal and seismic interface movements and seismic response spectra at the steam generator nozzle and reactor building supports and penetration are established from System 80+ analyses of the RCS and reactor building. Routing and support definition of the MSL inside containment are presented in Appendix B. Gravity, thermal and seismic analysis results are presented in Appendix B, which also contains steam hammer analysis results. The LBB evaluation of the MSL is presented in Appendix H.

#### Shutdown Cooling Line (SC)

Thermal and seismic interface movements at the hot leg nozzle and reactor building anchors and supports are established from System 80+ analyses of the RCS and reactor building. Routing and support definition of the shutdown cooling line inside containment, from the hot leg nozzle to the first anchor, are presented in Appendix C. Gravity, thermal and seismic analyses results are also presented in Appendix C. LBB evaluation is not performed beyond the second normally closed valve of the shutdown cooling line, because that portion of the line is not pressurized and pipe breaks are not required to be postulated there. The LBB evaluation of the shutdown cooling line is presented in Appendix I.

#### Direct Vessel Injection (DVI)

Thermal and seismic interface movements and seismic response spectra at the reactor vessel nozzle and reactor building supports and anchors are established from System 80+ analyses of the RCS and building. Routing and support definition of the DVI line inside containment, from the reactor vessel nozzle to the first anchor, are presented in Appendix D. Gravity, thermal and seismic analyses results are also presented in Appendix D. The LBB evaluation of the DVI line is presented in Appendix J.

### SAMPLE CALCULATIONS

#### SAMPLE ASME CLASS 1 PIPING ANALYSIS

For a selected Class 1 piping system, the results of a full piping analysis is presented in Appendix K, including analyses due to

gravity and thermal loads, seismic excitations and vibratory motion due to a pipe break in another piping system. The Class 1 piping system selected for the sample analysis is the System 80+ preliminary shutdown cooling line. Sample RCS response motions due to a feedwater economizer break from a prior ABB-CE design are used as input to this analysis. Demonstration of compliance of analytical results to sample analysis specification is presented. Sample analysis specifications for the Class 1 piping system are provided in a separate document.

#### SAMPLE ASME CLASS 2/3 PIPING ANALYSIS AND SAMPLE PIPE BREAK ANALYSIS

For a selected Class 2/3 piping system, the results of a full piping analysis is presented in Appendix L, including analyses due to gravity and thermal loads, seismic excitations and vibratory motion due to a pipe break. The Class 2/3 piping system selected for the sample analysis is the System 80+ preliminary feedwater economizer line.

Thermal and seismic interface movements and seismic response spectra at the steam generator nozzle and reactor building supports and anchors are established from System 80+ analyses of the RCS and reactor building. Routing, support definition and results of the gravity, thermal and seismic analyses of the feedwater economizer line are presented in Appendix L. Demonstration of compliance of analytical results to sample analysis specification is presented. A sample analysis specification for the Class 2/3 piping system is provided in a separate document.

In order to demonstrate how the System 80+ design mitigates the dynamic effects of postulated pipe breaks for piping systems where LBB is not incorporated, a sample pipe break analysis for pipe breaks in the feedwater economizer line is presented in Appendix L. Results of a postulated pipe break location analysis and the design criteria for possible jet shields and pipe whip restraints are also presented in Appendix L.

#### SAMPLE HVAC DUCTWORK ANALYSIS

A sample routing of HVAC ductwork, established using guidelines of the Distribution Systems Design Guide, is presented in Appendix M. Results of the sample gravity and seismic analyses are also presented in Appendix M. Appropriate thermal and seismic inputs to the analysis from System 80+ containment design analyses are utilized.

#### SAMPLE CABLE TRAY ANALYSIS

A sample routing of electrical cable tray, established using guidelines of the Distribution Systems Design Guide, is presented in Appendix N. Results of the sample gravity and seismic analyses are also presented in Appendix N. Appropriate thermal and seismic inputs to the analysis from System 80+ containment design analyses are utilized.

APPENDIX A

SURGE LINE

PRELIMINARY ROUTING AND LOADS ANALYSIS

## APPENDIX A

### SURGE LINE - PRELIMINARY ROUTING AND LOADS ANALYSIS

#### Purpose

This appendix reports the results of a preliminary stress analysis of the System 80+ surge line in the Reactor Building to provide applicable forces and moments for the Leak-Before-Break (LBB) evaluation. The piping included in the model is represented in the isometric sketch that follows. The analysis model originates at the hot leg nozzle and terminates at the Pressurizer nozzle. Anchors are modelled at these locations. All applicable design conditions, loadings, codes, and regulatory requirements are defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 2.

The types of analysis results required for the LBB evaluation are shown on the following page. Other results in the detailed analysis include pipe displacements, stresses, support/restraint loads, and nozzle loads (anchor loads). Since the analysis is preliminary and design information is not available for allowable nozzle loads, it is not within the scope of the calculation to evaluate those loads.

A code compliance check is performed to verify that pipe stresses are within the ASME allowables for the pipe as modelled. As additional design information becomes available, it will be included in a final analysis.

#### Method

The piping is modelled as a three dimensional framework for analysis. Static analysis is performed by the Direct Stiffness Method and a simple Lumped Mass Idealization is used to determine mode shapes and frequencies for the dynamic analysis. This piping is analyzed using the SUPERPIPE computer program.

### References and Design Inputs


1. ASME Boiler and Pressure Vessel Code, Section III, 1989.
2. Draft Distribution Systems Design Guide.
3. ABB-CE Letter dated 4/21/92 to R.W. Bonsall enclosing Preliminary Thermal Movements and SSE Seismic Anchor Movements.
4. ABB-Impell memo dated 5/21/92 to ABB-CE, Attn: R.A. Matzie enclosing System 80+ N-411 Spectra and SAM.
5. System 80+ Nuclear Island Detailed Arrangement Drawings.
6. System 80+ Reactor Coolant System Piping and Instrumentation Diagram.

### Results

Forces and moments results for the load cases listed below are provided for the Leak-Before-Break evaluation shown in Appendix G.

1. Gravity - Fluid-filled
2. Thermal Expansion - Uniform Temperature
3. Thermal Expansion - Stratified Flow (653°F top,  
293°F bottom)
4. Thermal Expansion - Stratified Flow (480°F top,  
120°F bottom)
5. Thermal Expansion - Stratified Flow (653°F top,  
621°F bottom)
6. Gravity + Thermal - Uniform (1+2)
7. Gravity + Thermal - Stratified (1+3)
8. Gravity + Thermal - Stratified (1+4)
9. Gravity + Thermal - Stratified (1+5)
10. Seismic Inertia - SSE
11. Seismic Anchor Movement - SSE
12. Seismic Inertia + Seismic Anchor Movement

SYS80<sup>+</sup> SURFACE



O — DCP #

SUPPORT CODE:  CONSTANT-FORCE  
SPRING HANGER

\_\_\_\_\_ SOP #

(R) RIGID SWAY STRUT

LOAD CASE NO. 1 (GRA1), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1								
1	1		2339.85	34.52	12.53	4180.22	-5449.33	-53847.95
2L	2A		975.23	34.52	12.53	4180.22	-4558.51	-56301.67
2R	2A		975.23	12.53	-34.52	4180.22	-56301.68	-4558.51
3	2B		-10.27	434.23	-34.52	56940.88	3265.30	-8285.59
4			-15.08	-488.26	-34.52	56940.88	1606.52	-6987.08
5L	3A		-19.89	-1410.79	-34.52	56940.88	-52.28	38636.10
5R	3A		4.12	-51.17	-3195.69	56940.88	38635.85	-149.00
6L	3B		48.34	1.29	-2652.84	14001.05	4305.15	697.89
6R	3B		48.34	2652.81	-12.53	14001.05	-675.44	4308.73
7			41.64	1365.21	-12.53	14001.05	-1515.99	-130422.77
8			34.93	77.61	-12.53	14001.05	-2356.55	-178803.20
9			28.22	-1210.00	-12.53	14001.05	-3197.10	-140831.86
10L	6A		21.51	-2497.61	-12.53	14001.05	-4037.66	-16508.04
10R	6A		21.51	3.49	2497.65	14001.05	-16486.76	4123.67
11L	6B		-3.32	18.68	3049.49	-33354.70	63843.79	3727.65
11R	6B		-20.46	2461.76	34.52	-33285.71	-4015.36	63862.35
12L	60		-19.66	2327.35	34.52	-33285.71	-3773.65	47097.19
12R	60		25.75	2327.28	34.52	-33351.66	-3137.79	47097.19
13			18.26	1007.29	34.52	-33351.66	-764.26	-67530.05
14			10.76	-312.71	34.52	-33351.66	1609.28	-91406.41
15			3.26	-1632.71	34.52	-33351.66	3982.81	-24531.33
16L	61		-4.24	-2952.72	34.52	-33351.66	6356.36	133095.97
16R	61		25.15	2410.97	-24.23	-33354.49	6341.51	133095.97
17			20.17	1458.95	-24.23	-33354.49	5139.93	37150.53
18L	7A		15.19	506.92	-24.23	-33354.49	3938.14	-11588.58
18R	7A		15.18	-25.34	-506.86	-33354.57	-11597.13	-3912.18
19L	7B		27.23	-7.77	-235.44	-13428.51	-36509.41	-3669.72
19R	73		27.23	235.42	-8.27	-13423.51	3591.36	-36517.20
20L	71		21.35	-888.66	-8.27	-13428.51	3106.95	-17394.90
20R	71		158.08	-889.37	128.45	-13428.51	3106.95	-17394.90
21L	8A		153.26	-1811.01	128.45	-13428.51	9273.03	47417.96
21R	8A		169.67	-135.31	1328.21	-13428.51	-47465.23	9027.99
22L	8B		172.52	166.83	785.37	28443.15	5592.44	8409.91
22R	8B		132.52	786.23	-152.73	28443.15	8439.02	-5548.40
23L	81A		128.60	27.71	-162.73	28443.15	2010.25	-21626.48
23R	81A		128.60	162.58	28.55	28443.15	21615.81	2121.93
24L	81B		-165.38	125.80	-514.29	-17243.46	24072.02	-3119.21
24R	81B		-165.38	-513.64	-128.45	-17243.46	-2994.84	-24087.81
25L	9A		-169.31	-1273.93	-128.45	-17243.46	-8081.45	11305.22
25R	9A		-169.31	1273.93	-128.45	-17243.46	8081.45	-11305.22
26L	98		-1815.87	-162.73	128.45	-10470.61	-14889.37	-36048.43

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER/SEIS FOR LBB (lbb2)

PAGE 104  
23-JUN-92 16:01:25

LOAD CASE NO. 1 (GRA1<sup>1</sup>, FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1 (CONTD.)								
26R	9B		-1815.87	-24.23	205.89	-10470.61	-36018.47	-14961.72
27			-2582.57	-24.23	205.89	-10470.61	-27796.64	-13993.97
28	10		-3349.27	-24.23	205.89	-10470.61	-19574.79	-13026.23

LOAD CASE NO. 2 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1								
1	1	516.14	7067.10	3998.82	1059415.25	-364544.44	574455.00	
2L	2A	516.14	7067.10	3998.82	1059415.25	-43870.22	7728.37	
2R	2A	516.14	3998.82	-7067.10	1059415.38	7728.39	43870.22	
3L	2B	-3996.07	536.98	-7067.10	140573.86	915914.75	-47770.09	
3R	2B	-3996.07	536.98	-7067.10	140573.84	915914.75	-47770.09	
4		-3996.07	536.98	-7067.10	140573.84	532790.75	-76880.87	
5L	3A	-3996.07	536.98	-7067.10	140573.84	149665.16	-105991.76	
5R	3A	-3996.07	-7069.80	-500.15	140573.84	-106769.99	-149111.17	
6L	3B	7069.69	-3996.26	-500.15	116931.37	130413.10	75627.72	
6R	3B	7069.69	479.32	-3998.82	116931.37	-74946.98	130805.51	
7		7069.69	479.32	-3998.82	116931.37	-377528.28	94536.53	
8		7069.69	479.32	-3998.82	116931.37	-680110.88	58267.39	
9		7069.69	479.32	-3998.82	116931.35	-982693.44	21998.26	
10L	6A	7069.69	479.32	-3998.82	116931.37	-1285277.25	-14271.02	
10R	6A	7069.69	-4001.26	-458.46	116931.37	-7570.03	1285334.25	
11L	6B	4001.45	7069.58	-458.46	16884.09	107620.01	1223020.00	
11R	6B	3991.54	569.69	7067.10	39638.52	-1221916.62	113989.74	
12L	60	3991.54	569.69	7067.10	39638.52	-1166019.25	109489.37	
12R	60	4001.68	493.42	7067.10	17379.35	-1166633.25	109489.37	
13		4001.68	493.42	7067.10	17379.35	-618427.62	71213.98	
14		4001.68	493.42	7067.10	17379.35	-70219.83	32938.43	
15		4001.68	493.42	7067.10	17	9.35	477988.09	-5337.13
16L	61	4001.68	493.42	7067.10	17379.35	1026197.75	-43612.81	
16R	61	4001.45	495.20	-5139.79	16922.46	1026205.44	-43612.81	
17		4001.45	495.20	-5139.79	16922.46	738649.56	-71317.91	
18L	7A	4001.45	495.20	-5139.79	16922.46	451052.6	-99023.11	
18R	7A	4001.45	-5140.85	-484.09	16912.94	-100005.61	-450876.19	
19L	7B	6464.58	-805.75	-484.09	85552.77	-65708.21	-400851.63	
19R	7B	6464.58	482.36	-806.79	85552.77	400709.65	-66568.30	
20L	71	6464.58	482.36	-806.79	85552.77	147414.88	-98431.88	
20R	71	6278.69	483.33	-992.68	85552.77	347414.88	-98431.88	
21L	8A	6278.69	483.33	-992.68	85552.77	293649.78	-124609.69	
21R	8A	6278.69	990.17	498.45	85552.77	123091.30	294289.50	
22L	8B	-990.00	6278.71	498.45	18.83	95476.21	146666.86	
22R	8B	-990.00	521.26	-6276.08	13.008.84	147163.91	-94708.27	
23L	81A	-990.00	521.26	-6276.08	-133008.84	-132595.50	-117943.84	
23R	81A	-990.00	6273.30	553.67	-133008.83	118627.12	-131984.55	
24L	81B	-6273.33	-989.84	553.67	-129875.11	-121760.92	-239285.58	
24R	81B	-6273.33	548.55	992.68	-129875.13	-239911.30	120523.38	
25L	9A	-6273.33	548.55	992.68	-129873.13	-195558.66	96014.29	
25R	9A	-6273.33	-548.55	-992.68	-129875.13	195558.66	-96014.29	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS

PAGE 109  
23-JUN-92 16:01:26

SPC: SURGE LINE DWT/THRE. AIS FOR LBB (lbb2)

LOAD CASE NO. 2 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SCP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1 (CONTD.)								
26L	9B		516.14	-6276.08	-992.68	-176170.25	-149023.78	41875.64
26R	9B		516.14	-5139.79	3735.92	-176170.23	-7765.18	134986.28
27			516.14	-5139.79	3735.92	-176170.22	9258.93	366562.31
28	10		516.14	-5139.79	3735.92	-176170.23	260883.79	598139.31

S80+ SURGE LINE DWT/THER/SEIS FOR LBB (1bbb2)

LOAD CASE NO. 3 (STRH), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	S.F.	DCP MMB	NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1									
1	1			1676.80	3754.52	2694.87	574027.50	-1633913.88	1227809.38
2L	2A			1676.80	3754.52	2694.87	574027.50	-1434207.88	949577.44
2R	2A			1676.80	2694.87	-3754.52	593872.88	982406.38	1483791.38
3L	2P			-2686.10	1690.82	-3754.52	-906776.94	526085.31	1399078.00
3R	2B			-2686.10	1690.82	-3754.52	-906777.00	526085.47	1399078.00
4				-2686.10	1690.82	-3744.52	-906777.00	331489.72	1311443.25
5L	3A			-2686.10	1690.82	-3754.52	-906777.00	136893.30	1223808.25
5R	3A			-2686.10	-3763.27	-1671.24	-906776.94	1223078.50	-143266.73
6L	3B			3763.20	-2686.20	-1671.24	-1190653.75	-939193.87	-18041.94
6R	3B			3763.20	1657.21	-2694.87	-1190653.75	13146.63	-939275.12
7				3763.20	1657.21	-2694.87	-1190653.75	-181806.44	-1059161.62
8				3763.20	1657.21	-2694.87	-1190653.75	-376760.28	-1179048.50
9				3763.20	1657.21	-2694.87	-1190653.75	-571714.13	-1298935.38
10L	6A			3763.20	1657.21	-2694.87	-1190653.75	-766668.75	-3418823.00
10R	6A			3763.20	-2703.48	-1643.14	-1190653.75	-1414806.75	774055.44
11L	6B			2703.58	3763.13	-1643.14	1446678.25	-1222596.75	753480.94
11R	6B			2672.16	1712.77	3754.52	1460572.87	-732776.19	-1218655.00
12L	60			2672.16	1712.77	3754.52	1460572.87	-704420.44	-1231590.63
12R	60			2704.35	1661.46	3754.52	1446864.75	-732163.63	-1231590.63
13				2704.35	1661.46	3754.52	1446864.75	-453719.91	-1354808.50
14				2704.35	1661.46	3754.52	1446864.75	-175275.13	-1478027.13
15				2704.35	1661.46	3754.52	1446864.75	103169.74	-1601245.50
16L	61			2704.35	1661.46	3754.52	1446864.75	381615.47	-1724464.38
16R	61			2703.61	1662.67	-1255.71	1446694.63	382259.66	-1724464.38
17				2703.61	1662.67	-1255.71	1446694.63	315094.00	-1813397.50
18L	7A			2703.61	1662.67	-1255.71	1446694.63	247928.16	-1902330.63
18R	7A			2703.58	-1259.33	-1659.98	1446689.63	-1902866.13	-243813.62
19L	7B			2802.21	1021.21	-1859.98	2377930.25	-345383.50	-241898.55
19R	7B			2802.21	1662.17	1017.64	2377930.25	24156.78	-345901.75
20L	71			2802.21	1662.17	1017.64	2377930.25	305425.88	-450875.88
20R	71			10129.22	1623.87	8344.76	2377930.25	305425.88	-450875.88
21L	8A			10129.22	1623.87	8344.76	2377930.25	737526.69	-534961.81
21R	8A			10129.22	-8353.03	1580.75	2377930.25	531145.19	740279.94
22L	8B			8353.31	10129.00	1580.75	-561773.31	2408637.50	705797.31
22R	8B			8353.31	1633.67	-10120.60	-561773.31	718377.75	-2404915.50
23L	81A			8353.31	1633.67	-10120.60	-561773.31	287073.44	-2474536.75
23R	81A			8353.31	10112.02	1685.92	-561773.25	2473020.75	299850.84
24L	81B			-10111.80	8353.13	1685.92	-2505770.25	-528972.06	-58682.69
24R	81B			-10111.80	1729.05	-8344.76	-2505770.25	-61414.09	528661.94
25L	9A			-10111.80	1729.05	-8344.76	-2505770.25	-417868.72	454803.91
25R	9A			-10111.80	-1729.05	8344.76	-2505770.50	417868.69	-454803.91

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER,SEIS FOR LBB (lbb2)

PAGE 114  
23-JUN-92 16:01:26

LOAD CASE NO. 3 (STRH), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
-----------	---------	----------	------------------	--------------	--------------	-------------------	-------------------	-------------------

PRN1  
(CONTD.)

26L	9B	1676.80	-10120.60	8344.76	-591997.56	-2341552.25	-225906.98
26R	9B	1676.80	-1255.71	13056.98	-619211.25	-1898923.63	1564756.63
27		1676.80	-1255.71	13056.98	-619211.19	-1310634.12	1621333.13
28	10	1676.80	-1255.71	13056.98	-619211.25	-722342.06	1677910.13

S80+ SURGE LINE EWT/THER/SEIS FOR LBB (lbb2)

LOAD CASE NO. 4 (STRL), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1								
	1	1	1539.43	1538.26	1439.87	2588.9.12	-1520214.88	1059396.00
	2L	2A	1539.43	1538.36	1439.87	2588.9.12	-1417149.50	949281.19
	2R	2A	1539.43	1439.87	-1538.36	268369.69	984310.05	1469443.00
	3L	2B	-1431.83	1546.91	-1538.36	-954131.94	244580.08	1413592.00
	3R	2B	-1431.83	1546.91	-1538.36	-954132.00	244580.09	1413592.00
	4		-1431.83	1546.91	-1538.36	-954131.94	167392.31	1335975.13
	5L	3A	-1431.83	1546.91	-1538.36	-954132.00	90204.24	1258358.00
	5R	3A	-1431.83	-1545.40	-1538.88	-954132.06	1257871.13	-96758.30
	6L	3B	1546.36	-1431.87	-1538.88	-1228971.37	-983024.31	-40777.21
	6R	3B	1546.36	1531.39	-1439.87	-1228971.37	35653.15	-983223.38
	7		1546.36	1531.39	-1439.87	-1228971.37	-65185.50	-1090471.50
	8		1546.36	1531.39	-1439.87	-1228971.37	-166024.56	-1197720.25
	9		1546.36	1531.39	-1439.97	-1228971.37	-266863.66	-1304968.75
	10L	6A	1546.36	1531.39	-1439.87	-1228971.37	-367703.09	-1412217.75
	10R	6A	1546.36	-1447.84	-1523.86	-1228971.37	-14.0281.50	375060.69
	11L	6B	1447.88	1546.32	-1523.86	1438891.50	-1257653.75	373209.59
	11R	6B	1419.11	1558.59	1538.36	1445711.75	-352903.47	-1255692.63
	12L	60	1419.11	1558.59	1538.36	1445711.75	-341655.94	-1267088.00
	12R	60	1448.59	1531.22	1538.36	1438928.89	-369181.63	-1267088.00
	13		1448.59	1531.22	1538.36	1438929.09	-258734.92	-1377022.50
	14		1448.59	1531.22	1538.36	1438929.00	-148287.81	-1486957.50
	15		1448.59	1531.22	1538.36	1438928.88	-77840.67	-1596892.38
	16L	61	1448.59	1531.22	1538.36	1438928.88	72606.84	-1706827.75
	16R	61	1447.91	1531.87	281.94	1438896.50	73247.44	-1706827.75
	17		1447.91	1531.87	281.94	1438896.50	87846.55	-1786149.25
	18L	7A	1447.91	1531.87	281.94	1438896.50	102445.70	-1865471.25
	18R	7A	1447.88	278.60	-1532.51	1438894.38	-1865590.00	-98411.64
	19L	7B	826.82	1220.80	-1532.51	2345127.75	-322185.69	-110085.76
	19R	7B	826.82	1535.13	1217.50	2345127.50	109394.08	-322421.16
	20L	71	826.82	1535.13	1217.50	2345127.50	183831.05	-416277.22
	20R	71	7885.31	1498.23	8276.09	2345127.50	183831.05	-416277.22
	21L	8A	7885.31	1498.23	8276.09	2345127.50	598697.50	-491381.00
	21R	8A	7885.31	-8283.72	1455.46	2345127.75	488282.00	601227.63
	22L	8B	8283.93	7885.08	1455.46	-515576.34	2372499.25	608720.50
	22R	8B	8283.93	1496.66	-7877.37	-515576.47	621113.25	-2369285.00
	23L	81A	8283.93	1496.66	-7877.37	-515576.47	296123.00	-2431031.50
	23R	81A	8283.93	7869.53	1537.33	-515576.28	2429469.50	308675.50
	24L	81B	-7869.31	8284.14	1537.33	-2458379.50	-486614.50	5042.25
	24R	81B	-7869.31	1580.09	-8276.09	-2458379.75	2528.79	486634.00
	25L	9A	-7869.31	1580.09	-8276.09	-2458379.75	-339708.63	421293.09
	25R	9A	-7869.31	-1580.09	8276.09	-2458379.75	339708.53	-421293.09

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER/SEIS FOR LBS (lbb2)

PAGE 119  
23-JUN-92 16:01:26

LOAD CASE NO. 4 (STRL), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1 (CONTD.)								
26L	98	1539.43	-7877.37	8276.09	-507164.50	-2301028.25	-244436.58	
26R	98	1539.43	281.94	11422.22	-524586.31	-1861744.75	1504164.50	
27		1539.43	281.94	11422.22	524586.31	-1369070.50	1492023.50	
28	10	1539.43	281.94	11422.22	-524586.31	-876394.25	1479862.63	

LOAD CASE NO. 5 (ST32), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB. IN)	YY MOMENT (LB. IN)	ZZ MOMENT (LB. IN)
PRN1								
	1	632.49	7009.73	4002.10	1053015.37	-493644.84	656482.06	
2L	2A	632.49	7009.73	4002.10	1053015.37	-172709.64	94320.65	
2R	2A	632.49	4002.10	-7009.73	1053015.50	94320.68	172709.64	
3L	2B	-3998.75	653.34	-7009.73	52799.23	911122.38	78670.52	
3R	2B	-3998.75	653.34	-7009.73	52799.22	911122.38	78670.52	
4		-3998.75	653.34	-7009.73	52799.22	531084.62	43299.53	
5L	3A	-3998.75	653.34	-7009.73	52799.22	151045.42	7928.42	
5R	3A	-3998.75	-7015.04	-616.81	52799.23	7141.46	-151084.69	
6L	3B	7012.93	-3998.94	-616.81	5268.71	40290.34	72564.14	
6R	3B	7012.93	595.96	-4002.10	5368.70	-72353.16	40668.01	
7		7012.93	595.96	-4002.10	5369.70	-375180.75	-4359.90	
8		7012.93	595.96	-4002.10	5361.76	-678009.53	-49388.00	
9		7012.93	595.96	-4002.10	5361.76	-980838.44	-94416.10	
10L	6A	7012.93	595.96	-4002.10	5368	-283658.52	-139444.37	
10R	6A	7012.93	-4005.15	-575.09	5368.	-132750.08	1284378.13	
11L	6B	4005.34	7012.83	-575.09	144411.56	-6296.59	1223286.25	
11R	6B	3993.26	686.07	7009.73	167159.91	-1220402.00	76.07	
12L	60	3993.26	686.07	7009.73	167159.91	-1165024.38	-5336.65	
12R	60	4005.63	609.74	7009.73	145874.00	-1168012.63	-6215.65	
13		4005.63	609.74	7009.73	145874.00	-624256.63	-53514.45	
14		4005.63	609.74	7009.74	145874.00	-80498.72	-100813.43	
15		4005.63	609.74	7009.73	145874.00	463259.37	-148112.39	
16L	61	4005.63	609.74	7009.73	145874.00	1007019.19	-195411.55	
16R	61	4005.35	611.53	-4974.58	145425.64	1007084.06	-195411.55	
17		4005.35	611.53	-4974.58	145425.64	728771.13	-229624.72	
18L	7A	4005.35	611.53	-4974.58	145425.64	450457.25	-263837.97	
18R	7A	4005.34	-4975.90	-600.77	145416.11	-264118.72	-449884.44	
19L	7B	6350.69	-686.36	-600.77	293652.50	-93061.23	-402251.88	
19R	7B	6350.69	599.30	-687.65	293652.50	402051.22	-93924.25	
20L	71	6350.69	599.30	-687.65	293652.50	356626.56	-133512.70	
20R	71	6840.92	596.74	-197.41	293652.50	356626.56	-133512.70	
21L	8A	6840.92	596.74	-197.41	293652.50	345936.72	-165832.80	
21R	8A	6840.92	194.32	597.75	293652.47	164043.80	346786.59	
22L	8B	-194.14	6840.93	597.75	-176175.42	305796.81	203908.94	
22R	8B	-194.14	633.50	-6837.71	-176175.45	205504.56	-304726.78	
23L	81A	-194.14	633.50	-6837.71	-176175.45	-99290.01	-332965.28	
23R	81A	-194.14	6834.35	668.81	-176175.42	333473.63	-97568.89	
24L	81B	-6834.35	-193.95	668.81	-347061.03	-162583.47	-232427.58	
24R	81B	-6834.35	667.80	197.41	-347061.03	-233264.23	161380.81	
25L	9A	-6834.35	667.80	197.41	-347061.03	-224444.22	131543.97	
25R	9A	-6834.35	-667.80	-197.41	-347061.06	224444.20	-131543.97	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER/SEIS FOR LBB (1bb2)

PAGE 124  
23-JUN-92 16:01:26

LOAD CASE NO. 5 (ST32), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
-----------	---------	----------	------------------	--------------	--------------	-------------------	-------------------	-------------------

PRN1  
(CONTD.)

26L	9B	632.49	-6937.71	-197.41	-222245.36	-349906.25	20102.93
26R	9B	632.49	-1974.58	4695.40	-222245.33	-233206.17	261636.02
27		632.49	-4974.58	4695.40	-222245.31	-21652.14	485769.44
28	10	632.49	-4974.58	4695.40	-222245.33	189902.83	709901.87

LOAD CASE NO. 6 (THDW), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
PRN1								
	1	2855.99	7101.62	4011.35	1063595.50	-369993.78	520007.06	
2L	2A	1491.38	7101.62	4011.35	1063595.50	-48426.73	-48573.30	
2R	2A	1491.38	4011.35	-7101.62	1063595.63	-48573.28	48429.73	
3L	2B	-4006.34	971.20	-7101.62	197514.73	919180.06	-56055.69	
3R	2B	-4006.34	971.20	-7101.62	197514.70	919180.06	-56055.69	
4		-4011.15	48.70	-7101.62	197514.70	534397.25	-93867.95	
5L	3A	-4015.96	-873.81	-7101.62	197514.70	149613.08	-67355.66	
5R	3A	-3991.95	-7120.97	-3635.84	197514.70	-68134.14	-149260.17	
6L	3B	7118.04	-3994.97	-3153.00	130932.42	134718.25	76325.61	
6R	3B	7118.04	3132.13	-4011.35	130932.42	-75622.41	135114.25	
7		7111.33	1844.53	-4011.35	130932.42	-379044.28	-35886.25	
8		7104.62	556.93	-4011.35	130932.42	-682467.44	-120535.81	
9		7097.91	-730.68	-4011.35	130932.41	-985890.50	-118833.60	
10L	6A	7091.20	-2018.29	-4011.35	132932.42	-1289314.88	-30779.06	
10R	6A	-791.20	-4000.77	2039.18	130932.42	-24056.79	1 9457.88	
11L	6B	3998.14	7088.27	2582.02	-16470.61	171463.81	1 46747.63	
11R	6B	3971.08	3031.46	7101.62	6352.81	-1225902.00	177852.09	
12L	60	3972.08	2897.04	7101.62	6352.81	-1169862.88	156586.56	
12R	60	4027.44	2820.70	7101.62	-15972.32	-1169771.13	156586.56	
13		4019.94	1500.71	7101.62	-15972.32	-619191.88	3683.93	
14		4012.44	180.71	7101.62	-15972.32	-68610.55	-58467.99	
15		4004.94	-1139.29	7101.62	-15972.32	481970.91	-29868.46	
16L	61	3997.45	-2459.30	7101.62	-15	1032554.06	89483.16	
16R	61	4026.62	2906.17	-5164.02	-1	1032547.00	89483.16	
17		4021.64	1954.15	-5164.02	-16432.03	743789.38	-34167.39	
18L	7A	4016.65	1002.12	-5164.02	-16432.02	455030.78	-110611.69	
18R	7A	4016.63	-5166.19	-990.95	-16441.63	-111602.77	-454788.38	
19L	7B	6491.81	-813.52	-719.53	72124.27	-10223.63	-404521.34	
19R	7B	6491.81	717.78	-815.06	72124.27	404301.06	-103085.50	
20L	71	6485.93	-406.30	-815.06	72124.27	350521.84	-115826.77	
20R	71	6436.77	-406.04	-864.23	72124.27	350521.84	-115826.77	
21L	8A	6431.95	-1327.68	-864.23	72124.27	302922.81	-77191.73	
21R	8A	6448.36	854.86	1816.65	72124.25	75626.07	303317.47	
22L	8B	-857.49	6445.55	1273.82	-104565.59	101068.65	155076.77	
22R	8B	-857.49	1307.49	-6438.80	-104565.70	155602.94	-100256.67	
23L	81A	-861.41	548.97	-6438.80	-104565.70	-130585.25	-139570.31	
23R	81A	-861.41	6435.88	582.22	-104565.69	140242.92	-129862.61	
24L	81B	-6438.71	-864.04	39.38	-147118.56	-97688.91	-242404.80	
24R	81B	-6438.71	34.91	864.23	-147118.58	-242906.14	96435.58	
25L	9A	-6442.63	-725.38	264.23	-147118.58	-203640.11	107319.50	
25R	9A	-6442.63	725.38	-964.23	-147118.58	203640.11	-107319.50	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER/SEIS FOR LBB (1bb2)

PAGE 129  
23-JUN-92 16:01:26

LOAD CASE NO. 6 (THDW). FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB. IN)	YY MOMENT (LB. IN)	ZZ MOMENT (LB. IN)
-----------	---------	----------	------------------	--------------	--------------	--------------------	--------------------	--------------------

PRN1  
(CONTD.)

26L	98	-1299.73	-6438.80	-864.23	-186640.86	-163913.16	5827.20
26R	98	-1299.73	-5164.02	3941.82	-186640.84	-111793.65	120024.57
27		-2066.42	-5164.02	3941.82	-186640.83	64762.29	352568.34
28	10	-2833.13	-5164.02	3941.82	-186640.84	241309.00	585113.12

LOAD CASE NO. 7 (SHDN), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1								
1	1	4016.54	379.04	2707.41	578207.75	-1639363.13	1173961.37	
2L	2A	2652.03	3789.04	2707.41	578207.75	-1438766.38	893275.75	
2R	2A	2652.03	2707.41	-3789.04	598053.13	926104.69	1488349.88	
3L	2B	-2696.37	2125.05	-3789.04	-849836.06	529350.63	1190792.38	
3R	2B	-2696.37	2125.05	-3789.04	-849836.13	529370.75	1190792.38	
4		-2701.18	1202.54	-3789.04	-849836.13	333096.25	1304456.13	
5L	3A	-2705.98	280.03	-3789.04	-849836.13	136841.02	1262444.38	
5R	3A	-2681.97	-3814.15	-4866.92	-849836.06	1261714.38	-143415.73	
6L	3B	3811.54	-2684.91	-4324.08	-1176652.75	-934888.69	-17344.05	
6R	3B	3811.54	4310.03	-2707.41	-1176652.75	12471.19	-934966.44	
7		3804.84	3022.43	-2707.41	-1176652.75	-183322.44	-1189584.38	
8		3798.13	1734.82	-2707.41	-1176652.75	-379116.81	-1357851.63	
9		3791.42	447.21	-2707.41	-1176652.75	-574911.19	-1439767.38	
10L	6A	3784.71	-840.40	-2707.41	-1176652.75	-770706.44	-1435331.00	
10R	6A	3784.71	-2702.99	854.50	-1176652.75	-1431293.63	778179.06	
11L	5B	2700.26	3781.81	1397.35	1413323.50	-1158753.00	757208.62	
11R	6B	2651.69	4174.53	3789.04	1427287.13	-736791.56	-1154792.75	
12L	60	2653.49	4040.12	3789.04	1427287.13	-708194.00	-1184493.38	
12R	60	2730.11	3998.74	3789.04	1413513.00	-735301.38	-1184493.38	
13		2722.51	26.875	3789.04	1413513.00	-454484.16	-1422338.50	
14		2715.11	1348.75	3789.04	1413513.00	-173665.84	-1569433.50	
15		2707.61	28.75	3789.04	1413513.00	107152.55	-1625776.88	
16L	61	2700.12	-1291.26	3789.04	1413513.00	387971.84	-1591368.39	
16R	61	2728.77	4073.64	-1279.94	1413340.13	388601.16	-1591368.39	
17		2723.79	3121.61	-1279.94	1413340.13	320233.81	-1776247.00	
18L	7A	2718.80	2164.58	-1279.94	1413340.13	251866.30	-1913919.25	
18R	7A	2718.75	-1284.67	-2166.85	1413335.00	-1914463.25	-247725.81	
19L	7B	2829.44	1013.44	-1895.42	2364501.75	-381892.94	-245568.27	
19R	7B	2829.44	1897.59	1009.37	2364501.75	244748.14	-382438.97	
20L	71	2823.56	773.52	1009.37	2364501.75	308532.84	-468270.78	
20R	71	10287.30	734.50	8473.21	2364501.75	308532.84	-468270.78	
21L	8A	10282.49	-187.14	8473.21	2364501.75	746799.69	-487543.81	
21R	8A	10298.90	-8488.35	2908.96	2364501.75	483680.00	749308.00	
22L	8B	8485.82	10295.83	2366.12	-533330.12	2414230.00	714207.19	
22R	8B	8485.82	2419.90	-10283.32	-533330.12	726816.75	-2410463.75	
23L	91A	8481.90	1661.38	-10283.32	-533330.12	289083.69	-2496163.25	
23R	81A	8481.91	10274.60	1714.47	-533330.06	2494636.50	301972.75	
24L	81B	-10277.18	8479.38	1171.63	-2523013.75	-504900.07	-61801.90	
24R	81B	-10277.18	1215.41	-8473.21	-2523013.75	-56408.93	504574.12	
25L	9A	-10281.11	455.12	-8473.21	-2523013.75	-425950.16	466109.09	
25R	9A	-10281.11	-455.12	8473.21	-2523014.00	-50.13	-466109.09	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S804 SURGE LINE DWT/THER/SEIS FOR LPS (1bb2)

PAGE 134  
23-JUN-92 16:01:26

LOAD CASE NO. 7 (SHOW), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
C-1								
26L	98		-139.07	-10283.32	8473.21	-602469.13	-2356441.75	-261955.41
26R	98		-139.07	-1279.94	13262.87	-629681.81	-1934942.00	1549794.88
27			-905.77	-1279.94	13262.87	-629681.75	-1318230.75	1607339.13
28	10		-1672.48	-1279.94	13262.87	-629681.81	-761916.81	1664883.88

LOAD CASE NO. 8 (SLDW), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
PRN1								
1	1	3879.27	1572.88	1452.41	262999.34	-1525664.13	1005548.06	
2L	2A	2514.56	1572.89	1452.41	262999.34	-1421708.06	892979.50	
2R	2A	2514.56	1452.41	-1572.88	272549.91	925008.38	1474001.50	
3L	2B	-1442.10	1981.14	-1572.88	-897191.12	247845.37	1405306.38	
3R	2B	-1442.10	1981.14	-1572.88	-897191.19	247845.39	1405306.38	
4		-1466.91	1050.60	-1572.88	-897191.12	168998.84	1328988.00	
5L	3A	-1451.72	136.12	-172.88	-897191.19	90151.96	1296994.13	
5R	3A	-1427.76	-1597.57	-4734.56	-897191.25	1296507.07	-96307.29	
6L	3B	1594.70	-1430.58	-4191.72	-3214970.38	-978719.13	-49073.32	
6R	3B	1594.70	4184.21	-3452.41	-3214970.25	34977.71	-9/8914.69	
7		1587.53	2896.60	-1452.41	-3214970.25	-66701.49	-1220894.25	
8		1581.29	2609.00	-1452.41	-3214970.25	-168381.12	-1376523.38	
9		2574.58	321.39	-1452.41	-3214970.25	-270060.75	-1445800.63	
10L	6A	1567.57	-966.22	-1452.41	-3214970.25	-321746.75	-1428225.88	
10R	6A	1567.57	-1447.35	973.78	-3214970.25	-1425768.25	279184.54	
11L	6B	1444.56	1565.90	1516.52	1405536.79	-1193610.00	376932.25	
11R	6B	1398.64	4020.35	1572.88	1412426.00	-356918.91	-1191830.38	
12L	60	1400.45	3885.94	1572.88	14012426.00	-345429.59	-1219990.98	
12R	60	1474.24	3858.51	1572.88	1405577.13	-372319.41	-219990.98	
13		1466.95	2538.51	1572.88	1405577.25	-259499.17	-1444552.50	
14		1459.35	1218.51	1572.88	1405577.25	-146678.53	-1578363.88	
15		1451.85	-101.49	1572.88	1405577.13	-33857.85	-1621423.75	
16L	61	1448.35	-1421.49	1572.88	1405577.13	78963.20	-1573731.75	
16R	61	1473.06	3942.94	257.70	1405542.00	29558.95	-1573731.75	
17		1468.08	2990.81	257.70	1405542.30	92986.38	-1748998.75	
18L	7A	1463.10	2038.79	257.70	1405542.00	106382.84	-1877059.08	
18R	7A	1463.05	253.26	-2039.37	1405539.75	-1877287.13	-102323.82	
19L	7B	854.05	1213.03	-1767.95	2321699.25	-338695.13	-113755.47	
19R	7B	854.05	1770.55	1209.23	2321699.00	112985.45	-358938.34	
20L	71	848.17	646.47	1229.23	2321699.00	186938.00	-433672.13	
20R	71	8083.39	608.86	8604.54	2231699.00	186938.03	-433672.13	
21L	8A	8038.57	-312.78	8404.54	2331699.00	607970.50	-443963.03	
21R	8A	8054.58	-8419.03	2783.66	2331699.25	440816.78	610255.63	
22L	8B	8416.45	8051.92	2240.83	-487133.22	2378091.75	617130.44	
22R	8B	8416.45	2282.89	-9040.09	-487133.34	629552.31	-2374833.25	
23L	81A	8412.53	1524.37	-8040.09	-487133.34	298133.25	-2452658.00	
23R	81A	8413.53	8032.11	1565.88	-487133.16	2451085.25	310797.44	
24L	81B	-8034.59	8403.94	1023.03	-2475622.75	-462542.47	1923.04	
24R	81B	-8034.59	1066.46	-8404.54	-2475623.00	-466.05	462546.22	
25L	9A	-8025.62	306.16	-8404.54	-2475623.00	-247790.06	432598.31	
25R	9A	-3038.62	-306.16	-8404.54	-2475623.00	347789.97	-432599.31	

S80+ SURGE LINE DWT/THER/SEIS FOR LBB (lbb2)

LOAD CASE NO. 8 (SLDW), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1 (CONTD.)								
26L	9B	-276.44	-8040.09	8404.54	-517635.06	-2315917.75	-280485.03	
26R	9B	-276.44	257.70	11628.11	-535056.87	-1897763.13	1489223.75	
27		-1043.14	257.70	11628.11	-535056.87	-1396867.12	1478029.50	
28	10	-1809.85	257.70	11628.11	-535056.87	-895969.00	1466836.38	

S80+ SURGE LINE DWT/THER/SEIS FOR LBB (lbb2)

LOAD E NO. 9 (32DW), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
PRN1								
1	1	2972.33	7044.26	4014.63	1057195.50	-499094.19	602634.13	
2L	2A	1607.72	7044.26	4014.63	1057195.50	-177269.16	38018.98	
2R	2A	1607.72	4014.63	-7044.26	1057195.50	38019.00	177269.16	
3L	2P	-4009.02	1087.56	-7044.26	11740.10	914387.69	70384.92	
3R	2B	-4009.02	1087.56	-7044.26	109740.09	914387.69	70384.92	
4		-4013.82	165.06	-7044.26	109740.09	532691.13	36312.45	
5L	3A	-4018.63	-757.45	-7044.26	109740.09	150593.16	46564.52	
5R	3A	-3994.62	-7064.22	-3812.50	109740.10	45777.30	-151233.69	
6L	3B	7061.28	3997.54	-3269.66	19369.76	44595.49	73262.03	
6R	3B	7061.28	3249.77	-4014.63	19369.75	-73028.60	44976.73	
7		7054.57	195.17	-4014.63	19369.75	-376696.75	-134782.69	
8		7047.86	673.57	-4014.63	19369.75	-620366.19	-228191.20	
9		7041.16	-614.04	-4014.63	19369.73	-984035.50	-235247.95	
10L	6A	7034.45	-1901.65	-4014.63	19369.75	-1287706.12	-155952.42	
10R	6A	7034.45	-4004.66	1922.56	19369.75	-149236.84	1288501.88	
11L	6B	4002.02	7031.51	2465.40	111056.87	57547.21	1227013.88	
11R	6B	3972.80	3147.03	7044.26	133874.20	-1224417.38	63938.42	
12L	60	3974.60	3013.42	7044.26	133874.20	-1168798.13	41760.53	
12R	60	4031.38	2937.03	7044.26	112522.33	-1171150.38	40881.54	
13		4023.88	1617.93	7044.26	112522.33	-625020.94	-121044.49	
14		4016.38	207.03	7044.26	112522.33	-78889.45	-192219.84	
15		4008.89	-1022.97	7044.26	112522.33	467242.19	-172643.72	
16L	61	4001.39	-2342.97	7044.26	112522.33	1013375.56	-62315.58	
16R	61	4030.51	3022.50	-4998.81	112071.15	1013425.56	-62315.58	
17		4025.52	2070.47	-4998.81	112071.15	733910.94	-192474.20	
18L	7A	4020.54	1118.45	-4998.81	112071.15	454325.38	-275426.56	
18R	7A	4020.52	-5001.24	-1107.64	112061.53	-276415.87	-453796.59	
19L	7B	6377.92	-654.13	-836.21	280224.00	-129570.65	-405921.56	
19R	7B	6377.92	834.72	-695.92	280224.00	405642.56	-130441.45	
20L	71	6372.04	-289.36	-695.92	280224.00	359733.53	-150907.61	
20R	71	6999.00	-292.63	-68.95	280224.00	359733.53	-150907.61	
21L	8A	6994.18	-1214.27	-68.95	280224.00	355207.75	-118414.84	
21R	8A	7010.60	59.01	1925.96	280223.97	116578.57	355814.66	
22L	8B	-61.62	7007.76	1383.12	-147732.27	311389.25	212318.84	
22R	8B	-61.62	1419.73	-7000.44	-147732.30	213943.59	-310275.19	
23L	81A	-65.54	661.21	-7000.44	-147732.30	-97279.77	-354591.75	
23R	81A	-65.54	6996.93	697.36	-147732.27	355289.44	-95446.97	
24L	81B	-6999.73	-68.16	154.51	-364304.50	-138511.44	-235546.80	
24R	81B	-6999.73	154.16	68.95	-364304.50	-236259.08	137293.00	
25L	9A	-7003.66	-606.13	68.95	-364304.50	-232525.67	142849.20	
25R	9A	-7003.66	606.13	-68.95	-364304.53	232525.66	-142849.20	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER/SEIS FOR LBB (1bb2)

PAGE 144  
23-JUN-92 16:01:26

LOAD CASE NO. 9 (32DW), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1 (CONTD..)								
	26L	9B	-1183.38	-7000.44	-68.95	-232715.97	-164795.63	-15945.51
	26R	9B	-1183.38	-4998.81	4901.30	-232715.94	-269224.63	246674.30
	27		-1950.08	-4998.81	4901.30	-232715.92	-49468.78	471774.44
	28	10	-2716.79	-4998.81	4901.30	-232715.94	170328.05	696875.63

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM ABB COMBUSTION ENGINEERING - H<sup>2</sup>/APOLLO DOMAIN/OS

P: 24-1-2020 02:56:08

S80+ SURGE LINE DWT/THER/SEIS FOR LBB (lbb2)

LOAD CASE NO. 10 (EQSI), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1								
1	1	17550.01	31297.49	24974.03	1778811.13	2369006.00	2471061.50	
2L	2A	17412.50	31139.75	24456.19	1778811.13	1821226.50	797998.06	
2R	2A	17332.72	23164.66	30721.71	1778811.13	797998.06	1821226.50	
3L	2B	23178.28	17315.45	30721.71	900455.00	1241216.50	1599864.13	
3R	2B	21278.15	16990.86	29760.21	900455.00	1241216.50	1599864.13	
4		21278.15	16990.86	29760.21	900454.94	375137.06	838872.19	
5L	3A	19045.29	15143.71	27330.54	906455.00	1557091.75	375202.19	
5R	3A	17450.53	24535.76	12434.03	900455.00	379308.53	1556863.88	
6L	3B	24536.04	17450.12	12434.03	403343.56	833945.81	1773333.13	
6R	3B	1312.03	9788.40	15670.02	403343.56	1771264.88	838316.00	
7		17149.42	6731.69	12178.99	403343.56	1272290.75	723619.06	
8		13129.11	4684.98	9916.68	403343.56	995352.63	748526.75	
9		9421.23	5317.94	11968.46	403343.53	675733.44	580008.75	
10L	6A	6577.10	7240.23	15539.09	403343.56	860741.69	299747.19	
10R	6A	5844.31	17088.67	7999.25	403343.56	301245.41	860456.50	
11L	6B	17088.64	5844.43	7999.25	289055.41	427179.72	1107262.25	
11R	6B	17639.68	8239.58	5886.04	284986.72	1108377.63	426352.06	
12L	60	17639.68	8239.58	5886.04	284986.72	1105776.50	444867.97	
12R	60	18666.27	8728.28	6453.82	289106.63	1104553.13	444867.97	
13		20726.76	8017.46	7159.12	289106.63	973190.56	796104.63	
14		22929.18	6646.33	9374.96	289106.63	773764.19	1155820.63	
15		25252.00	5961.03	12348.11	289106.63	77531.50	1347102.25	
16L	61	27785.62	6266.46	14477.63	289106.63	748.25	1346697.63	
16R	61	30368.95	6692.69	12421.68	289206.09	1020.38	1346697.63	
17		30368.95	6692.69	12421.68	289206.09	667428.25	1213566.75	
18L	7A	32864.47	7800.24	11348.07	289206.09	743198.69	963304.19	
18R	7A	34481.00	10948.89	923.21	289206.09	963822.44	743312.62	
19L	7B	30933.68	18557.00	9231.21	585459.63	714796.63	659466.25	
19R	7B	32426.54	11569.06	19605.89	585459.63	659483.06	715213.00	
20L	71	32426.54	11569.06	19605.89	585459.63	878025.44	536323.06	
20R	71	11550.28	10558.96	9865.33	565459.63	878025.44	536323.06	
21L	8A	11550.28	14558.96	9865.33	585459.63	556109.44	953523.94	
21R	8A	13176.34	9968.31	16834.24	585459.63	953126.13	557051.75	
22L	8B	9968.06	13176.53	16834.24	1201089.38	290152.44	316657.59	
22R	8B	10342.73	19329.16	14610.99	1201089.38	316054.13	290991.84	
23L	81A	10342.73	19329.16	14610.99	1201089.38	480346.31	519742.56	
23R	81A	11148.50	15471.68	20924.77	1201089.38	518078.44	481448.81	
24L	81B	15471.96	11148.12	20924.77	890958.56	944102.44	549994.62	
24R	81B	16349.53	21958.28	12284.33	890958.56	550500.06	944820.19	
25L	9A	16349.53	21958.28	12284.33	890958.56	167830.22	858296.63	
25R	9A	17435.28	22227.05	13421.17	890958.56	167830.22	858296.63	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABS COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER/SEIS FOR LBB (lbb2)

PAGE 165  
24-JUN-92 09:56:00

LOAD CASE NO. 1Q (EQSI), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
PRN1 (CONTD.)								
	26L	9B	22251.95	17419.51	13421.17	273002.34	797506.44	1029725.44
	26R	9B	22304.72	22743.24	6241.50	273002.34	538984.88	1186104.63
	27		22410.61	23258.53	6742.81	273002.31	497984.19	1514602.50
	28	10	22410.61	23258.53	6742.81	273002.34	582724.00	2214749.00

IMPELL CORPORATION  
 SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
 S80+ SURGE LINE DWT/THER/SEIS FOR LBB (lbb2)

PAGE 158  
 24-JUN-92 09:56:00

LOAD CASE NO. II (STOT). FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP NMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
PRN1								
1	1		48.35	688.43	426.62	107082.54	41035.59	68340.48
2L	2A		48.35	688.43	426.62	107082.54	12353.53	19591.96
2R	2A		48.35	426.62	688.43	107082.54	19591.96	12353.53
3	2B		426.61	50.08	688.43	16632.80	94806.09	7520.73
4			426.61	50.08	688.43	16632.80	61848.74	8983.00
5L	3A		426.61	50.08	688.43	16632.81	59443.72	10540.77
5R	3A		426.61	688.40	47.86	16632.80	10681.08	59434.71
6L	3B		688.38	426.63	47.86	11443.31	15833.45	62981.41
6R	3B		688.38	45.20	426.62	11443.31	63017.84	15787.81
7			688.38	45.20	426.62	11443.31	52058.46	12926.63
8			688.38	45.20	426.62	11443.31	52832.93	10065.43
9			688.38	45.20	426.62	11443.31	78963.51	7982.60
10L	6A		688.38	45.20	426.62	11443.31	105574.67	8057.59
10R	6A		688.38	426.61	44.54	11443.31	8525.95	105575.77
11L	6B		426.63	688.37	44.54	8595.80	10748.28	100908.37
11R	6B		426.56	52.78	688.43	7688.89	100899.84	11170.94
12L	60		426.56	52.78	688.43	7688.89	95097.39	10867.34
12R	60		426.63	46.48	688.43	8561.71	96113.22	10867.34
13			426.63	46.48	688.43	8561.71	53130.67	9009.48
14			426.63	46.48	688.43	8561.71	42977.21	7181.40
15	6		426.63	46.48	688.43	8561.71	75335.93	6218.91
16L	61		426.63	46.48	688.43	8561.71	107758.43	7877.10
16R	61		426.63	46.52	633.90	8593.14	107758.88	7877.10
17			426.63	46.52	633.90	8593.14	80159.73	9206.06
18L	7A		426.63	46.52	633.90	8593.14	53737.86	10767.74
18R	7A		426.63	633.84	46.12	8593.60	10828.08	53737.38
19L	7B		746.61	463.11	46.12	9918.56	10764.30	46876.30
19R	7B		746.61	46.27	463.04	9818.56	46878.59	10817.19
20L	71		746.61	46.27	463.04	9818.56	30355.16	12909.39
20R	71		735.74	45.63	912.76	9818.56	30355.16	12909.39
21L	8A		735.74	45.63	912.76	9818.56	41433.90	14615.21
21R	8A		735.74	912.88	44.98	9818.56	14497.64	41502.56
22L	8B		912.89	735.74	44.98	15136.88	10152.55	46995.00
22R	8B		912.89	47.90	735.70	15136.88	47035.96	9972.26
23L	81A		912.89	47.90	735.70	15136.88	45628.81	10695.04
23R	81A		912.89	735.65	51.02	15136.88	10500.51	45672.37
24L	81B		735.65	912.89	51.02	10958.81	14384.72	30960.05
24R	81B		735.65	51.22	912.76	10958.81	30956.06	14267.72
25	9A		735.65	51.22	912.76	10958.81	29733.67	12612.71
26L	9B		48.35	735.70	912.76	32877.81	14999.96	15867.44
26R	9B		48.35	613.90	674.84	32877.81	16130.84	12515.26

## LOAD CAS- NO. 11 (STOT), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XZ MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
PRN2 (CONTD.)	27		48.35	633.90	674.84	32877.81	38986.33	36958.50
	28	10	48.35	633.90	674.84	32877.81	61939.52	62203.78

IMPELL CORPORATION  
 SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
 S80+ SURGE LINE DWT/THER/SEIS FOR LBB (1bb2)

PAGE 159  
 23-JUN-92 16:01:26

LOAD CASE NO. 12 (EQSE). FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB-IN)	YY MOMENT (LB-IN)	ZZ MOMENT (LB-IN)
PRN1								
1	1	1	17598.37	31985.91	25400.65	1885893.63	2410941.75	2539402.00
2L	2A	17460.95	31828.17	24892.81	1885893.63	1833580.00	817590.00	
2R	2A	17381.07	23591.28	31410.13	1885893.63	817590.00	1833580.00	
3L	2B	23604.89	17365.53	31410.13	917087.81	1336022.75	1607384.88	
3R	2B	21704.76	17040.94	30448.64	917087.81	1336022.75	1607384.88	
4		21704.76	17040.94	30448.63	917087.75	436985.78	847855.19	
5L	3A	19471.90	15193.39	28018.95	917087.81	1616535.50	386742.94	
5R	3A	17877.14	25224.15	12481.89	917087.81	389989.63	1616298.63	
6L	3B	25224.43	17876.75	12481.89	414786.87	849779.25	1836314.63	
6R	3B	22000.42	9834.60	16095.64	414786.87	1834282.75	854103.75	
7		17837.52	5777.88	12605.61	414786.87	1324349.25	736545.69	
8		13617.49	4731.18	10343.30	414786.87	1048185.56	758592.19	
9		10109.61	5364.15	12395.09	414786.87	752696.94	587991.31	
10L	6A	7265.48	72886.43	15965.72	414786.87	9566316.38	307804.78	
10R	6A	6532.70	17515.28	8043.79	414786.87	309771.34	966042.45	
11L	6B	17515.26	6532.80	8043.79	297651.22	437928.00	1208170.50	
11R	6B	18066.24	8292.36	6574.46	292575.59	1209477.39	437522.97	
12L	60	18066.24	8292.36	6574.46	292675.59	1201873.87	455735.31	
12R	60	19092.90	8774.75	7142.25	297668.34	1200656.25	455735.31	
13		21151.39	8063.94	7847.54	297668.34	1026321.19	805114.06	
14		23355.80	6692.81	10063.39	297668.34	716741.38	1163002.12	
15		25678.63	6007.51	13036.54	297668.34	662867.44	1353321.13	
16L	51	28212.25	6312.94	15166.05	297668.34	1349806.63	1354574.75	
16R	61	30795.59	6739.31	13055.59	297799.22	1349779.25	1354574.75	
17		30795.58	6739.31	13055.59	297799.22	947587.94	1222772.87	
18L	7A	33291.10	7846.37	11981.97	297799.22	796936.50	974071.94	
18R	7A	34907.63	11582.74	9277.33	297799.59	974651.50	797050.00	
19L	7B	31680.29	19020.11	9277.33	595278.13	725561.94	706342.50	
19R	7B	33173.15	11615.33	20068.94	595278.13	706361.69	725030.19	
20L	71	33173.15	11615.33	20068.94	595278.13	908380.63	549232.44	
20R	71	12286.02	14604.59	10778.09	595278.13	908380.63	549222.44	
21L	8A	12286.02	14604.59	10778.09	595278.13	597543.31	968139.15	
21R	9A	13912.08	10681.20	16879.2	595278.13	967623.69	598554.31	
22L	8B	10880.95	13912.27	16879.22	1216226.25	300315.00	363652.59	
22R	9B	11255.61	19377.06	15346.70	1216226.25	363090.09	300954.13	
23L	81A	11255.61	19377.06	15346.70	1216226.25	525975.12	530437.56	
23R	81A	12061.38	16207.33	20975.79	1216226.25	526578.94	527121.19	
24L	81B	16207.60	12061.00	20975.79	901917.38	958487.13	580954.69	
24R	81B	17085.18	22009.50	13197.09	901917.38	581456.13	959087.87	
25L	9A	17085.18	22009.50	13197.09	901917.38	197563.89	870909.38	
25R	9A	18170.87	22278.27	14333.94	901917.38	197563.89	870909.36	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 ; SYSTEM: ABB COMBUSTION ENGINEERING - HP/APOLLO DOMAIN/OS  
S80+ SURGE LINE DWT/THER/SEIS FOR LBS (1bb2)

PAGE 160  
23-JUN-92 16:01:26

LOAD CASE NO. 12 (EQSE), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.IN)	YY MOMENT (LB.IN)	ZZ MOMENT (LB.IN)
PRN1 (CONTD.)								
26L	9B		22300.30	18155.21	14333.94	305880.16	812506.38	1045592.88
26R	9B		22352.08	23377.15	6916.34	305880.16	555115.75	1198619.88
27			22458.96	23892.41	7417.66	305880.13	536972.56	1551561.00
28	10		22458.96	23892.43	7417.66	305880.16	644663.50	2276953.00

APPENDIX B

MAIN STEAM LINE

PRELIMINARY ROUTING AND LOADS ANALYSIS

## APPENDIX B

### MAIN STEAM LINE - PRELIMINARY ROUTING AND LOADS ANALYSIS

#### Purpose

This appendix reports the results of a preliminary stress analysis of a System 80+ Main Steam line in the Reactor Building to provide applicable forces and moments for the Leak-Before-Break (LBB) evaluation. The piping included in the model is represented in the isometric sketch that follows. The analysis model originates at the Steam Generator nozzle and terminates at the Reactor Building penetration. Anchors are modelled at these locations. The model also includes additional piping in the Main Steam Valve House, but only to evaluate thermal flexibility between effective anchors at the valve house walls. All applicable design conditions, loadings, codes, and regulatory requirements are defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 2.

The types of analysis results required for the LBB evaluation are shown on the following page. Other results in the detailed analysis include pipe displacements, stresses, support/restraint loads, and nozzle loads (anchor loads). Since the analysis is preliminary and design information is not available for allowable nozzle or penetration loads, it is not within the scope of the calculation to evaluate those loads.

A code compliance check is performed to verify that pipe stresses are within the ASME allowables for the pipe as modelled. As additional design information becomes available, it will be included in a final analysis.

#### Method

The piping is modelled as a three dimensional framework for analysis. Static analysis is performed by the Direct Stiffness Method and a simple Lumped Mass Idealization is used to determine mode shapes and frequencies for the dynamic analysis. This piping is analyzed using the SUPERPIPE computer program.

### References and Design Inputs


1. ASME Boiler and Pressure Vessel Code, Section III, 1989.
2. Draft Distribution Systems Design Guide.
3. Consolidated Valve Drawing 3NC-046.
4. CESSAR Design Certification, Tables 10.1-1 and 10.3.2-1.
5. ABB-CE Letter dated 4/21/92 to R.W. Sonsall enclosing Preliminary Thermal Movements and SSE Seismic Anchor Movements.
6. ABB-Impell memo dated 5/21/92 to ABB-CE, Attn: R.A. Matzie enclosing System 80+ N-411 Spectra and SAM.
7. System 80+ Main Steam System Piping and Instrumentation Diagram.
8. System 80+ Nuclear Island Detailed Arrangement Drawings.


### Results

Forces and moments results for the load cases listed below are provided for the Leak-Before-Break evaluation shown in Appendix H.

1. Gravity - Fluid-filled for Hydrostatic Testing
2. Gravity - Steam-filled
3. Thermal Expansion
4. Gravity Steam + Thermal (Normal Operation)
5. Seismic Inertia - SSE
6. Seismic Anchor Movement - SSE
7. Steam Hammer
8. Seismic Inertia + Seismic Anchor Movement


PRELIMINARY MAIN STEAM ANALYSIS





RELIEF VALVE DETAIL

RELIEF VALVE  
(SILV 2-60 Similar  
(and not 5))



## GRAVITY-HYDRO

STATIC ANALYSIS NO. 1 IGR-H1. FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS

RUN	SOP NAME NO.	DCP NAME TYPE	COMP NAME	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	H/Z (PSI)	I/H/Z (PSI)	
RUN1	1H	SGHZ	AHBT	15334.27	5521.11	198.03	-11561.72	28468.98	30498.01	531.12	849.47	
	1	STRP	15334.27	55.1.11	198.	.	-11561.72	28468.98	30498.01	531.12	531.12	
	2L	A01A	AHBH	12263.21	4410.70	198.0	-11561.72	29291.55	9871.76	404.87	404.87	
	2R	A01A	BELB	12263.21	-198.03	4410.70	-11561.72	29291.55	9871.77	404.87	404.87	
	3L	A01B	BELB	198.03	7956.29	2835.95	-3715.70	2025.74	-7914.93	1148.44	1148.44	
	3R	A01B	AHBW	198.03	2835.95	-3715.70	2025.74	-7914.91	110.23	312.33	312.33	
	4	STRP	EHIN	8446.42	-56.08	-3715.69	-803.29	-8130.45	110.11	110.11	110.11	
	5L	STRP	EHOU	1020.30	-56.08	-3715.69	-1336.09	-53.97	653.20	653.20	653.20	
	5R	STRP	EHOU	198.03	-1329.79	-56.08	-3715.69	-1504.35	-52640.61	647.67	647.67	
	6L	A02A	STRP	198.03	-1324.79	135.52	-3715.69	-1504.35	-52640.61	647.67	647.67	
	6R	A02A	AHBW	198.03	-7320.41	135.52	-3715.69	-646.95	-19486.27	243.43	243.43	
	7L	A02A	BELB	198.03	-7320.41	135.52	-3715.69	-946.95	-19486.27	243.43	243.43	
	7R	A02B	AHBH	11274.98	198.03	135.52	-3715.70	-460.75	-19486.27	243.43	243.43	
	8L	E1146	STRP	11274.98	198.03	135.52	-3715.70	-320.7	15856.22	198.47	198.47	
	8R	E1146	STRP	39933.17	198.03	135.52	-3715.70	-320.7	15856.22	198.47	198.47	
	9L	A03A	STRP	39933.17	8450.19	-83.20	-43.24	-1647.99	1647.99	109.36	109.36	
	9R	A03A	AHBH	96773.03	8450.19	-83.20	-43.24	1647.99	1647.99	109.36	109.36	
	10L	A03B	BELB	96773.03	8450.14	-83.20	-43.24	919.99	-65177.97	799.68	799.68	
	10R	A03B	AHBW	96773.03	8450.12	83.20	-43.24	-919.99	-65177.97	799.68	799.68	
	11L	CHIN	STRP	8450.14	-51377.60	83.20	608.00	268.76	-87166.46	1069.39	1069.39	
	11R	CHIN	STRP	8450.14	51377.60	-83.20	608.00	-268.76	-87166.46	1069.39	1069.39	
	12	CHOU	STRP	8450.14	-13202.05	-0.37	505.00	-352.00	-352.00	1069.39	1069.39	
	13L	005	STRP	8450.14	-7903.76	-0.37	605.00	-353.45	-353.45	1069.39	1069.39	
	13R	005	AHBH	8450.14	-7903.76	-0.37	605.00	-353.48	-353.48	1069.39	1069.39	
	14L	004	STRP	8450.14	-51159.29	-83.20	608.00	-268.76	-268.76	1069.39	1069.39	
	14R	004	STRP	8450.14	16336.66	-0.37	505.00	-352.00	-352.00	1069.39	1069.39	
	15	RAIN	STRP	8450.14	13202.05	-0.37	605.00	-353.45	-353.45	1069.39	1069.39	
	16	RBOU	STRP	8450.14	-7903.76	-0.37	605.00	-353.48	-353.48	1069.39	1069.39	
	17L	003	STRP	8450.14	-7903.76	-0.37	605.00	-353.48	-353.48	1069.39	1069.39	
	17R	003	AHBH	8450.14	-6414.46	-7903.76	-0.37	605.00	-353.48	-353.48	1069.39	1069.39
	18L	002	STRP	8450.14	-6414.46	-6414.46	-1328.72	608.00	-16813.43	487.82	487.82	
	18R	002	STRP	8450.14	-6414.46	-6414.46	-1328.72	608.00	-16813.43	487.82	487.82	
	19L	001	STRP	8450.14	-6805.31	-1328.72	608.00	-17477.79	49333.77	528.09	528.09	

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

STATIC ANALYSIS NO. 1 (GR-H). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS (CONTD.)

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)	B2M/Z (PSI)
RUN1 (CONT'D.)												
18R	002	STRP		-1074.20	11133.90	2634.42	21576.95	-74499.97	45163.52	1101.09	1101.09	1101.09
19L	001	STRP		-1074.20	10352.20	2634.42	21576.95	-71865.53	34420.46	1012.76	1012.76	1012.76
19H	001	AMBH		-1074.20	10352.20	2634.42	21576.95	-71865.53	34420.46	1012.76	1012.76	1012.76
19R	001	STRP		-1074.00	10352.20	2634.42	21576.95	-71865.53	420.46	1012.76	1012.76	1012.76
20L	A04A	STRP		-1074.20	-15135.02	2634.42	21576.95	14029.88	112392.41	1414.52	1414.52	1414.52
20H	A04A	AMBH		-1074.20	-15135.02	2634.42	21576.95	14029.88	112392.41	1414.52	1414.52	1414.52
20R	A04A	BELB		-1074.21	39652.35	2634.42	21576.94	14029.87	112392.41	1414.52	2777.84	4012.42
21L	A04B	BELB		-35027.78	-1074.20	2634.42	-23908.96	31456.04	-23567.12	564.40	1108.37	1600.97
21H	A04B	AMBH		-35027.78	-1074.20	2634.42	-23908.96	31456.04	-23567.12	564.40	564.40	564.40
21R	A04B	STRP		-35027.77	-1074.00	2634.42	-23908.96	31456.04	-23567.12	564.40	564.40	564.40
22L	A05A	STRP		-27210.65	-1074.20	2634.42	-23908.96	57800.85	-12824.93	783.34	783.34	783.34
22H	A05A	AMBH		-27210.65	-1074.20	2634.42	-23908.96	57800.85	-12824.93	783.34	783.34	783.34
22R	A05A	BELB		-27210.64	2634.41	1074.20	-23708.96	-12824.93	-57800.85	783.34	1538.52	2222.00
23L	A05B	BELB		-2635.71	-22606.09	1074.20	8795.55	-19881.46	25721.44	413.17	811.38	1171.98
23H	A05B	AMBH		-2635.71	-22606.09	1074.20	8795.55	-19881.46	25721.44	413.17	413.17	413.17
23R	A05B	STRP		-2630.58	22606.68	-1074.20	8800.06	19879.46	-2521.44	413.17	413.17	413.17
24L	AB01	STRP		-2630.75	21629.40	-1074.20	8800.06	18536.49	-53375.69	701.51	701.51	701.51
24R	AB01	STRP		-2634.42	19715.06	-1074.20	8454.54	18537.99	-53373.69	700.88	700.88	700.88
25L	AB02	STRP		-2634.42	17369.97	-1074.20	8454.54	15315.39	-109001.28	1354.34	1354.34	1354.34
25R	AB02	STRP		-2634.42	15456.09	-1074.20	8112.17	15715.39	-109001.28	1354.05	1354.03	1354.03
26L	AB03	STRP		-2634.42	13111.00	-1074.20	8112.17	12092.80	-151551.91	1871.47	1871.47	1871.47
26P	AB03	STRP		-2634.42	11197.32	-1074.20	7769.80	12092.00	-151851.91	1871.25	1871.25	1871.25
27L	AB04	STRP		-2634.42	8852.02	-1074.20	7769.80	8870.21	-181925.62	2235.55	2236.55	2236.55
27R	AB04	STRP		-2634.42	6938.14	-1074.20	7427.43	8870.21	-181925.62	2236.37	2236.37	2236.37
28L	AB05	STRP		-2634.42	4593.05	-1074.20	7427.43	5647.61	-199222.60	2446.74	2446.74	2446.74
28R	AB05	STRP		-2634.42	2678.81	-1074.20	7084.50	5648.56	-199222.40	2446.59	2446.59	2446.59
29L	10	STRP		-2632.44	-14860.12	-1074.20	7084.30	-18453.21	-62566.31	804.96	804.96	804.96
29H	10	AMTT		-2632.44	-14860.12	-1074.20	7084.30	-18453.21	-62566.31	804.96	1287.45	804.96
29R	10	VALV		-2634.42	-14859.77	-1074.20	7081.83	-18454.36	-62566.31	N/A		
30	MSIV	VALV		-2634.42	-16793.25	-1074.20	7081.83	-23288.15	8646.25	N/A		
31	11	VALV		-2634.42	-46415.00	-1074.20	7081.83	-25436.43	170639.19	N/A		
31L	11	AMTT		-2634.42	-46415.00	-1074.20	7081.83	-25436.43	170639.19	2118.32	3388.04	2118.32
31R	11	STRP		-2634.42	-66415.00	-1074.20	7081.83	-25436.43	170639.19	2118.32	2118.32	2118.32
32	MSVH	STRP		-2634.42	-51886.87	-1074.20	7081.83	-32955.82	514695.71	6327.82	6327.82	6327.82

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

# GRAVITY - STEAM

STATIC ANALYSIS NO. 2 (GR-S). FORCES, MOMENTS AND STRESSES ALONG PIPE RUN

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)	B/M/Z (PSI)
<b>RUN1</b>												
1M	SGNZ	AHTT	1009 <sup>a</sup>	68	3536.79	131.67	-7608.82	18742.98	20088.78	349.67	559.26	349.67
1	SGNZ	STRP	1009.68		3636.29	131.67	-7608.82	18732.98	20088.78	349.67	549.67	349.67
2L	A01A	STRP	8C39.97		2904.87	131.67	-7608.82	19279.89	6504.18	266.50	266.50	266.50
2H	A01A	ANBH	8089.97		2904.87	131.67	-7608.82	19279.89	6504.18	266.50	266.50	266.50
2R	A01A	BELB	8089.97	-131.67	2904.87	1867.59	-7608.82	-6504.19	19279.89	266.50	523.36	755.97
3L	A01B	BELB	131.67		5239.86	1867.59	-2444.18	1339.54	-5219.77	72.59	142.55	205.92
3H	A01B	ANBH	131.67		5239.86	1867.59	-2444.18	1339.54	-5219.77	72.59	72.59	72.59
3R	A01B	STRP	131.67		5562.61	-37.04	-2444.18	-526.38	-5363.14	72.59	72.59	72.59
4	CHIN	STRP	131.67	671.08	-37.04	-37.04	-2444.18	-878.23	-34973.15	430.23	430.23	430.23
5L	EHOU	STRP	131.67	-873.61	-37.04	-37.04	-2444.18	-989.34	-34669.36	426.55	426.55	426.55
5R	EHOU	STRP	131.67	-873.61	89.64	-2444.18	-989.34	-34669.36	426.55	426.55	426.55	426.55
6L	A02A	STRP	131.67	-4822.88	89.64	-2444.18	-309.46	-12823.29	160.19	160.19	160.19	160.19
6R	A02A	ANBH	131.67	-4822.88	89.64	-2444.18	-309.46	-12823.29	160.19	160.19	160.19	160.19
7L	A02B	BELB	131.67	-4822.88	89.64	-2444.18	-309.46	-12823.29	160.19	314.59	454.40	454.40
7H	A02B	ANBH	7855.88	131.67	89.64	-22.94	-2111.77	70455.61	130.86	256.98	371.20	371.20
7R	A02B	STRP	7855.88	131.67	89.64	-22.94	-2111.77	10455.61	130.86	130.86	130.86	130.86
8L	E146	STRP	26304.67	131.67	89.64	-22.94	1064.25	5737.79	71.59	71.59	71.59	71.59
8R	E146	STRP	26304.67	5553.26	-45.91	-22.94	1064.25	5737.79	71.59	71.59	71.59	71.59
9L	A03A	STRP	30810.03	5553.26	-45.91	-22.94	662.51	-42853.24	525.79	525.79	525.79	525.79
9H	A03A	ANBH	30810.03	5553.26	-45.91	-22.94	662.51	-42853.24	525.79	525.79	525.79	525.79
9R	A03A	BE-B	30810.02	-5553.26	45.91	-22.94	-662.51	42655.24	525.79	1032.54	1491.44	1491.44
10L	A03B	BELB	5553.27	33843.02	45.91	490.33	149.23	-57546.52	706.01	1386.46	2002.66	2002.66
10H	A03B	ANBH	5553.27	33843.02	45.91	490.33	149.23	-57546.52	706.01	706.01	706.01	706.01
10R	A03B	STRP	5553.26	-33843.02	-45.91	490.33	-149.23	57546.52	706.01	706.01	706.01	706.01
11L	CHIN	STRP	5553.26	-34357.93	-45.91	490.33	-195.14	91647.01	1124.35	1124.35	1124.35	1124.35
11R	CHIN	STRP	5553.26	10782.41	-3.75	490.33	-195.14	91647.01	1124.35	1124.35	1124.35	1124.35
11R	CHOU	STRP	5553.26	8717.67	-3.75	490.33	-210.19	52549.34	644.71	644.71	644.71	644.71
13L	CC	STRP	5553.26	-5164.58	-3.75	490.33	-311.48	4852.62	59.96	59.96	59.96	59.96
13H	005	ANBH	5553.26	-5164.58	-3.75	490.33	-311.48	4852.62	59.96	59.96	59.96	59.96
13R	005	STRP	5553.26	-5164.58	-3.75	490.33	-311.48	4852.62	59.96	59.96	59.96	59.96
14L	004	STRP	5553.26	-5699.47	-3.75	490.33	-315.23	10294.65	126.50	126.50	126.50	126.50
14R	004	STRP	5553.26	2099.80	-1057.02	490.33	-309.96	10333.64	126.97	126.97	126.97	126.97
15	RBIN	STRP	5553.26	-2019.39	-1057.02	490.33	-8766.12	10012.00	163.37	163.37	163.37	163.37
16	RBCU	STRP	5553.26	-4084.13	-1057.02	490.33	-13004.77	22249.54	316.22	316.22	316.22	316.22
17L	003	STRP	5553.26	-4277.21	-1057.02	490.33	-13401.16	23817.28	335.32	335.32	335.32	335.32
17H	003	ANBH	5553.26	-4277.21	-1057.02	490.33	-13401.16	23817.28	335.32	335.32	335.32	335.32
17R	003	STRP	5553.26	-4277.21	-1057.02	490.33	-13401.16	23817.28	335.32	335.32	335.32	335.32
18L	002	STRP	5553.26	-4534.66	-1057.02	490.33	-13929.67	26020.25	362.13	362.13	362.13	362.13

PPELL CORPORATION  
JPERPIPE VERSION 22E 05/31/90 SYSTEM: IBM-VM/MVS

JULY 87  
8-6-92 17:51:26

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

STATIC ANALYSIS NO. 2 (GR-5). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS (CONT'D.)

RUN NAME	SUP NO.	DCP NAME	CMP TYPE	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)	B2M/Z (PSI)
RUN1 (CONT'D.)												
1ER	002	STRP	-841.78	6970.08	2095.83	17246.74	-59392.53	26152.39	875.77	823.77	823.77	
19L	001	STRP	-841.78	645L.18	2095.83	17246.74	-57296.68	19979.76	771.84	771.84	771.84	
19H	001	ANBH	-841.78	6455.18	2095.83	17246.74	-57296.68	19479.76	771.84	771.84	771.84	
19R	001	STRP	-841.78	6455.18	2095.83	17246.74	-57296.68	19439.76	771.84	771.84	771.84	
20L	A04A	STRP	-841.78	-10333.06	2095.83	17246.74	1x037.77	82658.45	1044.71	1044.71	1044.71	
20H	A04A	ANBH	-841.78	-10333.06	2095.83	17246.74	11037.77	82658.45	1044.71	1044.71	1044.71	
20R	A04A	BELB	-841.80	29340.28	2095.83	17246.74	11037.78	82658.45	1044.71	2051.61	2963.42	
21L	A04B	BELB	-26307.27	-841.78	2095.83	-18897.12	25106.10	-18523.68	447.50	878.79	1269.36	
21H	A04B	ANBH	-26307.27	-841.78	2095.83	-18897.12	25106.10	-18523.68	447.50	447.50	447.50	
21R	A04B	STRP	-26307.28	-841.78	2095.83	-18897.13	25106.08	-18523.69	447.50	447.50	447.50	
22L	A05A	STRP	-21158.20	-841.78	2095.83	-18897.13	46064.81	-10105.67	623.28	623.28	623.28	
22H	A05A	ANBH	-21158.20	-841.78	2095.83	-18897.13	46064.81	-10105.67	623.28	623.28	623.28	
22R	A05A	BELB	-21158.20	2095.81	841.78	-18897.12	-10105.68	-46064.85	623.28	1224.00	1768.00	
23L	A05B	BELB	-2096.86	-18125.20	841.78	6948.05	-15741.92	19728.25	321.15	630.67	910.96	
23H	A05B	ANBH	-2096.86	-18125.20	841.78	6948.05	-15741.92	19728.25	321.15	321.15	321.15	
23R	A05B	STRP	-2092.75	18125.66	-841.78	6951.66	15739.44	-19728.25	321.15	321.15	321.15	
24L	AB01	STRP	-2092.86	17481.93	-841.78	6951.66	1x687.03	-41986.78	552.32	552.32	552.32	
24R	AB01	STRP	-2095.83	15567.73	-841.78	6606.86	14688.21	-41986.75	551.69	551.69	551.69	
25L	AB02	STRP	-2095.83	14023.04	-841.78	6606.86	21262.66	-86372.94	1073.14	1073.14	1073.14	
25R	AB02	STRP	-2095.83	12109.19	-841.78	6264.57	12162.86	-86372.94	1072.84	1072.84	1072.84	
26L	AB03	STRP	-2095.83	10564.49	-841.78	5264.57	9657.51	-120383.46	1483.58	1483.58	1483.58	
26R	AB03	STRP	-2095.83	9650.64	-841.78	5922.27	9657.51	-120383.46	1483.37	1483.37	1483.37	
27L	AB04	STRP	-2095.83	7105.95	-841.78	5922.27	7112.16	-144018.33	1770.46	1770.46	1770.46	
27R	AB04	STRP	-2095.83	5192.09	-841.78	5579.97	7112.16	-144018.33	1770.30	1770.30	1770.30	
28L	AB05	STRP	-2095.83	3647.40	-841.78	5579.97	4586.81	-157277.57	1931.52	1931.52	1931.52	
28R	AB05	STRP	-2096.06	1733.27	-841.78	5237.06	4587.51	-157277.57	1931.37	1931.37	1931.37	
29L	10	STRP	-2094.51	-9819.50	-841.78	5237.06	-14299.58	-66562.18	837.68	837.68	837.68	
29H	10	ANTT	-2094.51	-9819.50	-841.78	5237.06	-14299.58	-66562.18	837.68	1339.79	827.68	
29R	10	VALV	-2095.83	-9819.22	-841.78	5235.15	-14300.28	-66562.18	N/A			
30	MSIV	VALV	-2095.83	-11749.71	-841.78	5235.15	-18086.51	-18032.10	N/A			
31L	11	VALV	-2095.83	-41374.44	-841.78	5235.15	-19771.88	133879.72	N/A			
31H	11	ANTT	-2095.83	-41374.44	-841.78	5235.15	-19771.88	133879.72	1661.49	1661.49	1661.49	
31R	11	STRP	-2095.83	-41374.44	-841.78	5235.15	-19771.88	133879.72	1661.49	1661.49	1661.49	
32	MSVH	STRP	-2095.83	-44978.72	-841.78	5235.15	-25664.35	936115.62	5359.91	5359.91	5359.91	

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

# THERMAL EXPANSION

TSTATIC ANALYSIS NO. 3 (TH-1). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
<b>RUN1</b>											
1H	SGNZ	AMTT		4250.26	-9202.49	-25010.74	71046.09	347193.41	-74132.58	4874.67	7796.55
1	SGNZ	STRP		4250.26	-9202.49	-25010.74	71046.09	347193.41	-74132.58	4874.67	4874.67
2L	A01A	STRP		4250.26	-9202.49	-25010.74	71046.09	243309.59	-35909.31	3446.74	3446.74
2H	A01A	AMBH		4250.26	-9202.49	-25010.74	71046.09	243309.59	-35909.31	3446.74	3446.74
2R	A01A	BELB		4250.25	25010.74	-9202.49	71046.10	35909.34	243309.59	3446.74	6765.72
3L	A01B	BELB		-25010.74	4250.26	-9202.49	-1399.95	36536.75	133580.81	1864.66	3661.82
3H	A01B	AMBH		-25010.74	4250.26	-9202.49	-1399.95	36536.75	133580.81	1864.66	1864.66
3R	A01B	STRP		-25010.74	846.75	-10101.17	-1399.95	80017.85	113030.55	1864.66	1864.66
4	EHN	STRP		-25010.74	846.75	-10101.17	-1399.95	-15943.4	104986.47	1429.84	1429.84
5L	EHOU	STRP		-25010.74	846.75	-10101.17	-1399.95	-46246.75	102446.22	1513.46	1513.46
5R	EHOU	STRP		-25010.74	846.75	1137.30	-1399.95	-46246.73	102446.22	1513.46	1513.46
6L	A02A	STRP		-25010.74	846.75	1137.30	-1399.95	-37523.63	95951.65	1387.27	1387.27
6H	A02A	AMBH		-25010.74	846.75	1137.30	-1399.95	-37523.63	95951.65	1387.27	1387.27
6R	A02A	BELB		-25010.73	846.74	1137.30	-1399.95	-37523.64	95951.65	1387.27	2724.33
7L	A02B	BELB		-846.75	-25010.73	1137.30	33258.75	2864.92	186566.65	7551.78	2011.20
7H	A02B	AMBH		-846.75	-25010.73	1137.30	33258.75	2864.92	186566.65	551.78	2051.78
7R	A02B	STRP		-846.75	-25010.74	1137.30	33258.75	2864.94	186566.66	2551.78	2551.78
8L	E146	STRP		-846.75	-25010.74	1137.30	33258.75	43614.55	1082701.66	14595.94	14595.94
8R	E146	STRP		-846.75	172633.14	-2637.03	33258.75	43614.55	1082701.66	14595.94	14595.94
9L	A03A	STRP		-846.75	172633.14	-2637.03	33258.75	20540.58	-427838.28	5784.31	5784.31
9H	A03A	AMBH		-846.75	172633.14	-2637.03	33258.75	20540.58	-427838.28	5784.31	5784.31
9R	A03A	BELB		-846.72	-172633.14	2637.04	33258.75	-20540.62	427838.28	5784.31	11359.24
10L	A03B	BELB		172633.14	-846.77	2637.01	10651.84	43147.53	1078387.85	14531.49	28536.97
10H	A03B	AMBH		172633.14	-846.77	2637.01	10651.84	43147.53	1078387.85	14531.49	14531.49
10R	A03B	STRP		172633.14	846.75	-2637.01	10651.83	-43147.55	-1078387.85	14531.49	14531.49
11L	CHIN	STRP		172633.14	846.75	-2637.01	10651.83	-45784.55	-1079234.53	14514.34	14544.34
11R	CHIN	STRP		172633.13	-43801.27	2048.65	10651.83	-45784.55	-1079234.53	14544.34	14544.34
12	CHOU	STRP		172633.13	-43801.27	2048.65	10651.83	-37569.46	-903591.28	12177.10	12177.10
13L	005	STRP		172633.13	-43801.27	2048.65	10651.83	17744.13	279042.95	3767.29	3767.29
13H	005	AMBH		172633.13	-43801.27	2048.65	10651.83	17744.13	279042.95	3767.29	3767.29
13R	005	STRP		172633.13	-43801.27	2048.65	10651.83	17744.15	279042.95	3767.29	3767.29
14L	004	STRP		172633.13	-43801.27	2048.65	10651.83	19792.78	32284.24	4357.22	4357.22
14R	004	STRP		172633.13	28635.27	14981.84	10651.83	19728.12	323206.43	4362.03	4362.03
15	RBIN	STRP		172633.13	28635.27	14981.84	10651.83	139582.87	94124.14	2271.20	2271.20
16	RBOU	STRP		172633.13	28635.27	14981.84	10651.83	199660.06	-20703.34	2706.39	2706.39
17L	003	STRP		172633.13	28635.27	14981.84	10651.83	205278.25	-31441.57	2799.73	2799.73
17H	003	AMBH		172633.13	28635.27	14981.84	10651.83	205278.25	-31441.57	2799.73	2799.73
17R	003	STRP		172633.13	28635.27	14981.84	10651.83	205278.25	-31441.57	2799.73	2799.73
18L	002	STRP		172633.13	28635.27	14981.84	10651.83	212769.18	-45759.20	2933.68	2933.68

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

TATIC ANALYSIS NO. 3 (TH-1). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS (CONT'D.)

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
<b>RUN1 (CONT'D.)</b>											
18R	002	STRP	19519.18	-5987.67	-35365.01	210342.74	908880.02	-54184.11	12581.55	12581.55	
19L	001	STRP	19519.18	-5987.67	-35365.01	210342.74	873514.78	-48196.42	12114.36	12114.36	
19H	001	ABMB	19519.18	-5987.67	-35365.01	210342.74	873514.78	-48196.42	12114.36	12114.36	
19R	001	STRP	19519.18	-5987.67	-35365.01	210342.74	873514.78	-48196.42	12114.36	12114.36	
20L	A04A	STRP	19519.18	-5987.67	-35365.01	210342.74	-279561.34	147031.68	5109.44	5109.44	
20H	A0 A	ABMB	19519.18	-5987.67	-35365.01	210342.74	-279561.34	147031.68	5109.44	5109.44	
20R	A04A	BELB	19519.18	-16553.80	-35365.01	210342.75	-279561.26	147031.68	5109.44	10033.93	
21L	A04B	BELB	16553.81	19519.17	-35365.01	412180.11	77723.87	135911.54	5936.37	11657.85	
21H	A04B	ABMB	16553.81	19519.17	-35365.01	412180.11	77723.83	135911.54	5936.37	5936.37	
21R	A04B	STRP	16553.80	19519.17	-35365.01	412180.07	77723.95	135911.52	5936.37	5936.37	
22L	A05A	STRP	16553.80	19519.17	-35365.01	412180.07	-275933.74	-59284.43	6725.78	6725.78	
22M	A05A	ABMB	16553.80	19519.17	-35365.01	412180.07	-275933.74	-59284.43	6725.78	6725.78	
22R	A05A	BELB	16553.82	-35365.00	-19519.18	412180.18	-59284.29	275933.74	6725.78	13208.09	
23L	A05B	BELB	35365.95	16551.78	-19519.18	132500.77	338979.79	346479.22	6765.62	13286.33	
23M	A05B	ABMB	35365.95	16551.78	-19519.18	132500.77	338979.79	346479.22	6765.62	6765.62	
23R	A05B	STRP	35362.20	-16559.82	-19519.18	132423.79	-339009.88	-346479.22	6765.62	6765.62	
24L	A001	STRP	35362.20	-16559.82	-19519.18	132423.79	-314606.74	-325775.99	6352.89	6352.89	
24R	A001	STRP	35365.01	-16553.80	-19519.18	132477.25	-314584.23	-325775.99	6352.89	6352.89	
25	A002	STRP	35365.01	-16553.80	-19519.18	132477.25	-256026.67	-276114.54	5374.37	5374.37	
26	A002	STRP	35365.01	-16553.80	-19519.18	132477.25	-197469.12	-226453.12	4421.07	4421.07	
27	A004	STRP	35365.01	-16553.80	-19519.18	132477.25	-138911.56	-176791.67	3513.55	3513.55	
28L	A005	STRP	35365.01	-16553.80	-19519.18	132477.25	-80354.00	-127130.25	2698.44	2698.44	
28R	A005	STRP	35367.22	-16549.07	-19519.18	132488.00	-80336.30	-127130.25	2698.44	2698.44	
29L	10	STRP	35367.22	-16549.07	-19519.18	132488.00	357615.61	244181.53	6096.97	6096.97	
29M	10	AMTT	35367.22	-16549.07	-19519.18	132488.00	357615.61	244181.53	6096.97	9751.50	
29R	10	VALV	35365.01	-16553.80	-19519.18	132535.81	357597.71	244181.53	N/A		
30	MSIV	VALV	35365.01	-16553.80	-19519.18	132535.81	445933.98	318673.67	N/A		
31L	11	VALV	35365.01	-16553.80	-19519.18	132535.81	484472.40	351781.30	N/A		
31M	11	AWTT	35365.01	-16553.80	-19519.18	132535.81	484472.40	351781.30	8256.15	13204.89	
31R	11	STRP	35365.01	-16553.80	-19519.18	132535.81	484472.40	351781.30	8256.15	8256.15	
32	MSVH	STRP	35365.01	-16553.80	-19519.18	132535.81	621106.86	467657.95	10618.83	10618.84	
<b>RUN2</b>											
33	A001	VALV	0.00	0.00	0.00	0.00	0.00	0.00	N/A		
34	101	VALV	0.00	0.00	0.00	0.00	0.00	0.00	N/A		
35L	102	VALV	0.00	0.00	0.00	0.00	0.00	0.00	N/A		
35R	102	NONS	0.00	0.00	0.00	0.00	0.00	0.00	N/A		
36L	B01A	NONS	0.00	0.00	0.00	0.00	0.00	0.00	N/A		

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

NORMAL OPERATION

(GRAV. STM+THRM)

JAD CASE NO. 4B (HOT1). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
<b>RUN1</b>											
1M	SGNZ	AMTT		14349.93	-5566.20	-24879.06	70362.06	399766.62	-61269.44	5036.13	8054.79
1	SGNZ	STRP		14349.93	-5566.20	-24879.06	70362.06	399766.62	-61269.44	5036.13	5036.13
2L	A01A	STRP		12340.23	-6297.62	-24879.06	70362.06	286304.62	-32905.15	3639.36	3639.36
2H	A01A	AMBH		12340.23	-6297.62	-24879.06	70362.06	286304.62	-32905.15	3639.36	3639.36
2R	A01A	BELB		12340.21	24879.04	-6297.62	70362.00	32905.18	286304.62	3639.36	7146.93
3L	A01B	BELB		-24879.04	9490.11	-7334.90	-3980.58	41437.46	141381.06	1808.09	3550.72
3H	A01B	AMBH		-24879.04	9490.11	-7334.90	-3980.58	41437.46	141381.06	1808.09	1808.09
3R	A01B	STRP		-24879.06	6409.36	-10138.20	-3980.59	87290.69	118684.37	1808.69	1808.09
4	EWIN	STRP		-24879.06	1517.83	-10138.20	-3980.59	-18375.45	80246.25	1011.12	1011.12
5L	ENOU	STRP		-24879.06	-26.87	-10138.20	-3980.59	-51743.70	77762.19	1146.93	1146.93
5R	ENOU	STRP		-24879.06	-26.87	1225.94	-3980.59	-51743.70	77762.19	1146.93	1146.93
6L	A02A	STRP		-24879.06	-3976.13	1225.94	-3980.59	-41490.46	92480.62	1244.46	1244.46
6H	A02A	AMBH		-24879.06	-3976.13	1225.94	-3980.59	-41490.46	92480.62	1244.46	1244.46
6R	A02A	BELB		-24879.04	-3976.14	1225.94	-3980.57	-41490.44	92480.62	1244.46	2445.87
7L	A02B	BELB		7009.13	-24879.04	1225.94	36477.48	1032.39	215206.75	2677.85	5258.76
7H	A02B	AMBH		7009.13	-24879.04	1225.94	36477.48	1032.39	215206.75	2677.85	2677.85
7R	A02B	STRP		7009.13	-24879.06	1225.94	36477.50	1032.41	215206.75	2677.85	2677.85
8L	E146	STRP		25457.92	-24879.06	1225.94	36477.50	48929.87	1193969.00	14666.75	14666.75
BR	E146	STRP		25457.92	178186.37	-2682.94	36477.50	48929.87	1193969.00	14666.75	14666.75
9L	A03A	STRP		29963.27	178186.37	-2682.94	36477.50	23205.14	-512392.31	6308.37	6308.37
9H	A03A	AMBH		29963.27	178186.37	-2682.94	36477.50	23205.14	-512392.31	6308.37	6308.37
9R	A03A	BELB		29963.29	-178186.31	2682.92	36477.48	-23205.16	512392.31	6308.37	12388.39
10L	A03B	BELB		178186.31	32996.23	2682.92	12180.40	47502.26	1125951.00	13826.28	27152.07
10H	A03B	AMBH		178186.31	32996.23	2682.92	12180.40	47502.26	1125951.00	13826.28	13826.28
10R	A03B	STRP		178186.37	-32996.26	-2682.92	12180.39	-47502.30	-1125951.00	13826.28	13826.28
11L	CHIN	STRP		178186.37	-33511.17	-2682.92	12180.39	-50442.27	-1092779.00	13421.34	13421.34
11R	CHIN	STRP		178186.37	-33018.86	2044.90	12180.39	-50442.27	-1092779.00	13421.34	13421.34
12	CHOU	STRP		178186.37	-35083.59	2044.90	12180.39	-41441.51	-939114.06	11533.24	11533.24
13L	005	STRP		178186.37	-48985.84	2044.90	12180.39	19162.16	311093.69	3826.65	3826.65
13H	005	AMBH		178186.37	-48985.84	2044.90	12180.39	19162.16	311093.69	3826.65	3826.65
13R	005	STRP		178186.37	-48985.84	2044.90	12180.39	19162.16	311093.69	3826.65	3826.65
14L	004	STRP		178186.37	-49500.73	2044.90	12180.39	21406.74	364606.12	4483.18	4483.18
14R	004	STRP		178186.37	30735.06	13924.82	12180.39	21341.02	365042.31	4488.48	4488.48
15	RBIN	STRP		178186.37	26615.87	13924.82	12180.39	144421.75	113310.31	2256.96	2256.96
16	RBOU	STRP		178186.37	24551.13	13924.82	12180.39	206115.94	-471.74	2533.05	2533.05
17L	003	STRP		178186.37	24358.05	13924.82	12180.39	211885.37	-10688.86	2607.00	2607.00
17H	003	AMBH		178186.37	24358.05	13924.82	12180.39	211885.37	-10688.86	2607.00	2607.00
17R	003	STRP		178186.37	24358.05	13924.82	12180.39	211885.37	-10688.86	2607.00	2607.00
18L	002	STRP		178186.37	24100.60	13924.82	12180.39	219577.94	-24199.06	2714.21	2714.21

## -DAD CASE NO. 4 (HOT1). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS (CONT'D.)

RUN	SUP. NAME NO.	DCP NAME NO.	COMP TYPE	AXIAL FORCE (1 LB)	Y FORCE (1 LB)	Z FORCE (1 LB)	TOPS MOMENT (LB.FT)	YF MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	H/Z (PSI)	TH/Z (PSI)
18R	32	STRP		18677.38	982.41	-33269.16	248091.37	936075.31	-33312.99	11911.00	
19L	001	AHBW		18677.38	467.51	-33269.16	248091.37	901358.50	-33454.31	11976.45	11976.45
19R	001	STRP		18677.38	467.51	-33269.16	248091.37	901358.50	-33454.31	11976.45	11976.45
20L	A04A	STRP		18677.38	-16320.72	-33269.16	248091.37	901358.50	-33454.31	11976.45	11976.45
20R	A04A	AHBW		18677.38	-16320.72	-33269.16	248091.37	901358.50	-33454.31	11976.45	11976.45
20R	A0-A	BELB		18677.35	12786.48	-33269.16	248091.37	901358.50	-33454.31	11976.45	11976.45
21L	A04B	BELB		9753.48	18677.38	-33269.16	433457.69	110405.44	244021.56	5602.83	11002.83
21R	A04B	AHBW		9753.48	18677.38	-33269.16	433457.69	110405.44	244021.56	5602.83	11002.83
21R	A04B	STRP		9753.48	18677.37	-33269.16	433457.69	110405.44	244021.56	5602.83	11002.83
22L	A05A	STRP		-4604.40	18677.37	-33269.16	433457.69	110405.44	244021.56	5602.83	11002.83
22R	A05A	AHBW		-4604.40	18677.37	-33269.16	433457.69	110405.44	244021.56	5602.83	11002.83
22R	A05A	BELB		-4604.40	-33269.16	-18677.38	433457.69	110405.44	244021.56	5602.83	11002.83
23L	A05B	BELB		33269.06	-1573.43	-18677.38	152363.44	356278.31	399978.19	13416.67	13416.67
23R	A05B	AHBW		33269.06	-1573.43	-18677.38	152363.44	356278.31	399978.19	13416.67	13416.67
23R	A05B	STRP		33269.44	1565.84	-18677.38	152282.62	356313.19	399978.19	13416.67	13416.67
24L	A001	STRP		33269.33	922.12	-18677.38	152282.62	356313.19	399978.19	13416.67	13416.67
24R	A001	STRP		33269.33	-986.07	-18677.38	152282.62	356313.19	399978.19	13416.67	13416.67
25L	A002	STRP		33269.16	-2530.77	-18677.38	151996.56	33058.25	399515.62	6629.03	6629.03
25R	A002	STRP		33269.16	-4944.62	-18677.38	151996.56	33058.25	399515.62	6629.03	6629.03
26L	A003	STRP		33269.16	-5989.31	-18677.38	151654.25	-268818.50	389400.06	6097.07	6097.07
26R	A003	STRP		33269.16	-7993.16	-18677.38	151654.25	-268818.50	389400.06	6095.79	6095.79
27L	A004	STRP		33269.16	-9667.86	-18677.38	151311.94	-207078.75	-368908.56	5513.43	5513.43
27R	A004	STRP		33269.16	-11361.71	-18677.38	151311.94	-207078.75	-368908.56	5512.02	5512.02
28L	A005	STRP		33269.16	-12906.40	-18677.38	150969.62	-145339.00	-338041.75	4880.92	4880.92
28R	A005	STRP		33271.15	-14815.80	-18677.38	150969.62	-145339.00	-338041.75	4879.33	4879.33
29L	10	STRP		33272.69	-26368.56	-18677.38	150638.50	-83579.06	-296799.06	4211.88	4211.88
29R	10	AMTT		33272.69	-26368.56	-18677.38	150638.50	378172.25	20149.50	4210.04	4210.04
29R	10	VALV		33269.16	-26373.02	-18677.38	150638.50	378172.25	20149.50	5571.83	5571.83
30	HSIV	VALV		33269.16	-28303.50	-18677.38	150689.06	378151.69	20149.50	N/A	N/A
31L	11	VALV		33269.16	-57928.44	-18677.38	150689.06	470761.44	331702.31	N/A	N/A
31R	11	AWTT		33269.16	-57928.24	-18677.38	150689.06	511921.25	511921.25	9140.43	9140.43
32	HSVH	STRP		33269.16	-61532.52	-18677.38	150689.06	511921.25	511921.25	9140.43	9140.43
							655981.19	949355.56		14276.80	14276.80

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

# SEISMIC INERTIA (SSE)

LOAD CASE NO.530 (SSEA). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS

RUN NAME	SUP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
<b>RUNS</b>											
1H	SGNZ	AMTT		30571.56	37291.18	120621.62	72601.75	851262.12	300532.37	11110.77	17770.55
1	SGNZ	STRP		30571.56	37291.18	120621.62	72601.75	851262.12	300532.37	11110.77	11110.77
2L	A01A	STRP		30571.56	37291.18	120621.62	72601.75	352546.25	148113.44	4775.04	4775.04
2H	A01A	AMBH		30571.56	37291.18	120621.62	72601.75	352546.25	148113.44	4775.04	4775.04
2R	A01A	BELB		29835.28	117660.50	36027.01	72601.75	148113.44	352546.25	4775.04	9577.23
3L	A01B	BELB		117660.50	29835.28	36027.01	29126.65	89229.94	187977.94	2577.63	5061.95
3H	A01B	AMBH		117660.50	29835.28	36027.01	29126.65	89229.94	187977.94	2577.63	2577.63
3R	A01B	STRP		104306.81	21431.15	33096.14	29126.65	108015.44	175588.06	2533.52	2533.52
4L	EHN	STRP		104306.81	21431.15	33096.14	29126.65	405980.50	366342.12	6718.07	6718.07
4R	EHN	STRP		93295.50	5188.62	31877.81	29126.65	405980.50	366342.12	6718.07	6718.07
5L	EHOU	STRP		93295.50	5188.62	31877.81	29126.65	499453.81	373955.75	7662.00	7662.80
5R	EHOU	STRP		83960.62	14596.23	50967.50	29126.65	499453.81	373955.75	7662.80	7662.80
6L	A02A	STRP		83960.62	14596.23	50967.50	29126.65	110684.06	270208.06	3600.02	3600.02
6H	A02A	AMBH		83960.62	14596.23	50967.50	29126.65	110684.06	270208.06	3600.02	3600.02
6R	A02A	BELB		72152.12	31412.63	40728.97	29126.65	110684.06	270208.06	3600.02	7069.73
7L	A02B	BELB		31412.63	72152.12	40728.97	44708.83	137022.37	114307.25	2256.79	4431.88
7H	A02B	AMBH		31412.63	72152.12	40728.97	44708.83	137022.37	114307.25	2256.79	2256.79
7R	A02B	STRP		42677.55	49899.66	22053.13	44708.83	137022.37	114307.25	2256.79	2256.79
8L	E146	STRP		91090.12	75959.00	40691.16	44708.83	333491.69	557875.06	7992.49	7992.49
8R	E146	STRP		108310.44	51434.37	25462.83	44708.83	333491.69	557875.06	7992.49	7992.49
9L	A03A	STRP		108310.44	51434.37	25462.83	44708.83	113378.19	328935.37	4303.46	4303.46
9H	A03A	AMBH		108310.44	51434.37	25462.83	44708.83	113378.19	328935.37	4303.46	4303.46
9R	A03A	BELB		122059.00	48891.89	29029.82	44708.83	113378.19	328935.37	4303.46	8451.15
10L	A03B	BELB		48891.89	122059.00	29029.82	10020.87	149481.69	174518.62	2821.69	5541.25
10H	A03B	AMBH		48891.89	122059.00	29029.82	10020.87	149481.69	174518.62	2821.69	2821.69
10R	A03B	STRP		49961.79	123643.44	29853.26	10020.87	149481.69	174518.62	2821.69	2821.69
11L	CHIN	STRP		49961.79	123643.44	29853.26	10020.87	178597.81	281030.75	4086.85	4086.85
11R	CHIN	STRP		50907.73	26980.50	17749.05	10020.87	178597.81	281030.75	4086.85	4086.85
12L	CHOU	STRP		50907.73	26980.50	17749.05	10020.87	167518.06	281036.37	4015.67	4015.67
12R	CHOU	STRP		53973.75	22240.84	12970.66	10020.87	167518.06	281036.37	4015.67	4015.67
13L	C05	STRP		65079.04	44640.02	23500.59	10020.87	101882.87	196440.31	2717.56	2717.56
13H	005	AMBH		65079.04	44640.02	23500.59	10020.87	101882.87	196440.31	2717.56	2717.56
13R	005	STRP		68682.56	48992.68	26045.87	10020.87	101882.87	196440.31	2717.56	2717.56
14L	004	STRP		68682.56	48992.68	26045.87	10020.87	127311.12	244911.31	3388.51	3388.51
14R	004	STRP		72118.50	23058.26	16620.15	10020.87	127495.31	245275.19	3393.51	3393.51
15L	RBIN	STRP		72118.50	23058.26	16620.15	10020.87	124210.31	119804.00	2120.69	2120.69
15R	RBIN	STRP		76810.75	23948.76	17223.23	10020.87	124210.31	119804.00	2120.69	2120.69
16L	RBOU	STRP		76810.75	23948.76	17223.23	10020.87	171205.62	155291.37	2838.32	2838.32
16R	RBOU	STRP		78563.81	24755.81	17750.88	10020.87	171205.62	155291.37	2838.32	2838.32

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

DAD CASE NO. 5301 (SSEA). FORCES, MOMENTS AND STRESSES ALONG PIPE RING (CONT'D.)

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
RUN1 (CONT'D.)											
17L	003	STRP	78563.81	24755.81	17750.88	10020.87	176443.62	159866.94	2923.55	2923.55	2923.55
17M	003	AHBM	78563.81	24755.81	17750.88	10020.87	176443.62	159866.94	2923.55	2923.55	2923.55
17R	003	STRP	78917.12	24935.11	17869.32	10020.87	176443.62	159866.94	2923.55	2923.55	2923.55
18L	002	STRP	78917.12	24935.11	17869.32	10020.87	183642.69	166045.00	3039.79	3039.79	3039.79
18R	002	STRP	144975.25	67310.69	42790.83	243194.69	757615.00	645560.51	12570.21	12570.21	12570.21
19L	001	STRP	144978.25	67310.69	42790.83	243194.69	716050.50	578351.62	11679.52	11679.52	11679.52
19M	001	AHBM	144978.25	67310.69	42790.83	243194.69	716050.50	578351.62	11679.52	11679.52	11679.52
19R	001	STRP	144274.00	66987.44	41905.72	243194.69	716050.50	578351.62	11679.52	11679.52	11679.52
20L	A04A	STRP	142384.62	59381.84	12392.99	243194.69	190876.19	1484027.00	18596.92	18596.92	18596.92
20M	A04A	AHBM	142384.62	59381.84	12392.99	243194.69	190876.19	1484027.00	18596.92	18596.92	18596.92
20R	A04A	BELB	141953.87	104202.94	28220.09	243194.69	190876.19	1484027.00	18596.92	18596.92	18596.92
21L	A04B	BELB	104202.94	141953.87	28220.09	170828.56	178347.62	862960.37	11011.80	21625.00	21625.00
21M	A04B	AHBM	104202.94	141953.87	28220.09	170828.56	178347.62	862960.37	11011.80	11011.80	11011.80
21R	A04B	STRP	96681.62	134892.69	47383.04	170828.56	178347.62	862960.37	11011.80	11011.80	11011.80
22L	A05A	STRP	96681.62	134892.69	47585.04	170828.56	403591.50	487517.94	8042.26	8042.26	8042.26
22M	A05A	AHBM	96681.62	134892.69	47383.04	170828.56	403591.50	487517.94	8042.26	8042.26	8042.26
22R	A05A	BELB	89898.94	49743.64	103644.19	170828.56	487517.94	403591.50	8042.26	8042.26	8042.26
23L	A05B	BELB	49747.10	89897.06	103644.19	874369.87	400180.37	406151.75	12805.98	12805.98	12805.98
23M	A05B	AHBM	49747.10	89897.06	103644.19	874369.87	400180.37	406151.75	12805.98	12805.98	12805.98
23R	A05B	STRP	50175.74	85119.37	86704.81	874459.75	397983.44	406151.75	12805.98	12805.98	12805.98
24L	AB01	STRP	50175.74	85119.37	86704.81	874459.75	506289.12	403277.37	13347.02	13347.02	13347.02
24M	AB01	STRP	49778.34	76292.94	62305.41	826967.19	506401.44	404440.12	12889.52	12889.52	12889.52
25L	AB02	STRP	49778.34	76292.94	62305.41	826967.19	687299.25	433854.69	14224.91	14224.91	14224.91
25R	AB02	STRP	50780.93	62726.58	50636.83	781151.44	68726.37	436134.12	13840.29	13840.29	13840.29
26L	AB03	STRP	50780.93	62726.58	50636.83	781151.44	785551.19	490710.31	14864.48	14864.48	14864.48
26R	AB03	STRP	53089.50	47723.18	47590.15	737311.94	785518.62	493395.94	14536.98	14536.98	14536.98
27L	AB04	STRP	53089.50	47723.18	47590.15	737311.94	805196.37	571823.31	15119.80	15119.80	15119.80
27R	AB04	STRP	56180.85	35470.66	43853.95	695976.94	805164.50	574103.25	14835.01	14835.01	14835.01
28L	AB05	STRP	56180.85	35470.66	43853.95	695976.94	751053.81	619087.31	14679.30	14679.30	14679.30
28R	AB05	STRP	62087.22	40340.12	61382.05	657674.87	751107.19	619633.19	14415.01	14415.01	14415.01
29L	10	STRP	68045.62	44931.54	87623.94	657674.87	951795.00	551551.81	15723.45	15723.45	15723.45
29M	10	AHTT	68045.62	44931.54	87623.94	657674.87	951795.00	551551.81	15723.45	15723.45	15723.45
29R	10	VALV	71582.00	47128.63	95470.56	657550.50	951880.94	551551.81	N/A	N/A	N/A
30	MSIV	VALV	71582.00	47128.63	95470.56	657550.50	1563794.00	609381.87	N/A	N/A	N/A
31L	11	VALV	120422.12	151668.56	194714.81	582919.31	1715624.00	485723.69	N/A	N/A	N/A
31M	11	AHTT	120422.12	151668.56	194714.81	582919.31	1715624.00	485723.69	23013.84	23013.84	23013.84
31R	11	STRP	122982.00	156911.37	199628.56	582919.31	1715624.00	485723.69	23013.84	23013.84	23013.84
32	MSVH	STRP	122982.00	156911.37	199628.56	582919.31	2718845.00	1467581.00	38572.53	38572.53	38572.53

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

LOAD CASE NO. 638 (SAMF). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
<b>RUN1</b>											
1M	SGNZ	AMTT		14098.06	36842.91	11846.74	463057.31	188617.44	290737.69	7095.61	11348.71
1	SGNZ	STRP		14098.06	36842.91	11846.74	463057.31	188617.44	290737.69	7095.61	11348.71
2L	A01A	STRP		14098.06	36842.91	11846.74	463057.31	164547.06	138520.50	6263.73	6263.73
2H	A01A	AMBH		14098.06	36842.91	11846.74	463057.31	164547.06	138520.50	6263.73	6263.73
2R	A01A	BELB		14098.05	11846.74	56842.91	463057.31	164547.06	138520.50	6263.73	6263.73
3L	A01B	BELB		11846.74	14098.06	36842.91	17343.97	325261.31	109337.75	12300.72	
3H	A01B	AMBH		11846.74	14098.06	36842.91	17343.97	325261.31	109337.75	4215.10	8277.62
3R	A01B	STRP		11846.74	7379.16	38252.67	17343.98	329532.25	57791.39	4215.10	4215.10
4	EWIN	STRP		11846.74	7379.16	38252.67	17343.98	35986.05	80582.19	4109.91	4109.91
5L	EHOU	STRP		11846.74	7379.16	38252.67	17343.98	149756.44	92780.12	1103.39	1103.39
5R	EHOU	STRP		11846.74	7379.16	4899.79	17343.98	149756.44	92780.12	2171.68	2171.68
6L	A02A	STRP		11846.74	7379.16	4899.79	17343.98	112233.50	135065.56	2171.68	2171.68
6H	A02A	AMBH		11846.74	7379.16	4899.79	17343.98	112233.50	135065.56	2164.87	2164.87
6R	A02A	BFLB		11846.74	7379.16	4899.79	17343.97	112233.50	135065.56	2164.87	2164.87
7L	A02B	BELB		7379.16	11846.74	4899.79	93960.56	23752.14	117723.06	2164.87	4251.38
7H	A02B	AMBH		7379.16	11846.74	4899.79	93960.56	23752.14	117723.06	1870.68	3673.64
7R	A02B	STRP		7379.16	11846.74	4899.79	93960.56	23752.18	117723.06	1870.68	1870.68
8L	E146	STRP		7379.16	11846.74	4899.79	93960.62	191585.31	307514.06	4591.88	4591.88
8R	E146	STRP		7379.16	25765.86	14342.66	93960.62	191585.31	307514.06	4591.88	4591.88
9L	A03A	STRP		7379.16	25765.86	14342.66	93960.62	66964.69	82177.87	1737.82	1737.82
9H	A03A	AMBH		7379.16	25765.86	14342.66	93960.62	66964.69	82177.87	1737.82	1737.82
9R	A03A	BELB		7379.15	25765.86	14342.66	93960.62	66964.69	82177.87	1737.82	1737.82
10L	A03B	BELB		25765.84	7379.16	14342.66	13584.89	147400.56	41228.82	1885.10	3701.96
10H	A03B	AMBH		25765.84	7379.16	14342.66	13584.89	147400.56	41228.82	1885.10	1885.10
10R	A03B	STRP		25765.86	7379.16	14342.66	13584.89	147400.56	41228.82	1885.10	1885.10
11L	CHIN	STRP		25765.86	7379.16	14342.66	13584.88	147400.62	41228.82	1885.10	1885.10
11R	CHIN	STRP		25765.86	1967.15	6553.69	13584.88	161734.94	48453.82	2077.99	2077.99
12	CHOU	STRP		25765.86	1967.15	6553.69	13584.88	161734.94	48453.82	2077.99	2077.99
13L	005	STRP		25765.86	1967.15	6553.69	13584.88	135570.62	40569.26	1744.04	1744.04
13H	005	AMBH		25765.86	1967.15	6553.69	13584.88	41699.47	12550.77	559.63	559.63
13R	005	STRP		25765.86	1967.15	6553.69	13584.88	41699.47	12550.77	559.63	559.63
14L	004	STRP		25765.86	1967.15	6553.69	13584.88	41699.47	12550.77	559.63	559.63
14R	004	STRP		25765.86	1785.82	8057.63	13584.88	48253.14	14517.86	640.25	640.25
15	RBIN	STRP		25765.86	1785.82	8057.63	13584.88	48309.25	14533.52	640.94	640.94
16	RBOU	STRP		25765.86	1785.82	8057.63	13584.88	26062.61	7148.23	371.08	371.08
17L	003	STRP		25765.86	1785.82	8057.63	13584.88	49611.36	8094.23	638.71	638.71
17H	003	AMBH		25765.86	1785.82	8057.63	13584.88	52632.02	8678.99	675.30	675.30
17R	003	STRP		25765.86	1785.82	8057.63	13584.88	52632.02	8678.99	675.30	675.30
18L	002	STRP		25765.86	1785.82	8057.63	13584.88	56659.82	9531.77	724.30	724.30

SEISMIC ANCHOR MOVEMENT (SSE)

BB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTAM ANALYSIS  
BB COMBUSTION SERVICES, INC.

BB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTAM ANALYSIS  
BB COMBUSTION SERVICES, INC.

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
P- MARY MAINSTEAM ANALYSIS  
ENGINEERING & SERVICES, INC.

STEAM HAMMER

LOAD CASE NO. 7 (STMH). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS

RUN	SOP NAME	DCP NAME	CMP TYPE	AXIAL FORCE (LBS)	Y FORCE (LBS)	Z FORCE (LBS)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
<b>RUN1</b>											
1H	SGNZ	AMTT		4450.00	444.17	12376.98	2649.66	78626.19	2675.46	965.69	1544.53
1L	SGNZ	STRP		4450.00	444.17	12376.98	2649.66	78626.19	2675.46	965.69	965.69
2L	A01A	STRP		4450.00	444.17	12376.98	2649.66	27217.41	864.98	335.65	335.65
2H	A01A	ANBH		4450.00	444.17	12376.98	2649.66	27217.41	864.98	335.65	335.65
2R	A01A	BELB		1260.27	12376.98	324.92	2649.66	864.98	27217.41	335.65	659.15
3L	A01B	BELB		12376.98	1260.27	324.92	379.77	1513.87	19527.92	240.33	471.97
3N	A01B	ANBH		12376.98	1260.27	324.92	379.77	1513.87	19527.92	240.33	240.33
3R	A01B	STRP		12376.98	1169.10	562.95	379.77	6819.71	1837.28	244.04	244.04
4	EHIN	STRP		12376.98	1169.10	562.95	379.77	1478.63	9271.97	115.20	115.20
5L	ENOU	STRP		12376.98	1169.10	562.95	379.77	342.39	7480.23	91.98	91.98
5R	EHOU	STRP		12376.98	1169.10	12.16	379.77	342.39	7480.23	91.98	91.98
6L	A02A	STRP		12376.98	1169.10	12.16	379.77	251.83	5980.10	73.58	73.58
6H	A02A	ANBH		12376.98	1169.10	12.16	379.77	251.83	5980.10	73.58	73.58
6R	A02A	BELB		842.99	1169.10	12.16	379.77	251.83	5980.10	73.58	144.45
7L	A02B	BELB		1169.10	842.99	12.16	268.76	358.43	7203.00	88.54	173.87
7H	A02B	ANBH		1169.10	842.99	12.16	268.76	358.43	7203.00	88.54	88.54
7R	A02B	STRP		1169.10	842.99	12.16	268.76	358.43	7203.00	88.54	88.54
8L	E146	STRP		1169.10	842.99	12.16	268.76	340.70	23001.46	792.23	292.23
8R	E146	STRP		1169.10	6385.37	24.78	268.76	340.70	23001.46	2.23	207.23
9L	A03A	STRP		1169.10	6385.37	24.78	268.76	123.85	37850.47	464.36	464.36
9H	A03A	ANBH		1169.10	6385.37	24.78	268.76	123.85	37850.47	464.36	464.36
9R	A03A	BELB		23124.75	6385.36	24.78	268.76	123.85	37850.47	464.36	911.92
10L	A03B	BELB		6385.37	23124.75	24.78	43.16	308.24	33937.62	416.36	817.66
10H	A03B	ANBH		6385.37	23124.75	24.78	43.16	308.24	33937.62	416.36	416.36
10R	A03B	STRP		42253.66	23124.75	24.78	43.16	308.24	33937.62	416.36	416.36
11L	CHIN	STRP		42253.66	23124.75	24.78	43.16	321.24	57062.41	700.05	700.05
11R	CHIN	STRP		42253.66	2317.25	13.05	43.16	7.1.24	57062.41	700.05	700.05
12	CHOU	STRP		42253.66	2317.25	13.05	43.16	2.8.91	47779.25	586.06	586.06
13L	005	STRP		42253.66	2317.25	13.05	43.16	83.45	14795.38	181.51	181.51
13H	005	ANBH		42253.66	2317.25	13.05	43.16	83.45	14795.38	181.51	181.51
13R	005	STRP		42253.66	2317.25	13.05	43.16	83.45	14795.38	181.51	181.51
14L	004	STRP		42253.66	2317.25	13.05	43.16	96.50	17112.63	209.94	209.94
14R	004	STRP		42253.65	1453.43	8.15	43.16	96.61	17111.48	210.17	210.17
15	RBIN	STRP		42253.65	1453.43	8.15	43.16	32.10	5503.99	67.53	67.53
16	RBOU	STRP		42253.65	1453.43	8.15	43.16	3.02	324.28	4.01	4.01
17L	003	STRP		42253.65	1453.43	8.15	43.16	6.68	869.32	10.68	10.68
17H	003	ANBH		42253.65	1453.43	8.15	43.16	6.68	869.32	10.68	10.68
17R	003	STRP		42253.65	1453.43	8.15	43.16	6.68	869.32	10.68	10.68
18L	002	STRP		42253.65	1453.43	8.15	43.16	10.75	1596.04	19.59	19.59

ABARA COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DOWNE ENGINEERING & SERVICES, INC.

卷之三

SSE + SAMS

LOAD CASE NO. B8 (SANS). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS

RUN	SUP. NAME NO.	DP NAME NO.	COP TYPE	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	YY MOMENT (PSI)	ZZ MOMENT (PSI)
RUN1	24	SENZ	AMHT	44669.62	74134.06	132468.37	535658.87	1039879.37	591269.96	16079.42	25717.42
	1	SGNZ	STRP	66669.62	74134.06	132468.37	535658.87	1039879.37	591269.96	16079.42	16079.42
	21	A01A	ABHM	44669.62	74134.06	132468.37	535658.87	1039879.37	591269.96	9787.34	9787.34
	2H	A01A	BELB	44669.62	74134.06	132468.37	535658.87	1039879.37	591269.96	9787.34	9787.34
	2R	A01A	STRP	43333.34	129507.19	728669.87	535658.87	517093.12	286633.94	9787.34	9787.34
	31	A01B	BELB	129507.19	43933.34	728669.87	464676.61	517093.12	517093.12	19220.40	19220.40
	3H	A01B	ABHN	129507.19	43933.34	728669.87	464676.61	414491.25	297315.75	6283.80	12390.14
	3R	A01B	STRP	11615.56	28810.30	71348.81	46470.61	414491.25	297315.75	6283.80	6283.80
	4L	EHIN	STRP	116153.56	28810.30	71348.81	46470.62	43545.62	251379.44	6098.94	6098.94
	4R	EHIN	STRP	105142.25	125567.79	70130.44	46470.62	44196.50	44196.50	44196.50	44196.50
	5L	EHOU	STRP	105142.25	125567.79	70130.44	46470.62	44196.50	44196.50	44196.50	44196.50
	5R	EHOU	STRP	95807.37	21975.39	55867.28	46470.62	64921.00	466735.69	9825.71	9825.71
	6L	A02A	STRP	95807.37	21975.39	55867.28	46470.62	64921.00	466735.69	9825.71	9825.71
	6H	A02A	ABHM	95807.37	21975.39	55867.28	46470.62	22291.75	405273.44	5702.95	5702.95
	6-	AC2A	BELB	63998.87	58791.78	45628.75	46470.61	22291.75	405273.44	5702.95	5702.95
	7L	A02B	BELB	35791.78	83998.87	45628.75	46470.61	138669.37	16079.50	16079.50	16079.50
	7H	A02B	ABHM	35791.78	83998.87	45628.75	46470.61	138669.37	16079.50	16079.50	16079.50
	7R	A02B	STRP	50056.70	61766.40	26952.91	46470.61	138669.37	16079.50	16079.50	16079.50
	8L	E146	STRP	94669.25	8705.75	45590.95	46470.61	138669.37	16079.50	16079.50	16079.50
	8R	E146	STRP	115689.56	77200.19	39305.68	133669.44	525076.87	865389.06	12534.00	12534.00
	9L	A03A	STRP	115689.56	77200.19	39305.68	138669.44	180342.94	865389.06	12534.00	12534.00
	9R	A03A	ABHM	115689.56	77200.19	39305.68	138669.44	180342.94	411113.00	5764.22	5764.22
	10L	A03B	BELB	129538.12	7657.75	43372.47	138669.37	180342.94	411113.00	5764.22	5764.22
	10H	A03B	ABHM	74657.69	129538.12	43372.47	138669.37	180342.94	411113.00	11313.79	11313.79
	11L	CHIN	STRP	75727.62	131022.56	44195.91	23605.73	23605.73	340332.81	4511.61	4511.61
	11R	CHIN	STRP	76673.56	28947.65	24302.73	23605.73	23605.73	340332.81	5018.50	5018.50
	12L	CHOU	STRP	76673.56	28947.65	24302.73	23605.73	23605.73	340332.81	5018.50	5018.50
	12R	CHOU	STRP	796669.56	24207.99	19524.34	23605.73	23605.73	321605.62	5429.20	5429.20
	13L	005	STRP	90844.87	46507.16	30054.28	23605.73	23605.73	303086.75	4511.61	4511.61
	13H	005	ABHM	90844.87	46507.16	30054.28	23605.73	23605.73	303086.75	5429.20	5429.20
	13R	005	STRP	94468.44	50959.82	32599.55	23605.73	23605.73	143582.37	3124.14	3124.14
	14L	004	STRP	94468.44	50959.82	32599.55	23605.73	23605.73	143582.37	3124.14	3124.14
	14R	004	STRP	97884.37	24644.07	24677.77	23605.73	23605.73	175566.25	3853.87	3853.87
	15L	RPIN	STRP	97884.37	24644.07	24677.77	23605.73	23605.73	175804.56	3859.36	3859.36
	15R	RBIN	STRP	102576.56	25754.57	25260.85	23605.73	23605.73	126952.19	2430.68	2430.68
	16L	RBOU	STRP	102576.56	25754.57	25260.85	23605.73	23605.73	163335.56	3381.97	3381.97
	16R	RBOU	STRP	104329.69	26541.62	25808.50	23605.73	23605.73	163335.56	3381.97	3381.97

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTEAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

LOAD CASE NO. #8 (SAMI). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS (CONT'D.)

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)	IM/Z (PSI)
RUN1 (CONT'D.)											
17L	003	STRP	104329.69	26541.62	25808.50	23605.73	229075.62	168545.94	3501.02	3501.02	
17H	003	AMBH	104325.69	26541.62	25808.50	23605.73	229075.62	168545.94	3501.02	3501.02	
17R	003	STRP	104683.00	26720.92	25926.94	23605.73	229075.62	168545.94	3501.02	3501.02	
18L	002	STRP	104683.00	26720.92	25926.94	23605.73	240302.50	175576.75	3662.57	3662.57	
18R	002	STRP	149598.87	69473.87	50665.77	299484.44	979682.06	680325.25	15086.71	15086.71	
19L	001	STRP	149598.87	69473.87	50665.77	299484.44	930361.94	611233.81	14142.15	14142.15	
19H	001	AMBH	149598.87	69473.87	50665.77	299484.44	930361.94	611233.81	14142.15	14142.15	
19P	001	STRP	148894.62	69150.62	49778.66	299484.44	930361.94	611233.81	14142.15	14142.15	
20L	A04A	STRP	147005.19	61545.00	20267.93	299484.44	250227.94	1529395.00	19363.84	19363.84	
20H	A04A	AMBH	147005.19	61545.00	20267.93	299484.44	250227.94	1529395.00	19363.84	19363.84	
20R	A04A	BELB	146574.44	106664.56	36095.05	299484.44	250227.94	1529395.00	19363.84	19363.84	
21L	A04B	BELB	106664.56	146574.44	36095.03	255096.19	205145.69	895484.81	11696.83	22970.26	
21H	A04B	AMBH	106664.56	146574.44	36095.03	255096.19	205145.69	895484.81	11696.83	11696.83	
21R	A04B	STRP	99143.19	139513.31	55257.98	255096.19	205145.69	895484.81	11696.83	11696.83	
22L	A05A	STRP	99143.19	139513.31	55257.98	255096.19	455724.62	502028.37	8887.25	8887.25	
22H	A05A	AMBH	99143.19	139513.31	55257.98	255096.19	455724.62	502028.37	8887.25	8887.25	
22R	A05A	BELB	92360.56	57618.58	108264.75	15096.19	502028.37	55724.62	8887.25	17452.60	
23L	A05B	BELB	57622.18	92358.19	108264.75	905898.56	469761.12	478516.62	13827.01	27153.50	
23H	A05B	AMBH	57622.18	92358.19	108264.75	905898.56	469761.12	478516.62	13827.01	13827.01	
23R	A05B	STRP	58050.25	87582.31	91325.44	905975.37	469570.00	478516.62	13826.79	13826.79	
24L	AB01	STRP	58050.25	87582.31	91325.44	905975.37	571269.56	472566.75	14561.75	14561.75	
24R	AB01	STRP	57653.28	78754.56	66925.94	858491.62	571377.31	473729.50	13922.43	13922.43	
25L	AB02	STRP	57653.28	78754.56	66925.94	858491.62	742134.81	495749.69	15192.24	15192.24	
25R	AB02	STRP	58655.87	65188.19	55257.42	812675.87	742101.94	498049.19	14819.48	14819.48	
26L	AB03	STRP	58655.87	65188.19	55257.42	812675.87	832205.50	545753.94	15760.02	15760.02	
26R	AB03	STRP	60964.43	50184.79	52210.74	768836.37	832172.94	547937.56	15439.46	15439.46	
27L	AB04	STRP	60964.43	50184.79	52210.74	768836.37	846802.81	618999.43	15954.76	15954.76	
27R	AB04	STRP	64055.79	37932.27	48474.54	727501.37	846770.94	521279.37	15573.64	15673.64	
28L	AB05	STRP	64055.79	37932.27	48474.54	727501.37	791922.94	658902.75	15472.07	15472.07	
28R	AB05	STRP	69962.44	42800.68	66026.62	689198.94	791976.62	65948.62	15209.84	15209.84	
29L	10	STRP	75920.87	47392.09	92244.56	689198.94	1067515.00	567479.87	17072.45	17072.45	
29R	10	AMTT	75920.87	47392.09	92244.56	689198.94	1067515.00	567479.87	17072.45	27305.36	
30	MSIV	VALV	79856.94	49590.24	100091.12	689088.62	1067597.00	567479.87	N/A		
31L	11	VALV	128297.06	154130.19	199335.44	614457.44	1859848.00	517460.00	N/A		
31M	11	AMTT	128297.06	154130.19	199335.44	614457.44	1859848.00	517460.00	24854.02	39751.51	
31R	11	STRP	130856.94	159373.00	204249.19	614457.44	1859848.00	517460.00	24854.02	24854.02	
32	MSVH	STRP	130856.94	159373.00	204249.19	614457.44	2894341.00	1516481.00	40789.05	40789.05	

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY MAINSTREAM ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

LOAD CASE NO. 3B (SAMII). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS (CONT'D.)											
RUN	SUP NAME	UCP NO.	COP NAME	COMP TYPE	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	M/Z (PSI)
RUN 32											
33	AB01	VALV	7977.45	14777.39	4832.15	911.77	15854.88	48395.05	N/A	N/A	
34	101	VALV	7977.45	14777.39	4832.15	911.77	15854.88	48395.05	N/A	N/A	
35L	102	VALV	1666.23	697.71	516.98	93.93	215.21	398.07	N/A	N/A	
35R	102	NONS	960.08	529.79	315.00	93.93	215.21	398.07	N/A	N/A	
36L	B01A	NONS	960.08	529.79	315.00	93.93	215.21	398.07	N/A	N/A	
36R	B01A	BELB	283.11	161.84	112.76	93.93	215.21	398.07	N/A	N/A	
37L	B01B	BELB	161.84	283.11	112.76	0.00	0.00	0.00	0.00	0.00	
37R	B01B	STRP	0.09	0.16	0.07	0.00	0.00	0.00	0.00	0.00	
38	103	STRP	0.09	0.16	0.07	0.00	0.00	0.00	0.00	0.00	
RUN 33											
39	AB02	VALV	9740.95	14091.42	5226.49	960.35	17218.7	46150.84	N/A	N/A	
40	201	VALV	9740.95	14091.42	5226.49	960.35	17218.7	46150.84	N/A	N/A	
41L	202	VALV	1583.35	101.93	5339.18	105.98	231.37	425.19	N/A	N/A	
41R	202	NONS	916.72	6317.53	3261.16	105.98	231.37	425.19	N/A	N/A	
42L	C01A	NONS	914.72	6317.53	3261.16	105.98	231.37	425.19	N/A	N/A	
42R	C01A	BELB	270.19	195.99	127.16	105.98	231.37	425.19	N/A	N/A	
43L	C01B	BELB	195.99	270.09	127.10	0.00	0.00	0.00	0.00	0.00	
43R	C01B	STRP	0.11	0.16	0.07	0.00	0.00	0.00	0.00	0.00	
44	203	STRP	0.11	0.16	0.07	0.00	0.00	0.00	0.00	0.00	
RUN 34											
45	AB03	VALV	11133.00	13631.39	5938.40	1085.65	19568.49	45997.75	N/A	N/A	
46	301	VALV	11133.00	13631.39	5938.40	1085.65	19568.49	45997.75	N/A	N/A	
47L	302	VALV	1506.59	1297.50	587.30	118.99	260.08	467.58	N/A	N/A	
47R	302	NONS	670.69	728.20	365.41	118.99	260.08	467.58	N/A	N/A	
48L	D01A	BELB	257.64	223.73	165.91	118.99	231.17	431.17	N/A	N/A	
48R	D01A	BELB	223.73	257.64	142.84	118.99	231.17	431.17	N/A	N/A	
49L	D01B	BELB	0.17	257.64	142.84	0.00	0.00	0.00	0.00	0.00	
49R	D01B	STRP	0.13	0.15	0.08	0.00	0.00	0.00	0.00	0.00	
50	303	STRP	0.13	0.15	0.08	0.00	0.00	0.00	0.00	0.00	
RUN 35											
51	AB04	VALV	11853.22	12791.48	6227.31	1136.86	20521.26	41907.37	N/A	N/A	
52	401	VALV	11853.22	12791.48	6227.31	1136.86	20521.26	41907.37	N/A	N/A	
53L	402	NONS	1431.24	1329.15	613.45	124.21	271.38	504.65	N/A	N/A	
53R	402	NONS	827.59	776.01	361.70	124.21	271.38	504.65	N/A	N/A	
54L	E01A	NONS	827.59	776.01	361.70	124.21	271.38	504.65	N/A	N/A	
54R	E01A	BELB	245.65	238.54	149.12	124.21	271.38	504.65	N/A	N/A	

## LOAD CASE #3, 98 (SAM1). FORCES, MOMENTS AND STRESSES ALONG PIPE RUNS (CONT'D.)

RUN NO.	SOP NO.	DCP NAME	COMP TYPE	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	TORS MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	N/Z (PSI)	IM/Z (PSI)
(CONT'D.)											
RUN5	55L	E01B	BELB	238.54	245.65	149.12	0.00	0.00	0.00	0.00	0.00
	55R	E01B	STRP	0.14	0.14	0.09	0.00	0.00	0.00	0.00	0.00
	56	403	STRP	0.14	0.14	0.09	0.00	0.00	0.00	0.00	0.00
RUN6	57	A005	VALV	12068.81	12150.03	5883.27	1074.81	19387.71	39803.82	N/A	
	58	501	VALV	12068.81	12150.03	5683.27	1074.81	3915.30	7995.62	N/A	
	59L	502	VALV	1359.96	1350.09	580.11	117.49	256.66	529.00	N/A	
	59R	502	NONS	784.04	787.74	360.97	117.49	256.66	524.00	N/A	
	60L	F01A	NONS	784.04	787.74	360.97	117.49	117.49	267.26	N/A	
	60R	F01A	BELB	235.39	261.81	141.05	117.49	117.49	267.26	126.28	309.40
	61L	F01B	BELB	241.81	235.39	14.05	0.00	0.00	0.00	0.00	
	61R	F01B	STRP	0.14	0.14	0.08	0.00	0.00	0.00	0.00	
	62	503	STRP	0.14	0.14	0.08	0.00	0.00	0.00	0.00	
RUN7	63	002	STRP	194715.69	84025.12	79308.37	304013.37	743786.87	507158.87	5815.21	
	64L	07A	STRP	194715.69	84025.12	74308.37	304013.37	803881.94	578433.62	6340.22	
	64R	07A	STRP	196735.37	86231.00	74907.56	304013.37	803881.94	578433.62	6340.22	
	65L	07B	STRP	196735.37	84231.00	74907.56	304013.37	1093235.00	912711.06	8912.29	
	65R	07B	STRP	11126.10	21393.69	57357.90	0.00	450780.00	644094.12	4811.41	
	66L	07C	STRP	X1126.10	81393.69	57357.90	0.00	336388.94	481565.12	3595.06	
	66R	07C	STRP	4646.15	80330.31	56113.21	0.00	336388.94	481565.12	3595.06	
	67L	07D	STRP	4646.15	80330.31	56113.21	0.00	271.05	386.74	2.89	
	67R	07D	FLXC	0.01	77348.37	54209.75	0.00	271.05	386.74	N/A	
	68	004	FLXC	0.0	77348.37	54209.75	0.00	271.05	386.74	N/A	

## LOAD CASE NO. 88 (SAM1). FORCES, MOMENTS AND STRESSES ALONG PIPE RUES (CONT'D.)

RUN	SCD NAME	DCP NAME	CMP TYPE	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	TORS MOMENT (LB.FT)	MOMENT (LB.FT)	MOMENT (LB.FT)	H/Z (PSI)
(CONT'D.)										
RUN55	55L	E01B	BELB							N/A
	55R	E01B	STRP	238.54	245.65	149.12	0.00	0.00	0.00	0.00
	56	403	STRP	0.14	0.14	0.09	0.00	0.00	0.00	0.00
RUN56	57	A005	VALV	12068.81	12150.03	5883.27	1074.81	19887.71	39803.82	N/A
	58	501	VALV	12068.81	12150.03	5883.27	1074.81	3915.30	7995.62	N/A
	59L	502	VALV	1354.96	1350.09	580.11	117.49	256.66	520.00	N/A
	59R	502	NCRS	784.04	787.74	560.97	117.49	258.66	529.00	N/A
	60L	F01A	NCRS	769.04	787.74	360.97	117.49	117.49	267.26	N/A
	60R	F01A	BELB	235.39	241.81	141.05	117.49	117.49	267.26	309.40
	61L	F01B	BELB	241.81	235.39	141.05	0.00	0.00	0.00	0.00
	61R	F01B	STRP	0.14	0.14	0.08	0.00	0.00	0.00	0.00
	62	503	STRP	0.14	0.14	0.08	0.00	0.00	0.00	0.00
RUN57	63	002	STRP	194715.69	84025.12	74308.37	304013.37	743786.67	507158.87	5815.21
	64L	07A	STRP	194715.69	84025.12	74308.37	304013.37	803881.94	57843.62	6340.22
	64R	07A	STRP	196735.37	84231.00	74907.56	304013.37	803881.94	57843.62	6340.22
	65L	07B	STRP	196735.37	84231.00	74907.56	304013.37	109325.00	91271.06	8912.29
	65R	07B	STRP	11126.10	81393.69	57357.90	0.00	450780.00	644094.12	4811.41
	66L	07C	STRP	11126.10	81393.69	57357.90	0.00	336388.94	98565.12	2595.06
	66R	07C	STRP	4646.15	80330.31	56113.21	0.00	336388.94	48565.12	3595.06
	67L	07D	STRP	4646.15	80330.31	56113.21	0.00	271.05	386.74	2.69
	67R	07D	FLXC	0.01	77348.37	54209.75	0.00	271.05	386.74	2.69
	68	004	FLXC	0.01	77348.37	54209.75	0.00	271.05	386.74	N/A

APPENDIX C

SHUTDOWN COOLING LINE

PRELIMINARY ROUTING AND LOADS ANALYSIS

## APPENDIX C

### SHUTDOWN COOLING LINE - PRELIMINARY ROUTING AND LOADS ANALYSIS

#### Purpose

This appendix reports the results of a preliminary stress analysis of a System 80+ Shutdown Cooling line in the Reactor Building to provide applicable forces and moments for the Leak-Before-Break (LBB) evaluation. The piping included in the model is represented in the isometric sketch that follows. The analysis model originates at the hot leg nozzle and terminates at the Reactor Building penetration. Anchors are modelled at these locations. The model also includes additional piping for the relief valve discharge to the holdup volume. All applicable design conditions, loadings, codes, and regulatory requirements are defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 2.

The types of analysis results required for the LBB evaluation are shown on the following page. Other results in the detailed analysis include pipe displacements, stresses, support/restraint loads, and nozzle loads (anchor loads). Since the analysis is preliminary and design information is not available for allowable nozzle or penetration loads, it is not within the scope of the calculation to evaluate those loads.

A code compliance check is performed to verify that pipe stresses are within the ASME allowables for the pipe as modelled. As additional design information becomes available, it will be included in a final analysis.

#### Method

The piping is modelled as a three dimensional framework for analysis. Static analysis is performed by the Direct Stiffness Method and a simple Lumped Mass Idealization is used to determine mode shapes and frequencies for the dynamic analysis. This piping is analyzed using the SUPERPIPE computer program.


### References and Design Inputs

1. ASME Boiler and Pressure Vessel Code Section III, 1989.
2. Draft Distribution Systems Design Guide.
3. ABB-CE Letter dated 4/21/92 to R.W. Bonsall enclosing Preliminary Thermal Movements and SSE Seismic Anchor Movements.
4. ABB-Impell memo dated 5/21/92 to ABB-CE, Attn: R.A. Matzie enclosing System 80+ N-411 Spectra and SAM.
5. System 80+ Shutdown Cooling System Piping and Instrumentation Diagram.
6. System 80+ Nuclear Island Detailed Arrangement Drawings.

### Results

Forces and moments results for the load cases listed below are provided for the Leak-Before-Break evaluation shown in Appendix I.

1. Gravity - Fluid-filled for Hydrostatic Testing
2. Thermal Expansion
3. Gravity + Thermal (Normal Operation)
4. Seismic Inertia - SSE
5. Seismic Anchor Movement - SSE
6. Seismic Inertia + Seismic Anchor Movement



Shutdown  
Cooling  
Line

AZ 103° 45'  
Dwg. No. \_\_\_\_\_

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	1	-5092.86	11.19	-30.01	-530.91	-15165.10	5932.72	
2	2	-5092.85	11.19	-30.01	-530.91	-15225.12	5910.35	
3	2A	-4676.64	11.19	-30.01	-530.91	-15265.13	5895.63	
4L	A01A	-4591.96	11.19	-30.01	-530.91	-15273.27	5892.40	
4R	A01A	-4591.96	20.40	24.69	-530.91	2533.63	-16173.25	
5		-2914.63	-2885.77	24.69	-2181.42	1451.06	-13554.27	
6L	A01B	-20.40	-3611.03	24.69	-2583.02	-481.52	-8011.05	
6R	A01B	-20.40	3611.03	-24.69	-2583.02	481.52	8011.05	
7		-20.40	3076.29	-24.69	-2583.02	459.23	2284.61	
8		-20.40	2541.53	-24.69	-2583.02	396.94	-2526.03	
9		-20.40	2006.78	-24.69	-2583.02	354.65	-6420.85	
10L	A1A	-20.40	1472.03	-24.69	-2583.02	312.35	-9399.81	
10R	A1A	-20.40	-24.69	-1472.03	-2583.02	-9399.81	-312.35	
11		-5.32	-31.59	-1145.06	2769.78	-10740.52	-282.20	
12L	A1B	11.19	-50.01	-818.08	7994.04	-8920.15	-249.19	
12R	A1B	11.19	818.08	-30.01	7994.04	249.19	-8920.14	
13		11.19	232.80	-30.01	7994.04	192.93	-9905.06	
14		11.19	-352.48	-30.01	7994.04	136.67	-9792.89	
15		11.19	-937.76	-30.01	7994.04	80.41	-8185.62	
16		11.19	-1523.05	-30.01	7994.04	24.15	-6277.26	
17		11.19	-2108.33	-30.01	7994.04	-32.11	-2873.81	
18		11.19	-2693.61	-30.01	7994.04	-80.37	1626.74	
19L	X01A	11.19	-3278.90	-30.01	7994.04	-144.63	7224.42	
19R	X01A	11.19	-30.01	-4040.84	7994.03	7224.43	144.63	
20		29.13	-13.31	-3550.38	2623.96	5393.27	180.52	
21L	X01B	30.01	11.19	-3059.91	-123.67	893.28	182.29	
21R	X01B	30.01	3059.91	11.19	-123.67	-182.29	893.28	
22		30.01	2480.80	11.19	-123.67	-161.54	-4244.98	
23		30.01	1901.67	11.19	-123.67	-140.79	-9309.16	
24		30.01	1322.55	11.19	-123.67	-120.05	-11299.21	
25		30.01	743.43	11.19	-123.67	-97.30	-13215.14	
26		30.01	164.30	11.19	-123.67	-78.56	-14056.95	
27		30.01	-414.82	11.19	-123.67	-57.81	-13824.62	
28		30.01	-993.94	11.19	-123.67	-37.06	-12510.18	
29		30.01	-1573.07	11.19	-123.67	-16.32	-10157.60	
30L	X02A	30.01	-2152.19	11.19	-123.67	4.43	-6682.88	
30R	X02A	30.01	-11.19	-2152.19	-123.67	6682.88	4.43	
31		29.13	13.31	-2642.66	-3264.92	1297.59	2.67	
32L	X02B	11.19	30.01	-3133.12	-1397.57	-5408.98	-33.23	
32R	X02B	11.19	-3133.12	-30.01	-1397.56	-33.23	5408.98	
33L	X1	11.19	-3445.36	-30.01	-1397.56	-63.24	8698.22	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SHUB, X SHUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

## STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP HMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XO MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
	33R	X1	11.19	3632.21	-30.01	-1397.56	-63.24	8698.22
	34L	X03A	11.19	3319.97	-30.01	-1397.56	-93.25	5222.13
	34R	X03A	11.19	30.01	3319.97	-1397.56	-5222.13	-93.25
	35		-13.31	29.13	2829.51	1046.89	-332.49	-142.25
	36L	X03B	-30.01	11.19	2339.05	-11.19	-436.89	4261.46
	36R	X03B	-30.01	2339.05	-11.19	-436.89	-175.65	-4261.46
	37L	XX1	-30.01	2182.93	-11.19	-436.89	-181.25	-5391.95
	37R	XX1	-30.01	2182.93	13.39	-436.89	-181.25	-5391.95
	38		-30.01	1621.15	13.39	-436.89	-157.15	-8014.06
	39		-30.01	1059.38	13.39	-436.89	-133.06	-11225.45
	40		-30.01	497.60	13.39	-436.89	-109.96	-12626.10
	41		-30.01	-64.18	13.39	-436.89	-84.87	-13016.01
	42		-30.01	-625.95	13.39	-436.89	-60.77	-12395.17
	43		-30.01	-1187.73	13.39	-436.89	-36.68	-10763.59
	44		-30.01	-1749.51	13.39	-436.89	-12.58	-8121.27
	45		-30.01	-2311.28	13.39	-436.89	11.51	-4468.21
	46L	X04A	-30.01	-2873.06	13.39	-436.89	35.61	195.62
	46R	X04A	-30.01	13.39	2873.06	-436.89	195.62	-35.61
	47		-30.69	-11.75	3363.53	-2617.56	4239.53	-36.96
	48L	X04B	-13.39	-30.01	3853.99	-6922.67	6290.16	-2.36
	48R	X04B	-13.39	-3853.99	-30.01	-6922.67	2.36	6290.16
	49L	X2	-13.39	-4192.24	-30.01	-6922.67	-30.15	10648.40
	49R	X2	-13.39	4282.03	-30.01	-6922.67	-30.15	10648.40
	50L	X05A	-13.39	3943.75	-30.01	-6922.67	-62.37	6192.49
	50R	X05A	-13.39	30.01	3943.75	-6922.67	-6192.50	-62.67
	51		-30.69	11.75	3455.28	-2559.20	-4043.34	-97.27
	52L	X05B	-30.01	-13.39	2962.82	-714.07	-16.10	-95.91
	52R	X05B	-30.01	2962.82	13.39	-714.07	-95.91	16.10
	53L	3	-30.01	2709.12	13.39	-714.07	-85.03	-2288.12
	53R	3	-30.01	1959.13	13.39	-714.07	-85.03	-2288.12
	54L	4	-30.01	1781.93	13.39	-714.07	-58.25	-6029.17
	54R	4	-30.01	-718.07	13.39	-714.07	-58.25	-6029.17
	55L	5	-30.01	-895.27	13.39	-714.07	-31.46	-4415.83
	55R	5	-30.01	-1615.27	13.39	-714.07	-31.46	-4415.83
	56L	A04A	-30.01	-1978.37	13.39	-714.07	-17.18	-2482.94
	56R	A04A	-30.01	13.39	1978.37	-714.07	-2482.94	17.18
	57		-32.20	-6.60	2366.66	-20.03	96.71	12.81
	58L	A04B	-22.33	-24.12	2754.94	-1090.20	3007.83	32.54
	58R	A04B	-22.33	3510.08	23.87	-1090.21	-32.54	3007.83
	59L	6	-22.33	3176.98	23.87	-1090.21	-7.08	-559.12

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)	
<b>RUN1 (CONTD.)</b>									
	59R	6	-22.33	2426.98	23.87	-1090.21	-7.08	-559.12	
	60L	7	-22.33	2249.78	23.87	-1090.21	40.65	-5235.88	
	60R	7	-22.33	-250.22	23.87	-1090.21	40.65	-5235.88	
	61	8	-22.33	-427.42	23.87	-1090.21	88.39	-4558.25	
<b>RUN2</b>									
	62	8	-22.33	-1177.42	23.87	-1090.21	88.39	-4558.25	
	63		-22.33	-1579.91	23.87	-1090.21	119.16	-2781.09	
	64	9	-22.33	-1982.40	23.87	-1090.21	149.92	-485.09	
	65		-22.33	-2606.88	23.87	-1090.21	197.66	4104.18	
	66L	10	-22.33	-3231.74	23.87	-1090.21	245.39	9942.42	
	66R	10	-22.33	4774.42	23.87	-1090.21	245.39	9942.42	
	67		-22.33	4461.40	23.87	-1090.21	269.32	5312.49	
	68	8A	-22.33	4148.35	23.87	-1090.21	293.25	996.41	
	69L	8B	-22.33	3836.11	23.87	-1090.21	317.12	-2995.82	BRANCH AXES
	69R	8B	-55.87	1595.99	18.85	302.06	-217.63	-479.53	
						-302.06	217.63	479.53	BRANCH AXES
	70	8C	-55.87	1283.75	18.85	302.06	-198.78	-1919.40	
	71		-55.87	676.51	18.85	302.06	-162.13	-3825.55	
	72		-55.87	69.27	18.85	302.06	-125.47	-4550.74	
	73		-55.87	-537.97	18.85	302.06	-88.82	-4094.97	
	74		-55.87	-1145.22	18.85	302.06	-52.17	-2458.23	
	75	P5	-55.87	-1752.46	18.85	302.06	-15.51	359.48	
	76L	P4	-55.87	-1934.59	18.85	302.06	-4.52	1434.81	
	76R	P4	-55.87	1044.25	1.70	302.06	-4.52	1434.81	
	77		-55.87	530.81	1.70	302.06	-1.48	22.18	
	78		-55.87	17.36	1.70	302.06	1.57	-469.46	
	79		-55.87	-496.08	1.70	302.06	4.61	-40.10	
	80		-55.87	-1009.53	1.70	302.06	7.65	1310.25	
	81	P3	-55.87	-1522.97	1.70	302.06	10.69	3581.61	
	82L	P2	-55.87	-1737.65	1.70	302.06	11.97	4804.34	
	82R	P2	0.00	214.68	0.00	0.00	0.00	80.50	
	83	P1	0.00	0.00	0.00	0.00	0.00	0.00	
<b>RUN3</b>									
	84	8B	2240.12	30.14	-15.53	534.75	-509.54	2830.27	
	85	11	2108.26	30.14	-15.53	1392.26	-534.75	2516.28	
	86		1853.93	30.14	-15.53	534.75	-523.95	2802.33	
						534.75	-551.72	2748.43	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN3 (CONTD.)								
87			1599.60	30.14	-15.53	534.75	-579.50	2694.53
85	12		1345.26	30.14	-15.53	534.75	-607.28	2640.63
89L	13		1307.16	30.14	-15.53	534.75	-622.82	2610.48
89R	13		-33.54	1107.16	-5.02	1428.87	534.75	2271.75
90	14		-33.54	1069.06	-5.02	1428.87	529.73	1183.64
91			-33.54	807.01	-5.02	1428.87	520.48	-544.64
92			-33.54	544.96	-5.02	1428.87	511.23	-1790.11
93			-33.54	282.91	-5.02	1428.87	501.98	-2552.77
94			-33.54	20.86	-5.02	1428.87	492.72	-2832.61
95			-33.54	-241.19	-5.02	1428.87	483.47	-2629.63
96			-33.54	-503.25	-5.02	1428.87	474.22	-1943.83
97			-33.54	-765.50	-5.02	1428.87	464.97	-775.21
98			-33.54	-1027.35	-5.02	1428.87	455.72	876.22
99L	B01A		-33.54	-1289.40	-5.02	1428.87	446.47	3010.49
99R	B01A		-33.54	-	-1652.42	1428.87	3010.50	-446.47
100L	B01B		-10.33	-32.30	-1454.61	-985.04	871.39	-417.46
100R	B01B		-10.33	1454.61	-32.30	-985.04	417.46	871.39
101			-10.33	1193.54	-32.30	-985.04	358.17	-1559.05
102			-10.33	932.46	-32.30	-985.04	298.89	-3510.28
103			-10.33	671.39	-32.30	-985.04	239.60	-4982.29
104			-10.33	410.31	-32.30	-985.04	180.31	-5975.06
105			-10.33	149.24	-32.30	-985.04	121.03	-6488.62
106			-10.33	-111.84	-32.30	-985.04	61.74	-6522.94
107			-10.33	-372.91	-32.30	-985.04	2.45	-6078.04
108			-10.33	-633.99	-32.30	-985.04	-56.83	-5153.91
109			-10.33	-895.06	-32.30	-985.04	-116.12	-3750.56
110			-10.33	-1156.14	-32.30	-985.04	-175.41	-1867.97
111L	B02A		-10.33	-1417.21	-32.30	-985.04	-234.69	493.86
111R	B02A		-10.33	32.30	96.15	-985.04	-493.86	-234.69
112L	B02B		-32.30	-10.33	-183.12	548.22	-1039.40	-262.16
112R	B02B		-32.30	-183.12	10.33	548.22	-262.16	1039.40
113			-32.30	-467.58	10.33	548.22	-241.50	2690.09
114L	B03A		-32.30	-752.06	10.33	548.22	-220.84	2909.71
114R	B03A		-32.30	3072.43	10.33	548.22	-220.84	2909.71
115L	B03B		-2793.16	-32.30	10.33	207.92	561.13	-715.91
115R	B03B		-2793.16	30.14	15.53	207.92	-903.01	109.45
116			-2522.53	30.14	15.53	207.92	-873.45	52.10
117			-2251.90	30.14	15.53	207.92	-843.89	-5.26
118			-1961.27	30.14	15.53	207.92	-814.33	-62.61
119			-1710.64	30.14	15.53	207.92	-784.77	-119.97

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN3 (CONTD.)</b>								
120		-1440.01	30.14	15.53	207.92	-755.21	-177.32	
121L 14S		-1169.37	30.14	15.53	207.92	-725.65	-234.68	
121R 14S		-1169.37	30.14	1.81	207.92	-725.65	-234.68	
122		-1009.36	30.14	1.81	207.92	-723.62	-268.59	
123L B04A		-849.36	30.14	1.81	207.92	-721.58	-302.50	
123R B04A		-849.36	22.59	-20.03	207.93	-724.13	296.34	
124L B04B		-22.59	-570.09	-20.03	749.18	182.88	1155.25	
124R B04B		-22.59	570.09	20.03	749.18	-182.88	-1155.25	
125		-22.59	287.32	20.03	749.18	-143.05	-2007.56	
126		-22.59	4.56	20.03	749.18	-103.22	-2297.70	
127		-22.59	-278.21	20.03	749.18	-63.39	-2025.67	
128		-22.59	-560.98	20.03	749.18	-23.56	-1191.48	
129L B05A		-22.59	-843.75	20.03	749.18	16.26	204.90	
129R B05A		-22.59	20.03	843.75	749.18	204.90	-16.26	
130L B05B		-30.14	-1.81	983.38	50.39	1482.12	-25.70	
130R B05B		-30.14	-983.38	-1.81	50.39	25.70	1482.12	
131L 15S		-30.14	-1194.20	-1.81	50.39	23.02	3095.96	
131R 15S		-30.14	730.98	-1.81	50.39	23.02	3095.96	
132		-30.14	459.24	-1.81	50.39	19.56	1958.96	
133		-30.14	187.49	-1.81	50.39	16.10	1341.15	
134		-30.14	-84.25	-1.81	50.39	12.64	1242.51	
135		-30.14	-355.99	-1.81	50.39	9.18	1663.07	
136		-30.14	-627.73	-1.81	50.39	5.72	2602.80	
137L B06A		-30.14	-899.47	-1.81	50.39	2.26	4061.73	
137R B06A		-30.15	4060.19	-1.81	50.39	2.26	4061.73	
138L B06B		-3780.93	-30.14	-1.81	0.00	48.13	-801.29	
138R B06B		-3780.93	30.14	1.81	0.00	-48.13	801.29	
139		-3510.86	30.14	1.81	0.00	-44.69	744.06	
140		-3240.80	30.14	1.81	0.00	-41.25	686.82	
141		-2970.73	30.14	1.81	0.00	-37.81	629.59	
142		-2700.67	30.14	1.81	0.00	-34.38	572.35	
143		-2430.60	30.14	1.81	0.00	-30.94	515.12	
144		-2160.53	30.14	1.81	0.00	-27.50	457.88	
145		-1890.47	30.14	1.81	0.00	-24.06	39.65	
146		-1620.40	30.14	1.81	0.00	-20.63	343.41	
147		-1350.33	30.14	1.81	0.00	-17.19	286.18	
148		-1080.27	30.14	1.81	0.00	-13.75	228.94	
149		-810.20	30.14	1.81	0.00	-10.31	171.71	
150		-540.14	30.14	1.81	0.00	-6.68	114.47	
151		-270.07	30.14	1.81	0.00	-3.44	57.24	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X058  
 OPTIONAL ROUTING 7 FROM DEST  
 16" SHUTDOWN COOLING LINE

## STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

RUN NO.	SOP GROUP	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN3 (CONT'D.)	152	15	0.00	30.14	1.81	0.00	0.00	0.00
REBS								
	15	P4	0.00	-3252.84	17.15	0.00	0.00	0.00
		PC	0.00	-4663.33	17.15	0.00	60.03	13853.30
	16	PC	0.00	-4937.33	17.15	0.00	60.03	13853.30
		PB	0.00	-5630.50	17.15	0.00	89.51	22934.86
	17	PB	55.87	4239.75	-12.81	-302.06	37.34	9919.25
		PA	55.87	2728.51	-12.81	-302.06	-10.69	-3146.24
	18	PA	55.87	2254.58	-1.70	-302.06	-10.69	-3146.24
		P2	55.87	1952.33	-1.70	-302.06	-11.97	-4723.84
	19	4	1000.00	0.00	0.00	0.00	0.00	0.00
		OP4	1000.00	0.00	0.00	0.00	0.00	0.00
	20	OP7	1000.00	0.00	0.00	0.00	0.00	0.00
		OP7	1000.00	0.00	0.00	0.00	0.00	0.00

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 2 (THMP), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	1		846.39	13783.31	4562.01	64977.12	31235.66	72969.37
2	2		846.39	13783.31	4562.01	64977.12	21842.51	41826.34
3	2A		846.39	13783.31	4562.01	64977.12	15581.97	21069.47
4L	A01A		846.39	13783.31	4562.01	64977.12	14308.26	19679.24
4R	A01A		846.40	534.57	12927.74	64977.08	0.00	6055.17
5			8265.25	0.00	12927.74	49385.23	51542.95	9664.56
6L	A01B		10842.45	846.39	12927.74	5892.02	86793.94	12970.29
6R	A01B		10842.45	785.84	0.00	5892.04	43207.20	10127.83
7			10842.45	785.84	0.00	5892.04	26987.59	8791.48
8			10842.45	785.84	0.00	5892.04	17828.32	7455.13
9			10842.45	785.84	0.00	5892.04	8669.00	6118.78
10L	A1A		10842.45	785.84	0.00	5892.04	0.00	4782.42
10R	A1A		10842.45	0.00	846.39	5892.04	4782.43	161522.62
11			14217.70	0.00	846.39	2920.51	6307.43	169148.87
12L	A1B		13783.31	4562.01	846.39	1039.10	6142.37	168167.44
12R	A1B		13783.31	785.84	4562.01	1039.11	0.00	6142.37
13			13783.31	785.84	4562.01	1039.11	0.00	4679.74
14			13783.31	785.84	4562.01	1039.11	0.00	3217.12
15			13783.31	785.84	4562.01	1039.11	0.00	1754.48
16			13783.31	785.84	4562.01	1039.11	0.00	291.86
17			13783.31	785.84	4562.01	1039.11	0.00	552.88
18			13783.31	785.84	4562.01	1039.11	0.00	2345.25
19L	X01A		13783.31	785.84	4562.01	1039.11	0.00	4137.64
19R	X01A		13783.30	4562.02	181.80	1039.10	4137.64	132718.12
20			11810.27	12972.10	181.80	2496.86	3145.23	131225.56
21L	X01B		4198.71	13783.31	181.80	3735.01	875.26	114838.56
21R	X01B		4198.71	148.35	13783.31	3735.02	0.00	875.26
22			4198.70	148.35	13783.31	3735.02	0.00	723.31
23			4198.70	148.35	13783.31	3735.02	9947.30	615.24
24			4198.70	148.35	13783.31	3735.02	27552.61	950.04
25			4198.70	148.35	13783.31	3735.02	56433.89	1284.85
26			4198.70	148.35	13783.31	3735.02	85315.12	1619.66
27			4198.70	148.35	13783.31	3735.02	114196.31	1954.46
28			4198.70	148.35	13783.31	3735.02	143077.56	2289.27
29			4198.70	148.35	13783.31	3735.02	171958.87	2624.08
30L	X02A		4198.71	148.35	13783.31	3735.02	230840.37	2958.89
30P	X02A		4198.71	0.00	148.35	3735.02	2487.29	200840.37
31			11810.27	0.00	148.35	4839.05	293.52	225880.87
32L	X02B		13783.30	4198.70	148.35	3319.92	3375.78	242291.25

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 20 (THMP), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP	DCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
32R	X02B	13783.31	148.35	4562.01	3319.92	292291.25	3467.25	
33L	X1	13783.31	148.35	4562.01	3319.92	247445.12	3299.65	
33R	X1	13783.31	177.75	4562.01	3319.92	247445.12	3299.65	
34L	X03A	13783.31	177.75	4562.01	3319.92	252599.00	3098.84	
34R	X03A	13783.31	4198.71	177.75	3319.91	7961.74	252599.00	
35		12972.10	11810.27	177.75	589.02	4114.08	250766.06	
36L	X03B	4562.02	13783.30	177.75	2697.22	2856.45	231763.69	
36R	X03B	4562.01	177.75	0.00	2697.22	231763.69	2420.87	
37L	XX1	4562.01	177.75	0.00	2697.22	223977.94	2320.46	
37R	XX1	4562.01	177.75	726.60	2697.22	223977.94	2320.46	
38		4562.01	177.75	726.60	2697.22	97276.94	1959.17	
39		4562.01	177.75	726.60	2697.22	170575.81	1597.87	
40		4562.01	177.75	726.60	2697.22	143874.69	1236.58	
41		4562.01	177.75	726.60	2697.22	117173.50	875.28	
42		4562.01	177.75	726.60	2697.22	90472.37	513.99	
43		4562.01	177.75	726.60	2697.22	4771.27	152.69	
44		4562.01	177.75	726.60	2697.22	3.0.13	177.94	
45		4562.01	177.75	726.60	2697.22	30.20.27	594.87	
46L	X04A	4562.01	177.75	726.60	2697.22	25416.81	1011.81	
46R	X04A	4562.02	726.59	233.38	2697.22	1011.80	16332.29	
47		12514.63	0.00	233.38	2685.31	964.78	34301.01	
48L	X04B	13136.35	4562.00	233.38	1332.82	2295.60	35705.79	
48R	X04B	13136.34	177.75	4562.01	1332.82	11256.39	2295.60	
49L	X2	13136.34	177.75	4562.01	1332.82	6659.20	2078.06	
49R	X2	13136.34	227.38	4562.01	1332.82	6659.20	2078.06	
50L	X05A	13136.34	227.38	4562.01	1332.82	3028.57	1884.34	
50R	X05A	13136.35	4198.71	227.38	1332.82	1958.79	3028.57	
51		12514.63	6062.96	227.38	2170.13	570.37	0.00	
52L	X05B	4562.02	13136.34	227.38	1548.34	1690.43	0.00	
52R	X05B	4562.01	227.38	726.60	1548.34	0.00	1152.17	
53	3	~2.01	227.38	726.60	1548.34	0.00	1020.91	
54	4	4562.01	227.38	726.60	1548.34	233.18	697.81	
55	5	4562.01	227.38	726.60	1548.34	1676.10	374.70	
56L	A04A	4562.01	227.38	726.60	1548.34	2445.77	202.36	
56R	A04A	4562.02	726.60	62.92	1548.34	202.36	131165.31	
57		11359.85	0.00	62.92	2904.90	654.00	146524.87	
58L	A04B	13905.61	646.90	62.92	3329.62	1459.28	152277.00	
58R	A04B	13905.61	143.05	7146.79	3329.62	0.00	1459.28	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT %5B  
 OPTIONAL ROUTING 7 FROM 2EST  
 16" SHUTDOWN COOLING LINE

2 (THRP), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

LOAD CASE NO.	END (THRP),	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CCWTO.)	59	6	13905.61	143.05	7146.79	3329.62	0.00
	60	7	13905.61	143.05	7146.79	3329.62	0.00
	61	8	13905.61	143.05	7146.79	3329.62	0.00
RUN2	62	8	13905.61	143.05	7146.79	3147.64	0.00
	63	9	13905.61	143.05	7146.79	3147.64	0.00
	64	10	13905.61	143.05	7146.79	3147.64	0.00
	65	10	13905.61	143.05	7146.79	3147.64	0.00
	66L	10	13905.61	143.05	7146.79	3147.64	0.00
	66R	10	13905.61	965.16	7146.79	3147.64	0.00
	67	10	13905.61	965.16	7146.79	3147.64	0.00
	68	8A	13905.61	965.16	7146.79	3147.64	0.00
	69L	2B	13905.61	965.16	7146.79	3147.64	0.00
	69R	8B	13905.61	965.16	7146.79	3147.64	0.00
	70	8C	14890.07	84.71	6594.43	0.00	0.00
	71		14890.07	86.71	6594.43	0.00	0.00
	72		14890.07	84.71	6594.43	0.00	0.00
	73		14890.07	86.71	6594.43	0.00	0.00
	74		14890.07	86.71	6594.43	0.00	0.00
	75	P5	14890.07	84.71	6594.43	0.00	0.00
	76L	P4	14890.07	84.71	6594.43	0.00	0.00
	76R	P4	14890.07	12.99	0.00	0.00	44476.06
	77		14890.07	12.99	0.00	0.00	44476.06
	78		14890.07	12.99	0.00	0.00	12976.26
	79		14890.07	12.99	0.00	0.00	24207.11
	80		14890.07	12.99	0.00	0.00	14072.64
	81	P3	14890.07	12.99	0.00	0.00	3938.15
	82L	P2	14890.07	12.99	0.00	0.00	2.93
	82R	P2	0.00	0.00	0.00	0.00	10.32
	83	P1	0.00	0.00	0.00	0.00	0.00
RUN3	84	8B	867.41	97.70	11.48	3022.03	6257.66
			88.83	887.41	42.27	5335.21	1836.60
	85	11	867.41	97.70	11.48	3022.03	3750.59
						5053.12	2955.35

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTINE 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 38 (T:IMP), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GRUP <sup>a</sup>	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN3 (CONTD.)</b>								
86			887.41	97.70	11.48	3022.03	5658.58	5054.62
87			887.41	97.70	11.48	3022.03	5264.04	7173.89
88	12		887.41	97.70	11.48	3022.03	4869.51	9293.18
89L	13		887.41	97.70	11.48	3022.03	4648.87	10478.32
89R	13		984.46	887.41	42.27	154.34	3022.03	11416.57
90	14		984.46	887.41	42.27	154.34	2432.15	10468.89
91			984.46	887.41	42.27	154.34	1345.34	8722.83
92			984.46	887.41	42.27	154.34	389.19	6976.76
93			984.46	887.41	42.27	154.34	254.21	5230.70
94			984.46	887.41	42.27	154.34	331.54	3484.63
95			984.46	887.41	42.27	154.34	408.87	1738.56
96			984.46	887.41	42.27	154.34	486.20	12.67
97			984.46	887.41	42.27	154.34	563.53	153.21
98			984.46	887.41	42.27	154.34	640.87	301.15
99L	B01A		984.46	887.41	42.27	154.34	718.20	449.06
99R	B01A		984.46	42.27	588.89	154.34	449.06	7349.22
100L	B01B		930.81	638.63	588.89	3808.99	276.74	7277.61
100R	B01B		930.81	54.17	638.63	3808.99	703.77	276.74
101			930.81	54.17	638.63	3808.99	592.64	178.01
102			930.81	54.17	638.63	3808.99	481.52	86.15
103			930.81	54.17	638.63	3808.99	370.40	920.69
104			930.81	54.17	638.63	3808.99	259.27	2075.08
105			930.81	54.17	638.63	3808.99	221.11	3229.47
106			930.81	54.17	638.63	3808.99	624.84	4383.86
107			930.81	54.17	638.63	3808.99	1485.66	5538.25
108			930.81	54.17	638.63	3808.99	2737.56	6692.64
109			930.81	54.17	638.63	3808.99	3989.46	7847.03
110			930.81	54.17	638.63	3808.99	5241.35	9001.41
111L	B02A		930.81	54.17	638.63	3808.99	6493.26	10155.82
111R	B02A		930.81	60.97	469.44	3809.00	809.28	6493.26
112L	B02B		638.63	930.81	469.44	9529.16	4435.65	6103.23
112R	B02B		638.63	469.44	77.20	9529.15	6103.23	348.20
113			638.63	469.44	77.20	9529.15	4115.16	430.14
114L	B03A		638.63	469.44	77.20	9529.15	2127.10	544.43
114R	B03A		638.63	158.77	77.20	9529.15	2127.10	544.43
115L	B03B		2111.70	638.63	77.20	96.02	8286.61	505.85
115R	B03B		2111.70	97.70	206.60	96.02	718.22	216.35
116			2111.70	97.70	206.60	96.02	696.54	53.76

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 30 (THMP), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP	DCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN3 (CONTD.)								
117			2111.70	97.70	206.60	96.02	674.85	1814.61
118			2111.70	97.70	206.60	96.02	653.17	4069.69
119			2111.70	97.70	206.60	96.02	631.49	6324.76
120			2111.70	97.70	206.60	96.02	609.81	8579.83
121L 14S			2111.70	97.70	206.60	96.02	588.13	10834.92
121R 14S			2111.70	97.70	30.97	96.02	588.13	10834.92
122			2111.70	97.70	30.97	96.02	622.75	12168.21
123L B04A			2111.70	97.70	30.97	96.02	657.33	13501.49
123R B04A			2111.70	90.98	527.64	96.02	4329.80	14764.19
124L B04B			1041.81	2111.70	527.64	376.84	37.46	13335.97
124R B04B			1041.81	188.77	47.18	376.84	871.31	1126.52
125			1041.81	188.77	47.18	376.84	486.66	753.88
126			1041.81	188.77	47.18	376.84	193.50	381.25
127			1041.81	188.77	47.18	376.84	241.96	114.40
128			1041.81	188.77	47.18	376.84	335.10	4597.86
129L B05A			1041.81	188.77	47.18	376.84	428.24	9081.34
129R B05A			1041.81	47.18	2111.70	376.84	9081.34	5421.04
130L B05B			1109.76	363.57	2111.70	855.99	4855.08	5511.76
130R B05B			1109.76	188.77	363.57	855.99	436.58	4855.07
131L 15S			1109.76	188.77	363.57	855.99	390.99	8197.72
131R 15S			1109.76	175.90	363.57	855.99	390.99	8197.72
132			1109.76	175.90	363.57	855.99	332.23	12329.16
133			1109.76	175.90	363.57	855.99	273.47	16460.62
134			1109.76	175.90	363.57	855.99	214.72	20592.09
135			1109.76	175.90	363.57	855.99	155.96	24723.53
136			1109.76	175.90	363.57	855.99	97.20	28854.98
137L B06A			1109.76	175.90	363.57	855.99	38.44	32986.47
137R B06A			1109.76	0.00	363.57	855.99	38.44	32986.47
138L B06B			0.00	1109.76	363.57	0.00	817.5	31505.05
138R B06B			0.00	97.70	30.97	0.00	10321.96	2528.81
139			0.00	97.70	30.97	0.00	9584.23	2394.61
140			0.00	97.70	30.97	0.00	8846.98	2210.41
141			0.00	97.70	30.97	0.00	8109.73	2026.21
142			0.00	97.70	30.97	0.00	7372.48	1842.01
143			0.00	97.70	30.97	0.00	6655.24	1657.81
144			0.00	97.70	30.97	0.00	5897.99	1473.61
145			0.00	97.70	30.97	0.00	5160.74	1289.41
146			0.00	97.70	30.97	0.00	4423.49	1105.21



ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 2 (THMX), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	S6P MMS	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	1		846.39	13783.31	4562.01	-73819.25	31235.66	72969.37
2	2		846.39	13783.31	4562.01	-73819.25	21842.51	41826.34
3	2A		846.39	13783.31	4562.01	-73819.25	15581.97	21069.47
4L	A01A		846.39	13783.71	4562.01	-73819.25	14308.26	19679.24
4R	A01A		846.40	-10842.45	12927.74	-73819.25	-18128.77	-10726.78
5			8265.25	-7068.29	12927.74	49385.28	51542.95	-10920.39
6L	A01B		10842.45	846.39	12927.74	-10792.67	86793.94	12970.29
6R	A01B		10842.45	-846.39	-12927.74	-10386.22	-86793.94	-12970.29
7			10842.45	-846.39	-12927.74	-10386.22	-105976.00	-11332.66
8			10842.45	-846.39	-12927.74	-10386.22	-124158.19	-9695.04
9			10842.45	-846.39	-12927.74	-10386.22	-142840.37	-8057.41
10L	A1A		10842.45	-846.39	-12927.74	-10386.22	-161522.62	-6419.77
10R	A1A		10842.45	-12927.74	846.39	-10386.22	-6419.78	161522.62
11			14217.70	-9887.96	846.39	-7337.83	-8561.40	169148.87
12L	A1B		13783.31	4562.01	846.39	-2788.26	-9381.25	168167.44
12R	A1B		13783.31	-846.39	4562.01	-2788.26	-168167.44	-9381.25
13			13783.31	-846.39	4562.01	-2788.26	-158506.69	-7754.82
14			13783.31	-846.39	4562.01	-2788.26	-148845.87	-6128.38
15			13783.31	-846.39	4562.01	-2788.26	-139185.00	-4501.94
16			13783.31	-846.39	4562.01	-2788.26	-129524.25	-2875.50
17			13783.31	-846.39	4562.01	-2788.26	-119863.44	-1249.06
18			13783.31	-846.39	4562.01	-2788.26	-124245.94	-2633.40
19L	X01A		13783.31	-846.39	4562.01	-2788.26	-132718.12	4137.64
19R	X01A		13783.30	4562.02	181.80	-2788.26	4137.64	132718.12
20			11810.27	12972.10	181.80	-3416.90	3145.23	131225.56
21L	X01B		-4562.00	13783.31	181.80	-3802.44	-2691.36	114838.56
21R	X01B		-4562.01	-181.80	13783.31	-3802.45	-107825.25	-2527.00
22			-4562.01	-181.80	13783.31	-3802.44	-84386.06	-2442.62
23			-4562.01	-181.80	13783.31	-3802.44	-60946.77	-2358.24
24			-4562.01	-181.80	13783.31	-3802.44	-37507.43	-2273.87
25			-4562.01	-181.80	13783.31	-3802.44	56433.89	-2189.50
26			-4562.01	-181.80	13783.31	-3802.44	85315.12	-2105.12
27			-4562.01	-181.80	13783.31	-3802.44	114196.31	-2020.75
28			-4562.01	-181.80	13783.31	-3802.44	143077.56	2289.27
29			-4562.01	-181.80	13783.31	-3802.44	171958.87	2624.08
30L	X02A		-4562.01	-181.80	13783.31	-3802.45	200840.37	2958.89
30R	X02A		-4562.00	-13783.31	-181.80	-3802.45	-2958.89	200840.37
31			11810.27	-12972.11	-181.80	4839.05	-642.93	225880.87
32L	X02B		13783.30	-4562.02	-181.80	3319.52	-3467.24	242291.25

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

Z  
LOAD CASE NO. 26 (THMX), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
32R	X02B	13783.31	-181.80	4562.01	3319.92	242291.25	3467.25	
33L	X1	13783.31	-181.80	4562.01	3319.92	247445.12	3299.65	
33R	X1	13783.31	-233.38	4562.01	3319.92	247445.12	3299.65	
34L	X03A	13783.31	-233.38	4562.01	3319.92	252599.00	3098.84	
34R	X03A	13783.31	-4562.00	-233.38	3319.91	-3098.84	252599.00	
35		12972.10	11810.27	-233.38	389.02	4114.08	250766.06	
36L	X03B	4562.02	13783.50	-233.38	2697.22	2856.45	231763.69	
36R	X03B	4562.01	-233.38	-13783.31	2697.22	231763.69	-2856.45	
37L	XX1	4562.01	-233.38	-13783.31	2697.22	223977.94	-2740.58	
37R	XX1	4562.01	-233.38	-13136.34	2697.22	223977.94	-2740.58	
38		4562.01	-233.38	-13136.34	2697.22	197276.94	-2323.65	
39		4562.01	-233.38	-13136.34	2697.22	170575.81	-1906.72	
40		4562.01	-233.38	-13136.34	2697.22	143874.69	-1489.79	
41		4562.01	-233.38	-13136.34	2697.22	117173.50	-1072.86	
42		4562.01	-233.38	-13136.34	2697.22	90472.37	-655.93	
43		4562.01	-233.38	-15136.34	2697.22	63771.27	-238.99	
44		4562.01	-233.38	-13136.34	2697.22	37070.13	-208.60	
45		4562.01	-233.38	-13136.34	2697.22	30520.27	594.87	
46L	X04A	4562.01	-233.38	-13136.34	2697.22	25416.81	1011.81	
46R	X04A	4562.02	-13136.34	233.38	2697.22	1011.80	-25416.81	
47		12514.63	-6062.95	233.38	2683.31	964.78	34301.01	
48L	X04B	13136.35	4562.00	233.38	-1475.27	2295.60	35705.79	
48R	X04B	13136.34	-233.38	4562.01	-1475.27	-35705.79	2295.60	
49L	X2	13136.34	-233.38	4562.01	-1475.27	-30122.60	2078.06	
49R	X2	13136.34	227.38	4562.01	-1475.27	-30122.60	2078.06	
50L	X05A	13136.34	227.38	4562.01	-1475.27	-24538.88	-1958.79	
50R	X05A	13136.35	-4562.00	227.38	-1475.27	1958.79	-24538.88	
51		12514.63	6062.96	227.38	-2522.88	570.37	-25943.62	
52L	X05B	4562.02	13136.54	227.38	-2281.90	1690.43	-43912.40	
52R	X05B	4562.01	227.38	-13136.34	-2281.90	-43912.40	-1690.43	
53	3	4562.01	227.38	-13136.34	-2281.90	-55970.43	-1835.72	
54	4	4562.01	227.38	-13136.34	-2281.90	-85651.69	-2193.34	
55	5	4562.01	227.38	-13136.34	-2281.90	-115333.00	-2550.95	
56L	A04A	4562.01	227.38	-13136.34	-2281.90	-131165.31	-2741.71	
56R	A04A	4562.02	-13136.34	-227.38	-2281.90	-2741.71	131165.31	
57		11359.85	-8020.55	-227.38	2904.90	-2086.35	146524.87	
58L	A04B	13905.61	-4877.99	-227.38	3329.62	-2401.71	152277.00	
58R	A04B	13905.61	-241.83	7146.79	3329.62	-152277.00	-2401.71	

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 35 (THMX), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONT'D.)								
	59	6	13905.61	-241.83	7146.79	3329.62	-143663.44	-2145.54
	60	7	13905.61	-241.83	7146.79	3329.62	-127515.44	-1665.30
	61	8	13905.61	-241.83	7146.79	3329.62	-111367.44	-1185.06
RUN2								
	62	8	13905.61	-241.83	7146.79	3147.44	-105273.81	-1185.06
	63		13905.61	-241.83	7146.79	3147.44	-95435.44	-875.54
	64	9	13905.61	-241.83	7146.79	3147.44	-85597.12	-566.01
	65		13905.61	-241.83	7146.79	3147.44	-70332.69	219.70
	66L	10	13905.61	-241.83	7146.79	3147.44	-55068.27	394.47
	66R	10	13905.61	965.16	7146.79	3147.44	-55068.27	394.47
	67		13905.61	965.16	7146.79	3147.44	-4/416.16	-872.14
	68	8A	13905.61	965.16	7146.79	3147.44	-39764.10	-1905.53
	69L	8B	13905.61	965.16	7146.79	3147.44	-32131.88	-2936.25
	69R	8B	14890.07	84.71	6594.43	-2187.78	32131.88	2936.25
			14890.07	84.71	6594.43	-2187.78	35153.89	854.09
	70	8C	14890.07	84.71	6594.43	-2187.78	-28111.55	764.47
	71		14890.07	84.71	6594.43	-2187.78	-14415.66	590.17
	72		14890.07	84.71	6594.43	-2187.78	-719.70	415.87
	73		14890.07	84.71	6594.43	-2187.78	12976.26	246.90
	74		14890.07	84.71	6594.43	-2187.78	26672.20	85.43
	75	P5	14890.07	84.71	6594.43	-2187.78	40368.27	-107.03
	76L	P4	14890.07	84.71	6594.43	-2187.78	44476.06	-159.31
	76R	P4	14890.07	-15.70	-5290.50	-2187.78	44476.06	-159.31
	77		14890.07	-15.70	-5290.50	-2187.78	34341.60	-129.51
	78		14890.07	-15.70	-5290.50	-2187.78	24207.11	-99.71
	79		14890.07	-15.70	-5290.50	-2187.78	14072.54	-69.91
	80		14890.07	-15.70	-5290.50	-2187.78	3938.15	-40.11
	81	P3	14890.07	-15.70	-5290.50	-2187.78	-6196.38	-14.10
	82L	P2	14890.07	-15.70	-5290.50	-2187.78	-10433.78	-12.04
	82R	P2	0.00	0.00	0.00	0.00	0.00	0.00
	83	P1	0.00	0.00	0.00	0.00	0.00	0.00
RUN3								
	84	8B	887.41	-1109.76	-206.60	3022.03	6257.66	1836.60
			984.46	887.41	552.36	5335.21	3022.03	3750.59
	85	11	887.41	-1109.76	-206.60	3022.03	6053.12	2935.35

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUP AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 2 (THMD), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP NMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	X' MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN3 (CONTD.)</b>								
86			887.41	-1109.76	-206.60	3022.03	5658.58	5054.62
87			887.41	-1109.76	-206.60	3022.03	5264.04	7173.89
88	12		887.41	-1109.76	-206.60	3022.03	4669.51	9293.18
89L	13		887.41	-1109.76	-206.60	3022.03	4648.87	10478.32
89R	13		984.46	887.41	-552.36	-1034.02	3022.03	11416.57
90	14		984.46	887.41	-552.36	-1034.02	2432.15	10468.89
91			984.46	887.41	-552.36	-1034.02	1345.34	8722.83
92			984.46	887.41	-552.36	-1034.02	389.19	6976.76
93			984.46	887.41	-552.36	-1034.02	-1149.10	5230.70
94			984.46	887.41	-552.36	-1034.02	-2027.36	3484.63
95			984.46	887.41	-552.36	-1034.02	-3001.93	1738.56
96			984.46	887.41	-552.36	-1034.02	-4088.76	12.67
97			984.46	887.41	-552.36	-1034.02	-5175.57	-1753.58
98			984.46	887.41	-552.36	-1034.02	-6262.39	-3499.65
99L	B01A		984.46	887.41	-552.36	-1034.02	-7349.22	-5245.73
99R	B01A		984.46	-552.36	588.89	-1034.02	-5245.73	7349.22
100L	B01B		930.81	638.63	588.89	3808.99	-2542.47	7277.61
100R	B01B		930.81	-588.89	638.63	3808.99	-7277.61	-2542.47
101			930.81	-588.89	638.63	3808.99	-6025.71	-1388.08
102			930.81	-588.89	638.63	3808.99	-4773.82	-233.70
103			930.81	-588.89	638.63	3808.99	-3521.92	920.69
104			930.81	-588.89	638.63	3808.99	-2270.03	2075.08
105			930.81	-588.89	638.63	3808.99	-1011.13	3229.47
106			930.81	-588.89	638.63	3808.99	624.84	4383.86
107			930.81	-588.89	638.63	3808.99	1485.66	5538.25
108			930.81	-588.89	638.63	3808.99	2737.56	6692.64
109			930.81	-588.89	638.63	3808.99	3989.46	7847.03
110			930.81	-588.89	638.63	3808.99	5241.35	9001.41
111L	B02A		930.81	-588.89	638.63	3808.99	6493.26	10155.82
111R	B02A		930.81	-638.63	469.44	3809.00	-10155.81	6493.26
112L	B02B		638.63	930.81	469.44	9529.16	4435.65	6103.23
112R	B02B		638.63	469.44	-930.81	9529.15	6103.23	-4435.65
113			638.63	469.44	-930.81	9529.15	4115.16	-5438.31
114L	B03A		638.63	469.44	-930.81	9529.15	2127.10	-6440.97
114R	B03A		638.63	-2111.70	-930.81	9529.15	2127.10	-6440.97
115L	B03B		2111.70	638.63	-930.81	-1113.15	8286.61	-4474.56
115R	B03B		2111.70	-1109.76	206.60	-1113.15	-9023.51	-2695.52
116			2111.70	-1109.76	206.60	-1113.15	-8603.70	-993.54

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNB, X SNB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

2

LOAD CASE NO. 25 (THIN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XO MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUNS (CONTD.)</b>								
117		2111.70	-1109.76	206.60	-1113.15	-8183.88	1814.61	
118		2111.70	-1109.76	206.60	-1113.15	-7763.06	4069.69	
119		2111.70	-1109.76	206.60	-1113.15	-7344.25	6324.76	
120		2111.70	-1109.76	206.60	-1113.15	-6926.43	8579.83	
121L 14S		2111.70	-1109.76	206.60	-1113.15	-6504.51	10834.92	
121R 14S		2111.70	-1109.76	-363.57	-1113.15	-6504.61	10834.92	
122		2111.70	-1109.76	-363.57	-1113.15	-5941.41	12168.21	
123L B04A		2111.70	-1109.76	-363.57	-1113.15	-7378.52	13501.49	
123R B04A		2111.70	-1041.80	527.64	-1113.15	4329.80	14764.19	
124L B04B		1041.81	2111.70	527.64	-5034.15	-871.30	13335.97	
124R B04B		1041.81	-2111.70	527.64	-5034.15	871.31	-13335.97	
125		1041.81	-2111.70	527.64	-5034.15	-940.04	-8852.53	
126		1041.81	-2111.70	527.64	-5034.15	-2060.29	-4369.96	
127		1041.81	-2111.70	527.64	-5034.15	-3180.54	-480.83	
128		1041.81	-2111.70	-527.64	-5034.15	-4300.79	4597.86	
129L B05A		1041.81	-2111.70	-527.64	-5034.15	-5471.04	9081.34	
129R B05A		1041.81	-27.64	2111.70	-5034.15	9081.34	5421.04	
130L B05B		1109.76	363.57	2111.70	-10806.80	4853.08	5511.76	
130R B05B		1109.76	-2111.70	363.57	-10806.80	-5511.76	4255.07	
131L 15S		1109.76	-2111.70	363.57	-10806.80	-4936.25	8197.72	
131R 15S		1109.76	-2024.87	363.57	-10806.80	-4936.25	8197.72	
132		1109.76	-2024.87	363.57	-10806.80	-4194.44	12329.36	
133		1109.76	-2024.87	363.57	-10806.80	-3452.62	16440.62	
134		1109.76	-2024.87	363.57	-10806.80	-2710.80	20592.09	
135		1109.76	-2024.87	363.57	-10806.80	-1968.98	24723.53	
136		1109.76	-2024.87	363.57	-10806.80	-1227.16	28854.98	
137L B06A		1109.76	-2024.87	363.57	-10806.80	-485.34	32986.47	
137R B06A		1109.76	0.00	363.57	-10806.80	-485.34	32986.47	
138L B06B		0.00	1109.76	363.57	-0.01	-10321.46	51505.05	
138R B06B		0.00	-1109.76	-363.57	0.00	10321.46	-31505.05	
139		0.00	-1109.76	-363.57	0.00	9584.23	-29254.70	
140		0.00	-1109.76	-363.57	0.00	8846.98	-27004.36	
141		0.00	-1109.76	-363.57	0.00	8109.73	-24753.97	
142		0.00	-1109.76	-363.57	0.00	7372.48	-22503.62	
143		0.00	-1109.76	-363.57	0.00	6635.24	-20253.28	
144		0.00	-1109.76	-363.57	0.00	5897.59	-18002.92	
145		0.00	-1109.76	-363.57	0.00	5160.74	-15752.56	
146		0.00	-1109.76	-363.57	0.00	4423.49	-13502.20	

ADVANCED LIGHT WATER REACTOR 16" SHU, X1 Z SHUB, X SCALE A  
OPTIONAL ROUTING 7 FROM DEST  
16" SHU, OWN COOLING LINE

LOAD CASE NO.	TYPE	DCP NAME	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	XOZ MOMENT (LB.FT)	YOY MOMENT (LB.FT)	ZZZ MOMENT (LB.FT)
<b>RUNS</b>								
1	CONST.	157	0.00	-1109.-76	-363.-57	0.00	3686.-25	-11251.-86
148	PC	0.00	-1109.-76	-363.-57	0.00	7409.00	-9001.47	
149	PC	0.00	-1109.-76	-343.-57	0.00	2211.-75	-6751.11	
150	PC	0.00	-1109.-76	-363.-57	0.00	1474.-51	-4500.75	
151	PC	0.00	-1109.-76	-363.-57	0.00	737.-26	-2250.39	
152	PC	0.00	-1109.-76	-363.-57	0.00	0.00	0.00	
<b>REPS</b>								
1	P4	0.06	100.-42	21804.-93	0.00	0.00	0.00	0.00
16	PC	2.-30	100.-42	11884.-93	0.00	41597.-27	-351.-46	
16	PC	0.-00	100.-42	11884.-93	0.00	41597.-27	-351.-46	
16	PB	0.00	100.-42	11884.-93	0.00	62025.-09	-524.-06	
17	FB	-14890.-07	-52.-04	-5223.-56	2046.-63	25390.-61	-222.-92	
17	PA	-14290.-07	-62.-04	-5223.-56	2046.-63	5892.-27	13.-20	
18	PA	-14890.-07	15.-70	5290.-50	2046.-63	5802.-27	13.-20	
18	PZ	-14890.-07	15.-70	5290.-50	2046.-63	9770.-15	11.-38	
19	P4	5.00	0.-60	0.00	0.00	0.00	0.00	
19	CP4	0.00	0.-60	0.00	0.00	0.00	0.00	
20	P7	0.06	0.95	0.00	0.00	0.30	0.00	
20	CP7	0.00	0.95	0.00	0.00	0.30	0.00	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SHED, X SHED AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

LOAD CASE NO.	SOP GROUP	DCP NRB NAME	FORCES AND MOMENTS IN LOCAL COORDINATES				ZZ MOMENT (LB.FT)
			X AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	XX MOMENT (LB.FT)	
RUN1	1	1	-785.86	0.00	-4198.71	-73819.25	-19952.50
	2	2	-785.86	0.00	-4198.71	-73819.25	0.00
	3	2A	-785.86	0.00	-4198.71	-73819.25	0.00
	4L	A01A	-785.86	0.00	-4198.71	-73819.25	0.00
	4R	A01A	-785.86	-10842.45	0.00	-4879.62	-10726.78
	5		-933.67	-7068.29	0.00	-47850.06	-10920.39
	6L	A01B	-534.57	-785.86	0.00	-10792.67	-44566.47
	6R	A01B	-534.57	-846.39	-12927.76	-46897.89	-10127.85
	7		-534.57	-846.39	-12927.76	-56793.94	-12970.29
	8		-534.57	-846.39	-12927.76	-10386.22	-105976.00
	9		-534.57	-846.39	-12927.76	-10386.22	-11352.66
	10L	A1A	-534.57	-846.39	-12927.76	-10386.22	-124158.19
	10R	A1A	-534.57	-12927.76	-785.84	-10386.22	-8057.41
	11		0.00	-9887.96	-785.84	-10386.22	-6419.77
	12L	A1B	0.00	-4198.71	-785.84	-7337.83	0.00
	12R	A1B	0.00	-846.39	-4198.71	-2788.26	-851.40
	13		0.00	-846.39	-4198.70	-2788.26	-9695.04
	14		0.00	-846.39	-4198.70	-2788.26	-9695.04
	15		0.00	-846.39	-4198.70	-2788.26	-9695.04
	16		0.00	-296.39	-4198.70	-2788.26	-9695.04
	17		9.00	-846.39	-4198.70	-2788.26	-9695.04
	18		0.00	-846.39	-4198.70	-2788.26	-9695.04
	19L	X01A	0.00	-846.39	-4198.71	-2788.26	-132718.12
	19R	X01A	0.00	-4198.70	-148.35	-2788.26	-4096.04
	20		0.00	0.00	-148.35	-3416.90	0.00
	21L	XG1B	-4562.00	0.00	-148.35	-3802.44	-2875.50
	21R	XG1B	-4562.00	0.00	-148.35	-3802.44	-1249.96
	22		-9552.01	-181.80	0.00	-3802.44	-168167.44
	23		-4562.01	-181.80	0.00	-3802.44	-168167.44
	24		-4562.01	-181.80	0.00	-3802.44	-168167.44
	25		-4562.01	-181.80	0.00	-3802.44	-168167.44
	26		-4562.01	-181.80	0.00	-3802.44	-168167.44
	27		-4562.01	-181.80	0.00	-3802.44	-168167.44
	28		-4562.01	-181.80	0.00	-3802.44	-168167.44
	29		-4562.01	-181.80	0.00	-3802.44	-168167.44
	30L	X02A	-4562.01	-181.80	0.00	-3802.44	-168167.44
	30R	X02A	-4562.00	-13783.51	-181.80	-3802.44	-2958.89
	31		0.00	-12972.11	-161.80	-4545.69	-692.93
	32L	X02B	0.00	-4562.02	-161.80	-2822.69	0.00
	32R	X02B	0.00	-4562.02	-161.80	-3667.24	0.00

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL FLUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

Z

LOAD CASE NO. 56 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SUP ID#	DC# NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
32R	X02B		0.00	-181.80	-4198.71	-2822.49	0.00	-3373.99
33L	X1		0.00	-181.80	-4198.71	-2822.49	0.00	-3193.47
33R	X1		0.00	-233.38	-4198.71	-2822.49	0.00	-3193.47
34L	X03A		0.00	-233.38	-4198.71	-2822.49	0.00	-2961.74
34R	X03A		0.00	-4562.00	-233.38	-2822.49	-3098.84	0.00
35			0.00	0.00	-233.38	77.08	-3903.02	0.00
36L	X03B		-4198.70	0.00	-233.38	-2498.27	-2420.87	0.00
36R	X03B		-4198.71	-233.38	-13783.31	-2498.27	0.00	-2874.45
37L	XX1		-4198.71	-233.38	-13783.31	-2498.27	0.00	-2740.58
37R	XX1		-4198.71	-233.38	-13136.34	-2498.27	0.00	-2740.58
38			-4198.70	-233.38	-13136.34	-2498.27	0.00	-2323.65
39			-4198.76	-233.38	-13136.34	-2498.27	0.00	-1906.72
40			-4198.70	-233.38	-13136.34	-2498.27	0.00	-1485.79
41			-4198.70	-233.38	-13136.34	-2498.27	0.00	-1072.86
42			-4198.70	-233.38	-13136.34	-2498.27	0.00	-655.93
43			-4198.70	-233.38	-13136.34	-2498.27	0.00	-258.99
44			-4198.70	-233.38	-13136.34	-2498.27	0.00	-208.60
45			-4198.70	-233.38	-13136.34	-2498.27	0.00	-569.90
46L	X04A		-4198.71	-233.38	-13136.34	-2498.27	-16332.29	-931.20
46R	X04A		-4198.70	-13136.34	-177.75	-2498.27	-931.19	-25416.81
47			-2745.42	-6062.95	-177.75	-2617.74	-723.37	-18919.46
48L	X04B		-726.60	-4198.71	-177.75	-1475.27	-2034.80	-11256.39
48R	X04B		-726.60	-233.38	-4198.71	-1475.27	-35705.79	-2034.81
49L	X2		-726.60	-233.38	-4198.71	-1475.27	-30122.60	-1783.77
49R	X2		-726.60	-62.92	-4198.71	-1475.27	-30122.60	-1783.77
50L	X05A		-726.60	-62.92	-4198.71	-1475.27	-24538.88	-1958.79
50R	X05A		-726.60	-4562.00	-62.92	-1475.27	-1884.34	-24538.88
51			-2745.42	0.00	-62.92	-2522.88	-460.47	-25945.62
52L	X05B		-4198.70	-726.59	-62.92	-2281.90	-1152.17	-43912.40
52R	X05B		-4198.71	-62.92	-13136.34	-2281.90	-43912.40	-1690.43
53	3		-4198.71	-62.92	-13136.34	-2281.90	-55970.43	-1835.72
54	4		-4198.71	-62.92	-13136.34	-2281.90	-85651.69	-2193.34
55	5		-4198.71	-62.92	-13136.34	-2281.90	-115333.00	-2550.95
56L	A04A		-4198.71	-62.92	-13136.34	-2281.90	-13115.51	-2741.71
56R	A04A		-4198.70	-13136.34	-227.38	-2281.90	-2741.71	-2445.77
57			-2988.58	-8020.55	-227.38	-1912.23	-2086.50	-2113.27
58L	A04B		-1702.50	-4677.99	-227.38	-705.86	-2401.71	0.00
58R	A04B		-1702.50	-241.83	0.00	-705.86	-152277.00	-1401.71

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

Z

LOAD CASE NO. 36 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1 (CONTD.)</b>								
	59	6	-1702.50	-241.83	0.00	-705.86	-143663.44	-2145.54
	60	7	-1702.50	-241.83	0.00	-705.86	-127515.44	-1665.30
	61	8	-1702.50	-241.83	0.00	-705.86	-111367.44	-1185.96
<b>RUN2</b>								
	62	8	-1702.50	-241.83	0.00	-705.86	-105273.81	-1185.06
	63		-1702.50	-241.83	0.00	-705.86	-95435.44	-875.54
	64	9	-1702.50	-241.83	0.00	-705.86	-85597.12	-566.01
	65		-1702.50	-241.83	0.00	-705.86	-70332.69	-85.77
	66L	10	-1702.50	-241.83	0.00	-705.86	-55068.27	-224.37
	66R	10	-1702.50	-52.69	0.00	-705.86	-55068.27	-224.37
	67		-1702.50	-52.69	0.00	-705.86	-47416.16	-872.14
	68	8A	-1702.50	-52.69	0.00	-705.86	-39764.10	-1905.53
	69L	8B	-1702.50	-52.69	0.00	-705.86	-32131.88	-2936.25
			1702.50	52.69	0.00	705.86	32131.88	2936.25
	69R	8B	-1791.33	-46.43	0.00	-2187.78	-35153.89	-433.80
			1791.33	46.43	0.00	2187.78	35153.89	433.80
	70	8C	-1791.33	-46.43	0.00	-2187.78	-28111.55	-584.68
	71		-1791.33	-46.43	0.00	-2187.78	-14415.66	-289.16
	72		-1791.33	-46.43	0.00	-2187.78	-719.70	-193.64
	73		-1791.33	-46.43	0.00	-2187.78	0.00	-98.12
	74		-1791.33	-46.43	0.00	-2187.78	0.00	-15.30
	75	P5	-1791.33	-46.43	0.00	-2187.78	0.00	-107.03
	76L	P4	-1791.33	-46.43	0.00	-2187.78	0.00	-159.31
	76R	P4	-1791.33	-15.70	-5290.50	-2187.78	0.00	-159.31
	77		-1791.33	-15.70	-5290.50	-2187.78	0.00	-129.51
	78		-1791.33	-15.70	-5290.50	-2187.78	0.00	-99.71
	79		-1791.33	-15.70	-5290.50	-2187.78	0.00	-69.91
	80		-1791.33	-15.70	-5290.50	-2187.78	9.00	-40.11
	81	P3	-1791.33	-15.70	-5290.50	-2187.78	-6196.38	-14.10
	82L	P2	-1791.33	-15.70	-5290.50	-2187.78	-10433.78	-12.04
	82R	P2	0.00	0.00	0.00	0.00	0.00	0.00
	83	P1	0.00	0.00	0.00	0.00	0.00	0.00
<b>RUN3</b>								
	84	8B	-80.86	-1109.76	-206.60	-19.76	-538.64	-710.41
			904.46	80.86	552.36	281.70	19.76	845.85
	85	11	-80.86	-1109.76	-206.60	-19.76	-528.07	-411.09
							BRANCH AXES	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

Z

LOAD CASE NO. 36 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUNS (CONTD.)</b>								
86			-80.86	-1109.76	-206.60	-19.76	-507.70	-417.90
87			-80.86	-1109.76	-206.60	-19.76	-487.52	-591.57
88	12		-80.86	-1109.76	-206.60	-19.76	-468.95	-764.85
89L	13		-80.86	-1109.76	-206.60	-19.76	-455.55	-861.85
89R	13		-88.83	-80.86	-552.36	-1034.02	-19.76	-962.55
90	14		-88.83	-80.86	-552.36	-1034.02	0.00	-882.26
91			-88.83	-80.86	-552.36	-1034.02	0.00	-734.34
92			-88.83	-80.86	-552.36	-1034.02	-270.83	-586.41
93			-88.83	-80.86	-552.36	-1034.02	-1149.10	-438.49
94			-88.83	-80.86	-552.36	-1034.02	-2027.36	-290.56
95			-88.83	-80.86	-552.36	-1034.02	-3001.93	-142.64
96			-88.83	-80.86	-552.36	-1034.02	-4088.76	-11.37
97			-88.83	-80.86	-552.36	-1034.02	-5175.57	-1753.58
98			-88.83	-80.86	-552.36	-1034.02	-6262.39	-3499.65
99L	B01A		-88.83	-80.86	-552.36	-1034.02	-7347.22	-5245.73
99R	B01A		-88.83	-552.36	-54.17	-1034.02	-5245.73	-718.20
100L	B01B		-77.20	-60.97	-54.17	-296.99	-2542.47	-705.77
100R	B01B		-77.20	-588.89	-60.97	-296.99	-7277.61	-2542.47
101			-77.20	-588.89	-60.97	-296.99	-6025.71	-1388.06
102			-77.20	-588.89	-60.97	-296.99	-4773.82	-233.70
103			-77.20	-588.89	-60.97	-296.99	-3521.92	-19.45
104			-77.20	-588.89	-60.97	-296.99	-2270.03	-118.17
105			-77.20	-588.89	-60.97	-296.99	-1018.13	-216.90
106			-77.20	-588.89	-60.97	-296.99	0.00	-315.63
107			-77.20	-588.89	-60.97	-296.99	-74.10	-414.36
108			-77.20	-588.89	-60.97	-296.99	-185.22	-513.09
109			-77.20	-588.89	-60.97	-296.99	-"	-611.82
110			-77.20	-588.89	-60.97	-296.99	-447.47	-710.55
111L	B02A		-77.20	-588.89	-60.97	-296.99	-518.55	-809.26
111R	B02A		-77.20	-638.63	-157.85	-296.99	-10155.81	-518.59
112L	B02C		-60.97	-77.20	-157.85	-758.07	-348.70	-498.45
112R	B02B		-60.97	-157.85	-930.81	-758.07	-496.45	-4435.65
113			-60.97	-157.85	-930.81	-758.07	-345.15	-538.31
114L	B03A		-60.97	-157.85	-930.81	-758.07	-191.84	-6440.97
114R	B03A		-60.97	-2111.70	-930.81	-758.07	-191.84	-6440.97
115L	B03B		-188.77	-60.97	-930.81	-1113.15	-662.25	-4474.56
115R	B03B		-188.77	-1109.76	-11.48	-1113.15	-9023.51	-2695.52
116			-188.77	-1109.76	-11.48	-1113.15	-8603.70	-993.54

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

Z

LOAD CASE NO. 36 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUNS (CONTD.)							
117		-188.77	-1109.76	-11.48	-1113.15	-8183.88	-523.91
118		-188.77	-1109.76	-11.48	-1113.15	-7764.06	-335.41
119		-188.77	-1109.76	-11.48	-1113.15	-7344.25	-520.00
120		-188.77	-1109.76	-11.48	-1113.15	-6924.43	-704.58
121L 14S		-188.77	-1109.76	-11.48	-1113.15	-6504.61	-889.17
121R 14S		-188.77	-1109.76	-363.57	-1113.15	-6504.61	-889.17
122		-188.77	-1109.76	-363.57	-1113.15	-6941.41	-998.31
123L B04A		-188.77	-1109.76	-363.57	-1113.15	-7378.22	-1107.44
123R B04A		-188.77	-1041.80	-47.18	-1113.15	-318.28	-1247.88
124L B04B		-90.98	-188.77	-47.18	-5034.15	-871.30	-1126.52
124R B04B		-90.98	-2111.70	-527.64	-5034.15	-37.46	-13335.97
125		-90.98	-2111.70	-527.64	-5034.15	-940.04	-8852.53
126		-90.98	-2111.70	-527.64	-5034.15	-2060.29	-4369.06
127		-90.98	-2111.70	-527.64	-5034.15	-3180.54	-480.83
128		-90.98	-2111.70	-527.64	-5034.15	-4500.79	-364.02
129L B05A		-90.98	-2111.70	-527.64	-5034.15	-5421.04	-736.66
129R B05A		-90.98	-527.64	-188.77	-5034.15	-736.66	-426.24
130L B05B		-97.70	-30.97	-188.77	-10806.80	-488.10	-436.58
130R B05B		-97.70	-2111.70	-30.97	-10806.80	-5511.76	-488.10
131L 15S		-97.70	-2111.70	-30.97	-10806.80	-4936.25	-697.92
131R 15S		-97.70	-2024.87	-30.97	-10806.80	-4936.25	-697.92
132		-97.70	-2024.87	-30.97	-10806.80	-4194.44	-1031.61
133		-97.70	-2024.87	-30.97	-10806.80	-3452.62	-1565.30
134		-97.70	-2024.87	-30.97	-10806.80	-2710.80	-1698.99
135		-97.70	-2024.87	-30.97	-10806.80	-1963.98	-2032.68
136		-97.70	-2024.87	-30.97	-10806.80	-1227.16	-2366.37
137L B06A		-97.70	-2024.87	-30.97	-10806.80	-485.34	-2700.07
137R B06A		-97.70	0.00	-30.97	-10806.80	-485.34	-2700.07
138L B06B		0.00	-97.70	-30.97	-0.01	-10321.46	-2578.81
138R B06B		0.00	-1109.76	-363.57	0.00	-817.54	-31505.05
139		0.00	-1109.76	-363.57	0.00	-759.15	-29254.70
140		0.00	-1109.76	-363.57	0.00	-700.75	-27004.36
141		0.00	-1109.76	-363.57	0.00	-642.36	-24753.97
142		0.00	-1109.76	-363.57	0.00	-583.96	-22503.62
143		0.00	-1109.76	-363.57	0.00	-525.56	-20253.28
144		0.00	-1109.76	-363.57	0.00	-467.17	-18002.92
145		0.00	-1109.76	-363.57	0.00	-408.77	-15752.56
146		0.00	-1109.76	-363.57	0.00	-350.38	-13502.20

ADVANCED LIGHT WATER REACTOR ~~W&I Z SNMB~~, X SNMB AT X058  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINEZ  
LOAD CASE NO. 7 (TRIM), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

RUN GROUP	SOP NAME	DCP NAME	AXIAL FORCE (LB.)	V FORCE (LB.)	Z FORCE (LB.)	XX MOMENT (LB.FT.)	YY MOMENT (LB.FT.)	ZZ MOMENT (LB.FT.)
RUNS (CONT'D.)								
147			0.00	-1109.76	-363.57	0.00	-291.96	-11251.84
148			0.00	-1109.76	-363.57	0.00	-232.58	-9001.47
149			0.00	-1109.76	-363.57	0.00	-175.19	-6751.31
150			0.00	-1109.76	-363.57	0.00	-116.79	-4500.75
151			0.00	-1109.76	-363.57	0.00	-58.40	-2250.39
152			0.00	-1109.76	-363.57	0.00	0.00	0.00
MM85								
15	P4		0.00	-59.42	0.00	0.00	0.00	0.00
	PC		0.00	-59.42	0.00	0.00	0.00	351.96
16	PC		0.00	-59.42	0.00	0.00	0.00	-551.46
	PB		0.00	-59.42	0.00	0.00	0.00	-529.96
17	PB		-14890.07	-62.04	-5223.56	0.00	0.00	-222.92
	PA		-14890.07	-62.04	-5223.56	0.00	0.00	-5.06
18	PA		-14890.07	-12.99	0.00	0.00	0.00	-3.06
	P2		-14890.07	-12.99	0.00	0.00	0.00	-10.39
19	4		0.00	0.00	0.00	0.00	0.00	0.00
	CP4		0.00	0.00	0.00	0.00	0.00	0.00
20	7		0.00	0.00	0.00	0.00	0.00	0.00
	CP7		0.00	0.00	0.00	0.00	0.00	0.00

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SHAB, X SHAB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COUPLING LINE

**3** LOAD CASE NO. 30 (NORTH), FORCES AND MOMENTS IN LOCAL COORDINATES

LOAD CASE NO.	RUN GROUP	SOP HB	BCP NAME	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	XX MOMENT (LB.FT.)	YY MOMENT (LB.FT.)	ZZ MOMENT (LB.FT.)
RUN1	1	1		-5878.70	13796.50	4532.00	-74350.19	-35117.60	78902.12
	2	2		-5878.70	13796.50	4532.00	-74350.19	-26173.42	67736.68
	3A	ZA		-5962.48	13796.50	4532.00	-74350.19	-2170.70	26964.87
	4L A01A			-5377.80	13796.50	4532.00	-74350.19	25571.64	
	4R A01A			-10822.05	17952.44	-74350.12	-15595.14	-26900.01	
	5			5350.62	12952.45	-59031.46	5299.00	-24474.65	
	6L A01B			10822.05	-6396.87	12952.44	-13375.69	86312.94	-18138.88
	6R A01B			10822.05	6396.87	-12952.44	-12969.24	-86312.94	18138.88
	7			10822.05	3862.13	-12952.43	-12969.23	-105056.81	1076.09
	8			10822.05	3327.36	-12952.43	-12969.23	-123761.25	-12221.06
	9			10822.05	2792.63	-12952.43	-12969.23	-142465.75	-14478.23
	10L A1A			10822.05	2257.87	-12952.44	-12969.24	-161210.25	-15819.58
	10R A1A			10822.05	-12952.45	-2257.87	-12969.23	-15819.59	161210.25
	11			16212.38	-9919.45	-1930.90	5690.29	-19301.92	168366.25
	12L A1B			15794.49	4531.99	-1603.92	9033.14	-18301.39	167918.25
	12R A1B			13796.50	1603.92	4532.00	9033.14	-167918.25	-18301.39
	13			13796.49	1018.64	4532.00	9033.14	-158313.75	-17656.88
	14			13794.49	-1198.88	4532.00	9033.14	-148709.19	-15921.26
	15			1704.16	-1391.04	4532.00	9033.14	-139104.62	-13085.56
	16			13794.49	-236.44	4532.00	9033.14	-129500.66	-9152.76
	17			13794.49	-2954.72	4532.00	9033.14	-119895.56	-4122.86
	18			13796.49	-3549.00	4532.00	9033.14	-126359.31	3972.90
	19L X01A			17794.50	-4125.29	4532.00	9033.14	-132862.75	11362.07
	19R X01A			13794.49	4532.00	-4129.19	9033.13	11362.07	132862.75
	20			11819.61	12958.79	-3690.73	-120.92	8558.50	131406.06
	21L X01B			13794.49	-236.44	4532.00	9033.14	-129500.66	116026.81
	21R X01B			4531.99	13794.50	-3208.27	-3926.11	-108007.59	1768.54
	22			-4532.00	2629.15	13796.49	-3926.11	-89547.56	-6687.59
	23			-4532.00	2050.02	13794.49	-3926.11	-61087.55	-10567.39
	24			-4532.00	1670.90	13794.49	-3926.11	-37627.46	-13573.07
	25			-4532.00	891.78	13794.49	-3926.11	56334.58	-15404.63
	26			-4532.00	312.65	13794.49	-3926.11	85236.56	-16162.06
	27			-4532.00	-598.62	13796.49	-3926.11	114158.50	15805.37
	28			-4532.00	-1175.74	13796.49	-3926.11	143040.50	-14454.54
	29			-4532.00	-1759.86	13796.49	-3926.11	171962.56	-12319.04
	30L X02A			-4532.00	-2331.99	13794.50	-3926.11	200864.75	-9170.16
	30R X02A			-4531.99	-13794.50	-2333.49	-3926.12	9170.16	208644.75
	31			11839.40	-12958.79	-2828.45	-7810.61	1541.11	225883.56
	32L X02B			13796.49	-5314.92	-4220.05	-8876.22	-8876.22	262258.00

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X0F3  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

LOAD CASE NO. 3 (NORM), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
32R	X02B	13794.50	-3314.92	4532.00	-4220.05	242258.00	8876.23	
33L	X1	13794.50	-3627.16	4532.00	-4220.05	247381.87	11997.87	
33R	X1	13794.50	3809.96	4532.00	-4220.05	247381.87	11997.87	
34L	X03A	13794.50	3497.72	4532.00	-4220.05	252505.75	8320.96	
34R	X03A	13794.50	-4531.99	3497.72	-4220.04	-8320.96	252505.75	
35		12958.79	11859.40	3007.26	1435.91	-4235.51	-50623.81	
36L	X03B	4532.00	13794.49	2516.79	-2935.16	7117.91	231588.06	
36R	X03B	4532.00	2516.79	-13794.50	-2935.17	231588.06	-7117.91	
37L	X01	4532.00	2360.57	-13794.50	-2935.17	223796.62	-8132.54	
37R	X01	4532.00	2360.67	-13122.95	-2935.17	223796.62	-8132.54	
38		4532.00	1798.90	-13122.95	-2935.16	197119.75	-11137.71	
39		4532.00	1237.13	-13122.95	-2935.16	170642.75	-15132.16	
40		4532.00	675.35	-13122.95	-2935.16	143765.89	-14115.88	
41		4532.00	-297.56	-13122.95	-2935.16	117088.62	-14000.85	
42		4532.00	-859.33	-13122.95	-2935.16	90411.56	-13051.09	
43		4532.00	-1421.11	-13122.95	-2935.16	63734.59	-11002.58	
44		4532.00	-1982.69	-13122.95	-2935.16	37057.54	-8329.87	
45		4532.00	-2544.66	-13122.95	-2935.16	30531.76	-5038.11	
46L	X04A	4532.00	-3106.44	-13122.95	-2935.17	25452.41	1207.43	
46R	X04A	4532.00	-13122.95	3106.44	-2935.17	1207.42	-25452.41	
47		12483.94	-6074.71	3596.91	-5035.30	5204.11	34264.04	
48L	X04B	13122.95	4531.99	4087.37	-8397.94	8585.76	35703.41	
48R	X04B	13122.95	-4087.37	4532.00	-8397.94	-35705.41	8585.75	
49L	X2	13122.95	-4425.62	4532.00	-8397.94	-30152.75	12726.45	
49R	X2	13122.95	4509.40	4532.00	-8397.94	-30152.73	12726.45	
50L	X05A	13122.95	4171.12	4532.00	-8397.94	-24601.54	8076.83	
50R	X05A	13122.95	-4531.99	4171.12	-8397.94	-8076.83	-24601.54	
51		12483.94	6074.71	3680.66	-5062.08	-4505.80	-26040.87	
52L	X05B	4532.00	13122.95	3190.20	-2995.97	1674.33	-44008.30	
52R	X05B	4532.00	3190.20	-13122.95	-2995.97	-44008.30	-1674.33	
53L	3	4532.00	2936.50	-13122.95	-2995.97	-56055.45	-4123.84	
53R	3	4532.00	2186.51	-13122.95	-2995.97	-56055.45	-6123.84	
54L	4	4532.00	2009.31	-13122.95	-2995.97	-85709.94	-8222.51	
54R	4	4532.00	-780.99	-13122.95	-2995.97	-85709.94	-8222.51	
55L	5	4532.00	-958.19	-13122.95	-2995.97	-115364.44	-6966.78	
55R	5	4532.00	-1708.19	-13122.95	-2995.97	-115364.44	-6966.78	
56L	A04A	4532.00	-2041.29	-13122.95	-2995.97	-131182.50	-5224.65	
56R	A04A	4532.00	-13122.95	2041.29	-2995.97	-5224.64	131182.50	

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

3

LOAD CASE NO. 3 (INORM), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN1  
(CONTD.)

	SOP	DCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	JX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
57			11327.65	-8027.15	2429.57	2684.87	-1989.63	146537.69
58L	A04B		13883.28	-4902.17	2817.86	2239.42	4467.11	152309.56
58R	A04B		13883.28	3653.15	7170.65	2239.42	-152109.56	4467.11
59L	6		13883.28	5320.15	7170.65	2239.42	-145670.56	-2704.66
59R	6		13883.28	2570.13	7170.65	2239.42	-145610.56	-2704.66
60L	7		13883.28	2392.83	7170.65	2239.42	-127474.75	-6901.18
60R	7		13883.28	-492.05	7170.65	2239.42	-127474.75	-5901.18
61	8		13883.28	-669.25	7170.65	2239.42	-111279.00	5743.31

RUN2

	SOP	DCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	JX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
62	6		13883.28	-1412.24	7170.65	2057.23	-105105.37	-5743.31
63			13883.28	-182.75	7170.65	2057.23	-95316.31	-3656.62
64	9		13883.28	-229.23	7170.65	2057.23	-85947.25	-1051.10
65			13883.28	-2848.70	7170.65	2057.23	-70135.00	4323.87
66L	10		13883.28	-3473.18	7170.65	2057.23	-54822.86	10336.89
66R	10		13883.28	5739.61	7170.65	2057.23	-54822.86	10336.89
67			13883.28	5426.55	7170.65	2057.23	-47146.84	5759.41
68	8A		13883.28	5113.50	7170.65	2057.23	-39470.55	1495.79
69L	68		13883.28	4801.27	7170.65	2057.23	-31814.74	-5952.06
69R	88		13883.28	4801.27	7170.65	2057.23	31814.74	5932.06
69R	88		14834.21	1680.70	6613.27	-1885.72	-35371.50	-913.33
			14834.21	1680.70	6613.27	-1885.72	35371.50	913.33
70	8C		14834.21	1368.46	6613.27	-1885.72	-28310.32	-2304.08
71			14834.20	761.22	6613.27	-1885.72	-14577.79	-4114.70
72			14834.20	155.98	6613.27	-1885.72	-845.17	-4744.37
73			14834.20	-584.46	6613.27	-1885.72	12887.44	-4193.08
74			14834.20	-1191.64	6613.27	-1885.72	26620.02	-2471.53
75	P5		14834.21	-1798.89	6613.27	-1885.72	40352.75	452.40
76L	P4		14834.21	-1981.02	6613.27	-1885.72	44471.52	1556.38
76R	P4		14834.21	1057.24	-5288.81	-1885.72	44471.52	1556.38
77			14834.20	543.80	-5288.80	-1885.72	34340.11	119.10
78			14834.20	30.34	-5288.80	-1885.72	24208.66	-569.16
79			14834.20	-511.76	-5288.80	-1885.72	14077.25	-110.01
80			14834.20	-1025.23	-5288.80	-1885.72	3945.80	1333.18
81	P3		14834.21	-1538.68	-5288.81	-1885.72	-6185.69	3284.64
82L	P2		14834.21	-1753.35	-5288.81	-1885.72	-10421.81	4814.66
82R	P2		0.00	214.68	0.00	0.00	0.00	80.50
83	P1		0.00	0.00	0.00	0.00	0.00	0.00

BRANCH AXES

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

3

LOAD CASE NO. 3 (NORM), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
-----------	---------	----------	------------------	--------------	--------------	-------------------	-------------------	-------------------

RUNS								
84	88	3127.53	-1079.62	-222.13	3556.78	5748.12	4666.87	
		950.92	3127.53	557.38	3942.95	3556.78	6266.87	BRANCH AXES
85	11	2995.67	-1079.62	-222.13	3556.78	5529.17	5757.68	
86		2741.34	-1079.62	-222.13	3556.78	5106.86	7803.04	
87		2487.00	-1079.62	-222.13	3556.78	4684.54	9868.42	
88	12	2232.67	-1079.62	-222.13	3556.78	4262.23	11933.80	
89L	13	2194.57	-1079.62	-222.13	3556.78	4026.06	13088.80	
89R	13	950.92	1994.57	-557.38	1583.22	3556.78	13688.32	
90	14	950.92	1956.47	-557.38	1583.22	2961.86	11652.52	
91		950.92	1694.42	-557.38	1583.21	1865.82	8178.19	
92		950.92	1432.37	-557.38	1583.21	900.41	5186.65	
93		950.92	1170.32	-557.38	1583.21	756.18	-2991.25	
94		950.92	908.27	-557.38	1583.21	-1534.63	-3123.17	
95		950.92	646.21	-557.38	1583.21	-2518.46	-2772.27	
96		950.92	-584.10	-557.38	1583.21	-3614.53	-1955.19	
97		950.92	-846.15	-557.38	1583.21	-4710.60	-2528.79	
98		950.92	-1108.20	-557.38	1583.21	-5806.67	-2623.42	
99L	B01A	950.92	-1370.26	-557.38	1583.22	-6902.75	3459.55	
99R	B01A	950.92	-557.38	-1706.59	1583.21	3459.55	6902.75	
100L	B01B	920.48	606.33	-1508.78	2823.95	-1671.07	6860.14	
100R	B01B	920.48	1508.78	606.34	2823.95	-6860.14	-1671.07	
101		920.48	1247.70	606.34	2823.95	-5667.54	-2947.13	
102		920.48	986.63	606.34	2823.95	-4474.93	-3743.97	
103		920.48	725.56	606.34	2823.95	-3282.32	-5001.73	
104		920.48	464.48	606.34	2823.95	-2089.71	-6093.23	
105		920.48	-439.65	606.34	2823.95	-897.10	-6705.52	
106		920.48	-700.73	606.34	2823.95	686.58	-6838.57	
107		920.48	-961.80	606.34	2823.95	1488.12	-6492.40	
108		920.48	-1222.88	606.34	2823.95	2680.73	-5667.00	
109		920.48	-1483.95	606.34	2823.95	3873.33	-4362.37	
110		920.48	-1745.03	606.34	2823.95	5065.45	7133.44	
111L	B02A	920.48	-2006.11	606.34	2823.95	6258.57	10649.67	
111R	B02A	920.48	-606.33	565.59	2823.96	-10649.67	6258.57	
112L	B02B	606.34	920.48	-340.96	10077.37	3396.25	5841.08	
112R	B02B	606.34	-340.96	-920.48	10077.37	5841.08	-3396.26	
113		606.34	-625.42	-920.48	10077.37	3873.67	-3748.22	
114L	B03A	606.34	-909.88	-920.48	10077.37	1906.26	-3531.26	
114R	B03A	606.33	3261.19	-920.48	10077.37	1906.27	-3531.26	
115L	B03B	-2981.93	606.33	-920.48	-905.22	8847.73	-5190.47	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

3

LOAD CASE NO. 3 (INORM), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUNS (CONTD.)</b>								
	115R	B03B	-2981.93	-1079.62	222.13	-905.23	-9926.52	-2586.07
	116		-2711.30	-1079.62	222.13	-905.23	-9477.14	-941.44
	117		-2440.67	-1079.62	222.13	-905.23	-9027.77	1809.36
	118		-2170.03	-1079.62	222.13	-905.23	-8578.39	4007.07
	119		-1899.40	-1079.62	222.13	-905.23	-8129.02	6204.79
	120		-1628.77	-1079.62	222.13	-905.23	-7679.84	-12.51
	121L	14S	-1358.14	-1079.62	222.13	-905.23	-7230.27	10600.24
	121R	14S	-1358.14	-1079.62	-361.76	-905.23	-7230.27	10600.24
	122		-1198.13	-1079.62	-361.76	-905.23	-7665.03	11899.62
	123L	B04A	1262.35	-1079.62	-361.76	-905.23	-8099.80	13199.00
	123R	B04A	1262.35	-1019.21	507.60	-905.23	3605.67	15060.52
	124L	B04B	1019.21	1541.61	507.60	-4284.97	-668.42	14491.22
	124R	B04B	1019.21	-1541.61	-507.60	-4284.97	688.42	-14491.22
	125		1019.21	-1824.38	-507.60	-4284.97	-1083.09	-10860.08
	126		1019.21	-2107.15	-507.60	-4284.97	-2163.51	-6666.77
	127		1019.21	-2389.91	-507.60	-4284.97	-3243.93	-2506.50
	128		1019.21	-2672.68	-507.60	-4284.97	-4324.35	3406.38
	129L	B05A	1019.21	-2955.45	-507.60	-4284.97	-5404.78	9286.24
	129R	B05A	1019.21	-507.60	2955.45	-4284.97	9286.24	5404.78
	130L	B05B	1079.62	361.76	3095.08	-10756.41	6337.19	5486.06
	130R	B05B	1079.62	-3095.08	361.76	-10756.41	-5486.06	6337.19
	131L	15S	1079.62	-3305.90	361.76	-10756.41	-4913.23	11295.68
	131R	15S	1079.62	-1293.89	361.76	-10756.41	-4913.23	11295.68
	132		1079.62	-1565.63	361.76	-10756.41	-4174.88	14288.12
	133		1079.62	-1837.37	361.76	-10756.41	-3456.52	17801.77
	134		1079.62	-2109.12	361.76	-10756.41	-2698.16	21834.60
	135		1079.62	-2380.86	361.76	-10756.41	-1959.80	26586.60
	136		1079.62	-2652.60	361.76	-10756.41	-1221.44	31457.77
	137L	B06A	1079.62	-2924.34	361.76	-10756.41	-483.07	37048.20
	137R	B06A	1079.62	4060.19	361.76	-10756.41	-483.06	57048.20
	138L	B06B	-3780.93	1079.62	361.76	-0.01	-10273.34	39703.76
	138R	B06B	-3780.93	-1079.62	-361.76	0.00	10273.34	-30703.76
	139		-3510.86	-1079.62	-361.76	0.00	9539.54	-28510.64
	140		-3240.80	-1079.62	-361.76	0.00	8805.73	-26317.53
	141		-2970.73	-1079.62	-361.76	0.00	8071.91	-24124.37
	142		-2700.66	-1079.62	-361.76	0.00	7338.11	-21931.25
	143		-2430.60	-1079.62	-361.76	0.00	6604.30	-19738.16
	144		-2160.53	-1079.62	-361.76	0.00	5870.48	-17545.04

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X058  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

**3 (NORTH), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)**

LOAD CASE NO.	SUP GROUP	DCP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUNS (CONTD.)</b>									
145				-1890.47	-1079.62	-361.76	0.00	5136.68	-15351.91
146				-1620.40	-1079.62	-361.76	0.00	4902.87	-13158.79
147				-1350.35	-1079.62	-361.76	0.00	3667.06	-10965.66
148				-1080.27	-1079.62	-361.76	0.00	2935.25	-8772.53
149				-810.20	-1079.62	-361.76	0.00	2201.44	-6279.41
150				-540.14	-1079.62	-361.76	0.00	1667.63	-4386.28
151				-270.07	-1079.62	-361.76	0.00	733.82	-2193.16
152	15			0.00	-1079.62	-361.76	0.00	0.00	0.00
<b>MERS</b>									
15	P4	PC	PC	0.00	-3312.26	11902.09	0.00	0.00	0.00
		PC	PC	0.00	-4722.75	11902.09	0.00	41657.29	14061.27
		PC	PC	0.00	-6996.75	11902.09	0.00	41657.29	14061.27
16	PL	PL	PL	0.00	-5689.42	11902.09	0.00	62114.59	23294.96
17	PB	PB	PB	-14834.21	4274.45	-5236.37	1746.57	25927.94	10051.02
		PB	PB	-14834.21	2765.21	-5236.37	1746.57	5791.57	-3149.30
18	PA	PA	PA	-14834.21	2270.28	5288.81	1746.57	5791.57	-3149.30
		PA	PA	-14836.21	1968.03	5288.81	1746.57	9758.18	-4754.23
19	P2			1200.00	0.00	0.00	0.00	0.00	0.00
		P2		1000.00	0.00	0.00	0.00	0.00	0.00
20	OP4	OP4	OP4	1000.00	0.00	0.00	0.00	0.00	0.00
		OP7	OP7	1000.00	0.00	0.00	0.00	0.00	0.00

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DLSI  
 16" SHUTDOWN COOLING LINE

4

LOAD CASE NO. 5 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP NMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	1		498.43	5826.17	3499.73	49751.70	19597.77	31899.86
2	2		498.43	5826.17	3499.73	49751.70	12920.72	21132.38
3	ZA		498.43	5826.17	3499.73	49751.70	8682.28	14355.04
4L	A01A		498.43	5826.17	3499.73	49751.70	7860.85	15042.93
4R	A01A		498.43	3562.85	5697.39	49751.70	10913.90	10585.97
5			2608.38	2562.40	5697.39	33221.44	33595.77	6773.46
6L	A01B		3562.85	498.43	5697.39	6167.30	39909.71	6646.50
6R	A01B		3562.85	498.43	5697.39	6167.29	39909.71	6646.50
7			3562.84	498.43	5697.39	6167.29	34666.36	5815.09
8			3562.84	498.43	5697.39	6167.29	31263.27	4991.50
9			3562.84	498.43	5697.39	6167.29	29484.01	4180.64
10L	A1A		3562.85	498.43	5697.39	6167.29	29966.00	3392.41
10R	A1A		3562.85	5697.39	498.43	6167.29	3392.41	29966.00
11			4766.61	4357.72	498.43	4278.97	5166.10	30496.93
12L	A1B		5826.16	3499.73	498.43	2155.69	5887.03	29624.17
12R	A1B		5826.17	498.43	3499.73	2155.69	29624.17	5887.03
13			5826.16	498.43	3499.73	2155.69	27193.21	4972.94
14			5826.16	498.43	3499.73	2155.69	26141.71	4067.99
15			5826.16	498.43	3499.73	2155.69	26457.20	3179.97
16			5826.16	498.43	3499.73	2155.69	27901.94	2328.42
17			5826.16	498.43	3499.73	2155.69	30195.88	1574.68
18			5826.16	498.43	3499.73	2155.69	33092.41	1139.75
19L	X01A		5826.17	498.43	3499.73	2155.69	37118.47	1364.95
19R	X01A		5826.16	3499.73	132.57	2155.69	1364.95	37118.47
20			5156.70	4046.19	132.57	1527.17	1913.11	39973.05
21L	X01B		3499.73	5826.16	132.57	1192.30	1918.34	38791.73
21R	X01B		3499.73	132.57	5826.17	1192.30	38791.73	1918.34
22			3499.73	132.57	5826.16	1192.30	35663.60	1707.79
23			3499.73	132.57	5826.16	1192.30	34039.94	1512.41
24			3499.73	132.57	5826.16	1192.30	34535.63	1534.55
25			3499.73	132.57	5826.16	1192.30	37208.20	1177.73
26			3499.73	132.57	5826.16	1192.30	41788.72	1050.60
27			3499.73	132.57	5826.16	1192.30	48514.88	965.77
28			3499.73	132.57	5826.16	1192.30	57238.45	936.50
29			3499.73	132.57	5826.16	1192.30	66937.56	969.67
30L	X02A		3499.73	132.57	5826.17	1192.30	77051.56	1060.63
30R	X02A		3499.73	5826.16	132.57	1192.30	1060.63	77051.56
31			5156.70	4046.19	132.57	1585.39	212.50	84836.50
32L	X02B		5826.16	3499.73	132.57	1208.89	1057.30	88063.25

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

4

LOAD CASE NO. 55 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1 (CONTD.)</b>								
32R	X02B	5826.17	132.57	3499.73	1208.89	88063.25	1057.30	
33L	X1	5826.17	132.57	3499.73	1208.89	88245.00	1009.79	
33R	X1	5826.17	76.86	58378.33	1208.89	88245.00	1009.79	
34L	X03A	5826.17	76.86	58378.33	1208.89	29927.41	938.40	
34R	X03A	5826.13	58378.30	76.86	1208.89	938.40	29927.41	
35		38165.62	45078.40	76.86	441.40	1329.17	68450.12	
36L	X03B	58378.30	5826.20	76.86	798.32	1060.76	105607.06	
36R	X03B	58378.33	76.86	5826.17	798.32	105607.06	1060.76	
37L	X01	58378.33	76.86	5826.17	798.32	107261.94	1023.87	
37R	X01	58378.33	76.86	11180.72	798.32	107261.94	1023.87	
38		58378.30	76.86	11180.72	798.32	87181.94	891.60	
39		58378.30	76.86	11180.72	798.32	67104.81	760.19	
40		58378.30	76.86	11180.72	798.32	47032.21	629.79	
41		58378.30	76.86	11180.72	798.32	26969.02	500.67	
42		58378.30	76.86	11180.72	798.32	7959.13	373.71	
43		58378.30	76.86	11180.72	798.32	19692.82	254.00	
44		58378.30	76.86	11180.72	798.32	39572.27	200.02	
45		58378.30	76.86	11180.72	798.32	59487.35	243.79	
46L	X04A	58378.33	76.86	11180.72	798.32	79411.37	527.75	
46R	X04A	58378.31	11180.66	76.86	798.32	527.75	79411.37	
47		49110.05	33452.91	76.86	830.30	282.89	60923.94	
48L	X04B	11180.74	58378.30	76.86	471.53	663.65	16875.58	
48R	X04B	11180.72	76.86	58378.33	471.53	16875.58	663.65	
49L	X2	11180.72	76.86	58378.33	471.53	78626.37	594.31	
49R	X2	11180.72	109.93	58378.33	471.53	78626.37	594.31	
50L	X05A	11180.72	109.93	58378.33	471.53	141823.12	649.79	
50R	X05A	11180.74	58378.30	109.93	471.53	649.79	141823.12	
51		49110.05	33452.89	109.93	824.76	254.18	217880.62	
52L	X05B	58378.31	11180.66	109.93	797.00	373.08	236429.62	
52R	X05B	58378.33	109.93	56989.62	797.00	236429.62	373.08	
53	3	58378.33	109.93	56989.62	797.00	190602.25	370.20	
54	4	58378.33	109.93	56989.62	797.00	80209.12	404.89	
55	5	58378.33	109.93	56989.62	797.00	51311.94	456.01	
56L	A04A	58378.33	109.93	56989.62	797.00	105008.56	487.84	
56R	A04A	58378.30	56989.57	109.93	797.00	487.84	105008.56	
57		80431.87	13782.11	109.93	668.57	912.77	149099.62	
58L	A04B	72576.75	37264.51	109.93	620.73	1045.77	137004.62	
58R	A04B	72576.75	941.11	8052.62	620.73	137004.62	1045.77	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

4

LOAD CASE NO. 200 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP HNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1 (CONTD.)</b>								
	59	6	72576.75	941.11	8052.62	620.73	128583.25	1322.32
	60	7	72576.75	941.11	8052.62	620.73	112864.37	2910.10
	61	8	72576.75	941.11	8052.62	620.73	97272.00	4552.84
<b>RUN2</b>								
	62	8	72576.75	941.11	8052.62	620.73	97272.00	4552.84
	63		72576.75	941.11	8052.61	620.73	87321.06	5615.46
	64	9	72576.75	941.11	8052.62	620.73	77482.94	6679.23
	65		72576.75	941.11	8052.61	620.73	62566.47	8330.89
	66L	10	72576.75	941.11	8052.62	620.73	48418.00	10180.16
	66R	10	72576.75	1561.00	8052.62	620.73	48418.00	10180.16
	67		72576.75	1561.00	8052.61	620.73	41861.15	8616.26
	68	8A	72576.75	1561.00	8052.62	620.73	35927.45	7952.87
	69L	8B	72576.75	1561.00	8052.62	620.73	30788.20	5494.50
			72576.69	1561.00	8052.62	620.73	30968.20	5494.50
	69R	8B	72699.12	1505.04	7926.71	577.22	31599.47	6489.79
			72699.12	1505.04	7926.70	577.22	31599.47	6489.79
	70	8C	72699.12	1505.04	7926.71	577.22	27263.51	4985.87
			72699.06	1505.04	7926.70	577.22	29629.62	2065.76
	72		72699.06	1505.04	7926.70	577.22	30729.19	954.72
	73		72699.06	1505.04	7926.70	577.22	41931.81	5834.83
	74		72699.06	1505.04	7926.70	577.22	55205.68	6730.32
	75	P5	72699.12	1505.04	7926.71	577.22	69570.75	9656.26
	76L	P4	72699.12	1505.04	7926.71	577.22	73717.06	10533.96
	76R	P4	72699.12	1345.60	9594.82	577.22	73717.06	10533.96
	77		72699.06	1345.59	9594.81	577.22	56508.66	8120.30
	78		72699.06	1345.59	9594.81	577.22	39302.80	5706.63
	79		72699.06	1345.59	9594.81	577.22	22104.05	5292.97
	80		72699.06	1345.59	9594.81	577.22	4989.05	879.37
	81	P3	72699.12	1345.60	9594.82	577.22	12394.25	1534.48
	82L	P2	72699.12	1345.60	9594.82	577.22	19572.32	2543.65
	82R	P2	0.00	0.00	0.00	0.00	0.00	0.00
	83	P1	0.00	0.00	0.00	0.00	0.00	0.00
<b>RUN3</b>								
	84	8B	63.14	155.23	106.02	3985.37	836.82	1240.01
			112.92	63.14	150.29	393.07	3985.37	1442.93
	85	11	63.14	155.23	106.02	3985.37	746.94	1147.14
							BRANCH AXES	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

4

LOAD CASE NO. 4 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XOX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN3 (CONTD.)</b>								
36			63.14	155.23	106.02	3985.37	591.25	1002.71
87			63.14	155.23	106.02	3985.37	459.20	921.51
88	12		63.14	155.23	106.02	3985.37	381.72	920.47
89L	13		63.14	155.23	106.02	3985.37	376.59	955.75
89R	13		139.35	63.14	126.14	92.49	3985.37	1020.52
90	14		139.35	63.14	126.14	92.49	3870.91	957.96
91			139.35	63.14	126.14	92.49	3662.02	842.91
92			139.35	63.14	126.14	92.49	3456.14	728.27
93			139.35	63.14	126.14	92.49	3253.83	614.27
94			139.35	63.14	126.14	92.49	3055.80	501.93
95			139.35	63.14	125.14	92.49	2862.94	392.64
96			139.35	63.14	126.14	92.49	2676.36	287.60
97			139.35	63.14	126.14	92.49	2497.46	193.99
98			139.35	63.14	126.14	92.49	2328.06	138.46
99L B01A			139.35	63.14	126.14	92.49	2170.32	167.23
99R B01A			139.35	126.14	46.58	92.49	167.23	2170.32
100L B01B			152.19	110.36	46.58	141.18	86.68	2043.01
100R B01B			152.19	46.58	110.36	141.18	2043.01	86.68
101			152.19	46.58	110.36	141.18	1896.33	799.69
102			152.19	46.58	110.36	141.18	1760.76	256.41
103			152.19	46.58	110.36	141.18	1639.08	306.17
104			152.19	46.58	110.36	141.18	1534.60	387.01
105			152.19	46.58	110.36	141.18	1451.03	468.36
106			152.19	46.58	110.36	141.18	1392.14	549.98
107			152.19	46.58	110.36	141.18	1361.14	631.78
108			152.19	46.58	110.36	141.18	1359.92	713.71
109			152.19	46.58	110.36	141.18	1388.58	795.91
110			152.19	46.58	110.36	141.18	1445.31	879.98
111L B02A			152.19	46.58	110.36	141.18	1527.00	965.19
111R B02A			152.19	110.36	177.53	141.18	965.19	1527.00
112L B02B			110.36	152.19	177.53	1085.21	165.00	1407.59
112R B02B			110.36	177.53	152.19	1085.21	1407.59	165.00
113			110.36	177.53	152.19	1085.21	1109.89	491.81
114L B03A			110.36	177.53	152.19	1085.21	817.28	841.10
114R B03A			110.36	93.45	152.19	1085.21	817.28	841.10
115L B03B			93.45	110.36	152.19	639.80	895.78	813.44
115R B03B			93.45	155.23	106.02	639.80	612.74	1043.07
116			93.45	155.23	106.02	639.80	425.38	749.13

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

4

LOAD CASE NO. ■■■ (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMG	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XO MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN3 (CONTD.)								
117		93.45	155.23	106.02	639.80	260.47	457.03	
118		93.45	155.23	106.02	639.80	190.14	176.29	
119		93.45	155.23	106.02	639.80	292.91	166.51	
120		93.45	155.23	106.02	639.80	465.63	445.97	
121L 14S		93.45	155.23	106.02	639.80	655.16	737.93	
121R 14S		93.45	155.23	28.30	639.80	655.16	737.93	
122		93.45	155.23	28.30	639.80	638.81	911.59	
123L B04A		93.45	155.23	28.30	639.80	623.65	1085.56	
123R B04A		93.45	129.73	89.83	639.80	1042.84	692.57	
124 B04B		129.73	93.45	89.83	1150.84	527.81	715.20	
125		129.73	93.45	89.83	1150.84	350.03	545.89	
126		129.73	93.45	89.83	1150.84	173.68	391.63	
127		129.73	93.45	89.83	1150.84	40.13	278.08	
128		129.73	93.45	89.83	1150.84	193.37	264.84	
129L B05A		129.73	93.45	89.83	1150.84	370.13	363.45	
129R B05A		129.73	89.83	93.45	1150.84	363.45	370.13	
130L B05B		155.23	28.30	93.45	787.73	924.99	401.76	
130R B05B		155.23	93.45	28.30	787.73	401.76	924.99	
131L 15S		155.23	93.45	28.30	787.73	359.81	925.88	
131R 15S		155.23	438.07	28.30	787.73	359.81	925.88	
132		155.23	438.07	28.30	787.73	305.74	567.55	
133		155.23	438.07	28.30	787.73	251.67	1090.48	
134		155.23	438.07	28.30	787.73	197.60	1859.41	
135		155.23	438.07	28.30	787.73	143.52	2669.57	
136		155.23	438.07	28.30	787.73	89.45	3492.40	
137L B06A		155.23	438.07	28.30	787.73	35.38	4320.66	
137R B06A		155.23	0.00	28.30	787.73	35.38	4320.66	
138 B06B		0.00	155.23	28.30	0.00	752.35	4126.62	
139		0.00	155.23	28.30	0.00	698.61	3831.86	
140		0.00	155.23	28.30	0.00	644.88	3537.10	
141		0.00	155.23	28.30	0.00	591.14	3242.35	
142		0.00	155.23	28.30	0.00	537.40	2947.59	
143		0.00	155.23	28.30	0.00	483.66	2652.83	
144		0.00	155.23	28.30	0.00	429.92	2358.07	
145		0.00	155.23	28.30	0.00	376.18	2063.31	
146		0.00	155.23	28.30	0.00	322.44	1768.56	
147		0.00	155.23	28.30	0.00	268.70	1473.80	
148		0.00	155.23	28.30	0.00	214.96	1179.04	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
LINE: SHUTDOWN COOLING LINE

七

LOAD CASE NO. 100 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

5

LOAD CASE NO. 5 (SSTI), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP HMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1								
	1	1	14476.73	23139.97	9975.21	89805.62	103069.50	120449.44
	2L	2	14476.73	23139.97	9975.21	89805.62	91841.75	75268.25
	2R	2	14383.50	23079.86	9690.14	89805.62	91841.75	75268.25
	3L	2A	14383.50	23079.86	9690.14	89805.62	86182.94	46428.70
	3R	2A	14283.15	23006.88	9348.11	89805.62	86182.94	46428.70
	4L	A01A	14283.15	23006.88	9348.11	89805.62	85237.81	40916.99
	4R	A01A	14114.28	16132.26	18428.73	89805.62	37460.57	86854.44
	5		15123.27	15123.27	18428.71	57535.57	45321.78	69459.25
	6L	A01B	16132.26	14114.28	18428.73	25265.42	53303.09	52064.07
	6R	A01B	14601.48	12793.14	17377.59	25265.42	53303.09	52064.07
	7		14601.48	12793.14	17377.58	25265.40	56493.13	48412.07
	8		14601.48	12793.14	17377.58	25265.40	59683.17	49760.07
	9		14601.48	12793.14	17377.58	25265.40	62873.24	41108.08
	10L	A1A	14601.48	12793.14	17377.59	25265.42	66063.31	37456.10
	10R	A1A	13470.26	15328.39	6214.83	25265.42	37456.10	66063.31
	11		15757.22	9558.12	6214.82	26499.80	43583.18	71277.75
	12L	A1B	18044.19	5787.86	6214.83	27734.17	49710.27	76492.19
	12R	A1B	14218.92	1948.86	6649.07	27734.17	76492.19	49710.27
	13		14218.92	1948.86	6649.07	27734.15	65210.27	48127.04
	14		14218.92	1948.86	6649.07	27734.15	53928.31	46543.83
	15		14218.92	1948.86	6649.07	27734.15	42646.39	44960.64
	16		8526.34	7842.21	8955.50	27734.15	35056.68	40832.71
	17		8526.34	7842.21	8955.50	27734.15	31159.30	34160.08
	18		8526.34	7842.21	8955.50	27734.15	27261.90	27487.45
	19L	X01A	8526.34	7842.21	8955.50	27734.17	23364.52	20814.81
	19R	X01A	4803.47	9565.14	7338.87	27734.17	20814.81	23364.52
	20		7184.30	7184.30	7338.87	25772.24	24214.80	35765.93
	21L	X01B	9565.14	4803.47	7338.87	23810.34	27614.83	48167.38
	21R	X01B	10514.11	5533.55	3086.03	23810.34	48167.38	27614.83
	22		10514.11	5533.55	3086.03	23810.32	46661.10	32801.88
	23		10514.11	5533.55	3086.03	23810.32	45154.85	37988.98
	24		10514.11	5533.55	3086.03	23810.32	43648.56	43176.09
	25		10514.11	5533.55	3086.03	23810.32	42142.30	48363.18
	26		13023.25	5383.76	7550.32	23810.32	40599.96	47515.71
	27		13023.25	5383.76	7550.32	23810.32	39021.55	40633.65
	28		13023.25	5383.76	7550.32	23810.32	37443.16	33751.61
	29		13023.25	5383.76	7550.32	23810.32	35864.75	26869.55
	30L	X02A	13023.25	5383.76	7550.32	23810.34	34286.36	19987.48
	30R	X02A	15268.90	8801.50	7816.04	23810.34	19987.48	34286.36

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

5

LOAD CASE NO. 86 (SSTI), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1 (CONTD.)</b>								
31		12035.20	12035.20	7816.04	21736.37	18310.28	32321.64	
32L	X02B	8801.50	15268.90	7816.04	19662.43	16633.07	30476.93	
32R	X02B	9216.23	8302.40	16058.97	19662.43	30476.93	16633.07	
33L	X1	9216.23	8302.40	16058.97	19662.43	30572.14	17910.31	
33R	X1	5451.91	9580.89	12310.24	19662.43	30572.14	17910.31	
34L	X03A	9451.91	9580.89	12310.24	19662.43	25321.33	15151.06	
34R	X03A	10006.35	11288.34	8992.00	19662.43	15151.06	23321.33	
35		10647.34	10647.34	8992.00	21769.51	18901.52	22746.68	
36L	X03B	11288.34	10006.35	8992.00	23876.63	22651.98	22172.08	
36R	X03B	10268.75	7523.29	10404.86	23876.63	22172.08	22651.98	
37L	XX1	10268.75	7523.29	10404.86	23876.63	23784.20	24715.37	
37R	XX1	7923.51	4424.92	3909.39	23876.63	23784.20	24715.37	
38		7923.51	4424.92	3909.39	23876.61	25546.87	29992.48	
39		7923.51	4424.92	3909.39	23876.61	27309.55	35269.59	
40		7923.51	4424.92	3909.39	23876.61	29072.23	40546.71	
41		7923.51	4424.92	3909.39	23876.61	30834.90	45823.84	
42		4202.17	6557.94	3272.45	23876.61	29535.67	43975.37	
43		4202.17	6557.94	3272.45	23876.61	25174.48	35001.18	
44		4202.17	6557.94	3272.45	23876.61	20813.29	26027.00	
45		4202.17	6557.94	3272.45	23876.61	16452.09	17052.84	
46L	X04A	4202.17	6557.94	3272.45	23876.63	12090.89	8078.64	
46R	X04A	3742.51	5415.54	9841.09	23876.63	8078.64	12090.89	
47		4579.02	4579.02	9841.09	23255.29	10827.38	10257.25	
48L	X04B	5415.54	3742.51	9841.09	22633.97	13576.12	8443.59	
48R	X04B	6052.61	10607.16	4527.67	22633.97	8443.59	13576.12	
49L	X2	6052.61	10607.16	4527.67	22633.97	6717.43	17953.18	
49R	X2	6399.01	11201.16	4955.91	22633.97	6717.43	17953.18	
50L	X05A	6399.01	11201.16	4955.91	22633.97	8255.48	17074.32	
50R	X05A	7103.60	5800.80	10273.14	22633.97	17074.32	8255.48	
51		6452.20	6452.20	10273.14	26571.22	22476.95	15411.91	
52L	X05B	5800.80	7103.60	10273.14	30108.50	27879.56	22568.34	
52R	X05B	6599.14	8978.69	9530.28	30108.50	22568.34	27879.56	
53L	3	6599.14	8978.69	9530.28	30108.50	20255.82	32325.73	
53R	3	8025.77	7462.82	8944.26	30108.50	20255.82	32325.73	
54L	4	8025.77	7462.82	8944.26	30108.50	29710.27	42659.18	
54R	4	12480.19	6873.66	8862.06	45453.43	24717.27	37832.51	
55L	5	12488.19	6873.66	8862.06	45453.43	36729.82	30599.64	
55R	5	14207.49	7753.96	8796.78	45453.43	36729.82	43059.64	

30" SED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 FINAL ROUTING 7 FROM DESI  
 15" SHUTDOWN COOLING LINE

5

TAD CASE NO. 000 (SSTT1). FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1 (CONTD.)</b>								
	56L	A04A	14207.49	7753.96	8796.78	45453.43	44601.38	46627.91
	56R	A04A	15167.33	8853.64	8353.59	45453.43	46627.91	44601.38
	57		12938.52	11454.41	8353.59	44695.21	51948.80	51662.56
	58L	A04B	10709.71	14055.17	8353.59	43937.04	59269.72	58723.76
	58R	A04B	11080.84	8845.09	17312.29	43937.04	58723.76	59269.72
	59L	6	11080.84	8845.09	17312.29	43937.04	40592.19	52872.44
	59R	6	11843.76	7635.52	16710.01	43937.04	40592.19	52872.44
	60L	7	11843.76	7635.52	16710.01	43937.04	11164.59	43164.09
	60R	7	14421.09	6251.83	12591.04	39407.55	11164.59	44658.61
	61	8	14421.09	6251.83	12591.04	39407.55	19372.64	34220.30
<b>RUN2</b>								
	62	8	15716.48	6837.81	10587.44	39407.55	19372.64	34220.30
	63		15716.48	6837.81	10587.44	39407.54	32319.44	27914.61
	64L	9	15716.48	6837.81	10587.44	39407.55	45266.32	21608.93
	64R	9	16835.05	7787.41	8679.99	39407.55	45266.32	21608.93
	65		16835.04	7787.41	8679.99	39407.54	61511.20	23740.60
	66L	10	16835.05	7787.41	8679.99	39407.55	77756.12	25872.30
	66R	10	17882.12	8000.38	7633.29	39407.55	77756.12	25872.30
	67		17882.11	8000.38	7633.29	39407.54	83799.37	26990.21
	68L	8A	17882.12	8000.38	7633.29	39407.55	89842.62	28108.16
	68R	8A	18414.55	7440.21	7742.21	39407.55	89842.62	28108.16
	69L	8B	18414.55	7440.21	7742.21	39407.55	95112.19	32374.50
	69R	8B	24401.30	5807.53	8270.49	42465.56	75042.12	51661.89
			24401.30	5807.53	8270.48	42465.56	75042.12	51661.89
	70L	8C	24401.30	5807.53	8270.49	42465.56	67347.37	46477.46
	70R	8C	25272.86	5623.82	10775.16	42465.56	67347.37	46477.46
	71		25272.84	5623.82	10775.16	42465.54	47822.88	36231.37
	72		24941.70	5473.11	10758.91	42758.47	28560.55	25425.74
	73		26455.73	6118.09	13893.18	42758.47	25920.98	18348.33
	74		26455.73	6118.09	13893.18	42758.47	39974.31	14132.14
	75L	P5	26455.75	6118.09	13893.18	42758.49	54027.71	9915.93
	75R	P5	27326.52	6677.64	14485.45	42758.49	54027.71	9915.93
	76L	P4	27326.52	6677.64	14485.45	42758.49	62237.09	13464.91
	76R	P4	29136.41	1589.97	7625.52	42758.49	62237.09	13464.91
	77		29136.40	1589.97	7625.52	42758.47	48643.48	10926.96
	78		29136.40	1589.97	7625.52	42758.47	35049.87	8589.01

BRANCH AXES

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB. X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

5

LOAD CASE NO. 20 (SSTI), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN2 (CONTD.)</b>								
	79		30528.12	2235.11	7828.01	42758.47	20186.10	6808.07
	80		30528.12	2235.11	7828.01	42758.47	16052.25	6184.16
	81L P3		30528.14	2235.11	7828.01	42758.49	7918.36	5560.26
	81R P3		31350.69	3365.83	8164.28	42758.49	7918.36	5560.26
	82L P2		31350.69	3365.83	8164.28	42758.49	13821.14	7868.08
	82R P2		144.81	192.05	164.85	0.00	123.64	144.04
	83	P1	144.81	192.05	164.85	0.00	0.00	0.00
<b>RUNS</b>								
	84	88	4332.17	14699.36	13999.48	67330.94	79429.56	79325.31
			9419.28	4332.17	17981.48	49715.91	67330.94	100647.31
	85L	11	4332.17	14699.36	13999.48	67330.94	66585.00	65827.94
	85R	11	3938.09	14655.89	13585.05	67330.94	66585.00	65827.94
	86		3938.09	14655.88	13585.05	67330.94	47560.41	49265.87
	87		3938.09	14655.88	13585.05	67330.94	28535.77	52705.78
	88L	12	3938.09	14655.89	13585.05	67330.94	9511.07	16141.63
	88R	12	3672.53	13815.71	11567.59	67330.94	9511.07	16141.63
	89L	13	3672.53	13815.71	11567.59	67330.94	19436.02	28699.95
	89R	13	13422.17	3561.93	10162.27	16071.89	67330.94	30752.16
	90L	14	13422.17	3561.93	10162.27	16071.89	59807.73	29002.93
	90R	14	12273.17	3342.33	8829.91	16071.89	59807.73	29002.93
	91		12273.17	3342.33	8829.91	16071.89	50042.75	27708.91
	92		12273.17	3342.33	8829.91	16071.89	40277.77	26414.88
	93		10235.81	2246.95	7745.10	16071.88	30512.76	25120.83
	94		10961.15	2402.49	7565.97	15313.01	32704.75	23269.14
	95		10961.15	2402.49	7565.97	15313.01	35068.55	21171.27
	96		9394.79	3938.04	7893.29	15313.01	37432.34	19073.40
	97		9394.79	3938.04	7893.29	15313.01	47266.79	17152.22
	98		9394.79	3938.04	7893.29	15313.01	57101.27	15251.04
	99L B01A		9394.79	3938.04	7893.29	15313.01	66935.75	13309.66
	99R B01A		8720.39	7227.84	5482.27	15313.01	13309.86	66935.75
	100L B01B		9392.87	6363.80	5482.27	6514.53	14904.27	69217.25
	100R B01B		8538.60	5058.59	5972.26	6514.53	69217.25	14904.27
	101		8538.60	5058.59	5972.26	6514.53	66093.25	19212.22
	102		8538.60	5058.59	5972.26	6514.53	62969.27	23520.16
	103		7803.77	5008.53	5371.25	5174.36	60801.68	26964.44
	104		6666.67	3101.89	4190.93	5174.36	58389.23	30261.6
	105		6666.67	3101.89	4190.93	5174.36	54704.33	32588.61

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

**5**  
 LOAD CASE NO. 205 (SSTI), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUNS (CONTD.)</b>								
106		7615.20	3186.49	4800.80	6514.53	49386.36	37079.55	
107		7615.20	3186.49	4800.80	6514.53	45796.55	39813.60	
108		7560.04	5542.40	6378.94	6514.53	44096.66	43184.86	
109		7560.04	5542.40	6378.94	6514.53	43341.72	46874.70	
110		7560.04	5542.40	6378.94	6514.53	42586.75	50564.52	
J11L B02A		7560.04	5542.40	6378.94	6514.53	41831.83	54254.40	
J11R B02A		7990.81	5774.50	7064.75	6514.53	54254.40	41831.83	
J12L B02R		5774.50	7990.81	7064.75	54336.80	7125.25	37336.04	
J12R B02S		5381.30	7151.07	8169.20	54336.80	37336.04	7125.25	
J13		5381.30	7151.07	8169.20	54336.78	32353.09	20430.39	
J14L B03A		5381.30	7151.07	8169.20	54336.80	27370.16	33735.52	
J14R B03A		5184.21	6702.09	7156.92	54336.80	27370.16	33735.52	
J15L B03B		6702.09	5184.21	7156.92	30842.66	48001.47	31298.95	
J15R B03B		6015.51	5036.70	6481.59	30842.68	42405.28	38562.59	
J16		6015.51	5036.70	6481.59	30842.65	32703.45	31447.04	
J17		6015.51	5036.70	6481.59	30842.65	23001.65	24331.54	
J18		5144.97	4676.67	7350.90	30842.65	13299.84	17216.03	
J19		5144.97	4676.67	7350.90	30842.65	21015.87	16976.08	
J20		5335.70	3393.64	7829.73	31041.43	30585.37	13631.53	
J21L 14S		5335.70	3393.64	7829.73	31041.45	39257.78	12712.13	
J21R 14S		4901.17	3527.90	4607.65	31041.45	39257.78	12712.13	
J22		4901.17	3527.90	4607.65	31041.47	38833.60	15093.66	
J23L B04A		4689.62	4383.02	4691.39	30842.68	35287.03	24372.68	
J23R B04A		4515.55	4775.57	3568.31	30842.68	30062.20	30588.69	
J24L B04B		4775.57	4515.55	3568.31	32069.80	28836.49	29020.77	
J24R B04B		4243.08	4359.24	2947.61	32069.80	28836.49	29020.77	
J25		4243.08	4359.24	2947.61	32069.79	27658.33	25963.81	
J26		4243.08	4359.24	2947.61	32069.79	26489.19	22906.84	
J27		3584.72	4465.46	2213.28	32069.79	26179.76	23303.81	
J28		3584.72	4465.46	2213.28	32069.79	26730.09	27154.68	
J29L B05A		3584.72	4465.46	2213.28	32069.80	27289.41	31005.60	
J29R B05A		3277.53	1683.46	4657.09	32069.80	31005.60	27289.41	
J30L B05B		2982.46	2138.27	4657.09	24580.53	40426.56	26713.77	
J30R B05B		2900.56	4758.81	2029.74	24580.53	26713.77	40426.56	
J31L 15S		2900.56	4758.81	2029.74	24580.53	24623.19	45598.33	
J31R 15S		2785.99	4666.98	2062.29	24580.53	24623.19	45598.33	
J32		2785.99	4666.98	2062.29	24580.51	21111.68	40918.64	
J33		2785.99	4666.98	2062.29	24580.51	17600.17	36239.00	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SHUB, X SHUB AT X058  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COPLING LINE

### 5 SSST1, FORCES AND MOMENTS IN LOCAL COORDINATES (CON)

LOAD CASE NO.	SOP	DCP	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	XX MOMENT (LB.FT.)	YY MOMENT (LB.FT.)	ZZ MOMENT (LB.FT.)
RUNS								
(CONT'D.)								
134			3010.85	4652.96	2133.36	24580.51	14088.66	31559.33
135			3010.85	4652.96	2133.36	24580.51	10131.68	32952.56
136			3010.85	4652.96	2133.36	24580.51	6174.69	34395.75
137L	B06A		3010.85	4652.96	2133.36	24580.53	2217.71	35739.00
137R	B06A		3396.91	6384.20	1774.16	24580.53	2217.71	35739.00
138L	B06B		6386.20	3396.91	1774.16	0.00	24204.79	33380.76
138R	B06B		5383.18	3732.60	2136.71	0.00	24204.79	33380.76
139			5383.18	3732.60	2136.71	0.00	32701.50	32701.50
140			5383.18	3732.60	2136.71	0.00	23665.61	32021.67
141			5383.18	3732.60	2136.71	0.00	23396.04	31394.43
142			3842.04	2400.16	1709.77	0.00	23409.08	31394.719
143			3842.04	2400.16	1709.77	0.00	23704.75	32036.20
144			3842.04	2400.16	1709.77	0.00	24000.59	32725.16
145			2303.98	1806.39	1296.31	0.00	35419.15	35419.15
146			2303.99	1806.39	1296.31	0.00	22256.04	30612.57
147			2303.99	1806.39	1296.31	0.00	20207.00	27811.00
148			2303.99	1806.39	1296.31	0.00	18163.69	25009.42
149			767.79	3552.40	2579.34	0.00	14963.04	20235.98
150			767.79	3552.40	2579.34	0.00	9795.04	13490.65
151			767.79	3552.40	2579.34	0.00	4397.68	6745.32
152	15		767.79	3552.40	2579.34	0.00	0.00	0.00
MPS								
15	P4	0.00	9910.29	23011.79	0.00	0.00	0.00	0.00
	PC	0.00	10074.50	23094.85	0.00	80832.00	35260.67	
16	PC	-1788.93	11662.69	23678.91	0.00	80832.00	35260.07	
	PB	1788.93	11662.69	23678.91	0.00	121461.37	55145.35	
17	PB	32691.19	7087.00	12101.50	42758.49	49976.39	23032.55	
	PA	32891.19	7087.00	12101.50	42758.49	7541.65	4784.30	
18	PA	31875.23	4144.77	89446.90	42758.49	7541.65	4784.30	
	P2	31875.23	4144.77	8946.90	42758.49	13760.96	7725.01	
19	4	2131.61	4032.01	2399.19	0.00	11995.94	29160.07	
	OP4	2131.60	4031.99	2399.19	0.00	11995.94	0.00	
20	7	1807.25	2020.43	4085.25	0.00	2042.63	10102.17	
	OP7	1807.25	2020.43	4085.25	0.00	0.00	0.00	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X-58  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

6

LOAD CASE NO. 2 (SET), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP HMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	1	14975.16	28966.12	13474.94	139557.31	122667.25	152349.31	
2L	2	14975.16	28966.12	13474.94	139557.31	104762.50	96400.62	
2R	2	14851.93	28906.02	13189.87	139557.31	104762.50	96400.62	
3L	2A	14881.93	28906.02	13189.87	139557.31	94865.19	60783.77	
3R	2A	14781.58	28833.04	12047.84	139557.31	94865.19	60783.11	
4L	A01A	14781.58	28833.04	12847.84	139557.31	93096.62	53961.90	
4R	A01A	14612.71	19695.10	24126.11	139557.31	48374.48	97640.64	
5		17731.64	17685.67	24126.10	90757.00	78975.50	76232.69	
6L	A01B	19695.10	14612.71	24126.11	31432.72	93212.75	58710.58	
6R	A01B	18164.32	13291.57	23074.98	31432.70	93212.75	58710.58	
7		18164.32	13291.57	23074.96	31432.68	91159.44	54227.16	
8		18164.32	13291.57	23074.96	31432.68	90946.44	49751.57	
9		18164.32	13291.57	23074.96	31432.68	92357.25	45288.72	
10L	A1A	18164.32	13291.57	23074.98	31432.70	96029.31	40848.50	
10R	A1A	17033.09	19025.77	6713.25	31432.70	40848.50	96029.31	
11		20523.83	13915.85	6713.25	30778.77	46749.27	101774.69	
12L	A1B	23870.35	9287.59	6713.25	29889.86	55597.30	106116.37	
12R	A1B	20045.07	2447.29	10148.79	29889.86	106116.37	55597.30	
13		20045.07	2447.29	10148.79	29889.83	92393.44	53099.96	
14		20045.07	2447.29	10148.79	29889.83	80079.00	50611.80	
15		20045.07	2447.29	10148.79	29889.83	69103.56	48140.59	
16		14352.51	8340.64	12455.23	29889.83	62958.62	43161.12	
17		14352.51	8340.64	12455.23	29889.83	61355.19	35734.75	
18		14352.51	8340.64	12455.23	29889.83	60354.32	28627.18	
19L	X01A	14352.51	8340.64	12455.23	29889.86	60483.00	22179.75	
19R	X01A	10629.64	13064.87	7471.45	29889.86	22179.75	60483.00	
20		12341.01	11230.49	7471.45	27299.40	26127.91	75738.94	
21L	X01B	13064.87	10629.64	7471.45	25002.65	29533.16	86959.06	
21R	X01B	14013.84	5666.12	8912.20	25002.65	86959.06	29533.16	
22		14013.84	5666.12	8912.19	25002.62	82324.69	34509.67	
23		14013.84	5666.12	8912.19	25002.62	79194.75	39501.39	
24		14013.84	5666.12	8912.19	25002.62	78184.19	44510.62	
25		14013.84	5666.12	8912.19	25002.62	79350.46	49540.90	
26		16522.96	5516.33	13376.48	25002.62	82388.62	48566.31	
27		16522.96	5516.33	13376.48	25002.62	87536.37	41599.41	
28		16522.96	5516.33	13376.48	25002.62	94681.56	34688.11	
29		16522.96	5516.33	13376.48	25002.62	102802.31	27839.21	
30L	X02A	16522.96	5516.33	13376.49	25002.65	111337.94	21048.12	
30R	X02A	18768.61	14527.67	7943.61	25002.65	21048.12	111537.94	

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DESI  
 16" SHUTDOWN COOLING LINE

## LOAD CASE NO. 30 (SSET), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP NAME	DCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XK MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b> <b>{CONTD.}</b>								
31		17191.89	16081.37	7948.61	23319.75	18522.78	117218.12	
32L	X02B	1467.67	16768.61	7948.61	20871.32	17690.37	116540.19	
32R	X02B	15042.39	8434.97	19558.70	20871.32	118816.19	17690.37	
33L	X1	15042.39	8434.97	19558.70	20871.32	118817.19	18920.10	
33R	X1	15278.09	9657.75	70688.56	20871.32	118817.19	18920.10	
34L	X03A	15278.09	9657.75	70688.56	20871.32	53248.75	16089.47	
34R	X03A	15832.48	69666.62	9068.86	20871.32	16089.47	53248.75	
35		48812.96	55725.74	9068.86	22210.90	23230.69	91196.81	
36L	X03B	69666.62	15832.55	9068.86	24674.93	23712.73	127779.15	
36R	X03B	68647.06	7600.15	16231.02	24674.93	127771.19	23712.73	
37L	X01	68647.06	7600.15	16231.02	24674.93	131046.19	25739.24	
37R	X01	66301.81	4501.78	15090.11	24674.93	11046.19	25739.24	
38		66301.75	4501.77	15090.11	24674.91	12728.81	50884.08	
39		66301.75	4501.77	15090.11	24674.91	94414.37	36029.79	
40		66301.75	4501.77	15090.11	24674.91	76104.44	41176.50	
41		66301.75	4501.77	15090.11	24674.91	57803.92	46324.49	
42		62580.46	6634.80	14453.17	24674.91	32494.80	44349.07	
43		62580.46	6634.80	14453.17	24674.91	44867.29	35251.17	
44		62580.46	6634.80	14453.17	24674.91	60385.55	26227.01	
45		62580.46	6634.80	14453.17	24674.91	75939.44	17296.63	
46L	X04A	62580.49	6634.80	14453.17	24674.93	91502.25	8406.39	
46R	X04A	62120.82	16596.19	9917.95	24674.93	80406.39	91502.25	
47		53689.06	38031.92	9917.95	24065.57	11110.27	71141.14	
48L	X04B	16596.27	62120.80	9917.95	23105.49	14239.78	25519.16	
48R	X04B	17233.32	10684.02	62905.99	23105.49	25319.16	14239.78	
49L	X2	17233.32	10684.02	62905.99	23105.49	85343.81	18547.48	
49R	X2	17579.73	11311.09	65334.23	23105.49	85343.81	18547.48	
50L	X05A	17579.73	11311.09	53334.23	23105.49	150078.62	17724.11	
50R	X05A	18284.33	64179.^9	10383.06	23105.49	1724.11	150078.62	
51		55562.24	39905.^9	10383.08	27195.96	22731.10	233292.50	
52L	X05B	64179.31	18284.25	10383.08	30905.50	2821.62	258997.94	
52R	X05B	64977.46	9088.62	66519.87	30.^5.50	258997.94	21252.62	
53L	3	64977.46	9088.62	66519.87	50	210858.06	32675.93	
53R	3	66404.06	7572.76	65933.87	50	210858.06	32695.93	
54L	4	66404.06	7572.76	65933.87	104919.37	43064.07		
54R	4	70866.50	6983.59	65851.69	46250.43	88041.75	38287.40	
55L	5	70866.50	6983.59	65851.69	46250.43	88041.75	93515.63	
55R	5	72585.81	7863.89	65786.37	46250.43	88041.75	47515.63	

ADVANCED LIGHT WATER REACTOR ~~\*\*\*~~ XI Z SNUB. X SMB AT X058  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

LOAD CASE NO. ~~BP~~ (SSET), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SCP MMB	DCP NAME	XAXIAL FORCE (LB)	YFORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
	56L	A04A	72585.81	7863.89	65786.37	46250.43	149610.00	47115.75
	56R	A04A	73545.62	65843.19	8463.52	46250.43	47115.75	149610.00
	57		93370.37	25236.51	8463.52	45363.77	53861.56	200762.19
	58L	A04B	83286.94	51319.67	8463.52	44557.77	60315.48	195728.37
	58R	A04B	83657.62	9786.21	25364.90	44557.77	195728.37	60315.48
	59L	6	83657.62	9786.21	25364.90	44557.77	169175.50	54194.75
	59R	6	84420.50	8576.62	24762.62	44557.77	169175.50	54194.75
	60L	7	84420.50	8576.62	24762.62	44557.77	124029.00	46074.18
	60R	7	86297.87	192.94	20643.66	40028.29	124029.00	47560.71
	61	8	86997.87	192.94	20643.66	40028.29	116694.69	38773.14
RUN2								
	62	8	88293.25	7778.93	18640.06	40028.29	116694.69	38773.14
	63		88293.25	7778.93	18640.06	40028.29	119640.50	33530.07
	64L	9	88293.25	7778.93	18640.06	40028.29	122749.25	28288.15
	64R	9	89411.81	8728.52	167.1.61	40028.29	122749.25	28288.15
	65		89411.81	8728.52	16732.61	40028.29	124077.62	32071.43
	66L	10	89411.81	8728.52	16732.61	40028.29	126174.12	36052.45
	66R	10	90458.87	9561.38	15685.91	40028.29	126174.12	36052.45
	67		90458.87	9561.38	15685.90	40028.29	125750.50	35606.47
	68L	8A	90458.87	9561.38	15685.91	40028.29	125770.06	35161.02
	68R	8A	90991.31	9001.21	15794.83	40028.29	125770.06	35161.02
	69L	8B	90991.31	9001.21	15794.83	40028.29	126100.37	37868.98
	69R	8B	90991.25	9001.21	15794.83	40028.28	126100.37	37868.98
	70L	8C	97100.44	7312.57	16197.19	43042.77	106641.56	58121.68
	70R	8C	97100.44	7312.57	16197.19	43042.77	94610.87	51465.32
	71		97972.00	7128.86	18701.86	43042.77	94610.87	51463.32
	72		97971.94	7128.86	18701.86	43042.75	72452.50	38297.12
	73		97640.61	6978.15	18685.61	43335.68	54289.74	26385.45
	74		99154.81	7623.12	21819.89	43335.68	67851.75	7185.15
	75L	P5	99154.87	7623.12	21819.89	43335.68	95179.94	20862.46
	75R	P5	100025.62	8182.68	22412.16	43335.70	123398.44	19572.21
	76L	P4	100025.62	8182.68	22412.16	43335.70	135954.19	23998.86
	76R	P4	101835.56	2935.57	17220.34	43335.70	135954.19	23998.86
	77		101835.59	2935.57	17220.32	43335.68	105152.51	19047.27
	78		101835.50	2935.57	17220.32	43335.68	74352.62	14095.64

BRANCH AXES  
BRANCH AXES

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNB, X SNB AT X95B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

LOAD CASE NO. 100 (SET1), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP NMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN2 (CONTD.)</b>								
	79	103227.19	3580.71	17422.82	43335.68	66290.14	10101.04	
	80	103227.19	3580.71	17422.82	43335.68	21041.30	7063.53	
	81L P5	103227.25	3580.71	17422.82	43335.70	20312.61	7094.73	
	81R P3	104049.81	6711.42	17759.09	43335.70	20312.61	7094.73	
	82L P2	104049.81	711.42	17759.09	43335.70	33593.46	10411.73	
	82R P2	144.81	192.05	164.85	0.00	123.64	144.0	
	83	P1	144.81	192.05	164.85	0.00	0.00	0.00
<b>RUN3</b>								
	84	58	1595.30	14854.60	14105.50	71316.31	80265.56	80565.31
			9532.20	4395.30	18131.78	50109.91	71316.31	102090.19
	85L	11	6775.37	14854.60	14105.50	71316.31	67333.94	66975.06
	85R	11	4001.22	14811.12	13691.07	71316.31	67333.94	66975.06
	86	4001.22	14811.12	13691.07	71316.31	48151.66	50268.58	
	87	4001.22	14811.12	13691.07	71316.31	28994.96	33625.27	
	88L	12	4001.22	14811.12	13691.07	71316.31	9892.79	17062.11
	88R	12	3735.66	13970.95	11673.61	71316.31	9892.79	17062.11
	89L	13	3735.66	13970.95	11673.61	71316.31	19812.61	29655.70
	89R	13	13561.52	3625.06	10288.41	16164.58	71316.31	31772.67
	90L	14	13561.52	3625.06	10288.41	16164.58	63678.62	29960.88
	90R	14	12412.52	3405.46	8956.04	16164.58	63678.62	29960.88
	C1		12412.52	3405.46	8956.04	16164.58	53704.76	28751.80
			12412.52	3405.46	8956.04	16164.58	43733.91	27143.15
			10375.16	2310.09	7871.24	16164.57	33766.59	25735.09
			11100.50	2465.63	7692.11	15405.50	35760.54	23771.06
	95	11100.50	2465.63	7692.11	15405.50	37937.48	21553.91	
	96	9534.14	4001.17	8019.42	15405.50	40106.69	19361.00	
	97	9534.14	4001.17	8019.42	15405.50	49764.27	173**.20	
	98	9534.14	4001.17	8019.42	15405.50	59429.31	151**.50	
	99L B01A	9534.14	4001.17	8019.42	15405.50	69106.06	13477.09	
	99R B01A	8859.74	7553.97	5528.85	15405.50	13477.09	69106.06	
	100L B01B	9545.06	6479.16	5528.85	6655.71	14990.95	71260.25	
	100R B01B	8670.79	5105.18	6082.62	6655.71	71260.25	14990.95	
	101	8690.79	5105.18	6082.62	6655.71	67989.56	19361.91	
	102	8690.79	5105.18	6082.62	6655.71	64730.01	23746.56	
	103	7955.96	5055.12	5481.61	5315.53	62440.76	27270.59	
	104	6818.86	3148.47	4301.28	5315.53	59923.82	30448.77	
	105	6818.86	3148.47	4301.28	5315.53	56155.34	33056.95	

BRANCH AXES

ADVANCED LIGHT WATER REACTOR PWR 2 1600, A SNUB AT X05B  
 OPTIONAL ROUTING 7 FROM DEG  
 "6" SHUTDOWN COOLING LINE

## LOAD CASE NO. 20 (SSET), FORCES AND MOMENTS IN LBS AND INCHES (CONT'D.)

RUN GROUP	SOP	DCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUNS (CONT'D.)</b>								
106			7767.39	3233.07	4911.16	6655.71	50778.49	37100.52
107			7767.39	3233.07	4911.16	6655.71	47157.68	46100.58
108			7712.23	5588.98	6489.30	6655.71	45456.59	43898.56
109			7712.23	5588.98	6489.30	6655.71	44730.29	47670.60
110			7712.23	5588.98	6489.30	6655.71	44032.87	51444.48
111L B02A			7712.23	5588.98	6489.30	6655.71	43358.83	55219.59
111R B02A			8143.00	5884.86	7242.27	6655.71	55219.59	3358.83
112L B02B			5884.86	8143.00	7242.27	55422.00	7290.26	48743.64
112R B02B			5491.66	7328.60	8321.39	55422.00	38743.64	7290.26
113			5491.66	7328.60	8321.39	55421.98	33462.98	20922.19
114L B03A			5491.66	7328.60	8321.39	55422.00	28187.44	34576.60
114R B03A			5294.57	6795.54	7309.11	55422.00	28187.44	34576.60
115L B03E			6795.54	5294.57	7309.11	31482.46	48897.24	32112.39
115R B03B			6108.96	5191.93	6587.60	31482.46	43018.01	39605.66
116			6108.96	5191.93	6587.60	31482.45	33128.83	32196.17
117			6108.96	5191.93	6587.60	31482.45	23262.11	24788.57
118			5238.42	4831.90	7456.91	31482.45	13489.98	17392.32
119			5238.42	4831.90	7456.91	31482.45	21308.78	17142.59
120			5429.15	3548.87	7935.75	31681.21	31050.99	14077.50
121L 14S			5429.15	3548.87	7935.75	31681.24	39912.93	13450.06
121R 14S			4994.62	3483.13	4635.95	31681.21	39912.93	13450.06
122			4994.62	3483.13	4635.95	31681.21	39472.39	16005.25
123L B04A			4783.07	4538.25	4719.69	31482.46	35910.67	25458.23
123R B04A			4609.01	4905.30	3658.14	31482.46	31105.02	31281.25
124L B04B			4905.30	4609.01	3658.14	33220.64	29364.30	29735.96
124R B04B			4372.81	4452.70	3037.44	33220.64	29364.30	29735.96
125			4372.81	4452.70	3037.44	33220.62	28008.34	26509.69
126			4372.81	4452.70	3037.44	33220.62	26653.85	23298.46
127			3714.45	4558.91	2303.11	33220.62	26210.88	23581.89
128			3714.45	4558.91	2303.11	33220.62	26923.45	27419.51
129L B05A			3714.45	4558.91	2303.11	33220.64	27659.53	31369.04
129R B05A			3407.26	1773.29	4750.55	33220.64	31369.04	27659.53
130L B05B			3137.69	2166.57	4750.55	25368.25	41351.55	27115.52
130R B05B			3055.80	4852.26	2058.04	25368.25	27115.52	41351.55
131L 15S			3055.80	4852.26	2058.04	25368.25	24982.99	46524.20
131R 15S			2941.22	5105.05	2090.59	25368.25	24982.99	46524.20
132			2941.22	5105.05	2090.59	25368.23	21417.42	41486.19
133			2941.22	5105.05	2090.59	25368.23	17851.84	37329.47

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

6

LOAD CASE NO. 60 (SSET), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XO MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN3 (CONTD.)								
134			3166.08	5091.03	2161.66	25368.23	14286.26	33418.72
135			3166.08	5091.03	2161.66	25368.23	10275.20	35622.11
136			3166.08	5091.03	2161.66	25368.23	6264.14	37838.14
137L B06A			3166.08	5091.03	2161.66	25368.25	2253.08	40059.66
137R B06A			3552.14	6384.20	1802.47	25368.25	2253.08	40059.66
138L B06B			6384.20	3552.14	1802.47	0.00	24957.13	37507.37
138R B06B			5383.18	3887.84	2165.01	0.00	24957.13	37507.37
139			5383.18	3887.83	2165.01	0.00	24633.81	36533.14
140			5383.18	3887.83	2165.01	0.00	24310.47	35558.96
141			5383.18	3887.83	2165.01	0.00	23987.16	34584.76
142			3842.04	2555.39	1738.07	0.00	23946.47	34294.76
143			3842.04	2555.39	1738.07	0.00	24188.37	34689.01
144			3842.04	2555.39	1738.07	0.00	24430.30	35083.23
145			2303.98	1961.62	1324.61	0.00	24672.20	35477.46
146			2303.99	1961.62	1324.61	0.00	22574.42	32381.12
147			2303.99	1961.62	1324.61	0.00	20476.65	29284.79
148			2303.99	1961.62	1324.61	0.00	18378.85	26188.46
149			767.79	3707.63	2607.64	0.00	14854.25	2110.26
150			767.79	3707.63	2607.64	0.00	9902.84	1400.17
151			767.79	3707.63	2607.64	0.00	4951.42	7040.09
152	15		767.79	3707.63	2607.64	0.00	0.00	0.00
MMBS								
15	P4		0.00	12760.75	40264.79	0.00	0.00	0.00
	PC		0.00	12924.77	40347.84	0.00	141217.44	45236.68
16	PC		1788.93	14513.15	40931.90	0.00	141217.44	45236.68
	PB		1788.93	14513.15	40931.90	0.00	211481.31	70021.31
17	PB		105590.31	8355.96	18744.36	43335.70	86698.44	29325.18
	PA		105590.31	8355.96	18744.36	43335.70	19935.89	6318.78
18	PA		104574.37	5490.36	18041.72	43335.70	19935.89	6318.78
	PZ		104574.37	5490.36	18041.72	43335.70	33333.27	10268.66
19	4		2131.61	4032.01	2399.19	0.00	1995.94	20160.07
	OP4		2131.60	4031.99	2399.19	0.00	0.00	0.00
20	7		1807.25	2020.43	4085.25	0.00	20426.23	10102.17
	OP7		1807.25	2020.43	4085.25	0.00	0.00	0.00

APPENDIX D

DIRECT VESSEL INJECTION

PRELIMINARY ROUTING AND LOADS ANALYSIS

## APPENDIX D

### DIRECT VESSEL INJECTION - PRELIMINARY ROUTING AND LOADS ANALYSIS

#### Purpose

This appendix reports the results of a preliminary stress analysis of a System 80+ Direct Vessel Injection (DVI) line in the Reactor Building to provide applicable forces and moments for the Leak-Before-Break (LBB) evaluation. The piping included in the model is represented in the isometric sketch that follows. The analysis model originates at the Reactor Vessel nozzle and terminates at the anchor on the inside face of the crane wall. Anchors are modelled at these locations. All applicable design conditions, loadings, codes, and regulatory requirements are defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 2.

The types of analysis results required for the LBE evaluation are shown on the following page. Other results in the detailed analysis include pipe displacements, stresses, support/restraint loads, and nozzle loads (anchor loads). Since the analysis is preliminary and design information is not available for allowable nozzle loads, it is not within the scope of the calculation to evaluate those loads.

A code compliance check is performed to verify that pipe stresses are within the ASME allowables for the pipe as modelled. As additional design information becomes available, it will be included in a final analysis.

#### Method

The piping is modelled as a three dimensional framework for analysis. Static analysis is performed by the Direct Stiffness Method and a simple Lumped Mass Idealization is used to determine mode shapes and frequencies for the dynamic analysis. This piping is analyzed using the SUPERPIPE computer program.

### References and Design Inputs


1. ASME Boiler and Pressure Vessel Code, Section III, 1989.
2. Draft Distribution Systems Design Guide.
3. ABB-CE Letter dated 4/21/92 to R.W. Bonsall enclosing Preliminary Thermal Movements and SSE Seismic Anchor Movements.
4. ABB-Impell memo dated 5/21/92 to ABB-CE, Attn: R.A. Matzie enclosing System 80+ N-411 Spectra and SAM.
5. System 80+ Safety Injection System Piping and Instrumentation Diagram.
6. System 80+ Nuclear Island Detailed Arrangement Drawings.

### Results

Forces and moments results for the load cases listed below are provided for the Leak-Before-Break evaluation shown in Appendix J.

1. Gravity - Fluid-filled
2. Thermal Expansion
3. Gravity + Thermal (Normal Operation)
4. Seismic Inertia - SSE
5. Seismic Anchor Movement - SSE
6. Seismic Inertia + Seismic Anchor Movement

## DVI Isometric



DVI ANALYSIS FOR DESI \*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06# DUE TO LBB CONCERNS \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 6/19/92

## STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	RVND		5.54	1212.35	-5.66	336.90	52.56	3592.16
2	N1		5.54	1199.30	-5.66	336.90	49.73	2989.25
3L	RVNA		5.54	925.15	-5.66	336.90	39.26	1021.97
3R	RVNA		5.54	-5.66	-925.15	336.90	1021.97	-39.26
4L	RVNB		7.92	-0.08	-779.82	-172.31	207.37	-36.29
4R	RVNB		7.92	779.82	-0.08	-172.31	36.29	207.37
5			7.92	493.85	-0.08	-172.31	36.13	-1022.90
6			7.92	207.88	-0.08	-172.31	35.98	-1700.72
7			7.92	-78.10	-0.08	-172.31	35.83	-1826.08
8			7.92	-366.07	-0.08	-172.31	35.67	-1398.98
9	C01A		7.92	-650.04	-0.08	-172.31	35.52	-419.41
10	C01B		940.70	7.92	-0.08	-35.42	-172.41	564.91
11			1160.69	7.92	-0.08	-35.42	-172.52	553.14
12			1380.67	7.92	-0.08	-35.42	-172.64	541.38
13	SN1		1600.66	7.92	-0.08	-35.42	-172.76	529.61
14L	C02A		1657.67	7.92	-0.08	-35.42	-172.78	527.63
14R	C02A		1637.67	-7.92	0.08	-35.42	172.78	-527.63
15L	C02B		7.92	1928.32	0.08	-172.88	-35.32	-2746.47
15R	C02B		7.92	-1928.32	-0.08	-172.88	35.32	2746.47
16L	H1		7.92	-1965.33	-0.08	-172.88	35.30	3233.18
16R	H1		7.92	2365.98	-0.08	-172.88	35.30	3233.18
17	SN2		7.92	2326.97	-0.08	-172.88	35.28	2646.81
18L	V1		7.92	2289.96	-0.08	-172.88	35.26	2069.69
18R	V1		7.92	1289.96	-0.08	-172.88	35.26	2069.69
19			7.92	1247.55	-0.08	-172.88	35.13	7.96
20L	V2		7.92	1205.14	-0.08	-172.88	35.00	-1984.85
20R	V2		7.92	205.14	-0.08	-172.88	35.00	-1984.85
21			7.92	-60.08	-0.08	-172.88	34.86	-2114.80
22			7.92	-325.30	-0.08	-172.88	34.71	-1769.56
23			7.92	-590.52	-0.08	-172.88	34.57	-949.14
24			7.92	-655.74	-0.08	-172.88	34.43	346.46
25			7.92	-1120.96	-0.08	-172.88	34.28	2117.25
26L	H2		7.92	-1386.18	-0.08	-172.88	34.14	4363.23
26R	H2		7.92	1487.73	-0.08	-172.88	34.14	4363.23
27			7.92	1200.93	-0.08	-172.88	33.99	1758.60
28			7.92	914.12	-0.08	-172.88	33.83	-290.35
29			7.92	627.31	-0.08	-172.88	33.68	-1783.62
30			7.92	340.51	-0.08	-172.88	33.52	-2721.20
31			7.92	53.70	-0.08	-172.88	33.37	-3103.09
32			7.92	-233.11	-0.08	-172.88	33.21	-2929.29

DVI ANALYSIS FOR DESI \*\*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERN \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1 (CONTD.)</b>								
33			7.92	-519.91	-0.08	-172.88	33.06	-2199.80
34L	C03A		7.92	-806.72	-0.08	-172.88	32.91	-914.61
34R	C03A		7.92	0.08	-806.72	-172.88	914.61	32.91
35L	C03B		-0.08	7.92	-1097.38	275.45	-1362.94	22.91
35R	C03B		-0.08	-1097.38	-7.92	275.45	22.91	1362.94
36L	H3		-0.08	-1134.36	-7.92	275.45	20.93	1641.91
36R	H3		-0.08	1263.91	-7.92	275.45	20.93	1641.91
37			-0.08	1000.24	-7.92	275.45	6.82	-374.58
38			-0.08	736.56	-7.92	275.45	-7.28	-1921.42
39			-0.08	472.88	-7.92	275.45	-21.38	-2998.58
40			-0.08	209.21	-7.92	275.45	-35.49	-3606.07
41			-0.08	-54.47	-7.92	275.45	-49.59	-3743.88
42			-0.08	-318.15	-7.92	275.45	-63.70	-3412.01
43			-0.08	-581.83	-7.92	275.45	-77.80	-2610.47
44L	C04A		-0.08	-845.51	-7.92	275.45	-91.91	-1339.25
44R	C04A		-0.08	-7.92	845.51	275.45	-1339.25	91.91
45L	C04B		7.92	-0.08	1136.16	100.71	1513.99	101.90
45R	C04B		7.92	-1136.16	-0.08	100.71	-101.90	1513.99
46L	H4		7.92	-1321.20	-0.08	100.71	-102.00	3049.84
46R	H4		7.92	1327.04	-0.08	100.71	-102.00	3049.84
47L	C05A		7.92	1142.00	-0.08	100.71	-102.10	1506.69
47R	C05A		7.92	-0.08	-1112.00	100.71	1506.69	102.10
48L	C05B		0.08	7.92	-851.34	-260.85	-1145.13	92.31
48R	C05B		0.08	851.34	7.92	-260.85	-92.31	-1145.13
49			0.08	587.67	7.92	-260.85	-78.20	-2426.75
50			0.08	323.99	7.92	-260.85	-64.10	-3238.69
51			0.08	60.31	7.92	-260.85	-49.99	-2580.97
52			0.08	-203.36	7.92	-260.85	-35.89	-3453.56
53			0.08	-467.04	7.92	-260.85	-21.78	-2856.49
54			0.08	-730.72	7.92	-260.85	-7.68	-1789.73
55			0.08	-994.39	7.92	-260.85	6.43	-253.30
56L	H5		0.08	-1258.07	7.92	-260.85	20.53	1752.81
56R	H5		0.08	736.50	7.92	-260.85	20.53	1752.81
57L	C06A		0.08	659.50	7.92	-260.85	22.51	1573.31
57R	C06A		0.08	-7.92	699.50	-260.85	-1573.31	22.51
58L	C06B		7.92	0.08	408.84	880.60	451.86	32.31
58R	C06B		7.92	408.84	-0.08	880.60	32.31	-431.86
59			7.92	134.37	-0.08	880.60	32.16	-935.46
60			7.92	-140.09	-0.08	880.60	32.01	-930.13

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90; SYSTEM: IBM-VM/MVS

PAGE 60  
0-20-92 16:45:34

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNS \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

STATIC ANALYSIS NO. 1 (GRAV), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONT'D.)								
61			7.52	-414.56	-0.08	880.60	31.86	-415.95
62	ANC1		7.92	-689.03	-0.03	880.60	31.72	607.17

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNS \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

## LOAD CASE NO. 2% (THMX), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP NMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	RVNO	2880.10	809.50	-1968.85	8882.34	-3079.83	13024.57	
2	H1	2880.10	809.50	-1968.85	8882.34	-3545.55	12727.48	
3L	RVNA	2880.10	809.50	-1968.85	8882.34	-7192.33	11627.02	
3R	RVNA	2880.10	-1968.85	-809.50	8882.34	11627.02	7192.33	
4L	RVNB	3428.72	644.35	-809.50	-3440.64	-397.11	7917.85	
4R	RVNB	3428.72	809.50	644.35	-3440.64	-7917.85	13082.54	
5		3428.72	809.50	644.35	-3440.64	-6600.92	12008.11	
6		3428.72	809.50	644.35	-3440.64	-5283.98	10933.68	
7		3428.72	809.50	644.35	-3440.64	-3967.05	9859.25	
8		3428.72	809.50	644.35	-3440.64	-2650.11	16094.63	
9	C0_1	3428.72	809.50	644.35	-3440.64	-1801.27	11602.02	
10L	C01b	-809.50	3428.72	644.35	1361.13	-2588.53	8043.11	
10R	C01B	-809.50	3428.72	644.35	1313.98	-2588.53	8043.11	
11		-809.50	3428.72	644.35	1313.98	-1575.47	2652.44	
12		-809.50	3428.72	644.35	1313.98	-562.41	-2738.23	
13	SN1	-809.50	3428.72	644.35	1313.98	450.65	-8128.91	
14L	C02A	-809.50	3428.72	644.35	1313.98	621.07	-9035.76	
14R	C02A	-809.50	-3428.72	-644.35	1313.98	-621.07	9035.76	
15L	C02B	3428.72	-809.50	-644.35	1473.19	889.10	12594.67	
15R	C02B	3428.72	809.50	644.35	1473.19	-889.10	-12594.67	
16	H1	3428.72	809.50	644.35	1473.19	-804.12	-12599.60	
17	SN2	3428.72	809.50	644.35	1473.19	-719.14	-12204.53	
18	V1	3428.72	809.50	644.35	1473.19	882.32	-12089.46	
19		3428.72	809.50	644.35	1473.19	1990.07	-10741.52	
20	V2	3428.72	809.50	644.35	1473.19	3097.82	-9473.59	
21		3428.72	809.50	644.35	1473.19	4319.17	-8075.61	
22		3428.72	809.50	644.35	1473.19	5540.53	-5000.09	
23		3428.72	809.50	644.35	1473.19	6761.90	-9962.02	
24		3428.72	809.50	644.35	1473.19	7983.26	-10923.95	
25		3428.72	809.50	644.35	1473.19	9204.62	-11885.89	
26L	H2	3428.72	809.50	644.35	1473.19	10425.99	-12847.82	
26R	H2	3428.72	-799.85	644.35	1473.19	10425.99	-12847.82	
27		3428.72	-799.85	644.35	1473.19	11746.76	-11281.51	
28		3428.72	-799.85	644.35	1473.19	13067.53	-9715.20	
29		3428.72	-799.85	644.35	1473.19	14388.31	-8148.87	
30		3428.72	-799.85	644.35	1473.19	15709.08	-6582.56	
31		3428.72	-799.85	644.35	1473.19	17029.86	-5016.24	
32		3428.72	-799.85	644.35	1473.19	18350.63	-3449.92	

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 3'-8" S OF C06\* DUE TO LBB CONCERNS \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

LOAD CASE NO. 2 ■ (THMX), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
33			3428.72	-799.85	644.35	1473.19	19671.41	-1883.60
34L C03A			3428.72	-799.85	644.35	1473.19	20992.20	-317.27
34R C03A			3428.72	-644.35	-799.85	1473.19	317.28	20992.20
35L C03B			644.35	3428.72	-799.85	693.25	1395.36	17310.06
35R C03B			644.35	-799.85	-3428.72	693.25	17310.06	-1395.36
36L H3			644.35	-799.85	-3428.72	693.25	16403.21	-1379.80
36R H3			644.35	-90.31	-3428.72	693.25	16403.21	-1379.80
37			644.35	-90.31	-3428.72	693.25	9941.96	-1209.62
38			644.35	-90.31	-3428.72	693.25	3480.67	-1039.44
39			644.35	-90.31	-3428.72	693.25	-2980.63	-869.25
40			644.35	-90.31	-3428.72	693.25	-9441.93	-699.07
41			644.35	-90.31	-3428.72	693.25	-15903.23	-528.89
42			644.35	-90.31	-3428.72	693.25	-22366.52	-358.70
43			644.35	-90.31	-3428.72	693.25	-28825.81	-210.81
44L C04A			644.35	-90.31	-3428.72	693.25	-35287.17	-286.57
44R C04A			644.36	-3428.72	90.31	693.25	-286.57	35287.17
45L C04B			3428.72	644.35	90.31	341.31	640.08	38969.30
45R C04B			3428.72	-90.31	644.35	341.31	-38969.30	640.08
46L H4			3428.72	-90.31	644.35	341.31	-38117.19	586.92
46R H4			3428.72	29.35	644.35	341.31	-38117.19	586.92
47L C05A			3428.72	29.35	644.35	341.31	-37265.08	549.84
47R C05A			3428.72	644.36	-29.35	341.31	549.84	37265.08
48L C05B			-644.35	3428.72	-29.35	-512.76	305.75	31878.71
48R C05B			-644.35	29.35	3428.72	-512.76	-31878.71	305.75
49			-644.35	29.35	3428.72	-512.76	-25417.42	255.08
50			-644.35	29.35	3428.72	-512.76	-18956.16	204.40
51			-644.35	29.35	3428.72	-512.76	-12494.87	153.73
52			-644.35	29.35	3428.72	-512.76	-6033.57	103.06
53			-644.35	29.35	3428.72	-512.76	1045.58	52.38
54			-644.35	29.35	3428.72	-512.76	6889.02	-31.62
55			-644.35	29.35	3428.72	-512.76	13350.32	-6.21
56L H5			-644.35	29.35	3428.72	-512.76	19811.67	-17.04
56R H5			-644.35	71.58	3428.72	-512.76	19811.67	-17.04
57L C06A			-644.35	71.58	3428.72	-512.76	20713.52	-118.13
57R C06A			-644.35	-3428.72	71.58	-512.76	138.13	20713.52
58L C06B			3428.72	-644.36	71.58	-228.57	-422.32	26104.86
58R C06B			3428.72	71.58	644.35	-228.57	26104.86	422.32

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90; SYSTEM: IBM-VM/MVS

PAGE 341  
8-20-92 16:45:34

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNs \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

LOAD CASE NO. 2 (THMX), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
59			3428.72	71.58	644.35	-228.57	27368.00	288.18
60			3428.72	71.58	644.35	-228.57	29632.75	154.03
61			3428.72	71.58	644.35	-228.57	29896.69	22.21
62	ANCL		3428.72	71.58	644.35	-228.57	31160.67	-114.26

DVI ANALYSIS FOR DESI \*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNS \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIIDDLE DATE: 8/19/92

## LOAD CASE NO. 2 (THMP), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP HMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	RVN0	2880.10	809.50	125.67	8882.34	0.00	13024.57	
2	NI	2880.10	809.50	125.67	8882.34	0.00	12727.46	
3L	RVNA	2880.10	809.50	125.67	8882.34	0.00	11627.02	
3R	RVNA	2880.10	125.67	737.54	8882.34	1162.02	7192.33	
4L	RVNB	3428.72	644.35	737.54	108.58	13977.11	7917.85	
4R	RVNB	3428.72	809.50	644.35	108.57	0.00	13082.54	
5		3428.72	809.50	644.35	108.57	0.00	12008.11	
6		3428.72	809.50	644.35	108.57	0.00	10933.68	
7		3428.72	809.50	644.35	108.57	0.00	9859.25	
8		3428.72	809.50	644.35	108.57	0.00	10094.65	
9	C01A	3428.72	809.50	644.35	108.57	0.00	11602.02	
10L	C01B	737.54	3428.72	644.35	1361.13	109.73	8043.11	
10R	C01B	737.54	3428.72	644.35	1313.98	109.73	8043.11	
11		737.54	3428.72	644.35	1313.98	111.10	2652.44	
12		737.54	3428.72	644.35	1313.98	112.47	1635.46	
13	SN1	737.54	3428.72	644.35	1313.98	450.65	1896.34	
14L	C02A	737.54	3428.72	644.35	1313.98	621.07	1940.23	
14R	C02A	737.54	176.80	0.00	1313.98	0.00	9035.76	
15L	C02B	3428.72	737.53	0.00	1473.19	889.10	12594.67	
15R	C02B	3428.72	809.50	644.35	1473.19	371.05	1154.95	
16	H1	3428.72	809.50	644.35	1473.19	541.48	954.00	
17	SN2	3428.72	809.50	644.35	1473.19	711.90	753.06	
18	V1	3428.72	809.50	644.35	1473.19	882.32	552.11	
19		3428.72	809.50	644.35	1473.19	1990.07	0.00	
20	V2	3428.72	809.50	644.35	1473.19	3097.82	0.00	
21		3428.72	809.50	644.35	1473.19	4319.17	0.00	
22		3428.72	809.50	644.35	1473.19	5540.53	0.00	
23		3428.72	809.50	644.35	1473.19	6761.90	0.00	
24		3428.72	809.50	644.35	1473.19	7983.26	0.00	
25		3428.72	809.50	644.35	1473.19	9204.62	0.00	
26L	H2	3428.72	809.50	644.35	1473.19	10425.99	0.00	
26R	H2	3428.72	0.00	644.35	1473.19	10425.99	0.00	
27		3428.72	0.00	644.35	1473.19	11746.76	0.00	
28		3428.72	0.00	644.35	1473.19	13067.53	0.00	
29		3428.72	0.00	644.35	1473.19	14388.31	0.00	
30		3428.72	0.00	644.35	1473.19	15709.08	0.00	
31		3428.72	0.00	644.35	1473.19	17029.86	0.00	
32		3428.72	0.00	644.35	1473.19	18350.63	0.00	

DVI ANALYSIS FOR DESI \*\*\*  
\*\*\* ANCHOR ADDED 6'-8" S OF C06\* DUE TO LBB CONCERN \*\*\*  
\*\*\* DIRECT VESSEL INJECTION SYSTEM \*\*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

*Z*

LOAD CASE NO. (THMP), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

RUN GROUP	SUP HNB	DCP NAME	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONT'D.)								
33	C03A	3428.72	0.00	644.35	1473.19	19671.41	0.00	0.00
34L	C03A	3428.72	0.00	644.35	1473.19	20992.20	0.00	0.00
35L	C03B	644.36	3428.72	0.00	693.25	317.28	17310.06	1395.36
36L	L03B	644.35	0.00	176.80	693.25	17310.06	729.84	16403.21
36L	H3	644.35	0.00	176.80	693.25	16403.21	0.00	0.00
37	H3	644.35	60.28	176.80	693.25	16403.21	0.00	0.00
38		644.35	80.58	176.80	693.25	3480.67	613.81	756.33
39		644.35	80.58	176.80	693.25	514.73	471.30	827.43
40		644.35	80.58	176.80	693.25	827.43	328.78	328.78
41		644.35	80.58	176.80	693.25	1160.13	106.21	106.21
42		644.35	80.58	176.80	693.25	1452.83	43.74	43.74
43	C04A	644.35	80.58	176.80	693.25	1765.53	0.00	0.00
44L	C04A	644.35	80.58	176.80	693.25	2078.23	0.00	0.00
44R	C04A	644.36	176.80	90.31	693.25	0.00	35287.17	35287.17
45L	C04B	3428.72	644.35	90.31	341.31	660.08	38969.30	38969.30
45R	C04B	3428.72	80.58	646.35	341.31	2298.83	640.08	586.92
46L	H4	3428.72	29.35	644.35	341.31	2299.98	586.92	586.92
46R	H4	3428.72	29.35	644.35	341.31	2301.13	549.84	549.84
47L	C05A	3428.72	644.36	5.50	341.31	549.84	37265.08	37265.08
47R	C05A	3428.72	0.00	3428.72	0.00	305.75	31878.71	31878.71
48L	C05B	0.00	3428.72	5.50	0.00	305.75	305.75	305.75
48R	C05B	0.00	29.35	3428.72	0.00	2082.85	1770.15	255.06
49		0.00	29.35	3428.72	0.00	1457.45	204.40	204.40
50		0.00	29.35	3428.72	0.00	1144.75	153.73	153.73
51		0.00	29.35	3428.72	0.00	832.05	102.06	102.06
52		0.00	29.35	3428.72	0.00	1045.58	52.38	52.38
53		0.00	29.35	3428.72	0.00	6889.02	1.71	1.71
54		0.00	29.35	3428.72	0.00	13350.32	0.00	0.00
55		0.00	29.35	3428.72	0.00	19811.67	0.00	0.00
56L	H5	0.00	71.58	3428.72	0.00	19811.67	0.00	0.00
56R	H5	0.00	71.58	3428.72	0.00	20718.52	0.00	0.00
57L	C06A	0.00	71.58	3428.72	0.00	138.13	20718.52	20718.52
57R	C06A	0.00	176.80	71.58	0.00	138.13	26104.96	26104.96
58L	C06B	3428.72	0.00	71.58	0.00	26104.96	472.32	472.32
58R	C06B	3428.72	71.58	0.00	0.00	0.00	0.00	0.00

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06# DUE TO LBB CONCERNS \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

2

LOAD CASE NO. 3 (THMP), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SCP HNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
59			3428.72	71.58	644.35	0.00	27368.80	288.18
60			3428.72	71.58	644.35	0.00	28632.75	154.03
61			3428.72	71.58	644.35	0.00	29396.69	22.21
62	ANC1		3428.72	71.58	644.35	0.00	31160.67	0.00

DV2 ANALYSIS FOR DESI \*\*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBS CONCERN \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

2. LOAD CASE NO. 4 (THRU), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN	SUP GROUP	BCP MBS	NAME	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	X0X MOMENT (LB.FT.)	Y0Y MOMENT (LB.FT.)	Z0Z MOMENT (LB.FT.)
<b>RUN1</b>									
1			RVN0	-124.36	-737.54	-1968.85	0.00	-3079.83	0.00
2		N1	-124.36	-737.54	-1968.85	0.00	-3545.55	0.00	
3L		RVNA	-124.36	-1968.85	0.00	-7192.33	0.00		
3R		RVNA	-124.36	-809.50	0.00	0.00	0.00	0.00	
4L		RVNB	-176.80	-809.50	-3440.64	0.00	0.00	0.00	
4R		RVNB	-176.80	-737.54	0.00	-3440.64	-7917.85	0.00	
5			-176.80	-737.54	0.00	-3440.64	-6600.92	0.00	
6			-176.80	-737.54	0.00	-3440.64	-5285.78	0.00	
7			-176.80	-737.54	0.00	-3440.64	-3967.05	0.00	
8			-176.80	-737.54	0.00	-3440.64	-2650.11	0.00	
9		C01A	-176.80	-737.54	0.00	-3440.64	-1801.27	0.00	
10		C01B	-809.50	-176.80	0.00	0.00	-2588.53	0.00	
11			-809.50	-176.80	0.00	0.00	-1575.47	0.00	
12			-809.50	-176.80	0.00	0.00	-562.41	-2738.25	
13		SN1	-809.50	-176.80	0.00	0.00	0.00	-8128.91	
14L		C02A	-809.50	-176.80	0.00	0.00	0.00	-9035.76	
14R		C02A	-809.50	-3420.72	-644.35	0.00	-621.07	-1940.23	
15L		C02B	-176.80	-809.50	-664.35	0.00	-371.06	-1154.95	
15R		C02B	-176.80	-737.54	0.00	0.00	-889.10	-12594.67	
16		H1	-176.80	-737.54	0.00	0.00	-804.12	-12399.60	
17		SH2	-176.80	-737.54	0.00	0.00	-719.14	-12204.53	
18		V1	-176.80	-737.54	0.00	0.00	-715.06	-12009.46	
19			-176.80	-737.54	0.00	0.00	-713.56	-10741.52	
20		V2	-176.80	-737.54	0.00	0.00	-712.06	-9473.59	
21			-176.80	-737.54	0.00	0.00	-716.41	-8075.61	
22			-176.80	-737.54	0.00	0.00	-708.76	-9000.09	
23			-176.80	-737.54	0.00	0.00	-707.19	-9962.02	
24			-176.80	-737.54	0.00	0.00	-705.45	-10923.95	
25			-176.80	-737.54	0.00	0.00	-703.80	-11885.89	
26L		H2	-176.80	-737.54	0.00	0.00	-702.15	-12847.82	
26R			-176.80	-799.85	0.00	0.00	-702.15	-12847.82	
27			-176.80	-799.85	0.00	0.00	-700.36	-11281.51	
28			-176.80	-799.85	0.00	0.00	-698.57	-9715.20	
29			-176.80	-799.85	0.00	0.00	-696.78	-8148.87	
30			-176.80	-799.85	0.00	0.00	-695.00	-6582.56	
31			-176.80	-799.85	0.00	0.00	-693.21	-5016.24	
32			-176.80	-799.85	0.00	0.00	-691.42	-3449.92	
33			-176.80	-799.85	0.00	0.00	-689.64	-1883.60	

DVI ANALYSIS FOR DESI \*\*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERN \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

2

LOAD CASE NO. 2 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SCP NAME	DCP (LB)	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
34L C03A	-176.80	-799.85	0.00	0.00	-687.85	-317.27		
34R C03A	-176.80	-644.35	-799.85	0.00	0.00	-687.85		
35L C03B	0.00	-176.80	-799.85	-42.86	-729.85	-467.26		
35R C03B	0.00	-799.85	-3428.72	-42.86	-467.26	-195.36		
56L H5	0.00	-799.85	-3428.72	-42.86	423.37	-1379.80		
56R .43	0.00	-90.31	-3428.72	-42.86	-423.37	-1379.80		
37	0.00	-90.31	-3428.72	-42.86	-110.67	-1209.62		
38	0.00	-90.31	-3428.72	-42.86	0.00	-1030.44		
39	0.00	-90.31	-3428.72	-42.86	-2980.62	-869.25		
40	0.00	-90.31	-3428.72	-42.86	-9441.93	-699.07		
41	0.00	-90.31	-3428.72	-42.86	-15903.23	-528.89		
42	0.00	-90.31	-3428.72	-42.86	-22364.52	-358.70		
43	0.00	-90.31	-3428.72	-42.86	-28825.81	-210.61		
44L C04A	0.00	-90.31	-3428.72	-42.86	-35287.17	-286.57		
44R C04A	0.00	-3428.72	-80.58	-42.86	-286.57	-2078.23		
45L C04B	-176.80	0.00	-80.58	-101.09	0.00	-2298.63		
45R C04B	-176.80	-90.31	0.00	-101.09	-38969.30	0.00		
46L H4	-176.80	-90.31	0.00	-101.09	-38117.19	0.00		
46R H4	-176.80	-5.50	0.00	-101.09	-38117.19	0.00		
47L C05A	-176.80	-5.50	0.00	-101.09	-37265.08	0.00		
47R C05A	-176.80	0.00	-29.35	-101.09	0.00	-2301.13		
48L C05B	-644.35	-176.80	-29.35	-512.76	-93.82	-2082.85		
48R C05B	-644.35	-5.50	-176.80	-512.76	-31878.71	-93.82		
49	-644.35	-5.50	-176.80	-512.76	-25417.42	-83.45		
50	-644.35	-5.50	-176.80	-512.76	-18956.16	-73.08		
51	-644.35	-5.50	-176.80	-512.76	-12494.87	-62.72		
52	-644.35	-5.50	-176.80	-512.76	-6033.57	-52.35		
53	-644.35	-5.50	-176.80	-512.76	0.00	-41.99		
54	-644.35	-5.50	-176.80	-512.76	0.00	-31.62		
55	-644.35	-5.50	-176.80	-512.76	-106.06	-67.21		
56L H5	-644.35	-5.50	-176.80	-512.76	-418.76	-120.04		
56R H5	-644.35	0.00	-176.80	-512.76	-418.76	-120.04		
57L C06A	-644.35	0.00	-176.80	-512.76	-462.65	-138.13		
57R C06A	-644.35	-3428.72	0.00	-512.76	0.00	-442.65		
58L C06B	-176.80	-644.36	0.00	-228.57	-422.32	-680.93		
58R C06B	-176.80	0.00	0.00	-228.57	-680.93	0.00		
59	-176.80	0.00	0.00	-228.57	-679.22	0.00		

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNS \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

2

LOAD CASE NO. 400 (THMN), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
	60		-176.80	0.00	0.00	-228.57	-677.51	0.00
	61		-176.80	0.00	0.00	-228.57	-675.80	-10.90
	62	ANC1	-176.80	0.00	0.00	-228.57	-674.09	-114.26

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNS \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

## LOAD CASE NO. 36 (NORM), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1		RVNO	2885.64	2021.86	-1974.50	9219.24	-3027.27	16616.73
2		N1	2885.64	2008.81	-1974.50	9219.24	-3495.82	15716.72
3L		RVNA	2885.64	1734.65	-1974.50	9219.24	-7153.07	12648.98
3R		RVNA	2885.64	-1974.50	-1734.65	9219.24	12648.99	7153.07
4L		RVNB	3436.64	644.27	-1589.32	-3612.95	14184.48	7881.56
4R		RVNB	3436.64	1589.32	644.27	-3612.95	-7881.56	13289.90
5			3436.64	1303.35	644.27	-3612.95	-6564.78	10985.21
6			3436.64	1017.38	644.27	-3612.95	-5248.00	9232.96
7			3436.64	-815.63	644.27	-3612.95	-3931.22	8033.18
8			3436.64	-1101.61	644.27	-3612.95	-2614.44	8695.66
9		C01A	3436.64	-1387.58	644.27	-3612.95	-1765.75	11182.61
10L		C01B	1678.24	3436.64	644.27	1325.72	-2760.93	8608.02
10R		C01B	1678.23	3436.64	644.27	1278.56	-2760.93	8608.02
11			1898.22	3436.64	644.27	1278.56	-1747.99	3205.58
12			2118.21	3436.64	644.27	1278.56	-735.05	-2196.86
13		SN1	"138.19	3436.64	644.27	1278.56	277.89	-7599.30
14L		C02A	~ 75.20	3436.64	644.27	1278.56	448.29	-8508.13
14R		C02A	2 75.20	-3436.64	-644.27	1278.56	-448.29	8508.13
15L		C02B	3436.64	2665.85	-644.27	1300.31	853.78	9848.20
15R		C02B	3436.64	-2665.86	644.27	1300.31	-853.78	-9848.20
16L		H1	3436.64	-2702.86	644.27	1300.31	-768.82	-9166.42
16R		H1	3436.64	3173.48	644.27	1300.31	-768.82	-9166.42
17		SN2	3436.64	3136.47	644.27	1300.31	747.18	-9557.72
18L		V1	3436.64	3099.46	644.27	1300.31	917.58	-9939.77
18R		V1	3436.64	2099.46	644.27	1300.31	917.58	-9939.77
19			3436.64	2057.05	644.27	1300.30	2025.20	-10733.56
20L		V2	3436.64	2014.64	644.27	1300.31	3132.82	-11458.43
20R		V2	3436.64	1014.64	644.27	1300.31	3132.82	-11458.43
21			3436.64	-797.61	644.27	1300.30	4354.03	-10190.40
22			3436.64	-1062.83	644.27	1300.30	5575.25	-10759.65
23			3436.64	-1328.05	644.27	1300.30	6796.47	-10911.16
24			3436.64	-1593.27	644.27	1300.30	8017.69	-10577.49
25			3436.64	-1858.49	644.27	1300.30	9238.91	-9768.64
26L		H2	3436.64	-2123.71	644.27	1300.31	10 <sup>6</sup> 0.13	-8484.59
26R		H2	3436.64	1487.73	644.27	1300.31	10460.13	-8484.59
27			3436.64	1200.93	644.27	1300.30	11780.74	-9522.91
28			3436.64	914.12	644.27	1300.30	13101.37	-10005.54
29			3436.64	627.31	644.27	1300.30	14421.98	-9932.50

DVI ANALYSIS FOR DESI \*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCEPNS \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

3

LOAD CASE NO. 35 (NORM), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP M#	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
30		3436.64	-459.35	644.27	1300.30	15742.61	-9303.75	
31		3436.64	-746.15	644.27	1300.30	17063.23	-8119.32	
32		3436.64	-1032.96	644.27	1300.30	18383.85	-6379.21	
33		3436.64	-1319.77	644.27	1300.30	19704.47	-4083.40	
34L C03A		3436.64	-1606.57	644.27	1300.31	21025.10	-1251.89	
34R C03A		3436.64	-644.27	-1606.57	1300.30	1231.89	21025.10	
35L C03B		644.28	3436.64	-1897.23	968.70	-2092.78	17332.97	
35R C03B		644.27	-1897.23	-3436.64	968.70	17332.97	2092.78	
36L H3		644.27	-1934.53	-3436.64	968.70	16424.14	2540.76	
36R H3		644.27	1344.49	-3436.64	968.70	16424.14	2540.76	
37		644.27	1080.82	-3436.64	968.70	9948.79	-1584.20	
38		644.27	817.14	-3436.64	968.70	3473.39	-2960.85	
39		644.27	553.46	-3436.64	968.70	-3002.02	-3867.63	
40		644.27	289.79	-3436.64	968.70	-9477.42	-4305.13	
41		644.27	-144.78	-3436.64	968.70	-15952.82	-4272.76	
42		644.27	-408.46	-3436.64	968.70	-22428.20	-3770.71	
43		644.27	-672.13	-3436.64	968.70	-28903.61	-2821.28	
44L C04A		644.27	-935.81	-3436.64	968.70	-35379.37	-1625.82	
44R C04A		644.28	-3436.64	935.81	968.70	-1625.82	35379.07	
45L C04B		3436.64	644.27	1226.47	442.02	2154.07	39071.19	
45R C04B		3436.64	-1226.47	644.27	442.02	-59071.19	2154.07	
46L H4		3436.64	-1411.50	644.27	442.02	-38219.18	3636.75	
46R H4		3436.64	1356.38	644.27	442.02	-38219.18	3636.75	
47L C05A		3436.64	1171.35	644.27	442.02	-57367.17	2054.52	
47R C05A		3436.64	644.28	-1171.35	442.02	2056.52	37367.17	
48L C05B		-644.27	3436.64	-880.69	-773.61	-1238.95	31971.01	
48R C05B		-644.27	880.69	3436.64	-773.61	-31971.01	-1238.95	
49		-644.27	617.02	3436.64	-773.61	-25495.61	-2510.19	
50		-644.27	353.34	3436.64	-773.61	-19020.26	-3311.78	
51		-644.27	89.56	3436.64	-773.61	-12544.86	-3643.68	
52		-644.27	-208.86	3436.64	-773.61	-6069.46	-3505.91	
53		-644.27	-472.54	3436.64	-773.61	1025.80	-2898.47	
54		-644.27	-736.22	3436.64	-773.61	6881.34	-1821.35	
55		-644.27	-999.90	3436.64	-773.61	13356.75	-320.51	
56L H5		-644.27	-1263.57	3436.64	-773.61	19832.26	1752.81	
56R H5		-644.27	808.09	3436.64	-773.61	19832.26	1752.81	
57L C06A		-644.27	771.08	3436.64	-773.61	2071.02	1573.31	

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNs \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

3

LOAD CASE NO. 30 (NORM), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP MMB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONTD.)								
	57R C06A		-644.27	-3436.64	771.08	-773.60	-1573.31	20741.02
	58L C06B		3436.64	-644.28	480.42	880.60	431.86	26137.15
	58R C06B		3436.64	480.42	644.27	880.60	26137.15	-431.86
59			3436.64	205.95	644.27	880.60	27400.94	-935.46
60			3436.64	-140.09	644.27	880.60	28664.76	-930.16
61			3436.64	-414.56	644.27	880.60	29928.55	-426.85
62	ANC1		3436.64	-689.03	644.27	880.60	31192.36	607.17

DVI ANALYSIS FOR DESI \*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06# DUE TO LBB CONCERNs \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

## 4

LOAD CASE NO. 4 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP	DCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XO MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	RVN0		9473.87	5551.01	9359.57	12474.87	30836.29	25838.46
2	N1		9473.87	5551.01	9359.57	12474.87	27064.13	23162.21
3L	RVNA		9473.87	5551.01	9359.57	12474.87	17467.59	13600.41
3R	RVNA		9473.87	9359.56	5551.01	12474.87	13600.41	17467.59
4L	RVNB		13158.86	2043.99	5551.01	8297.20	11758.27	16091.86
4R	RVNB		13158.87	5551.01	2044.00	8297.20	16091.86	11758.27
5			13158.86	5551.01	2043.99	8297.20	12245.34	3755.31
6			13158.86	5551.01	2043.99	8297.20	8492.98	11336.90
7			13158.86	5551.01	2043.99	8297.20	5048.52	21630.03
8			13158.86	5551.01	2043.99	8297.20	3164.68	32204.45
9L	C01A		13158.87	.551.01	2044.00	82.7.20	5078.76	42853.44
9R	C01A		13158.87	.551.00	2044.00	8297.20	5076.75	42853.44
10L	C01B		5551.02	13158.86	2044.00	7253.04	5755.80	33323.00
10R	C01B		5551.01	13158.87	2044.00	7253.04	5755.80	33323.00
11			5551.01	13158.86	2043.99	7253.04	2767.01	13812.68
12			5551.01	13158.86	2043.99	7253.04	794.65	5999.89
13L	SN1		5551.01	13158.87	2044.00	7253.04	3475.08	25417.09
13R	SN1		5551.01	13158.87	507.14	7253.04	3475.08	25417.09
14L	C02A		5551.01	13158.87	507.14	7253.04	3408.98	28701.99
14R	C02A		5551.02	13158.86	507.14	7253.04	3408.98	28701.99
15L	C02B		13158.87	.5551.00	507.14	3135.25	6797.40	38280.26
15R	C02B		13158.87	.5551.01	507.14	3135.25	6797.39	38283.28
16	H1		13158.87	.5551.01	507.14	3135.25	6709.75	36912.62
17L	SN2		13158.87	.5551.01	507.14	3135.25	6623.38	35546.51
17R	SN2		13158.87	3012.32	507.14	3135.25	6623.38	35546.51
18	V1		13158.87	3012.32	507.14	3135.25	6538.33	34793.44
19			13158.86	3012.32	507.14	3135.25	6021.55	29898.44
20	V2		13158.87	3012.32	507.14	3135.25	5579.48	25003.44
21			13158.86	3012.32	507.14	3135.25	5201.55	19606.45
22			13158.86	3012.32	507.14	3135.25	4963.76	14209.46
23			13158.86	3012.32	507.14	3135.25	4886.36	8812.62
24			13158.86	3012.32	507.14	3135.25	4976.58	5416.54
25			13158.86	3012.32	507.14	3135.25	5224.79	1984.99
26L	H2		13158.87	3012.32	507.14	3135.25	5610.46	7380.04
26R	H2		13158.87	467.32	507.14	3135.25	5610.46	7380.04
27			13158.86	467.32	507.14	3135.25	6152.06	6475.04
28			13158.86	467.32	507.14	3135.25	6792.99	5570.18
29			13158.86	467.32	507.14	3135.25	7507.99	4665.55

DVI ANALYSIS FOR DESI \*\*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBS CONCERNS \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

A

## LOAD CASE NO. 4 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

RUN GROUP	SOP NBS	DCP NAME	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONT'D.)								
30		13158	86	467.32	507.14	3135.25	8277.97	3761.31
31		13158	86	467.32	507.14	3135.25	9085.00	2857.82
32		13158	86	467.32	507.14	3135.25	9931.97	1956.14
33		13158	86	467.32	507.14	3135.25	10796.91	1060.88
34L	C03A	13158	87	467.32	507.14	3135.25	11681.26	252.79
34R	C03A	13158	87	507.14	967.32	3135.25	252.79	11681.26
35L	C03B	13158	86	467.32	467.32	499.40	3228.00	4191.35
35R	C03B	13158	86	467.32	13158.87	499.40	4191.35	3228.00
36L	H3	507	14	967.32	13158.87	499.40	7480.24	3258.87
36R	H3	507	14	232.84	503.62	499.40	7480.24	3256.87
37		507	14	232.84	503.62	499.40	6585.97	2844.68
38		507	14	232.84	503.62	499.40	5692.58	2430.67
39		507	14	232.84	503.62	499.40	4800.55	2026.96
40		507	14	232.84	503.62	499.40	3910.85	1603.79
41		507	14	232.84	503.62	499.40	3025.54	1191.70
42		507	14	232.84	503.62	499.40	2149.90	782.42
43		507	14	232.84	503.62	499.40	1303.80	385.02
44L	C04A	507	14	232.84	503.62	499.40	621.56	137.92
44R	C04A	507	14	503.62	232.84	499.40	167.92	621.56
45L	C04B	503	62	507.14	232.84	386.62	361.18	931.64
45R	C04B	503	62	232.84	507.14	386.62	931.64	361.18
46L	H4	503	62	232.84	507.14	386.62	1453.47	425.71
46R	H4	503	62	27.99	507.14	386.62	1453.47	425.71
47L	C05A	503	62	27.99	507.14	386.62	2039.85	428.54
47R	C05A	503	62	507.14	27.99	386.62	428.54	2039.85
48L	C05B	507	14	503.62	27.99	434.17	351.92	2046.84
48R	C05B	507	14	27.99	503.62	434.17	2046.84	351.92
49		507	14	27.99	503.62	434.17	1238.97	302.58
50		507	14	27.99	503.62	434.17	698.95	253.45
51		507	14	27.99	503.62	434.17	1026.60	204.66
52		507	14	27.99	503.62	434.17	1796.96	155.56
53		507	14	27.99	503.62	434.17	2668.23	110.02
54		507	14	27.99	503.62	434.17	3522.29	68.34
55		507	14	27.99	503.62	434.17	4405.61	47.93
56L	H5	507	14	27.99	503.62	434.17	5293.56	68.65
56R	H5	507	14	66.20	503.62	434.17	5293.56	68.65
57L	C06A	507	14	66.20	503.62	434.17	5418.43	77.79

DVI ANALYSIS FOR DESI \*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBS CONCERNS \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

A

## LOAD CASE NO. 1 (SSST), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

RUN GROUP	SOP MBS	DCP NAME	AXIAL FORCE (LB.)	Y FORCE (LB.)	Z FORCE (LB.)	<sup>XX</sup> MOMENT (LB.FT)	<sup>YY</sup> MOMENT (LB.FT)	<sup>ZZ</sup> MOMENT (LB.FT)
(RUN1 (CONT'D.))								
	57R	C06A	507.14	503.62	66.20	439.17	77.79	5418.43
	58L	C06B	503.62	501.14	66.20	144.81	351.63	5541.99
	58R	C06B	503.62	66.20	507.14	144.81	5541.99	351.63
59			503.62	66.20	507.14	144.81	4855.55	229.48
60			503.62	66.20	507.14	144.81	4266.70	108.68
61			503.62	66.20	507.14	144.81	3820.50	33.06
62		ANC1	503.62	66.20	507.14	144.81	3570.61	143.19

DVI ANALYSIS FOR DESI \*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNS \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

5

## LOAD CASE NO. 5 (SSTI), FORCES AND MOMENTS IN LOCAL COORDINATES

RUN GROUP	SOP MNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1</b>								
1	RVND	6470.34	3190.72	3803.59	9533.27	19278.79	10738.13	
2L	N1	6470.34	3190.72	3803.59	9533.27	17839.19	9431.60	
2R	N1	6390.04	3001.59	3686.26	9533.27	17839.19	9431.60	
3L	RVNA	6390.04	3001.74	3686.26	9533.27	13540.73	6076.87	
3R	RVNA	6282.93	3511.61	2730.18	9533.27	6076.87	15540.73	
4L	RVNB	5885.50	4135.91	2730.18	9904.99	3929.50	11175.97	
4R	RVNB	5600.52	2260.28	3983.41	9904.99	11175.97	3929.50	
5		5600.52	2260.28	3983.41	9904.99	12342.49	5290.43	
6		5600.52	2260.28	3983.41	9904.99	13509.00	6651.36	
7		5228.81	2170.46	3461.56	9904.99	17305.45	8975.59	
8		5228.81	2170.46	3461.56	9904.99	23731.86	12262.84	
9L	C01A	5228.81	2170.46	3461.56	9904.99	30158.27	15550.19	
9R	C01A	5057.18	3003.24	3502.20	9904.99	30158.27	15550.19	
10L	C01B	3003.24	5057.18	3502.20	34235.01	7645.61	12114.04	
10R	C01B	4145.87	4922.50	4151.04	34235.01	7645.61	12114.04	
11		4145.87	4922.50	4151.04	34234.99	10371.03	11499.33	
12		4145.87	4922.50	4151.04	34234.99	13096.44	10884.67	
13L	SN1	4145.87	4922.50	4151.04	34235.01	15821.86	10269.98	
13R	SN1	5055.51	4759.16	10811.25	34235.01	15821.86	10269.98	
14L	C02A	5055.51	4759.16	10811.25	34235.01	13213.41	11416.52	
14R	C02A	5494.89	4705.13	10772.28	34235.01	13213.41	11416.52	
15L	C02B	4705.13	5494.89	10772.28	3595.95	23699.83	14429.15	
15R	C02B	4690.91	5829.54	10602.79	3595.95	23699.83	14428.15	
16L	H1	4690.91	5829.54	10602.79	3595.95	21986.53	14268.68	
16R	H1	4690.23	5898.68	10559.79	3595.95	21986.53	14268.68	
17L	SN2	4690.23	5898.68	10559.79	3595.95	20474.35	14180.07	
17R	SN2	4690.31	5415.42	10511.50	3595.95	20474.35	14180.07	
18L	V1	4690.31	5415.42	10511.50	3595.95	19206.47	13416.68	
18R	V1	5012.69	3631.93	9096.49	3595.95	19206.47	13416.68	
19		5012.69	3631.92	9096.48	3595.94	22532.27	12424.73	
20L	V2	5012.69	3631.93	9096.49	3595.95	25858.09	11432.78	
20R	V2	6237.83	1233.48	5378.07	3595.95	25858.09	11432.78	
21		6237.83	1233.48	5378.07	3595.94	32319.34	10261.42	
22		6237.83	1233.48	5378.07	3595.94	38786.58	9090.05	
23		7149.04	2514.69	4053.26	3595.94	45241.87	7918.68	
24		7149.04	2514.69	4053.26	3595.94	47918.91	7731.35	
25		7149.04	2514.69	4053.26	3595.94	50595.95	7544.02	
26L	H2	7149.04	2514.69	4053.26	3595.95	53273.02	75 68	

DVI ANALYSIS FOR DESI \*\*\*  
 \*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERN; \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

### 5 (SSTI), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

LOAD CASE NO.	TOP GROUP	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONT'D.)		H2						
26R		8130.62	1896.86	4367.09	3595.95	53273.02	7356.68	
27		8130.62	1896.86	4367.09	3595.94	52614.45	6645.57	
28		8130.62	1896.86	4367.09	3595.94	51956.30	6934.47	
29		9144.77	767.31	5646.99	7595.94	51071.91	5669.73	
30		9144.77	767.31	5646.99	3595.94	49735.42	6297.71	
31		9144.77	767.31	5646.99	3595.94	48398.93	6925.71	
32		10189.35	1288.29	7053.98	3595.94	50330.08	5918.02	
33		10189.35	1288.29	7053.98	3595.94	53895.05	4092.50	
34L	C03A	10189.35	1288.29	7053.98	3595.95	57660.13	2266.97	
34R	C03A	10918.70	7104.98	1873.73	3595.95	2266.97	57460.13	
35L	C03B	7106.98	10918.70	1873.73	2295.29	4358.16	66289.44	
35R	C03B	7102.26	2108.64	11059.80	2295.29	66285.44	63558.16	
36L	H3	7102.26	2108.64	11059.80	2295.29	67410.87	4671.37	
36R	H3	7236.39	1410.83	6584.71	2295.29	67410.87	4671.37	
37		7236.38	1410.83	6584.71	2295.29	58042.12	5325.81	
38		7236.38	1410.83	6584.71	2295.29	48673.30	5980.26	
39		7977.30	459.23	5731.46	2295.29	40357.71	6489.77	
40		7977.30	459.23	5731.46	2295.29	34148.52	6709.39	
41		7977.30	459.23	5731.46	2295.29	27939.31	6929.00	
42		9215.19	1127.60	4657.50	2295.29	25324.97	5750.62	
43		9215.19	1127.60	4657.50	2295.29	3873.24		
44L	C04A	10293.55	1127.01	4657.50	2295.29	23691.14	1995.86	
44R	C04A	3515.04	1515.04	1597.89	2295.29	23691.14	23691.14	
45L	C04B	10293.53	10293.53	1597.89	2295.29	13160.17	13160.17	
45R	C04B	3165.43	1811.21	10806.34	1229.39	2581.93	2581.93	
46L	H4	3165.43	1811.21	10806.34	1229.39	19533.99	4239.33	
46R	H4	3100.61	1989.09	11164.88	1229.39	9533.99	4239.33	
47L	C05A	3100.61	1989.09	11164.88	1229.39	19808.00	2379.99	
47R	C05A	3309.30	11579.15	1735.17	1229.39	2379.99	19808.00	
48L	C05B	11579.15	3309.30	1755.17	2242.81	2011.84	30459.23	
48R	C05B	12462.29	1270.52	4420.68	2242.81	30459.23	2011.84	
49		12462.29	1270.52	4420.68	2242.81	26672.53	3967.52	
50		12462.29	1273.52	6420.68	2242.81	22885.24	5923.20	
51		13898.17	380.01	5626.25	2242.81	21648.79	7029.20	
52		13898.17	380.01	5626.25	2242.81	25510.93	6435.85	
53		13898.17	380.01	5626.25	2242.81	29373.07	5842.51	
54		13997.18	1619.75	6426.71	2242.81	36947.55	4862.46	

DVI ANALYSIS FOR DESI \*\*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNES \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

5 LOAD CASE NO. 5 (SSTI), FORCES AND MOMENTS IN LOCAL COORDINATES (CONT'D.)

RUN NO.	SOP GROUP	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
RUN1 (CONT'D.)								
55	H5	15497.18	1619.75	6426.71	2242.81	46378.16	3689.07	
56L	H5	15497.18	1619.75	6426.72	2242.81	55838.84	2515.68	
56R	H5	16387.31	1297.59	6538.48	2242.81	55806.84	2515.68	
57L	C06A	16387.31	1297.59	6538.48	2242.81	57271.90	2400.44	
57R	C06A	16790.67	6595.26	1002.83	2242.81	2900.44	57271.90	
58L	C06B	6595.26	16790.60	1002.83	2464.50	2300.52	52302.92	
58R	C06B	6794.05	336.02	17716.58	2964.50	52502.92	2300.52	
59		6744.05	336.02	17716.57	2464.50	57196.01	1959.35	
60		6998.48	1177.81	18173.61	2464.49	62089.04	1698.16	
61		6998.48	1177.81	18173.63	2464.50	90055.81	2498.28	
62	ANC1	6998.48	1177.81	18173.64	2464.50	118102.62	3298.40	

DVI ANALYSIS FOR 01-01-\*\*  
 \*\*\* ANCHOR ADDED 6'-6" S OF COGM DUE TO LSC CONCERNS \*\*\*  
 \*\*\* DIRECT VESSEL INJECTION SYSTEM \*\*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 07/9/92

6) ISSSET, FORCES AND MOMENTS IN LOCAL COORDINATES

LOAD CASE NO.	SOP	DOP	NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	X MOMENT (LB.FT)	Y MOMENT (LB.FT)	Z MOMENT (LB.FT)	PXENT (LB.FT)	PYENT (LB.FT)	PZENT (LB.FT)
RUN1	1	R107		15964.21	8741.72	13163.15	22008.14	50117.66	36718.58	50117.66	32117.79	32117.79
	2L	N1	15944.21	8741.72	13163.15	22008.14	44901.50	44901.50	44901.50	44901.50	44901.50	44901.50
	2R	N1	15863.92	8552.39	13045.83	22008.14	44903.50	44903.50	44903.50	44903.50	44903.50	44903.50
	3L	R10A	15863.9	8552.39	13045.83	22008.14	31098.52	31098.52	31098.52	31098.52	31098.52	31098.52
	3R	R10A	15756.21	8281.17	8281.19	22008.14	19677.29	19677.29	19677.29	19677.29	19677.29	19677.29
	4L	R10B	16054.36	6179.91	8281.19	18202.20	15687.77	27267.82	27267.82	27267.82	27267.82	27267.82
	4R	R10B	16759.34	7811.29	6027.41	18202.20	27267.82	15687.77	15687.77	15687.77	15687.77	15687.77
	5		18759.37	7811.29	6027.41	18202.20	24587.81	9045.73	9045.73	9045.73	9045.73	9045.73
	6		19387.66	7721.46	5505.55	18202.20	22001.98	17988.26	17988.26	17988.26	17988.26	17988.26
	7		18587.66	7721.46	5505.55	18202.20	22533.96	30605.51	30605.51	30605.51	30605.51	30605.51
	8		18587.66	7721.46	5505.55	18202.20	26896.53	44467.29	44467.29	44467.29	44467.29	44467.29
	9L	C01A	18087.66	7721.46	5505.55	18202.20	35237.02	58403.61	58403.61	58403.61	58403.61	58403.61
	9R	C01B	18216.94	85546.20	55446.20	18202.20	35237.02	58403.61	58403.61	58403.61	58403.61	58403.61
	10L	C01B	85549.26	18216.04	55446.20	18202.20	35237.02	58403.61	58403.61	58403.61	58403.61	58403.61
	10R	C01B	9694.85	18061.36	6195.04	41488.04	13401.41	45637.04	45637.04	45637.04	45637.04	45637.04
	11		9694.87	18081.36	6195.04	41488.04	13401.42	45637.04	45637.04	45637.04	45637.04	45637.04
	12		9694.87	18081.36	6195.04	41488.04	13401.42	45637.04	45637.04	45637.04	45637.04	45637.04
	13L	S01	9694.83	18081.36	6195.04	41488.04	13401.42	45637.04	45637.04	45637.04	45637.04	45637.04
	13R	S01	17605.52	17918.02	11318.40	41488.04	13401.42	45637.04	45637.04	45637.04	45637.04	45637.04
	14L	C02A	10606.52	17318.02	11318.40	41488.04	13401.42	45637.04	45637.04	45637.04	45637.04	45637.04
	14R	C02A	11045.91	17863.98	11279.42	41488.04	16622.39	40118.49	40118.49	40118.49	40118.49	40118.49
	15L	C02B	17664.00	11045.89	11109.93	6731.19	13158.04	52708.42	52708.42	52708.42	52708.42	52708.42
	15R	C02B	17849.78	11380.55	11109.93	6731.20	30497.21	30497.21	30497.21	30497.21	30497.21	30497.21
	16L	H1	17849.78	11380.55	11109.93	6731.20	28696.27	51481.30	51481.30	51481.30	51481.30	51481.30
	16R	H1	17849.09	11449.69	11066.94	6731.20	28696.27	51481.30	51481.30	51481.30	51481.30	51481.30
	17L	SM2	17849.09	11449.69	11066.94	6731.20	27997.72	49726.57	49726.57	49726.57	49726.57	49726.57
	17R	SM2	17849.17	8942.74	11018.64	6731.20	27997.72	49726.57	49726.57	49726.57	49726.57	49726.57
	18L	V1	17869.17	8942.74	11018.64	6731.20	25744.79	48210.11	48210.11	48210.11	48210.11	48210.11
	18R	V1	16171.55	6644.25	9603.63	6731.20	25744.79	48210.11	48210.11	48210.11	48210.11	48210.11
	19		16	55	6544.25	9603.63	28553.82	42323.16	42323.16	42323.16	42323.16	42323.16
	20L	V2	18171.55	6544.25	9603.63	6731.20	31437.56	36476.22	36476.22	36476.22	36476.22	36476.22
	20R	V2	19356.70	4245.80	5885.21	6731.20	31437.56	36476.22	36476.22	36476.22	36476.22	36476.22
	21		19356.70	4245.80	5885.21	6731.20	37520.88	29567.86	29567.86	29567.86	29567.86	29567.86
	22		19356.70	4245.80	5885.21	6731.20	43744.33	23294.52	23294.52	23294.52	23294.52	23294.52
	23		20307.91	5527.01	4560.41	6731.20	50128.22	16731.31	16731.31	16731.31	16731.31	16731.31
	24		20307.91	5527.01	4560.41	6731.20	52895.29	11197.89	11197.89	11197.89	11197.89	11197.89
	25		20307.91	5527.01	4560.41	6731.20	55820.75	9529.00	9529.00	9529.00	9529.00	9529.00
	26L	H2	20307.91	5527.01	4560.41	6731.20	9529.00	14736.72	14736.72	14736.72	14736.72	14736.72

DVI ANALYSIS FOR DESI \*\*  
 \*\*\* ANCHOR ADDED 8'-0" S OF C06\* DUE TO LBB CONCERNs \*\*\*  
 \*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
 ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

6

LOAD CASE NO. 400 (SSET), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP	PCP	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
<b>RUN1 (CONTD.)</b>								
26R	H2		21289.49	2364.18	4874.24	6731.20	58883.47	14736.
27			21289.47	2364.18	4874.24	6731.19	58766.71	13120.61
28			21289.47	2364.18	4874.24	6731.19	58749.29	11504.55
29			22303.62	1234.64	6154.13	6731.19	58579.88	10335.28
30			22303.62	1234.64	6154.13	6731.19	58013.37	10059.02
31			22303.62	1234.64	6154.13	6731.19	57487.92	9783.53
32			23348.19	1755.61	7561.12	6731.19	60261.14	7874.17
33			23348.19	1755.61	7561.12	6731.19	64691.98	5153.37
34L	C03A		23348.19	1755.61	7561.12	6731.20	69141.37	2519.76
34R	C03A		24077.56	7612.12	2341.06	6731.20	2519.76	69141.37
35L	C03B		7612.14	24077.56	2341.06	2794.69	7586.16	70480.75
35R	C03B		7609.41	2575.97	29218.67	2794.69	70480.75	7586.16
36L	H3		7609.41	2575.97	29218.67	2794.69	74891.12	7930.24
37R	H3		7743.53	1643.66	7088.33	2794.69	74891.12	7930.24
37			7743.53	1643.66	7088.33	2794.69	64628.08	8170.49
38			7743.53	1643.66	7088.33	2794.69	54365.87	8410.93
39			8484.45	692.06	6235.09	2794.69	45158.25	8506.73
40			8484.45	692.06	6235.09	2794.69	38059.37	8313.17
41			8484.45	692.06	6235.09	2794.69	30964.80	8120.70
42			9722.34	1359.84	5161.12	2794.69	27474.87	6533.04
43			9722.34	1359.84	5161.12	2794.69	25811.85	4258.26
44L	C04A		9722.34	1359.84	5161.12	2794.69	24312.68	2165.78
44R	C04A		10800.67	4018.66	1830.72	2794.69	2163.78	24312.68
45L	C04B		4018.66	10800.67	1839.72	1616.01	2943.11	14091.80
45R	C04B		3669.06	2044.05	11313.49	1616.01	14091.80	2933.11
46L	H4		3669.06	2044.05	11313.49	1616.01	10987.46	4665.04
46R	H4		3604.23	2017.08	11672.02	1616.01	10987.46	4665.04
47L	C05A		3604.23	2017.08	11672.02	1616.01	21847.84	2308.53
47R	C05A		3807.92	12086.29	1783.15	1616.01	2808.53	21847.84
48L	C05B		12086.29	3807.92	1783.15	2676.98	2363.76	52506.07
48R	C05B		12969.44	1298.51	4924.30	2676.98	32506.07	2363.76
49			12969.44	1298.51	4924.30	2676.98	27911.50	4270.10
50			12969.44	1298.51	4924.30	2676.98	23586.76	6176.64
51			14405.31	407.99	6129.87	2676.98	22175.37	7233.86
52			14405.31	407.99	6129.87	2676.98	27307.88	6592.41
53			14405.31	407.99	6129.87	2676.98	32021.29	5952.52
54			16004.32	1647.77	6930.34	2676.98	40469.83	4930.80

DVI ANALYSIS FOR DESI \*\*  
\*\*\* ANCHOR ADDED 8'-8" S OF C06\* DUE TO LBB CONCERNs \*\*\*  
\*\* DIRECT VESSEL INJECTION SYSTEM \*\*  
ANALYSIS BY: C. E. RIDDLE DATE: 8/19/92

6

LOAD CASE NO. # (SSET), FORCES AND MOMENTS IN LOCAL COORDINATES (CONTD.)

RUN GROUP	SOP HNB	DCP NAME	AXIAL FORCE (LB)	Y FORCE (LB)	Z FORCE (LB)	XX MOMENT (LB.FT)	YY MOMENT (LB.FT)	ZZ MOMENT (LB.FT)
-----------	---------	----------	------------------	--------------	--------------	-------------------	-------------------	-------------------

RUN1  
(CONTD.)

55		16004.32	1647.73	6930.34	2676.98	52783.78	3736.10	
56L	H5	16004.32	1647.73	6930.34	2676.98	5102.40	2584.32	
56R	H5	16894.45	1363.79	7042.10	2676.98	61102.40	2584.32	
57L	C06A	16894.45	1363.79	7042.10	2676.98	62690.32	2478.22	
57R	C06A	17297.74	7098.88	1069.03	2676.98	2478.22	62690.32	
58L	C06B	7098.89	17297.74	1069.03	2609.31	2652.15	57844.89	
58R	C06B	7247.68	402.22	18223.72	2609.31	57844.89	2652.15	
59		7247.67	402.22	18223.71	2609.31	62051.54	2228.83	
60		7502.10	1244.00	18680.75	2609.31	66355.69	1806.84	
61		7502.11	1244.01	18680.77	2609.31	93916.31	2531.36	
62	ANC1	7502.11	1244.01	18680.79	2609.31	121673.19	3441.58	

APPENDIX E

DESCRIPTION OF LEAK-BEFORE-BREAK METHODS

## APPENDIX E

### DESCRIPTION OF LEAK-BEFORE-BREAK METHODS

#### PURPOSE

This appendix describes the common analytical methods and assumptions employed in the stability analyses for the System 80+ piping systems presented in Appendices F to J of this report.

#### SCCPE

The methods and assumptions presented in this appendix are applicable to the analysis of the following System 80+ piping systems:

- Main Coolant Loop Hot Leg (HL)
- Main Coolant Loop Cold Leg (CL)
- Surge Line (SL)
- Main Steam Line (MSL)
- Shutdown Cooling Line (SC)
- Direct Vessel Injection Line (DVI)

For the purpose of the discussion in these appendices, passing LBB means that the pipeline under consideration has been demonstrated to be acceptable for LBB stability evaluation and has passed the stability evaluation of  $\sqrt{2} \times (\text{NOP} + \text{maximum design load})$  for the leakage crack length and  $(\text{NOP} + \text{maximum design load})$  for two times the leakage crack length, where the maximum design load is defined in the Distribution Systems Design Guide. The leakage crack length is determined by the criteria specified in the Design Guide.

This appendix discusses material properties, leakage crack determination methods, flow rate correlation, and finite element models common to the piping systems evaluated in this report.

## MATERIAL PROPERTIES

The detailed analysis of cracks in pipes requires consideration of the properties of the pipe and the weld materials. Previous work of Reference (1) has shown that a conservative bounding analysis results when the material stress-strain properties of the base metal (lower yield) and the fracture properties of the weld (lower toughness) are used for the entire pipeline. Methods for calculating the leakage crack length generally require a simple Ramberg-Osgood (R-O) material characterization. The fitting of the actual data is for this purpose only. It has been found that crack opening area calculations, which are elastic, require that the R-O curve fit for small strains in order to match assumed flow correlations. The actual material behavior is input for the finite element calculation.

### Stress-Strain Curves

The HL, CL and MSL are fabricated from SA516 Gr70. The material stress-strain curves are taken from the Piping Fracture Mechanics Data Base (PIFRAC), Figure (2). The stress-strain data are shown in Figure (1). The data shown in Figure (1) are used in the finite element analysis. In order to use these data in procedures requiring a R-O material behavior, the small strains characterization are emphasized by the fit.

The crack opening area calculations are very sensitive to the R-O parameters. Since the crack opening area calculations are essentially elastic, a good characterization of the elastic, small strain, behavior is required. The R-O fit is shown in Figure (2).

The SC, SL and DVI lines are fabricated with 316 stainless steel. A low strength 316 material is chosen from the PIFRAC data base, which bounds the stainless steel used in the System 80+ design. The stress-strain data are shown in Figure (3). The R-O fit to small strain data is shown in Figure (4). The rationale to the small strain fit follows the reasoning for establishing the SA516 Gr70 R-O parameters.

### Material Resistance Curves

The material resistance curves (J-R) for each of the pipelines is taken from the PIFRAC data base. The J-R material curve for the HL, CL, and MSL is for a SA516 Gr70, shielded metal arc weld (SMAW) and is shown in Figure (5). A fit to the data used in the stability evaluation is also shown in the figure. This J-R curve bounds the material toughness behavior in any of these pipelines.

The J-R material curve plotted in Figure (6) for the SC, SL and DVI lines is taken from the PIFRAC data base and is for a 304 stainless steel SMAW weld. This curve was taken from a set of data and is a lower bound result from a group of data for which significant crack extension was measured. This J-R curve bounds the material toughness behavior in any of these lines. In order to ensure LBB is satisfied for the SC, SL and DVI, which are relatively small diameter pipes, gas tungsten arc weld (GTAW) will be specified for all shop and field welds. A J-R material curve for GTAW weld will be developed and will be used in the stability evaluations of these lines.

The complete summary of material properties and R-O constants are given in Table (I) for each of the materials used in these evaluations.

#### LEAKAGE CRACK LENGTH DETERMINATION

The leakage flow rate used in the LBB evaluation should be based on theoretical and experimental data and must be sufficiently conservative to encompass many unknown variables. The following discussion is applicable to piping systems containing subcooled liquid and therefore pertains to all pipes reported herein except the MSL.

NUREG/CR-1319, Reference (3), provides a treatment of leakage through small cracks considering various uncertainties in crack definition. NUREG/CR-1319 addresses crack wall surface roughness, effective hydraulic ratio of the elongated crack shape, and the possibility that the crack may be longer at the inside of the pipe wall than at the outer surface of the pipe, resulting in a convergent opening. For typical PWR conditions at 2250 psi and 550°F for a high friction factor of .01, three different inlet and outlet crack opening areas are plotted on Figure (7) in units of gpm per square inch of crack opening versus outer surface crack area,  $A_e$ . Also plotted in Figure (7) are flow predictions based on simple orifice flow with a discharge coefficient of 0.6 and also a flow prediction using a Henry-Fauske critical flow model, Reference (4).

The Henry-Fauske correlation was developed on the basis of subcooled flow through nozzles, and provides an upper bound for flow through an irregular crack opening. The orifice flow does not consider subcooled water effects, and the constant discharge coefficient does not consider the irregular crack shape. Even so, the orifice prediction falls in the range of the NUREG/CR-1319 predictions, providing a measure of comparison.

The NUREG/CR-1319 predictions show a slight increase in flow rate per unit of exit area with increasing area, and a large increase for decreasing  $A_e/A_o$  ratio. Since for the purposes of identifying a through wall crack by means of leakage it would be conservative to underpredict the flow rate, the lowest value of all of these various predictions is used. The lowest flow rate prediction is about 885 gpm/in<sup>2</sup> at 0.001 in<sup>2</sup>. This means that a crack which opens to slightly greater than 0.001 square inches will leak at least 1.0 gpm. Application of the factor of 10 safety margin recommended in NUREG-1061, Volume 3, leads to a leakage area of 0.01 square inches for this leak rate.

Another procedure for relating the crack opening area to leakage rate was developed by EPRI and is used in the PICEP program, Reference (5). Using a procedure similar to PICEP with conservative input assumptions, cracks in the pipes considered here produce leakage rates of 250 to 350 gpm/in<sup>2</sup>. This implies a detectable leakage area of 0.003 to 0.004 square inches.

The value of 250 gpm/in<sup>2</sup> was also used in Reference (6) as an assumed conservative value. The flow correlation 250 gpm/in<sup>2</sup> is used for all lines in these analyses with subcooled liquid. The acceptability of the leakage crack length is determined from the area calculation in the finite element analysis using the real stress-strain law. Therefore, a crack length pertaining to a 1.0 gpm leak rate must have an area of 0.004 square inches.

In order to determine the leakage rate for steam lines, a study generalizing the previous work has been performed. For a given size leakage crack length, correlations to predict discharge rates have been developed based on thermodynamic conditions inside the pipe. These correlations are based on choked ("critical") flow downstream of a reservoir ("source") at a given stagnation pressure. Isentropic expansion is assumed to occur between the source and choke points. The ratio of choke point ("throat" or "critical") pressure to upstream stagnation pressure is determined by thermodynamic properties of the steam-water mixture, and is generally about 0.56 to 0.58. Flow at this cross section is, by definition, a limiting value and thereby determines discharge rate. Each correlation, (1) Henry-Fauske, (2) Moody, and (3) Homogeneous, uses some assumption about the interaction between liquid and gaseous phases moving at different speeds during the expansion process.

For a constant stagnation pressure, each correlation provides the relationship between flow rate and stagnation enthalpy. These three correlations are compared at 2250 psia and 900 psia in Figures (8) and (9).

Low values of enthalpy are associated with subcooled ("compressed") liquid, i.e., temperatures below saturation at that pressure. The saturation enthalpy corresponds to the onset of liquid boiling. As enthalpy increases beyond saturation, a two-phase steam-water mixture is present. While neither pressure nor temperature change, as enthalpy increases the steam gets progressively "drier", tending towards 0% moisture ("dry steam"). Any further increase in enthalpy constitutes superheated steam. The correlations, as plotted, terminate at the enthalpy corresponding to dry steam (the onset of superheat). However, the ASME Steam Tables (Figure 10) for critical mass flow rate can be used to predict the discharge of superheated steam. As Figures (8) and (9) indicate, the correlations do not yield identical results at the point of saturated liquid, but converge as the dry steam enthalpy is approached.

The Henry-Fauske correlation is an accepted method of computing discharge rates which is known to be conservative. Considering the main loop piping ( $550^{\circ}\text{F}$ , 2250 psia) the enthalpy for entering the curve is based almost entirely on temperature. The enthalpy of saturated water at  $550^{\circ}\text{F}$  (saturation pressure 1045 psia), the enthalpy of subcooled water at  $550^{\circ}\text{F}$  (2250 psia, "compressed liquid") is 547.3 Btu/lbm. From Figure (8), the Henry-Fauske correlation yield 23,600 lbm/ft<sup>2</sup>/sec. This is based on choked flow in the leakage crack, and assumes zero head loss in the rapidly flowing liquid phase prior to the choke point. Hence, it is a conservative result. The Henry-Fauske correlation value, 23,600 lbm/ft<sup>2</sup>/sec, is equivalent to 1233 gpm/in<sup>2</sup>, where the gallonage is in terms of condensed water at  $200^{\circ}\text{F}$ .

Discharge rates for dry steam conditions at 900 psia are considered next. The enthalpy for entering the curve is 1196.4 Btu/lbm which corresponds to 0% moisture. Note that all three correlations give essentially the same result, 1800 lbm/ft<sup>2</sup>/sec assuming choked flow. Therefore, there is no uncertainty about the extent to which the presence of liquid water influences the mass flow rate (unlike the situation when conditions are near saturated liquid). A discharge rate of 1800 lbm/ft<sup>2</sup>/sec corresponds to 93.7 gal/in<sup>2</sup>/min of  $200^{\circ}\text{F}$  water. Using the ASME Steam Table, Figure (10) yields an identical result, as expected.

This discharge rate is somewhat below that which would be predicted for a perfect gas flowing through a nozzle (2350 lbm/ft<sup>2</sup>/sec) as determined by compressible flow equations and based on the throat to stagnation pressure ratio of 0.585 for homogeneous flow and a specific heat ratio ("gamma") of 1.30 for steam. This serves as a check on the result since steam has slightly adhesive qualities compared to a perfect gas.

From Figures (8) and (9), it is clear that there is less uncertainty in the flow rates of dry steam than subcooled water. There is no uncertainty associated with the phase change during flow through the crack. It is reasonable then to use a margin on the order of 2.0 to 2.5 for the steam flow rate with respect to the theoretical value. The use of this margin would give a range of 38 to 47 gpm/in<sup>2</sup> of water at 200°F. For simplicity, the value of 40 gpm/in<sup>2</sup> is chosen as a conservative leakage rate for the steam line, which corresponds to the 250 gpm/in<sup>2</sup> flow rate chosen for the primary coolant loop piping. The flow correlation of 40 gpm(water)/in<sup>2</sup> is used for the MSL. Again, the acceptability of the leakage crack length is determined from the area calculation in the finite element analysis using the real stress-strain law. For the MSL, a crack length pertaining to 1.0 gpm must have an area of 0.025 square inches.

#### FINITE ELEMENT MODEL DESCRIPTION

##### Geometry and Boundary Conditions

The finite element model for a typical leakage crack length in the surge line is shown in Figure (11). All the finite element models used to model each of the lines are scaled from a base pattern and look essentially like the model shown in Figure (11). A close-up of the crack tip area is shown in Figure (12). The finite element model is simply a means for applying the pressure and moment loading to a section of pipe containing the hypothetical crack at some location in the pipeline. Since the crack is assumed to be aligned with the moment, a quarter symmetry model is used. The length of the pipe is chosen to at least five (5) pipe diameters in order that the point of load application not be close to the crack tip region. The mesh uses 20 node isoparametric solid elements. Boundary conditions are imposed on the model based upon symmetry and crack location. The crack surface area is free from constraint.

##### Loadings

The finite element model is loaded with internal pressure appropriate to the normal operating conditions of each piping system. An axial end load traction, which when integrated over the pipe cross-sectional area, is equal to the continuity axial force, is applied to the far end of the pipe. Moments are applied as a linearly varying traction to the far end of the pipe.

### J-Integral Calculation

The J-integral is evaluated from the calculated energy release rate using the virtual crack extension method. A virtual crack extension generates a strain energy change which, when divided by the virtual extension, provides the energy release rate. The following is the basic definition of J-integral:

$$J = \frac{1}{t} \times \frac{\Delta u}{\Delta a}$$

$\Delta u$  = strain energy change (in-lbs.)

$\Delta a$  = virtual crack advance (inches)

$t$  = thickness (inches)

### Stability Evaluation

There are two aspects to the LBB fracture mechanics method of evaluating the stability of a piping system. At each point of interest,

$$(1) \quad J_{LOAD} < J_{MAT}$$

$$(2) \quad \left. \frac{dJ}{da} \right|_{LOAD} < \left. \frac{dJ}{da} \right|_{MAT}$$

for some amount of ductile crack growth. In order to evaluate the derivative in the region of the leakage crack length tip location, three meshes are used. For a given leakage crack length "l" and model crack length "a<sub>1</sub>", the three meshes have crack length  $a_1 - \delta$ ,  $a_1$ , and  $a_1 + \delta$ . The value  $\delta$  is a length appropriate to the anticipated amount of stable crack growth. This is indicated in Figure (13). These three meshes are used in the analysis of the leakage crack. Similarly, three more meshes are generated for the analysis of twice the leakage crack length,  $2a_1 - \delta$ ,  $2a_1$ , and  $2a_1 + \delta$ .

In order to determine the critical load at instability, the material curve,  $J$  vs.  $a$ , is positioned at the crack tip location of either  $a_1$  or  $2a_1$ . The loading  $J$  curves for various load levels are plotted at  $a_1$ ,  $a_1$ , and  $a_1$  or  $2a_1$ ,  $2a_1$ , and  $2a_1$ . Figure (14) indicates this procedure. The point of tangency which is derived graphically is shown in Figure (14). The loading line vs. crack position labeled  $M_3$  is just equal in  $J$  ( $J_{LOAD} = J_{MAT}$ ) and tangent to the material curve  $\left. \frac{dJ}{da} \right|_{LOAD} = \left. \frac{dJ}{da} \right|_{MAT}$ .

## LBB PIPING EVALUATION PLOTS

### Constructing LBB Piping Evaluation Diagrams

In the course of developing routings and loadings for many different piping lines, it is not necessary to wait until the final design to analyze the line for LBB. A method has been developed which allows for the quick evaluation of the line in advance of the piping analysis, so that the LBB can be considered during the piping design. The LBB piping evaluation diagram can be prepared prior to the piping design and analysis and be used to quickly evaluate all points in a pipeline. The maximum design load at any time during the plant operation is the loading to be used in the stability analysis. Traditionally, this loading has been NOP + SSE. In the case of the surge line, a different situation occurs with stratified flow. That situation is particular to the surge line and is discussed in Appendix G. For the present discussion, the maximum design load is considered to be NOP + SSE.

The LBB piping evaluation plot requires performing two complete LBB evaluations. The evaluations are for two normal operating loads (NOP) which span the typical loadings for the line under consideration. A completed typical diagram is shown in Figure (15). The procedure used for generating that figure is as follows:

- (1) Choose NOP = Pressure + NOP<sub>1</sub>
- (2) Determine a<sub>1</sub>
- (3) Increase the analysis moment until the critical moment is found for a<sub>1</sub> and 2a<sub>1</sub>
- (4) Separate the critical analysis moment, M<sub>c</sub>, into the correct addition of SSE and NOP<sub>1</sub> proportion for the a<sub>1</sub> and 2a<sub>1</sub> evaluations.

$$(a) \quad M_c = \sqrt{2} (NOP_1 + SSE_1) \quad a_1 \text{ analysis}$$

$$SSE_1 = \frac{M_c}{\sqrt{2}} - NOP_1$$

$$(b) \quad M_c = (NOP_1 + SSE_1) \quad 2a_1 \text{ analysis}$$

$$SSE_1 = M_c - NOP_1$$

- (5) Plot values from (4a) and (4b) at  $NOP_1$ . This corresponds to the points labeled 1. in Figure (15).
- (6) Repeat steps (1) to (5) for  $NOP_2$ . The results are shown Figure (15), labeled 2.

Two stability evaluations must be performed for each pipeline under consideration in order to complete the piping evaluation diagram.

#### Using a LBB Piping Evaluation Diagram

Once the lines marking the acceptable areas of allowable piping loads are plotted as described in the previous section, all significant piping load results are plotted. Corresponding NOP and SSE values for all piping locations are plotted on the evaluation diagram. Figure (16) shows how the plot is used for a hypothetical line. Three points failed LBB in this example. The reasons for each failure are given in the figure. The designer can now use these results to revise the piping design; eg., lower the SSE response load by rerouting or by adding a snubber. Further review by the designer may result in other options for reducing the loads.

#### REFERENCES

- (1) "Analysis of Cracked Pipe Weldments", EPRI Report NP-5057, February 1987.
- (2) "A Users Guide to the NRC's Piping Fracture Mechanics Data Base (PIFRAC)", NUREG/CR-4894, May 1987.
- (3) "Cold Leg Integrity Evaluation", Battelle Columbus Laboratories, NURER/CR-1319, February 1980.
- (4) "The Two-Phase Critical Flow of One-Component Mixture in Nozzles, Orifices, and Short Tubes", Henry, R. E., and Fauske, H. R., *Journal of Heat Transfer*, Vol. 93, pp. 179-187, 1971.
- (5) PICEP: Pipe Crack Evaluation Program, EPRI, NP-3596-SR, August 1984.
- (6) "NRC Leak-Before-Break (LBB,NRC) Analysis Methods for Circumferentially Through-Wall Cracked Pipes Under Axial Plus Bending Loads", Klecker, R., Brust, F., Wilkowski, A., NUREG/CR-4572, May 1986.

## LIST OF FIGURES

- (1) 516 Stress-Strain PIFRAC
- (2) 516 Stress-Strain Small Strain Fit
- (3) 316 Stress-Strain PIFRAC
- (4) 316 Stress-Strain Small Strain Fit
- (5) 516 J-R Data and Fit PIFRAC
- (6) 304 J-R Data and Fit PIFRAC
- (7) Flow Rate vs. Crack Opening Area Correlations
- (8) Stagnation Enthalpy at 2250 psia
- (9) Stagnation Enthalpy at 900 psia
- (10) Steam Table, Critical Flow Rate
- (11) Overall Finite Element Model
- (12) Crack Area Closeup of Finite Element Model
- (13) Different Crack Lengths Used to Calculate Derivative
- (14) Stability Diagram
- (15) LBB Piping Evaluation Diagram
- (16) Use of the LBB Piping Evaluation Diagram

TABLE I

## MATERIAL CONSTANTS

Sa516 Gr70 (Hot Leg, Cold Leg, Main Steam Line)

Ramberg-Osgood Law Material Characterization

$$\frac{\epsilon}{\epsilon_0} = \frac{\sigma}{\sigma_0} + \alpha \left( \frac{\sigma}{\sigma_0} \right)^n \quad \alpha = 2.0$$

$$n = 4.5$$

$$\sigma_0 = 30,500 \text{ psi}$$

$$\text{Modulus } E = 28 \times 10^6 \text{ psi}$$

Finite Element Analysis (from PIFRAC Data Base)

$$\text{Modulus } E = 27.7 \times 10^6 \text{ psi}$$

$$\text{Yield} = 33,930 \text{ psi}$$

Work hardening slopes derived from  
data shown in Figure (1)

Stainless 316 (Shutdown Cooling, Surge and Direct Vessel Injection)

Ramberg-Osgood Law Material Characterization

$$\frac{\epsilon}{\epsilon_0} = \frac{\sigma}{\sigma_0} + \alpha \left( \frac{\sigma}{\sigma_0} \right)^n \quad \alpha = 7.06$$

$$n = 4.69$$

$$\sigma_0 = 30,000 \text{ psi}$$

$$\text{Modulus } E = 27.7 \times 10^6 \text{ psi}$$


Finite Element Analysis (from PIFRAC Data Base)

$$\text{Modulus } E = 27.7 \times 10^6 \text{ psi}$$

$$\text{Yield} = 24,143 \text{ psi}$$

Work hardening slopes derived from data  
shown in Figure (3)

Stress Strain for SA 516 Gr70  
Pipe data 37" Dia 3.5" thk 550 Deg



516 Stress-Strain PIFRAC  
Figure 1

Stress Strain for SA 516 Gr70  
Pipe data 37" Dia 3.5" thk 550 Deg  
 $S_0 = 30500$   $\alpha = 2.0$   $n = 4.5$




Figure 2  
516 Stress-Strain Small Strain Fit

Stress-Strain 316L @ 550  
Data Set 1




Figure 3  
316 Stress-Strain PIERRAC

Stress-Strain 316L @ 550  
Data Set 1  
 $S_0 = 30000$   $\sigma = 7.055$   $n = 4.691$




Figure 4  
316 Stress-Strain Small Strain Fit

Curve Fit to Data  
Data from PIFRAC No 62  
516 Pipe Weld




Figure 5  
516 J-R Data and Fit PIFRAC

Fit to aw45-3




Figure 6  
304 J-R Data and Fit PIFRAC




Figure 7  
Flow Rate vs Crack Opening Area Correlations

FLOW RATES versus STAGNATION ENTHALPY -- 2250 PSIA

HENRY FAUSKE; MOODY; HOMOGENEOUS




Figure 8  
Stagnation Enthalpy at 2250 psia




Figure 9  
Stagnation Enthalpy at 900 psia




Figure 10  
Steam Table, Critical Flow Model




Figure 11  
Overall Finite Element Model





Figure 12  
Crack Area Closeup of Finite Element Model



$l$  = Leakage Crack Length

$a_2$  = model crack length

$a_2 \pm \xi$  model crack length  
± a small amount

Figure 13  
Different Crack Lengths Used to Calculate Derivative

$M_i ; i=1-4$   $J$  results for 4 load levels at 3 crack positions

$M_1, M_2$  load levels O.K. since  $J_{LOAD} < J_{MAT}$   $\therefore \frac{dJ}{da}|_{LOAD} < \frac{dJ}{da}|_{MAT}$  STABLE TEARING

Critical Load at level  $M_c = M_3$   $J_{LOAD} = J_{MAT} \therefore \frac{dJ}{da}|_{LOAD} = \frac{dJ}{da}|_{MAT}$   
 $M_4$  Unstable tearing  $J_{LOAD} > J_{MAT} \therefore \frac{dJ}{da}|_{LOAD} > \frac{dJ}{da}|_{MAT}$

Acceptable LBB loads are below  $M_3$




Figure 14  
Stability Diagram

- ① Analysis no.1 results  
 ② Analysis no.2 results






Figure 15  
LBB Piping Evaluation Diagram



PIPE LING

$\Rightarrow$  LOADS



Points 1, 3-10, 12, 13 pass LBB

Point 2 fails ( $Nop + SSE$ ) on  $2a$

Point 11 fails  $\sqrt{2}(Nop + SSE)$  on  $a$

Point 14 fails ( $Nop + SSE$ ) on  $2a$   
and  $\sqrt{2}(Nop + SSE)$  on  $a$

Figure 16  
Use of the L<sup>2</sup>B Piping Evaluation Diagram

APPENDIX F

MAIN COOLANT LOOP

LEAK-BEFORE-BREAK EVALUATION

## APPENDIX F

### LBB EVALUATION OF THE MAIN COOLANT LOOP

#### LBB EVALUATION OF THE HOT LEG

The RCS hot leg was analyzed as a 49-inch OD, 3.5-inch thick pipe. The material used in this evaluation is discussed in Appendix E. The NOP loads for this System 80+ evaluation are based on specified loads from a previous (System 80) ABB-CE plant design. The maximum design loads for the hot leg are the SSE loads. The SSE loads are based on System 80+ envelope results of the RCS seismic analysis for all soil cases. Margin is included in all loads given to account for uncertainties. The loads are given in Table I.

A piping evaluation diagram was constructed for the hot leg using the procedure described in Appendix E. The data for this diagram were generated from two stability analyses. The first was for a leakage crack determined by pressure only,  $M = 0$ . The stability plots are shown in Figures (1) and (2). The second stability analysis was for a leakage crack length determined by pressure and a moment of 50,000 inch-kips. The stability plots are shown in Figures (3) and (4). These two stability analyses are used to construct the piping evaluation diagram, Figure (5).

The values for the NOP and SSE loading conditions from Table I are plotted on the diagram in Figure (5). The hot leg passes LBB for the preliminary loads and assumed lower bound material properties.

#### LBB EVALUATION OF THE COLD LEG

The RCS cold leg was analyzed as a 36-inch OD, 3.0-inch thick pipe. The material used in this evaluation is discussed in Appendix E. The NOP loads for this System 80+ evaluation are based on specified loads from a previous (System 80) ABB-CE plant design. The maximum design loads for the cold leg are the SSE loads. The SSE loads are based on System 80+ envelope results of the RCS seismic analysis for all soil cases. Margin is included in all loads given to account for uncertainties. The loads are given in Table I.

Rather than construct a piping evaluation diagram, a single stability evaluation was performed on a pressure only leakage crack length. The stability analysis of  $\sqrt{2} \times (\text{NOP} + \text{SSE})$  for the leakage crack is shown in Figure (6). The maximum NOP + SSE combination was used. The stability analysis of  $(\text{NOP} + \text{SSE})$  for 2 times the leakage crack is shown in Figure (7). The maximum NOP + SSE combination of loads at all locations was used.

#### RESULTS AND DISCUSSION

The RCS hot leg and cold leg clearly pass the stability analysis portion of the LBB evaluation for the given loads and lower bound material assumptions. The hot leg was analyzed using the piping evaluation diagram. The utility of this diagram is that for any changes in the loadings, the pipeline may immediately be reanalyzed without any more lengthy J-integral finite element analyses. The cold leg was analyzed using a limiting, conservative pressure-only crack length and highest combination of NOP and SSE loads at all locations. The cold leg passed the LBB stability evaluation with very low J-integral values.


TABLE I

PRELIMINARY SYSTEM 80+ MAIN COOLANT LOOP  
 HOT LEG AND COLD LEG NOP AND SSE LOADS

LOCATION	NORMAL OPERATION	SSE
	RSS MOMENT (inch-kips)	RSS MOMENT (inch-kips)
<b>Hot Leg</b>		
RV Outlet Nozzle	95,800	25,100
SG Inlet Nozzle	43,200	14,700
<b>Cold Leg</b>		
RV Inlet Nozzle	11,500	7,300
SG Outlet Nozzle	7,700	5,200
RCP Discharge Nozzle	13,600	6,100
RCP Suction Nozzle	11,700	4,800

System pressure = 2250 psia

ALWR HOT LEG  
Press + M = 0  
Leakage Crack



J-Integral (in-lbs/in<sup>2</sup>)

Figure 1

ALWR HOT LEG  
Press + M = 0  
2xLeakage Crack




Figure 2

ALWR HOT LEG  
Press + M =  $50 \times 10^{**6}$   
Leakage Crack




Figure 3

ALWR HOT LEG  
Press + M =  $50 \times 10^{**6}$   
2xLeakage Crack




Figure 4




Figure 5

ALWR COLD LEG  
Press + M = 0  
Leakage Crack




Figure 6

ALWR COLD LEG  
Press + M = 0  
2xLeakage Crack




Figure 7

APPENDIX G

SURGE LINE

LEAK-BEFORE-BREAK EVALUATION

## APPENDIX G

### LBB EVALUATION OF THE PRELIMINARY SURGE LINE

The surge line was analyzed as a 12.75-inch OD, 1.312-inch thick pipe. The material used in this evaluation is discussed in Appendix E. The pipe loads are developed and discussed in Appendix A. A piping evaluation diagram was constructed for the surge line using the procedure described in Appendix E. The stability of the leakage crack is evaluated for (NOP + maximum design load), and  $\sqrt{2} \times (\text{NOP} + \text{maximum design load})$ , where the maximum design load is either the SSE load or the stratified flow (SF) load. The data for this diagram were generated from two stability analyses. The first was for a leakage crack length determined by pressure +  $M_1 = (\text{later})$ . The stability plots are shown in Figures (1) and (2). The second stability analysis was for a leakage crack determined by pressure +  $M_2 = (\text{later})$ . The stability plots are shown in Figures (3) and (4). These two stability analyses are used to construct the piping evaluation diagrams, Figures (5) and (6).

For maximum design load = SSE:

From the first analysis, Figures (1) and (2):

$$\text{Analysis of a: } \sqrt{2} (\text{NOP} + \text{SSE}_1) = M_{\text{CRIT}}$$

$$\text{SSE}_1 = \frac{M_{\text{CRIT}} - \text{NOP}_1}{\sqrt{2}}$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_2) = M_{\text{CRIT}}$$

$$\text{SSE}_2 = M_{\text{CRIT}} - \text{NOP}$$

From the second analysis, Figures (3) and (4):

$$\text{Analysis of a: } \sqrt{2} (\text{NOP} + \text{SSE}_3) = M_{\text{CRIT}}$$

$$\text{SSE}_3 = \frac{M_{\text{CRIT}} - \text{NOP}}{\sqrt{2}}$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_4) = M_{\text{CRIT}}$$

$$\text{SSE}_4 = M_{\text{CRIT}} - \text{NOP}$$

Each of the calculated SSE and NOP values are plotted on the piping evaluation diagram, Figure (5).

For maximum design load = stratified flow (SF) load:

From the first analysis, Figures (1) and (2):

$$\text{Analysis of a: } \sqrt{2} (SF_1) = M_{\text{CRIT}}$$

$$SF_1 = \frac{M_{\text{CRIT}}}{\sqrt{2}}$$

$$\text{Analysis of 2a: } SF_2 = M_{\text{CRIT}}$$

From the second analysis, Figures (3) and (4):

$$\text{Analysis of a: } \sqrt{2} (SF_3) = M_{\text{CRIT}}$$

$$SF_3 = \frac{M_{\text{CRIT}}}{\sqrt{2}}$$

$$\text{Analysis of 2a: } SF_4 = M_{\text{CRIT}}$$

Each of the calculated SF and NOP values are plotted on the piping evaluation diagram, Figure (6).

The moment,  $M$ , will be determined (later). Figures (1) through (6) will be generated (later).

APPENDIX H

MAIN STEAM LINE

LEAK-BEFORE-BREAK EVALUATION

## APPENDIX H

### LBB EVALUATION OF THE PRELIMINARY MAIN STEAM LINE

The main steam line (MSL) was analyzed as a 28-inch ID, 1.5-inch thick pipe. The material used in this evaluation is discussed in Appendix E. MSL loads are developed and discussed in Appendix B. The maximum design load was determined to be the SSE load. A piping evaluation diagram was constructed for the MSL using the procedure in Appendix E. The data for this diagram were generated from two stability analyses. The first was for a leakage crack length determined by pressure +  $M = 1 \times 10^6$  inch-lbs. The stability plots are shown in Figures (1) and (2). The second stability analysis was for a leakage crack length determined by pressure +  $M = 50 \times 10^6$  inch-lbs. The stability plots are shown in Figures (3) and (4). These two stability analyses are used to construct the piping evaluation diagram, Figure (5).

From the first analysis, Figures (1) and (2):

$$\text{Analysis of a: } \sqrt{2} \times (\text{NOP} + \text{SSE}_1) = M_{\text{CRIT}} \quad \text{NOP} = 1 \times 10^6 \text{ in-lb}$$
$$M = 32.6 \times 10^6 \text{ in-lb}$$
$$\text{SSE}_1 = \frac{(32.6 - 1) \times 10^6}{\sqrt{2}}$$
$$\text{SSE}_1 = 22 \times 10^6$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_2) = M_{\text{CRIT}} \quad \text{NOP} = 1 \times 10^6 \text{ in-lb}$$
$$M = 13.4 \times 10^6 \text{ in-lb}$$
$$\text{SSE}_2 = 12.4 \times 10^6$$

From the second analysis, Figures (3) and (4):

$$\text{Analysis of a: } \sqrt{2} \times (\text{NOP} + \text{SSE}_3) = M_{\text{CRIT}} \quad \text{NOP} = 5 \times 10^6 \text{ in-lb}$$
$$M = 37.5 \times 10^6 \text{ in-lb}$$

$$\text{SSE}_3 = \frac{(37.5 - 5) \times 10^6}{\sqrt{2}}$$

$$\text{SSE}_3 = 21.5 \times 10^6$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_4) = M_{\text{CRIT}} \quad \text{NOP} = 5 \times 10^6 \text{ in-lb}$$
$$M = 20.5 \times 10^6 \text{ in-lb}$$

$$\text{SSE}_4 = 15.5 \times 10^6$$

Each of these calculated SSE vs. NOP values are plotted on the piping evaluation diagram, Figure (5).

The NOP and SSE piping loads from Appendix B are summarized in Tables I and II. The NOP and SSE loads are cross-plotted on the piping evaluation diagram, Figure (5), and all points in the line are shown to pass LBB.

TABLE I


PRELIMINARY SYSTEM 80+ MAIN STEAM LINE  
NOP LOADS

LOCATION POINT	$M_{yy}$ (ft-lb)	$M_{zz}$ (ft-lb)	RSS MOMENT (in-lb) $\times 10^6$
1	399,766	61,265	4.85
2	286,304	32,905	3.46
3	87,290	118,684	1.77
4	18,375	80,246	0.99
5	51,743	80,246	1.12
6	41,490	92,480	1.22
7	1,032	215,206	2.59
8	48,929	1,193,969	14.30
9	23,205	512,392	6.15
10	47,502	1,125,951	13.50
11	50,442	1,092,779	13.10
12	41,441	939,114	11.30
13	19,162	311,093	3.70
14	21,341	365,042	4.38
15	144,421	113,310	2.20
16	206,115	471	2.47
17	211,885	10,688	2.54
18	938,075	33,312	11.30

TABLE II  
 PRELIMINARY SYSTEM 80+ MAIN STEAM LINE  
 SSE LOADS

LOCATION POINT	$M_{yy}$ (ft-lb)	$M_{zz}$ (ft-lb)	RSS MOMENT (in-lb) $\times 10^{-6}$
1	1,039,879	571,269	14.2
2	517,093	286,633	7.1
3	414,491	297,315	6.1
4	441,965	446,924	7.5
5	649,210	446,735	9.4
6	222,917	405,273	5.5
7	160,724	232,030	3.1
8	525,076	865,389	12.1
9	180,342	411,113	5.4
10	296,882	215,747	4.4
11	340,332	329,484	5.7
12	303,088	321,605	5.3
13	143,502	208,991	3.0
14	175,804	259,808	3.7
15	150,27	126,952	2.4
16	220,817	163,335	3.3
17	229,075	168,545	3.4
18	979,682	680,325	14.3

ALWR Main Steam  
Press + M =  $1 \times 10^{12}$   
Leakage Crack



J-Integral (in-lbs/in<sup>2</sup>)

Figure 1

ALWR Main Steam  
Press + M =  $1 \times 10^{**6}$   
2xLeakage Crack





Figure 2


ALWR Main Steam  
Press + M =  $5 \times 10^{**6}$   
Leakage Crack



J-Integral (in-lbs/in<sup>2</sup>)

Figure 3

ALWR Main Steam  
Press + M =  $5 \times 10^{**6}$   
2xLeakage Crack



J-Integral (in-lbs/in<sup>2</sup>)

Figure 4

SYSTEM 80<sup>+</sup>  
 Main Steam Line  
 LBU Piping Evaluation Diagram

- Stability Analysis points
- Piping location i




Figure 5

APPENDIX I

SHUTDOWN COOLING LINE

LEAK-BEFORE-BREAK EVALUATION

## APPENDIX I

### LBB EVALUATION OF THE PRELIMINARY SHUTDOWN COOLING LINE

The shutdown cooling line was analyzed as a 16.00-inch OD, 1.438-inch thick pipe. The material used in this evaluation is discussed in Appendix E. The pipe loads are developed and discussed in Appendix C. A piping evaluation diagram was constructed for the shutdown cooling line using the procedure described in Appendix E. The data for this diagram were generated from two stability analyses. The first was for a leakage crack length determined by pressure +  $M_1$  = (later). The stability plots are shown in Figures (1) and (2). The second stability analysis was for a leakage crack determined by pressure +  $M_2$  = (later). The stability plots are shown in Figures (3) and (4). These two stability analyses are used to construct the piping evaluation diagram, Figure (5).

The LBB evaluation of the shutdown cooling line is performed for the normally pressurized portion of the line, based on the Appendix C loads analysis for the anchor-to-anchor portion of the line.

From the first analysis, Figures (1) and (2):

$$\text{Analysis of a: } \sqrt{2} (\text{NOP} + \text{SSE}_1) = M_{\text{CRIT}}$$

$$\text{SSE}_1 = \frac{M_{\text{CRIT}} - \text{NOP}_1}{\sqrt{2}}$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_2) = M_{\text{CRIT}}$$

$$\text{SSE}_2 = M_{\text{CRIT}} - \text{NOP}$$

From the second analysis, Figures (3) and (4):

$$\text{Analysis of a: } \sqrt{2} (\text{NOP} + \text{SSE}_3) = M_{\text{CRIT}}$$

$$\text{SSE}_3 = \frac{M_{\text{CRIT}} - \text{NOP}}{\sqrt{2}}$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_4) = M_{\text{CRIT}}$$

$$\text{SSE}_4 = M_{\text{CRIT}} - \text{NOP}$$

Each of the calculated SSE and NOP values are plotted on the piping evaluation diagram, Figure (5).

The moment,  $M$ , will be determined (later). Figures (1) through (5) will be generated (later).

APPENDIX J

DIRECT VESSEL INJECTION  
LEAK-BEFORE-BREAK EVALUATION

## APPENDIX J

### LBB EVALUATION OF THE PRELIMINARY DIRECT VESSEL INJECTION

The direct vessel injection line was analyzed as a 10.75-inch OD, 1.0-inch thick pipe. The material used in this evaluation is discussed in Appendix E. The pipe loads are developed and discussed in Appendix D. A piping evaluation diagram was constructed for the direct vessel injection cooling line using the procedure described in Appendix E. The data for this diagram were generated from two stability analyses. The first was for a leakage crack length determined by pressure +  $M_1 =$  (later). The stability plots are shown in Figures (1) and (2). The second stability analysis was for a leakage crack determined by pressure +  $M_2 =$  (later). The stability plots are shown in Figures (3) and (4). These two stability analyses are used to construct the piping evaluation diagram, Figure (5).

From the first analysis, Figures (1) and (2):

$$\text{Analysis of a: } \sqrt{2} (\text{NOP} + \text{SSE}_1) = M_{\text{CRIT}}$$

$$\text{SSE}_1 = \frac{M_{\text{CRIT}} - \text{NOP}}{\sqrt{2}}$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_2) = M_{\text{CRIT}}$$

$$\text{SSE}_2 = M_{\text{CRIT}} - \text{NOP}$$

From the second analysis, Figures (3) and (4):

$$\text{Analysis of a: } \sqrt{2} (\text{NOP} + \text{SSE}_3) = M_{\text{CRIT}}$$

$$\text{SSE}_3 = \frac{M_{\text{CRIT}} - \text{NOP}}{\sqrt{2}}$$

$$\text{Analysis of 2a: } (\text{NOP} + \text{SSE}_4) = M_{\text{CRIT}}$$

$$\text{SSE}_4 = M_{\text{CRIT}} - \text{NOP}$$

Each of the calculated SSE and NOP values are plotted on the piping evaluation diagram, Figure (5).

The moment,  $M$ , will be determined (later). Figures (1) through (5) will be generated (later).

## APPENDIX K

### SAMPLE ASME CLASS 1 PIPING ANALYSIS

APPENDIX K  
SAMPLE ASME CLASS 1 PIPING ANALYSIS

Purpose

This appendix summarizes the results of a sample ASME Class 1 stress analysis. The System 80+ Shutdown Cooling line in the Reactor Building is used as the sample model. The piping included in the model is represented in the isometric sketch shown in Appendix C. The analysis model originates at the hot leg nozzle and terminates at the Reactor Building penetration. Anchors are modelled at these locations. The model also includes additional piping for the relief valve discharge to the holdup volume. All applicable design conditions, loadings, cases, and regulatory requirements are met in the analysis as defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 2.

Method

The piping is modelled as a three dimensional framework for analysis. Static analysis is performed by the Direct Stiffness Method and a simple Lumped Mass Idealization is used to determine mode shapes and frequencies for the dynamic analysis. This piping is analyzed using the SUPERPIPE computer program.

References and Design Inputs

1. ASME Boiler and Pressure Vessel Code, Section III, 1989.
2. Draft Distribution Systems Design Guide.
3. ABB-CE Letter dated 4/21/92 to R.W. Bonsall enclosing Preliminary Thermal Movements and SSE Seismic Anchor Movements.
4. ABB-Impell memo dated 5/21/92 to ABB-CE, Attn: R.A. Matzie enclosing System 80+ N-411 Spectra and SAM.
5. ABB-CE Letter dated 6/16/92 to R.W. Bonsall enclosing Vibratory Motion at Steam Generator Nozzles Due to Feedwater Line Break.
6. ABB-CE Letter dated 5/8/92 to R.W. Bonsall enclosing Thermal Transient Data.
7. System 80+ Shutdown Cooling System Piping and Instrumentation Diagram.
8. System 80+ Nuclear Island Detailed Arrangement Drawings.

### Results

The following pages provide the Class 1 code compliance check of ASME code equations for the pipe as modelled. As additional design information becomes available, it will be included in a final analysis. Results from the detailed analysis include pipe displacements, forces, moments, and stresses, support/restraint loads, and nozzle loads (anchor loads). Since the analysis is preliminary and design information is not available for allowable nozzle or penetration loads, it is not within the scope of the calculation to evaluate those loads.

TRIPELL CORPORATION 22E 05/31/90; SYSTEM: IBH-VH/NYS  
- SUPERPIPE VERSION

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SUB, X SUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COUPLING LINE

PAGE 858  
8-24-92 9:39:52

ASME SECTION III CLASS I CODE COMPLIANCE SUMMARY

IB-3e40 PRESSURE DESIGN OF COMPONENTS

MAXIMUM RATIO OF DESIGN PRESSURE TO EQ. 3 ALLOWABLE PRESSURE (RATIO OF 1.0 IS ACCEPTABLE)

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	SECTION NAME	PRESSURE RATIO
RUN1	3R	2A	STRP	16S140	0.89

SINCE THE RATIO DOES NOT EXCEED 1.00 THE CODE REQUIREMENTS FOR STRP, CRVP AND BELB COMPONENTS UNDER INTERNAL PRESSURE ARE MET

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

ASME SECTION III CLASS I CODE COMPLIANCE SUMMARY

NB-3652 CONSIDERATION OF DESIGN CONDITIONS

MAXIMUM RATIO OF EQ. 9 STRESS TO 1.50SM

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	STRESS RATIO
RUN1	3H	ZA	AWTT	AWTT-NOZ	SA376 TP316	0.43
RUN1	3R	ZA	STRP	16S140	SA376 TP316	0.43

SINCE THE RATIO DOES NOT EXCEED 1.0 THE CODE REQUIREMENTS FOR PRIMARY STRESSES ARE MET

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X058  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

ASME SECTION III CLASS I CODE COMPLIANCE SUMMARY

NB-3653, NB-3654 CONSIDERATION OF LEVEL A AND B SERVICE LIMITS

MAXIMUM CUMULATIVE USAGE FACTOR

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	USAGE FACTOR	
RUN1	1R	1	STRP	RIGID	SA376	TP316	0.00
RUN1	2L	2	STRP	RIGID	SA376	TP316	0.00
RUN1	2R	2	STRP	3XTK	SA376	TP316	0.00
RUN1	3L	2A	STRP	3XTK	SA376	TP316	0.00
RUN1	3H	2A	ANNT	ANNT-NOZ	SA376	TP316	0.00
RUN1	3R	2A	STRP	16S140	SA376	TP316	0.00
RUN1	4L	A01A	STRP	16S140	SA376	TP316	0.00
RUN1	4H	A01A	AMBW	AMBW	SA376	TP316	0.00
RUN1	4R	A01A	BELB	16S140	SA376	TP316	0.00
RUN1	5		BELB	16S140	SA376	TP316	0.00
RUN1	6L	A01B	BELB	16S140	SA376	TP316	0.00
RUN1	6H	A01B	AMBW	AMBW	SA376	TP316	0.00
RUN1	6R	A01B	STRP	16S140	SA376	TP316	0.00
RUN1	7		STRP	16S140	SA376	TP316	0.00
RUN1	8		STRP	16S140	SA376	TP316	0.00
RUN1	9		STRP	16S140	SA376	TP316	0.00
RUN1	10L	A1A	STRP	16S140	SA376	TP316	0.00
RUN1	10H	A1A	AMBW	AMBW	SA376	TP316	0.00
RUN1	10R	A1A	BELB	16S140	SA376	TP316	0.00
RUN1	11		BELB	16S140	SA376	TP316	0.00
RUN1	12L	A1B	BELB	16S140	SA376	TP316	0.00
RUN1	12M	A1B	AMBW	AMBW	SA376	TP316	0.00
RUN1	12R	A1B	STRP	16S140	SA376	TP316	0.00
RUN1	13		STRP	16S140	SA376	TP316	0.00
RUN1	14		STRP	16S140	SA376	TP316	0.00
RUN1	15		STRP	16S140	SA376	TP316	0.00
RUN1	16		STRP	16S140	SA376	TP316	0.00
RUN1	17		STRP	16S140	SA376	TP316	0.00
RUN1	18		STRP	16S140	SA376	TP316	0.00
RUN1	19L	X01A	STRP	16S140	SA376	TP316	0.00
RUN1	19H	X01A	AMBW	AMBW	SA376	TP316	0.00
RUN1	19R	X01A	BELB	16S140	SA376	TP316	0.00
RUN1	20		BELB	16S140	SA376	TP316	0.00
RUN1	21L	X01B	BELB	16S140	SA376	TP316	0.00
RUN1	21H	X01B	AMBW	AMBW	SA376	TP316	0.00

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X05B  
OPTIONAL RUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

ASME SECTION III CLASS 1 CODE COMPLIANCE SUMMARY

NB-3653, NB-3654 CONSIDERATION OF LEVEL A AND B SERVICE LIMITS (CONTD.)

MAXIMUM CUMULATIVE USAGE FACTOR

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	USAGE FACTOR
RUN1	21R	X01B	STRP	16S140	SA376 TP316	0.00
RUN1	22		STRP	16S140	SA376 TP316	0.00
RUN1	23		STRP	16S140	SA376 TP316	0.00
RUN1	24		STRP	16S140	SA376 TP316	0.00
RUN1	25		STRP	16S140	SA376 TP316	0.00
RUN1	26		STRP	16S140	SA376 TP316	0.00
RUN1	27		STRP	16S140	SA376 TP316	0.00
RUN1	28		STRP	16S140	SA376 TP316	0.00
RUN1	29		STRP	16S140	SA376 TP316	0.00
RUN1	30L	X02A	STRP	16S140	SA376 TP316	0.00
RUN1	30H	X02A	AMBH	AMBH	SA376 TP316	0.00
RUN1	30R	X02A	BELB	16S140	SA376 TP316	0.00
RUN1	31		BELB	16S140	SA376 TP316	0.00
RUN1	32L	X02B	BELB	16S140	SA376 TP316	0.00
RUN1	32H	X02B	AMBH	AMBH	SA376 TP316	0.00
RUN1	32R	X02B	STRP	16S140	SA376 TP316	0.00
RUN1	33L	X1	STRP	16S140	SA376 TP316	0.00
RUN1	34L	X03A	STRP	16S140	SA376 TP316	0.00
RUN1	34M	X03A	AMBH	AMBH	SA376 TP316	0.00
RUN1	34R	X03A	BELB	16S140	SA376 TP316	0.00
RUN1	35		BELB	16S140	SA376 TP316	0.00
RUN1	36L	X03B	BELB	16S140	SA376 TP316	0.00
RUN1	36H	X03B	AMBH	AMBH	SA376 TP316	0.00
RUN1	36R	X03B	STRP	16S140	SA376 TP316	0.00
RUN1	37L	XX1	STRP	16S140	SA376 TP316	0.00
RUN1	38		STRP	16S140	SA376 TP316	0.00
RUN1	39		STRP	16S140	SA376 TP316	0.00
RUN1	40		STRP	16S140	SA376 TP316	0.00
RUN1	41		STRP	16S140	SA376 TP316	0.00
RUN1	42		STRP	16S140	SA376 TP316	0.00
RUN1	43		STRP	16S140	SA376 TP316	0.00
RUN1	44		STRP	16S140	SA376 TP316	0.00
RUN1	45		STRP	16S140	SA376 TP316	0.00
RUN1	46L	X04A	STRP	16S140	SA376 TP316	0.00
RUN1	46H	X04A	AMBH	AMBH	SA376 TP316	0.00

ADVANCED LIGHT WATER REACTOR \*\*\* X1 Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

ASME SECTION III CLASS I CODE COMPLIANCE SUMMARY

NB-3653, NB-3654 CONSIDERATION OF LEVEL A AND B SERVICE LIMITS (CONTD.)

MAXIMUM CUMULATIVE USAGE FACTOR

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	USAGE FACTOR
RUN1	46R	X04A	BELB	16S140	SA376 TP316	0.00
RUN1	47		BELB	16S140	SA376 TP316	0.00
RUN1	48L	X04B	BELB	16S140	SA376 TP316	0.00
RUN1	48H	X04B	AMBH	AMBH	SA376 TP316	0.0J
RUN1	48R	X04B	STRP	16S140	SA376 TP316	0.00
RUN1	49L	X2	STRP	16S140	SA376 TP316	0.00
RUN1	50L	X05A	STRP	16S140	SA376 TP316	0.00
RUN1	50M	X05A	AMBH	AMBH	SA376 TP316	0.00
RUN1	50R	X05A	BELB	16S140	SA376 TP316	0.00
RUN1	51		BELB	16S140	SA376 TP316	0.00
RUN1	52L	X05B	BELB	16S140	SA376 TP316	0.00
RUN1	52M	X05B	AMBH	AMBH	SA376 TP316	0.00
RUN1	52R	X05B	STRP	16S140	SA376 TP316	0.00
RUN1	53L	3	STRP	16S140	SA376 TP316	0.00
RUN1	53H	3	AMTT	AMTT-VLV	SA376 TP316	0.00
RUN1	55M	5	AMTT	AMTT-VLV	SA376 TP316	0.00
RUN1	55R	5	STRP	16S140	SA376 TP316	0.00
RUN1	56L	A04A	STRP	16S140	SA376 TP316	0.00
RUN1	56M	A04A	AMBH	AMBH	SA376 TP316	0.00
RUN1	56R	A04A	BELB	16S140	SA376 TP316	0.00
RUN1	57		BELB	16S140	SA376 TP316	0.00
RUN1	58L	A04B	BELB	16S140	SA376 TP316	0.00
RUN1	58M	A04B	AMBH	AMBH	SA376 TP316	0.00
RUN1	58R	A04B	STRP	16S140	SA376 TP316	0.00
RUN1	59L	6	STRP	16S140	SA376 TP316	0.00
RUN1	59M	6	AMTT	AMTT-VLV	SA376 TP316	0.00

SINCE THE USAGE FACTOR DOES NOT EXCEED 1.0 THE CODE REQUIREMENTS FOR SECONDARY AND PEAK STRESSES ARE MET

ADVANCED LIGHT WATER REACTOR \*\*\* XI Z SNUB, X SNUB AT X05B  
OPTIONAL ROUTING 7 FROM DESI  
16" SHUTDOWN COOLING LINE

ASME SECTION III CLASS I CODE COMPLIANCE SUMMARY

NB-3656.1 CONSIDERATION OF LEVEL D SERVICE CONDITIONS - PERMISSIBLE PRESSURE

MAXIMUM RATIO OF LEVEL D PRESSURE TO EQ. 3 ALLOWABLE PRESSURE (RATIO OF 2.00 IS ACCEPTABLE)

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	SECTION NAME	PRESSURE RATIO
RUN1	3R	2A	STRP	16S140	0.89

SINCE THE RATIO DOES NOT EXCEED 2.00 THE CODE REQUIREMENTS FOR STRP, CRVP AND BELB COMPONENTS UNDER INTERNAL PRESSURE ARE MET

NB-3656.2 CONSIDERATION OF LEVEL D SERVICE CONDITIONS - ANALYSIS OF PIPING COMPONENTS

MAXIMUM RATIO OF EQ.9 STRESS TO 3.00SM

RUN NAME	SOP NO.	DCP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	STRESS RATIO
RUN1	4R	A01A	BELB	16S140	SA376 TP316	0.42

SINCE THE RATIO DOES NOT EXCEED 1.0 THE CODE REQUIREMENTS FOR PRIMARY STRESSES ARE MET

APPENDIX L

SAMPLE ASME CLASS 2/3 PIPING ANALYSIS

APPENDIX L  
SAMPLE ASME CLASS 2/3 PIPING ANALYSIS

Purpose

This appendix summarizes the results of a sample ASME Class 2/3 stress analysis which includes a postulated pipe break analysis. The System 80+ Feedwater economizer line in the Reactor Building is used as the sample model. The piping included in the model is represented in the isometric sketch shown on the following page. The analysis model originates at the Steam Generator nozzles and terminates at the Main Steam Valve House exterior wall. Anchors are modelled at these locations. All applicable design conditions, loadings, codes, and regulatory requirements are met in the analysis as defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 2.

Method

The piping is modelled as a three dimensional framework for analysis. Static analysis is performed by the Direct Stiffness Method and a simple Lumped Mass Idealization is used to determine mode shapes and frequencies for the dynamic analysis. This piping is analyzed using the SUPERPIPE computer program.



References and Design Inputs

1. ASME Boiler and Pressure Vessel Code, Section III, 1989.
2. Draft Distribution Systems Design Guide.
3. ABB-CE Letter dated 4/21/92 to R.W. Bonsall enclosing Preliminary Thermal Movements and SSE Seismic Anchor Movements.
4. ABB-Impell memo dated 5/21/92 to ABB-CE, Attn: R.A. Matzie enclosing System 80+ N-411 Spectra and SAM.
5. ABB-CE Letter dated 6/16/92 to R.W. Bonsall enclosing Vibratory Motion at Steam Generator Nozzles Due to Feedwater Line Break.
6. System 80+ Feedwater System Flow Diagram.
7. System 80+ Nuclear Island Detailed Arrangement Drawings.
8. CESSAR Design Certification, Chapter 3.6.

## Results

The following pages provide the Class 2/3 code compliance check of ASME code equations for the pipe as modelled. The postulated pipe break analysis results are also included, which provide the bases for design of possible jet shields and pipe whip restraints. CESSAR-DC Chapter 3.6 and the Distribution Systems Design Guide, Section 7.1.8 provide the criteria for protection against dynamic effects associated with the postulated rupture of piping. As additional design information becomes available, it will be included in a final analysis.

Results from the detailed analysis include pipe displacements, forces, moments, and stresses, support/restraint loads, and nozzle loads (anchor loads). Since the analysis is preliminary and design information is not available for allowable nozzle or penetration loads, it is not within the scope of the calculation to evaluate those loads.



IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90; SYSTEM: IBM-VM/MVS

PAGE 526  
8-26-92 19:17:44

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY FEEDWATER ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

ASME SECTION III CLASS 2/3 CODE COMPLIANCE SUMMARY (CONT'D.)

NORMAL (LEVEL A)

TEMPERATURE DISTRIBUTION: TEMP PRESSURE DISTRIBUTION: PRES

LOAD CASES SPECIFIED  
MA MB MC SAM MD  
HT-1

MAXIMUM STRESS RATIO OF EQUATION 8 TO 1.0SH

SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	ALLOW. STRESS	COMPUTED STRESS	STRESS RATIO
45L	122	BRED	28X24	SA106 B		2.000	22500.00	13369.01	0.594

UPSET (LEVEL B)

TEMPERATURE DISTRIBUTION: TEMP PRESSURE DISTRIBUTION: PRES

LOAD CASES SPECIFIED  
MA MB MC SAM MD  
HT-1 EQ-9  
SAMO

MAXIMUM STRESS RATIO OF EQUATION 9 TO 1.2SH

SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	ALLOW. STRESS	COMPUTED STRESS	STRESS RATIO
55	AB01	BTEE	24X20	SA106 B		1.488	26999.98	20623.55	0.764

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY FEEDWATER ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

ASME SECTION III CLASS 2/3 CODE COMPLIANCE SUMMARY (CONTD.)

FAULTED (LEVEL D)

TEMPERATURE DISTRIBUTION: TEMP PRESSURE DISTRIBUTION: PRES

LOAD CASES SPECIFIED  
MA MB MC SAM MD  
HT-1 EQ9F

MAXIMUM STRESS RATIO OF EQUATION 9F TO 2.4SH

SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	ALLOW. STRESS	COMPUTED STRESS	STRESS RATIO
55	A001	BTEE	24X20	SA106 B		1.488	45000.00	34750.91	0.772

SECONDARY (LEVEL A & B)

TEMPERATURE DISTRIBUTION: TEMP PRESSURE DISTRIBUTION: F FACTOR: 1.000

LOAD CASES SPECIFIED  
MA MB MC SAM MD  
TH-1

MAXIMUM STRESS RATIO OF EQUATION 10 TO 1.0SA

SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	ALLOW. STRESS	COMPUTED STRESS	STRESS RATIO
26R	A05A	BELB	24S80	SA106 B		1.855	22500.00	20888.55	0.928

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90; SYSTEM: IBM-VM/MVS

PAGE 544  
8-26-92 19:17:44

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY FEEDWATER ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

CLASS 2 BREAK LOCATIONS, CHECK TYPE C2BL

CHECKING REGION INDICATOR	=	(ALL CLASS 2 RUNS)
OUTPUT DETAIL INDICATOR	= DETL	(DETAILED PRINTOUT)
COMMENTARY INDICATOR	=	(NO COMMENTARY)
LOAD CASE INDICATOR	=	(RE-USE PREVIOUS CASES)
PRESSURE DISTRIBUTION INDICATOR	=	(RE-USE PREVIOUS DISTRIBUTIONS)
TEMPERATURE DISTRIBUTION INDICATOR	=	(RE-USE PREVIOUS DISTRIBUTIONS)
SECTION MODULUS INDICATOR	= EXTF	(AT EXTREME FIBFR)
PRESSURE TERM INDICATOR	= D/4T	(USE PD/4T)

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90; SYSTEM: IBM-VM/MVS

PAGE 545  
8-26-92 19:17:44

ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY FEEDWATER ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

LOAD SET SPECIFICATION

LOAD SET NAME	MA CASE	MB CASE	MC CASE	FACTOR A	FACTOR B	PRESSURE SET	TEMPERATURE SET FOR SH	TEMPERATURE SET FOR SC	MIN. PEAKS	PERCENT RANGE	TITLE
BREK	HT-1	EQ-9	TH-1	0.960	0.800	PRES	TEMP		3	10	

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/31/90 SYSTEM: IBM-VMS/VMS  
ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY FEEDWATER ANALYSIS  
DIKE ENGINEERING & SERVICES, INC.

BREAK LOCATION INFORMATION

RUN NO.	TOP NAME	DCP NAME	PROP. OF RUN	COMP NAME	CMP TYPE	SECTION NAME	MATERIAL NAME	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CALC. STRESS (PSI)	STRESS RATIO	SEQ A	SEQ B
RUN1																
1	A002	0.0000		BELB	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	18902.89	0.583	15	END	
2L	A01B	0.0187		BELB	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	13074.51	0.404	32		
2R	A01B	0.0187		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	10082.87	0.311			
3L	A02A	0.0423		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	4859.40	0.304			
3R	A02A	0.0423		BELB	20S60	SA106 B	BREK	1200.00	650.0	70.0	32400.00	12778.17	0.396	33		
4L	A02B	0.0610		BELB	20S60	SA106 B	BREK	1200.00	650.0	70.0	32400.00	14379.79	0.444	27		
4R	A02B	0.0610		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	10878.81	0.336			
5L	100	0.0848		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	10216.79	0.315			
5R	100	0.0848		ANHT												
5R	100	0.0848		VALV	SG612	SA106 B	BREK	1200.00	650.0	70.0	32400.00	12241.04	0.378	35		
6	101	0.0920		VALV	SG612	SA106 B						N/A				
7L	102	0.0991		VALV	SG612	SA106 B						N/A				
7R	102	0.0991		ANHT												
7R	102	0.0991		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	11259.54	0.348	37		
8L	A03A	0.1182		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	9608.19	0.297			
8R	A03A	0.1182		BELB	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	11376.77	0.351	36		
9L	A03B	0.1570		BELB	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	10701.73	0.370	38		
9R	A03B	0.1570		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	8923.56	0.275			

IMPELL CORPORATION 22E 05/31/901 SYSTEM: IBM-VM/PWS  
 SUPERPIPE VERSION ABB COMBUSTION ENGINEERING  
 SYSTEM 80+ PRELIMINARY FEEDWATER ANALYSIS  
 DURE ENGINEERING & SERVICES, INC.

PAGE 547  
 8-26-92 19:17:44

BREAK LOCATION INFORMATION (CONT'D.)

RUN NAME	SUP NO.	DCP NAME	PROP. OF RUN	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CALC. STRESS (PSI)	SE9 A	SE9 B
(RUN1) (CONT'D.)															
10L	105	0.1929		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	19796.27	0.611		
10R	105	0.1929		BRED-E	24x20	SA106 B	BREK	1200.00	650.0	70.0	32400.00	30535.24	0.942	2	2
11L	104	0.2009		BRED-E	24x20	SA106 B	BREK	1200.00	650.0	70.0	32400.00	21950.94	0.677	5	
11R	104	0.2009		BTEE-R	24x20	SA106 B						N/A			
12BL	AB01	0.2076		BTEE-R	24x20	SA106 B	BREK	1200.00	650.0	70.0	32400.00	18713.36	0.578		
12R	AB01	0.2076		BTEE-R	24x20	SA106 B	BREK	1200.00	650.0	70.0	32400.00	19825.25	0.612	7	
13L	105	0.2144		BTEE-R	24x20	SA106 B						N/A			
13R	105	0.2144		STRP	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	15135.30	0.467	23	
14L	A06A	0.2212		STRP	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	13943.25	0.450		
14R	A06A	0.2212		BELB	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	19140.45	0.591	10	
15L	A04B	0.2436		BELB	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	14540.38	0.449	25	
15R	A04B	0.2436		STRP	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	11357.74	0.351		
16	CS1	0.2549		STRP	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	9820.55	0.303	39	
17	CNS0	0.2744		STRP	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	9689.40	0.299	40	
18L	106	0.3342		STRP	24S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	11454.29	0.354		
18R	106	0.3342		AMTT											
19	107	0.3485		VALV	SG599	SA106 B						N/A			
				VALV	SG599	SA106 B						N/A			

ABAR COMBUSTION ENGINEERING  
S-STEM 80+  
PRELIMINARY FEEDWATER ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

BREAK LOCATION INFORMATION (CONT.)

IMPELL CORPORATION  
SUPERPIPE VERSION 22E 05/21/90; SYSTEM: IBM-PC/VMS  
ASB COMBUSTION ENGINEERING  
SYSTEM 60,  
PRELIMINARY FIREWATER ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

PAGE 549  
8-26-92 17-17-04

BREAK LOCATION INFORMATION (CONT'D.)

RUN NO.	SOP NAME	DCP NAME	GROUP OF RUN	COPD NAME	COPD TYPE	SECTION NAME	MATERIAL NAME	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CALC. STRESS (PSI)	STRESS RATIO	SEC A	SEC B
(CONT'D.)																
304	111	0.6237	LNTT	AMTT				BREK 1900.00	650.0	70.0	32400.00	18968.44	0.588	12		
308	111	0.6237	STRF	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	16205.79	0.500			
311	112	0.6738	STRP	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	12203.38	0.377			
314	112	0.6738	AMTT					BREK 1900.00	650.0	70.0	32400.00	13348.06	0.412	31		
318	112	0.6738	VALV	SG1177		SA106 B						N/A				
32	113	0.6851	VALV	SG1177		SA106 B						N/A				
331	114	0.7024	VALV	SG1177		SA106 B						N/A				
334	114	0.7024	AMTT					BREK 1900.00	650.0	70.0	32400.00	13539.50	0.418	29		
338	114	0.7024	STRP	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	11621.98	0.358			
341	A06A	0.7262	STRF	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	13432.79	0.414			
344	A06A	0.7262	BELB	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	15291.76	0.472	24		
351	B06B	0.7487	BELB	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	16555.50	0.511	20		
354	A06B	0.7487	STRP	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	14412.00	0.445			
361	115	0.7582	STRP	24S120		SA106 B		BREK 1900.00	650.0	70.0	32400.00	15126.32	0.467			
364	115	0.7582	AMTT					BREN 1900.00	650.0	70.0	32400.00	18452.76	0.570	15		
368	115	0.7582	VALV	SG1122		SA106 B						N/A				
37	116	0.7725	VALV	SG1122		SA106 B						N/A				
381	117	0.7868	VALV	SG1122		SA106 B						N/A				

IMPEL CORPORATION SUPERPIPE VERSION 22E CS-31/90; SYSTEM: IBH-VN/IVS  
 ABB COMBUSTION ENGINEERING  
 SYSTEM 80+  
 PRELIMINARY FEEDWATER ANALYSIS,  
 BWE ENGINEERING & SERVICES, INC.

PAGE 550  
 6-26-92 19:17:04

BREAK LOCATION INFORMATION (CONT'D.)

RUN NO.	SOP NO.	DEP NAME	PROP CT%	CORP 20%	COMP NAME	SECTION TYPE	MATERIAL NAME	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLIED STRESS (PSI)	CALC STRESS (PSI)	SEF A	SEF B
RUN1 (CONT'D.)															
36H	117	0.7868			AHTT		BREK	1900.00	650.0	75.0	32400.00	19590.91	0.589	31	
38R	117	0.7868	STRP	24S120	SA106 B	STRP	BREK	1900.00	650.0	75.0	32400.00	15966.08	0.493		
39L	118	0.7964	STRP	24S120	SA106 B	STRP	BREK	1900.00	650.0	70.0	32400.00	15622.12	0.482		
39H	118	0.7964	AHTT			AHTT	BREK	1900.00	650.0	70.0	32400.00	18555.21	0.573	14	
39R	118	0.7964	VALV	SG113	SA106 B	VALV						N/A			
40	119	0.6107	VALV	SG113	SA106 B	VALV						N/A			
41L	120	0.8250	VALV	SG113	SA106 D	VALV						N/A			
41H	120	0.8250	AHTT	STRP	24S120	AHTT	BREK	1900.00	650.0	70.0	32400.00	14470.13	0.447	26	
41R	120	0.8250	STRP	24S120	SA106 B	STRP	BREK	1900.00	650.0	70.0	32400.00	12376.39	0.382		
42L	A07A	0.8297	STRP	24S120	SA106 B	STRP	BREK	1900.00	650.0	70.0	32400.00	11590.59	0.358		
42R	A07A	0.8297	BELB	24S120	SA106 B	BELB	BREK	1900.00	650.0	70.0	32400.00	12756.04	0.394	34	
43L	A07B	0.2622	BELB	24S120	SA106 B	BELB	BREK	1900.00	650.0	70.0	32400.00	13580.87	0.419	28	
43R	A07B	0.6522	STRP	24S120	SA106 B	STRP	BREK	1900.00	650.0	70.0	32400.00	12164.25	0.375		
44L	121	0.8856	STRP	24S120	SA106 B	STRP	BREK	1900.00	650.0	70.0	32400.00	14159.09	0.437		
44R	121	0.8856	BRED-E	28X24	SA106 B	BRED-E	BREK	1900.00	650.0	70.0	32400.00	21219.51	0.655	6	
45L	122	0.8951	BRED-E	28X24	SA106 B	BRED-E	BREK	1900.00	650.0	70.0	32400.00	17332.87	0.535	19	
45R	122	0.8951	STRP	22SPEC	SA106 B	STRP	BREK	1900.00	650.0	70.0	32400.00	12235.76	0.378		
46	ANC7	1.0000	STRP	26SPEC	SA106 B	STRP	BREK	1900.00	650.0	70.0	32400.00	18075.00	0.558	16	

## BREAK LOCATION INFORMATION (CONT'D.)

RUN NAME	SUP NO.	DCP NAME	PROP. OF RUN	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOM. STRESS (PSI)	CALC. STRESS (PSI)	STRESS RATIO	SEQ A	SEQ B
R242																
4.7	B002	0.0000		BELB	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	27119.48	0.837	1	END	
48L	B01B	0.1439		BELB	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	17451.09	0.539	3		
49R	B01B	0.1459		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	12516.07	0.366			
49L	B02A	0.3243		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	10663.66	0.529			
49R	B02A	0.3243		BELB	20S30	SA106 B	BREK	1200.00	650.0	70.0	32400.00	16136.54	0.436	5		
50L	B02B	0.4686		BELB	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	18842.22	0.582	2		
50R	B02B	0.4686		STRP	20Sd0	SA106 B	BREK	1200.00	650.0	70.0	32400.00	13306.96	0.411			
51L	B02	0.6518		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	12381.62	0.382			
51R	Z02	0.6518		AMTT	AMTT	SG651	BREK	1200.00	650.0	70.0	32400.00	15718.13	0.465	4		
52	Z02	0.70567		VALV	SG651	SA106 B	N/A									
				VALV	SG651	SA106 B	N/A									
E3L	Z02	0.76317		VALV	SG651	SA106 B	N/A									
53H	Z02	0.76117		AMTT	AMTT	SG651	BREK	1200.00	650.0	70.0	32400.00	13584.95	0.419	6		
53R	Z02	0.76117		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	11151.39	0.344			
54L	Z03	0.9461		STRP	20S80	SA106 B	BREK	1200.00	650.0	70.0	32400.00	9546.52	0.295	8		
54R	Z03	0.9461		BTEE-B	24X20	SA106 B	N/A									
55	A001	1.0002		BTEE-C	24X20	SA106 B	BREK	1200.00	650.0	70.0	32400.00	10071.69	0.311	7	END	

IMPELL CORPORATION  
SUPERPIPE VERSION 27E 05/31/901 SYSTEM: 12H-VH/MS  
ABB COMBUSTION ENGINEERING  
SYSTEM 80+  
PRELIMINARY FEEDWATER ANALYSIS  
DUKE ENGINEERING & SERVICES, INC.

PAGE 552  
8-26-92 19:17:44

BREAK LOCATION INFORMATION (CONT'D.)

RUN NO.	SOP NAME	DCP NAME	PROP. OF RUN	COPP. NAME	COMP. TYPE	SECTION NAME	MATERIAL NAME	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CALC. STRESS (PSI)	STRESS RATIO (PSI)	SEQ A	SEQ B
56	RSP0	0.0000		STRP	3010	SA106 B		BREK 1200.00	650.0	70.0	32400.00	7431.4	0.229	1	END	
57	CD01	0.8889		STRP	3010	SA106 B		BREK 1200.00	650.0	70.0	32400.00	6610.51	0.204	2		
58	301	1.0000		Strp	3010	SA106 B		BREK 1200.00	650.0	70.0	32400.00	6600.00	0.204	3	END	
RUNS																
59	CD01	0.0000		FLXC	FLXC	SA106 B							N/A			
60	401	1.0000		FLXC	FLXC	SA106 B							N/A			

APPENDIX M

SAMPLE HVAC DUCTWORK ANALYSIS

APPENDIX M  
SAMPLE HVAC DUCTWORK ANALYSIS

Purpose

This appendix reports the results of the stress analysis of a sample section of System 80+ Annulus Ventilation ductwork. The analysis determines support/restraint (S/R) locations, S/R loads (including seismic), and provides a seismic qualification of the ductwork. The ductwork included in the model is represented in the sketch that follows. All applicable design conditions, loadings, codes, and regulatory requirements are defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 1.

Method

The ductwork is modelled as a three dimensional framework for analysis. The conservative static coefficient method is used to preclude determination of the system natural frequency. Instead, the system response is assumed to be the peak of the required response spectra. A 5% damped response spectra is utilized. This response is then multiplied by a static coefficient of 1.5, which takes into account the effects of both multifrequency excitation and multimode response. Having determined the peak response accelerations, the S/R loadings are determined as follows:

1. Determination of seismic coefficients,  $S_{SSE}$  and  $S_{OBE}$ .
2. Layout of support/restraints (see attached sketch).
3. Seismic qualification of ductwork spans.
4. Calculation of support/restraint loads (normal, upset, emergency, and faulted).


References and Design Inputs

1. Draft Distribution Systems Design Guide.
2. ABB-Impell Letter dated 6/10/92 to DE&S, Attn: S.R. McDowell enclosing System 80+ Node 169 2% and 5% Spectra Preliminary Model.
3. System 80+ Annulus Ventilation System Air Flow Diagram.
4. System 80+ Nuclear Island Detailed Arrangement Drawings.
5. ANSI/ANS N690-1984, Nuclear Facilities-Steel Safety-Related Structures for Design Fabrication and Erection.

## Results

Results of the analysis are shown below.

### 1. Figure



### 2. Static coefficients

$$S_{SSE} = 5.55$$

$$S_{OBE} = 2.5$$

### 3. Support/restraint layout - See figure above

### 4. Seismic duct qualification

a. Allowable stress = 16600 psi

b. Stress results

Condition	Max. Stress	Allow. Stress
Service Level A	281 psi	16,600 psi
Service Level B	2262 psi	16,600 psi
Service Level C	4679 psi	16,600 psi x 1.6
Service Level D	Qualified by inspection	16,600 psi x 1.7

5. Support/restraint loads (normal, upset, emergency, and faulted) - See table below for Support No. 3.

	DIRECTION		
	Lateral	Vertical	Axial
Normal Load	0 lb	858.32 lb	0 lb
Upset Load	± 2145.8 lb	3004.12 lb - 1287.48 lb	± 4489.5 lb
Emergency Load	± 4763.68 lb	5622.0 lb - 3905.36 lb	± 9966.69 lb
Faulted Load	same as Emergency Load	same as Emergency Load	same as Emergency Load

APPENDIX N

SAMPLE CABLE TRAY ANALYSIS

APPENDIX N  
SAMPLE CABLE TRAY ANALYSIS

Purpose

This appendix reports the results of the stress analysis of a sample section of System 80+ cable tray. The analysis determines support/restraint (S/R) locations, S/R loads (including seismic), and provides a seismic qualification of the cable tray. The cable tray included in the model is represented in the sketch that follows. All applicable design conditions, loadings, codes, and regulatory requirements are defined in the System 80+ Certification Program Draft Distribution Systems Design Guide, Reference 1.

Method

The cable tray is modelled as a three dimensional framework for analysis. The conservative static coefficient method is used to preclude determination of the system natural frequency. Instead, the system response is assumed to be the peak of the required response spectra. A 5% damped response spectra is utilized. This response is then multiplied by a static coefficient of 1.5, which takes into account the effects of both multifrequency excitation and multimode response. Having determined the peak response accelerations, the S/R loadings are determined as follows:

1. Determination of seismic coefficients,  $S_{SS}$  and  $S_{OS}$ .
2. Layout of support/restraints (see attached sketch).
3. Seismic qualification of cable tray spans.
4. Calculation of support/restraint loads (normal, upset, emergency, and faulted).


References and Design Inputs

1. Draft Distribution Systems Design Guide.
2. ABB-Impell Letter dated 6/10/92 to DE&S, Attn: S.R. McDowell enclosing System 80+ Node 169 2% and 5% Spectra Preliminary Model.
3. National Electrical Manufacturers Association Standards Publication No. VE 1-1984, Metallic Cable Tray Systems.
4. System 80+ Nuclear Island Detailed Arrangement Drawings.
5. ANSI/ANS N690-1984, Nuclear Facilities-Steel Safety-Related Structures for Design Fabrication and Erection.

## Results

Results of the analysis are shown below.

### 1. Figure



### 2. Static coefficients

$$S_{SSE} = 1.575$$

$$S_{OBE} = 0.709$$

### 3. Support/restraint layout - See figure above

### 4. Seismic cable tray qualification

a. Allowable stress = 36000 psi

b. Stress results

Condition	Max. Stress	Allow. Stress
Service Level A	4,248 psi	36,000 psi
Service Level B	16,964 psi	36,000 psi
Service Level C	32,496 psi	36,000 psi x 1.6
Service Level D	Qualified by inspection	36,000 psi x 1.7

5. Support/restraint loads (normal, upset, emergency, and faulted) - See table below for Support No. 3.

	DIRECTION		
	Lateral	Vertical	Axial
Normal Load	0 lb	400 lb	0 lb
Upset Load	± 283.6 lb	683.6 lb	± 886.25 lb
Emergency Load	± 630 lb	1030 lb - 230 lb	± 1968.75 lb
Faulted Load	same as emergency load	same as emergency load	same as emergency load