

KEY

- MORAINES
- KANKAKEE TORRENT AREAS
- LAKE CHICAGO AND OUTLET
- LIMIT OF WISCONSINAN GLACIATION IN ILLINOIS



SCALE
0 5 10 20 MI.

- NOTES**
1. THESE PHYSIOGRAPHIC SECTIONS AND SUBSECTIONS ARE PART OF THE CENTRAL LOWLAND PHYSIOGRAPHIC PROVINCE.
 2. THE AREAS SHOWN IN WHITE ARE PRIMARILY GLACIAL DRIFT AND GROUND MORAINE EXCEPT FOR THE WISCONSIN DRIFTLESS SECTION AND PARTS OF THE GREEN RIVER LOWLAND.
 3. COMPILED FROM:
 - A. LEIGHTON, M.M., EKBLAW, G.E., AND HORBEG, C.L. 1948, PHYSIOGRAPHIC DIVISIONS OF ILLINOIS, ILLINOIS STATE GEOLOGIC SURVEY, REPORT OF INVESTIGATIONS 129.
 - B. EKBLAW, GEORGE, 1960, GLACIAL MAP OF NORTHEASTERN ILLINOIS; ILLINOIS GEOLOGICAL SURVEY.
 - C. FRYE, J.C., ET AL., 1969, GLACIAL TILLS OF NORTHWESTERN ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 457.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-1

REGIONAL GLACIAL MAP AND
PHYSIOGRAPHIC DIVISIONS




NOTE
 STRATIGRAPHIC COLUMN OF THE
 PLEISTOCENE DEPOSITS OF ILLINOIS
 IS SHOWN ON FIGURE 2.5-5.

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-2

REGIONAL STRATIGRAPHIC COLUMN

REFERENCE:
 ILLINOIS STATE GEOLOGICAL SURVEY, 1967,
 GEOLOGIC MAP OF ILLINOIS.



LEGEND

- T TERTIARY ROCKS
- K CRETACEOUS ROCKS
- J JURASSIC ROCKS
- Cp PENNSYLVANIAN ROCKS
- Cm MISSISSIPPIAN ROCKS
- D DEVONIAN ROCKS
- S SILURIAN ROCKS
- O ORDOVICIAN ROCKS
- C CAMBRIAN ROCKS
- Pc PRECAMBRIAN ROCKS

NOTE:


COMPILED FROM:

- A. STOSE, G.W., 1932, GEOLOGICAL MAP OF THE UNITED STATES, UNITED STATES GEOLOGICAL SURVEY, REPRINTED 1960.
- B. WILLMAN, H.B., ET AL, 1967, GEOLOGIC MAP OF ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY.
- C. P. B. KING AND H.B. BECKMAN 1974, GEOLOGIC MAP OF THE UNITED STATES, UNITED STATES GEOLOGICAL SURVEY.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-3

REGIONAL BEDROCK GEOLOGY MAP



NOTES

1. REFER TO FIGURE 2.5-7 FOR LOCATION OF REGIONAL GEOLOGIC CROSS SECTION.
2. MODIFIED FROM: GROUNDWATER GEOLOGY IN EAST CENTRAL ILLINOIS BY L.F. SELKREGG AND J.P. KEMPTON, ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 248, 1958.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-4

REGIONAL GEOLOGIC CROSS SECTIONS

TIME STRATIGRAPHY		ROCK STRATIGRAPHY				SOIL STRATIGRAPHY		
QUATERNARY SYSTEM	PLEISTOCENE SERIES	Holocene Stage			Lake Michigan Fm. Ravinia Sand M. Waukegan M. Lake Forest M. Winnethka M. Sheboygan M. Wilmette B. South Haven M.	Modern Soil		
		Wisconsinan Stage	Valderan Substage	Pearia Loess	Richland Loess	Wadsworth T.M. Hoeger T.M. Yorkville T.M. Malden T.M. Tiskilwa T.M. Delavan T.M. Lee Center T.M. Esmond T.M.	Snider T.M. Batestown T.M. Glenburn T.M. Oakland T.M.	Jules Soil
			Twocreekan Substage					
			Woodfordian Substage	Morton Loess				Fermdale Soil
			Farmdalian Substage	Robein Silt	Peddicord Fm.			
			Altonian Substage	Roxana Silt Meadow Loess M. McDonough Loess M. Markham Silt M.	Winnebago Fm. Capron T.M. Plano Silt M. Argyle T.M.			Pleasant Grove Soil Chopin Soil
		Sangamonian Stage			Berry Clay Member Glasford Fm. Radnor T.M. Sterling T.M. Toulon M. Winslow T.M. Hagerstown M. Raby Silt M. Hulick T.M. Ogle T.M. Vandalia T.M. Duncan Mills M. Mulberry Grove M. Kellerville T.M. Smithboro T.M.		Sangamon Soil	
		Illinoian Stage	Jubileean Substage	Loveland Silt	Teneriffe Silt	Banner Fm. Liere Clay Member Tilton T.M. Hillery T.M. Horkness Silt M. Harmattan T.M. Belgium M. Senkasy Sand M. Hegeler T.M. Mahomet Sand M.	Pearl Fm.	Pike Soil
			Monican Substage					
			Liman Substage					
Yarmouthian Stage					Yarmouth Soil			
Kansan Stage								
Aftonian Stage					Afton Soil			
Nebraskan Stage		Enion Formation	Mounds Gravel	Gravel Gravel				

Fm.=Formation M.=Member T.M.=Till Member B.=Bed


REFERENCE

1. N.S. WILLMAN, ET. AL., HANDBOOK OF ILLINOIS STRATIGRAPHY, BULLETIN 98, ILLINOIS STATE GEOLOGICAL SURVEY, URBANA, 1970.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-5

STRATIGRAPHIC COLUMN OF THE PLEISTOCENE DEPOSITS OF ILLINOIS




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-6

BEDROCK VALLEY MAP OF ILLINOIS

NOTE:

MODIFIED FROM: GLACIAL DRIFT IN ILLINOIS: THICKNESS AND CHARACTER, ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 490, URBANA, 1976.



KEY


- APPROXIMATE AXIS OF BEDROCK VALLEY
- A—A' LINE OF CROSS SECTION ON FIGURE 2.5-4.
- B—B' LINE OF CROSS SECTION ON FIGURE 2.5-4.
- DELINEATION OF LA SALLE ANTICLINAL BELT



- NOTES:**
1. SEE FIGURE 2.5-4 FOR REGIONAL GEOLOGIC CROSS SECTIONS.
 2. MODIFIED FROM: SELKREGG, L.F. AND J.P. KEMPTON, GROUNDWATER IN EAST CENTRAL ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 248, 1958.


**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

**FIGURE 2.5-7
MAHOMET BEDROCK VALLEY AND
ITS TRIBUTARIES**



NOTES:


1. STRUCTURE CONTOUR LINES ARE CONSTRUCTED ON THE TOPS OF DIFFERENT LITHOLOGIC UNITS IN DIFFERENT LOCALITIES. THE NAMES AND BOUNDARIES OF THESE CONTOURED UNITS ARE DELINEATED BY DOTTED LINES ON THE MAP.
2. MODIFIED FROM: UNITED STATES GEOLOGICAL SURVEY AND THE AMERICAN ASSOCIATION OF PETROLEUM GEOLOGISTS, 1962, TECTONIC MAP OF THE UNITED STATES, AND ILLINOIS STATE GEOLOGICAL SURVEY, 1976, CIRCULAR 491, PLUM RIVER FAULT ZONE IN NORTHWESTERN ILLINOIS.
3. FOLDED STRUCTURES IN THE REGIONAL AREA ARE SHOWN IN MORE DETAIL ON FIGURE 2.5-9. FAULTED STRUCTURES IN THE REGIONAL AREA ARE SHOWN IN MORE DETAIL ON FIGURE 2.5-10.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-8

REGIONAL TECTONIC MAP



FOLDED STRUCTURES IN THIS AREA ARE SHOWN IN FIGURE 2.5-11

LEGEND

- + ANTICLINE
- ⊕ SYNCLINE

NOTE:

DATA ARE SUMMARIZED IN TABLE 2.5-1.

COMPILED FROM:

- A. UNITED STATES GEOLOGICAL SURVEY AND THE AMERICAN ASSOCIATION OF PETROLEUM GEOLOGISTS, 1962, TECTONIC MAP OF THE UNITED STATES.
- B. BUSCHBACH, T.G., 1973, CLINTON FSAR ATTACHMENT D2.9
- C. ILLINOIS GEOLOGICAL SURVEY, 1967, GEOLOGIC MAP OF ILLINOIS
- D. CLEGG, K.E., 1965, SUBSURFACE GEOLOGY AND COAL RESOURCES OF THE PENNSYLVANIAN SYSTEM IN CLARK AND EDGAR COUNTIES, ILLINOIS ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 380.
- E. MCCracken, M.M., 1971, STRUCTURAL FEATURES OF MISSOURI; MISSOURI GEOLOGICAL SURVEY, REPORT OF INVESTIGATIONS NUMBER 49
- F. MCGINNIS, L.D., AND BRADBURY, V.C., 1964, AEROMAGNETIC STUDY OF THE HARDIN COUNTY AREA, ILLINOIS; ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 363.
- G. HOLATA, D.R. AND BUSCHBACH, T.G., 1976, PLUM RIVER FAULT ZONE OF NORTHWESTERN ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY, CIRCULAR 401.
- H. HARRIS, S.E. JR. AND PARKER, M.C., 1964 STRATIGRAPHY OF THE OSAGE SERIES IN SOUTHEASTERN IOWA, IOWA GEOLOGICAL SURVEY, REPORT OF INVESTIGATION 1.
- I. TREWORTHY, J.D., 1981, STRUCTURAL FEATURES IN ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 519


MILES



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-9

MAJOR FOLDS



LEGEND

- TRACE OF PROVEN FAULT
DOWNTHROWN SIDE
- TRACE OF INFERRED FAULT
DOWNTHROWN SIDE

NOTES:


1. STRUCTURAL NAMES IN PARENTHESES ARE ASSIGNED BY DAMLS & MOORE
2. DOWNTHROWN SIDE NOT SHOWN FOR ALL INDIVIDUAL FAULTS IN FAULT SYSTEMS.
3. COMPILED FROM:
 - A. UNITED STATES GEOLOGICAL SURVEY AND THE AMERICAN ASSOCIATION OF PETROLEUM GEOLOGISTS, 1962, TECTONIC MAP OF THE UNITED STATES.
 - B. THINAITES, F. T., 1957, PURIFIED PRE-CAMBRIAN OF WISCONSIN : UNIVERSITY OF WISCONSIN AND WISCONSIN GEOLOGICAL SURVEY.
 - C. ILLINOIS STATE GEOLOGICAL SURVEY, 1967, GEOLOGIC MAP OF ILLINOIS.
 - D. BUSCHBACH, T. C., AND G. E. HEIM, 1972, PRELIMINARY GEOLOGIC INVESTIGATIONS OF ROCK TUNNEL SITES FOR FLOOD AND POLLUTION CONTROL IN THE GREATER CHICAGO AREA: ILLINOIS GEOLOGICAL SURVEY, ENVIRONMENTAL GEOLOGY NOTES NO. 52, P. 26.
 - E. GREEN, D. A., 1957, TRENTON STRUCTURE IN OHIO, INDIANA AND NORTHERN ILLINOIS: BULLETIN AMERICAN ASSOCIATION OF PETROLEUM GEOLOGISTS, V. 41, NO. 4, P. 29.
 - F. BACKGROUND MATERIALS AND PROCEEDINGS OF SYMPOSIUM ON FUTURE PETROLEUM POTENTIAL OF N. P. C. REGION 9: ILLINOIS STATE GEOLOGICAL SURVEY, ILLINOIS PETROLEUM 95 AND 96, 1971.
 - G. MEYL, A. V., ET AL., 1965, REGIONAL STRUCTURE OF THE SOUTHEAST MISSOURI AND ILLINOIS-KENTUCKY MINERAL DISTRICTS, UNITED STATES GEOLOGICAL SURVEY BULLETIN 1202-B.
 - H. OSTROM, M. E., 1976, WISCONSIN GEOLOGICAL AND NATURAL HISTORY SURVEY, UNPUBLISHED COMMUNICATION.
 - I. ISLATA, B. R. AND BRIDGEMAN, T. C., PLUM RIVER FAULT ZONE IN NORTHWESTERN ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY, CIRCULAR 400.
 - J. MCKENNA, L. D., 1964, CRUSTAL TECTONICS AND PRECAMBRIAN BASEMENT IN NORTHWESTERN ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY, REPORT OF INVESTIGATIONS NO. 1.
 - K. OSTROM, M. E., 1976, CLINTON PS&A ATTACHMENT D2.9
 - L. OSTROM, M. E., 1971, GEOLOGIST FIELD TRIP SOUTHWESTERN DADE COUNTY, WISCONSIN GEOLOGICAL AND NATURAL HISTORY SURVEY.
4. DATA ARE SUMMARIZED IN TABLE 2.5-2



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-10

MAJOR FAULTS




LEGEND

- 100— Structure contours on top of Glenwood Formation
- - -100- - Structure contours on top of Glenwood Formation, inferred
- - - - - Top of Glenwood Formation eroded
- - - - - State Line
- - - - - Township Lines
- - - - - County Lines
- - - - - Trace of Fault
- ⊥ Downthrust Side

NOTE


1. Modified from Kolata D.R. and Buschbach T.C., Plum River Fault Zone of Northwestern Illinois, Illinois State Geological Survey Circular 491, 1976.
2. The location of this area with respect to the regional area is shown on Figure 2.5-9.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-11


PLUM RIVER FAULT ZONE AND ASSOCIATED
STRUCTURES IN ILLINOIS



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

**FIGURE 2.5-12
REGIONAL BOUGUER GRAVITY ANOMALY MAP**

Circular 324 - Plate 1




KEY
 6300 Magnetic contour lines, interval 100 gammas.

0 10 20 30 40
 Scale in Miles

MODIFIED FROM: MCGINNIS, L. D., AND HEIGOLD, P. C., REGIONAL MAPS OF VERTICAL MAGNETIC INTENSITY IN ILLINOIS, ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 324, 1961.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT
 FIGURE 2.5-13
 REGIONAL VERTICAL MAGNETIC ANOMALIES



LEGEND:
 E-6 BORING LOCATION
 E — E' SUBSURFACE SECTION LOCATION









- NOTES:**
1. REFER TO FIGURES 2.5-278 THROUGH 2.5-280 FOR SUBSURFACE SECTIONS.
 2. REFER TO FIGURES 2.5-80, 2.5-83, 2.5-96, AND 2.5-145 THROUGH 2.5-151 FOR LOGS OF BORINGS.
 3. BASE MAP MODIFIED FROM: MAROA, ILLINOIS 15 MINUTE QUADRANGLE (1:62500) UNITED STATES GEOLOGICAL SURVEY, 1957.

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-14
 SITE VICINITY MAP



LEGEND

-  MORAINIC RIDGES
 -  LAKEBED SEDIMENTS
 -  ICE-CONTACT STRATIFIED DRIFT
 -  ALLUVIATED VALLEYS AND OUTWASH PLAINS
 -  GROUND MORAINE
 -  25
 -  8
 -  4
- APPROXIMATE THICKNESS OF LOESS
25, 8, 4 FOOT CONTOURS


**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-15

SURFICIAL GEOLOGY MAP

MODIFIED FROM: THORNBURN, T.H., SURFACE DEPOSITS OF ILLINOIS,
UNIVERSITY OF ILLINOIS ENGINEERING EXPERIMENT STATION, CIVIL
ENG. STUDIES, SOIL MECHANICS SERIES 3.

E 364,000



NOTES:

1. REFER TO FIGURES 2.5-19 THROUGH 2.5-73 AND FIGURES 2.5-162 THROUGH 2.5-242 FOR LOGS OF BORINGS.
2. REFER TO FIGURE 2.5-284 FOR SUBSURFACE SECTIONS J-J' AND K-K'.

LEGEND:


- ◆ LOCATION OF BORINGS THAT EXTEND TO BEDROCK
- BORING LOCATION
- (P) INDICATES PIEZOMETER INSTALLATION
- INDICATES ALL CATEGORY 1 STRUCTURES
- SUBSURFACE SECTION LOCATION

NOTE: UNIT 2 HAS BEEN CANCELLED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-16

PLOT PLAN - ULTIMATE HEAT SINK



LEGEND:

- ◆ BORING LOCATION
- PRIVATE WATER WELL
- ELEVATION OF TOP OF BEDROCK
- CONTOUR ON TOP OF BEDROCK SURFACE
CONTOUR INTERVAL 25 FEET

NOTE:

1. BASE MAP MODIFIED FROM: MARGA, ILLINOIS 15 MINUTE QUADRANGLE (1:62,500), UNITED STATES GEOLOGICAL SURVEY, 1957.
2. SEE FIGURE 2.5-282 FOR ENLARGED VIEW OF BORINGS IN PLANT AREA.
3. BEDROCK CONTOURS ADOPTED FROM "GEOLOGICAL SIGNIFICANCE OF THE GRAVITY FIELDS IN THE DEWITT-MCLEAN COUNTY AREA, ILLINOIS BY P. C. HEIGOLD, L. D. MCGINNIS AND R. H. HOWARD; ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 369, 1964, WITH MODIFICATIONS FROM BOREHOLE DATA.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-17
CONTOURS ON BEDROCK SURFACE
SITE VICINITY

TIME STRATIGRAPHY			STRATIGRAPHIC UNITS		
			UPLAND	VALLEY	
Quaternary System	Pleistocene Series	Holocene Stage	Richland Loess	Cahokia	
				Peyton Colluvium	
		Wisconsinan Stage	Valderan Substage	Alluvium	Henry Formation
			Twocreekan Substage		
			Woodfordian Substage	Wedron Formation	
			Farmdalian Substage	Robein Silt	
			Altonian Substage		
		Sangamonian Stage	weathered Glasford Formation	unaltered Glasford Formation	
		Illinoian Stage			
		Yarmouthian Stage	Unconformity		Banner Formation
Kansan Stage			Bond Formation		
Pennsylvanian System			McLeansboro Group	Modesto Formation	
			Kewanee Group	Carbondale Formation	

STRATIGRAPHIC DESCRIPTION		
STRATIGRAPHIC UNIT	APPROXIMATE THICKNESS*	GENERAL DESCRIPTION
Cahokia Alluvium	0-35 ft.	Alluvium and silty clay (CL, SM or ML)
Peyton Colluvium	0-10 ft.	
Richland Loess	0-10 ft.	Loess, clayey silt (ML or CL), may be leached, soft.
Henry Formation	0-35 ft.	Stratified sand and gravel (SP, GP, SM).
Wedron Formation	20-55 ft.	Till, clayey sandy silt till (ML or CL), stiff to very stiff, with lenses of stratified sand, gravel, or silt.
Robein Silt	0-2 ft.	Silt (ML or CL), black or dark brown, massive, soft.
weathered Glasford Formation	10-15 ft.	Silt and silty clay (ML or CL), weathered, soft; and till (ML or CL), weathered, soft with lenses of sand or silt; black, dark brown, green.
unaltered Glasford Formation	90-140 + ft.	Till, gray sandy silt (ML or SM), hard. Upper part may contain lenses of stratified sand, silt, or gravel.
Banner Formation	25-105 ft.	Complex sequence, variably consisting of glaciolactustrine silt (ML or CL), hard; clay till (ML), hard; may be undelain by very dense sand (Mahomet Sand Member), 0-140 ft. thick.
McLeansboro Group and Kewanee Group	Not Completely Penetrated	Alternating beds of shale, siltstone, limestone, and coal bedrock.

NOTES:

1. The stratigraphic units are discussed in detail in subsection 2.5.1.2 and Attachment C2.5.
2. Figure 2.5-274 shows a comparison of stratigraphic nomenclature used in the FSAR, PSAR, and boring logs.
3. Excavations for the Clinton Power Station did not extend below the unaltered Glasford Formation.
4. Borings for the Clinton Power Station did not extend below rocks of the Carbondale Formation.
5. Illinoian-age till of the Glasford Formation was subjected to a significant period of weathering during the Sangamonian Stage and Altonian Substage.
6. Deposits of Cahokia Alluvium and Henry Formation were not differentiated; reported approximate thicknesses of each unit represents a combined thickness for both deposits. The Cahokia Alluvium is Holocene and quite possibly, in part, Valderan/Two-creekan in age; the Henry Formation is Woodfordian (probably early) in age. The Wedron Formation is probably early Woodfordian.

7. The Holocene Stage is represented by a significant period of weathering and development of agricultural soil profiles.
8. Vertical scale does not represent either relative thickness of stratigraphic units or relative duration of time interval.
9. Standard Unified Soil Classification symbols are used.
10. Locally, the Peyton Colluvium rests directly on Glasford Formation.

*Based on data from excavations and boring logs.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-18
SITE STRATIGRAPHIC COLUMN

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS RUN OR REFERRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 pcf	σ_3 pcf	q_u pcf	q_p pcf		
680								1500	
670	SA							23.3	102
660								4500+	131
650								4500+	137
640								4500+	131
630								4500+	136
620								4500+	137
610	MA							4500+	9.6
600								4500+	139
590								4500+	

BORING P-1

SURFACE ELEVATION 675.9

BLOW COUNTS SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
4	ML	BLACK CLAYEY SILT WITH TRACE OF SAND AND ORGANIC MATTER - (TOPSOIL)
1	ML	Top of Salt Creek Alluvium
14	GP SP	MOTTLED BROWN AND GRAY SANDY SILT WITH CLAY (SOFT)
23	GP SP	BROWN GRAVELLY FINE TO COARSE SAND (MEDIUM DENSE)
72	ML	Top of Illinoian Glacial Till
120/6"	ML	GRAY CLAYEY SILT WITH SAND AND OCCASIONAL GRAVEL (VERY STIFF)
125/6"	ML	GRADES TO HARD
150/5"	ML	
132	ML	
100/6"	ML	5" SEAM OF GRAVEL
58	ML	
47	ML	
34	ML	
55	ML	
48	ML	
136	ML	
89	ML	

BORING COMPLETED AT 79.5 FEET ON 6-26-72 CASING USED TO A DEPTH OF 6.0 FEET

PIEZOMETER INSTALLED ON 6-26-72
PIEZOMETER TIP PLACED AT ELEVATION 609.9. PEA GRAVEL WAS PLACED FROM ELEVATION 596.4 TO ABOVE THE TIP; A BENTONITE SEAL; AND CEMENT GROUT TO ELEVATION 675.9.
PIEZOMETER INSTALLED ON 6-26-72
BORING P-1B WAS DRILLED ADJACENT TO P-1A, AND THE PIEZOMETER TIP WAS PLACED AT ELEVATION 665.9.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET		DATE
TIP ELEVATION 609.9	TIP ELEVATION 665.9	
1.9	2.9	8-3-72
1.8	3.1	8-15-72
2.5	3.8	8-6-72

REFER TO FIGURE 2.4-36 FOR WATER LEVEL OBSERVATIONS.


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-19

LOG OF BORING P-1

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 psi	σ_3 psi	q_u psi	S_e psi		
740									
730									
720								4500+	
710								4500+	
700								4500+	
690								2900	
680								2200	
670								4500+	
660								4500+	
650								4500+	

BORING P-4

SURFACE ELEVATION 735.3

BLOW COUNTS
SAMPLES

	SYMBOLS	DESCRIPTIONS
6	ML	LIGHT BROWN CLAYEY SILT WITH ORGANICS - (8" TOPSOIL)
10	ML	BROWN CLAYEY SILT WITH TRACE OF ORGANICS AND FINE ROOTS (MEDIUM STIFF)(WEATHERED LOESS)
7	ML	BROWN CLAYEY SILT WITH TRACE OF FINE TO MEDIUM SAND (STIFF)
24	ML SM	Top of Wisconsinan Glacial Till BROWN CLAYEY SILT WITH SOME SAND AND GRAVEL
27	ML	GRAY FINE SANDY SILT WITH TRACE OF CLAY (VERY STIFF)
56	SP	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND (VERY STIFF) BASE OF WEATHERED ZONE AT 12.0 FEET
84	ML	GRAY CLAYEY SILT WITH TRACE OF FINE TO MEDIUM SAND (HARD)
68	SP	GRAY FINE TO MEDIUM SAND WITH TRACE OF SILT (VERY DENSE)
10	ML	GRAY CLAYEY SILT WITH TRACE OF FINE TO COARSE SAND (HARD)
15	ML	Top of Interglacial Zone GRAY CLAYEY SILT WITH TRACE OF FINE SAND (STIFF)
136	CL	GRAY AND GREEN SILTY CLAY WITH SOME FINE TO COARSE SAND AND OCCASIONAL GRAVEL (MEDIUM STIFF)
100'	ML SM	Top of Illinoian Glacial Till GRAY FINE VERY SANDY SILT AND SILTY SAND WITH TRACE OF CLAY (HARD)
34		GRADES TO VERY STIFF WITH MORE SILT
19		
28	ML	BROWN CLAYEY SILT WITH TRACE OF ORGANICS (STIFF)
137	ML	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND (HARD)
100'		

BORING COMPLETED AT 80.0 FEET ON 5-24-72 CASING USED TO A DEPTH OF 7.0 FEET

WATER LEVEL NOT RECORDED.


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-21

LOG OF BORING P-4

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REQUIRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 pcf	σ_3 pcf	σ_c pcf	σ_p pcf		
740								2400	
								500	20.8 106
730						1725		1600	15.9 118
									12.5 119
720								4500+	
						7900		4500+	12.7 126
710								3500	
						1575		2000	15.7 116
700									
						1225		1300	17.8 112
690									
								4500+	8.2 136
680									
									8.0 126
670									
								4500+	9.7 127
660								4500+	
						15,000	6,000	4500+	6.6 143
650									
								4500+	
640									
630									
								4500+	4.2 143
620									
610									

BORING P-6
SURFACE ELEVATION 738.1

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
8	ML	BROWN CLAYEY SILT WITH ORGANICS - (12" TOPSOIL)
4	ML	BROWN CLAYEY SILT WITH TRACE OF ORGANICS AND FINE ROOTS (MEDIUM STIFF) (WEATHERED LOESS)
		<i>Top of Wisconsinan Glacial Till</i>
7	ML SM	BROWN CLAYEY SILT AND FINE TO COARSE SAND (SOFT TO MEDIUM STIFF)
		GRADES WITH LESS SAND
30	SP ML	BROWN FINE TO COARSE SAND (MEDIUM DENSE)
		GRADES WITH THIN SEAMS OF CLAYEY SILT
		BASE OF WEATHERED ZONE AT 15.0 FEET
78		GRAY CLAYEY SILT WITH LITTLE FINE TO COARSE SAND (HARD)
		OCCASIONAL FINE SAND SEAM
21		GRADES VERY STIFF
17	ML	GRADES WITH MORE CLAY
9		GRADES STIFF
		6" SAND SEAM
		<i>Top of Interglacial Zone</i>
10	ML	DARK GRAY CLAYEY SILT (MEDIUM STIFF)
6	ML	BROWN CLAYEY SILT WITH SOME FINE TO COARSE SAND (MEDIUM STIFF)
		<i>Top of Illinoian Glacial Till</i>
50		GRAY FINE SANDY SILT WITH SOME MEDIUM TO COARSE SAND (HARD)
65	ML SM	GRADES WITH TRACE OF FINE GRAVEL
180/11"		GRADES WITH MORE SILT
167/11"		15" FINE TO MEDIUM SAND LAYER
38		GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL GRAVEL (HARD)
66		
173/10"		GRADES WITH MORE FINE SAND
185/11"		
100/6"		GRADES WITH LESS FINE SAND
150/3"	ML	
135/6"		
110/6"		
75/6"		
105/9"		
130		

BORING COMPLETED AT 120.0 FEET
ON 5-23-72
CASING USED TO A DEPTH OF 5.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-23

LOG OF BORING P-6

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 sat	σ_3 sat				
740								2600	
730								1700	11.0 118
720								4500	
710								4500+	7.4 133
700						3900		4500+	13.8 123
690						3050		3300	18.2 111
680								4500+	
670									
660									4.3 138
650								4500+	
640								4500+	
630								4500+	
620								4500+	
610								4500+	
600								4500+	
590									
580									

BORING P-7

SURFACE ELEVATION 737.5

BLOW COUNTS SAMPLES:


SYMBOLS	DESCRIPTIONS
12	ML BROWN CLAYEY SILT WITH FINE SAND AND ROOTS (TOPSOIL)
6	CL LIGHT BROWN SILTY CLAY (STIFF) (WEATHERED LOESS)
10	ML <i>Top of Wisconsinan Glacial Till</i> TAN AND BROWN FINE SANDY SILT (LOOSE)
19	CL LIGHT BROWN SANDY CLAY WITH SILT AND SOME GRAVEL (STIFF) APPROXIMATE BASE OF WEATHERED ZONE AT 12.5'
31	ML GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (VERY STIFF) LAYER OF REDDISH-BROWN FINE SAND WITH SOME GRAVEL
74	ML LAYER OF BROWN SILTY CLAY WITH SOME SAND AND GRAVEL GRADES TO HARD
90	ML LAYER OF GRAY FINE TO MEDIUM SAND WITH SOME GRAVEL OCCASIONAL LAYERS OF FINE SANDY SILT WITH SOME GRAVEL GRADES TO BROWNISH-GRAY GRADES TO VERY STIFF
23	ML <i>Top of Interglacial Zone</i> GRAY CLAYEY SILT AND SILTY CLAY WITH SAND AND SOME GRAVEL (MEDIUM STIFF TO STIFF)
8	ML
14	CL
48	SM <i>Top of Illinoian Glacial Till</i> LIGHT GREENISH-GRAY SILTY SAND AND SANDY SILT WITH OCCASIONAL GRAVEL (VERY DENSE TO HARD)
78	ML GRADES WITH MORE SILT
160	ML
94	SP GRAY FINE TO MEDIUM SAND WITH SILT AND SOME GRAVEL (VERY DENSE)
32	SM
121	ML GRAY SANDY SILT WITH SOME GRAVEL AND TRACE OF ORGANIC MATTER (DENSE TO HARD) GRADES WITH MORE SAND
94	SM GRADES WITH LAYERS OF DARK GRAY FINE TO MEDIUM SAND WITH SOME GRAVEL
100/7'	ML GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD) (SAND, SILT AND CLAY CONTENT VARIES WITH DEPTH)
175/11'	ML
200/5'	ML
190/6'	ML
155/10'	ML
180/10'	ML
105	ML
118	ML 3" LAYER OF GRAY FINE SAND
112	ML
85	ML
75	ML 6" LAYER OF FINE TO MEDIUM SAND


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-24

LOG OF BORING P-7

(SHEET 1 of 2)







**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-26
LOG OF BORING P-9

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS OBTAINED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				$\frac{e_1 - e_2}{e_1}$ pcf	σ_1 pcf			$\frac{e_1 - e_2}{e_1}$ pcf		
750										
740										
730								1900		
720								4500+		
710								4500+		
700								2900		
690								2400		
680								2300		
670								4500+		
660								4500+		
650										

BORING P-10
SURFACE ELEVATION 740.0

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
10	ML	LIGHT BROWN CLAYEY SILT WITH ORGANICS - (16" TOPSOIL)
7	ML	BROWN CLAYEY SILT WITH TRACE OF FINE ROOTS (STIFF)
11	ML	GRADING WITH SOME FINE TO COARSE SAND (WEATHERED LOESS)
		<i>Top of Wisconsin Glacial Till</i>
13	SP	BROWN CLAYEY SILT WITH SOME SAND AND GRAVEL (MEDIUM DENSE)
10	ML	GRAY CLAYEY SILT WITH LITTLE FINE TO COARSE SAND (STIFF)
21	ML	BASE OF WEATHERED ZONE AT 16.0 FEET
		BROWN AND GRAY CLAYEY SILT WITH TRACE OF ORGANICS (VERY STIFF)
33	ML	GRAY FINE VERY SANDY SILT (DENSE)
47	SM	
29	ML	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL GRAVEL (VERY STIFF)
		<i>Top of Interglacial Zone</i>
17	ML	BROWN CLAYEY SILT WITH TRACE OF ORGANICS (STIFF)
8	CL	GRADES WITH TRACE OF FINE TO MEDIUM SAND (MEDIUM STIFF)
8	CL	GRAY SILTY CLAY WITH TRACE OF FINE TO COARSE SAND (MEDIUM STIFF)
		<i>Top of Illinoian Glacial Till</i>
62	ML	GRAY CLAYEY SILT WITH SOME FINE SAND AND TRACE OF COARSE SAND AND FINE GRAVEL (HARD)
39	ML	OCCASIONAL FINE SAND LENSES
64	SP	GRAY FINE TO COARSE SAND WITH TRACE OF SILT (VERY DENSE) (GLACIAL OUTWASH)
33	ML	GRAY CLAYEY SILT WITH TRACE FINE TO COARSE SAND (HARD) (TILL)
81	SP	GRAY FINE TO COARSE SAND WITH TRACE OF SILT (VERY DENSE) (OUTWASH)

BORING COMPLETED AT 80.0 FEET
ON 6-1-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-27

LOG OF BORING P-10

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY per
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				q ₁ per	q ₂ per	q _u per	q _p per		
740									
730							1100		
720									
710									
700									
690							2200		
680							4500+		
670							4500+		
660	SA						4500+		
650							4500+		

BORING P-11
SURFACE ELEVATION 734.5

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
10	ML	BLACK CLAYEY SILT WITH ROOTS-(TOPSOIL)
	ML	BLACK AND GRAY CLAYEY SILT (WEATHERED LOESS)
7	ML	Top of Wisconsinan Glacial Till
17	ML	BROWN AND GRAY CLAYEY SILT (MEDIUM STIFF)
	SM	LIGHT BROWN FINE SANDY SILT WITH LAYERS OF SILTY FINE SAND WITH SOME GRAVEL (MEDIUM DENSE)
18		GRAY SILTY CLAY WITH SOME SAND AND GRAVEL (VERY STIFF)
11	CL	GRADES TO STIFF
9		
12	ML	GRAY CLAYEY SILT WITH FINE SAND (STIFF)
		Top of Interglacial Zone
9	ML	DARK GRAY CLAYEY SILT WITH TRACE OF ORGANIC MATTER (MEDIUM STIFF)
9	CL	GREENISH-GRAY SILTY CLAY WITH SAND AND LAYERS OF CLAYEY SILT (STIFF)
	ML	OCCASIONAL SAND SEAMS
64	ML	Top of Illinoian Glacial Till
	SM	GRAY SANDY SILT TO SILTY SAND WITH SOME GRAVEL (VERY DENSE)
100/6"		GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
175/9"	ML	
100/6"	SM	GRAY SILTY SAND WITH SOME GRAVEL (GLACIAL OUTWASH)
122	ML	GRAY SANDY SILT WITH SOME CLAY AND GRAVEL (VERY DENSE)
	ML	GRAY CLAYEY SILT WITH SOME SAND (HARD)
33	ML	GRAY CLAYEY SILT WITH FINE SAND AND TRACE OF ORGANIC MATTER (HARD)
	SM	GRAY SILTY FINE TO COARSE SAND WITH SOME GRAVEL (DENSE)
100/5"		GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)(TILL)
100/4"	ML	OCCASIONAL LENSES OF FINE SAND

BORING COMPLETED AT 80.0 FEET
ON 5-23-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-28

LOG OF BORING P-11

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION psi	POCKET PENETROMETER		
				$\frac{e_1 - e_2}{z}$	σ_3				
				psi	psi				
680							3300		
670					800		500	31.7 88	
660								14.6 108	
650			18,500	2000			4500+	7.1 141	
640							4500+		
630							4500+	8.5 139	
620							4500+	7.9 140	
610							4500+	9.6 135	
600			24,500	5000			4500+	8.6 137	
590							4500+		

BORING P-12
SURFACE ELEVATION 676.8

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
5	ML	BLACK CLAYEY SILT WITH FINE SAND AND ROOTS - (TOPSOIL)
2	CL	Top of Salt Creek Alluvium MOTTLED BROWN AND GRAY SILTY CLAY WITH SOME FINE SAND (VERY SOFT)
P		GRAY FINE TO COARSE SAND WITH SOME GRAVEL (MEDIUM DENSE)
23		1 INCH SEAM OF SILT WITH SOME ORGANIC MATTER
30	SP	GRADES WITH SEAMS OF GRAVEL GRADES TO DENSE
112		Top of Illinoian Glacial Till
161		GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
126/6'		3 INCH SEAM OF GRAVEL
167/10'		
140	ML	
141		
145		
80		
60		
34		
96		2 INCH SEAM OF GRAVEL
119/6'		


BORING COMPLETED AT 79.0 FEET
ON 6-23-72
CASING USED TO A DEPTH OF 6.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-29

LOG OF BORING P-12

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



BORING COMPLETED AT 120.0 FEET
ON 5-25-72
CASING USED TO A DPETH OF 5.0 FEET
WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-30

LOG OF BORING P-13

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT	DRY DENSITY (PCF)
		PLASTIC LIMIT	PLASTICITY INDEX	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				Q ₁	Q ₂				
740								2400	
730				2320	1000			2100	14.6
720									
710	TX/DY			880	2500			4500	16.6
700								1200	
690				5880	5000			4500 ⁺	17.2
680	C	12.5	12.5					1600	16.2
670	CHEM*			21,700	4000			4500 ⁺	8.1
660	SA SA PERH	11.0	4.0					4500 ⁺	5.1
650								4500 ⁺	
640								4500 ⁺	
630				> 15,000	9000			4500 ⁺	8.2
620	TX/DY			20,500	9000			4500 ⁺	8.3
610	RES. TX/DY			26,300	9000			4500 ⁺	7.6
600	SHOCK TX/DY							4500 ⁺	
590								4500 ⁺	
580								4500 ⁺	

* ON WATER SAMPLE OBTAINED ON 10-7-72

BORING P-14

SURFACE ELEVATION 738.3

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
8	ML	BROWN CLAYEY SILT WITH SOME ORGANICS - (TOPSOIL)
	ML	MOTTLED BROWN AND GRAY CLAYEY SILT (VERY STIFF) (WEATHERED LOESS)
2	ML	Top of Wisconsinan Glacial Till line TO COARSE BROWN CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL GRAVEL (STIFF)
8	ML	BASE OF WEATHERED ZONE 17.0 FEET GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND (STIFF)
35	ML	7" SEAM OF GRAY FINE TO MEDIUM SAND GRAY CLAYEY SILT WITH TRACE OF FINE SAND (HARD)
65	ML	OCCASIONAL FINE SAND STRINGER GRAY CLAYEY SILT WITH SOME FINE TO MEDIUM SAND (HARD)
27	ML	2 INCH SEAM OF BROWN FINE SAND GRAY SILTY CLAY WITH TRACE OF FINE TO MEDIUM SAND (STIFF)
33	ML	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL GRAVEL (STIFF)
10	CL	Top of Interglacial Zone DARK GRAYISH-BROWN CLAYEY SILT WITH ORGANIC ODOR
11	ML	DARK GRAY SILTY CLAY WITH TRACE OF FINE SAND (STIFF)
16	ML	GRADES WITH SOME FINE TO MEDIUM SAND
14	CL	Top of Illinoian Glacial Till GRAY FINE SANDY SILT WITH SOME MEDIUM TO COARSE SAND AND OCCASIONAL GRAVEL (HARD)
12	ML	OCCASIONAL FINE SAND SEAM GRADES CLAYEY
100/6"	SM	BROWN FINE TO MEDIUM SAND WITH TRACE OF SILT (DENSE) (GLACIAL OUTWASH)
77	ML	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL GRAVEL (TILL)
118	SM	
106	SW	
35	SM	
100/5"		
100/6"		
100/4"		
140/6"		
100/4"		
160/10"		
105/6"	ML	TRACE OF ORGANICS
127		
100/5"		
100/6"		GRADES WITH LESS COARSE SAND
155		
	SW	GRAY FINE TO COARSE SAND WITH GRAVEL AND TRACE OF SILT (VERY DENSE)


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-31

LOG OF BORING P-14
(SHEET 1 of 2)

LABORATORY TEST DATA

BORING P-14 CONTINUED



PIEZOMETER INSTALLED ON 7-10-72 BORING WAS REOPENED TO 240 FEET AND FLUSHED WITH CLEAN WATER. A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS INSTALLED TO ELEVATION 578.33 GRANULAR BACKFILL WAS PLACED FROM ELEVATION 498.3 TO 589.3; A BENTONITE SEAL FROM ELEVATION 589.3 TO 590.3; AND CEMENT GROUT AND GRAVEL FROM ELEVATION 590.3 TO 738.3.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
57.5	8-3-72
56.9	8-22-72
57.3	9-6-72

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

REFER TO FIGURE 2.4-36 FOR WATER LEVEL OBSERVATIONS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-31
LOG OF BORING P-14
(SHEET 2 of 2)

BORING COMPLETED AT 284.0 FEET ON 6-2-72 CASING USED TO A DEPTH OF 7.0 FEET

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REQUIRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				q ₁ PCF	q ₂ PCF	q _u PCF	q _u PCF			
740								2600	25.2	98
730								1000	21.8	106
720				2390	1000			1600	13.9	123
710	C	14.5	8.5							
700				1530	3000			2000	32.1	92
690	TX/DY			1980	3000			3200	18.0	111
680								4500 ⁺	9.7	135
670				14,000	4,000			4500 ⁺	8.6	133
660	SA							4500 ⁺	12.6	123
650								4500 ⁺	11.9	103
640								4500 ⁺		
630								4500 ⁺	9.4	130
620				36,000	8,000			4500 ⁺	7.4	140
610								4500 ⁺		


BORING P-15

SURFACE ELEVATION 736.3

BLOW COUNTS SAMPLES

SYMBOLS

DESCRIPTIONS



BORING COMPLETED AT 120.0 FEET ON 5/24/72 CASING USED TO A DEPTH OF 5.0 FEET WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-32

LOG OF BORING P-15


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET		
			σ_1 psi	σ_3 psi	q_u psi	q_p psi		
690								
680								
670								
660								
650							4500+	
640							4500+	
630							4500+	
620							4500+	
610							4500+	
600							4500+	

BORING P-16
SURFACE ELEVATION 688.0

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 80.0 FEET
ON 5-30-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-33


LOG OF BORING P-16

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS RUN OR ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 PSI	σ_3 PSI	q_u PSI	q PSI		
740								2500	
730									
720									
710								3200	
700								1700	
690								2700	
680								4500+	
670								4500+	
660									4500+
650									

BORING P-17
SURFACE ELEVATION 738.2



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-34


LOG OF BORING P-17

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

BORING P-18

SURFACE ELEVATION 738.2




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-35

LOG OF BORING P-18
(SHEET 1 of 2)

BORING P-18 CONTINUED



BORING COMPLETED AT 279.5 FEET ON 6-3-72
CASING USED TO A DEPTH OF 5.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-35
LOG OF BORING P-18
(SHEET 2 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
			σ_1 pcf	σ_3 pcf	q_u pcf	q_p pcf		
740								
730						1200		
720						1900		
710						4500+		
700						1100		
690						4500+		
680						4500+		
670						4500+		
660						4500+		
650						4500+		

BORING P-19
SURFACE ELEVATION 734.5

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
10	ML	LIGHT BROWN CLAYEY SILT WITH SOME ORGANICS - (TOPSOIL) (STIFF)
5	ML	MOTTLED BROWN AND GRAY CLAYEY SILT WITH TRACE OF FINE TO MEDIUM SAND (MEDIUM STIFF) (LOESS)
7	CL	BASE OF WEATHERED ZONE AT 12.0 FEET GRADES BROWN WITH LESS CLAY AND MORE SILT <i>Top of Wisconsinan Glacial Till</i>
7	CL	GRAY SILTY CLAY WITH TRACE OF FINE TO MEDIUM SAND AND OCCASIONAL WOOD FRAGMENT (MEDIUM STIFF)
35	ML	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND TRACE OF FINE GRAVEL (VERY STIFF)
15	ML	GRADES STIFF WITH LESS COARSE SAND
10	SP	<i>Top of Interglacial Zone</i>
6	ML	GRAY SILTY FINE TO COARSE SAND (LOOSE)
6	CL	BROWN CLAYEY SILT WITH TRACE OF ORGANICS (MEDIUM STIFF)
17	ML	GRADES TO DARK BROWN
17	CL	GRAY SILTY CLAY WITH SOME FINE SAND (MEDIUM STIFF)
110	ML	DARK GREENISH-GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND (STIFF)
110	CL	<i>Top of Illinoian Glacial Till</i>
96	ML	GRAY FINE SANDY SILT WITH SOME MEDIUM TO COARSE SAND AND TRACE OF CLAY (HARD)
42	SM	GRADES WITH MORE FINE SAND
101	ML	GRADES WITH LESS FINE SAND
73	ML	GRADES WITH MORE FINE SAND
125	SP	GRAY FINE SAND WITH TRACE OF SILT (VERY DENSE) (GLACIAL OUTWASH)
106	ML	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL FINE GRAVEL (HARD) (TILL)
100/3"	ML	

BORING COMPLETED AT 80.0 FEET
ON 5-17-72
CASING USED TO A DEPTH OF 7.5 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-36

LOG OF BORING P-19

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

BORING P-20
SURFACE ELEVATION 738.3

ELEVATION IN FEET

TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH						MOISTURE CONTENT %	DRY DENSITY pcf
			PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION		
	σ ₁ (psf)	σ ₃ (psf)			σ ₁ (psf)	σ ₃ (psf)	σ ₁ (psf)	σ ₃ (psf)		
								1900	22.7	98
									16.4	116
									15.8	119
								4500+	9.9	133
								4500+		
									11.7	126
								4500+		
							2600	3900	14.5	120
c	14.4	7.2					3400	3200	19.5	110
								2300		
								4500+	15.5	130
									12.5	122
								4500+		
								4500+	7.7	140
								4500+		
								4500+		
								4500+	9.3	135
								4500+		
								4500+		
								4500	8.0	140
								4500+		
								4500	8.6	137

BLOW COUNTS SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
12	ML	BROWN CLAYEY SILT WITH FINE SAND AND ROOTS (TOPSOIL)
8"	CL	LIGHT BROWN CLAYEY SILT WITH FINE SAND (STIFF)
12	ML	<i>Top of Wisconsin Glacial Till (WEATHERED LOESS)</i> BROWN SANDY CLAY WITH LAYERS OF CLAYEY SILT WITH SAND AND SOME GRAVEL (STIFF)
61	ML	OCCASIONAL SMALL LAYERS OF SILTY SAND WITH CLAY
	SM	BROWN SILTY VERY FINE SAND TO FINE SAND (DENSE)
49	SP	GRADES WITH LAYERS OF CLAYEY SILT WITH SAND
65	ML	BROWNISH-GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
45	ML	APPROXIMATE BASE OF WEATHERED ZONE AT 22.0 FEET
27	SP	GRAY VERY FINE SAND WITH SILT (MEDIUM DENSE)
32	SM	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (VERY STIFF)
18	ML	<i>Top of Interglacial Zone</i> GRAY SILTY CLAY WITH SAND AND SOME GRAVEL (VERY STIFF)
TWP	SP	TRACE OF ORGANIC MATTER
14	CL	GRAY FINE TO COARSE SAND WITH SOME GRAVEL (MEDIUM DENSE)
12	ML	BROWNISH-GRAY SILTY CLAY AND CLAYEY SILT WITH SAND AND SOME GRAVEL (STIFF)
112	CL	SEAM OF SILTY FINE TO COARSE SAND WITH SOME GRAVEL
126	ML	<i>Top of Illinoian Glacial Till</i> BROWNISH-GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
102	SP	GRAY FINE TO COARSE SAND WITH SOME GRAVEL, OCCASIONAL COBBLES AND TRACE OF SILT (VERY DENSE) (GLACIAL OUTWASH)
90	SW	
136/11"		BROWNISH-GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD) (TILL)
110/8"		
100/6"		
125/5"		
100/5"		LAYER OF SILTY SAND WITH GRAVEL
110		
65		
112	ML	12" LAYER OF SAND
70		
156/11"		
68		GRADES TO GRAY
69		

BORING CONTINUED


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-37

LOG OF BORING P-20

(SHEET 1 of 2)

BORING P-20 CONTINUED



PIEZOMETER INSTALLED ON 6-28-72 BORING FLUSHED WITH CLEAN WATER AFTER COMPLETION AT 305.5 FEET. A 3/4 INCH PVC PIPE WITH AN 18 INCH POROUS STONE TIP WAS INSTALLED TO ELEVATION 503.3. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 432.8 TO 568.3; A BENTONITE SEAL FROM ELEVATION 568.3 TO 570.3; AND CEMENT GROUT AND GRAVEL FROM ELEVATION 570.3 TO 738.3.

WATER LEVEL READINGS	
DEPTH BELOW GROUND SURFACE IN FEET	DATE
58.0	8-3-72
58.2	8-22-72
58.4	9-2-72

NOTE: SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

REFER TO FIGURE 2.4-36 FOR WATER LEVEL OBSERVATIONS.


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-37

LOG OF BORING P-20

(SHEET 2 of 2)

BORING COMPLETED AT 305.5 FEET ON 6-27-72 CASING USED TO A DEPTH OF 50 FEET





* ON WATER SAMPLE OBTAINED ON 10-7-72


**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-39
LOG OF BORING P-22
(SHEET 1 of 2)

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY PCF
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ ₁ (PSF)	σ ₃ (PSF)			σ _c (PSF)		
			19,500	11,000			8.5	137	
							4500+	8.3	139
							4500+		
							4500+	9.6	136
							4500+		
							4500+		
							4.5 x 10.5		

BORING P-22 CONTINUED

ELEVATION IN FEET



PIEZOMETER INSTALLED ON 6-28-72 BORING P-22B, LOCATED 10 FEET FROM P-22A, WAS DRILLED TO A DEPTH OF 64 FEET. A 3/4 INCH PVC PIPE WITH AN 18 INCH POROUS STONE TIP WAS PLACED TO ELEVATION 670.0. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 670.0 TO 679.0; A BENTONITE SEAL FROM 679.0 TO 680.5; AND CEMENT GROUT AND GRAVEL FROM ELEVATION 680.5 TO 734.0.

REFER TO FIGURE 2.4-36 FOR WATER LEVEL OBSERVATIONS.

BORING COMPLETED AT 293.5 FEET ON 6-7-72 CASING USED TO A DEPTH OF 5.0 FEET

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
18.2	8-15-72
18.4	8-29-72

NOTE: SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-39
LOG OF BORING P-22
(SHEET 2 of 2)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				$\frac{q_1 - q_2}{3}$	q_1			$\frac{q_1}{3}$		
740										
730										
720										
710										
700										
690									4500+	
680									4500+	
670									4500+	
660									4500+	
650									4500+	

BORING P-23
SURFACE ELEVATION 732.2

BLOW COUNTS
SAMPLES

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
10	ML	BLACK CLAYEY SILT WITH ORGANICS - (30" TOPSOIL) (STIFF)
2	ML	MOTTLED BROWN AND GRAY CLAYEY SILT (VERY SOFT) (WEATHERED LOESS)
10	ML	<i>Top of Wisconsin Glacial Till</i> BROWN CLAYEY SILT WITH FINE TO COARSE SAND (MEDIUM STIFF TO STIFF)
20	ML	GRAY FINE SANDY SILT WITH SOME COARSE SAND AND CLAY (VERY STIFF) SMALL SAND SEAM BASE OF WEATHERED ZONE AT 15.0 FEET
13	ML	OCCASIONAL FINE TO COARSE SAND SEAMS GRADES TO STIFF
6	ML	GRAY CLAYEY SILT WITH LITTLE FINE TO MEDIUM SAND (MEDIUM STIFF)
14	ML	<i>Top of Interglacial Zone</i> BROWN CLAYEY SILT WITH TRACE OF ORGANICS (STIFF)
8	ML	GRADES TO MEDIUM STIFF WITH LITTLE FINE TO MEDIUM SAND
48	ML	GRAY CLAYEY SILT WITH TRACE OF FINE SAND (HARD)
111	ML	<i>Top of Illinoian Glacial Till</i> GRAY FINE SANDY SILT WITH SOME CLAY AND MEDIUM TO COARSE SAND (HARD)
152/10'	ML SM	OCCASIONAL THIN FINE TO COARSE SAND SEAM
25	ML	GRADES TO VERY STIFF
56	ML	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL GRAVEL
87	ML	
157/10'	ML	
100/2'	ML	

BORING COMPLETED AT 80.0 FEET
ON 5-16-72
CASING USED TO A DEPTH OF 7.5 FEET
WATER LEVEL NOT RECORDED.

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-40

LOG OF BORING P-23

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 psi	σ_3 psi	q_u psi	q_p psi			
750									
740						700			
730						2500			
720									
710						4500+			
700						3000			
690									
680									
670									
660									

ELEVATION IN FEET

BORING P-24
SURFACE ELEVATION 741.5

BLOW COUNTS	SAMPLES	SYMBOLS	DESCRIPTIONS
14	1	ML	LIGHT BROWN CLAYEY SILT WITH ROOTS - (TOPSOIL)
	2	ML	BROWN CLAYEY SILT WITH SOME VERY FINE SAND (STIFF) (WEATHERED LOESS)
5	3	CL	BROWN SILTY CLAY WITH SOME SAND (SOFT)
8	4	ML	<i>Top of Wisconsinian Glacial Till</i> GRADES TO MEDIUM STIFF
	5	ML	GRADES TO CLAYEY SILT WITH SOME SAND
53	6	ML	BROWN VERY FINE SANDY SILT WITH SOME CLAY (VERY DENSE) OCCASIONAL CLAY SEAMS
71	7	SM	BROWN AND GRAY SILTY VERY FINE SAND (VERY DENSE)
	8	ML	BASE OF WEATHERED ZONE AT 20.0 FEET
65	9	ML	GRAY VERY FINE SANDY SILT WITH LENSES OF SILT (VERY DENSE)
35	10	ML	BROWNISH-GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
16	11	CL	BROWNISH-GRAY SILTY CLAY WITH SAND AND SOME GRAVEL (STIFF)
11	12	CL	
	13	ML	<i>Top of Interglacial Zone</i> GRAY SILT WITH CLAY SEAMS (STIFF)
14	14	ML	GREENISH-BROWN AND GRAY CLAYEY SILT WITH SAND AND LAYERS OF SANDY CLAY (STIFF TO VERY STIFF)
26	15	CL	
	16	SM	<i>Top of Illinoian Glacial Till</i> GRAY SANDY SILT TO SILTY SAND WITH TRACE OF CLAY AND GRAVEL (VERY DENSE)
100/2'	17	ML	
	18	ML	GRAY CLAYEY SILT WITH SAND, SOME GRAVEL AND SEAMS OF FINE TO MEDIUM SAND (STIFF TO VERY STIFF)
24	19	SM	
	20	ML	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL
15	21	ML	
24	22	S.M	
	23	ML	
94	24	ML	GRAY FINE SANDY SILT WITH TRACE OF GRAVEL (VERY DENSE)


BORING COMPLETED AT 80.0 FEET
ON 5-22-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-41

LOG OF BORING P-24

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ ₁ psf	σ ₃ psf	σ _c psf	N ₆₀ blows		
740								2600	
730						525	1000	22.1	110
720							4500*	10.9	124
710									
700								2400	
690	c	9.8	11.6					1800	14.6 120
680									9.8 126
670								4500*	5.2 138
660				15700	5000				9.3 135
650									

BORING P-26
SURFACE ELEVATION 736.8

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
12	ML CL	BROWN CLAYEY SILT WITH TRACE OF FINE SAND AND ROOTS - (TOPSOIL)
9	ML	BROWN SILTY CLAY WITH TRACE OF SAND (STIFF) (WEATHERED LOESS)
4	ML	MOTTLED BROWN AND GRAY CLAYEY SILT WITH TRACE OF VERY FINE SAND (MEDIUM STIFF) SEAM OF FINE TO MEDIUM SAND GRADES TO SOFT
38	SW	BROWN FINE TO COARSE SAND WITH SOME GRAVEL (DENSE) BASE OF WEATHERED ZONE AT 16.0 FEET
27	ML	<i>Top of Wisconsinan Glacial Till</i> GRAY CLAYEY SILT WITH SOME SAND (VERY STIFF) GRADES WITH SOME GRAVEL
11		GRAY SILTY CLAY AND CLAYEY SILT WITH SAND AND SOME GRAVEL (STIFF)
10	CL ML	GRADES WITH MORE SAND LAYER OF FINE TO COARSE SAND
18		<i>Top of Interglacial Zone</i> DARK GRAY CLAYEY SILT WITH ORGANIC DEBRIS
14	ML	
8	CL	GRAY SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (MEDIUM STIFF)
72	ML SM	<i>Top of Illinoian Glacial Till</i> LIGHT GRAY SANDY SILT WITH CLAY AND SOME GRAVEL (HARD)
134/6"	SP	GRAY AND BROWN FINE TO COARSE SAND WITH SOME GRAVEL (VERY DENSE) (GLACIAL OUTWASH)
117	ML	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD) (TILL)
182/1"	SP SW	GRAY FINE TO COARSE SAND WITH SOME GRAVEL (VERY DENSE) (OUTWASH)
44	ML	GRAY CLAYEY SILT WITH SAND AND OCCASIONAL GRAVEL (HARD) (TILL)
165/8"	SP	GRAY FINE TO MEDIUM SAND WITH SOME GRAVEL (VERY DENSE)
156	ML	GRAY CLAYEY SILT WITH SOME SAND AND OCCASIONAL GRAVEL (HARD)


BORING COMPLETED AT 80.0 FEET
ON 5-16-72
CASING USED TO A DEPTH OF 7.5 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-43

LOG OF BORING P-26

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ ₁ pcf	σ ₃ pcf	σ _c pcf	q pcf			
			1910	1000				15.6	115
								13.9	120
c	10.4	6.8						11.2	126
								17.3	118
					2200			12.1	124
c	12.4	11.5						17.5	109
					1475			15.9	114
SA								11.3	124
								7.6	139
								9.8	130

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
13	ML	BROWN CLAYEY SILT WITH TRACE OF SAND AND ROOTS (TOPSOIL)
5	CL	<i>Top of Wisconsinan Glacial Till</i> BROWN SILTY CLAY WITH SOME SAND (MEDIUM STIFF)
7	CL	GRADES TO GREENISH-BROWN GRADES WITH OCCASIONAL GRAVEL
8	CL	GRAY SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (MEDIUM STIFF)
41	SP	BROWN FINE TO MEDIUM SAND WITH OCCASIONAL GRAVEL (DENSE)
145	SM	LAYER OF CLAYEY SILT
127	ML	GRAY SILTY SAND TO SANDY SILT WITH TRACE OF GRAVEL (HARD)
12	ML	TRACE OF ORGANIC MATTER
P	CL	GRAY CLAYEY SILT WITH SAND (HARD)
15	ML	9" LAYER OF GRAY FINE TO COARSE SAND
P	CL	<i>Top of Interglacial Zone</i> GRAY SILTY CLAY WITH SOME SAND AND OCCASIONAL GRAVEL (STIFF)
15	ML	TRACE OF ORGANIC MATTER
P	ML	GRAY CLAYEY SILT WITH SOME VERY FINE SAND (STIFF)
P	ML	GRAY SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (STIFF)
105	ML	GRADES WITH MORE SAND
149	SM	<i>Top of Illinoian Glacial Till</i> GRAY VERY FINE SANDY SILT TO SILTY SAND WITH TRACE OF CLAY AND OCCASIONAL GRAVEL (HARD)
22	SM	GRADES WITH MORE CLAY
17	SM	GRADES TO VERY STIFF
35	SM	GRADES WITH LESS CLAY
		TRACE OF ORGANIC MATTER
		GRADES TO FINE SANDY SILT

PIEZOMETER INSTALLED ON 6-6-72
TIP ELEVATION 685.4

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
26.5	8-15-72
26.7	8-29-72

REFER TO FIGURE 2.4-36 FOR WATER LEVEL OBSERVATIONS.


BORING COMPLETED AT 80.0 FEET
ON 6-6-72
CASING USED TO A DEPTH OF 7.0 FEET

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-44

LOG OF BORING P-27

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-45

LOG OF BORING P-28

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



NOTES:

A PITCHER SAMPLER 3.0 INCHES IN OUTSIDE DIAMETER AND 2.9 INCHES IN INSIDE DIAMETER WAS USED IN THIS BORING TO OBTAIN UNDISTURBED SAMPLES.

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-46

LOG OF BORING P-29

(SHEET 1 of 2)

BORING P-29 CONTINUED


ELEVATION IN FEET	LABORATORY TEST DATA										MOISTURE CONTENT %	DRY DENSITY pcf
	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH								
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION		POCKET PENETRATION			
				σ_1 pcf	σ_3 pcf	σ_1 pcf	σ_2 pcf	psi				
580	C	11.7	35								7.6	141
570												
560												
550											4500+	
540												
530												
520	C										14.9	116
	C	15.7	9.7								16.9	116
510												
	C											
500												



BORING COMPLETED AT 232 FEET
 ON 4-23-73
 CASING USED TO A DEPTH OF 5 FEET
 GROUND WATER NOT MEASURED

* NOTE:
 USED TRI-CONE ROLLER BIT -
 NO CORE SAMPLE OBTAINED.

LABORATORY TEST DATA									
ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAL COMPRESSION		UNCONFINED COMPRESSION σ_c pcf	POCKET PENETROMETER σ_p pcf		
				σ_1 pcf	σ_3 pcf				
740									
730		16.3	15.3					1700	24.6 99
720								4500+	10.1 134
710		10.7	9.4					4500	12.5 127
700								4500+	15.3 118
690		13.8	9.7			900	2250	15.7	118
680									16.1 116
670									
660						962 3960		4500+	11.8 126
650									
640		11.4	1.7					4500+	9.9 136
630							1720	4500+	10.9 130
620						4446 5400		2500	30.3 88
610									
600		8.0	8.5						7.5 146
590									
580		9.8	5.7					4500+	7.9 139




NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-47
LOG OF BORING P-30
(SHEET 1 of 2)

LABORATORY TEST DATA

BORING P-30 CONT'D



BORING COMPLETED AT 200.0 FEET ON 9-5-73. CASING USED TO A DEPTH OF 14.0 FEET. WATER LEVEL NOT RECORDED.


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-47
LOG OF BORING P-30
(SHEET 2 of 2)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 psi	σ_3 psi	q_u psi	S_u psi		
740									
730								3000	
720									
710		11.8	11.3					3000	15.1 120
700						2340		3000	13.4 122
690		15.5	11.0					4500+	14.2 121
680								2000	21.2 106
670		15.2	4.5					4500+	
660				9036	5000			4500+	9.8 134
650		9.6	6.9					4500+	7.1
640								4500+	
630		NON-PLASTIC						4500+	
620								4500+	
610		10.5	7.3					4500+	8.2 137
600								4500+	7.2 140
590		10.6	5.9					4500+	7.4 141
580				18500	8640			4500+	7.1 139
								4500+	7.9 139

BORING P-31
SURFACE ELEVATION 736.8



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-48

LOG OF BORING P-31
(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

BORING P-31 CONT'D

ELEVATION IN FEET	LABORATORY TEST DATA										BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
	TESTS PERFORMED ELEVATION ELEVATION	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf				
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION							
				σ_1 psf	σ_3 psf	σ_1 psf	σ_3 psf						
580								4500+			180/11" B		
570		10.3	10.6					4500+			155/11" B	ML	GRADES TO BROWNISH-GRAY
560								4500+			170 B		<i>Top of Pre-Miocene Glacial Till</i> MOTTLED BLuish-GREEN CLAYEY SILT WITH SOME FINE TO MEDIUM SAND AND GRAVEL (HARD)
550								4500+			62 B		
550		14.9	8.5					4500+	10.3	134	130/6" B	ML	GRADES GRAYISH-BROWN GRADES WITH LESS CLAY
540								4500+			230/6" B		
540								4500+	9.1	132	200/3" B	SP	GRAY FINE TO COARSE SAND WITH SOME FINE GRAVEL (VERY DENSE)
530								4500+			200/2" B	ML	DARK GRAY SANDY SILT WITH SOME CLAY (HARD)
520								4500+			250/10" B		

BORING COMPLETED AT 200.0 FEET
ON 9-10-73.
CASING USED TO A DEPTH OF 5.0 FEET.
WATER LEVEL NOT RECORDED.

PIEZOMETER INSTALLED ON 9-11-73. BORING WAS
FILLED WITH GRAVEL AND SEALED WITH BENTONITE
TO 159.0 FEET AFTER FLUSHING WITH CLEAN
WATER. A 2 INCH PVC PIPE WITH THE LOWER END
PLUGGED AND THE LOWER 109.0 FEET PERFORATED
WAS INSTALLED TO ELEVATION 577.8. GRANULAR
BACKFILL WAS PLACED FROM ELEVATION 577.8 TO
686.8. A BENTONITE SEAL FROM ELEVATION 686.8
TO 688.8; AND CEMENT GROUT FROM ELEVATION
688.8 TO 734.8.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
25.3	10-29-73
25.3	11-15-73
24.5	12-31-73


**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-48
LOG OF BORING P-31
(SHEET 2 of 2)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY Pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ ₁ Pcf	σ ₃ Pcf	σ _u Pcf	P (Pcf)		
740								3000	
730								1000	
								2500	13.9 123
								4500+	
								2500	15.5 115
710								2250	15.9 119
700								1500	
								2500	
690				10437	3888			8.8	137
								4500+	
680								12.8 14.5	123 120
670	SA							4500+	
	c	11.3	10.8					4500+	8.4 136
660								4500+	
	TX/DY							4500+	7.9 135
650								4500+	
	c	11.3	6.6	7697	6480			6.7 6.4	138 138
640		9.9	4.7					4500+	7.0 126
								4500+	
630								4500+	7.3 135
	c	10.9	8.9					4500+	6.9 140
620								4500+	7.1 139
	TX/DY							4500+	9.6 133
610								4500+	7.7 139
600				18720+	10008+			25.2	120
590	c	10.6	7.8					4500+	8.5 136
580									

BORING P-32
SURFACE ELEVATION 737.4



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-49

LOG OF BORING P-32

(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.


BORING P-32 CONT'D



BORING COMPLETED AT 240.0 FEET ON 9-28-73. CASING USED TO DEPTH OF 4.0 FEET. NO GROUND WATER LEVEL RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-49
LOG OF BORING P-32
(SHEET 2 of 2)



LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				a) σ_1 pcf	b) σ_3 pcf				
740									
730								3000	
								2000	
		12.4	8.6					2500	16.8 117
720								2750	
								2500	15.0 120
710								2500	
		12.2	9.0					1500	18.0 112
700								1500	
								1500	18.1 111
690								4500+	8.0 138
		11.4	3.0					4500+	7.9 139
680	c							7.2 139	
								8.0 131	
670									
660									
								4500+	
650		9.7	7.9					4500+	
									7.6 143
640									
630									

BORING P-33
SURFACE ELEVATION 734.6

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
9 #	ML	BROWN CLAYEY SILT WITH SOME ORGANICS (TOPSOIL)
9 #	ML	BLACK CLAYEY SILT WITH TRACE OF ORGANICS (VERY STIFF) (WEATHERED LOESS)
	CL	MOTTLED BROWN AND GRAY SILTY CLAY (STIFF)
13 #	ML	Top of Wisconsinan Glacial Till
		BROWN CLAYEY SILT WITH FINE TO COARSE SAND AND OCCASIONAL GRAVEL (VERY STIFF)
10 #		GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND (VERY STIFF)
11 #	ML	GRADES WITH OCCASIONAL FINE GRAVEL
9 #		
8 #		GRADES TO STIFF
		Top of Interglacial Zone
10 #	ML	DARK GRAY CLAYEY SILT WITH SANDY INTRUSIONS (STIFF)
8 #		GRADES TO GRAY AND WITH MORE SAND
10 #	SM	GREENISH-GRAY SILTY SAND WITH OCCASIONAL GRAVEL (LOOSE)
		Top of Illinoian Glacial Till
180/10 #		GRAY CLAYEY SILT WITH SOME SAND AND GRAVEL (HARD)
100/6 #	ML	
152 #		
140 #		
32 #	SM	GRAY FINE SILTY SAND WITH SOME FINE GRAVEL (MEDIUM DENSE) WOOD FRAGMENTS
99 #	SP	GRAY FINE TO COARSE SAND WITH SOME FINE GRAVEL (VERY DENSE)
125/6 #		GRAY CLAYEY SILT WITH SOME SAND AND GRAVEL (HARD)
100/5 #	ML	
100/5 #		

BORING COMPLETED AT 89.0 FEET ON 8-10-73.
CASING USED TO A DEPTH OF 5.0 FEET.
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-50


LOG OF BORING P-33

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS RECORDED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{\sigma_1 - \sigma_3}{2}$	σ_3				
740								4200	
730									
720								4500+	9.12 148
710		10.9	12.0					4500+	
700						3888	4500+	13.7	121
690		11.0	2.1					10.5	132
680		10.4	6.5					4500	
670						1984	4500+	8.7	132
660								4500+	13.8 120
650								16.5	111
640		10.3	7.4				4500+	6.9	146

BORING P-34
SURFACE ELEVATION 737.2



BORING COMPLETED AT 90.0 FEET ON 8-27-73.
CASING USED TO A DEPTH OF 5.0 FEET.
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-51


LOG OF BORING P-34

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY Pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				q ₁ psi	q ₂ psi	q ₃ psi	q ₄ psi		
740									
								250	
730								2750	
								4500+	
720								4500+	
								4500+	
710		11.6	12.3					9.8	133
								4500+	13.9
700								2800	123
								2000	15.1
690		11.7	9.9					4500+	120
								4500+	7.37
680								4500+	143
								4500+	10.0
670									
660									
650								7.1	141
640		9.7	4.2					4500+	6.4
								4500+	143
630								4500+	
								4500+	8.4
620								4500+	138
								4500+	
610		10.9	6.4					4500+	7.6
								4500+	140
600		11.6	8.1					4500+	7.4
								4500+	139
600								4500+	
								4500+	7.5
590								4500+	140.0
								4500+	
580								4500+	

BORING P-35
SURFACE ELEVATION 737.8



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-52

LOG OF BORING P-35
(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

BORING P-35 CONT'D




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-52
 LOG OF BORING P-35
 (SHEET 2 of 2)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{q_1 - q_3}{2}$ pcf	$\frac{q_2 - q_3}{2}$ pcf				
740								3000	
								2000	
								1500	
730								1000	
								4500+	
720								4500+	
								3750	
710								2000	
								2000	
700								3000	
								1500	
690								2500	
								500	
680				12816	4248			4500+	8.2 137
	TX/DY							2000	13.0 132
670								4000	
660									
650								4500+	
640	C	10.7	6.5					4500+	6.5 140
630								4500+	6.6 142
				26280	8236			4500+	6.6 142
620								4500+	8.6 135
	C	11.9	9.0					4500+	8.6 135
610				14040	8640			4500+	8.0 137
600	C	11.8	7.0					4500+	7.9 138
590								4500+	
580								4500+	

BORING P-36
SURFACE ELEVATION 738.2




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-53

LOG OF BORING P-36
(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

BORING P-36 CONT'D



PIEZOMETER INSTALLED ON 11-6-73. BORING WAS FILLED WITH GRAVEL AND SEALED WITH BENTONITE TO 223.0 FEET AFTER FLUSHING WITH CLEAN WATER. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 45.0 FEET PERFORATED WAS INSTALLED TO ELEVATION 515.2. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 515.2 TO 560.2; A BENTONITE SEAL FROM ELEVATION 560.2 TO 562.2; AND CEMENT GROUT FROM ELEVATION 562.2 TO 738.2.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
57.8	11-15-73
56.4	12-31-73

BORING COMPLETED AT 251.1 FEET ON 11-3-73. CASING USED TO A DEPTH OF 231.0 FEET. GROUNDWATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-53
LOG OF BORING P-36
(SHEET 2 of 2)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 / 2 pcf	σ_3 / 2 pcf	q_u / 2 pcf	q_p / 2 pcf		
740								1100	
730								2250	
720								4500+	11.6 128
710		12.5	2.7					4500+	13.3 117
700								4500+	13.5 124
690		12.6	16.1					17.0	113
680								4500+	8.0 140
670		9.5	4.8			12064		4500+	8.2 138
660								4500+	8.2 140
650								4500+	8.0 139
640		8.41	5.8					4500+	7.2 144
630								4500+	8.1 137
620		10.4	9.5					4500+	10.6
610						13410		4500+	7.9 137
600								4500+	8.3 138
590		10.7	6.9					4500+	7.9 140
580		10.9	6.0					4500+	7.5 140
								4500+	7.3 140

BORING P-37

SURFACE ELEVATION 739.1

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
4	ML	DARK BROWN CLAYEY SILT WITH TRACE OF ORGANICS (TOPSOIL)
9	ML	YELLOWISH-BROWN CLAYEY SILT WITH TRACE OF FINE SAND (STIFF) (WEATHERED LOESS)
19		<i>Top of Wisconsinan Glacial Till</i>
20	ML	LIGHT GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND (VERY STIFF)
21		GRADES TO GRAY (HARD)
21		GRADES WITH FINE GRAVEL
19	ML	GRAY CLAYEY SILT WITH FINE SAND (HARD)
33	ML	GRADES WITH OCCASIONAL COBBLES
32	ML	GRAY CLAYEY SILT WITH TRACE OF FINE TO MEDIUM SAND (HARD)
27	ML	GRADES WITH TRACE OF COARSE SAND AND FINE GRAVEL
13	ML	<i>Top of Interglacial Zone</i>
20	SM	GRAY CLAYEY SILT WITH TRACE OF FINE SAND AND OCCASIONAL GRAVEL
147	SM	GRADES WITH TRACE OF ORGANICS
177/11"	ML	BLUISH-GREEN SILTY FINE TO COARSE SAND WITH TRACE OF CLAY (MEDIUM DENSE)
127	ML	GRADES WITH LAYERS OF SILTY SAND
46		<i>Top of Illinoian Glacial Till</i>
83	SP	GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL FINE GRAVEL (HARD)
175/10"	SP	GRAY FINE TO COARSE SAND AND FINE GRAVEL AT 79.5'
220		GRAY FINE TO COARSE SAND AND FINE GRAVEL
100/6"		GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND OCCASIONAL FINE GRAVEL (HARD)
200		GRADES WITH OCCASIONAL COARSE GRAVEL
105/6"		
250/4"		
80	ML	
180/10"	ML	
200/10"	ML	
200		
200		
220		GRADES WITH MORE GRAVEL
100/5"		
115/6"		
130		

ELEVATION IN FEET

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-54


LOG OF BORING P-37

(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

BORING P-37 CONT'D

ELEVATION IN FEET	LABORATORY TEST DATA									
	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
		PLASTIC LIMIT %	PLASTIC INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION				
				σ_1 pcf	σ_3 pcf	σ_1 pcf	σ_3 pcf			
580							4500+		16.4	119
570						5400	4500+	13.6	121	
560		9.6	7.3				4500+	8.9	136	
550							4500+	11.2		
540		13.4	11.4				4500+	11.7		
530							4500+			



SYMBOLS

DESCRIPTIONS

180B ML
 Top of *Lacustrine Deposit*
 GREENISH-GRAY SANDY SILT (VERY DENSE)

180B ML
 Top of *Pre-Illinoian Glacial Till*
 GREENISH-BLUE CLAYEY SILT WITH TRACE OF FINE TO COARSE SAND (HARD)
 GRADES TO BROWNISH-GRAY
 GRADES WITH LESS CLAY AND MORE SAND

220B ML
 GRADES WITH FINE GRAVEL

BORING COMPLETED AT 201.0 FEET ON 8-27-73. CASING USED TO A DEPTH OF 5.0 FEET. WATER LEVEL NOT RECORDED.

PIEZOMETER INSTALLED IN 8-27-73. BORING WAS FILLED WITH GRAVEL AND SEALED WITH BENTONITE TO 41.0 FEET AFTER FLUSHING WITH CLEAN WATER. A 1 1/2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 24.0 FEET PERFORATED WAS INSTALLED TO ELEVATION 699.1 FEET. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 701.1 TO 726.1; A BENTONITE SEAL FROM ELEVATION 726.1 TO 728.1; AND CEMENT GROUT FROM ELEVATION 728.1 TO 739.1.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
14.2	10-5-73
16.0	10-29-73
15.9	11-15-73


**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-54
 LOG OF BORING P-37
 (SHEET 2 of 2)

LABORATORY TEST DATA

BORING P-38

SURFACE ELEVATION 7389




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-55

LOG OF BORING P-38

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-55
LOG OF BORING P-38
(SHEET 2 of 3)

LABORATORY TEST DATA

BORING P-38 CONT'D




BORING COMPLETED AT 444.5 FEET ON 9-19-73. CASING USED TO A DEPTH OF 238.0 FEET.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-55
LOG OF BORING P-38
(SHEET 3 of 3)

ELEVATION IN FEET	LABORATORY TEST DATA										MOISTURE CONTENT %	DRY DENSITY PCF
	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH								
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION			UNCONFINED COMPRESSION		POCKET PENETRATION			
				σ_1 SAT	σ_3 SAT	σ_1 SAT	σ_3 SAT	σ_1 SAT				
750												
740										3500		
										2000		
730										2000	15.1	138
720											13.3	126
710		12.8	8.7							4000	12.1	127
										4500+		
							4590			4500+		
700										4500+	12.1	143
690		13.5	10.9								12.7	124
680											14.3	120
670											11.7	131
660										4500+	8.7	138
650											7.2	142
640												
630											7.7	136
620		9.6	7.9								7.7	139
610											8.6	138
600		10.4	5.5								7.3	142
590											7.4	143




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-56
LOG OF BORING P-39
(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

BORING P-39 CONT'D



PIEZOMETER INSTALLED ON 8-28-73. BORING WAS FILLED WITH GRAVEL AND SEALED WITH BENTONITE TO 152.0 FEET AFTER FLUSHING WITH CLEAN WATER. A 1 1/2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 90.0 FEET PERFORATED WAS INSTALLED TO ELEVATION 570.8 FEET. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 590.8 TO 578.8; A BENTONITE SEAL FROM ELEVATION 578.8 TO 680.8; AND CEMENT GROUT FROM ELEVATION 680.8 TO 740.8.


WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
32.9	9-7-73
33.4	10-29-73
33.2	11-15-73

BORING COMPLETED AT 200.0 FEET ON 8-27-73.
CASING USED TO A DEPTH OF 5.0 FEET.
NO WATER LEVEL RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-56
LOG OF BORING P-39
(SHEET 2 of 2)




NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-57
LOG OF BORING P-40
(SHEET 1 of 2)

BORING P-40 CONT'D



PIEZOMETER INSTALLED ON 10-19-73. BORING WAS FILLED WITH GRAVEL AND SEALED WITH BENTONITE TO 38.0 FEET AFTER FLUSHING WITH CLEAN WATER. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 28.0 FEET PERFORATED WAS INSTALLED TO ELEVATION 704.1. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 704.1 TO 732.1; A BENTONITE SEAL FROM ELEVATION 732.1 TO 734.1; AND CEMENT GROUT FROM ELEVATION 734.1 TO 742.1.

WATER LEVEL READINGS


DEPTH BELOW GROUND SURFACE IN FEET	DATE
12.6	10-29-73
12.4	11-15-73

BECAME INOPERATIVE DECEMBER 31, 1973

BORING COMPLETED AT 257.5 FEET ON 10-18-73. CASING USED TO A DEPTH OF 8.5 FEET. WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-57
LOG OF BORING P-40
(SHEET 2 of 2)




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-58

LOG OF BORING P-41

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.




LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{q_1 - q_2}{3}$	$\frac{q_1 - q_2}{3}$	$\frac{q_1 - q_2}{3}$	$\frac{q_1 - q_2}{3}$			
750									
740							3750		
							2250	16.2	118
730	12.5	6.7					4400	14.4	121
							4500+	13.1	123
720							4500+		
							4500+	13.0	123
710	14.8	9.7					4500+		
							2500	14.3	118
700	12.6	7.1					1500	11.4	119
							1200	17.9	113
690	11.1	9.4					800	17.5	113
							4500+	9.5	135
680	10.4	2.9					4500+	8.8	137
							4500+	7.9	140
670							4500+		
							4500+		
660	NON-PLASTIC							11.9	130
650							4500+	7.0	142
							4500+	7.8	160
640									

ELEVATION IN FEET

BORING P-43
SURFACE ELEVATION 740.3

BLOW COUNTS SAMPLES



BORING COMPLETED AT 89.0 FEET ON 9-25-73.
CASING USED TO A DEPTH OF 3.0 FEET.
GROUNDWATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-60


LOG OF BORING P-43

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{e_1 - e_2}{T}$	σ_1	σ_u	$\frac{S_e}{T}$			
			psi	psi	psi	psi			
	22.3	23.5					3500	20.8	101
							750	16.3	113
			2950	1728			4500+	13.3	126
			4994	2764			4500+	8.1	133
							4500+	6.4	144

ELEVATION IN FEET

BORING P-44
SURFACE ELEVATION 686.2



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-61

LOG OF BORING P-44


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

ELEVATION IN FEET

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{q_1 - q_2}{3}$ pcf	q_3 pcf			$\frac{q_u}{3}$ pcf		
	20.6	26.1					4000	14.7	101
							3500		
							3500		
							4500		
	12.5	10.9					4500	17.7	120
							4000		
			4248	2088			4000	13.0	124
							4500		
	12.5	15.4					4500	12.7	127
							4500		
			2214	3528			4500	13.0	125

BLOW COUNTS SAMPLES

BORING P-45
SURFACE ELEVATION 738.8



BORING COMPLETED AT 50.0 FEET ON 11-8-73. CASING USED TO A DEPTH OF 10.0 FEET. GROUNDWATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-62


LOG OF BORING P-45

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pci	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 / psi	σ_3 / psi	σ_u / psi	q_u / psi			
750									
740		14.1	9.4	2229	432		23.4	95	
730							750		
720				3612	1008		13.3	122	
710		13.3	7.4				4500	22.0	118
700				4662	2808		4000	11.7	126
690		12.6	7.9				4500	13.6	125

ELEVATION IN FEET

BORING P-46
SURFACE ELEVATION 741.1



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-63

LOG OF BORING P-46

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION		POCKET PENETROMETER		
				σ ₁ pcf	σ ₃ pcf	σ _c pcf	σ _u pcf			
740		19.3	45.5					3750	21.0	95
								750		
730		13.5	3.4						17.0	112
				1199	1008				12.7	124
720										
710				3924	2088			4000	12.9	124
		12.8	7.8					1000	15.3	120
700								750		
				4464	3168			4000	12.7	118
690		14.8	4.6					1000	16.5	113
680										

BORING P-47

SURFACE ELEVATION 739.7

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
9	ML	BROWN SILT WITH ORGANICS AND TRACE OF FINE GRAVEL (TOPSOIL)
3	ML	BROWN CLAYEY SILT WITH TRACE OF FINE GRAVEL (WEATHERED LOESS)
5		<i>Top of Wisconsin Glacial Till</i>
		BROWN FINE SANDY SILT WITH TRACE OF CLAY AND FINE GRAVEL (LOOSE)
19	ML	GRADES WITH LESS FINE SAND
48		BROWN FINE SAND WITH TRACE OF FINE GRAVEL GRADES GRAY AND WITH MEDIUM SAND
83	SP	
		GRAY CLAYEY SILT WITH SOME FINE TO COARSE SAND AND GRAVEL (HARD)
18		
		(MEDIUM STIFF)
8	ML	
		GRADES WITH MORE COARSE GRAVEL
9		
		(HARD)
27		
		<i>Top of Interglacial Zone</i>
9	ML	DARK GRAY SILT WITH ORGANICS AND TRACE OF FINE SAND AND CLAY (MEDIUM STIFF)

BORING COMPLETED AT 50.0 FEET ON 11-8-73.
CASING USED TO A DEPTH OF 10.0 FEET.
GROUNDWATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-64

LOG OF BORING P-47

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS PERFORMED OR REFERRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				$\frac{e-1}{e}$	σ_1					$\frac{e-1}{e}$
				PCF	PCF	PCF	PCF			
730		13.8	9.1					4500+	11.4	120
720				3317	720			4500+	13.3	123
710								4500+		
700		12.4	13.0					4500+	12.4	126
690				1962	2088				14.0	121
								4500+	14.4	124
				3942	2808			4500+	13.7	123
680										
		11.2	3.8						9.2	135
670										

BORING P-48

SURFACE ELEVATION 724.6

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
18	ML	Top of Wisconsin Glacial Till
36	SP	MOTTLED BROWN AND GRAY ORGANIC FINE TO MEDIUM SANDY SILT WITH SOME COARSE SAND AND FINE GRAVEL AND TRACE OF CLAY
34		ORANGE FINE SAND WITH TRACE OF MEDIUM SAND
21		DARK GRAY SILT WITH SOME CLAY AND FINE TO MEDIUM SAND AND GRAVEL (HARD)
24	ML	
16		
20		
18	ML	Top of Interglacial Zone
27		DARK GREENISH CLAYEY SILT WITH SOME FINE SAND AND GRAVEL AND OCCASIONAL ORGANICS (HARD)
		3" COBBLE AT 30.7'
24	ML	Top of Illinoian Glacial Till
		GRAY SILT WITH FINE SAND, OCCASIONAL FINE GRAVEL AND OCCASIONAL FINE TO MEDIUM SAND SEAMS (HARD)
30	SP	BLACK FINE TO COARSE SAND WITH SOME FINE GRAVEL
54	ML	LIGHT GRAY FINE TO MEDIUM SANDY SILT WITH SOME COARSE SAND, FINE GRAVEL AND TRACE OF CLAY (HARD)

BORING COMPLETED AT 50.0 FEET ON 11-6-73.
CASING USED TO A DEPTH OF 3.5 FEET.
GROUNDWATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-65

LOG OF BORING P-48

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf	σ_1 psf						
0										
5				800*						
10				1500*						
15										
20				2100*						
20	C			2000*	11.9	16.7	149	114		
25				3800*			140			
30				4500*						
30	C			4500*	11.5	14.0	105	128		
35				2600*						
40				4070 2500*			148	125		
40	C				NP		256	99		
45				1500*						
45	C			3500*	10.0	24.4	174	110		
50							186			
55				4500*			9.2			
60				4500*			8.0			
60	C			4500*	10.3	8.0	7.1	133		
65										
65	C			4500*	10.8	7.4	8.4	132		
70							107			
75										

BLOW COUNTS
SAMPLES

BORING P-49

SURFACE ELEVATION 740.2

ELEVATION
(FEET)



Boring completed at 70.0 feet on 4-7-75.
Water level at 4.5 feet.


NOTES

Logged by: Sargent & Lundy Engineers
 Drilled by: Raymond International
 Tested by: Soil Testing Services Inc.

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-66

LOG OF BORING P-49




Logged by: Sargent & Lundy Engineers
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-67

LOG OF BORING P-56




Boring completed at 70.0 feet on 11-18-75.
Water level at 9.9 feet on 11-20-75.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-68

LOG OF BORING P-57

Logged by: Sargent & Lundy Engineers
Drilled by: Raymond International
Tested by: Westenhoff & Novick, Inc.





**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-69

LOG OF BORING P-58

Logged by: Sargent & Lundy Engineers
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick, Inc.





NOTES

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION

UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-71


LOG OF BORING P-60

DEPTH (FEET)	TESTS REPORTED	SHEAR STRENGTH			ATTENDING LIMITS			WATER CONTENT, %	FLUIDITY	WATER	WATER	WATER
		TRIAxIAL COMPRESSION			PLASTIC LIMIT, %	FLUIDITY INDEX, %	WATER					
		Q ₁ , psi	Q ₂ , psi	Q ₃ , psi								
0												
5				4200			12.2					
10							14.8					
15				6460	13.6	17.1	12.6	128				
20				3510			14.0	122				
25												
30												
35												
40												
45												
50												
55												
60												
65												
70												
75												

BLOW COUNTS
SAMPLES

BORING P-61
SURFACE ELEVATION APPROXIMATELY 736

DEPTH (FEET)




- NOTES**
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: RAYMOND INTERNATIONAL.
 3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-72

LOG OF BORING P-61



NOTES

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-73


LOG OF BORING P-61A

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION q_u pcf	POCKET PENETROMETER q_p pcf		
				a pcf	b pcf				
720									
710						2740		2900	11.6 123
700								4250	12.7 123
690	SA								9.4 132
680						3780		4500+	12.8 124
670	SA								18.4 108
660								4500+	
650								4500+	
640								4500+	
630								4500+	
620								4500+	
610								4500+	
600								4500+	
590								4500+	

BORING D-1
SURFACE ELEVATION 716.1

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 119.75 FEET ON 7-21-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-74

LOG OF BORING D-1

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS RECORDED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\sigma_1 - \sigma_3$ psf	σ_3 psf	σ_c psf	σ_p psf			
680									
670							4500 ⁺		
660							4500 ⁺		
650									
640							4500 ⁺		
630							4500 ⁺		
620							4500 ⁺		
610							4500 ⁺		
600							4500 ⁺		
590							4500 ⁺		

ELEVATION IN FEET

BLOW COUNTS
SAMPLES

BORING D-2
SURFACE ELEVATION 673.4

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	
11	ML	LIGHT BROWN CLAYEY SILT WITH ROOTS - (TOPSOIL)	
19	CL	BROWN SILTY CLAY WITH OCCASIONAL GRAVEL AND LENSES OF SILT (VERY STIFF) (LOESS)	
48	CL	<i>Top of Illinoian Glacial Till</i> BROWN SILTY CLAY WITH SAND AND SOME GRAVEL (HARD)	
46	ML	GRAY CLAYEY SILT WITH SAND, SOME GRAVEL AND OCCASIONAL LAYERS OF SAND (HARD)	
38		BASE OF WEATHERED ZONE AT 10.5 FEET	
41		GRADES WITH MORE CLAY	
104		GRADES WITH MORE SAND	
81		GRAY CLAYEY SILT WITH SAND AND GRAVEL (HARD)	
100/4'		ML	
100/3'			
170			
100/5'			
100/5'			
100/5'			
152		OCCASIONAL SAND SEAMS	
149/5'		GRADES WITH LESS GRAVEL	
152			

BORING COMPLETED AT 79.5 FEET
ON 7-21-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-75

LOG OF BORING D-2

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY Pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSIVE STRENGTH		UNCONSOLIDATED SAMPLES				
			σ ₁ (PSI)	σ ₃ (PSI)	σ ₁ (PSI)	σ ₃ (PSI)			
						2175		20.1	104
SA CHEM*								22.8	102
			10,200	3000				9.8	135
								4500*	
PERM SA								4500*	7.5

* ON WATER SAMPLE OBTAINED ON 10-7-72

PIEZOMETER INSTALLED IN D-3A ON 7-13-72 A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS PLACED AT ELEVATION 620.0. PEA GRAVEL WAS PLACED FROM ELEVATION 620.0 TO 630.0; A BENTONITE SEAL FROM ELEVATION 630.0 TO 632.0; AND PEA GRAVEL AND CEMENT GROUT FROM ELEVATION 632.0 TO 660.0.

PIEZOMETER INSTALLED IN D-3B ON 7-13-72 BORING D-3B WAS LOCATED 6 FEET FROM D-3A AND WAS DRILLED TO A DEPTH OF 20.5 FEET. A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS PLACED AT ELEVATION 639.5. PEA GRAVEL WAS PLACED FROM ELEVATION 639.5 TO 649.5; A BENTONITE SEAL FROM ELEVATION 649.5 TO 651.5; AND PEA GRAVEL AND CEMENT GROUT FROM ELEVATION 651.5 TO 660.0.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET

TIP ELEVATION 620.0	TIP ELEVATION 639.5	DATE
9.7	9.9	8-3-72
10.0	10.3	8-15-72
11.0	11.5	9-6-72

REFER TO FIGURE 2.4-37 FOR WATER LEVEL OBSERVATIONS.

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS	SHEAR STRENGTH	MOISTURE CONTENT %	DRY DENSITY Pcf
680					
670					
660					
650				1500	
640				800	
630					
620				4500*	
610				4500*	

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

BORING D-3
SURFACE ELEVATION 660.0

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
4	ML	Top of Salt Creek Alluvium
	SP	BROWN FINE TO MEDIUM SAND (TOPSOIL)
7	CL	BROWN SILTY CLAY WITH TRACE OF VERY FINE SAND (MEDIUM STIFF)
2	SC	ALTERNATING LAYERS OF CLAYEY SAND, SILTY SAND AND FINE TO COARSE SAND WITH SOME GRAVEL (VERY LOOSE AND VERY SOFT)
	ML	
	SP	OCCASIONAL LAYERS OF CLAYEY SILT WITH SAND
39	SP	BASE OF WEATHERED ZONE AT 17.0 FEET
		GRAY FINE TO COARSE SAND WITH SOME GRAVEL (DENSE)
12/10		Top of Illinoian Glacial Till
85/6		GRAY SANDY SILT WITH SOME GRAVEL (HARD)
85	ML	
100/4		

BORING COMPLETED AT 40.0 FEET ON 7-13-72 CASING USED TO A DEPTH OF 20.0 FEET

BORING D-4
SURFACE ELEVATION 656.6


BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
16	ML	DARK BROWN TO BLACK CLAYEY SILT WITH SOME SAND AND ORGANIC MATTER (TOPSOIL)
7	CL	Top of Salt Creek Alluvium
2		BROWN SILTY CLAY WITH SOME FINE SAND (MEDIUM STIFF)
	ML	BROWN CLAYEY SILT WITH SOME FINE SAND (SOFT)
9		OCCASIONAL SEAMS OF FINE SAND
	SP	GRAYISH-BROWN FINE SAND
13		
	SP	BROWN FINE TO COARSE SAND WITH GRAVEL (MEDIUM DENSE)
17		
	SW	
42		
		Top of Illinoian Glacial Till
90		GRAY SANDY SILT WITH CLAY AND SOME GRAVEL (HARD)
100/6	ML	

BORING COMPLETED AT 39.5 FEET ON 7-14-77 CASING USED TO A DEPTH OF 20.0 FEET WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-76

LOG OF BORINGS D-3 AND D-4




LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION				POCKET PNEUMOMETER
				σ ₁ pcf	σ ₃ pcf	σ ₁ pcf	σ ₃ pcf			
660										
650	C	20.1	9.5			775		500	27.4 33.1	96 88
640								4500+		
630								4500+	8.8	134
620								4500+	7.1	147
610								4500+		
600	C							4500+	6.5	136
590								4500+		
580				2040	6000			4500+	16.5	115
570	TX/DY			9650	6000			4500+	9.0	135

BORING D-6

SURFACE ELEVATION 656.0

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 80.0 FEET ON 7-18-72
CASING USED TO A DEPTH OF 20.0 FEET
WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-78

LOG OF BORING D-6

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 / psf	σ_3 / psf				
560									
650									
640									
630							4500 ⁺		
620							4500 ⁺		
610							4500 ⁺		

BORING D-7
SURFACE ELEVATION 655.7

BLOW COUNTS
SAMPLES

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
13	ML	DARK BROWN TO BLACK CLAYEY SILT WITH SOME FINE SAND AND ORGANIC MATTER (TOPSOIL)
12	CL	<i>Top of Salt Creek Alluvium</i> BROWN AND GRAY SILTY CLAY (STIFF)
2	ML	BROWN AND GRAY CLAYEY SILT WITH FINE SAND (SOFT)
30	SP	BROWN AND GRAY FINE TO MEDIUM SAND WITH SOME GRAVEL AND TRACE OF SILT (DENSE)
39	ML	<i>Top of Illinoian Glacial Till</i> GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
15/9'	ML	GRAY SANDY SILT WITH CLAY AND SOME GRAVEL (HARD)
170/10'		
147		
173/10'		

BORING COMPLETED AT 39.5 FEET
ON 7-18-72
CASING USED TO A DEPTH OF 7.0 FEET

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-79

LOG OF BORING D-7

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{q_1 - q_2}{3}$ psi	q_1 psi	$\frac{q_u}{2}$ psi	$\frac{q_u}{2}$ psi		
660								24.7	86
650	c	18.8	12.2				1000	25.8	95
640									
630	TX/CU/PP						4500+		
620									
610								7.1	134
600									
590	TX/CU/PP								
580									
570									
560						4100		10.1	130
550									
540						4160		8.6	132
530							4500+		

BORING D-8

SURFACE ELEVATION 655.7

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
9	ML	DARK BROWN CLAYEY SILT WITH ORGANIC MATTER (TOPSOIL)
3	CL	Top of Salt Creek Alluvium BROWN SILTY CLAY (SOFT)
1	ML	BROWN AND GRAY CLAYEY SILT (SOFT)
14	ML	GRAY VERY FINE SANDY SILT WITH CLAY (SOFT TO VERY LOOSE)
20	SP GP	BROWN FINE TO COARSE SAND AND GRAVEL (MEDIUM DENSE)
109		Top of Illinoian Glacial Till GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (VERY STIFF)
130		GRADES TO HARD
80/6"	ML	
97/6"		OCCASIONAL SEAMS OF VERY FINE SANDY SILT
103/6"		
90		
109	SW	MEDIUM TO COARSE SAND WITH SOME GRAVEL (AQUIFER WITH ARTESIAN HEAD TO GROUND SURFACE)
99	ML	GRAY SILT WITH TRACE OF CLAY AND OCCASIONAL SEAM OF FINE SAND (GLACIAL OUTWASH)
97		GRAY CLAYEY SILT WITH SAND AND GRAVEL AS ABOVE (TILL)
117		
104		
100		
161	ML	OCCASIONAL SEAMS OF SANDY SILT WITH GRAVEL
63		
41		
74		
90		OCCASIONAL SEAMS OF SILTY FINE SAND
70		GRADES WITH MORE CLAY
98		
80		

BORING COMPLETED AT 120.0 FEET ON 7-19-72
CASING USED TO A DEPTH OF 58.0 FEET

PIEZOMETER INSTALLED IN D-8 ON 7-19-72
BORING D-8B WAS LOCATED ADJACENT TO 8A AND WAS DRILLED TO A DEPTH OF 16.0 FEET A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS PLACED AT ELEVATION 639.7. PEA GRAVEL WAS PLACED FROM ELEVATION 639.7 TO 654.2; AND CEMENT GROUT FROM ELEVATION 654.2 TO 655.7.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
5.9	8-3-72
6.2	8-15-72
7.8	9-6-72

REFER TO FIGURE 2.4-37 FOR WATER LEVEL OBSERVATIONS.

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-80

LOG OF BORING D-8

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				e	f	q	s		
660									
650									
640									
630									
620							4500+		
610							4500+		

BORING D-9

SURFACE ELEVATION 654.8

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

14	ML	DARK BROWN TO BLACK CLAYEY SILT WITH SOME FINE SAND AND ORGANIC MATTER (TOPSOIL)
8	CL	<i>Top of Salt Creek Alluvium</i> BROWN STIFF CLAY WITH SOME SAND (STIFF)
10		BROWN FINE TO COARSE SAND WITH SOME GRAVEL (MEDIUM DENSE)
30	SP	
29	SW	GRADES BROWNISH-GRAY
173	SP	GRAY FINE TO MEDIUM SAND WITH TRACE OF GRAVEL (VERY DENSE)
160		<i>Top of Illinoian Glacial Till</i> GRAY SANDY SILT WITH CLAY AND SOME GRAVEL (HARD)
169	ML	
166		

BORING COMPLETED AT 39.5 FEET ON 7-18-72
CASING USED TO A DEPTH OF 7.0 FEET

WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-81

LOG OF BORING D-9


NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				$\sigma_1 - \sigma_3$ pcf	σ_3 pcf			q_u pcf		
660									13.0	98
650	D/CD D/CD D/CD									
640	D/CD D/CD D/CD							4500+		
630	PERM SA							4500+	7.2	131
620										
610								4500+		
600								4500+		
590	SA D/CD								14.8	116
580								4500+		
570								4500+		

BORING D-10
SURFACE ELEVATION 658.0



BORING COMPLETED AT 80.0 FEET ON 7-19-72
CASING USED TO A DEPTH OF 6.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-82

LOG OF BORING D-10

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REQUIRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 pcf	σ_3 pcf	σ_u pcf	q_u pcf		
660									
650								1700	23.2
640								4500+	10.7 135
630	D/CD							4500+	7.5 142
620								4500+	
610	TX/DY							4500+	
600	TX/DY			16,900	4000			4500+	7.9 139
590				15,300	4000			4500+	8.4 137
580								4500+	
570	DR D/CD							4500+	
560								4500+	
550								4500+	
540								4500+	
530								4500+	
520	D/CD							4500+	
510								4500+	9.6 128
500								4500+	

BLOW COUNTS
SAMPLES

BORING D-11
SURFACE ELEVATION 653.8

SYMBOLS

DESCRIPTIONS

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
7	ML	DARK BROWN CLAYEY SILT WITH TRACE OF ORGANIC MATTER (TOPSOIL)
P	CL	Top of Salt Creek Alluvium DARK GRAY AND BROWN SILTY CLAY WITH SOME FINE SAND (STIFF)
P	SM	OCCASIONAL SAND SEAM
20	SP	GRADES TO MOTTLED DARK GRAY AND BROWN AND ORGANIC MATTER
27	SW	GRAY SILTY FINE SAND WITH POCKETS OF CLAY AND ORGANIC MATTER Top of Illinoian Glacial Till GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
166		SEAM OF SAND
107		6 INCH SEAM COARSE GRAVEL
170/10"		
100.6"		LAYER OF SAND AND GRAVEL
144		
82		
100		LAYERS OF FINE TO COARSE SAND WITH GRAVEL
152/10"		
115	SP	18 INCH LAYER OF FINE TO MEDIUM SAND (AQUIFER WITH ARTESIAN HEAD TO GROUND SURFACE)
85	ML	20 INCH LAYER OF GRAVEL
112		
78		
94		6 INCH LAYER OF SAND
65		PIECES OF ORGANIC MATTER
66		
67		
69		3 INCH SEAM OF GRAVEL
96		
75		
91		
30		3 INCH SEAM OF GRAVEL GRADES WITH MORE CLAY GRADES WITH LESS CLAY
62		Top Of Pre-Illinoian Glacial Till (ESTIMATED) GRADES WITH SEAMS OF CLAY GRADES TO MOTTLED GREEN AND GRAY
52		TRACE OF ORGANIC MATERIAL


BORING CONTINUED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-83

LOG OF BORING D-11


(SHEET 1 of 3)



ELEVATION IN FEET

TESTS REPORTED ELSEWHERE	LABORATORY TEST DATA										MOISTURE CONTENT %	DRY DENSITY pci
	ATTERBERG LIMITS		SHEAR STRENGTH									
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION	POCKET PENETROMETER					
			σ_1 psi	σ_3 psi	σ_c psi							
340												
330												
320												
310												

BORING D-II CONTINUED
SURFACE ELEVATION



SYMBOLS
DESCRIPTIONS
LIGHT GRAY MICACEOUS SILTSTONE WITH OCCASIONAL THIN SEAM OF SHALE, VERY SANDY IN ZONES, MASSIVE

PIEZOMETER INSTALLED IN D-11 ON 6-21-72 BORING FLUSHED WITH CLEAR WATER AFTER COMPLETION AT 343.5 FEET. A 3/4 INCH PVC PIPE WITH AN 18 INCH POROUS STONE TIP WAS PLACED AT ELEVATION 493.8. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 310 TO 310.3; A BENTONITE SEAL FROM ELEVATION 513.8 TO 515.3; AND GRAVEL AND CEMENT GROUT FROM ELEVATION 515.3 TO 653.8.

BORING COMPLETED AT 343.5 FEET ON 6-19-72 CASING USED TO A DEPTH OF 65.0 FEET

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
33.5	6-29-72
PROBE LODGED AT 34.5 - NO WATER	7-7-72

REFER TO FIGURE 2.4-37 FOR WATER LEVEL OBSERVATIONS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-83
LOG OF BORING D-11
(SHEET 3 of 3)


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS RUN HERE OR ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{q_1 - q_2}{2}$ #	q_1 #	q_u #	q_p #		
680									
670							4300		
660	SA							4.9	
650									
640							4500 ⁺		
630							4500 ⁺		
620							4500 ⁺		

BORING D-12

SURFACE ELEVATION: 677.4



BORING COMPLETED AT 49.5 FEET ON 7-31-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-84

LOG OF BORING D-12

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION pcf	POCKET PENETROMETER pcf		
				σ_1	σ_3				
				pcf	pcf				
690									
680	PERM SA						1700	21.9 24.8	104 94
670									
660	PERM SA							6.4	105
650									
640				14,600	4000		4500 ⁺	8.5	137
630	SA PERM						4500 ⁺	7.3	142
620							4500 ⁺		
610				24,600	6000		4500 ⁺	6.5	141
600									

BORING D-13
SURFACE ELEVATION 685.4

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
8	ML	LIGHT BROWN CLAYEY SILT WITH ROOTS - (TOPSOIL)
7	ML	BROWN CLAYEY SILT WITH FINE SAND (MEDIUM STIFF) (WEATHERED LOESS)
7	SP	BROWN FINE TO MEDIUM SAND WITH SOME SILT (LOOSE) (GLACIAL OUTWASH)
14		BROWN FINE TO COARSE SAND WITH TRACE OF GRAVEL AND SILT (MEDIUM DENSE)
12	SP	GRADES WITH TRACE OF SILT
23	SW	
9		GRADES TO LOOSE
22		Top of Illinoisian Glacial Till
46		GRAY CLAYEY SILT WITH SAND AND TRACE OF GRAVEL (VERY STIFF) GRADES TO HARD
41		
79		
134	ML	
128		
100/6"		OCCASIONAL SEAMS OF SILT
100/5"		GRADES WITH LESS CLAY
155		
100/5"		

BORING COMPLETED AT 80.0 FEET
ON 8-1-72
CASING USED TO A DEPTH OF 6.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-85

LOG OF BORING D-13


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FINER NO. 200 SIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	FLUIDITY INDEX %	LIQUID LIMIT %	PLASTICITY INDEX %			
		Q ₁	Q ₃	Q ₅							
0											
5											
10								13.3	122		
15								12.4			
20				6200	16.8	11.2	12.0	131			
25	MA							11.8			
30											
35								7.5			
40	MA							9.5	137	55	
45								8.2	139		
50	PERM MA			2300	34.5	1.5	29.0	94	92.5		
55								11.5	132		
60								7.7	139		
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING D-14
SURFACE ELEVATION 701.1

ELEVATION
(FEET)



- NOTES**
1. Logged by: Sargent & Lundy Engineers
 2. Drilled by: Raymond International
 3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-86

LOG OF BORING D-14

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 psi	σ_3 psi	q_u psi	q_p psi		
660								1800	
650								700	
640									
630								4500+	
620								4500+	
610								4500+	

BORING D-16
SURFACE ELEVATION 659.5

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
11	ML	DARK BROWN CLAYEY SILT WITH FINE SAND AND ORGANIC MATTER (TOPSOIL)
5	CL	<i>Top of Salt Creek Alluvium</i> BROWN CLAYEY SILT WITH TRACE OF SAND (MEDIUM STIFF)
3	ML	MOTTLED BROWN AND GRAY CLAYEY SILT WITH FINE SAND (SOFT)
5	ML	GRADING TO VERY FINE SANDY SILT WITH LAYERS OF CLAYEY SILT
24	SP SW	BROWN AND GRAY FINE TO COARSE SAND WITH SILT AND GRAVEL (MEDIUM DENSE)
66		<i>Top of Illinoian Glacial Till</i> GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
124	ML	
102		
100/6		

OCCASIONAL SEAMS OF SANDY SILT WITH SOME GRAVEL

BORING COMPLETED AT 39.5 FEET ON 7-25-72
CASING USED TO A DEPTH 21.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-87

LOG OF BORING D-16

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA								
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET		
			$\frac{e-f}{3}$ psi	$\frac{e}{3}$ psi	$\frac{e}{3}$ psi	psi		
						2600		
						4500+		
						4500+		
						4500+		

ELEVATION IN FEET

BORING D-17
SURFACE ELEVATION 662.9

BLOW COUNTS
SAMPLES

SYMBOLS		DESCRIPTIONS
17	ML	DARK BROWN TO BLACK CLAYEY SILT WITH FINE SAND AND ORGANIC MATTER (TOPSOIL)
12	CL	<i>Top of Salt Creek Alluvium</i> BROWN SILTY CLAY WITH SOME FINE SAND (STIFF) GRADES WITH MORE SAND AND SOME GRAVEL
6	ML	BROWN CLAYEY SILT WITH SAND AND SOME GRAVEL (VERY STIFF)
36	ML	
94	SP	BROWN FINE TO COARSE SAND WITH SOME GRAVEL (VERY DENSE)
141	ML	<i>Top of Illinoian Glacial Till</i> GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
100.5	ML	
175.5		
100.5		

BORING COMPLETED AT 39.0 FEET ON 7-13-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-88

LOG OF BORING D-17

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				a) $\frac{\sigma_1 - \sigma_3}{2}$ psf	b) σ_3 psf	c) $\frac{\sigma_c}{2}$ psf	d) $\frac{Q_n}{T}$ psf		
		660							
650	c	17.2	15.1			1700		11.7	112
640									
630									
620	c						4500 ⁺	7.2	136
610							4500 ⁺		

BORING D-18
SURFACE ELEVATION 657.1

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
11	OL ML	BLACK CLAYEY SILT WITH ORGANIC MATTER (TOPSOIL)
6		<i>Top of Salt Creek Alluvium</i>
3	CL	MOTTLED BROWN AND GRAY SILTY CLAY WITH FINE SAND AND TRACE OF ORGANIC MATTER (MEDIUM STIFF)
1/18		GRADES TO SOFT
5	SP	BROWN FINE TO COARSE SAND WITH SOME GRAVEL (VERY LOOSE TO LOOSE)
12		GRADES WITH MORE GRAVEL
52		GRADES WITH TRACE OF SILT
146/1 ¹	ML	<i>Top of Illinoian Glacial Till</i> GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
100/6 ²		GRADES WITH LESS CLAY

BORING COMPLETED AT 39.5 FEET
ON 7-24-72
CASING USED TO A DEPTH OF 20.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-89

LOG OF BORING D-18

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

ELEVATION IN FEET	LABORATORY TEST DATA									
	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCT	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				σ_1 T	σ_3 B	σ_c T	q_p T			
660										
650							1100			
640										
630	SA							13.5		
620							4500 ⁺			
610										

BORING D-19
SURFACE ELEVATION 658.9

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
15	ML	DARK BROWN TO BLACK CLAYEY SILT WITH FINE SAND AND ORGANIC MATTER (TOPSOIL)
15	CL	<i>Top of Salt Creek Alluvium</i> DARK BROWN SILTY CLAY WITH TRACE OF FINE SAND (STIFF)
6	CL	BROWN AND GRAY SILTY CLAY (MEDIUM STIFF)
3	ML	BROWN AND GRAY CLAYEY SILT WITH LENSES OF SILTY VERY FINE SAND (SOFT) GRADES WITH MORE FINE SAND
7	SP SW	BROWN FINE TO COARSE SAND WITH SOME GRAVEL AND TRACE OF SILT (LOOSE TO MEDIUM DENSE)
12		<i>Top of Illinoian Glacial Till</i>
98	ML	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
88		
184/9		

BORING COMPLETED AT 38.7 FEET
ON 7-13-72
CASING USED TO A DEPTH OF 7.0 FEET

PIEZOMETERS INSTALLED IN D-19B ON 7-13-72
BORING D-19B WAS DRILLED TO 38.0 FEET
ADJACENT TO D-19A AND WAS FLUSHED WITH
CLEAN WATER AFTER COMPLETION. A 3/4
INCH PVC PIPE WITH A POROUS STONE TIP WAS
PLACED AT ELEVATION 620.9. PEA GRAVEL
WAS PLACED FROM ELEVATION 620.9 TO 625.9.
A BENTONITE SEAL FROM 625.9 TO 628.9,
AND PEA GRAVEL FROM 628.9 TO 630.9.
A 3/4 INCH PVC PIPE WITH A POROUS STONE TIP
WAS PLACED AT ELEVATION 630.9. PEA
GRAVEL WAS PLACED FROM ELEVATION 630.9
TO 635.9; A BENTONITE SEAL FROM ELEVATION
635.9 TO 637.1; AND GRAVEL FROM ELEVATION
637.1 TO 658.9.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET		DATE
TIP ELEVATION 620.9	TIP ELEVATION 630.9	
8.9	8.8	8-8-72
9.7	10.0	8-22-72
10.5	10.5	9-6-72

REFER TO FIGURE 2.4-37 FOR
WATER LEVEL OBSERVATIONS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-90

LOG OF BORING D-19

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\bar{\sigma}_1$	σ_3				
				q	pcf	d	pcf		
660									
650								600	
640									
630									
620								4500 ⁺	
610								4500 ⁺	

BORING D-20
SURFACE ELEVATION 655.2

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
9	ML	DARK BROWN CLAYEY SILT WITH ORGANIC MATTER (TOPSOIL)
	CL	<i>Top of Salt Creek Alluvium</i>
2	ML	BROWN SILTY CLAY WITH SOME SAND (STIFF)
1	CL	MOTTLED BROWN AND GRAY CLAYEY SILT AND SILTY CLAY (SOFT)
	SP	BROWN AND GRAY FINE TO COARSE SAND WITH SOME GRAVEL (VERY LOOSE)
29	SW	GRADES TO MEDIUM DENSE GRADES WITH MORE GRAVEL
		<i>Top of Illinoian Glacial Till</i>
33	ML	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
100/7"		OCCASIONAL SEAMS OF SAND
100/2"		SEAMS OF SILTY VERY FINE SAND
100/4"	ML	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
105/4"		

BORING COMPLETED AT 40.0 FEET ON 7-25-72
CASING USED TO A DEPTH OF 21.0 FEET
WATER LEVEL NOT RECORDED.

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS	SHEAR STRENGTH	MOISTURE CONTENT %	DRY DENSITY pcf
660					
650					1300
640					4500 ⁺
630					4500
620					4500 ⁺
610					4500 ⁺

BORING D-21
SURFACE ELEVATION 656.0

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
11	ML	DARK BROWN TO BLACK CLAYEY SILT WITH FINE SAND AND ORGANIC MATTER - (TOPSOIL)
	CL	<i>Top of Salt Creek Alluvium</i>
12		BROWN AND GRAY SILTY CLAY (STIFF)
10	SP	BROWN FINE TO MEDIUM SAND WITH TRACE OF COARSE SAND AND GRAVEL (MEDIUM DENSE)
		<i>Top of Illinoian Glacial Till</i>
42		GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
80		GRADES WITH OCCASIONAL SEAMS OF SAND AND GRAVEL
89	ML	
185		
100/6"		
188		

BORING COMPLETED AT 40.0 FEET ON 7-14-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-91

LOG OF BORINGS D-20 AND D-21

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA										
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf		
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER				
			σ_1 pcf	σ_3 pcf	σ_u pcf	σ_p pcf				
									900	
									4500 ⁺	
									4500 ⁺	
									4500 ⁺	

BORING D-22
SURFACE ELEVATION 654.7

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
8	ML	DARK BROWN TO BLACK CLAYEY SILT WITH SOME FINE SAND AND ORGANIC MATTER - (TOPSOIL)
1	CL	<i>Top of Salt Creek Alluvium</i> BROWN SILTY CLAY WITH SOME SAND (VERY SOFT TO SOFT)
1	SP	BROWN FINE TO MEDIUM SAND WITH TRACE OF SILT (VERY LOOSE)
23	SP	BROWN AND GRAY FINE TO COARSE SAND WITH GRAVEL (MEDIUM DENSE)
20	SW	
95	SM	<i>Top of Illinoisian Glacial Till</i> GRAY SILTY FINE TO COARSE SAND WITH SOME GRAVEL AND TRACE OF CLAY (VERY DENSE)
105		
100/9"	ML	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
100/6"		

BORING COMPLETED AT 39.5 FEET
ON 7-21-72
CASING USED TO A DEPTH OF 19.0 FEET
WATER LEVEL NOT RECORDED.

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS	SHEAR STRENGTH	MOISTURE CONTENT %	DRY DENSITY pcf
660					
650					1300
640					4500 ⁺
630					4500 ⁺
620					4500 ⁺
610					4500 ⁺

BORING D-23
SURFACE ELEVATION 655.8

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
7	ML	DARK BROWN TO BLACK CLAYEY SILT WITH FINE SAND AND ORGANIC MATTER - (TOPSOIL)
9	CL	<i>Top of Salt Creek Alluvium</i> BROWN AND GRAY SILTY CLAY WITH SOME VERY FINE SAND (MEDIUM STIFF)
2	ML	BROWN AND GRAY CLAYEY SILT (VERY SOFT TO SOFT)
18	SP	BROWN FINE TO COARSE SAND WITH SOME GRAVEL (MEDIUM DENSE)
29		<i>Top of Illinoisian Glacial Till</i>
45		GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
160/3"	ML	GRADES WITH LESS CLAY
135		
100/5"		
100/6"		

BORING COMPLETED AT 39.0 FEET
ON 7-14-72
CASING USED TO A DEPTH OF 7.0 FEET

PIEZOMETERS INSTALLED IN D-23 ON 7-14-72
BORING D-23B WAS DRILLED TO 35.0 FEET
ADJACENT TO D-23A AND WAS FLUSHED WITH
CLEAN WATER AFTER COMPLETION. A BENTONITE
SEAL WAS PLACED FROM ELEVATION 620.8 TO
624.3, AND A 3/4 INCH PVC PIPE WITH A POROUS STONE
STONE TIP WAS PLACED AT ELEVATION 624.3.
PEA GRAVEL WAS PLACED FROM ELEVATION 624.3
TO 630.8 AND A BENTONITE SEAL FROM ELEVATION
630.8 TO 639.8. A 3/4 INCH PVC PIPE WITH
A POROUS STONE TIP WAS PLACED AT ELEVATION
641.0. PEA GRAVEL WAS PLACED FROM ELEVATION
639.8 TO 644.3; A BENTONITE SEAL FROM ELEVATION
644.3 TO 652.8; AND CONCRETE FROM ELEVATION
652.8 TO 655.8.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	TIP ELEVATION 624.3	T+P ELEVATION 641.0	DATE
4.9		6.4	8-8-72
5.3		6.9	8-22-72
6.0		8.4	9-6-72

REFER TO FIGURE 2.4-37 FOR
WATER LEVEL OBSERVATIONS.

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.


**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-92

LOG OF BORINGS D-22 AND D-23

LABORATORY TEST DATA									
ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCT
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 T PCT	σ_3 D PCT				
660									
650	D/CD D/CD D/CD D/CD								
640	D/CD D/CD								
630	PERM SA						4500 ⁺	7.4	123
620							4500 ⁺ 4500 ⁺		
610							4500 ⁺		


BORING D-24
SURFACE ELEVATION 655.0



BORING COMPLETED AT 39.5 FEET ON 7-24-72
CASING USED TO A DEPTH OF 18.5 FEET
WATER LEVEL NOT RECORDED.

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCT
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 T PCT	σ_3 D PCT				
660									
650									
640									
630							4500 ⁺		
620							4500 ⁺ 4500 ⁺		
610							4500 ⁺		

BORING D-25
SURFACE ELEVATION 655.6



BORING COMPLETED AT 39.0 FEET ON 7-19-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT

FIGURE 2.5-93

LOG OF BORINGS D-24 AND D-25

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION				POCKET PENETROMETER
				σ_1	σ_3	q_u	q_u			
				pcf	pcf	pcf	pcf			
730										
720										
710										
700										
690										
680										
670										
660										
650										
640										
630										
620										
610										

BORING D-29
SURFACE ELEVATION 721.6

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
12	ML	BROWN CLAYEY SILT WITH ROOTS - (TOPSOIL)
	CL	BROWN SILTY CLAY WITH TRACE OF SAND (STIFF) (WEATHERED LOESS)
9	SM	BROWN SILTY SAND WITH SOME CLAY (LOOSE)
11	ML	<i>Top of Wisconsinan Glacial Till</i> BROWN CLAYEY SILT WITH SAND (STIFF)
23	CL	BROWN SILTY CLAY WITH SAND (VERY STIFF) BASE OF WEATHERED ZONE AT 17.0 FEET
19	CL ML	GRAY SILTY CLAY WITH SOME SAND AND LAYERS OF CLAYEY SILT (VERY STIFF)
21	ML	GRAY SILT WITH TRACE OF CLAY AND OCCASIONAL GRAVEL (MEDIUM DENSE)
26	CL	GRAY SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (VERY STIFF)
	SP	<i>Top of Interglacial Zone</i> BROWN FINE TO COARSE SAND WITH SOME GRAVEL
18	OL PT	DARK BROWN ORGANIC SILT WITH LAYERS OF PEAT (VERY STIFF)
13	CL	GREENISH-GRAY SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (STIFF)
33	ML	<i>Top of Illinoian Glacial Till</i> GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
100/7"	ML	GRADES WITH MORE SAND
88		
47	SP	GRAY FINE TO COARSE SAND WITH TRACE OF SILT AND GRAVEL (DENSE) (GLACIAL OUTWASH)
88		
65		GRADES WITH LAYERS OF SANDY SILT WITH SOME GRAVEL
100/7"		GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (HARD)
100/6"	ML	
100/7"		
100/2"		
100/7"		
100/2"	SP	GRAY FINE TO MEDIUM SAND WITH TRACE OF SILT (VERY DENSE) (GLACIAL OUTWASH) BORING COMPLETED AT 99.0 FEET ON 7-27-72 CASING USED TO A DEPTH OF 19.0 FEET WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-94

LOG OF BORING D-29


NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	LIQUIDITY INDEX %	TRIAxIAL COMPRESSION		UNIDRILLED PENETRATION				
			Q ₁ pcf	Q ₂ pcf	q ₁ pcf	q ₂ pcf	q ₃ pcf		
							2260	19.6	105
SA								20.8	104
								11.7	117
D/CO									

ELEVATION IN FEET

BORING D-30
SURFACE ELEVATION 669.9



PIEZOMETER D-30A INSTALLED IN BORING D-30 ON 7-27-72. A 3/4 INCH PVC PIPE WITH A POROUS STONE TIP WAS PLACED AT ELEVATION 620. PEA GRAVEL WAS PLACED FROM ELEVATION 620 TO 625. BENTONITE PLACED FROM 625 TO 627 AND CEMENT GROUT FROM ELEVATION 627 TO 669.9.

PIEZOMETER D-30B INSTALLED IN BORING D-30B (DRILLED ADJACENT TO D-30A) ON 7-27-72. A 3/4 INCH PVC PIPE WITH A POROUS STONE TIP WAS PLACED AT ELEVATION 658. PEA GRAVEL WAS PLACED FROM ELEVATION 658 TO 666.4 AND CEMENT GROUT FROM ELEVATION 666.4 TO 669.9.

PIEZOMETER D-30C INSTALLED IN BORING D-30C (DRILLED ADJACENT TO D-30A) ON 8-3-72. 15 FEET OF 4 INCH CASING WAS USED TO SEAL OFF THE SALT CREEK ALLUVIUM. A 3/4 INCH PVC PIPE WITH A POROUS STONE TIP WAS PLACED FROM ELEVATION 680. PEA GRAVEL WAS PLACED FROM ELEVATION 620 TO 625. A BENTONITE SEAL FROM ELEVATION 625 TO 627 AND CEMENT GROUT FROM ELEVATION 627 TO 669.9.

WATER LEVEL READINGS
(DEPTH BELOW GROUND SURFACE IN FEET)

D-30A	D-30B	D-30C	DATE
9.7	9.6	42.3	8-8-72
10.0	10.0	41.9	8-22-72
10.0	10.0	41.8	9-6-72

REFER TO FIGURE 2.4-37 FOR WATER LEVEL OBSERVATIONS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{\sigma_1 - \sigma_3}{2}$	σ_3	$\frac{q_u}{2}$	q_u		
670									
660								21.4	98
650	TX/DY			2950	2500			8.3	131
	TX/DY			15,000	2500			7.6	140
640									
630									
620				22,800	5000			8.4	137
610	CHEM*							8.6	135
600								9.0	138
590				18,000	7000			8.8	137
580								7.7	143
570								17.2	116
560									
550									
540	TX/DY								
530									
520				6080	10,000			11.6	129
510									


* ON WATER SAMPLE OBTAINED ON 10-7-72

BORING CONTINUED

BORING D-31

SURFACE ELEVATION 667.7

BLOW COUNTS
SAMPLES



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-96


LOG OF BORING D-31

(SHEET 1 of 3)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ ₁ psi	σ ₃ psi				
510									
500	TX/DY			3690	10,000			17.5	114
490						3900		14.8	116
480									
470									
460									
450									
440	SA							17.4	106
430									
420									
410									
400									
390									
380									
370									
360									
350									


BORING D-31 CONTINUED
SURFACE ELEVATION'



BORING CONTINUED

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-96
LOG OF BORING D-31
(SHEET 2 of 3)



PIEZOMETER INSTALLED IN D-31 ON 6-16-72
BORING WAS FLUSHED WITH CLEAN WATER
AFTER COMPLETION AT 356.5 FEET. A 3/4
INCH PVC PIPE WITH AN 18 INCH POROUS STONE
TIP WAS PLACED AT ELEVATION 461.7. GRANULAR
BACKFILL WAS PLACED FROM ELEVATION 311.2
TO 509.7; A BENTONITE SEAL FROM ELEVATION
509.7 TO 511.2; AND CEMENT GROUT AND GRAVEL
FROM 511.2 TO 667.7.

BORING COMPLETED AT 356.5 FEET
ON 6-14-72
CASING USED TO A DEPTH OF 14.0 FEET

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
54.8	8-3-72
54.3	8-15-72
54.7	9-6-72

REFER TO FIGURE 2.4-37 FOR
WATER LEVEL OBSERVATIONS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-96
LOG OF BORING D-31
(SHEET 3 of 3)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\sigma_1 - \sigma_3$	σ_3	q_u	q_p		
				a) pcf	b) pcf	c) pcf	d) pcf		
730									
720									
710									
700									
690									
680									
670									
660									
650									
640									

BORING D-32
SURFACE ELEVATION 720.0

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
17	ML	BROWN CLAYEY SILT WITH ROOTS - (TOPSOIL)
6	ML	BROWN CLAYEY SILT WITH SOME FINE SAND (MEDIUM STIFF)
9		<i>Top of Wisconsinan Glacial Till</i>
6	ML	BROWN CLAYEY SILT WITH SOME SAND AND OCCASIONAL GRAVEL (MEDIUM STIFF)
	CL	GRADES WITH MORE CLAY
		BASE OF WEATHERED ZONE AT 20.0 FEET
6		
5		<i>Top of Interglacial Zone</i>
	ML	DARK BROWN TO DARK GRAY SILT WITH SOME CLAY AND ORGANIC MATTER (MEDIUM STIFF)
6		GRAY SILT CLAY WITH TRACE OF SAND AND OCCASIONAL GRAVEL (MEDIUM STIFF)
	CL	
8		GREENISH-GRAY SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (STIFF)
	CL	
19		<i>Top of Illinoian Glacial Till</i>
	ML	GRAY CLAYEY SILT WITH SAND AND SOME GRAVEL (VERY STIFF)
	CL	
21		
96		GRAY SANDY SILT WITH SOME CLAY AND OCCASIONAL GRAVEL (VERY DENSE TO HARD)
51		
73		GRADES WITH MORE CLAY
42		
35		GRADES WITH LESS CLAY AND SEAMS OF SILTY SAND
100/5"		
100/6"		

BORING COMPLETED AT 79.0 FEET
ON 7-27-72
CASING USED TO A DEPTH OF 5.0 FEET
WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-97

LOG OF BORING D-32


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH			MOISTURE CONTENT %	DRY DENSITY pcf	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION			POCKET PENETROMETER
				$\frac{\sigma_1 - \sigma_3}{2}$	σ_3	$\frac{q_u}{2}$			$\frac{q_u}{2}$
				psi	psf	psi			psf
660									
650							300		
640							3400		
630							4500+		
620							4500+		
610							4500+		

BORING D-33
SURFACE ELEVATION 654.9

BLOW COUNTS
SAMPLES




BORING COMPLETED AT 39.5 FEET
ON 7-20-72
CASING USED TO A DEPTH OF 18.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-98

LOG OF BORING D-33

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



BORING COMPLETED AT 80.0 FEET ON 7-31-72
CASING USED TO A DEPTH OF 6.0 FEET
WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-99

LOG OF BORING D-34


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 psf	σ_3 psf	σ_u psf	q_u psf		
680									
670									
660									
650									
640								4500+	
630								4500+	
620								4500+	
610								4500+	

BORING D-35
SURFACE ELEVATION 677.8

BLOW COUNTS
SAMPLES




BORING COMPLETED AT 59.0 FEET
ON 7-31-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-100

LOG OF BORING D-35

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



BORING D-36
SURFACE ELEVATION 670.0


BORING COMPLETED AT 59.5 FEET
ON 8-1-72
CASING USED TO A DEPTH OF 7.0 FEET
WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-101

LOG OF BORING D-36

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-102

LOG OF BORING D-37

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA											
ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH						MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION		POCKET PENETROMETER		
				σ_1 psi	σ_3 psi	σ_2 psi	q_u psi	q_p psi			
690											
680									1750	17.9	100
									1000	21.0	106
670											
								4420	4500+	9.0	136
660									4500+		
	C								4500+	20.2	111
650									4500+	10.8	130
									4500+		
640								5940	4500+	9.4	135
								6700	4500+	9.2	135
630									4500+		
									4500+		
620									4500+		

BORING D-40
SURFACE ELEVATION 681.1



OCCASIONAL SAND LAYERS


BORING COMPLETED AT 55.5 FEET ON 4-19-73
CASING USED TO DEPTH OF 15.0 FEET
WATER LEVEL NOT RECORDED

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-103

LOG OF BORING D-40




ELEVATION IN FEET

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-104

LOG OF BORING D-4I

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-105

LOG OF BORING D-42

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-106

LOG OF BORING D-43

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REQUIRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{q_1 - q_2}{2}$	q_3	q_u	$\frac{q_u}{2}$		
				pcf	pcf	pcf	pcf		
660									
650							2000		
								31.0	92
640							1000		
							4500+		
630							10,640	4500+	7.1
620									

BORING D-44
SURFACE ELEVATION 660.0

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
8	CL	LIGHT BROWN SANDY CLAY WITH OCCASIONAL GRAVEL <i>Top of Salt Creek Alluvium</i>
	ML	DARK GRAY CLAYEY SILT WITH SAND
5	CL	DARK GRAY TO BLACK CLAY WITH SILTY SAND AND TRACE OF GRAVEL AND ORGANICS (STIFF) GRADES WITH MORE SAND
2	SC	LIGHT BROWN CLAYEY SAND
	CL	LIGHT BROWN SANDY CLAY
	SC	GRAY CLAYEY SAND
34		<i>Top of Winigan Glacial Till</i>
125	ML	GRAY CLAYEY SILT WITH SAND AND OCCASIONAL GRAVEL (HARD)
100/3		GRADES VERY SANDY

BORING COMPLETED AT 32.8 FEET
ON 4-24-73
NO CASING USED
WATER LEVEL NOT RECORDED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-107

LOG OF BORING D-44

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1	σ_3	q_u	q_p		
				psi	psi	psi	psi		
670									
660							1000		
650							1500	29.2	97
							1000		
640							4000		
							4500+	7.3	142
630									

BORING D-45
SURFACE ELEVATION 660.4

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
		<i>Top of Salt Creek Alluvium</i>
7	CL	BLACK SANDY CLAY WITH OCCASIONAL GRAVEL GRAVEL GRADES OUT GRADES WITH LESS SAND
4	CL	BROWN CLAY WITH SILT, SOME FINE SAND AND ORGANICS (STIFF)
2	SC	GRAYISH-BROWN CLAYEY SAND WITH SILT
16		<i>Top of Illinoian Glacial Till</i>
100/3'	ML	GRAY CLAYEY SILT WITH SAND AND OCCASIONAL GRAVEL (H ₂ O)
100/6'	SC	GRAY CLAYEY FINE TO COARSE SAND WITH SILT


BORING COMPLETED AT 30.5 FEET ON 4-24-73
NO CASING USED
WATER LEVEL NOT RECORDED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-108

LOG OF BORING D-45

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.




LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCT
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 PPT	σ_3 PPT	σ_u PPT	q_u PPT		
720									
710									
700						3150	4500+	14.1	121
690							4500+		
680	SA						3500	14.0	122
670							3500		
660							4500+		
650							4500+	8.3	133
640							4500+	5.2	144
630							4500+	7.7	139
620							4500+	7.7	143
								7.3	143

BORING D-47

SURFACE ELEVATION 715.7



BORING COMPLETED AT 91.0 FEET ON 4-11-73 CASING USED TO A DEPTH OF 10 FEET

A PIEZOMETER WAS INSTALLED IN D-47A ON 4-24-73. BORING D-47A WAS AUGERED TO 38.0 FEET ADJACENT TO D-47. A 3/4 INCH CPVC PIPE WITH A CAPPED TIP WAS PLACED AT ELEVATION 677.7. THE PIPE WAS SLOTTED FROM ELEVATION 677.7 TO 707.7. PEA GRAVEL WAS PLACED FROM ELEVATION 677.7 TO 713.7. A CONCRETE SEAL WAS PLACED FROM ELEVATION 713.7 TO 715.7.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
13.3	4-25-73
14.3	4-27-73
14.4	4-30-73
18.1	6-12-73
18.5	7-3-73

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-110

LOG OF BORING D-47

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 psf	σ_3 psf	q_u psf	q_p psf		
720								2200	
710	TX/CU PP							2000	
700	TX/CU PP							4500	
690								4500	12.6 124
680	TX/CU PP							4190	4000 12.4 124
670								4000	
660								1420	2250 22.6 104
650								2500	16.3 117
640								4500+	
630								4500+	7.7 143
620								2560	2750 17.0 117
								4500+	9.3 135
								4500+	
								4500+	7.3 143
								4500+	8.4 140
								4500+	
								4500+	


A PIEZOMETER WAS INSTALLED IN D-48A ON 4-24-73. BORING D-48A WAS AUGERED TO 39.0 FEET ADJACENT TO D-48. A 3/4 INCH CPVC PIPE WITH A CAPPED TIP WAS PLACED AT ELEVATION 676.3. THE PIPE WAS SLOTTED FROM ELEVATION 676.3 TO 706.3. PEA GRAVEL WAS PLACED FROM ELEVATION 676.3 TO 713.3. A CONCRETE SEAL WAS PLACED FROM ELEVATION 713.3 TO 715.3.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
25.5	4-25-73
25.6	4-27-73
28.7	6-12-73
28.0	7-3-73

BORING D-48

SURFACE ELEVATION 715.3



BORING COMPLETED AT 90.6 FEET ON 4-13-73 CASING USED TO A DEPTH OF 15 FEET

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-111


LOG OF BORING D-48

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION σ_u	POCKET PENETROMETER		
				$\sigma_1 - \sigma_3$	σ_2				
				σ_1	σ_3				
670									
660							700		
650							1000	12.0	125
640							3600	10.9	130
630							4500+	7.3	143
620							4500+		

BORING D-49
SURFACE ELEVATION 660.6




BORING COMPLETED AT 36.0 FEET ON 4-25-73 CASING USED TO A DEPTH OF 10 FEET WATER LEVEL NOT RECORDED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-112

LOG OF BORING D-49

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-113

LOG OF BORING D-50

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF	PERCENT MOISTURE	FLUIDITY INDEX	PLASTICITY INDEX	FLUIDITY INDEX
		COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX	FLUIDITY INDEX					
		σ_1 psi	σ_3 psi	$\sigma_1 - \sigma_3$ psi									
0													
5													
10	MA								4.8				7.5
15	MA								3.8				6.0
20									12.1				
25					12.2	6.5			11.0				135
30									8.7				137
35									8.7				
40									6.4				139
45													
50													
55													
60													
65													
70													
75													

BLOW COUNTS
SAMPLES

BORING D-51

SURFACE ELEVATION 671.1

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	TOP OF LOESS Brown, silty clay.	666.1
9 SS	TOP OF OUTWASH	
SC	Brown, clayey, fine to coarse sand, and clay, some fine to coarse gravel.	
15 SS	Brown, fine to coarse sand and fine gravel, trace silt and clay.	
SW SM		
24 SS	Brown, fine to coarse sand, trace fine gravel, trace silt and clay.	
SP SM		
14 SS	TOP OF ILLINOIAN TILL Gray, clayey silt, some fine to coarse sand, trace fine gravel.	651.6
ML		
19 SS		
35 SS	Boring completed at 39.0 feet on 4-8-75. Water level at 17.0 feet.	
35 SS		
120 6" SS		

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-114

LOG OF BORING D-51

DEPTH (FEET)	TESTS REPORTED EL SEQUENCE	SHEAR STRENGTH			ATTERBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING NO. 20 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQ. LIMIT %	FLUIDITY INDEX			
		Q ₁	Q ₂	Q ₃						
0										
5										
10	HA								120	
15										
20										
25	HA								120	
30					11.0	8.3	8.4	140		
35	HA						6.0	140	100/3	
40							7.2		100/4	
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING D-52
SURFACE ELEVATION 668.5

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS
	TIP OF LOESS
CL	Brown, silty clay, trace fine to coarse sand.
	TIP OF OUTWASH 666.0
GC	Brown, clayey, fine to coarse gravel.
SW	Brown, fine to coarse sand, trace fine to coarse gravel, trace silt.
SM	
ML	Gray, silt, some fine to coarse sand, trace fine gravel.
2 SS	SW
	SM
	Brown, fine to coarse sand, some fine gravel, trace silt. cobble: noted.
7 SS	
12 SS	
	TIP OF ILLINOIAN TILL 642.0
54 SS	ML
	CL
	Gray, clayey silt, some fine to medium sand, trace fine gravel.
100/3 SS	SM
	ML
	Gray, fine to coarse sand and clayey silt, trace fine gravel.
100/4 SS	

Boring completed at 40.0 feet on 4-7-75.
Water level at 3.5 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.


CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-115
LOG OF BORING D-52

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			DENSITY PCF WET PCF DRY	WATER CONTENT %	PLASTIC INDEX	FLUIDITY
		COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLAS- TICITY INDEX %				
		CU	QU	CV							
0											
5											
10	MA									140	
15	MA									140	
20											
25	MA									120	
30								7.4			
35	MA								4.3	500	
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING D-53
SURFACE ELEVATION 672.1

ELEVATION
(FEET)



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-116


LOG OF BORING D-53

DEPTH (FEET)	TESTS REPORTED ELEVATION	SHEAR STRENGTH			ATTERBERG LIMITS				FIELD MOISTURE CONTENT %	DRY DENSITY PCF	FLUIDITY INDEX %	PIZZETT RABBIT SOIL SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQ. LIMIT %	PLAS. TICITY INDEX %					
		σ_1 psi	σ_3 psi	σ_p psi								
0												
5												
10	MA											180
15	MA											LLD
20												
25								7.4	137			
30					11.1	8.1	7.5					
35								12.7	9.3			
40								6.4				
45												
50												
55												
60												
65												
70												
75												

BLOW COUNTS
SAMPLES

BORING D-54
SURFACE ELEVATION 668.0

ELEVATION
(FEET)




NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-117

LOG OF BORING D-54



- NOTES**
1. Logged by: Sargent & Lundy Engineers
 2. Drilled by: Raymond International
 3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-118

LOG OF BORING D-55

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD WATER CONTENT %	DRY DENSITY PCF	PERCENT FINE SAND 200 SIEVE
		TRIAxIAL COMPRESSION		UNCONSOLIDATED COHESIVE SOILS	PLASTIC LIMIT %	LIQUID LIMIT %	PLAS- TICITY INDEX %			
		q_1 psi	q_3 psi							
0										
5										
10										
15	MA								190	
20										
25										
30	MA								100	
35							23.7			
40							11.2			
45							7.5	138		
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING D-56

SURFACE ELEVATION 686.8

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	CL	Brown, silty clay.	
6	SS	TOP OF OUTWASH	682.3
	SM	Brown, fine to coarse sand, some silt and clay.	
4	SS	-trace fine gravel.	
13	SS		
20	SS	SP Brown, fine sand.	
28	SS	SW SM Brown, fine to coarse sand, some fine to coarse gravel, trace silt.	
5	SS		
10	SS	SP Light brown, fine sand, trace fine gravel, trace silt.	
26	SS	SW SM Gray, fine to coarse sand, some fine to coarse gravel, trace silt.	647.3
	ML	TOP OF ILLINOIAN TILL	
	ML	Gray, clayey silt and fine to coarse sand, trace fine gravel.	
78	SS		
55	SS	ML Gray, clayey silt, some fine to coarse sand, trace fine gravel.	

Boring completed at 50.0 feet
on 4-4-75.
Water level at 29.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-119

LOG OF BORING D-56

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS		FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING NO. 20 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %			
		σ_1 psf	σ_3 psf	$\sigma_1 - \sigma_3$ psf					
0									
5						236			
10						229			
15						127	124		
20									
25	MA							5.0	
30					12.6	8.2	7.9	135	
35						7.1	137		
40									
45	MA					149		525	
50	MA					8.4	140	475	
55						7.0			
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING D-57

SURFACE ELEVATION 694.0

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
6 SS	CL	Brown, silty clay, trace fine to coarse sand. TOP OF WISCONSINAN TILL	687.5
2 SS	ML CL	Brown, clayey silt, trace fine to coarse sand.	
21 SS		-some fine to coarse sand, trace fine gravel.	
52 SS	SW SM	Brown, fine to coarse sand, some fine to coarse gravel, trace silt.	
29 SS		-26.0 to 27.0 feet, cobbles and large gravel noted. TOP OF ILLINOIAN TILL	
69 SS	ML	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
79 SS		-37.0 feet, cobbles noted.	
54 SS	ML SM	Gray, clayey silt and fine to medium sand.	
25 SS			
58 SS	SM ML	Gray, clayey silt and fine to coarse sand, trace fine gravel.	
95 SS		Boring completed at 60.0 feet on 4-8-75. Water level at 12.5 feet.	
80 SS			

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-120

LOG OF BORING D-57

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS		FIELD MOISTURE CONTENT %	DRY DENSITY PCF	WATER CONTENT %
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %			
		σ_1 psi	σ_3 psi	σ_d psi					
0									
5									
10	MA					20.7	255		
15						22.7	115		
20						21.8			
25	MA				13.1 NP	14.2	148 108	124	
30					11.9	7.1	11.7	143	
35							103	138	
40							103		
45	MA						132	465	
50	MA						112	135	
55							9.1	141	
60							110		
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING D-58
SURFACE ELEVATION 695.7

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	TOP OF LOESS Brown, silty clay, trace fine sand.	
6 SS		
4 SS	TOP OF OUTWASH Brown, silty, fine to coarse sand, trace fine gravel.	688.2
20 SS	TOP OF WISCONSINAN TILL Brown, silty clay, trace fine to coarse sand, trace fine gravel.	682.2
9 SS ST	- 18.5 feet color grades to gray.	
15 SS	SM Reddish brown, fine to coarse sand, some fine gravel, some silt and clay.	
33 SS	TOP OF ILLINOIAN TILL ML Gray, clayey silt, trace fine to coarse sand, trace fine gravel.	669.7
79 SS		
26 SS	ML SM Gray, clayey silt and fine to coarse sand, trace fine gravel.	
37 SS	SM ML Gray, clayey silt and fine to medium sand.	
23 SS	ML SM Greenish gray to gray, clayey silt and fine to coarse sand, trace fine gravel.	
68 SS	-53.3 feet color grades to gray.	
42 SS	ML Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
	Boring completed at 60.0 feet on 4-7-75. Water level at 6.5 feet.	

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-121


LOG OF BORING D-58

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING NO. 200 SIEVE
		COMPRESSION			PLASTIC LIMIT %	LIQUIDITY INDEX %	FIELD MOISTURE CONTENT %			
		QUAD pcf	CU pcf	CU pcf						
0										
5										
10							208	115		
15	MA						134	126	20	
20	MA						133	125	20	
25							130	122		
30			5600				8.9	138		
35	MA						8.0	136	25	
40										
45							223	116		
50	C PERM MA				27.0	26.7	269	102	980	
55								104		
60							8.7			
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING D-59
SURFACE ELEVATION 697.2

ELEVATION
(FEET)




NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-122

LOG OF BORING D-59



DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD CONTENT %	WET DENSITY PCF	WET DENSITY PERCENT PASCALS POD SIEVE
		TRIAxIAL COMPRESSION		C _u psi	PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
		σ ₁ psi	σ ₃ psi							
0										
5							128			
10							128	126		
15							124			
20							149	125		
25	TRIAxIAL PERM	4199	1434		11.4	14.4	126	126		
30	TRIAxIAL PERM	2151	2868		17.3	24.7	193	110		
35							197			
40							129	137		
45							8.8	132		
50							9.1			
55							282			
60							117	135		
65							8.8			
70							8.2			
75										

BLOW COUNTS
SAMPLES

BORING D-61

SURFACE ELEVATION 708.6

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
		TOP OF WISCONSINAN TILL	
10 SS	CL	Reddish brown, silty clay, some fine to coarse sand, trace fine gravel.	
13 SS			
	SM	Brown, silty, fine to coarse sand, trace fine gravel.	
31 SS	CL	Brown, silty clay, trace fine to coarse sand, trace fine gravel.	
17 SS	CL	Gray, silty clay, some fine to coarse sand, trace fine gravel.	
19 SS			
10 SS	ML	TOP OF INTERGLACIAL ZONE Dark gray, silt, little fine to coarse sand.	680.6
14 SS	CL	Greenish-gray, silty clay, some organics. -organics grade out. -grades to some fine to coarse sand, trace fine gravel.	
29 SS			
81 SS	ML SM	TOP OF ILLINOIAN TILL Gray, clayey silt and fine to coarse sand, trace fine gravel.	669.1
100 SS			
40 SS	ML	Gray, silt.	
27 SS	ML CL	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
67 SS		Boring completed at 70.0 feet on 4-11-75. Water level at 11.0 feet.	
77 SS			

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-124

LOG OF BORING D-61

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FLUID MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT WATER BY WEIGHT
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %	SHRINKAGE INDEX %			
		σ_1 psf	σ_3 psf	σ_c psf							
0											
5											
10	TXCUPP	922	1434 2868		11.6	13.4	1.18	141	124		
15					14.5	11.5	1.31	124			
20											
25								136	129		
30											
35								190			
40								199	114		
45											
50											
55								111	139		
60								234			
65								109			
70											
75								101	140		
80											

BLOW COUNTS
SAMPLES

BORING D - 62
SURFACE ELEVATION 714.2

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	TOP OF WISCONSINAN TILL	
8 SS	Brown, silty clay, some fine to coarse sand, trace fine gravel.	
14 SS		
15 SS	Gray, silty clay, trace fine to coarse sand, trace clay, trace fine gravel.	
16 SS		
20 SS		
13 SS		
15 SS	TOP OF INTERGLACIAL ZONE	680.7
12 SS	Greenish-gray, silty clay, trace organics, trace fine sand.	
27 SS		
63 SS	TOP OF ILLINOIAN TILL	670.7
104 SS	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
31 SS		
20 SS	Gray, silt, trace clay and fine sand, trace organics.	
50 SS		
68 SS	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
100 SS		

Boring completed at 80.0 feet on 4-10-75.
Water level at 24.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-125

LOG OF BORING D-62

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF PERCENT WETNESS
		TRIAKIAL COMPRESSION		UNCONSOLIDATED COMPRESSION	PLASTIC LIMIT %	FLUIDITY INDEX %	MOISTURE CONTENT %	LIQUID LIMIT %	
		σ_1 psf	σ_3 psf						
0									
5									
10					14.8	11.8	118	124	
15	MA							9.7	19.5
20								147	126
25					15.0	12.2	126	129	
30								140	128
35								157	127
40								158	
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING D - 63

SURFACE ELEVATION 721.7

ELEVATION
(FEET)

SYMBOLS		DESCRIPTIONS	ELEVATION (FEET)
CL		TOP OF LOESS	
ML	7 SS	Brown, silty clay, manganese nodules noted, TOP OF WISCONSINAN TILL	715.7
CL	15 SS	Brown, silty clay, trace fine to coarse sand, trace fine gravel.	
SM	50 SS	Brown, silty, fine to coarse sand, trace fine gravel.	
CL	19 SS	Gray, silty clay, trace fine to coarse sand, trace fine gravel.	
CL	32 SS		
CL	23 SS		
SM	26 SS	Brown, silty, fine to coarse sand, some fine gravel.	
ML		Dark gray, silty clay, some fine to coarse gravel, trace fine to coarse sand.	
CL	22 SS	TOP OF INTERGLACIAL ZONE	682.7
CL		Greenish gray, silty clay, trace organics trace fine sand.	

Boring completed at 40.0 feet on 4-8-75.
Water level at 11.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-126


LOG OF BORING D-63

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING NO. 200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %	SHRINKAGE INDEX %			
		Q _u psi	σ _v psi	τ _u psi							
0											
5											
10								137	126		
15								121	124		
20								141			
25	C PERM TWO	3175	2868		19.3	11.8	179	114			
30								191			
35				1300			175 179	118 116			
40								142			
45											
50				6500			9.7	140			
55								9.2			
60								130	130		
65								105			
70								8.3	141		
75									198	117	

BLOW COUNTS
SAMPLES

BORING D-64
SURFACE ELEVATION 712.2

ELEVATION
(FEET)



Boring completed at 78.7 feet
on 4-9-75.
Water level not recorded.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-127

LOG OF BORING D-64

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FLUID MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FINE FOR NO. 200
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	FLUID LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %			
		$C_1 - C_3$	C_2	C_3							
		psi	psi	psi							
0											
5								173			
10	HA							116	515		
15					15.5	11.5	125	125			
20								107			
25					11.8	15.8	116	130			
30											
35								136			
40								338			
45								196	108		
50								128			
55								9.5			
60											
65								7.5			
70											
75											

BLOW COUNTS
SAMPLES

BORING D-65
SURFACE ELEVATION 724.1

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	CL	TOP OF LOESS	
10	SS	Brown, silty clay	
		TOP OF WISCONSINAN TILL	721.6
	CL	Brown, silty clay, some fine to coarse sand, trace fine gravel.	
20	SS		
	SC	Brown, silty clayey sand, trace fine gravel.	
30	SS		
	CL	Brown, silty clay, some fine to coarse sand, trace fine gravel.	
50	SS		
	SM	Gray, silty, fine sand, trace clay.	
47	SS		
	CL	Gray, silty clay, trace fine to coarse sand, trace fine gravel.	
36	SS		
18	SS		
17	SS		
	ML	TOP OF INTERGLACIAL ZONE	686.6
		Greenish brown, clayey silt, some organics, trace fine to coarse sand.	
16	SS		
	ML	Greenish-gray, silt, little fine to coarse sand, trace organics.	
22	SS		
		-trace fine gravel.	
		TOP OF ILLINOIAN TILL	673.1
147	SS		
	ML SM	Gray, clayey silt and fine to coarse sand, trace fine gravel.	
113	SS		
99	SS		
	ML CL	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
33	SS		
	ML	Gray, silt, trace fine sand, trace clay, varved.	

BORING CONTINUED

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Service*, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-128

LOG OF BORING D-65

(SHEET 1 of 2)

BORING D - 65 (cont.)

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
		TRIAxIAL COMPRESSION		UNSATURATED CROSS-COMPRESSION	PLASTIC LIMIT %	PLAS- TICITY INDEX %	FIELD MOISTURE CONTENT %						
		σ_1 psf	σ_3 psf										
70													
75							16.7			31 SS		-73.5 to 78.5 feet, fine to medium sand lenses, trace clay.	
80										95 SS	ML CL	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
85							8.2			145 SS			
90										100 5 th SS			
95							8.2	111		215 SS			
100										265 SS			
													Boring completed at 100.0 feet on 4-15-75. Water level at 12.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-128
LOG OF BORING D-65
(SHEET 2 of 2)

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FINE 200 SIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLAS- TICITY INDEX %			
		σ_1 psf	σ_3 psf	q_u psf						
0										
5	MA				12.3	21.5	105			
10					14.5	14.5	120		68.0	
15										
20					13.4	14.8	178			
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING S-2
SURFACE ELEVATION 704.9

ELEVATION
(FEET)

SYMBOLS		DESCRIPTIONS
AG	CL	Grayish brown, silty clay (topsoil). TOP OF WISCONSINAN TILL
BC	CL	Reddish brown, silty clay, trace fine to coarse sand, trace fine gravel.
BG	CL	Brown, clayey silt, some fine to coarse sand.
BG		16.0 feet, color grades to gray, trace fine gravel.

703.9

Boring completed at 20.0 feet
on 4-3-75.
Water level not recorded.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-129 LOG OF BORING S-2

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT, %	DRY DENSITY PCF	WATER CONTENT, PERCENT	FIELD DENSITY PCF
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLAS- TICITY INDEX %				
		σ_1 pcf	σ_3 pcf	σ_c pcf							
0											
5							16.3				
10							130				
15											
20	COMP MA UC/R						8.8		600		
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING S-3

SURFACE ELEVATION 725.0

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
AG	ML	TOP OF LOESS	
		Brown, clayey silt, manganese nodules noted.	
	ML	Yellow, silt, trace fine sand and clay.	
BG			
		TOP OF WISCONSINAN TILL	714.0
BG	CL	Brown, silty clay, little fine to coarse sand.	
	CL	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
WC			

Boring completed at 20.0 feet on 4-3-75.
Water level at 11.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-130
LOG OF BORING S-3


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING NO. 200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %			
		σ_1 psf	σ_3 psf	$\sigma_1 - \sigma_3$ psf						
0										
5				12.6	11.2	134				
10										
15	COMP UC/R			13.8	13.2	9.4				
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING S-4

SURFACE ELEVATION 722.8

ELEVATION
(FEET)



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-131
LOG OF BORING S-4

ELEVATION IN FEET

LABORATORY TEST DATA										
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH						MOISTURE CONTENT %	DRY DENSITY PSI
	PLASTIC LIGHT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION				
			Q ₁	Q ₂	Q ₃	Q ₁	Q ₂	Q ₃		
C C SA COMP									14.3	90
									3300	17.0
									4500	12.3
									4500	14.4
								4500*	11.6	127

BORING S-5
SURFACE ELEVATION 719.0

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
7 #	ML	LIGHT BROWN CLAYEY SILT WITH SOME ROOTS (TOPSOIL)
7 #	CL	BROWN SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (MEDIUM STIFF)
17 #		GRADES TO STIFF
19 #	CL	GRAY SILTY CLAY WITH SAND AND OCCASIONAL GRAVEL (VERY STIFF)
23 #		

BORING COMPLETED AT 20.0 FEET ON 7-28-72
NO CASING USED
WATER LEVEL NOT RECORDED.

ELEVATION IN FEET

680									
670									
660							700	21.3	91
							4500		
							4500*	9.4	132
650							4500*		

BORING S-6
SURFACE ELEVATION 670.1

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
4 #	ML	DARK BROWN CLAYEY SILT WITH SOME SAND AND ORGANIC MATTER - (TOPSOIL)
2 #	CL	DARK GRAY AND BROWN SILTY CLAY AND CLAYEY SILT WITH SOME GRAVEL AND OCCASIONAL SEAMS OF SILTY SAND. (SOFT)
30 #		GRAY SANDY SILT WITH CLAY AND SOME GRAVEL (VERY STIFF)
19 #	ML	GRADES WITH MORE SAND
17 #		

BORING COMPLETED AT 20.0 FEET ON 7-28-72
NO CASING USED
WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-132

LOG OF BORINGS S-5 AND S-6

NOTES

1. LOGGED BY: DAMES & MOORE
2. DRILLED BY: RAYMOND INTERNATIONAL
3. TESTED BY: DAMES & MOORE

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF
		TRIAXIAL COMPRESSION		C _u pcf	PLASTIC LIMIT %	FLUIDITY INDEX %	LIQUID LIMIT %		
		Q ₁ psi	Q ₂ psi						
0									
5							146		
10	COMP PERM				12.8	10.0	109		
15							105		
20	COMP PERM UC/R				25.5	12.7	105		
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING S-8

SURFACE ELEVATION 733.8

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS
AG	CL TOP OF LOESS
ML	Brown, silty clay, manganese nodules noted.
BG	TOP OF WISCONSINAN TILL
CL	Brown, clayey silt, little fine to coarse sand, trace fine gravel. 6.0 feet, some fine to coarse sand. 11.0 feet, color grades to gray.
BG	
BG	
BG	

731.3

Boring completed at 20.0 feet on 4-2-75.
Water level at 18.5 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-133


LOG OF BORING S-8

LABORATORY TEST DATA									
TESTS REPORTED ELEVATION	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONSOLIDATED COMPRESSION				
			σ_1 PSF	σ_3 PSF	σ_1 PSF	σ_3 PSF			
720								22.2	
710	COMP UC/R	13.1	9.3				4500+	10.8	
							3000	13.6	
700							3500	13.4	
690	COMP	13.5	10.7					11.1	
							4500+	11.4	
680								11.1	
670								12.1	

ELEVATION IN FEET

BLow COUNTS SAMPLES

BORING S-9
SURFACE ELEVATION 717.2



BORING COMPLETED AT 40.0 FEET
ON 3-19-73
NO CASING USED
WATER LEVEL NOT RECORDED

NOTES

1. LOGGED BY: DAMES & MOORE
2. DRILLED BY: RAYMOND INTERNATIONAL
3. TESTED BY: DAMES & MOORE


**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-134

LOG OF BORING S-9

LABORATORY TEST DATA												
ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH						MOISTURE CONTENT %	DRY DENSITY PPI	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION					
				q ₁ (psi)	q ₂ (psi)	q ₃ (psi)	q _u (psi)	q _v (psi)	q _w (psi)			
730												
720	COMP TX/CU PP	18.2	25.7							1000	26.6	
		10.3	20.9								17.9	
710	COMP TX/CU PP									1000	18.5	
											17.3	
700	COMP TX/CU PP	12.7	11.2							2500	13.1	
		11.5	10.2							1500	17.1	
690	UC/R PERH	13.9	9.5								15.9	
680										1500	16.9	

-BORING S-10
SURFACE ELEVATION 722.6




NOTES

1. LOGGED BY: DAMES & MOORE
2. DRILLED BY: RAYMOND INTERNATIONAL
3. TESTED BY: DAMES & MOORE


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-135

LOG OF BORING S-10



LABORATORY TEST DATA									
TEST NO. DEPTH ELEVATION	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
	PLASTIC LIQUID %	PLASTICITY INDEX %	TRIAxIAL		UNIDRAINED				
			CU	QU	CU	QU			
730									
720							1500	18.5	
							1000	16.6	
710								16.1	
	COMP	12.7	8.4				1500	16.4	
700								16.8	
								11.7	
690								12.9	
							1000	14.8	
680								33.9	



NOTES

1. LOGGED BY: DAMES & MOORE
2. DRILLED BY: RAYMOND INTERNATIONAL
3. TESTED BY: DAMES & MOORE

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-136


LOG OF BORING S-11

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
	PLASTIC LIGHT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION				
			Q ₁ PSF	Q ₂ PSF	Q _u PSF	Q _u PSF			
UC/R	14.0	9.0					23.1		
COMP						1000	14.9		
						2000	13.2		
COMP	11.2	7.4					14.5		
						2000	14.7		
COMP MA	13.0	8.6				1000	15.9		
						1000	15.9		

ELEVATION IN FEET

BORING S-12
SURFACE ELEVATION 722.2

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 40.0 FEET
ON 3-19-73
NO CASING USED
WATER LEVEL NOT RECORDED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-137

LOG OF BORING S-12

NOTES


1. LOGGED BY: DAMES & MOORE
2. DRILLED BY: RAYMOND INTERNATIONAL
3. TESTED BY: DAMES & MOORE

LABORATORY TEST DATA										
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH						MOISTURE CONTENT %	DRY DENSITY PCF
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION				
			Q ₁ (TON)	Q ₂ (TON)	Q ₃ (TON)	Q _u (TON)	Q _u (TON)	Q _u (TON)		
COMP MA	15.6	10.2						1000	25.2	
								1000	16.8	
								1000	16.4	
								4500+	12.9	
								4500+	12.5	
COMP MA	12.4	8.4							14.1	
								4500	15.8	
								1000	27.5	

ELEVATION IN FEET

BORING S-13
SURFACE ELEVATION 722.2

BLOW COUNTS
SAMPLES




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-138

LOG OF BORING S-13

NOTES

1. LOGGED BY: DAMES & MOORE
2. DRILLED BY: RAYMOND INTERNATIONAL
3. TESTED BY: DAMES & MOORE



DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT, %	DRY DENSITY PCF	FLUIDITY PASSING #200 SIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	FIELD MOISTURE CONTENT, %			
		σ_1 psf	σ_3 psf	$\sigma_1 - \sigma_3$ psf						
0										
5										
10	UC/R COMP MA PERM TXCUPP	1638	1434		14.3	14.9	116	670		
15	TX/UC/R									
20							104			
25	COMP MA UC/R				13.9	13.1	146	660		
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING S-17

SURFACE ELEVATION 715.4

ELEVATION
(FEET)

	SYMBOLS	DESCRIPTIONS	
AC	CL	TOP OF LOESS	
	ML	Brown, silty clay, manganese nodules noted.	
		TOP OF WISCONSINAN TILL	711.9
BG	CL	Brown, clayey silt, some fine to coarse sand, trace fine gravel.	
BG			
		16.5 feet, color grades to gray.	
BG			
BC			
		TOP OF INTERGLACIAL ZONE	689.9
	ML	Greenish gray, silt, some organics.	
		Boring completed at 30.0 feet on 4-4-75. Water level at 16.5 feet.	


NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-140

LOG OF BORING S-17



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-141

LOG OF BORING S-18


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH				ATTERBERG LIMITS				DRY DENSITY PCF PERCENT MOISTURE CONTENT %
		COMPRESSION		UNSATURATED CUTANET		PLASTIC LIMIT %	FLAS TICITY INDEX %	LIQUID LIMIT %	PLASTICITY INDEX %	
		σ_1 psi	σ_3 psi	σ_1 psi	σ_3 psi					
0										
5										
10										
15	COMP PERM EXCISE	6923	5776					13.5	12.2	141
20										8.9
25	EXMI PERM EXCISE	2560	2888					12.8	13.5	9.2
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING S-19

SURFACE ELEVATION 725.5

ELEVATION
(FEET)



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-142

LOG OF BORING S-19


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FINER FOR 200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLUIDITY INDEX %	LIQUID LIMIT %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf	$\sigma_1 - \sigma_3$ psf						
0										
5							14.1			
10	MA				13.4	10.0	12.2	67.0		
15										
20							14.8			
25							11.5			
30										
35	COMP MA UIC/R				14.0	13.0	10.2	70.0		
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING S-21

SURFACE ELEVATION 736.4

ELEVATION
(FEET)




NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Soil Testing Services, Inc.


CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-144

LOG OF BORING S-21



BORING E-1A CONTINUED



PIEZOMETER INSTALLED ON 7-13-72 BORING E-1B, LOCATED 10 FEET FROM E-1A, WAS DRILLED TO A DEPTH OF 40 FEET. A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS PLACED TO ELEVATION 693. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 693 TO 703; BENTONITE SEAL FROM ELEVATION 703 TO 705; AND CEMENT GROUT FROM ELEVATION 705 TO 733.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
10.0	8-3-72
10.6	8-22-72
11.7	9-6-72

REFER TO FIGURE 2.4-38 FOR WATER LEVEL OBSERVATIONS.

BORING COMPLETED AT 250.0 FEET ON 7-12-72 CASING USED TO A DEPTH OF 20.0 FEET

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-145

LOG OF BORING E-1A
(SHEET 2 of 2)

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA


ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{q_1 - q_2}{2}$ PCF	q_1 PCF	q_u PCF	q_p PCF		
750								4500+	
740								2000	
								1000	
730								3700	
720								4500+	
710									
								4000	
700								4400	
								4500+	
690									
								3000	
680									
								4500+	
670								4500+	
								4500+	
660								4500+	
								4500+	
650								4500+	
								4500+	
640								4500+	
								4500+	
630								4500+	
								4500+	
620								4500+	
								4500+	
610								4500+	
								4500+	
600								4500+	
								4500+	
590								4500+	

BORING CONTINUED

BORING E-2A

SURFACE ELEVATION 746

BLOW COUNTS
SAMPLES



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-146

LOG OF BORING E-2A

(SHEET 1 of 2)

LABORATORY TEST DATA

BORING E-2A CONTINUED



PIEZOMETER INSTALLED ON 7-12-72 BORING E-2B, LOCATED 10 FEET FROM E-2A, WAS DRILLED TO A DEPTH OF 68 FEET. A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS PLACED TO ELEVATION 678. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 679 TO 686; A BENTONITE SEAL FROM ELEVATION 686 TO 687; AND CEMENT GRANT FROM ELEVATION 687 TO 746. WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET

DATE

32.8	8-3-72
32.9	8-22-72
33.4	9-6-72

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

REFER TO FIGURE 2.4-38 FOR WATER LEVEL OBSERVATIONS.


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-146

LOG OF BORING E-2A

(SHEET 2 of 2)

BORING COMPLETED AT 300.0 FEET ON 7-10-72 CASING USED TO A DEPTH OF 6.0 FEET




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-147
LOG OF BORING E-3A
(SHEET 1 of 2)

LABORATORY TEST DATA

BORING E-3A CONTINUED



PIEZOMETER INSTALLED IN E-3A ON 7-5-72 BORING WAS REOPENED TO 238 FEET. A 3/4 INCH PVC PIPE WITH AN 18 INCH POROUS STONE TIP WAS PLACED AT ELEVATION 495. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 492 TO 516; A BENTONITE PLUG FROM ELEVATION 516 TO 518; AND CEMENT GROUT FROM ELEVATIONS 518 TO 730

PIEZOMETER INSTALLED ON 7-12-72 BORING E-3B LOCATED 10 FEET FROM E-3A WAS DRILLED TO A DEPTH OF 75 FEET. A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS PLACED AT ELEVATION 655. GRANULAR BACKFILL WAS PLACED FROM ELEVATIONS 655 TO 662; A BENTONITE SEAL FROM ELEVATIONS 662 TO 633; AND PEA GRAVEL AND CEMENT GROUT FROM ELEVATIONS 663 TO 730.

BORING COMPLETED AT 249.5 FEET ON 6-29-72

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET

TIP ELEVATION 492.0	TIP ELEVATION 657.5	DATE
81.6		8-15-72
81.8		9-6-72

REFER TO FIGURE 2.4-38 FOR WATER LEVEL OBSERVATIONS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-147

LOG OF BORING E-3A

(SHEET 2 of 2)


NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATYERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY Pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION			
				q ₁ Pcf	q ₂ Pcf	q _u Pcf	q _u Pcf		
750									
740							4000		1600
730							3200		
720							4500+		
710							4500+		
700							1100		
690							4500+		
680							4500+		
670							4500+		
660							4500+		
650							4500+		
640							4500+		
630							4500+		
620							4500+		
610							4500+		
600							4500+		
590							4500+		

BORING E-4A
SURFACE ELEVATION 740




BORING CONTINUED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-148

LOG OF BORING E-4A
(SHEET 1 of 2)

BORING E-4A CONTINUED



PIEZOMETER INSTALLED ON 7-6-72 BORING E-4B LOCATED 10 FEET FROM E-4A WAS DRILLED TO A DEPTH OF 76 FEET. A 3/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET PERFORATED WAS PLACED AT ELEVATION 644. GRANULAR BACKFILL WAS PLACED FROM ELEVATIONS 644 TO 654. A BENTONITE SEAL FROM ELEVATIONS 654 TO 656 AND PEA GRAVEL AND CEMENT GROUT FROM ELEVATIONS 656 TO 740.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
26.6	8-3-72
26.8	8-15-72
27.9	9-6-72

REFER TO FIGURE 2.4-38 FOR WATER LEVEL OBSERVATIONS.

BORING COMPLETED AT 255.0 FEET ON 7-5-72 CASING USED TO A DEPTH OF 5.0 FEET

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-148
 LOG OF BORING E-4A
 (SHEET 2 of 2)

NOTE:
 SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PPI
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	PICKET		
			σ_1 PPI	σ_3 PPI				
750							1000	
740							1500	
730	CHEM*						4500+	
720							4500+	
710							2000	
700							2500	
690							4500+	
680							4500+	
670							4500+	
660							4500+	
650							4500+	
640							4500+	
630							4500+	
620							4500+	
610							4500+	
600							4500+	
590							4500+	

* ON WATER SAMPLE OBTAINED ON 10-7-72

BORING E-5A
SURFACE ELEVATION 750

BLOW COUNTS
SAMPLES

SYMBOLS	DESCRIPTIONS
9 # ML	DARK GRAYISH-BROWN SILT WITH A TRACE OF CLAY ORGANIC DEBRIS (TOP SOIL) <i>Top of Wisconsin Glacial Till</i>
5 # CL	LIGHT BROWN SILTY CLAY WITH SOME SAND AND OCCASIONAL GRAVEL WEATHERED (MEDIUM STIFF)
7 # CL	
115 # SP	LIGHT BROWN FINE TO MEDIUM SAND WITH SOME SILT IN ZONES (VERY DENSE) GRADES TO GRAY COLOR APPROXIMATE BASE OF WEATHERED ZONE AT 17 FEET
114 # SP	
80 # ML	DARK BROWNISH-GRAY CLAYEY SILT WITH SOME SAND AND OCCASIONAL GRAVEL INTERBEDDED THIN SEAMS OF SAND (HARD) SAND SEAMS GRADING OUT INCREASED CLAY CONTENT
21 # ML	GRADES TO VERY STIFF
13 # ML	<i>Top of Interglacial Zone</i> DARK BROWNISH-GRAY SILT WITH A TRACE OF CLAY ORGANIC ORDER (STIFF)
8 # ML	
7 # CL	DARK BLUISH-GRAY SILTY CLAY WITH A TRACE OF SAND (MEDIUM STIFF)
63 # ML	GRADE TO GREENISH-GRAY SILTY CLAY WITH SOME SAND AND GRAVEL <i>Top of Illinois Glacial Till</i>
50 # ML	BROWNISH-GRAY SANDY SILT WITH SOME CLAY AND OCCASIONAL GRAVEL (HARD)
52 # ML	
45 # ML	
122 # ML	
69 # ML	
17 # ML	GRAY TO BROWN SILT WITH SOME CLAY IN ZONES, FINE ORGANIC DEBRIS OCCASIONAL SHELL FRAGMENTS (LACUSTRINE DEPOSIT) (MEDIUM STIFF)
37 # ML	BROWNISH-GRAY SANDY SILT WITH SOME SAND AND OCCASIONAL GRAVEL (GLACIAL TILL) (HARD)
71 # ML	
137 # ML	GRADING TO OCCASIONAL THIN LAYER OF SAND AND GRAVEL
50/10 # ML	
86 # ML	SAND AND GRAVEL GRADING OUT
66 # ML	
52 # ML	
61 # ML	
94 # ML	
80 # ML	
39 # ML	

BORING CONTINUED


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-149
LOG OF BORING E-5A
(SHEET 1 of 3)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH			MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION				
				σ ₁ (PSF)	σ ₃ (PSF)	τ (PSF)		
590								
580								
570						4500+		
560						4500+		
550								
540						4500+		
530								
520						4500+		
510						4500+		
500						4500+		
490								
480						4000		
470						4200		
460						4500±		
450								
440								
430								

BORING E-5A CONTINUED




BORING CONTINUED

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-149
 LOG OF BORING E-5A
 (SHEET 2 of 3)

BORING E-5A CONTINUED



PIEZOMETER INSTALLED ON 7-19-72 BORING E-5B, LOCATED 10 FEET FROM E-5A, WAS DRILLED TO A DEPTH OF 76 FEET. A 3/4 INCH PVC PIPE WITH AN 18 INCH POROUS STONE TIP WAS PLACED TO ELEVATION 675. GRANULAR BACKFILL WAS PLACED BETWEEN ELEVATIONS 674 TO 680; A BENTONITE SEAL BETWEEN ELEVATIONS 680 AND 683; AND CEMENT GROUT FROM ELEVATION 683 TO 750.

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
16.8	8-3-72
16.9	8-15-72
17.3	9-6-72

REFER TO FIGURE 2.4-38 FOR WATER LEVEL OBSERVATIONS.

BORING COMPLETED AT 329.0 FEET ON 7-17-72 CASING USED TO A DEPTH OF 6 FEET

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-149

LOG OF BORING E-5A

(SHEET 3 of 3)

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.


LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH						MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION		PURE TENSION		
				σ ₁ (psi)	σ ₃ (psi)	σ _c (psi)	σ _u (psi)	σ _t (psi)			
750											
740											
730											
720	CHEM*										
710											
700											
690											
680											
670											
660											
650											
640											
630											
620											
610											
600											
590											

* ON WATER SAMPLE OBTAINED ON 10-7-72

BORING E-6

SURFACE ELEVATION 736



BORING CONTINUED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-150

LOG OF BORING E-6

(SHEET 1 of 2)

BORING E-6 CONTINUED

ELEVATION IN FEET

590
580

LABORATORY TEST DATA								
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
			$\sigma_1 - \sigma_3$ p	σ_3 p	σ_c p	q p		

BLOW COUNTS
SAMPLES

SYMBOLS



DESCRIPTIONS

PIEZOMETER INSTALLED ON 7-25-72
BORING WAS FLUSHED WITH CLEAN WATER AND A 2 INCH ID PVC PIPE WITH THE LOWER END PLUGGED AND PERFORATIONS AT 1 FOOT INTERVALS FOR THE ENTIRE LENGTH WAS PLACED TO ELEVATION 586. GRANULAR BACK-FILL WAS PLACED FROM ELEVATIONS 585 TO 736.

BORING COMPLETED AT 151.0 FEET ON 7-25-72 CASING USED TO A DEPTH OF 6 FEET

WATER LEVEL READINGS

DEPTH BELOW GROUND SURFACE IN FEET	DATE
11.8	9-19-72
11.4	9-26-72
11.3	10-10-72

REFER TO FIGURE 2.4-38 FOR WATER LEVEL OBSERVATIONS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-150

LOG OF BORING E-6

(SHEET 2 of 2)

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



* ON WATER SAMPLE OBTAINED ON 10-7-72

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-151
LOG OF BORING E-7
(SHEET 1 of 2)


BORING E-7 CONTINUED

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{\sigma_1 - \sigma_3}{2}$ % a) pcf	σ_3 % b) pcf	$\frac{q_u}{2}$ % c) pcf	$\frac{q_u}{2}$ % d) pcf			
590									
580									
570									
560									
550									

BLOW COUNTS SAMPLES

SYMBOLS

DESCRIPTIONS



Top Of Lacustrine Deposits
GRAY SILT WITH SOME FINE SAND AND ORGANIC DEBRIS (VERY STIFF)

BORING COMPLETED AT 151.5 FEET ON 7-20-72 CASING USED TO A DEPTH OF 6.0 FEET

PIEZOMETER INSTALLED IN 7-20-72 BORING WAS FLUSHED WITH CLEAN WATER AND A 3 INCH ID PIPE WITH THE LOWER END PLUGGED AND PERFORATION AT 1 FOOT INTERVALS FOR THE ENTIRE LENGTH WAS PLACED TO ELEVATION 562. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 560.5 TO 712.

DEPTH BELOW GROUND SURFACE IN FEET	DATE
5.5	9-19-72
2.4	9-26-72
3.7	10-10-72

REFER TO FIGURE 2.4-38 FOR WATER LEVEL OBSERVATIONS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-151

LOG OF BORING E-7

(SHEET 2 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

ELEVATION IN FEET

TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH						MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION			UNCONFINED COMPRESSION		POCKET PENETROMETER		
			σ ₁ / pcf	σ ₃ / pcf	σ _c / pcf	q / pcf	p / pcf			
								d		
680										
670	24	27								
660										
650										
640										

BORING G-1
SURFACE ELEVATION 675.1

SAMPLES	SYMBOLS	DESCRIPTIONS
☒	CH	BROWN SILTY CLAY WITH SOME FINE ROOTS (MEDIUM STIFF TO STIFF) GRADING MOIST GRADING SANDY
☒	SM	BROWN SILTY FINE TO MEDIUM SAND (DENSE) GRADING WITH LESS SILT GRADING WITH SOME COARSER SAND
☒	SW	BROWN FINE TO COARSE SAND WITH SOME SILT AND FINE TO COARSE GRAVEL (DENSE)
☒	CL	GRAY FINE TO MEDIUM SANDY CLAY WITH OCCASIONAL FINE GRAVEL (VERY STIFF)

BORING COMPLETED ON 8-22-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 11.0 FEET ON 8-22-73.

700									
690									
680									
670									
660									
650									

BORING G-2
SURFACE ELEVATION 692.3

SAMPLES	SYMBOLS	DESCRIPTIONS
☒	ML	BROWN CLAYEY SILT WITH SOME FINE ROOTS (STIFF) GRADING MOIST GRADING MORE CLAYEY
☒	CL	
☒	SC	BROWN CLAYEY FINE SAND WITH SOME SILT (MEDIUM STIFF) GRADING STIFFER
☒	SM	GRAY CLAYEY FINE TO COARSE SAND WITH SOME FINE GRAVEL (VERY DENSE) GRADING LESS CLAYEY
☒	SM	GRAY SILTY FINE TO COARSE SAND (DENSE) GRADING MORE CLAYEY WITH OCCASIONAL GRAVEL

BORING COMPLETED AT 30.0 FEET ON 8-22-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 11.0 FEET ON 8-22-73.

ELEVATION IN FEET

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY, pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 psi	σ_3 psi	q_u psi	P psi			
730									
720									
710									
700									
690									
680									

BORING G-3
SURFACE ELEVATION 723.2

SAMPLES	SYMBOLS	DESCRIPTIONS
1	CL	BROWN SANDY CLAY WITH SOME FINE TO MEDIUM GRAVEL (STIFF)
2		GRADING WITH LENSES OF FINE TO MEDIUM SAND
3		GRADES GRAY
4		GRADING LESS SANDY AND MORE SILTY
5		GRADING MORE CLAYEY, SOME ORGANIC DARK GRAY CLAY (STIFF)

BORING COMPLETED AT 30.0 FEET ON 8-22-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 20.5 FEET ON 8-22-73.

730								
720								
710								
700								
690								
680								

BORING G-4
SURFACE ELEVATION 725.6

SAMPLES	SYMBOLS	DESCRIPTIONS
1	ML CL	BROWN CLAYEY SILT WITH SOME FINE ROOTS (STIFF) GRADING SANDY
2	CL	BROWN SANDY CLAY WITH SOME FINE TO MEDIUM GRAVEL (STIFF)
3		GRADING MORE SANDY
4		GRADES DARK GRAY MEDIUM GRAVEL GRADES OUT
5	CL	DARK GRAY SILTY CLAY WITH ORGANICS CEMENT (STIFF)

BORING COMPLETED AT 30.0 FEET ON 8-22-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 13.5 FEET ON 8-22-73.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-153

LOG OF BORINGS G-3 AND G-4

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET METROMETER		
				$\frac{e_1 - e_2}{L}$ pcf	σ_1 pcf	σ_2 pcf	σ_3 pcf		
730		26	23						
720									
710									
700									
690									

BORING G-5

SURFACE ELEVATION T29.3

SAMPLES	SYMBOLS	DESCRIPTIONS
		DARK BROWN SILTY CLAY WITH SOME FINE ROOTS (MEDIUM STIFF) GRADING MORE CLAYEY GRADING WITH OCCASIONAL MEDIUM GRAVEL
LIGHT BROWN AND GRAY CLAYEY FINE TO MEDIUM SAND AND GRAVEL (MEDIUM DENSE) GRADING WITH LESS FINE SAND GRADING MORE CLAYEY		
BROWN AND GRAY FINE SANDY CLAY (MEDIUM STIFF TO STIFF) GRADING GRAY AND STIFFER GRADING DARKER GRAY WITH OCCASIONAL FINE GRAVEL (STIFF TO VERY STIFF) GRADING MORE SANDY		

BORING COMPLETED AT 30.0 FEET ON 8-17-73.
 NO CASING USED.
 GROUNDWATER LEVEL RECORDED AT 9.5 FEET ON 8-17-73.

ELEVATION IN FEET

680									
670									
660	SA							18.2	11.6
650	SA							16.0	
640									
630									

BORING G-6

SURFACE ELEVATION 677.8


SAMPLES	SYMBOLS	DESCRIPTIONS
		BROWN CLAYEY SILT WITH SOME FINE ROOTS (STIFF) GRADING SANDY BROWN FINE MEDIUM SAND WITH SOME CLAY (MEDIUM DENSE TO DENSE) GRADING WITH SOME FINE TO MEDIUM GRAVEL
GRADING WITH LESS GRAVEL AND MORE SILT GRADING WITH MORE COARSE GRAVEL (DENSE)		
GRAY CLAYEY SILT WITH SOME FINE TO MEDIUM SAND AND GRAVEL (VERY STIFF)		

BORING COMPLETED AT 30.0 FEET ON 8-21-73.
 NO CASING USED.
 GROUNDWATER LEVEL RECORDED AT 13.5 FEET ON 8-21-73.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-154

LOG OF BORINGS G-5 AND G-6



LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 PSF	σ_3 PSF	q_u PSF				
690									
680									
670							13.3		
660									
650	SA								
640									

BORING G-7
SURFACE ELEVATION 682.0

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	ML	BROWN CLAYEY SILT WITH SOME ROOTS (STIFF)
⊗	SM	GRADING SANDY
⊗	SM	REDDISH-BROWN SILTY FINE TO COARSE SAND WITH SOME FINE TO MEDIUM GRAVEL (DENSE)
⊗	SM	BROWN FINE TO COARSE SAND WITH SOME SILT AND GRAVEL (DENSE)
⊗	SW SM	GRADING WITH MORE GRAVEL AND SILT
⊗	SM	GRADING GRAY (VERY DENSE)

BORING COMPLETED AT 30.0 FEET ON 8-21-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 14.5 FEET ON 8-21-73.

ELEVATION IN FEET

700								
690	27	30						
680								
670								
660								
650								

BORING G-8
SURFACE ELEVATION 691.9

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	CH	BROWN SILTY CLAY WITH SOME FINE ROOTS (STIFF)
⊗	CH	GRADING SANDY
⊗	SM	BROWN SILTY FINE TO COARSE SAND WITH SOME FINE GRAVEL (DENSE)
⊗	SM	GRADING GRAY (VERY DENSE)
⊗	ML	GRAY CLAYEY SILT (VERY STIFF)

BORING COMPLETED AT 30.0 FEET ON 8-21-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 10.0 FEET ON 8-21-73.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-155

LOG OF BORINGS G-7 AND G-8

ELEVATION IN FEET

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 pcf	σ_3 pcf	q_u pcf	q_p pcf			
730									
720									
710									
700									
690									
680									

BORING G-9
SURFACE ELEVATION 724.9

SAMPLES	SYMBOLS	DESCRIPTIONS
☒	CL	BROWN SILTY CLAY WITH SOME ROOTS (STIFF)
☒	ML	GRADING MORE SILTY
☒	SM	REDDISH-BROWN SILTY FINE TO COARSE SAND WITH FINE TO MEDIUM GRAVEL (VERY DENSE) GRADING LESS SANDY
☒	ML	GRADING MORE SANDY GRADING DARK GRAYISH-BROWN GRADING GRAY AND MORE SILTY
☒	ML	DARK GRAY CLAYEY SILT WITH FINE TO COARSE SAND AND SOME FINE GRAVEL (STIFF TO VERY STIFF) GRADING WITH SOME PEAT

BORING COMPLETED AT 30.0 FEET ON 8-20-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 14.5 FEET ON 8-20-73.

BORING G-10
SURFACE ELEVATION 727.2

SAMPLES	SYMBOLS	DESCRIPTIONS
☒	CL	MOTTLED BROWN AND GRAY SILTY CLAY WITH SOME FINE SAND (STIFF)
☒	SM	ORANGE-BROWN SILTY SAND WITH OCCASIONAL FINE TO MEDIUM GRAVEL AND SOME CLAY (MEDIUM DENSE)
☒	SP	REDDISH-BROWN SAND WITH SOME GRAVEL AND SILT (MEDIUM DENSE TO DENSE)
☒	ML	GRAY CLAYEY SILT WITH OCCASIONAL FINE GRAVEL (STIFF TO VERY STIFF)
☒	GC	GRAY CLAYEY GRAVEL WITH SOME SAND (DENSE)
☒	SC	GRADING DENSER WITH MORE FINE TO MEDIUM GRAVEL
☒	ML	GRADING WITH LESS GRAVEL
☒	PT	GRAY CLAYEY SILT WITH SOME SAND AND OCCASIONAL FINE GRAVEL (STIFF)
☒	ML	DARK GRAY PEAT GRAY CLAYEY SILT WITH SOME SAND AND GRAVEL

BORING COMPLETED AT 30.0 FEET ON 8-17-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 7.0 FEET ON 8-17-73.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-156

LOG OF BORINGS G-9 AND G-10

ELEVATION IN FEET

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 pcf	σ_3 pcf	q_u pcf	q_p pcf			
680									
670									
660	SA	NONPLASTIC							
650									
640									

BORING G-11
SURFACE ELEVATION 675.3

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	ML CL	BROWN CLAYEY SILT WITH SOME ROOTS (MEDIUM STIFF) GRADING SANDY
⊗	SM SW	BROWN SILTY FINE TO COARSE SAND WITH SOME FINE TO MEDIUM GRAVEL AND SOME CLAY (DENSE) GRADING MORE GRAVELLY AND LESS SILTY
⊗	SW	BROWN FINE TO COARSE SAND WITH SOME SILT AND GRAVEL (DENSE)
⊗		GRAY SILTY FINE TO MEDIUM SAND WITH SOME CLAY AND OCCASIONAL FINE GRAVEL (VERY DENSE)
⊗	SM	GRADING MORE SANDY
⊗		GRADING WITH MORE FINE TO MEDIUM GRAVEL

BORING COMPLETED AT 30.0 FEET ON 8-21-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 7.0 FEET ON 8-21-73.

BORING G-12
SURFACE ELEVATION 685.1

TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS	SHEAR STRENGTH	MOISTURE CONTENT %	DRY DENSITY pcf		
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER
			σ_1 pcf	σ_3 pcf	q_u pcf	q_p pcf
690						
680						
670	SA					
660	SA	NONPLASTIC				17.8
650						
660						

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	ML CL	BROWN CLAYEY SILT (STIFF)
⊗	SM	BROWN SILTY FINE TO COARSE SAND WITH SOME FINE TO MEDIUM GRAVEL (DENSE) GRADING WITH SOME CLAY
⊗		LIGHT BROWN FINE TO COARSE SAND WITH SOME SILT AND TRACE OF GRAVEL (DENSE)
⊗	SM	GRADING WITH LESS GRAVEL AND COARSE SAND
⊗		GRAY SILTY SAND WITH SOME FINE TO MEDIUM GRAVEL (VERY DENSE)
⊗	SM	GRADING MORE SILTY

BORING COMPLETED AT 30.0 FEET ON 8-20-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 17.5 FEET ON 8-20-73.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-157

LOG OF BORINGS G-11 AND G-12

ELEVATION IN FEET

LABORATORY TEST DATA								
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
			a) $\frac{C_1 - C_2}{3}$ pcf	b) $\frac{C_1 - C_2}{3}$ pcf	$\frac{C_u}{3}$ pcf	$\frac{C_u}{3}$ pcf		
700								
690	SA	NONPLASTIC						
680								
670								
660								

BORING G-13

SURFACE ELEVATION 697.6

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	ML	BROWN CLAYEY SILT WITH SOME ROOTS (MEDIUM STIFF)
⊗	SM	BROWN FINE TO COARSE SAND WITH SOME SILT AND FINE GRAVEL (MEDIUM DENSE)
⊗		GRADING WITH GRAVEL
⊗		GRADING WITH LENSES OF CLAY
⊗		GRADING GRAY WITH MORE FINE TO MEDIUM GRAVEL (VERY DENSE)
⊗		GRADING WITH MORE COARSE GRAVEL AND SOME SILT

BORING COMPLETED AT 30.0 FEET ON 8-20-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 18.5 FEET ON 8-20-73.

BORING G-14

SURFACE ELEVATION 715.0

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	ML	LIGHT BROWN CLAYEY SILT (STIFF) GRADING REDDISH-BROWN WITH SOME FINE SAND
⊗	SC	REDDISH-BROWN CLAYEY SAND WITH SOME FINE TO MEDIUM GRAVEL (MEDIUM DENSE TO DENSE) GRADING MORE SANDY WITH MORE GRAVEL
⊗	SC-SM	REDDISH-BROWN CLAYEY SAND WITH SILT AND GRAVEL (MEDIUM DENSE TO DENSE) GRADING DENSER
⊗	ML	GRAY CLAYEY SILT WITH SOME ORGANIC CONTENT (STIFF) GRADING WITH MORE ORGANIC MATTER AND SOME PEAT (STIFF)
⊗	SC	GRAYISH-BLUE SANDY CLAY (STIFF TO VERY STIFF) GRADING WITH OCCASIONAL FINE TO MEDIUM GRAVEL

BORING COMPLETED AT 30.0 FEET ON 8-17-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 11.0 FEET ON 8-17-73.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-158

LOG OF BORINGS G-13 AND G-14

ELEVATION IN FEET

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 pcf	σ_3 pcf	σ_c pcf	q pcf			
670									
660	SA	17	13						
650									
640									
630									

BORING G-15

SURFACE ELEVATION 669.6

SAMPLES

SYMBOLS	DESCRIPTIONS
CL	DARK GRAY SILTY CLAY (MEDIUM STIFF)
SC	BROWN SILTY FINE TO COARSE SAND WITH SOME GRAVEL (MEDIUM DENSE) GRADING WITH LENSES OF GRAY SILTY CLAY GRADING WITH CLAY GRADING WITH LESS GRAVEL GRADING WITH COARSER SAND
SM	GRAY SILTY FINE TO COARSE SAND WITH SOME FINE TO MEDIUM SIZE GRAVEL (VERY DENSE)

BORING COMPLETED AT 30.0 FEET ON 8-21-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 9.5 FEET ON 8-21-73.

BORING G-16

SURFACE ELEVATION 678.1

SAMPLES

SYMBOLS	DESCRIPTIONS
ML	BROWN SILT WITH SOME ORGANICS, TRACE OF FINE SAND AND CLAY (TOPSOIL)
ML	BROWN SILT WITH CLAY AND TRACE OF FINE SAND (STIFF)
SM	BROWN FINE TO MEDIUM SAND WITH SOME SILT AND GRAVEL
SP	BROWN FINE TO MEDIUM SAND WITH SOME GRAVEL AND TRACE OF SILT
SM	BROWN FINE TO COARSE SAND WITH SOME SILT AND GRAVEL GRADES WITH LESS GRAVEL GRADES WITH MORE FINE SAND AND SILT GRADES WITH LESS SILT
ML	GRAYISH-BROWN SILT WITH SOME CLAY, FINE SAND AND GRAVEL

BORING COMPLETED AT 30.0 FEET ON 9-19-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 11.5 FEET ON 9-19-73.

680									
670	SA							9.4	
								7.5	
								9.7	
660	SA							9.8	
								9.7	
650	SA							9.4	
640									

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-159

LOG OF BORINGS G-15 AND G-16

ELEVATION IN FEET


LABORATORY TEST DATA										MOISTURE CONTENT %	DRY DENSITY pcf
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				UNCONFINED COMPRESSION	POCKET PENETROMETER			
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		C	Q _u					
			σ ₁ #1	σ ₃ #1							
680											
670											
660	SA										8.3
	SA										13.4
650	SA										4.9
	SA										8.3
640											

BORING G-17
SURFACE ELEVATION 677.4



BORING COMPLETED AT 30.0 FEET ON 9-6-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 9.6 FEET ON 9-7-73.

BORING G-18
SURFACE ELEVATION 677.8



BORING COMPLETED AT 30.0 FEET ON 9-19-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 11.0 FEET ON 9-19-73.

680										
670										10.4
660	SA									8.5
650	SA									9.9
640										

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-160

LOG OF BORINGS G-17 AND G-18

ELEVATION IN FEET

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 / σ_3 / σ_3	σ_1 / σ_3			q / σ_3		
690									
680									
670	SA						7.1		
	SA						7.3		
	SA						9.9		
660									
650									
640									

BORING G-19
SURFACE ELEVATION 682.6

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	ML	BROWN SILT WITH SOME ORGANICS AND TRACE OF CLAY AND FINE SAND (TOPSOIL)
⊗	ML	BROWN SILT WITH SOME CLAY AND TRACE OF FINE SAND (STIFF)
⊗	SM	GRADES WITH MORE FINE SAND
⊗	SM	DARK BROWN SILTY SAND WITH SOME CLAY
⊗	SM	BROWN FINE TO COARSE SAND WITH SOME GRAVEL AND SILT
⊗	SM	GRADES WITH MORE FINE SAND
⊗	SM	GRADES WITH LESS FINE SAND
⊗	SM	COARSE GRAVEL GRADES OUT
⊗	ML	GRAY FINE TO COARSE SAND WITH SILT AND SOME FINE GRAVEL
⊗	ML	GRAY AND BROWN LAYERED SILT WITH SEAMS OF SAND AND FINE GRAVEL AND TRACE OF ORGANICS (MEDIUM STIFF)
⊗	ML	LIGHT GRAY SANDY SILT WITH SOME GRAVEL (MEDIUM STIFF)

BORING COMPLETED AT 30.0 FEET ON 9-19-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 16.0 FEET ON 9-19-73.

BORING G-20
SURFACE ELEVATION 668.9

SAMPLES	SYMBOLS	DESCRIPTIONS
⊗	CL	BLACK CLAY WITH SILT AND TRACE OF FINE SAND AND ORGANICS (TOPSOIL)
⊗	CL	DARK GRAY TO BLACK CLAY WITH SILT, TRACE OF FINE SAND AND SOME ORGANICS (VERY STIFF) GRADES LESS STIFF
⊗	SM	BROWN FINE TO COARSE SAND WITH SOME SILT, GRAVEL AND TRACE OF CLAY
⊗	SM	GRADES WITH SOME SEAMS OF CLAYEY SILT AND CLAYEY SAND
⊗	SM	GRADES WITH LESS SILT
⊗	SM	GRAY SILTY FINE TO COARSE SAND WITH SOME GRAVEL, TRACE OF CLAY AND SOME SEAMS AND LAYERS OF SILT
⊗	ML	GRAY SANDY SILT WITH SOME FINE GRAVEL AND TRACE OF CLAY
⊗	ML	GRADES WITH SEAMS OF FINE SAND

BORING COMPLETED AT 30.0 FEET ON 9-20-73.
NO CASING USED.
GROUNDWATER LEVEL RECORDED AT 3.2 FEET ON 9-20-73.

670									
660	SA						11.9		
650	SA						9.5		
	SA								
640									
630									

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-161


LOG OF BORINGS G-19 AND G-20

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{\sigma_1 - \sigma_3}{2}$	$\frac{\sigma_2 - \sigma_3}{2}$	σ_c	q		
680									
670	C						2000	23.8	96
660							4500+	9.1	135
650							4500+	8.3	137
640							4500+		
630							4500+	5.9	144
620							4500+	7.6	139
610							4500+	9.3	136
600							4500+	7.8	138
590							4500+	8.1	136

BORING H-1

SURFACE ELEVATION 671.7




BORING COMPLETED AT 76.5 FEET ON 10-30-73. CASING USED TO A DEPTH OF 5.0 FEET. ALLUVIAL WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-162

LOG OF BORING H-1

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-163

LOG OF BORING H-2

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.


LABORATORY TEST DATA

TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
			σ ₁ - σ ₃	σ ₃				
680								
670						2200		
660						2200		
650						4500+	12.2	134
640						4500+		
630						4500+	9.1	144
620						4500+	11.2	133

BORING H-3
SURFACE ELEVATION 674.1

ELEVATION IN FEET

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 50.0 FEET ON 11-15-73.
CASING USED TO A DEPTH OF 14.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 7.6 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-164


LOG OF BORING H-3

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf.
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION q_u psi	POCKET PENETROMETER q_p psi		
				σ_1 psi	σ_3 psi				
				a) psi	b) psi				
680									
670							750	31.6	78
							500	31.5	90
660									
							4500+	9.9	135
650							4500+		
							4500+		
640							4500+	8.4	138
							4500+		
630							4500+	8.1	136
							4500+		
620							4500+	8.1	138
							4500+		
610							4500+	9.2	135
							4500+		
600							4500+	8.0	138
							4500+		
590							4500+		

BORING H-4
SURFACE ELEVATION 671.6




BORING COMPLETED AT 75.5 FEET ON 11-14-73.
CASING USED TO A DEPTH OF 10.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 4.4 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-165

LOG OF BORING H-4

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-166

LOG OF BORING H-5

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\sigma_1 - \sigma_3$	σ_3					
680									
670						1000	25.4	86	
							17.1	103	
						1500	19.2	105	
660						4500+	9.9	132	
						4500+	6.5	138	
650	c					4500+			
						4500+			
640						4500+			
						4500+			
630						4500+			
						4500+			
620	TX/DY					4500+			
						4500+	8.5	133	
610									
						4500+	9.0	137	
600									
						4500+	9.8	138	
590						4500+			
						4500+			
580	c					4500+			
						4500+	17.0	140	
570						4500+			
						4500+			
560									
						4500+	9.4	135	
550									
						4500+			
540									
						4500+	11.4	130	
530									
						4500+			
520									




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-167
LOG OF BORING H-6
(SHEET 1 of 3)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

BORING H-6 CONT'D




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-167

LOG OF BORING H-6

BORING H-6 CONT'D



BORING COMPLETED AT 374.5 FEET ON 10-4-73.
CASING USED TO A DEPTH OF 10.0 FEET.
ALLUVIAL WATER LEVEL NOT RECORDED.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-167

LOG OF BORING H-6
(SHEET 3 of 3)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REQUIRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{\sigma_1 - \sigma_3}{2}$ a	σ_3 b				
680									
670							750	31.8	79
660							4500+	20.1	111
650							4500+		
640							4500+	7.6	142
630							4500+	7.6	141
620							4500+	9.9	134
610							4500+	8.4	139
600							4500	9.9	135
590							4500		

BORING H-7
SURFACE ELEVATION 673.5





CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-168

LOG OF BORING H-7

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.






LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 pcf	σ_3 pcf				
				a	b	c	d		
680									
670							750	21.9	98
660								21.2	101
650							4500	11.8	125
640							4500+	6.9	138
630							4500+	5.8	147
620							4500+	4500+	
610							4500+	7.1	141
600							4500+	8.0	137
590							4500+	7.6	139
							4500+	8.7	137
							4500+		

BORING H-10
SURFACE ELEVATION 672.2



BORING COMPLETED AT 15.5 FEET ON 11-3-73.
CASING USED TO A DEPTH OF 17.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 5.5 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-171

LOG OF BORING H-10

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY Pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				σ ₁ Pcf	σ ₃ Pcf		q Pcf	N		
680										
670								1750	23.6	82
									18.6	91
									21.7	102
660									13.1	117
								4500+	8.4	135
650								4500+	6.9	142
								4500+		
640										
								4500+		
630								4500+	8.4	137
								4500+		
620									9.2	134
								4500+		
610								4500+	8.2	136
								4500+		
600								4500+	9.1	135
590										

BORING H-II
SURFACE ELEVATION 673.1

BLOW COUNTS
SAMPLES

JAN - MON 2013
28
78
210/10"
260/8"
218/9"
210
176
119
119
102
106
138
78

SYMBOLS	DESCRIPTIONS
ML	Top of Salt Creek Alluvium DARK BROWN SILT WITH SOME ORGANICS AND TRACE OF CLAY (STIFF)
ML	BROWN FINE SANDY SILT WITH TRACE OF CLAY AND ORGANICS
SW	GRAY FINE TO COARSE SAND WITH TRACE OF SILT AND ORGANICS (LOOSE GRADES WITH MORE SILT)
	Top of Illinoian Glacial Till GRAY FINE TO COARSE SANDY SILT WITH TRACE OF CLAY AND FINE GRAVEL (HARD)
	GRADES WITH COARSE GRAVEL
	GRADES WITH MORE CLAY
ML	3" GRAY FINE TO MEDIUM SAND LAYER AT 49.7'
	GRADES WITH LESS COARSE GRAVEL

BORING COMPLETED AT 76.0 FEET ON 10-26-73.
CASING USED TO A DEPTH OF 14.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 7.2 FEET.

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-172

LOG OF BORING H-11


LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{q_1 - q_2}{2}$ pcf	q_2 pcf	q_u pcf	q_p pcf			
680									
670							23.3	86	
							29.6	92	
							17.1	123	
660							13.8	132	
							13.3		
650							4500+		
							4500+	10.6	137
640							4500+		
							4500+	11.9	135
630							4500+		
							4500+	11.6	136
620									

ELEVATION IN FEET

BORING H-12

SURFACE ELEVATION 674.6

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 49.5 FEET ON 11-6-73. CASING USED TO A DEPTH OF 21.0 FEET. ALLUVIAL WATER LEVEL RECORDED AT 8.0 FEET.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-173
LOG OF BORING H-12

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION			UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ ₁ - σ ₃	σ ₃	σ ₁				
680									18.2	102
670	TX/CU / PP								4500+	
660									22.5	108
650									4500+	
640									4500+	
630									8.8	134
620									4500+	
									14.6	119

BORING H-13
SURFACE ELEVATION 679.6

BLOW COUNTS	SYMBOLS	DESCRIPTIONS
7	ML	Top of Salt Creek Alluvium BROWN FINE SANDY SILT WITH TRACE OF FINE GRAVEL AND ORGANICS 18" LAYER OF SAND AT 7.0'
29	ML	Top of Illinoian Glacial Till LIGHT BROWN FINE TO COARSE SANDY SILT WITH TRACE OF CLAY AND GRAVEL (HARD) GRADES TO GRAY
7	SP	GRAY FINE SAND WITH TRACE OF MEDIUM AND COARSE SAND GRADES WITH MORE COARSE SAND
12	ML	GRAY FINE TO COARSE SANDY SILT WITH TRACE OF CLAY AND SOME GRAVEL
	SP	GRAY FINE TO MEDIUM SAND
190/10"		GRAY FINE TO COARSE SANDY SILT WITH TRACE OF CLAY AND SOME GRAVEL (HARD)
	ML	GRADES WITH OCCASIONAL BOULDER
210/8"		GRADES DARK GRAY
200/7"	SP	DARK GRAY FINE TO MEDIUM SAND

BORING COMPLETED AT 49.0 FEET ON 11-14-73.
CASING USED TO A DEPTH OF 14.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 9.3 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-174

LOG OF BORING H-13


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA								
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
			σ_1 pcf	σ_3 pcf	q_u pcf	q_p pcf		
680								
670						1000	34.1	75
660								
650						4500+		
640						4500+		
630	TX/DY					4500+	7.8	138
620						4500+		

ELEVATION IN FEET

BORING H-14
SURFACE ELEVATION 673.8

BLOW COUNTS
SAMPLES




BORING COMPLETED AT 50.5 FEET ON 11-12-73.
CASING USED TO A DEPTH OF 10.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 6.7 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-175

LOG OF BORING H-14

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



LABORATORY TEST DATA									
ELEVATION IN FEET	TESTS REPORTED	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ ₁ PCF	σ ₃ PCF				
730								18.9	102
720				3356	576				
710	TX/OY*						4500		
700				2423*	1555		4500	12.1*	125
690	RES*						2000		
680							2500		
670							4500+	11.4	134
660							4500+		
650							2500		
							4500+		
							4500+		

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
7	ML	BROWN SILT WITH ORGANICS (TOPSOIL)
8	SM	BROWN SILTY FINE TO MEDIUM SAND WITH TRACE OF CLAY (WEATHERED LOESS) (LOOSE)
20	ML	MEDIUM SAND AND CLAY GRADES OUT BROWN FINE SANDY SILT
26		<i>Top of Wisconsinan Glacial Till</i>
27	ML	GRAYISH-BROWN CLAYEY SILT WITH SOME FINE TO COARSE SAND AND GRAVEL GRADES WITH THIN FINE TO COARSE SAND LAYERS LAYER OF BROWN SILT AT 18.0'
20		GRADES TO GRAY WITH STRINGERS OF SAND
10		<i>Top of Interglacial Zone</i>
10	ML	MOTTLED BROWN AND GRAY CLAYEY SILT WITH ORGANICS
8	CL	GREENISH-GRAY SILTY CLAY WITH SOME FINE SAND AND GRAVEL (SOFT)
21		<i>Top of Illinoian Glacial Till</i>
140/10	ML	GRAY CLAYEY SILT WITH FINE TO COARSE SAND AND GRAVEL (STIFF) 12" SAND LAYERS AT 39.5' CLAY GRADES OUT
99		GRAY FINE TO COARSE SANDY SILT WITH GRAVEL AND TRACE OF CLAY (HARD)
69		GRADES WITH MORE CLAY
35		
	ML	GRADES WITH MORE GRAVEL
177/11		
166/9		

BORING COMPLETED AT 80.5 FEET ON 10-20-73.
CASING USED TO A DEPTH OF 5.0 FEET.
ALLUVIAL WATER LEVEL NOT RECORDED.

*SATURATED

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-176

LOG OF BORING H-15

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{\sigma_1 - \sigma_3}{2}$ psf	σ_3 psf	$\frac{\sigma_c}{2}$ psf	$\frac{Q_u}{2}$ psf			
							3500	30.1	94
							4500+		
								13.1	128
							4500+		
							4500+		
								8.3	133

ELEVATION IN FEET

BORING H-16
SURFACE ELEVATION 686.8

BLOW COUNTS
SAMPLES

	SYMBOLS	DESCRIPTIONS
9	ML	<i>Top of Salt Creek Alluvium</i> ORANGISH-BROWN SILT WITH SOME CLAY AND TRACE OF ORGANICS AND FINE SAND (VERY STIFF)
6	SM	BROWN SILTY FINE TO COARSE SAND AND GRAVEL WITH TRACE OF CLAY
15	SP	BROWN FINE TO MEDIUM SAND WITH TRACE OF COARSE SANDY SILT AND GRAVEL (MEDIUM DENSE)
36		GRADES WITH MORE SILT AND COARSE GRAVEL
10	GP	BROWN FINE TO COARSE SANDY GRAVEL WITH SOME SILT (LOOSE) GRADES WITH OCCASIONAL BOULDER
20	ML	<i>Top of Illinoian Glacial Till</i> GRAY FINE TO COARSE SANDY SILT WITH SOME CLAY, STRINGERS OF FINE TO MEDIUM SAND AND OCCASIONAL BOULDER
180	SP	GRAY FINE TO MEDIUM SAND
	ML	LIGHT GRAY SILT
150		DARK GRAY FINE TO COARSE SANDY SILT WITH SOME CLAY AND GRAVEL (HARD)
185/9'	ML	

BORING COMPLETED AT 49.3 FEET ON 11-9-73.
CASING USED TO A DEPTH OF 15.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 15.9 FEET.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-177


LOG OF BORING H-16

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION q_u pcf	POCKET PENETROMETER q_p pcf		
				$\frac{\sigma_1 - \sigma_3}{2}$ pcf	σ_3 pcf				
				G	D				
680									
670	C						1500		
660									
650	C TX/CU /PP RES						4500+	11.3	131
640							4500+		
630							4500+	14.5	125
620									

BORING H-17
SURFACE ELEVATION 675.1




BORING COMPLETED AT 50.5 FEET ON 11-13-73. CASING USED TO A DEPTH OF 10.0 FEET. ALLUVIAL WATER LEVEL RECORDED AT 7.4 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-178

LOG OF BORING H-17


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-179
 LOG OF BORING H-18

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.




NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-180

LOG OF BORING H-19




LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET			
			σ_1 pcf	σ_3 pcf	σ_c pcf	σ_p pcf			
							2500		
							1500		
								9.2	130
							4500+		
							4500+		
							4500+		
							4500+		
							4500+		
							4500+		
							4500+		

ELEVATION IN FEET

BORING H-21
SURFACE ELEVATION 678.6

BLOW COUNTS SAMPLES




BORING COMPLETED AT 51.5 FEET ON 11-13-73.
CASING USED TO A DEPTH OF 18.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 8.5 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-182

LOG OF BORING H-21


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-183
LOG OF BORING H-22
(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.





**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-184

LOG OF BORING H-23

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.


LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION σ_u pcf	POCKET PENETROMETER $\frac{S_u}{2}$ pcf		
				$\frac{\sigma_1 - \sigma_3}{2}$	σ_3				
				a pcf	b pcf				
680									
670	TX/CU / PP						1700	21.6	95
660								7.3	136
650							4500+	6.4	144
640							4500+	6.8	141
630							4500+	5.9	145
620							4500+	9.0	127

BORING H-24

SURFACE ELEVATION 676.2

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 49.6 FEET ON 10-1-73. CASING USED TO A DEPTH OF 21.5 FEET. ALLUVIAL WATER LEVEL RECORDED AT 5.9 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-185

LOG OF BORING H-24


NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAXIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 PCF	σ_3 PCF	q_u PCF	SP PCF		
680									
	TX/CU /PP							500	
670									21.1 105
660									
								4500+	6.5 142
650								4500+	
								4500+	6.2 143
640								4500+	
								4500+	6.6 146
630	TX/CU /PP							4500+	
								4500+	8.5 138
620									

BORING H-25
SURFACE ELEVATION 677.2

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 50.0 FEET ON 9-21-73. CASING USED TO A DEPTH OF 3.5 FEET. ALLUVIAL WATER LEVEL RECORDED AT 5.3 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-186

LOG OF BORING H-25


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY Pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSIVE STRENGTH		UNCONFINED COMPRESSIVE STRENGTH				
			q ₁ psf	q ₃ psf	q _u psf	q _u psf	q _u psf		
								27.9	80
								1500	16.0
								250	33.4
								1000	
								4500+	
								4500+	
								4500+	
								4500+	
								4500+	
								4500+	
								4500+	
								4500+	
								4500+	
								4500+	

ELEVATION IN FEET

BORING H-26
SURFACE ELEVATION 687.7

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 100.0 FEET ON 11-3-73. CASING USED TO A DEPTH OF 47.5 FEET. GROUNDWATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-187

LOG OF BORING H-26


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION				POCKET PENETROMETER
			$\frac{\sigma_1 - \sigma_3}{2}$ psi	σ_3 psi	$\frac{q_u}{2}$ psi	q_u psi			
700									
690							34.1	83	
680									
						4500+			
670							8.8	134	
						4500+			
660							18.1	124	
						4500+			
650							11.4	136	
						4500+			
640							10.4	123	
						4500+			
630							14.5	115	
						4500+			
620							8.6	135	
						4500+			
610									

ELEVATION IN FEET

BORING H-27
SURFACE ELEVATION 690.6

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 76.0 FEET ON 10-3-73. CASING USED TO A DEPTH OF 17.0 FEET. ALLUVIAL WATER LEVEL RECORDED AT 5.9 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-188

LOG OF BORING H-27


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REQUIRED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{C-\sigma_3}{2}$ SAT	σ_3 SAT	$\frac{S_u}{2}$ SAT	$\frac{S_u}{2}$ SAT			
690							750	10.4	96
680							1000 750	25.3	95
670							2500		
660							4500	10.9	131
650							4500	7.1	138
640							+4500	7.1	135
630							+4500		

ELEVATION IN FEET

BORING H-28
SURFACE ELEVATION 686.2

BLOW COUNTS
SAMPLES



BORING COMPLETED AT 50.5 FEET ON 11-10-73.
CASING USED TO A DEPTH OF 10.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 7.8 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-189

LOG OF BORING H-28

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

BORING H-29
SURFACE ELEVATION 687.7



BORING COMPLETED AT 90.0 FEET ON 10-25-73.
CASING USED TO A DEPTH OF 22.0 FEET.
GROUNDWATER LEVEL NOT RECORDED.

NOTES:
SLOPE BENCHED FOR ACCESS; NATURAL GROUND SURFACE AT ELEVATION 689.7.
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-190

LOG OF BORING H-29

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF	
		FLUIDITY INDEX	PLASTICITY INDEX	TOTAL COMPACTION		UNSATURATED				
				CU	QU	CU	QU			
700										
690				1898	389			4500+	13.9	100
680								4500+		
670								4500+		
660				10072	2693			4500+	7.9	135
650								4500+		
640								4500+		
630	TK/DY RES							4500+	6.8	145
620								4500+		
610								4500+		
600								4500+	9.2	136
590								4500+		
580								4500+	8.2	138
570								4150		
560								4500+		
550								4500+		
540										

BORING H-30
SURFACE ELEVATION 697.0




NOTE:
SLOPE BENCHMARK FOR ACCESS; NATURAL
GROUND SURFACE AT ELEVATION 698.5 .

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-191
LOG OF BORING H-30
(SHEET 1 of 2)



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-191
LOG OF BORING H-30
(SHEET 2 of 2)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				$\frac{e_1 - e_2}{2}$	σ_3			$\frac{e_1 - e_2}{2}$		
				a)	b)	c)	d)			
700										
690								4500+	11.6	117
									12.7	94
680								2500	17.8	105
								2100	18.6	109
670								4500+		
	RES*									
660								4500+		
650								4500+		
640								4500+		
	TX/CU /PP									
630								4500+		
620								4500+		
610								4500+		
600								4500+		
590								4500+		

* SATURATED

BORING H-31
SURFACE ELEVATION 691.1



BORING COMPLETED AT 99.5 FEET ON 10-20-73. CASING USED TO A DEPTH OF 17.0 FEET. GROUNDWATER LEVEL NOT RECORDED.


NOTES:

SLOPE BENCHED FOR ACCESS; NATURAL GROUND SURFACE AT ELEVATION 692.6.
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-192


LOG OF BORING H-31



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-193
LOG OF BORING H-32
(SHEET 1 of 2)

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-193
 LOG OF BORING H-32
 (SHEET 2 of 2)

LABORATORY TEST DATA


ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				$\frac{q_1 - q_2}{3}$	q_3				
690								9.8	107
680								20.5	107
								24.4	104
670								26.2	102
								26.8	99
660							4500+	15.2	125
							1700		
650							4500+		
								19.8	123
640									
								12.4	132
630									

BORING H-33

SURFACE ELEVATION 685.8

BLOW COUNTS
SAMPLES

12
11
10
9
8
7
6
5
4
3
2
1
0



SYMBOLS	DESCRIPTIONS
ML	BROWN ORGANIC SILT WITH SOME SAND AND CLAY (TOPSOIL)
ML	<i>Top of Salt Creek Alluvium</i> BROWN FINE SANDY SILT WITH SOME MEDIUM TO COARSE SAND AND GRAVEL (STIFF)
SW	BROWN SILTY FINE TO COARSE SAND WITH TRACE OF CLAY AND GRAVEL (LOOSE)
SM	BROWN FINE SILTY SAND WITH STRINGERS OF BROWN SANDY SILT
ML	GRAY SILT WITH SOME FINE SAND AND TRACE OF CLAY (VERY SOFT)
SP	DARK GRAY FINE SAND WITH SOME SILT (MEDIUM DENSE)
ML	GRAY SILT WITH SOME FINE TO COARSE SAND AND SOME GRAVEL
ML	<i>Top of Illinoian Glacial Till</i> GRAY FINE TO COARSE SANDY SILT WITH TRACE OF CLAY AND GRAVEL (HARD)
ML	

GRADES WITH STRINGERS AND THIN LAYERS OF FINE TO MEDIUM SAND


BORING COMPLETED AT 49.0 FEET ON 10-26-73. CASING USED TO A DEPTH OF 17.0 FEET. ALLUVIAL WATER LEVEL RECORDED AT 11.0 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-194

LOG OF BORING H-33

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.



NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-195

LOG OF BORING H-34

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY Pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 / Pcf	σ_3 / Pcf				
				σ_1 / Pcf	σ_3 / Pcf	q_u / Pcf	q_p / Pcf		
680									
670							1300	25.6	89
660									
650							4250		
640							4500+	8.3	137
630							4500+	6.0	143
620							4500+	6.8	143
							4500+	7.2	140

BORING H-35
SURFACE ELEVATION 671.8

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
7	ML	Top of Salt Creek Alluvium
6	ML	DARK BROWN CLAYEY SILT WITH ORGANICS AND SOME FINE SAND (TOPSOIL)
14	SW	DARK GRAY CLAYEY SILT WITH SOME FINE SAND (STIFF)
25		GRAY FINE TO COARSE SAND WITH GRAVEL AND TRACE OF SILT (MEDIUM DENSE)
53		GRADES WITH LESS FINE TO MEDIUM SAND
		Top of Illinoian Glacial Till
		GRAY FINE TO COARSE SANDY SILT WITH TRACE OF CLAY AND SOME FINE GRAVEL (HARD)
		6" LAYER OF SAND AND GRAVEL AT 17.5'
		GRADES WITH SEAMS OF FINE SAND
188/8"	ML	GRADES WITH COARSE GRAVEL
210		
180/10"		GRADES WITH MORE CLAY

BORING COMPLETED AT 49.9 FEET ON 11-13-73.
CASING USED TO A DEPTH OF 14.5 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 3.4 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-196

LOG OF BORING H-35


NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION			
				σ ₁ pcf	σ ₃ pcf	σ ₁ pcf	σ ₃ pcf		
680									
670							850	16.8	97
							1200	28.4	92
							1200	27.3	92
660									
							2500	10.3	133
							4500	8.2	137
							4500		
650									
							4500	6.8	142
640									
							4500+	9.8	132
							4500+		
630									
							4500+	5.6	142
620	TX/DY								
							4500+		
610								9.0	136
							4500+		
							4500+		
600	RES								
							4500+		
							4500+	7.4	139
590									
							4500+		
							4500+	14.6	118
580									
							4000		
							4500+	9.2	135
570									
							4500+		
560									
							4500+	9.5	132
550									
540								14.1	124
							4000		
530									
							4500+	16.3	118
520									

BORING H-36
SURFACE ELEVATION 671.2




ELEVATION IN FEET

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

FIGURE 2.5-197
LOG OF BORING H-36
(SHEET 1 of 2)



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-197
LOG OF BORING H-36
(SHEET 2 of 2)

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCOMPIRED COMPRESSION	POCKET PENETROMETER		
				σ_1 pcf	σ_3 pcf				
700									
690		20.1	22.6	5879	259			4250	
680								4500+	
670								4500+	
660								4500+	
650								4500+	
640								4500+	
630								4500+	
620								4500+	
610									

BORING H-37
SURFACE ELEVATION 693.9

BLOW COUNTS
SAMPLES

SYMBOLS	DESCRIPTIONS
ML	DARK BROWN SILT WITH SOME FINE SAND, ORGANICS AND TRACE OF CLAY (TOPSOIL)
ML	Top of Interglacial Zone
CL	LIGHT BROWN SILT WITH SOME FINE SAND ORANGISH-BROWN SILTY CLAY WITH SOME FINE TO COARSE SAND AND GRAVEL (HARD)
	LIGHT BROWN SILT WITH FINE TO MEDIUM SAND, TRACE OF CLAY AND OCCASIONAL GRAVEL (VERY STIFF)
	GRADES WITH MORE SAND, GRAVEL AND CLAY
	GRADES TO HARD
	13" LAYER OF FINE TO COARSE SAND AND GRAVEL AT 17.8'
	GRADES TO GRAY
	GRADES WITH FINE SAND AND SILT SEAMS
	24" LAYER OF GRAY FINE SANDY SILT AT 33.0'
ML	6" LAYER OF SILTY FINE SAND AT 34.8'
	24" LAYER OF GRAY FINE TO COARSE SAND WITH SOME GRAVEL AT 44.0'
	GRADES WITH MORE COARSE GRAVEL
	3" COBBLE AT 56.8'
SP	GRAY FINE SAND WITH TRACE OF SILT (VERY DENSE)
ML	DARK GRAY FINE TO COARSE SANDY SILT WITH SOME FINE GRAVEL, CLAY AND OCCASIONAL FINE SAND SEAMS
SP	GRAY FINE SAND WITH TRACE OF SILT

BORING COMPLETED AT 74.5 FEET ON 11-17-73. CASING USED TO A DEPTH OF 5.5 FEET. GROUNDWATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-198

LOG OF BORING H-37

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA


ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCT
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION			
				σ ₁ (psf)	σ ₃ (psf)	σ ₁ (psf)	σ ₃ (psf)		
730									
720							4500+	13.3 7.9	110 100
710	TX/CU /PP						4500+		
700	TX/DY						3000		
690									
680	TX/CU /PP						2000		
670							4500+		
660	TX/CU /PP						4500+	6.6	144
650							4500+		
640	TX/DY						4500+	6.7	139
630							4500+	6.1	143
620							4500+	8.9	134
							4500+	6.9	139

BORING H-38
SURFACE ELEVATION 726.9

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS



BORING COMPLETED AT 101.0 FEET ON 10-24-73.
CASING USED TO A DEPTH OF 5.0 FEET.
GROUNDWATER LEVEL NOT RECORDED.

NOTE:

SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-199

LOG OF BORING H-38

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET		
				σ_1 pcf	σ_3 pcf	σ_u pcf	σ_p pcf		
680									
670								3800	
660								4500+	
650								4500+	
640								4500+	
630								4500+	
620								4500+	


BORING H-39

SURFACE ELEVATION 677.9

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS



BORING COMPLETED AT 51.3 FEET ON 11-1-73.
CASING USED TO A DEPTH OF 8.0 FEET.
ALLUVIAL WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-200

LOG OF BORING H-39


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 pcf	σ_3 pcf	σ_c pcf	σ_p pcf			
680									
670						750			
660						4500+			
650						4500+			
640						4500+			
630						4500+			
620						4500+			

ELEVATION IN FEET

BORING H-40
SURFACE ELEVATION 674.1

BLOW COUNTS SAMPLES



BORING COMPLETED AT 50.0 FEET ON 10-24-73.
CASING NOT USED.
ALLUVIAL WATER LEVEL NOT RECORDED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-201

LOG OF BORING H-40

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA									
ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCF
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 (psi)	σ_3 (psi)	q_u (psi)	q_p (psi)		
680									
670	TX/CU / PP						1250		
660							4500+		
650							4500+		
640							4500+		
630							4500+		
620									

BORING H-41
SURFACE ELEVATION 672.7

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS
5	ML	Top of Salt Creek Alluvium BLACK ORGANIC SILT WITH TRACE OF SAND (TOPSOIL)
2	ML	MOTTLED LIGHT BROWN SILT WITH CLAY AND TRACE OF SAND
4	SM	BROWN SILTY FINE TO MEDIUM SAND WITH TRACE OF COARSE SAND AND CLAY (VERY LOOSE)
4	GP	ORANGISH-BROWN FINE TO COARSE SANDY GRAVEL WITH SOME SILT (VERY LOOSE)
17		Top of Illinoian Glacial Till GRAY FINE TO COARSE SANDY SILT WITH CLAY AND GRAVEL
101		GRADES WITH LESS CLAY
197/10	ML	GRADES WITH MORE GRAVEL
190		SAND SEAM AT 49.4'


BORING COMPLETED AT 49.5 FEET ON 11-14-73.
CASING USED TO A DEPTH OF 13.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 8.0 FEET.

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY PCT.	
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
				σ ₁ PPT	σ ₃ PPT					
										σ ₁ PPT
680								2500	24.7	86
670	TX/CU /PP							2000		
660								4500+		
650								4500+		
640								4500+		
630								4500+	6.4	143
620								4500+	8.4	144

BORING H-42
SURFACE ELEVATION 676.3




BORING COMPLETED AT 50.0 FEET ON 11-10-73.
CASING USED TO A DEPTH OF 8.0 FEET.
ALLUVIAL WATER LEVEL RECORDED AT 9.0 FEET.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-203

LOG OF BORING H-42

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-204

LOG OF BORING H-43

DEPTH (FEET)	TESTS REPORTED ELEVATION	SHEAR STRENGTH			ATTENDING LIMITS		WATER CONTENT, %	DWT	DENSITY PCF GRAVITY WATER	DENSITY PCF SOLIDS
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %				
		Q ₁ pcf	Q ₂ pcf	Q ₃ pcf						
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING H-44A
SURFACE ELEVATION 697.8

ELEVATION
(FEET)


SYMBOLS	DESCRIPTIONS
	Rotary drilled without sampling to 35.0 feet.
ST ST	Gray, clayey silt and fine to coarse sand, trace fine gravel. 39.0 to 39.6 feet, gray, silt, trace fine sand, organics noted.
	BORING COMPLETED AT 39.9 FEET ON 9/21/76.
	WATER LEVEL NOT RECORDED.

- NOTES:
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: RAYMOND INTERNATIONAL.
 3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-206

LOG OF BORING H-44A



DEPTH (FEET)	TESTS REPORTED ELEMENTS	SHEAR STRENGTH			ATTENBERG LIMITS			WATER CONTENT, %	FLUIDITY INDEX, %	UNIT WEIGHT, PCF	SANDY SILT OR SILTY SAND
		TRIAxIAL COMPRESSION			PLASTIC LIMIT, %	PLAS- TICITY INDEX, %	LIQUID LIMIT, %				
		Q _u	S _u	c _u							
0											
5											
10											
15											
20											
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING H-45A
SURFACE ELEVATION 705.2

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	Rotary drilled without sampling to 42.5 feet.	
ST	Gray, clayey silt, some fine to coarse sand, trace fine gravel. 44.0 feet, organics noted.	660.0
ST	Gray, silt, trace clay, black silt veins noted.	758.3
ST	Gray, silt and fine to coarse sand, little fine gravel, gravel seams noted.	
	BORING COMPLETED AT 47.7 FEET ON 9/22/76.	
	WATER LEVEL NOT RECORDED.	


NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-208

LOG OF BORING H-45A




NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-209

LOG OF BORING H-46




- NOTES:**
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: RAYMOND INTERNATIONAL.
 3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-210

LOG OF BORING H-47



NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-211


LOG OF BORING H-48

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH				ATTERBERG LIMITS				FIELD MOISTURE CONTENT, %	DRY DENSITY, PCF	PLUMPTON INDEX	NO. OF SAMPLES FOR SIEVE
		TRIAxIAL COMPRESSION				PLASTIC LIMIT, %	LIQUIDITY INDEX, %	FLUIDITY INDEX, %	SHRINKAGE INDEX, %				
		$\sigma_1 - \sigma_3$ 2 psi	σ_3 psi	σ_1 psi	σ_3 psi								
0													
5													
10													
15					4300				13.9	124			
20					1800*								
25					2500*								
30					1800*								
35													
40					9400				8.3	141			
45													
50													
55					2400				33.1	95			
					4500*				25.7				
					4500*								
60													
65					4500*								
70													
75													

BLOW COUNTS
SAMPLES

BORING H-49
SURFACE ELEVATION 716.1

ELEVATION (FEET)



BORING COMPLETED AT 65.0 FEET ON 9/27/76.

WATER LEVEL NOT RECORDED.

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-212

LOG OF BORING H-49


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS				WATER CONTENT (%)	DRY DENSITY PCF	MOISTURE RATIO
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLUIDITY INDEX %	FIELD TESTING CORRECTION FACTOR	FIELD TESTING CORRECTION FACTOR			
		Q _u PSF	S _u PSF	P _u PSF							
0											
5											
10											
15				2600				14.2	120		
20				3900				15.0	123		
25											
30				3100				20.4	107		
35				2200*							
40				6000				11.0	132		
45				4500*							
50				12200				8.4	138		
55				4500*							
				4500*							
				4500*							
60				11300				8.0	142		
								16.9			
								9.9			
65				4500*							
70				14900				7.7	140		
75											

BLOW COUNTS
SAMPLES

BORING H-50

SURFACE ELEVATION 722.9

ELEVATION
(FEET)



BORING COMPLETED AT 70.0 FEET
ON 9/24/76.


NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-213

LOG OF BORING H-50




NOTES


1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-214

LOG OF BORING H-51





NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-216

LOG OF BORING H-53

DEPTH (FEET)	TEST #	REPORTED ELEVATION	SHEAR STRENGTH			ATTENNORNS LIMITS			WATER CONTENT %	DRY DENSITY PCF	WET DENSITY PCF
			CU	QU	CV	PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %			
0											
5					4500*						
10					300*			19.1			
15					1630			14.8	122		
					2500*					53.8	
20								13.0	130		
25								12.0	7.7		
30								13.1	33.3		
35					14400			7.2	139	53.8	
					4500*						
40											
45											
50											
55											
60											
65											
70											
75											

BORING H-54
SURFACE ELEVATION 682.2

BLOW COUNTS
SAMPLES

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS
CL	ILLINOIAN TILL Light gray, mottled brown, silty clay, some fine to coarse sand, trace fine gravel.
18 SS	
3 SS	8.5 feet, grades to gray, and fine to medium sand.
7 SS	13.5 feet, trace fine to coarse sand, black silt pockets noted.
ML CL	14.0 feet, gray, clayey silt and fine to coarse sand, trace fine gravel, thin sand seams noted.
15 SS	18.5 feet, gray, silt and fine to medium sand, trace fine gravel, thin sand seams noted.
19 SS	22.8 feet, gray, fine to coarse sand, little fine to coarse gravel, trace silt.
SW SH SP SM	24.6 feet, gray, fine sand, trace silt.
100/11" SS	28.5 feet, brownish gray, fine to coarse sand, some silt, trace clay and fine gravel.
93 SS	29.0 feet, gray, clayey silt, some fine to coarse sand, trace fine gravel.
118 SS	31.0 feet, and fine to coarse sand.
SH ML CL	


BORING COMPLETED AT 35.0 FEET
ON 10/1/76.
WATER LEVEL AT 8.5 FEET.

- NOTES:
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: RAYMOND INTERNATIONAL.
 3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-217

LOG OF BORING H-54



NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-218

LOG OF BORING H-55


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS				FIELD MOISTURE CONTENT, %	DRY DENSITY PCF	WATER CONTENT PLASTICITY INDEX	UNIT WEIGHT PCF
		TRIAxIAL COMPRESSION			PLASTIC LIMIT, %	PLAS- TICITY INDEX, %	FIELD MOISTURE CONTENT, %	DRY DENSITY PCF				
		σ_1 psf	σ_3 psf	σ_1 pcf								
0				1000*								
5												
10				500*								
15				500*								
20				3750*								
25				1500*								
30				4500*								
35				4500*								
40				4500*								
45				4500*								
50				4500*								
55				4500*								
60				4500*								
65				4500*								
70				4500*								
75				4500*								

BLOW COUNTS
SAMPLES

BORING H-56

SURFACE ELEVATION 680.7

ELEVATION
(FEET)




NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-219

LOG OF BORING H-56



- NOTES:**
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: RAYMOND INTERNATIONAL.
 3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-220

LOG OF BORING H-57

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FLUID MOISTURE CONTENT %	DRY DENSITY PCF WATER CONTENT %
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %		
		σ_1 psi	σ_3 pcf	σ_u pcf					
0				2500*					
				1500				17.9	109.6
5				2500*				17.6	111.2
				2300					
				1750*					
				2500					
10				1250*				19.2	102.0
				2200					
15				1500*					
20				4500*				7.7	135.0
25				4500*					
30				4500*				8.8	112.4
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING H-58

SURFACE ELEVATION 682.8

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS
13 SS	ILLINOIAN TILL
CL	Dark brown, silty clay, some fine to coarse sand, trace fine gravel.
11 SS	CL
11 SS	Dark brown, silty clay-clayey silt, little fine to medium sand, trace coarse sand.
12 SS	9.5 feet, grades to yellowish-brown.
10 SS	CL
10 SS	Gray, silty clay-clayey silt, some fine to medium sand, trace coarse sand, trace fine gravel. Thin, fine to medium sand seams noted.
100 SS	ML
	SM
43 SS	Gray, clayey silt and fine to coarse sand, trace fine gravel, coarse gravel noted.
50 SS	

BORING COMPLETED AT 30.0 FEET
ON 10/12/76.
WATER LEVEL NOT RECORDED.

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-221

LOG OF BORING H-58

DEPTH (FEET)	TESTS REPORTED ELEMENTS	SHEAR STRENGTH				ATTERBERG LIMITS				FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FLUIDITY BY SHREVE
		TRIAxIAL COMPRESSION		UNIDIRECTIONAL COMPRESSION		PLASTIC LIMIT %	FLUIDITY LIMIT %	LIQUID LIMIT %	SHRINKAGE INDEX %			
		σ_1 psi	σ_3 psi	σ_c psi	σ_u psi							
0												
5					2200*							
10					900*				20.4			
15					2600*				15.4			
20					2300*				17.4			
25	C				4500*	12.2	7.5	9.1	134			
30					2300*				16.1			
35					3530				14.4	124		
40					2000*				17.7			
45					380				18.3	121		
50					1120				15.5	116		
55					4710				9.3	141		
60	MA				3800*				12.7	125	59.0	
65	MA				4500*				8.0			
					4500*				8.8	128	56.0	
					2700*				11.9			
					2000				12.4			
70					3000*	12.7	3.0	11.0				
					2300*			17.9				
					2700*			11.8				

BLOW COUNTS
SAMPLES

BORING AH-1

SURFACE ELEVATION 741.0

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	TOP OF LOESS Light yellowish-brown, mottled orange, silty clay, trace fine to coarse sand, organic material noted.	
6 SS		
7 SS	CL TOP OF WISCONSINAN TILL Light yellowish-brown, silty clay, some fine to coarse sand, trace fine gravel, light gray silty clay seams and reddish-brown silt pockets noted.	732.5
15 SS		
63 SS	CL Light grayish-brown, silty clay and fine to coarse sand, trace fine gravel, thin reddish-brown silt seams noted.	
HR	ML Gray, silt, some fine sand, trace clay. -trace fine gravel.	
30 SS	CL Gray, silty clay, some fine to coarse sand, little fine gravel, small sand pockets noted.	
24 SS	-trace fine gravel.	
12 SS	-organics noted. -39.7 to 39.8 ft., silty sand.	
13 SS	ML TOP OF INTERGLACIAL ZONE Gray, clayey silt, some fine to coarse sand.	697.5
15 SS	CL Greenish-blue, silty clay and fine to coarse sand, little fine gravel.	
47 SS	ML TOP OF ILLINOIAN TILL Gray, silt and fine to coarse sand, little fine gravel.	687.5
60 SS	SH Brown, fine to coarse sand, little fine gravel, trace silt and clay.	
HR	ML Light bluish-gray, clayey silt and fine to coarse sand, trace fine gravel.	
122 SS	HR	
17 SS	-thin organic seams noted.	
ST	ML Light yellowish-brown, clayey silt, some fine to coarse sand, trace fine gravel.	
20 SS	ML SM	

Boring continued.....

NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-222


LOG OF BORING AH-1
 (SHEET 1 of 2)

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FLAKES AND GRAVEL	BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLAS TICITY INDEX %	LIQUID LIMIT %							
		σ_1 psi	σ_3 psi	σ_c psi										
75				2300 2700			11.8			17 SS ST	ML			
80				4500* 8150	11.2	11.2	10.5	133		20 SS 40 SS	ML SM ML CL	Light bluish-gray, clayey silt and fine to coarse sand, trace fine gravel. Gray, clayey silt, some fine to coarse sand, trace fine gravel.		
85				4500*			8.0			174 11" SS			Boring completed at 84.9 feet on 3-26-75. Water level at 18.0 feet.	

NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-222 LOG OF BORING AH-1 (SHEET 2 of 2)




NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-223

LOG OF BORING AH-2



Boring completed at 75.0 feet on 4-4-75.
Water level at 3.0 feet.

NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-224

LOG OF BORING AH-3


DEPTH (FEET)	TESTS REPORTED	SHEAR STRENGTH			ATTENBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FINE SAND
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLUIDITY INDEX	SHRINKAGE INDEX			
		σ_1 psi	σ_3 psi	σ_c psi						
0										
5	TC	1436	1413	2000*	16.3	32.0		99		
				1000*			26.8			
10	IG			2000*			17.6	114		
				2200*			15.0			
	MA			3200*			17.8	117	10	
				1000*			14.6	121	4.0	
15										
20				1300*	11.2	10.1	9.3	140		
25				2700*						
30				2800*			16.4			
35				1000*			16.8			
40				1370			17.0	117		
				2100*			16.6			
				1530			17.8	114		
50				3200*						
				2700*						
				1360	10.8	11.4	15.6	120		
				4100*						
				1000*			14.2			
55										
				6980			8.3	135		
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING AH-4

SURFACE ELEVATION 737.4

ELEVATION (FEET)



Boring completed at 59.0 feet on 3-19-75.
Water level at 5.0 feet.


NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-225

LOG OF BORING AH-4




DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FLUID MOISTURE CONTENT, %	DRY DENSITY PCF	PERCENT FLUIDITY
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %	SHRINKAGE INDEX %			
		σ_1 psf	σ_3 psf	σ_p psf							
0											
5				500*				20.5			
10											
15				1000*				22.0			
20				7580				9.9	136		
25	MA			4000*	12.2	13.8	11.9	121	70		
30				4400*				13.9			
35				3050				14.5	120		
40				3200*	12.1	13.6	14.5				
45											
50				4300*				13.3			
55				3460				15.3	116		
60				4500*				14.5			
65				970				13.5	135		
70											
75											

BLOW COUNTS
SAMPLES

BORING AH-6

SURFACE ELEVATION 737.9

ELEVATION
(FEET)



NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-227

LOG OF BORING AH-6


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FIELD MOISTURE CONTENT %	DRY DENSITY PCF PERCENT 200 GRAVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %	FLUIDITY INDEX		
		Q _u psf	C _s psf	P _s psf						
0										
5										
10				4100*				11.5		
15	IG			2320	11.9	7.9	11.2	118		
20				4400*				12.7		
25				2170				13.2	123	
30				3100*	11.8	19.0	16.0			
35				2500*				14.9		
40				1000*				17.9		
45				2490				205	109	
				2000*	14.6	24.3	23.4	104		
50				2510				16.4	113	
55				3820				10.4	132	
60										
65										
70										
75										

BORING AH-7

SURFACE ELEVATION 732.3

BLOW COUNTS
SAMPLES

ELEVATION
(FEET)



NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-228


LOG OF BORING AH-7

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS				FIELD WATER CONTENT, %	DRY DENSITY PCF PASSED NO. 20 SIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	FIELD WATER CONTENT, %	DRY DENSITY PCF PASSED NO. 20 SIEVE		
		σ_1 psi	σ_3 psi	σ_{1-3} psi						
0										
5										
10				4500*				11.3	122	
15				4200*	11.4	25.6	12.9			
20				4500*				12.2		
25				1000*				13.6		
30				3340				14.9	115	
35				3300*						
40				1000*				55.1		
45				2040				20.3	105	
50										
55				4560				10.6	130	
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING AH-8
SURFACE ELEVATION 728.1

ELEVATION
(FEET)




NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-229

LOG OF BORING AH-8




NOTES
 Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-230

LOG OF BORING AH-9




NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-231

LOG OF BORING AH-10




NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-232

LOG OF BORING AH-11



NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-233

LOG OF BORING AH-12

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS				WATER CONTENT, % BY DRY WEIGHT	DRY DENSITY pcf BY ASTM D-155
		TRIAXIAL COMPRESSION			FLUIDITY LIMIT, %	PLAS- TICITY INDEX, %	FIELD LIQUID LIMIT, %	FIELD PLASTIC LIMIT, %		
		Q _u psi	c _u pcf	c _v pcf						
0										
5				1200				22.6	104	
10				1440				13.6	126	
15				4300*	11.6	9.8	11.1			
20				1000*				15.6		
25				3750				10.9	130	
30				4500*				14.5		
35				3800*						
40				2770	11.6	15.0	14.4	12.2		
45				2800*				14.1		
50				5010				13.5	124	
55				4500*						
60				2540				15.1	123	
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING AH-13
SURFACE ELEVATION 738.8

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS
CL	TOP OF LOESS Reddish to yellowish-brown, mottled gray, silty clay, some fine to coarse sand, pockets of organic material noted.
7 SS	
16 SS	TOP OF WISCONSINAN TILL 731.3 Brown, silty clay, and fine to coarse sand, trace fine gravel, silt seams and pockets noted.
CL · SC	
22 SS	Gray, clayey silt, some fine to coarse sand, trace fine gravel.
ML · CL	
52 SS	Gray, silty, fine to coarse sand, trace fine gravel.
SW · SM	
28 SS	Gray, silty clay, some fine to coarse sand, little fine gravel, thin silt seams noted.
CL · ML	
45 SS	-little fine to coarse sand, trace fine gravel, .025 foot thick sand lenses noted.
17 SS	-some fine to coarse sand, silt and sand seams noted.
ST	
14 SS	
24 SS	
25 SS	-and fine to coarse sand, little fine gravel, thin seams of brown organic material.
21 SS	
16 SS	-some fine to coarse sand, trace fine gravel.

Boring completed at 60.0 feet on 3-17-75.
Water level at 7.6 feet.

NOTES
Logged by: Sargent & Lundy
Drilled by: Raymond International
Tested by: Westenhoff & Novick

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-234

LOG OF BORING AH-13

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PORE RATIO	FLUIDITY INDEX %
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLAS- TICITY INDEX %	FIELD MOISTURE CONTENT %				
		Q ₁ PSI	Q ₂ PSI	Q ₃ PSI							
0											
5				2120			23.9	106			
10				4670	11.8	9.9	12.4				
15				4500*				12.3			
20				4930				13.2	125		
25				3800*			14.7				
30				4480			10.9	129			
35				4400*			12.7				
40				4400* 4200*			12.9				
45				4300*			13.2				
50				4500*	12.4	12.4	13.1	117			
55				4500*			13.0				
60				3260 2790			15.3 14.9	121 134			
65											
70											
75											


BLOW COUNTS
SAMPLES

BORING AH-14

SURFACE ELEVATION

735.9

ELEVATION
(FEET)



NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-235

LOG OF BORING AH-14

DEPTH (FEET)	TESTS REPORTED ELEVATION	SHEAR STRENGTH			ATTENBERG LIMITS				DRY DENSITY PCF	WATER CONTENT %	FLUIDITY INDEX %	SHRINKAGE INDEX %	PLASTICITY INDEX %
		COMPRESSION			PLASTIC LIMIT %	FLUIDITY LIMIT %	SHRINKAGE LIMIT %	PLASTICITY INDEX %					
		Q _u psf	Q _s psf	Q _p psf									
0													
5				460				29.5	92				
10				2720	13.3	13.1	16.1	124					
15				3000*									
20				4340	12.1	10.0	11.8	128					
25	TCU PP 1946	1440			12.4	13.0	14.3	122					
30	SA							10.1					157
35				2200*	13.1	14.1	17.6						
40	TCU PP 4977	2880		3700*	15.6	15.8							95.0
45				1000*						21.3			
50										17.0			
55				7950	12.6	8.2	10.3	131					
60				4500*									
65													
70													
75													

BLOW COUNTS
SAMPLES

BORING AH-15

SURFACE ELEVATION 733.9

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	CL	TOP OF LOESS	
5 SS		Brownish-gray, mottled reddish-brown, silty clay, trace fine to medium sand.	
	CL SC	TOP OF WISCONSINAN TILL Reddish-brown, clayey silt and fine to coarse sand, trace fine gravel, thin sand seams noted.	727.9
18 SS			
57 SS	ML	Gray, silt, trace fine sand, trace clay.	
31 SS	CL SC	Gray, clayey silt and fine to coarse sand, trace fine gravel.	
ST			
23 SS	SM	Gray, fine to coarse sand, some fine gravel, little silt, trace clay.	
14 SS	CL ML	Gray, clayey silt, little fine to coarse sand, trace fine gravel.	
22 SS	ML	Gray, clayey silt, trace fine sand.	
ST			
8 SS		-some fine to medium sand, trace fine gravel.	
	CL SC	TOP OF INTERGLACIAL ZONE Greenish-blue, silty clay and fine to coarse sand, fine gravel noted.	687.9
16 SS			
96 SS	ML SM	TOP OF ILLINOIAN TILL Bluish-gray, clayey silt and fine to coarse sand, trace fine gravel.	680.9
64 SS			

Boring completed at 60.0 feet
on 3-13-75.
Water level at 13.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-236

LOG OF BORING AH-15


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH				ATTENBERG LIMITS				FIELD MOISTURE CONTENT, %	DRY DENSITY, PCF	PLASTICITY INDEX, %	FIELD MOISTURE CONTENT, %	DRY DENSITY, PCF	PLASTICITY INDEX, %	
		TRIAxIAL COMPRESSION				PLASTIC LIMIT, %	PLASTICITY INDEX, %	FIELD MOISTURE CONTENT, %	DRY DENSITY, PCF							
		Q ₁	Q ₂	Q ₃	Q ₄											
0																
5	IG				1300*				27.7							
10					3180	15.1	17.7	16.8	119							
15					3200*				180	125						
20	7700	6759	1440		3300*				138							
25					4500*											
30					5140	12.6	15.8	13.3	125							
					7320				9.8	126						
35					4400*				129							
40					4500*											
45					5110	12.6	15.8	13.3	125							
					2030	12.0	14.3	14.8	120							
50					1100*											
55					4150	21.4	20.0	25.2	103							
60					2500*				192							
65									162							
									180							
70					4500*											
75																

BORING AH-16

SURFACE ELEVATION 737.5

BLOW COUNTS
SAMPLES

ELEVATION
(FEET)



Boring completed at 70.0 feet
on 3-17-75.
Water level at 12.5 feet.

NOTES


1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-237

LOG OF BORING AH-16

DEPTH (FEET)	TESTS REPORTED ELEMENTS	SHEAR STRENGTH			ATTENBERG LIMITS			WATER CONTENT %	WET DENSITY PCF	MOISTURE RATIO PER CENT
		TRIAxIAL COMPRESSION	UNCONSOLIDATED UNSATURATED	UNSATURATED SATURATED	PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
0										
8	IG			940				239	112	
10				1500	14.7	3.0	169			
15	MA			1300				105	564	
20				2330	14.0	5.3	133	141		
25				4500						
30	TCU	225	1440		11.4	16.1	126	127		
35				7190				122	130	
40				1500						
45	TCU	2880	3600		24.9	16.0				
				1800				206		
				1820	13.4	20.3	215	111		
50				3700						
				3300	12.2	26.6	187	127		
55				4500				8.6		
60				4500				7.7		
65										
70										
75										




NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-238

LOG OF BORING AH-17



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-239

LOG OF BORING AH-18

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH				ATTENBERS LIMITS				FIELD MOISTURE CONTENT, %	DRY DENSITY PCF WATER CONTENT PLASTICITY INDEX
		TRIAxIAL COMPRESSION		UNIAxIAL COMPRESSION		PLASTIC LIMIT %	FLAS- TICITY INDEX %	FLUIDITY INDEX %	UNSATURATED SHRINKAGE INDEX %		
		q _u	c _u	q _v	c _v						
0											
5					600*				253		
10					2650	12.5	9.5	141	123		
15	SA								16.1	120	
20									12.1		
25					7110	13.0	15.0	121	128		
30	MA				1850				156	124701	
35					2100*						
40						13.2	11.0	62.5			
45					2200*	14.3	16.1	19.7	108		
50					2330	12.1	30.3	173	201109		
55					4400*						
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING AH-19

SURFACE ELEVATION 737.0

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
		TOP OF LOESS	
7	ML	Yellow brown, mottled gray, clayey silt, trace fine sand, trace organics.	
		TOP OF WISCONSINAN TILL	731.6
15	ML CL	Yellow brown, clayey silt, some fine to coarse sand, trace fine gravel, trace organics.	
22	SP SH	Brown, fine to coarse sand, trace fine gravel, trace silt.	
20	ML	Gray silt, little fine to medium sand, trace fine gravel, trace clay.	
34	CL	Gray, clayey silt, some fine to coarse sand, trace fine gravel, trace organics.	
37	ML	Gray, silt, some fine to medium sand, trace fine gravel, thin sand seams noted.	
20	ML CL	Gray, clayey silt and silty clay, layered, some fine to coarse sand, trace fine to coarse gravel, thin sand seams noted.	
14	ST	TOP OF INTERGLACIAL ZONE	691.5
13	CL	Gray, clayey silt, little fine to medium sand, trace fine gravel. -47.0 to 48.0 feet, boulder.	
100	CL	Bluish-gray, silty clay, some fine to medium sand, fine gravel noted.	
		TOP OF ILLINOIAN TILL	683.5
100	ML	Light bluish-gray, clayey silt, some fine to coarse sand, little fine gravel, small sand pockets noted.	
100 3"	SH	Brown and gray, fine to coarse sand, little fine gravel, little silt, trace clay.	

Boring completed at 59.5 feet
on 3-11-75.
Water level at 11.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-240

LOG OF BORING AH-19

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH				ATTENBERG LIMITS				WET DENSITY PCF	WET DENSITY PCF PLUS 200 GRAVE
		TRIAxIAL COMPRESSION		Q _s PSF	U _s PSF	PLASTIC LIMIT %	FLAS TICITY INDEX %	MOISTURE CONTENT %	DRY DENSITY PCF		
		C _u PSF	C _s PSF								
0											
5	IG			740			270	99			
10				500*							
15				1130	12.4	13.8	163	110			
20	SA						8.8	112			
25											
30				7890	15.2	8.7	161	128			
35				1200*							
40				3370			152	127			
45				1470	14.3	13.6	192	119			
50				2500*							
55				4200*			128				
60											
65											
70											
75											

BORING AH-20

SURFACE ELEVATION 738.8

BLOW COUNTS
SAMPLES

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	CL	TOP OF LOESS	
6 SS	CL	Reddish-brown, mottled grayish-brown, silty clay, trace fine gravel, trace fine sand, trace organics.	
	SC	TOP OF WISCONSINAN TILL	733.8
6 SS	SC	Light reddish-brown, silty clay and fine to coarse sand, little fine gravel, trace organics.	
8 SS	CL	Gray, clayey silt, some fine to coarse sand, trace fine gravel.	
21 SS	SH	Gray, fine to coarse sand, some fine to coarse gravel, little silt and clay.	
27 SS			
57 SS	ML CL	Gray, silt, trace fine sand, trace clay.	
31 SS	CL	Gray, clayey silt, some fine to coarse sand, little fine gravel.	
27 SS		-black organic seams noted.	
10 SS	CL	TOP OF INTERGLACIAL ZONE	695.3
	CL	Gray, clayey silt, little fine to medium sand, trace fine gravel.	
9 SS	CL	Greenish-blue, silty clay, some fine to coarse sand, trace fine gravel.	
57 SS	ML SM	TOP OF ILLINOIAN TILL	695.3
131 SS	ML SM	Bluish-gray, clayey silt and fine to coarse sand, trace fine gravel, thin sand seams noted.	

Boring completed at 60.0 feet
on 3-13-75.
Water level at 5.6 feet.


NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-241

LOG OF BORING AH-20



NOTES

Logged by: Sargent & Lundy
 Drilled by: Raymond International
 Tested by: Westenhoff & Novick

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-242

LOG OF BORING AH-21


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF PERCENT H2O BELIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %	MOISTURE CONTENT %	
		σ_1 pcf	σ_3 pcf	c_u pcf					
0									
5									
10									
15	SA								158
20	SA								8.7
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING K-1

SURFACE ELEVATION 671.9

ELEVATION
(FEET)



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on bulk samples from 10.5 to 25.5 feet depth.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-243

LOG OF BORING K-1

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF PERCENT PASSING #200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	FLUID LIMIT %	LIQUID LIMIT %	
		σ_1 psf	σ_3 psf	σ_c psf					
0									
5	SA								20.5
10									
15	SA								13.3
20	SA								9.9
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING K-2

SURFACE ELEVATION 670.5

ELEVATION
(FEET)

	SYMBOLS	DESCRIPTIONS	
AC	CL ML	TOP OF SALT CREEK ALLUVIUM Brown, silty clay, trace fine sand.	
BC	SM	TOP OF OUTWASH Brown, fine to coarse sand, some silt, some fine to coarse gravel.	665.0
BC	GM	Brown, fine to coarse gravel, some fine to coarse sand, some silt.	
BC	SW SM	Brown, fine to coarse sand, some fine to coarse gravel, trace silt.	
	MI	TOP OF ILLINOIAN TILL Grey, clayey silt, some fine to coarse sand, trace fine gravel.	642.5
		Boring completed at 30.0 feet on 3-19-75. Water level at 11.0 feet.	

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-244

LOG OF BORING K-2

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	RELATIVE DENSITY 200 SIEVE
		COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf	q_u psf						
0										
5										
10	SA								2.33	
15	SA								1.35	
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING K-3
SURFACE ELEVATION 669.3

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	TOP OF SALT CREEK ALLUVIUM	
ML	Dark brown, silty clay, trace fine to coarse sand, trace fine gravel.	
BC	TOP OF OUTWASH	663.3
SM	Brown, silty, fine to medium sand, trace fine to coarse gravel. - some silt.	
BC		
ML	Gray, silt, some fine to coarse sand, some fine gravel, trace organics.	
	TOP OF ILLINOIAN TILL	642.3
ML	Gray, clayey silt, trace fine gravel.	
	Boring completed at 30.0 feet on 3-20-75. Water level at 9.5 feet.	

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on mixed bulk samples from 10.0 to 15.0 feet depth in K-3 and 15.0 to 25.0 feet in K-7.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-245


LOG OF BORING K-3

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS					DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQ- UID CONTENT %	FLUID CONTENT %	RELATIVE DENSITY		
		σ_1 pcf	σ_3 pcf	σ_{av} pcf							
0											
5											
10											
15	SA									121	
20											
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING K-4
SURFACE ELEVATION 684.1

ELEVATION
(FEET)



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on mixed bulk samples from 12.0 to 21.0 feet depth in K-4 and 6.5 to 15.0 feet depth in K-5.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-246
LOG OF BORING K-4

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS		FIELD MOISTURE CONTENT, %	DRY DENSITY, PCF	RELATIVE DENSITY PERCENTAGE PASSING 200 SIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT, %	LIQUID LIMIT, %			
		σ_1 psf	σ_3 psf	σ_c psf					
0									
5	SA						194		
10	SA						109		
15	SA						226		
20	SA						162		
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING K-5

SURFACE ELEVATION 683.3

ELEVATION
(FEET)

SYMBOLS		DESCRIPTIONS	
AC	CL ML	TIP OF SALT CREEK ALLUVIUM Brown, silty clay, trace fine sand.	
		TOP OF OUTWASH	676.8
BC	SM	Brown, fine to coarse sand, some fine to coarse gravel some silt.	
BC	SP SM	Brown, fine to coarse sand, some fine gravel, trace silt.	
BC	SM GM	Brown, silty, fine to coarse sand and fine to coarse gravel.	
BC	SM	Brown, fine to coarse sand, some fine to coarse gravel, some silt.	
	MI	TOP OF ILLINOIAN TILL. Gray, clayey silt, trace fine gravel.	660.3

Boring completed at 30.0 feet on 3-20-75.
Water level at 17.5 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on bulk samples from 6.5 to 20.0 feet depth and on mixed bulk samples from 6.5 to 15.0 feet depth in K-5 and 12.0 to 21.0 feet depth in K-4.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-247

LOG OF BORING K-5


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF PLASTIC LIQUID SHRINKAGE
		COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	FLUID CONTENT %	SHRINKAGE INDEX %	
		σ_c psi	σ_3 psi	σ_1 psi					
0									
5									
10	SA								24.1
15	SA								9.2
20									
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING K-6

SURFACE ELEVATION 671.8

ELEVATION
(FEET)



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on bulk samples from 6.5 to 15.0 feet depth.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-248

LOG OF BORING K-6

DEPTH (FEET)	TESTS REPORTED ELEVATION	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF	WET DENSITY PCF	WET DENSITY KG/M ³
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLUIDITY LIMIT %	LIQUID LIMIT %	SHRINKAGE INDEX %			
		Q ₁	Q ₂	Q ₃							
0											
5											
10	SA								276		
15	SA								7.9		
20	SA								4.3		
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING K-7
SURFACE ELEVATION 671.1

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	CL ML	TOP OF SALT CREEK ALLUVIUM Dark grayish-brown, silty clay.	
		TOP OF OUTWASH	665.1
BG	SM	Reddish-brown, silty, fine to coarse sand, some fine gravel, some silt.	
BG	SP SM	Brown, fine to coarse sand, some fine to coarse gravel, trace silt.	
BG	SP	Brown, fine to coarse sand, some fine gravel, trace silt.	
	ML	TOP OF ILLINOIAN TILL Gray, clayey silt, some fine gravel.	642.1
		Boring completed at 10.0 feet on 3-19-75. Water level at 11.5 feet.	

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on mixed bulk samples from 15.0 to 25.0 feet depth in K-7 and 10.0 to 15.0 feet depth in K-3.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-249

LOG OF BORING K-7

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS			FIELD DENSITY CORRECTED %	DRY DENSITY PCF	WATER CONTENT %	FLUIDITY INDEX %
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLAS- TICITY INDEX %	FIELD DENSITY CORRECTED %				
		σ_1 psf	σ_3 psf	σ_c psf							
0											
5											
10	SA									8.7	
15											
20	SA									6.9	
25	SA									4.3	
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS

BORING K-8
SURFACE ELEVATION 678.5

ELEVATION
(FEET)

SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
AC	ML CL	TOP OF SALT CREEK ALLUVIUM Brown, clayey silt, some fine to coarse sand, trace fine gravel.	
BC		TOP OF OUTWASH	672.5
BC	SP SM	Brown, fine to coarse sand, trace fine to coarse gravel, trace silt. -trace fine gravel.	
BC	SP	Brown, fine to coarse sand, trace fine gravel, trace silt.	
BC	ML	TOP OF ILLINOIAN TILL Gray, clayey silt, trace fine to coarse sand, trace fine gravel.	650.0
		Boring completed at 30.0 feet on 3-20-75. Water level at 24.0 feet.	

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on bulk samples from 6.0 to 20.0 feet depth.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-250

LOG OF BORING K-8

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS				FIELD CONTENTS % DRY DENSITY PCF RELATIVE DENSITY SAND BLOW
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	FLAS- TICITY INDEX %	LIQUID LIMIT %	PLASTICITY INDEX %	
		σ_1	σ_3	σ_d					
0									
5									
10	SA								18.5
15	SA								23
20	SA								8.4
25	SA								7.7
30	SA								4.1
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING K-11
SURFACE ELEVATION 682.5

ELEVATION
(FEET)

BLOW COUNTS	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
AG	CL • ML	TOP OF SALT CREEK ALLUVIUM Brown, silty clay, trace fine sand.	677.5
	SM	TIP OF OUTWASH	
BG		Brown, fine to coarse sand, some silt, trace fine gravel.	
BG			
BG	SP • SM	Brown, fine to coarse sand, some fine gravel, trace silt.	
BG			
BG	SP	Brown, fine to coarse sand, some fine gravel, trace silt.	

Boring completed at 30.0 feet
on 3-20-75.
Water level at 28.0 feet.

NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on bulk samples from 5.0 to 25.0 feet depth.


<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>FIGURE 2.5-251</p> <p>LOG OF BORING K-11</p>

DEPTH (FEET)	TESTS REPORTED ELEVATION	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	RELATIVE DENSITY PERCENT	TEST SHEET
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLAS- TICITY INDEX %				
		σ_1 psf	σ_3 psf	$\sigma_1 - \sigma_3$ psf							
0											
5	HA									4.76	
	SA									15.1	
10											
	SA									7.3	
15											
	SA									3.8	
20											
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS

BORING K-12
SURFACE ELEVATION 673.8

ELEVATION
(FEET)



NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.
4. Compaction and relative density tests performed on bulk samples from 5.0 to 20.0 feet depth.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-252

LOG OF BORING K-12

DEPTH (FEET)	TESTS REPORTED ELEVATION	SHEAR STRENGTH			ATTENBERG LIMITS				WATER CONTENT, %	DRY DENSITY PCF	RELATIVE DENSITY FOR SOILS
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX, %	FIELD CLASSIFICATION			
		σ_1 psi	σ_3 psi	τ psi							
0											
5	SA								23.7		
10	SA								8.8		
15	SA								7.5		
20											
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING K-15

SURFACE ELEVATION 668.4

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	CL	TOP OF SALT CREEK ALLUVIUM	
	ML	Brown, silty clay.	
		TOP OF OUTWASH	663.9
BG	SM	Brown, silty, fine to coarse sand, some fine to coarse gravel.	
BG	SP SM	Brown, fine to coarse sand, some fine to coarse gravel, trace silt.	
BG	SW SM	Brown, fine to coarse sand, some fine to coarse gravel, trace silt.	
		TOP OF ILLINOIAN TILL	645.4
	ML	Gray, silty clay, some fine to coarse sand, some fine gravel.	

Boring completed at 30.0 feet
on 3-19-75.
Water level at 9.0 feet.


NOTES

1. Logged by: Sargent & Lundy Engineers
2. Drilled by: Raymond International
3. Tested by: Westenhoff and Novick, Inc.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-253

LOG OF BORING K-15



PIEZOMETER INSTALLED ON 5/12/76. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 646.7. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 646.7 TO 656.7; BENTONITE SEAL FROM ELEVATION 656.7 TO 658.7; AND CEMENT GROUT FROM ELEVATION 658.7 TO 716.7.

BORING COMPLETED AT 70.0 FEET.

ON 5/12/76.

CASING USED TO A DEPTH OF 10.0 FEET.

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-254

LOG OF BORING OW-1

BORING OW-2

SURFACE ELEVATION APPROXIMATELY 675

DEPTH (FEET)

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS			FIELD SENSITIVITY %	WATER CONTENT %	FLUIDITY INDEX	DRY DENSITY PCF	WET DENSITY PCF	SAMPLING METHOD
		COMPRESSION			PLASTIC LIMIT %	PLASTICITY INDEX %	LIQUID LIMIT %						
		QU	Q ₃	Q ₁									
0													
5								13.4					
10				900				25.5	113				
15				3500				21.4	104				
20				2800				18.5					
25													
30													
35													
40													
45													
50													
55													
60													
65													
70													
75													

BLOW COUNTS
SAMPLES

SYMBOLS	DESCRIPTIONS
CL	WISCONSINAN TILL
ML	Tan to light brown, silty clay, some fine to coarse sand, trace fine gravel, organic material noted.
SS	Orange, medium to coarse sand, trace silt.
SP	TOP OF INTERGLACIAL ZONE 8.5
ML	Light gray, mottled tan, silt, trace fine to medium sand.
SS	Brown, mottled rust & gray, silty clay, little fine to coarse sand, trace fine gravel.
CL	Light green, mottled bluish gray, silty clay, trace fine to coarse sand, trace fine gravel.

BORING COMPLETED AT 20.0 FEET
ON 5/12/76.
WATER LEVEL AT 19.5 FEET.


PIEZOMETER INSTALLED ON 5/12/76. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 675. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 675 TO 690; BENTONITE SEAL FROM ELEVATION 690 TO 692; AND CEMENT GROUT FROM ELEVATION 692 TO 695.

- NOTES:
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: RAYMOND INTERNATIONAL.
 3. TESTED BY: WESTENHOFF & NOVICK.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-255

LOG OF BORING OW-2



PIEZMETER INSTALLED IN OW-3 DEEP ON 5/10/76. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 695.9. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 695.9 TO 705.9, BENTONITE SEAL FROM ELEVATION 705.9 TO 707.9, AND CEMENT GROUT FROM ELEVATION 707.9 TO 735.9.

PIEZMETER INSTALLED ON 5/10/76. BORING OW-3 SHALLOW LOCATED 2 FEET NORTH OF OW-3 DEEP WAS DRILLED TO A DEPTH OF 10 FEET. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 725.9. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 725.9 TO 730.9, BENTONITE SEAL FROM ELEVATION 730.9 TO 732.9, AND CEMENT GROUT FROM ELEVATION 732.9 TO 735.9.

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-256

LOG OF BORING OW-3

DEPTH (FEET)	TESTS REPORTED ELEMENTS	SHEAR STRENGTH			ATTENBERG LIMITS			WATER CONTENT %	DRY DENSITY PCF	MOISTURE RATIO	FLUIDITY CLASS
		TRIAxIAL COMPRESSION		S _v	PLASTIC LIMIT %	FLUIDITY LIMIT %	LIQUIDITY LIMIT %				
		Q _u psf	C _u psf								
0											
5				2500							
10				2500			22.2				
15				2400			12.3	126			
20											
25				4500+							
30	HA			4500+			12.8	121	66.2		
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING OW-4
SURFACE ELEVATION 721.0

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	LOESS Yellowish-brown, clayey silt, trace fine sand, thin layer of organic material noted. 3.5 feet, mottled light gray.	
8 SS		
8 SS	TOP OF WISCONSINAN TILL Brownish-gray, clayey silt, trace fine sand. 9.5 feet, grades to gray.	715.5
ML		
19 SS		
38 SS	CL Gray, silty clay, some fine to coarse sand, trace fine gravel.	
38 SS	SW Gray, fine to medium sand, trace silt, fine gravel noted.	
SM		
23 SS	CL Gray, silty clay, some fine to coarse sand, trace fine gravel.	

BORING COMPLETED AT 27.0 FEET
ON 5/7/76.
WATER LEVEL AT 5.5 FEET.

PIEZOMETER INSTALLED IN OW-4 DEEP ON 5-7-76. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 697.5 GRANULAR BACKFILL WAS PLACED FROM ELEVATION 697.5 TO 711; BENTONITE SEAL FROM ELEVATION 711 TO 713; AND CEMENT GROUT FROM ELEVATION 713 TO 721.

PIEZOMETER INSTALLED ON 5-7-76. BORING OW-4 SHALLOW LOCATED 3.5 FEET NORTH OF OW-4 DEEP WAS DRILLED TO A DEPTH OF 6.9 FEET. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 714.1 GRANULAR BACKFILL WAS PLACED FROM ELEVATION 714.1 TO 718.1; BENTONITE SEAL FROM ELEVATION 718.1 TO 720.1; CEMENT GROUT FROM ELEVATION 720.1 TO 721.0.


NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTERNHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-257

LOG OF BORING OW-4



PIEZOMETER INSTALLED IN OW-5 DEEP ON 5/7/76. A 2 INCH INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 694.4. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 694.4 TO 702.6; BENTONITE SEAL FROM ELEVATION 702.6 TO 704.6; AND CEMENT GROUT FROM ELEVATION 704.6 TO 712.6.

PIEZOMETER INSTALLED ON 5/7/76. BORING OW-5 SHALLOW LOCATED 2 FEET SOUTH OF OW-5 DEEP WAS DRILLED TO A DEPTH OF 8 FEET. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 704.6 GRANULAR BACKFILL WAS PLACED FROM ELEVATION 704.6 TO 708.6; BENTONITE SEAL FROM ELEVATION 708.6 TO 710. AND CEMENT GROUT FROM ELEVATION 710.6 TO 712.6.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-258

LOG OF BORING OW-5

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH TRIAXIAL COMPRESSION			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	WATER CONTENT %	PLASTICITY INDEX %
		C _u (PSI)	C _v (PSI)	C _d (PSI)	PLASTIC LIMIT %	FLUIDITY INDEX %	LIQUIDITY INDEX %				
0											
5				2700			21.3				
10				2300			17.7				
15											
20											
25				1400			16.7	116			
30				1800							
35				1900			13.9	116			
40							17.7				
45				4000			12.9				
50	NA			3300			38.4	799	8.9		
55											
60											
65											
70											
75											

BORING OW-6

SURFACE ELEVATION 743.2

ELEVATION (FEET)

BLOW COUNTS SAMPLES



BORING COMPLETED AT 52.0 FEET ON 5/10/76.

CASING USED TO A DEPTH OF 10.0 FEET.

PIEZOMETER INSTALLED IN OW-6 DEEP ON 5/10/76. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED AT ELEVATION 691.2. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 691.2 TO 733.2; BENTONITE SEAL FROM ELEVATION 733.2 TO 735.2; AND CEMENT GROUT FROM ELEVATION 735.2 TO 743.2.

PIEZOMETER INSTALLED ON 5/10/76. BORING OW-6 SHALLOW LOCATED 2 FEET NORTH OF OW-6 DEEP WAS DRILLED TO A DEPTH OF 7.5 FEET. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED AT ELEVATION 735.8. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 735.8 TO 740.8; BENTONITE SEAL FROM ELEVATION 740.8 TO 741.8; AND CEMENT GROUT FROM 741.8 TO 743.2.

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-259


LOG OF BORING OW-6

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENBERG LIMITS				PLASTICITY INDEX, %	MOISTURE CONTENT, %	DRY DENSITY PCF	RELATIVE DENSITY FOR SILT
		TRIAxIAL COMPRESSION			PLASTIC LIMIT, %	FLUIDITY LIMIT, %	SHRINKAGE LIMIT, %	LIQUID LIMIT, %				
		σ_1 / psf	σ_3 / psf	σ_c / psf								
0												
5				1800								
10				2600				14.1	124			
15				4500+								
20				2300				15.0	116			
25	MA			1400				15.8	120	58.4		
30												
35												
40												
45												
50												
55												
60												
65												
70												
75												

BLOW COUNTS
SAMPLES

BORING OW-7
SURFACE ELEVATION 718.6

ELEVATION (FEET)



BORING COMPLETED AT 25.0 FEET
ON 5/13/76.
WATER LEVEL NOT ENCOUNTERED.

PIEZOMETER INSTALLED IN OW-7 DEEP ON 5/13/76. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED AT ELEVATION 693.6. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 693.6 TO 708.6; BENTONITE SEAL FROM ELEVATION 708.6 TO 710.6; AND CEMENT GROUT FROM 710.6 TO 718.6.

PIEZOMETER INSTALLED ON 5/13/76, BORING OW-7 SHALLOW LOCATED 2.5 FEET WEST OF OW-7 DEEP WAS DRILLED TO A DEPTH OF 6.0 FEET. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED AT ELEVATION 712.6. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 712.6 TO 716.6; BENTONITE SEAL FROM ELEVATION 716.6 TO 717.6; AND CEMENT GROUT FROM ELEVATION 717.6 TO 718.6.


NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-260

LOG OF BORING OW-7



PIEZOMETER INSTALLED ON 5/12/76. A 2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 3 FEET PERFORATED WAS PLACED TO ELEVATION 677.2. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 677.2 TO 701.2; BENTONITE SEAL FROM ELEVATION 701.2 TO 703.2; AND CEMENT GROUT FROM ELEVATION 703.2 TO 719.2.

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: RAYMOND INTERNATIONAL.
3. TESTED BY: WESTENHOFF & NOVICK.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-261

LOG OF BORING OW-8

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTENUATION LIMITS			WELL LOGGING CORRECTION	DRY DENSITY PCF	WATER CONTENT PERCENT
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	FLAS- TICITY INDEX %	FLAS- TICITY INDEX %			
		σ_1	σ_2	σ_3						
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING OW-9

SURFACE ELEVATION 654.3

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
OL NL	TOPSOIL	
AG	TOP OF SALT CREEK ALLUVIUM Brown, silty clay.	649.3
AG	Brown, fine to coarse sand, some fine to coarse gravel.	
AG	TOP OF ILLINOIAN TILL	637.3
AG	Gray, clayey silt, some fine to coarse sand, trace fine gravel. Lenses of fine sand and gravelly clay noted.	

BORING COMPLETED AT 24.5 FEET
ON 8-1-77.
WATER LEVEL AT 12.5 FEET.
CASING USED TO A DEPTH OF 24.5 FEET.

PIEZOMETER INSTALLED ON 8-1-77. A 1½ INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED TO ELEVATION 629.8. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 629.8 TO 637.8; BENTONITE SEAL FROM ELEVATION 637.8 TO 639.8; AND GRANULAR BACKFILL FROM ELEVATION 639.8 TO 654.3.


NOTES:

1. LOGGED BY: SOIL TESTING SERVICES.
2. DRILLED BY: SOIL TESTING SERVICES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-262

LOG OF BORING OW-9




PIEZOMETER INSTALLED ON 8/2/77. A 1½ INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED TO ELEVATION 621.0. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 621.0 TO 629.0; BENTONITE SEAL FROM ELEVATION 629.0 TO 631.0; AND GRANULAR BACKFILL FROM ELEVATION 631.0 TO 656.0.

- NOTES:**
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: SOIL TESTING SERVICES.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-263

LOG OF BORING OW-10




DEPTH (FEET)	TESTS REPORTED ELEMENTS	SHEAR STRENGTH			ATTENBERG LIMITS				WATER CONTENT %	DRY DENSITY PCF	WET DENSITY PCF	SAND %	SILT %	CLAY %				
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLAS- TICITY INDEX %	PI/25 MOISTURE CONTENT %	DRY DENSITY PCF										
		Q _u	σ ₃	σ ₁														
0																		
5																		
10																		
15																		
20																		
25																		
30																		
35																		
40																		
45																		
50																		
55																		
60																		
65																		
70																		
75																		

BLOW COUNTS
SAMPLES

BORING OW-12

SURFACE ELEVATION 659.2

ELEVATION
(FEET)



BORING COMPLETED AT 25.0 FEET

ON 8/2/77.

CASING USED TO A DEPTH OF 20.0 FEET.

WATER LEVEL AT 18.5 FEET.

PIEZOMETER INSTALLED ON 8/2/77. A 1 1/2 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED TO ELEVATION 634.2. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 634.2 TO 642.2; BENTONITE SEAL FROM ELEVATION 642.2 TO 644.2; AND GRANULAR BACKFILL FROM ELEVATION 644.2 TO 659.2.


NOTES:

- LOGGED BY: SARGENT & LUND.
- DRILLED BY: SOIL TESTING SERVICES.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-265

LOG OF BORING OW-12



PIEZOMETER INSTALLED ON 8/2/77. A 1½ INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED AT ELEVATION 622.1. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 622.1 TO 630.1; BENTONITE SEAL FROM ELEVATION 630.1 TO 632.1; AND GRANULAR BACKFILL FROM ELEVATION 632.1 TO 662.1.

NOTES:

1. LOGGED BY: SARGENT & LUNDY.
2. DRILLED BY: SOIL TESTING SERVICES.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-266

LOG OF BORING OW-13

DEPTH (FEET)	TESTS REPORTED ELEMENTS	SHEAR STRENGTH			ATTENBERG LIMITS				WATER CONTENT %	DRY DENSITY PCF	FLUIDITY CLASSIFICATION	SOLIDS CONTENT %
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %	SHRINKAGE LIMIT %				
		Q _u PSF	C _s PSF	S _u PSF								
0												
5												
10												
15												
20												
25												
30												
35												
40												
45												
50												
55												
60												
65												
70												
75												

BLOW COUNTS
SAMPLES

BORING OW-14

SURFACE ELEVATION 657.1

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS
	Rotary drilled without sampling to 17.0 feet.
AG	TOP OF ILLINOIAN TILL 640.1 Gray, clayey silt, some fine to coarse sand, trace gravel.
AG	Gray, fine to coarse sand, trace gravel.
AG	Gray, clayey silt, some fine to coarse sand, trace gravel.
	BORING COMPLETED AT 31.0 FEET ON 8/2/77. CASING USED TO A DEPTH OF 30.0 FEET. WATER LEVEL AT 13.5 FEET.

PIEZOMETER INSTALLED ON 8/2/77. A 1 1/4 INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED FROM ELEVATION 626.1. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 626.1 TO 634.1; BENTONITE SEAL FROM ELEVATION 634.1 TO 636.1; AND GRANULAR BACKFILL FROM ELEVATION 636.1 TO 657.1.


NOTES:

1. LOGGED BY SARGENT & LUNDY.
2. DRILLED BY: SOIL TESTING SERVICES.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-267

LOG OF BORING OW-14




PIEZOMETER INSTALLED ON 8/3/77. A 1½ INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED TO ELEVATION 609.5. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 609.5 TO 617.5; BENTONITE SEAL FROM ELEVATION 617.5 TO 619.5; AND GRANULAR BACKFILL FROM ELEVATION 619.5 TO 664.5.

- NOTES:**
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: SOIL TESTING SERVICES

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-268

LOG OF BORING OW-15



PIEZOMETER INSTALLED ON 8/3/77. A 1½ INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED AT ELEVATION 627.9 GRANULAR BACKFILL WAS PLACED FROM ELEVATION 627.9 TO 635.9; BENTONITE SEAL FROM ELEVATION 635.9 TO 637.9; AND GRANULAR BACKFILL FROM ELEVATION 637.9 TO 657.9.

- NOTES:**
1. LOGGED BY: SARGENT & LUNDY.
 2. DRILLED BY: SOIL TESTING SERVICES

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-269

LOG OF BORING OW-16

DEPTH (FEET)	TESTS REPORTED ELEVATION	SHEAR STRENGTH			ATTENBERG LIMITS				WATER CONTENT %	DRY DENSITY PCF	RELATIVE DENSITY	SPT BLows
		TRIAXIAL COMPRESSION		UNCONSOLIDATED UNSATURATED	PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %	SHRINKAGE LIMIT %				
		Q _u	C _u									
0												
5												
10												
15												
20												
25												
30												
35												
40												
45												
50												
55												
60												
65												
70												
75												

BORING OW-17

SURFACE ELEVATION 659.5

ELEVATION
(FEET)

BLOW COUNTS
SAMPLES

SYMBOLS	DESCRIPTIONS
AG	NO SAMPLES TAKEN ABOVE ELEVATION 638.0 feet.
AG ML	TOP OF ILLINOIAN TILL 638.0 Gray, clayey silt, some fine to coarse sand, trace gravel.
AG SC	Gray, clayey sand, some fine to coarse gravel.

BORING COMPLETED AT 40.0 FEET
ON 8/3/77.
CASING USED TO A DEPTH OF 21.5 FEET.
WATER LEVEL NOT RECORDED.


PIEZOMETER INSTALLED ON 8/3/77. A 1½ INCH PVC PIPE WITH THE LOWER END PLUGGED AND THE LOWER 5 FEET SLOTTED WAS PLACED TO ELEVATION 619.5. GRANULAR BACKFILL WAS PLACED FROM ELEVATION 619.5 TO 627.5; BENTONITE SEAL FROM ELEVATION 627.5 TO 629.5; AND GRANULAR BACKFILL FROM ELEVATION 629.5 TO 659.5.

- NOTES:**
- LOGGED BY: SARGENT & LUNDY.
 - DRILLED BY: SOIL TESTING SERVICES.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-270

LOG OF BORING OW-17




LEGEND:

- 740— TOPOGRAPHIC CONTOURS
- P-1 BORING LOCATION
- LOCATION OF BORING THAT EXTENDED TO BEDROCK.
- H ——— H' SUBSURFACE SECTION LOCATION

NOTES:


1. BORING LOCATIONS ARE SHOWN ON SECTIONS 2, 3 & 276 AND 277.
2. BORING LOCATIONS ARE SHOWN ON SECTIONS 2, 3 & 276 THROUGH 2, 3 & 277 THROUGH 2, 3 & 194, 2, 3 & 195, 2, 3 & 196, 2, 3 & 197 AND 2, 3 & 198 FOR 10% OF BORINGS.




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-271

PLOT PLAN - STATION SITE






- NOTES:
1. REFER TO FIGURE 2.5-278 FOR SUBSURFACE SECTION.
 2. REFER TO FIGURES 2.5-94 THROUGH 2.5-97 FOR LOG OF BORINGS.

LEGEND

- TOPOGRAPHIC CONTOURS
- BORING D-30 BORING LOCATION
- BORING D-31 LOCATION OF BORING THAT EXTENDED TO BEDROCK.
- E — E' SUB SURFACE SECTION LOCATION



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-273

SECTION E-E' ALONG NORTH FORK
OF SALT CREEK

TIME STRATIGRAPHY		STRATIGRAPHIC UNITS					
		FSAR	PSAR	BORING LOGS			
Quaternary System	Pleistocene Series	Holocene Stage	Cahokia Alluvium	Peyton Colluvium	Salt Creek Alluvium or Flood Plain Alluvium and Recent Channel Deposits	Salt Creek Alluvium	
		Wisconsinan Stage	Valderan Substage	Richland Loess	Henry Formation	Loess	Loess
			Twocreekan Substage				
			Woodfordian Substage	Wedron Formation		Wisconsinan Till or Wisconsinan Glacial Till	Wisconsinan Glacial Till
			Farmdalian Substage	Robein Silt		Interglacial Zone or Sangamon Interglacial Zone or Sangamon Soil Interval	Interglacial Zone
			Altonian Substage				
		Sangamonian Stage	weathered Glasford Formation	Illinoian Till or Illinoian Glacial Till	Illinoian Glacial Till		
		Illinoian Stage	unaltered Glasford Formation				
		Yarmouthian Stage	Banner Formation	Lacustrine Deposit	Lacustrine Deposit		
		Kansan Stage		Pre-Illinoian Glacial Till or Kansan Till	Pre-Illinoian Glacial Till		
Pre-Illinoian Alluvial and Lacustrine Deposit or Kansan Alluvial or Lacustrine Soils	Pre-Illinoian Lacustrine Deposit						
		Bedrock Valley Outwash Deposit or Mahomet Valley Deposit	Mahomet Bedrock Valley Deposit				
Unconformity							
Pennsylvanian System		Bedrock	Bedrock	Bedrock			


NOTES:

- EXCAVATIONS FOR THE CLINTON POWER STATION DID NOT EXTEND BELOW THE UNALTERED GLASFORD FORMATION.
- BORINGS FOR THE CLINTON POWER STATION DID NOT EXTEND INTO ROCKS OLDER THAN THOSE OF THE PENNSYLVANIAN SYSTEM.
- ILLINOIAN-AGE TILL OF THE GLASFORD FORMATION WAS SUBJECTED TO A SIGNIFICANT PERIOD OF WEATHERING DURING THE SANGAMONIAN STAGE AND ALTONIAN SUBSTAGE.
- DEPOSITS OF CAHOKIA ALLUVIUM AND HENRY FORMATION WERE NOT DIFFERENTIATED.
- THE HOLOCENE STAGE IS REPRESENTED BY A SIGNIFICANT PERIOD OF WEATHERING AND DEVELOPMENT OF AGRICULTURAL SOIL PROFILES (MODERN SOIL).
- VERTICAL SCALE DOES NOT REPRESENT EITHER RELATIVE THICKNESS OF STRATIGRAPHIC UNITS OR RELATIVE DURATION OF TIME INTERVAL.

**CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT**

FIGURE 2.5-274

COMPARISON OF TERMINOLOGY USED FOR THE
FSAR, PSAR AND BORING LOGS




- NOTES:
1. GROUNDWATER LEVELS INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS WITH PIEZOMETERS. INFORMATION ON ACTUAL GROUNDWATER LEVELS EXIST ONLY AT BORING LOCATIONS WITH PIEZOMETERS. IT IS POSSIBLE THAT GROUNDWATER LEVELS BETWEEN BORINGS WITH PIEZOMETERS MAY VARY FROM THOSE INDICATED.
 2. THE DEPTH AND THICKNESS OF SOIL AND ROCK STRATA INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS. INFORMATION ON ACTUAL SOIL AND ROCK CONDITIONS EXIST ONLY AT BORING LOCATIONS. IT IS POSSIBLE THAT SOIL AND ROCK CONDITIONS MAY VARY FROM THOSE INDICATED.
 3. THE DISCUSSION IN THE TEXT IS NECESSARY FOR PROPER UNDERSTANDING OF THE NATURE OF THE SUBSURFACE MATERIALS.
 4. ELEVATIONS REFER TO U.S.G.S. DATUM.
 5. REFER TO FIGURE 2.5-271 FOR LOCATION OF SUBSURFACE PROFILES.
 6. FOR DETAILED WATER LEVEL DATA REFER TO FIGURE 2.4-36.
 7. STRATIGRAPHIC NOMENCLATURE OF THE QUATERNARY DEPOSITS USED IN THE PSAR TEXT DIFFERS FROM THAT USED ON THIS FIGURE AND ON THE BORING LOGS, AND IS CROSS REFERENCED ON FIGURE 2.5-274.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-275

GEOLOGIC SECTIONS A-A' AND B-B' -
STATION SITE




LEGEND

QUATERNARY	WISCONSINAN	LOESS - BROWN TO MOTTLED BROWN AND GRAY CLAYEY SILT OR SILTY CLAY WITH TRACE OF FINE SAND; WEATHERED
	WISCONSINAN	WISCONSINAN GLACIAL TILL - BROWNISH-GRAY TO GRAY CLAYEY SILT OR SILTY CLAY WITH SAND AND GRAVEL; CONTAINS (IRREGULAR AND DISCONTINUOUS LENSES OF SAND AND SILT THROUGHOUT (GLACIAL OUTFASH AND POSSIBLY LOCAL LACUSTRINE DEPOSITS)
	INTERGLACIAL	INTERGLACIAL ZONE - INCLUDES DARK GRAY TO GRAY ORGANIC CLAYEY SILT OR SILTY CLAY (COLLUVIAL SOILS); GREENISH TO BLuish-GRAY CLAYEY SILT WITH SAND AND GRAVEL (REWORKED AND WEATHERED ILLINOIAN GLACIAL TILL)
	ILLINOIAN	ILLINOIAN GLACIAL TILL - BROWNISH-GRAY TO GRAY CLAYEY SILT WITH SAND AND GRAVEL TO VERY SANDY SILT OR SILTY SAND WITH SOME CLAY AND GRAVEL; INTERBEDDED OUTFASH DEPOSITS IN UPPER HORIZONS.
QUATERNARY	YARMOUTHIAN	LACUSTRINE DEPOSIT - BROWNISH-GRAY TO BLACK AND GRAY CLAYEY SILT TO SILT, ORGANIC IN ZONES; INCLUDES GREENISH TO BLuish-GRAY CLAYEY SILT WITH SAND AND GRAVEL (REWORKED AND WEATHERED PRE-ILLINOIAN GLACIAL TILL); ASSIGNMENT TO YARMOUTHIAN GLACIAL STAGE IS TENTATIVE
	PRE-ILLINOIAN	PRE-ILLINOIAN GLACIAL TILL - GRAYISH-BROWN TO BROWN SILTY CLAY AND CLAYEY SILT WITH SOME SAND AND GRAVEL; BROWN COLOR AND RELATIVELY HIGH CLAY CONTENT IS CHARACTERISTIC; TENTATIVELY ASSIGNED TO KANSAN GLACIAL STAGE ON THE BASIS OF CLAY ANALYSIS BY ILLINOIS STATE GEOLOGICAL SURVEY
KANSAN	PRE-ILLINOIAN	PRE-ILLINOIAN ALLUVIAL AND LACUSTRINE DEPOSIT - CONSISTS OF GRAYISH-BROWN, BROWN AND GREEN CLAYEY SILT AND SILTY CLAY WITH SAND AND SOME GRAVEL (REWORKED GLACIAL TILL) AND GRAY TO BROWN CLAYEY SILT WITH ORGANIC DEBRIS (LACUSTRINE OR LOW ENERGY ALLUVIAL DEPOSIT); INCLUDED AS PART OF THE HANCOCK BEDROCK DEPOSIT IN AREAS WHERE IT IS UNDERLAIN BY SANDY OUTFASH DEPOSITS
PENNSYLVANIAN	BEDROCK	BEDROCK - INTERBEDDED LAYERS OF LIMESTONE, SHALE AND SILTSTONE ASSIGNED TO THE MCLAUSSON GROUP; IDENTIFICATION ON THE BASIS OF SPORE ANALYSIS OF THE COAL ENCOUNTERED IN BORING D-31
	LIMESTONE	LIMESTONE - GREENISH-GRAY, GRAY AND BROWN, FINE TO COARSELY CRYSTALLINE, SILTY, THIN BEDDED TO MASSIVE, NUMEROUS SHALE PARTINGS IN ZONES, FOSSILIFEROUS
	SHALE	SHALE - GRAY TO DARK GRAY SHALE, CARBORACEOUS TO CALCAREOUS; CLAYEY IN ZONES, EXPANSIVE, SLICKENSIDES; OCCASIONAL CONCRETION
	SILTSTONE	SILTSTONE - LIGHT GRAY SILTSTONE, MICACEOUS, FINE SANDY; CROSS-BEDDED IN ZONES; OCCASIONAL INTERBEDDED LAYER OF SILTY SANDSTONE

NOTES:


- GROUNDWATER LEVELS INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS WITH PIEZOMETERS. INFORMATION ON ACTUAL GROUNDWATER LEVELS EXIST ONLY AT BORING LOCATIONS WITH PIEZOMETERS. IT IS POSSIBLE THAT GROUNDWATER LEVELS BETWEEN BORINGS WITH PIEZOMETERS MAY VARY FROM THOSE INDICATED.
- THE DEPTH AND THICKNESS OF SOIL AND ROCK STRATA INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS. INFORMATION ON ACTUAL SOIL AND ROCK CONDITIONS EXIST ONLY AT BORING LOCATIONS. IT IS POSSIBLE THAT SOIL AND ROCK CONDITIONS MAY VARY FROM THOSE INDICATED.
- THE DISCUSSION IN THE TEXT IS NECESSARY FOR PROPER UNDERSTANDING OF THE NATURE OF THE SUBSURFACE MATERIALS.
- ELEVATIONS REFER TO U.S.G.S. DATUM.
- REFER TO FIGURE 2.5-271 FOR LOCATION OF SUBSURFACE PROFILES.
- FOR DETAILED WATER LEVEL DATA REFER TO FIGURE 2.4-36.
- STRATIGRAPHIC NOMENCLATURE OF THE QUATERNARY DEPOSITS USED IN THE FSAR TEXT DIFFERS FROM THAT USED ON THIS FIGURE AND ON THE BORING LOGS, AND IS CROSS REFERENCED ON FIGURE 2.5-274.




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-276

GEOLOGIC SECTION C-C' - STATION SITE




LEGEND



NOTES:



- GROUNDWATER LEVELS INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS WITH PIEZOMETERS. INFORMATION ON ACTUAL GROUNDWATER LEVELS EXIST ONLY AT BORING LOCATIONS WITH PIEZOMETERS. IT IS POSSIBLE THAT GROUNDWATER LEVELS BETWEEN BORINGS WITH PIEZOMETERS MAY VARY FROM THOSE INDICATED.
- THE DEPTH AND THICKNESS OF SOIL AND ROCK STRATA INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS. INFORMATION ON ACTUAL SOIL AND ROCK CONDITIONS EXIST ONLY AT BORING LOCATIONS. IT IS POSSIBLE THAT SOIL AND ROCK CONDITIONS MAY VARY FROM THOSE INDICATED.
- THE DISCUSSION IN THE TEXT IS NECESSARY FOR PROPER UNDERSTANDING OF THE NATURE OF THE SUBSURFACE MATERIALS.
- ELEVATIONS REFER TO U.S.G.S. DATUM.
- REFER TO FIGURE 2.5-272 FOR LOCATION OF SUBSURFACE PROFILES.
- FOR DETAILED WATER LEVEL DATA REFER TO FIGURES 2.4-37 AND 2.4-41.
- STRATIGRAPHIC NOMENCLATURE OF THE QUATERNARY DEPOSITS USED IN THE PSAR TEXT DIFFERS FROM THAT USED ON THIS FIGURE AND ON THE BORING LOGS, AND IS CROSS REFERENCED ON FIGURE 2.5-274.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-277

GEOLOGIC SECTION D-D' - DAM SITE




- NOTES:**
1. GROUNDWATER LEVELS INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS WITH PIEZOMETERS. INFORMATION ON ACTUAL GROUNDWATER LEVELS EXIST ONLY AT BORING LOCATIONS WITH PIEZOMETERS. IT IS POSSIBLE THAT GROUNDWATER LEVELS BETWEEN BORINGS WITH PIEZOMETERS MAY VARY FROM THOSE INDICATED.
 2. THE DEPTH AND THICKNESS OF SOIL AND ROCK STRATA INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS. INFORMATION ON ACTUAL SOIL AND ROCK CONDITIONS EXIST ONLY AT BORING LOCATIONS. IT IS POSSIBLE THAT SOIL AND ROCK CONDITIONS MAY VARY FROM THOSE INDICATED.
 3. THE DISCUSSION IN THE TEXT IS NECESSARY FOR PROPER UNDERSTANDING OF THE NATURE OF THE SUBSURFACE MATERIALS.
 4. ELEVATIONS REFER TO U.S.C.S. DATUM.
 5. REFER TO FIGURE 2.5-273 FOR LOCATION OF SUBSURFACE PROFILES.
 6. FOR DETAILED WATER LEVEL DATA REFER TO FIGURES 2.4-37, 2.4-38, 2.4-41 AND 2.4-42.
 7. STRATIGRAPHIC NOMENCLATURE OF THE QUATERNARY DEPOSITS USED IN THE FSAR TEXT DIFFERS FROM THAT USED ON THIS FIGURE AND ON THE BORING LOGS, AND IS CROSS REFERENCED ON FIGURE 2.5-274.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-278



**GEOLOGIC SECTION E-E' - ALONG NORTH
FORK OF SALT CREEK**



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-279

GEOLOGIC SECTION F-F' - SITE VICINITY



LEGEND


QUATERNARY	SALT CREEK ALLUVIUM - SHOWS TO GRAY SALTY CLAY, CLAYED SAND AND FINE TO COARSE SAND, SILTY TO GRAVELLY IN BORES; UNDERLAIN BY ORGANIC MUCKS.
ILLINOIAN	LOESS - BROWN TO MOTTLED BROWN AND GRAY CLAYEY SILT OR SILTY CLAY WITH TRACE OF FINE SAND; WEATHERED.
ILLINOIAN	WISCONSINAN GLACIAL TILL - BROWNISH-GRAY TO BROWN CLAYEY SILT OR SILTY CLAY WITH SAND AND GRAVEL; CONTAINS FRAGMENTS AND INDENTATIONS; LENSES OF SAND AND SILT THROUGHOUT; LOCAL LACUSTRINE DEPOSITS.
ILLINOIAN	INTERGLACIAL ZONE - INCLUDES BROWN SAND TO GRAY ORGANIC CLAYEY SILT OR SILTY CLAY (COLLUVIAL SOILS); GRADUALLY TO BROWN-GRAY CLAYEY SILT WITH SAND AND GRAVEL (WEATHERED AND UNWEATHERED ILLINOIAN GLACIAL TILL).
ILLINOIAN	ILLINOIAN GLACIAL TILL - BROWNISH-GRAY TO GRAY CLAYEY SILT WITH SAND AND GRAVEL; TO VERY SANDY SILT OR SILTY SAND WITH SOME CLAY AND GRAVEL; INTERGLACIAL OUTWASH DEPOSITS IN UPPER MEMBER.
ILLINOIAN	LACUSTRINE DEPOSIT - BROWNISH-GRAY TO BLACK GRAY CLAYEY SILT TO SILTY CLAY; ORGANIC IN SOME; INCLUDES SANDS TO BROWN-GRAY CLAYEY SILT WITH SAND AND GRAVEL (FRAGMENTS AND INDENTATIONS); ILLINOIAN GLACIAL TILL; ASSIGNMENT TO VANCOUVERIAN GLACIAL STAGE IS TENTATIVE.
ILLINOIAN	PRE-ILLINOIAN GLACIAL TILL - BROWNISH-GRAY TO BROWN SILTY CLAY AND CLAYEY SILT WITH SOME SAND AND GRAVEL; BROWN GRAY TO RELATIVELY HIGH CLAY CONTENT (IS CHARACTERISTIC); INDISTINCTLY RESOLVED TO ILLINOIAN GLACIAL STAGE ON THE BASIS OF CLAY ANALYSIS BY NATIONAL STATE GEOLOGICAL SURVEY.
ILLINOIAN	PRE-ILLINOIAN ALLUVIAL AND LACUSTRINE DEPOSIT - CONSISTS OF GRAYISH-BROWN SAND AND GRAY CLAYEY SILT AND SILTY CLAY WITH SAND AND SOFT GRAY TO BROWN CLAYEY SILT AND GRAY TO BROWN CLAYEY SILT WITH ORGANIC DEBRIS (EXPOSURE ON LOW SANDS ALONG RIVER); INCLUDED AS PART OF THE QUATERNARY DEPOSIT ON BASIS THAT IT IS UNDERLAIN BY SANDY OUTWASH DEPOSITS.
ILLINOIAN	BEDROCK VALLEY OUTWASH DEPOSIT - GRAY FINE TO MEDIUM SAND WITH SOME COARSE SAND AND OCCASIONAL GRAVEL; IN SOME, CLAYEY SANDY VALLEY DEPOSIT.
ILLINOIAN	BEDROCK - INTERBEDDED LAYERS OF Limestones, shales and siltstones assigned to the ILLINOIAN GROUP; SUBJECT TO FURTHER REVISION ON THE BASIS OF SPORE ANALYSIS OF THE COAL ENCOUNTERED IN BORING D-9.

- NOTES:**
- GROUNDWATER LEVELS INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS WITH PIEZOMETERS. INFORMATION ON ACTUAL GROUNDWATER LEVELS EXIST ONLY AT BORING LOCATIONS WITH PIEZOMETERS. IT IS POSSIBLE THAT GROUNDWATER LEVELS BETWEEN BORINGS WITH PIEZOMETERS MAY VARY FROM THOSE INDICATED.
 - THE DEPTH AND THICKNESS OF SOIL AND ROCK STRATA INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS. INFORMATION ON ACTUAL SOIL AND ROCK CONDITIONS EXIST ONLY AT BORING LOCATIONS. IT IS POSSIBLE THAT SOIL AND ROCK CONDITIONS MAY VARY FROM THOSE INDICATED.
 - THE DISCUSSION IN THE TEXT IS NECESSARY FOR PROPER UNDERSTANDING OF THE NATURE OF THE SUBSURFACE MATERIALS.
 - ELEVATIONS REFER TO U.S.G.S. DATUM.
 - REFER TO FIGURE 2.5-14 FOR LOCATION OF SUBSURFACE PROFILES.
 - FOR DETAILED WATER LEVEL DATA REFER TO FIGURES 2.4-37, 2.4-38, 2.4-41, 2.4-42 AND 2.4-43.
 - STRATIGRAPHIC NOMENCLATURE OF THE QUATERNARY DEPOSITS USED IN THE FSAR TEXT DIFFERS FROM THAT USED ON THIS FIGURE AND ON THE BORING LOGS, AND IS CROSS REFERENCED ON FIGURE 2.5-274.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-280

GEOLOGIC SECTION G-G' - SITE VICINITY





- KEY:**
- 1) WAPELLA DOME
 - 2) DELAND DOME
 - 3) PARNELL DOME
 - 500' --- CONTOURS ON BEDROCK SURFACE
 - APPROXIMATE POSITION OF MAHOMET VALLEY FILL DEPOSITS

NOTE:
 MODIFIED FROM: GEOLOGICAL SIGNIFICANCE OF THE GRAVITY FIELDS IN THE DEWITT - MCLEAN COUNTY AREA, ILLINOIS BY P.C. HETGOLD, L.D. MCGINNIS AND R.H. HOWARD: ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 369, 1964.




**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-281

RELIEF OF BEDROCK SURFACE



LEGEND:

-  BORING LOCATION
-  ELEVATION OF TOP OF BEDROCK
-  CONTOUR ON TOP OF BEDROCK SURFACE
- CONTOUR INTERVAL 10 FEET


NOTES:

1. ENLARGED VIEW OF BORINGS IN PLANT AREA FROM FIGURE 2.5-17.
2. BEDROCK CONTOURS ARE BASED ON GEOLOGICAL SIGNIFICANCE OF THE GRAVITY FIELDS IN THE DEWITT-MCLEAN COUNTY AREA, ILLINOIS BY P. C. MEIGOLD, L. D. MCGINNIS AND R. H. HOWARD; ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 369, 1964, WITH MODIFICATION FROM BOREHOLE DATA.

**CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT**

FIGURE 2.5-282

CONTOURS OF BEDROCK SURFACE
STATION SITE




REFERENCES:

KEMPTON, J.P., 1981, ILL. STATE GEOL. SURVEY ENVIRONMENTAL GEOLOGY NOTE 100.

CLEGG, K.E., 1972, ILL. STATE GEOL. SURVEY CIRCULAR 473

HEIGOLD, P.C. ET AL. 1964, ILL. STATE GEOL. SURVEY CIRCULAR 369





BRISTOL, H.M. & BUSCHBACH, T.C., 1973, ILL. STATE GEOL. SURVEY, ILL. PETROLEUM 99.



VERTICAL EXAGGERATION 100.0X

NOTE: SEE FIGURE 2.5-285 FOR LOCATION OF THE CROSS SECTION

<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>FIGURE 2.5-283</p>
<p>WAPELLA EAST, PARNELL AND DELAND DOMES, CROSS SECTION M-M'</p>




- NOTES:**
- GROUNDWATER LEVELS INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS WITH OBSERVED WATER LEVELS.
 - THE DEPTH AND THICKNESS OF SOIL AND ROCK STRATA INDICATED ON THE SUBSURFACE SECTION WERE OBTAINED BY INTERPOLATING BETWEEN BORINGS. INFORMATION ON ACTUAL SOIL AND ROCK CONDITIONS EXIST ONLY AT BORING LOCATIONS. IT IS POSSIBLE THAT SOIL AND ROCK CONDITIONS MAY VARY FROM THOSE INDICATED.
 - THE DISCUSSION IN THE TEXT IS NECESSARY FOR PROPER UNDERSTANDING OF THE NATURE OF THE SUBSURFACE MATERIALS.
 - ELEVATIONS REFER TO U.S.G.S. DATUM.
 - REFER TO FIGURE 2.5-16 FOR LOCATION OF SUBSURFACE PROFILES.
 - FOR DETAILED WATER LEVEL DATA REFER TO FIGURES 2.5-162 THROUGH 2.5-203.
 - STRATIGRAPHIC NOMENCLATURE OF THE QUATERNARY DEPOSITS USED IN THE PSAR TEXT DIFFERS FROM THAT USED ON THIS FIGURE AND ON THE BORING LOGS, AND IS CROSS REFERENCED ON FIGURE 2.5-274.

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-284

ULTIMATE HEAT SINK GEOLOGIC
 SECTIONS J-J' AND K-K'



- LEGEND:
- DIAMOND-DRILL HOLE
 - 3/3 3 ELEVATION TOP OF NO. 7 COAL
 - ▷ DRILL HOLE WITH ELECTRICAL LOG
 - ◊ CHURN-DRILL HOLE, WATER WELL, ETC.
 - ◊ LOCATION APPROXIMATE (WITHIN 1300 FEET)
 - ✦ ABANDONED COAL MINE SHAFT
 - ✦ DAMES & MOORE DIAMOND-DRILL HOLE
 - 200 — CONTOUR ON TOP OF NO. 7 COAL SURFACE
 - CONTOUR INTERVAL 20 FEET
 - APPROXIMATE AXIS OF DOWNS ANTICLINE
 - - - - - BOUNDARY OF COAL
 - - - - - BOUNDARY OF PENNSYLVANIAN




- NOTE:
1. MODIFIED FROM: SUBSURFACE GEOLOGY AND COAL RESOURCES OF THE PENNSYLVANIAN SYSTEM IN DEWITT, MCLEAN, AND PIATT COUNTIES, ILLINOIS; BY K.E. CLEGG, ILLINOIS STATE GEOLOGICAL SURVEY CIRCULAR 473, PLATE 1, 1972.
 2. SEE FIGURE 2.5-286 CROSS SECTION L-L'
SEE FIGURE 2.5-283 FOR CROSS SECTION M-M'

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-285

STRUCTURAL CONTOUR MAP OF THE TOP OF
THE NUMBER 7 COAL MEMBER



REFERENCES: CROSS SECTION L-L'

KEMPTON, J.P., 1981, ILL. STATE GEOL. SURVEY ENVIRONMENTAL GEOLOGY NOTE 100.

CLEGG, K.E., 1972, ILL. STATE GEOL. SURVEY CIRCULAR 473.


HEIGOLD, P.C. ET AL. 1964, ILL. STATE GEOL. SURVEY CIRCULAR 369

BRISTOL, H.M. & BUSCHBACH, T.C., 1973, ILL. STATE GEOL. SURVEY, ILL. PETROLEUM 99.



NOTE: SEE FIGURE 2.5-285 FOR LOCATION OF THE CROSS SECTION

<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>FIGURE 2.5-286</p>
<p>DOWN'S ANTICLINE - CROSS SECTION L-L'</p>




LEGEND

- Gas Storage Project
- ▨ Oil field

NOTES


1. Adapted from W. F. Meents, Oil and Gas Industry in Illinois, 1977, Illinois State Geological Survey, Urbana, 1977.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-287

LOCATION OF GAS STORAGE PROJECTS AND
OIL FIELDS IN THE SITE VICINITY



LEGEND

- LOCATION OF MAXIMUM INTENSITY
- INTENSITY NOT RECORDED
 - IV OR LESS
 - ⊙ IV-V TO V
 - ⊕ V-VI TO VI
 - VI-VII TO VII
 - ⊙ VII-VIII TO VIII

SEE TABLE 2.5.4 FOR COMPLETE LISTING

NOTES


1. BASIS FOR SEISMOTECTONIC BOUNDARIES DISCUSSED IN TEXT.
2. ONLY THE LARGEST EVENT IS PRESENTED ON MAP.
3. EARTHQUAKES LISTED IN TABLE 2.5.4 NOS. IN PARENTHESES INDICATE NO. OF EVENTS AT ONE LOCATION.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-288

EARTHQUAKE EPICENTERS AND RELATIONSHIP
TO SEISMOTECTONIC REGIONS




EXPLANATION
 ● LOCATION OF INTENSITY DATA POINT

Scale of Miles
 0 50 100 150

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-289
 ISOSEISMAL MAP FOR THE NORTHERN ILLINOIS EARTHQUAKE OF MAY 26, 1909

REFERENCE:
 DOCEKAL, J., 1970, EARTHQUAKES OF THE STABLE INTERIOR, UNPUBLISHED PH.D. DISSERTATION, UNIVERSITY OF NEBRASKA




EXPLANATION
 ● LOCATION OF INTENSITY DATA POINT

Scale of Miles
 0 50 100 150

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT
 FIGURE 2.5-290
 ISOSEISMAL MAP FOR THE WESTERN ILLINOIS EARTHQUAKE OF JULY 18, 1909

REFERENCE:
 DOCEKAL, J., 1970, EARTHQUAKES OF THE STABLE INTERIOR, UNPUBLISHED PH.D. DISSERTATION, UNIVERSITY OF NEBRASKA





EXPLANATION
 ● LOCATION OF INTENSITY DATA POINT

Scale of Miles
 0 50 100 150

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-291
 ISOSEISMAL MAP FOR THE WABASH VALLEY
 EARTHQUAKE OF SEPTEMBER 27, 1909

REFERENCE:
 DOCEKAL, J., 1970, EARTHQUAKES OF THE STABLE INTERIOR, UNPUBLISHED PH.D. DISSERTATION, UNIVERSITY OF NEBRASKA



NOTE:
 INTENSITIES REFER TO THE 1951 MODIFIED MERCALLI
 SCALE (SEE TABLE 2.5-61)


REFERENCE:
 COMPILED FROM:

GORDON AND OTHERS, 1970, THE SOUTH-CENTRAL ILLINOIS
 EARTHQUAKE OF NOVEMBER 9, 1968; MACROSEISMIC STUDIES,
 BULLETIN SEISMOLOGICAL SOCIETY OF AMERICA, VOL. 60,
 NO. 3, PP. 953-971.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-292

ISOSEISMAL MAP OF NOVEMBER 9, 1968
 SOUTHERN ILLINOIS EARTHQUAKE



NOTES:

1. INTENSITIES REFER TO THE 1931 MODIFIED MERCALLI SCALE.
2. ISOSEISMAL LINES INDICATE THE APPROXIMATE OUTER BOUNDARY OF THE REGION OF SPECIFIED INTENSITY.


REFERENCE:

NUTTLI, O.W. 1973, THE MISSISSIPPI VALLEY EARTHQUAKE OF 1811 AND 1812, INTENSITIES, GROUND MOTION, AND MAGNITUDES; SEISMOLOGICAL SOCIETY OF AMERICA, BULL. 63, NO. 1 P. 227-248.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-293


ISOSEISMAL MAP FOR NEW MADRID EARTHQUAKE OF DECEMBER 16, 1811



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-294


AREAS OF RELATIVELY HIGH SEISMICITY
 IN CENTRAL UNITED STATES



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-295
 COMPARISON OF EARTHQUAKE INTENSITY
 AND AVERAGE HORIZONTAL ACCELERATION


REFERENCE: TRIFUNAC, M.D., AND BRADY, A.E., 1975, ON THE CORRELATION OF SEISMIC INTENSITY SCALES WITH THE PEAKS OF RECORDED STRONG GROUND MOTION; SEISMOL. SOC. AMERICA BULL., VOL. 65, NO. 1, pp.139-162.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-296

HORIZONTAL SPECTRA FOR A MAXIMUM
 HORIZONTAL GROUND ACCELERATION OF 26%
 OF GRAVITY (SAFE SHUTDOWN EARTHQUAKE)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-297

HORIZONTAL SPECTRA FOR A MAXIMUM
 HORIZONTAL GROUND ACCELERATION OF 11%
 OF GRAVITY (OPERATING-BASIS EARTHQUAKE)

Triaxial Compression Test Unit



TRIAxIAL COMPRESSION TEST UNIT

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-299
Sheet 1 of 2
UNCONFINED COMPRESSION
AND TRIAXIAL COMPRESSION
TESTS (METHOD)

NOTES FOR FIGURE 2.5-299

Methods of Performing Unconfined Compression and Triaxial Compression Tests

The shearing strengths of soils are determined from the results of unconfined compression and triaxial compression tests. In triaxial compression tests the test method and the magnitude of the confining pressure are chosen to simulate anticipated field conditions.

Unconfined compression and triaxial compression tests are performed on undisturbed, or remolded samples of soil, approximately six inches in length and two and one-half inches in diameter. The tests are run either strain-controlled or stress-controlled. In a strain-controlled test the sample is subjected to a constant rate of deflection and the resulting stresses are recorded. In a stress-controlled test the sample is subjected to equal increments of load with each increment being maintained until an equilibrium condition with respect to strain is achieved.

Yield, peak, or ultimate stresses are determined from the stress-strain plot for each sample and the principal stresses are evaluated. The principal stresses are plotted on a Mohr's circle diagram to determine the shearing strength of the soil type being tested.

Unconfined compression tests can be performed only on samples with sufficient cohesion so that the soil will stand as an unsupported cylinder. These tests may be run at natural moisture content or on artificially saturated soils.

In a triaxial compression test the sample is encased in a rubber membrane, placed in a test chamber, and subjected to a confining pressure throughout the duration of the test. Normally, this confining pressure is maintained at a constant level, although for special tests it may be varied in relation to the measured stresses. Triaxial compression tests may be run on soils at field moisture content or on artificially saturated samples.

The tests are performed in one of the following ways:

Unconsolidated-undrained: The confining pressure is imposed on the sample at the start of the test. No drainage is permitted and the stresses which are measured represent the sum of the intergranular stresses and pore water pressures.

Consolidated-undrained: The sample is allowed to consolidate fully under the applied confining pressure prior to the start of the test. The volume change is determined by measuring the water and/or air expelled during consolidation. No drainage is permitted during the test and the stresses which are measured are the same as for the unconsolidated-undrained test.


Drained: The intergranular stresses in a sample may be measured by performing a drained, or slow, test. In this test, the sample is fully saturated and consolidated prior to the start of the test. During the test, drainage is permitted and the test is performed at a slow enough rate to prevent the buildup of pore water pressures. The resulting stresses which are measured represent only the intergranular stresses. These tests are usually performed on samples of generally non-cohesive soils, although the test procedure is applicable to cohesive soils if a sufficiently slow test rate is used.

An alternate means of obtaining the data resulting from the drained test is to perform an undrained test in which special equipment is used to measure the pore water pressures. The differences between the total stresses and the pore water pressures measured are the intergranular stresses.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-299
Sheet 2 of 2

UNCONFINED COMPRESSION
AND TRIAXIAL COMPRESSION
TESTS (METHOD)



**DIRECT SHEAR TESTING
& RECORDING APPARATUS**

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-300
Sheet 1 of 2

DIRECT SHEAR AND FRICTION
TESTS (METHOD)

NOTES FOR FIGURE 2.5-300

Method of Performing Direct Shear and Friction Tests

Direct shear tests are performed to determine the shearing strengths of soils. Friction tests are performed to determine the frictional resistances between soils and various other materials such as wood, steel, or concrete. The tests are performed in the laboratory to simulate anticipated field conditions.

Each sample is tested within three brass rings, two and one-half inches in diameter and one inch in length. Undisturbed samples of in-place soils are tested in rings taken from the sampling device in which the samples were obtained. Loose samples of soils to be used in constructing earth fills are compacted in rings to predetermined conditions and tested.

Direct Shear Tests

A three-inch length of the sample is tested in direct double shear. A constant pressure, appropriate to the conditions of the problem for which the test is being performed, is applied normal to the ends of the sample through porous stones. A shearing failure of the sample is caused by moving the center ring in a direction perpendicular to the axis of the sample. Transverse movement of the outer rings is prevented.


The shearing failure may be accomplished by applying to the center ring either a constant rate of load, a constant rate of deflection, or increments of load or deflection. In each case, the shearing load and the deflections in both the axial and transverse directions are recorded and plotted. The shearing strength of the soil is determined from the resulting load-deflection curves.

Friction Tests

In order to determine the frictional resistance between soil and the surfaces of various materials, the center ring of soil in the direct shear test is replaced by a disk of the material to be tested. The test is then performed in the same manner as the direct shear test by forcing the disk of material from the soil surfaces.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-300
Sheet 2 of 2
DIRECT SHEAR AND FRICTION
TESTS (METHOD)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-301
Sheet 1 of 2

PULSATING LOAD TRIAXIAL
TEST (METHOD)

NOTES FOR FIGURE 2.5-301

Methods of Performing Pulsating Load Triaxial Tests

Pulsating axial load tests are performed to evaluate the dynamic properties and the liquefaction potential of the soils under simulated anticipated field loading conditions.

Pulsating load tests are stress controlled and are performed on undisturbed or reconstituted samples of soil approximately six inches in length and two and one-half inches in diameter. The samples are encased in a rubber membrane, placed in a test chamber, and subjected to confining pressure throughout the duration of the test. The tests may be run on soils at field moisture content or on artificially saturated samples. The triaxial equipment acting through a Bellofram system applies a pulsating axial load. The cycling speed of the load can be varied between one-half to five cycles per second to simulate the field loading frequency.

Dynamic Properties Determination

To evaluate the dynamic parameters, the soil sample is loaded in cyclic compression. The load and deflection are recorded on two channels of a recording oscillograph. By tapping the output of the load and deflection transducers and applying these to vertical and horizontal plates, respectively, of a cathode ray oscilloscope, a hysteresis loop is produced. This loop is photographed, and the photograph is used to evaluate the damping value present. The procedure is repeated at various strain amplitudes to evaluate the dynamic properties in the range of interest on a particular sample. The load and deflection values obtained from the oscillograph are used to evaluate the dynamic moduli of elasticity.

Liquefaction Potential

To evaluate the liquefaction potential, the soil sample is subjected to axial cyclic loading, the magnitude, frequency, duration and sequence of loading is determined on the basis of past earthquake records. The load deflection, and pore pressure are recorded on three channels of a recording oscillograph. These records are used to evaluate the liquefaction potential for that particular soil type under the test conditions.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-301
Sheet 2 of 2


PULSATING LOAD TRIAXIAL
TEST (METHOD)

STRUCTURAL FILL BORROW

COMBINED BULK SAMPLE:

- G-18 (ELEV. 663-654)
- G-19 (ELEV. 673-663)
- G-20 (ELEV. 657-647)

FOR 80% RELATIVE DENSITY (123 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-302


DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW

COMBINED BULK SAMPLE:

- G-18 (ELEV. 663-654)
- G-19 (ELEV. 673-663)
- G-20 (ELEV. 657-647)

FOR 80% RELATIVE DENSITY (123 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-303


DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW

COMBINED BULK SAMPLE:

- G-18 (ELEV. 663-654)
- G-19 (ELEV. 673-663)
- G-20 (ELEV. 657-647)

FOR 80% RELATIVE DENSITY (123 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-304


DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW

COMBINED BULK SAMPLE:

- G-18 (ELEV. 663-654)
- G-19 (ELEV. 673-663)
- G-20 (ELEV. 657-647)

FOR 80% RELATIVE DENSITY (123 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-305


DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW

COMBINED BULK SAMPLE:

- G-18 (ELEV. 663-654)
- G-19 (ELEV. 673-663)
- G-20 (ELEV. 657-647)

FOR 80% RELATIVE DENSITY (123 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-306

DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW
COMBINED BORROW SAMPLE:

G-18 (ELEV. 663-654)
G-19 (ELEV. 673-663)
G-20 (ELEV. 657-647)

FOR 90% RELATIVE DENSITY (129 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-307

DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW


COMBINED BORROW SAMPLE:

G-18 (ELEV. 663-654)

G-19 (ELEV. 673-663)

G-20 (ELEV. 657-647)

FOR 90% RELATIVE DENSITY (129 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-308

DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW


COMBINED BORROW SAMPLE:

G-18 (ELEV. 663-654)

G-19 (ELEV. 673-663)

G-20 (ELEV. 657-647)

FOR 90% RELATIVE DENSITY (129 PCF), AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-309

DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW


COMBINED BORROW SAMPLE:

G-18 (ELEV. 663-654)

G-19 (ELEV. 673-663)

G-20 (ELEV. 657-647)

FOR 90% RELATIVE DENSITY (129 PCF),
AT THE 10TH CYCLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-310


DYNAMIC TRIAXIAL COMPRESSION TESTS

STRUCTURAL FILL BORROW

COMBINED BORROW SAMPLE:

- G-18 (ELEV. 663-654)
- G-19 (ELEV. 673-663)
- G-20 (ELEV. 657-647)

FOR 90% RELATIVE DENSITY (129 PCF), AT THE 10TH CYCLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-311

DYNAMIC TRIAXIAL COMPRESSION TESTS

BORING H-6 @ ELEVATION 619.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 8.6%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-312

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-6)

(SHEET 1 of 4)

BORING H-6 @ ELEVATION 619.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 8.6%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-312

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-6)

(SHEET 2 of 4)


BORING H-6 @ ELEVATION 619.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 8.6%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-312
DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-6)
(SHEET 3 of 4)

BORING H-6 @ ELEVATION 619.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 8.6%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-312

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-6)

(SHEET 4 of 4)

BORING H-14 @ ELEVATION 635.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.5%
FIELD DRY DENSITY: 140 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-313

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-14)

(SHEET 1 of 4)

BORING H-14 @ ELEVATION 635.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.5%
FIELD DRY DENSITY: 140 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-313

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-14)

(SHEET 2 of 4)

BORING H-14 @ ELEVATION 635.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.5%
FIELD DRY DENSITY: 140 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-313

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-14)

(SHEET 3 of 4)

BORING H-14 @ ELEVATION 635.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.5%
FIELD DRY DENSITY: 140 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-313

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-14)

(SHEET 4 of 4)

BORING H-20 @ ELEVATION 706.8 FEET
GRAY FINE SANDY SILT WITH SOME CLAY
AND MEDIUM TO COARSE SAND AND GRAVEL
(WISCONSINAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 8.6%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 1 of 12)

BORING H-20 @ ELEVATION 706.8 FEET
 GRAY FINE SANDY SILT WITH SOME CLAY
 AND MEDIUM TO COARSE SAND AND GRAVEL
 (WISCONSINAN GLACIAL TILL)
 FIELD MOISTURE CONTENT: 8.6%
 FIELD DRY DENSITY: 136 LBS./CU.FT.
 TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
 (BORING H-20)

(SHEET 2 of 12)


BORING H-20 @ ELEVATION 706.8 FEET
 GRAY FINE SANDY SILT WITH SOME CLAY
 AND MEDIUM TO COARSE SAND AND GRAVEL
 (WISCONSINAN GLACIAL TILL)
 FIELD MOISTURE CONTENT: 8.6%
 FIELD DRY DENSITY: 136 LBS./CU.FT.
 TEST DATA OBTAINED FROM PITCHER SAMPLE



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314
 DYNAMIC TRIAXIAL COMPRESSION TESTS
 (BORING H-20)
 (SHEET 3 of 12)

BORING H-20 @ ELEVATION 706.8 FEET
 GRAY FINE SANDY SILT WITH SOME CLAY
 AND MEDIUM TO COARSE SAND AND GRAVEL
 (WISCONSINAN GLACIAL TILL)
 FIELD MOISTURE CONTENT: 8.6%
 FIELD DRY DENSITY: 136 LBS./CU.FT.
 TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
 (BORING H-20)

(SHEET 4 of 12)

BORING H-20 @ ELEVATION 686.8 FEET
DARK GRAY CLAYEY SILT WITH TRACES
OF FINE SAND
(INTERGLACIAL SOIL)
FIELD MOISTURE CONTENT:
FIELD DRY DENSITY:
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 5 of 12)

BORING H-20 @ ELEVATION 686.8 FEET
DARK GRAY CLAYEY SILT WITH TRACES
OF FINE SAND
(INTERGLACIAL SOIL)
FIELD MOISTURE CONTENT:
FIELD DRY DENSITY:
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 6 of 12)

BORING H-20 @ ELEVATION 686.8 FEET
DARK GRAY CLAYEY SILT WITH TRACES
OF FINE SAND
(INTERGLACIAL SOIL)
FIELD MOISTURE CONTENT:
FIELD DRY DENSITY:
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 7 of 12)

BORING H-20 @ ELEVATION 686.8 FEET
DARK GRAY CLAYEY SILT WITH TRACES
OF FINE SAND
(INTERGLACIAL SOIL)
FIELD MOISTURE CONTENT:
FIELD DRY DENSITY:
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 8 of 12)

BORING H-20 @ ELEVATION 672.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 10.5%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 9 of 12)

BORING H-20 @ ELEVATION 672.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 10.5%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 10 of 12)

BORING H-20 @ ELEVATION 672.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 10.5%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)

(SHEET 11 of 12)

BORING H-20 @ ELEVATION 672.3 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 10.5%
FIELD DRY DENSITY: 136 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-314

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-20)


(SHEET 12 of 12)

BORING H-23 @ ELEVATION 677.8 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.1%
FIELD DRY DENSITY: 138 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-315
DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-23)
(SHEET 1 of 4)

BORING H-23 @ ELEVATION 677.8 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.1%
FIELD DRY DENSITY: 138 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-315

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-23)

(SHEET 2 of 4)

BORING H-23 @ ELEVATION 677.8 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.1%
FIELD DRY DENSITY: 138 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-315

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-23)

(SHEET 3 of 4)

BORING H-23 @ ELEVATION 677.8 FEET
GRAY FINE TO COARSE SANDY SILT WITH
SOME CLAY AND FINE GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.1%
FIELD DRY DENSITY: 138 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-315

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-23)

(SHEET 4 of 4)

BORING H-30 @ ELEVATION 638.5 FEET
DARK GRAY FINE TO COARSE SANDY SILT
WITH SOME GRAVEL AND TRACES OF CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 6.8%
FIELD DRY DENSITY: 145 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-316

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-30)


(SHEET 1 of 4)

BORING H-30 @ ELEVATION 638.5 FEET
DARK GRAY FINE TO COARSE SANDY SILT
WITH SOME GRAVEL AND TRACES OF CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 6.8%
FIELD DRY DENSITY: 145 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-316
DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-30)
(SHEET 2 of 4)

BORING H-30 @ ELEVATION 638.5 FEET
DARK GRAY FINE TO COARSE SANDY SILT
WITH SOME GRAVEL AND TRACES OF CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 6.8%
FIELD DRY DENSITY: 145 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-316

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-30)

(SHEET 3 of 4)

BORING H-30 @ ELEVATION 638.5 FEET
DARK GRAY FINE TO COARSE SANDY SILT
WITH SOME GRAVEL AND TRACES OF CLAY
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 6.8%
FIELD DRY DENSITY: 145 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-316

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-30)

(SHEET 4 of 4)

BORING H-36 @ ELEVATION 622.7 FEET
GRAY CLAYEY SILT WITH SOME FINE TO
COARSE SAND AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.4%
FIELD DRY DENSITY: 137 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-317

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-36)

(SHEET 1 of 4)

BORING H-36 @ ELEVATION 622.7 FEET
GRAY CLAYEY SILT WITH SOME FINE TO
COARSE SAND AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.4%
FIELD DRY DENSITY: 137 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-317

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-36)

(SHEET 2 of 4)

BORING H-36 @ ELEVATION 622.7 FEET
GRAY CLAYEY SILT WITH SOME FINE TO
COARSE SAND AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.4%
FIELD DRY DENSITY: 137 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-317

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-36)

(SHEET 3 of 4)

BORING H-36 @ ELEVATION 622.7 FEET
GRAY CLAYEY SILT WITH SOME FINE TO
COARSE SAND AND GRAVEL
(ILLINOIAN GLACIAL TILL)
FIELD MOISTURE CONTENT: 9.4%
FIELD DRY DENSITY: 137 LBS./CU.FT.
TEST DATA OBTAINED FROM PITCHER SAMPLE




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-317

DYNAMIC TRIAXIAL COMPRESSION TESTS
(BORING H-36)
(SHEET 4 of 4)

METHOD OF PERFORMING RESONANT COLUMN TESTS



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-318
Sheet 1 of 2

RESONANT COLUMN TESTS
(METHOD)

Method of Performing Resonant Column Tests

Resonant column tests are performed to determine the dynamic properties of soils under high frequency, small amplitude cyclic strains. The test is based on the fact that analytical solutions can relate the stiffness of the soil column to its resonant frequency. In the test the sample is excited by an oscillating device and the frequency is varied until the maximum response, or resonant frequency, is found.


The Dames and Moore resonant column apparatus subjects solid cylindrical samples to torsional oscillations. The sample base is fixed and the top of the sample is excited by a Hardin oscillator which is driven by a variable frequency sine wave generator. The response of the sample is measured by an accelerometer mounted in the oscillator and the output is displayed on an oscilloscope.

The equivalent linear shear modulus of the soil is obtained from the resonant frequency of the system after the manner suggested by Drnevich and Hardin ("Proposed Standard for Modulus and Damping of Soils by the Resonant Column Method", ASTM Committee D18.09, May 1974). The shear modulus of soils varies with the shear strain amplitude and thus actually varies along the radius of the sample but in calculating the shear modulus the average shear strain is taken to correspond to the cyclic shear strain developed two-thirds of the distance along the radius. The damping ratio at small strains may be computed from measurements of the logarithmic decrement which are obtained by subjecting the sample to a steady state oscillation and then shutting off the input voltage. The decay curve is retained on a recording oscilloscope and may be photographed to make a permanent record.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-318
Sheet 2 of 2

RESONANT COLUMN TESTS
(METHOD)



DEAD LOAD-PNEUMATIC
CONSOLIDOMETER

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-319
Sheet 1 of 2

CONSOLIDATION TESTS
(METHOD)

Method of Performing Consolidation Tests

Consolidation tests are performed to evaluate the volume changes of soils subjected to increased loads. Time-consolidation and pressure-consolidation curves may be plotted from the data obtained in the tests. Engineering analyses based on these curves permit estimates to be made of the probable magnitude and rate of settlement of the tested soils under applied loads.


Each sample is tested within brass rings two and one-half inches in diameter and one inch in length. Undisturbed samples of in-place soils are tested in rings taken from the sampling device in which the samples were obtained. Loose samples of soils to be used in constructing earth fills are compacted in rings to predetermined conditions and tested.

In testing, the sample is rigidly confined laterally by the brass ring. Axial loads are transmitted to the ends of the sample by porous disks. The disks allow drainage of the loaded sample. The axial compression or expansion of the sample is measured by a micrometer dial indicator at appropriate time intervals after each load increment is applied. Each load is ordinarily twice the preceding load. The increments are selected to obtain consolidation data representing the field loading conditions for which the test is being performed. Each load increment is allowed to act over an interval of time dependent on the type and extent of the soil in the field.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-319
Sheet 2 of 2



CONSOLIDATION TESTS
(METHOD)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-320


CONSOLIDATION TEST (BORING P-14)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-321


CONSOLIDATION TEST (BORING P-29)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-322


CONSOLIDATION TEST (BORING P-15)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-323


CONSOLIDATION TEST (BORING P-18)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-324


CONSOLIDATION TEST (BORING P-20)



**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-325

CONSOLIDATION TEST (BORING P-21)





**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-326
 CONSOLIDATION TEST (BORING P-22)
 (SHEET 1 of 2)





CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-326
 CONSOLIDATION TEST (BORING P-22)
 (SHEET 2 of 2)



**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-327
 CONSOLIDATION TEST (BORINGS P-22,
 P-26 AND P-27)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-328

CONSOLIDATION TEST (BORINGS P-27
 AND P-29)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-329

CONSOLIDATION TEST (BORING D-6)

(SHEET 1 of 2)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-329

CONSOLIDATION TEST (BORING D-6)


(SHEET 2 of 2)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-330

CONSOLIDATION TEST (BORING D-8)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-331
 CONSOLIDATION TEST (BORING D-18)
 (SHEET 1 of 2)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-331
 CONSOLIDATION TEST (BORING D-18)
 (SHEET 2 of 2)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-332
 CONSOLIDATION TEST (BORING S-5)
 (SHEET 1 of 2)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-332


CONSOLIDATION TEST (BORING S-5)

(SHEET 2 of 2)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-333
 CONSOLIDATION TEST (BORING P-29)
 (SHEET 1 of 3)



**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-333
 CONSOLIDATION TEST (BORING P-29)
 (SHEET 2 of 3)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-333

CONSOLIDATION TEST (BORING P-29)


(SHEET 3 of 3)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-334


CONSOLIDATION TEST (BORING D-40)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-335


CONSOLIDATION TEST (BORING D-41)



* A.A.S.H.O. TEST DESIGNATION T-180

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-336
 CONSOLIDATION TEST (BORING S-10)





* A.A.S.H.O. TEST DESIGNATION T-180

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-337



CONSOLIDATION TEST (BORING S-14)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-338



CONSOLIDATION TEST (BORINGS G-18,
 G-19 AND G-20)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-339

CONSOLIDATION TEST (BORING P-32)
 (SHEET 1 of 2)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-339



CONSOLIDATION TEST (BORING P-32)

(SHEET 2 of 2)





**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

**FIGURE 2.5-340
 CONSOLIDATION TEST (BORING P-33)**




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-341
 CONSOLIDATION TEST (BORING P-36)
 (SHEET 1 of 3)





**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-341
 CONSOLIDATION TEST (BORING P-36)
 (SHEET 2 of 3)





CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-341
 CONSOLIDATION TEST (BORING P-36)
 (SHEET 3 of 3)



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-342
 CONSOLIDATION TEST (BORING P-38)
 (SHEET 1 of 5)





CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-342


CONSOLIDATION TEST (BORING P-38)

(SHEET 2 of 5)




**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

**FIGURE 2.5-342
 CONSOLIDATION TEST (BORING P-38)
 (SHEET 3 of 5)**



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-342
CONSOLIDATION TEST (BORING P-38)
(SHEET 4 of 5)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-342


CONSOLIDATION TEST (BORING P-38)

(SHEET 5 of 5)





**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-343
 CONSOLIDATION TEST (BORING P-41)
 (SHEET 1 of 2)




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-343
 CONSOLIDATION TEST (BORING P-41)
 (SHEET 2 of 2)




**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-344
 CONSOLIDATION TEST (COMBINED BULK SAMPLE)
 (SHEET 1 of 3)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-344
 CONSOLIDATION TEST (COMBINED BULK SAMPLE)
 (SHEET 2 of 3)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-344
 CONSOLIDATION TEST (COMBINED BULK SAMPLE)
 (SHEET 3 of 3)




**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-345
 CONSOLIDATION TEST (BORING H-6)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-346
 CONSOLIDATION TEST (BORING H-32)
 (SHEET 1 of 2)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-346
 CONSOLIDATION TEST (BORING H-32)
 (SHEET 2 of 2)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-347
Sheet 1 of 2

PERCOLATION TEST (METHOD)

NOTES FOR FIGURE 2.5-347

Methods of Performing Percolation Tests

The quantity and the velocity of flow of water which will escape through an earth structure or percolate through soil are dependent upon the permeability of the earth structure or soil. The permeability of soil has often been calculated by empirical formulas but is best determined by laboratory tests, especially in the case of compacted soils.


A one inch length of the core sample is sealed in the percolation apparatus, placed under a confining load, or surcharge pressure, and subjected to the pressure of a known head of water. The percolation rate is computed from the measurements of the volume of water which flows through the sample in a series of time intervals. These rates are usually expressed as the velocity of flow in feet per year under a hydraulic gradient of one and at a temperature of 20 degrees Centigrade. The rate so expressed may be adjusted for any set of conditions involving the same soil by employing established physical laws. Generally, the percolation rate varies over a wide range at the beginning of the test and gradually approaches equilibrium as the test progresses.

During the performance of the test, continuous readings of the deflection of the sample are taken by means of micrometer dial gauges. The amount of compression or expansion, expressed as a percentage of the original length of the sample, is a valuable indication of the compression of the soil which will occur under the action of load or the expansion of the soil as saturation takes place.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-347
Sheet 2 of 2

PERCOLATION TEST (METHOD)




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-348

PARTICLE SIZE ANALYSIS - TYPE B
 MATERIAL - LIQUEFACTION SAMPLE

$$\text{STRESS RATIO, } R = \frac{\Delta\sigma_v}{2\bar{\sigma}_c}$$




- ⊙ Initial Liquefaction
- △ 5% Double Amplitude Strain

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-349

LIQUEFACTION TESTS OF TYPE B MATERIAL




NOTES

1. Moisture density relationships based on modified Proctor test ASTM D1557.
2. Data based on field laboratory testing of type A & C material used as backfill around the screenhouse and main plant.
3. H-306, H-333, H-309, H-347 and H-365 denote field sample number.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-350

TYPICAL MOISTURE-DENSITY
RELATIONSHIPS - SCREEN HOUSE AND
MAIN PLANT AREAS





CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-351
PARTICLE SIZE ANALYSIS - TYPE B
MATERIAL - STATISTICAL AVERAGE GRADATION



LEGEND:


-  TOPOGRAPHIC CONTOURS
-  BORING LOCATION

NOTES:

1. SEE FIGURE 2.5-14 FOR LOCATION OF BORROW AREA.
2. REFER TO FIGURES 2.5-152 THROUGH 2.5-161 FOR LOGS OF BORINGS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-352
PLOT PLAN - PROPOSED BORROW AREA
FOR STRUCTURAL FILL



NOTE
 REFER TO FIGURES 2.5-243 THROUGH
 2.5-253 FOR LOG OF BORINGS.


LEGEND
 ● BORINGS




**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-353
 PLOT PLAN - TYPE B STRUCTURAL FILL
 BORROW AREA

SOIL SAMPLER TYPE U
FOR SOILS DIFFICULT TO RETAIN IN SAMPLER
U. S. PATENT NO. 2,318,062



ALTERNATE ATTACHMENTS



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-354

DAMES AND MOORE U-TYPE SAMPLER

SOIL CLASSIFICATION CHART

MAJOR DIVISIONS			WOODWARD-CLYDE CONSULTANTS			DAMES AND MOORE			BARRETT & LINDY ENGINEERS			
			GRAPH SYMBOL	LETTER SYMBOL	TYPICAL DESCRIPTION	GRAPH SYMBOL	LETTER SYMBOL	TYPICAL DESCRIPTION	GRAPH SYMBOL	LETTER SYMBOL	TYPICAL DESCRIPTION	
COARSE GRAINED SOILS	GRAVEL AND GRAVELLY SOILS	CLEAN GRAVELS (little or no fines)					GW	Well-graded gravels, gravel - sand mixtures, little or no fines.		GW	Well-graded gravels, gravel - sand mixtures, little or no fines.	
		More than 50% of coarse fraction <u>RETAINED</u> on No. 4 sieve	GRAVELS WITH FINES (appreciable amount of fines)		SP-GP GP-SP GP	Gravelly sand, sandy gravel, poorly graded gravel.		GP	Poorly-graded gravels, gravel - sand mixtures, little or no fines.		GP	Poorly-graded gravels, gravel - sand mixtures, little or no fines.
			SAND AND SANDY SOILS	CLEAN SAND (little or no fines)		SP SP-SM SM	Sand with trace silt.		SM	Well-graded sands, gravelly sands, little or no fines.		SM
	More than 50% of material is <u>LARGER</u> than No. 200 sieve size	SANDS WITH FINES (appreciable amount of fines)			SM ML	Sand with some silt, silty sand, sandy silt.		SM	Silty sands, sand-silt mixtures.		SM	Silty sands, sand-silt mixtures.
			CLAYEY SAND.		SC	Clayey SAND.		SC	Clayey sands, sand-clay mixtures.		SC	Clayey sands, sand-clay mixtures.
		SILTS AND CLAYS	Liquid limit <u>LESS</u> than 50		ML CL CL-ML	SILT, Clayey SILT. Silty clay.		ML CL	Inorganic silts and very fine sands, rock flour, silty or clayey fine sands or clayey silts with slight plasticity. Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, clays, loam clays.		ML CL	Inorganic silts and very fine sands, rock flour, silty or clayey fine sands or clayey silts with slight plasticity. Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, silty clays, loam clays.
FINE GRAINED SOILS	SILTS AND CLAYS	Liquid limit <u>GREATER</u> than 50		CH	CLAY (High plasticity)		CH	Inorganic clays of high plasticity, fat clays.		CH	Inorganic clays of high plasticity, fat clays.	
				OH	Organic clays of medium to high plasticity, organic silts.		OH	Organic clays of medium to high plasticity, organic silts.		OH	Organic clays of medium to high plasticity, organic silts.	
	HIGHLY ORGANIC SOILS				PT	Peat, humus swamp soils with high organic contents.		PT	Peat, humus swamp soils with high organic contents.			
					Topsoil							


- NOTES:
- Woodward-Clyde Consultants presents only those materials encountered by their field study.
 - Dual symbols are used to indicate borderline classifications.
 - When shown on the boring logs, the following terms are used to describe the consistency of cohesive soils and the relative compactness of cohesionless soils.

CONSISTENCY OF COHESIVE SOILS			RELATIVE DENSITY OF GRANULAR SOILS	
NO. BLOWS/FT	UNCONFINED COMPRESSIVE STRENGTH (tsf)	CONSISTENCY	NO. OF BLOWS/FT	RELATIVE DENSITY
< 2	<0.25	Very Soft	0-3	Very Loose
2-3	0.25-0.49	Soft	4-9	Loose
4-7	0.50-0.99	Medium	10-29	Medium
8-14	1.00-1.99	Stiff	30-49	Dense
15-30	2.00-4.00	Very stiff	50-80	Very Dense
>30	>4.00	Hard	>80	Extremely dense

MATERIAL SIZE	PARTICLE SIZE				
	LOWER LIMIT		UPPER LIMIT		
	MILLIMETERS	STRIE SIZE	MILLIMETERS	STRIE SIZE	
SAND	FINE	.075	#200*	0.42	#40*
	MEDIUM	0.42	#40*	2.00	#10*
	COARSE	2.00	#10*	4.75	#4*
GRAVEL	FINE	4.75	#4*	19.1	3/4"
	COARSE	19.1	3/4"	76.2	3"
COBBLES		76.2	3"	304.8	12"
BOULDERS		304.8	12"	914.4	36"

* U.S. STANDARD * CLEAR SQUARE OPENINGS

GRADATION CHART




PLASTICITY CHART

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-355

UNIFIED SOIL CLASSIFICATION SYSTEM




- NOTES:
1. REFER TO FIGURES 2.5-359 THROUGH 2.5-363 FOR SEISMIC REFRACTION SURVEYS NO. 1 THROUGH NO. 5.
 2. REFER TO FIGURE 2.5-366 FOR UPHOLE VELOCITY SURVEY IN BORING P-14.

LEGEND

740 TOPOGRAPHIC CONTOURS



BORING P-28 BORING LOCATION



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-356

PLOT PLAN OF GEOPHYSICAL EXPLORATIONS
STATION SITE




- NOTES:**
1. REFER TO FIGURE 2.5-364 FOR SEISMIC REFRACTION SURVEY LINE NO. 6.
 2. REFER TO FIGURE 2.5-367 FOR UPHOLE VELOCITY SURVEY IN BORING D-11.

LEGEND

690 TOPOGRAPHIC CONTOURS


BORING D-11 BORING LOCATION



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-357

**PLOT PLAN OF GEOPHYSICAL EXPLORATIONS
DAM SITE**



- NOTES:
1. REFER TO FIGURE 2.5-364 FOR SEISMIC REFRACTION SURVEY LINE NO. 7.
 2. REFER TO FIGURE 2.5-368 FOR UPHOLE VELOCITY SURVEY IN BORING D-31.

LEGEND
 — TOPOGRAPHIC CONTOURS
 ◆ BORING D-31 BORING LOCATION




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-358

PLOT PLAN OF GEOPHYSICAL EXPLORATIONS
 ALONG NORTH FORK OF SALT CREEK

TIME-DISTANCE PLOT - SEISMIC LINE 1



SUBSURFACE SECTION - SEISMIC LINE 1





NOTES:

1. TIME DISTANCE PLOTS SHOW INFORMATION COLLECTED FROM SHOT POINTS MADE AT SEVERAL LOCATIONS ALONG A SEISMIC LINE, FOR CLARIFICATION, TWO PLOT SYMBOLS HAVE BEEN USED TO INDICATE THE ORIGIN OF THE ENERGY: FROM THE LEFT (.) FROM THE RIGHT (+).
2. THE SUBSURFACE SECTIONS SHOWN PRESENT OUR EVALUATION OF THE MOST PROBABLE SUBSURFACE CONDITIONS BASED UPON OUR INTERPRETATION OF PRESENTLY AVAILABLE DATA, SOME VARIATIONS FROM THESE CONDITIONS MUST BE EXPECTED.
3. REFER TO FIGURE 2.5-356 FOR LOCATION OF SEISMIC TEST LINE NO. 1.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-359
SEISMIC REFRACTION SURVEY LINE 1
STATION SITE




NOTES:


1. TIME DISTANCE PLOTS SHOW INFORMATION COLLECTED FROM SHOT POINTS MADE AT SEVERAL LOCATIONS ALONG A SEISMIC LINE, FOR CLARIFICATION, TWO PLOT SYMBOLS HAVE BEEN USED TO INDICATE THE ORIGIN OF THE ENERGY: FROM THE LEFT (.) FROM THE RIGHT (+).
2. THE SUBSURFACE SECTIONS SHOWN PRESENT OUR EVALUATION OF THE MOST PROBABLE SUBSURFACE CONDITIONS BASED UPON OUR INTERPRETATION OF PRESENTLY AVAILABLE DATA, SOME VARIATIONS FROM THESE CONDITIONS MUST BE EXPECTED.
3. REFER TO FIGURE 2.5-356 FOR LOCATION OF SEISMIC TEST LINE NO. 2.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT	
FIGURE 2.5-360 SEISMIC REFRACTION SURVEY LINE 2 STATION SITE	

TIME-DISTANCE PLOT - SEISMIC LINE 3



SUBSURFACE SECTION - SEISMIC LINE 3





NOTES:

1. TIME DISTANCE PLOTS SHOW INFORMATION COLLECTED FROM SHOT POINTS MADE AT SEVERAL LOCATIONS ALONG A SEISMIC LINE, FOR CLARIFICATION, TWO PLOT SYMBOLS HAVE BEEN USED TO INDICATE THE ORIGIN OF THE ENERGY: FROM THE LEFT (.) FROM THE RIGHT (+).
2. THE SUBSURFACE SECTIONS SHOWN PRESENT OUR EVALUATION OF THE MOST PROBABLE SUBSURFACE CONDITIONS BASED UPON OUR INTERPRETATION OF PRESENTLY AVAILABLE DATA, SOME VARIATIONS FROM THESE CONDITIONS MUST BE EXPECTED.
3. REFER TO FIGURE 2.5-356 FOR LOCATION OF SEISMIC TEST LINE NO. 3.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-361
SEISMIC REFRACTION SURVEY LINE 3
STATION SITE

TIME-DISTANCE PLOT - SEISMIC LINE 4





NOTES:

1. TIME DISTANCE PLOTS SHOW INFORMATION COLLECTED FROM SHOT POINTS MADE AT SEVERAL LOCATIONS ALONG A SEISMIC LINE. FOR CLARIFICATION, TWO PLOT SYMBOLS HAVE BEEN USED TO INDICATE THE ORIGIN OF THE ENERGY: FROM THE LEFT (.) FROM THE RIGHT (+).
2. THE SUBSURFACE SECTIONS SHOWN PRESENT OUR EVALUATION OF THE MOST PROBABLE SUBSURFACE CONDITIONS BASED UPON OUR INTERPRETATION OF PRESENTLY AVAILABLE DATA, SOME VARIATIONS FROM THESE CONDITIONS MUST BE EXPECTED.
3. REFER TO FIGURE 2.5-356 FOR LOCATION OF SEISMIC TEST LINE NO. 4.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-362

SEISMIC REFRACTION SURVEY LINE 4 -
STATION SITE




NOTES:

1. TIME DISTANCE PLOTS SHOW INFORMATION COLLECTED FROM SHOT POINTS MADE AT SEVERAL LOCATIONS ALONG A SEISMIC LINE, FOR CLARIFICATION, TWO PLOT SYMBOLS HAVE BEEN USED TO INDICATE THE ORIGIN OF THE ENERGY: FROM THE LEFT (.) FROM THE RIGHT (+).
2. THE SUBSURFACE SECTIONS SHOWN PRESENT OUR EVALUATION OF THE MOST PROBABLE SUBSURFACE CONDITIONS BASED UPON OUR INTERPRETATION OF PRESENTLY AVAILABLE DATA, SOME VARIATIONS FROM THESE CONDITIONS MUST BE EXPECTED.
3. REFER TO FIGURE 2.5-356 FOR LOCATION OF SEISMIC TEST LINE NO. 5.


CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-363
 SEISMIC REFRACTION SURVEY LINE 5 -
 STATION SITE

TIME-DISTANCE PLOT - SEISMIC LINE 6



SUBSURFACE SECTION - SEISMIC LINE 6



NOTES:


1. TIME DISTANCE PLOTS SHOW INFORMATION COLLECTED FROM SHOT POINTS MADE AT SEVERAL LOCATIONS ALONG A SEISMIC LINE, FOR CLARIFICATION, TWO PLOT SYMBOLS HAVE BEEN USED TO INDICATE THE ORIGIN OF THE ENERGY: FROM THE LEFT (.) FROM THE RIGHT (+).
2. THE SUBSURFACE SECTIONS SHOWN PRESENT OUR EVALUATION OF THE MOST PROBABLE SUBSURFACE CONDITIONS BASED UPON OUR INTERPRETATION OF PRESENTLY AVAILABLE DATA, SOME VARIATIONS FROM THESE CONDITIONS MUST BE EXPECTED.
3. REFER TO FIGURE 2.5-357 FOR LOCATION OF SEISMIC TEST LINE NO. 6.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-364

SEISMIC REFRACTION SURVEY LINE 6 -
DAM SITE

TIME-DISTANCE PLOT - SEISMIC LINE 7



SUBSURFACE SECTION - SEISMIC LINE 7




NOTES:

1. TIME DISTANCE PLOTS SHOW INFORMATION COLLECTED FROM SHOT POINTS MADE AT SEVERAL LOCATIONS ALONG A SEISMIC LINE, FOR CLARIFICATION, TWO PLOT SYMBOLS HAVE BEEN USED TO INDICATE THE ORIGIN OF THE ENERGY: FROM THE LEFT (.) FROM THE RIGHT (+).
2. THE SUBSURFACE SECTIONS SHOWN PRESENT OUR EVALUATION OF THE MOST PROBABLE SUBSURFACE CONDITIONS BASED UPON OUR INTERPRETATION OF PRESENTLY AVAILABLE DATA, SOME VARIATIONS FROM THESE CONDITIONS MUST BE EXPECTED.
3. REFER TO FIGURE 2.5-358 FOR LOCATION OF SEISMIC TEST LINE NO. 7.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-365

SEISMIC REFRACTION SURVEY LINE 7 -
SECTION E-E' ALONG NORTH FORK
OF SALT CREEK




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-366

UPHOLE (COMPRESSIONAL) VELOCITY SURVEY -
 BORING P-14, STATION SITE

NOTE:
 REFER TO FIGURE 2.5-356 FOR LOCATION OF BORING P-14.




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-367

UPHOLE (COMPRESSIONAL) VELOCITY SURVEY
 BORING D-11A, DAM SITE

NOTE:
 REFER TO FIGURE 2.5-357 FOR LOCATION OF BORING D-11.




NOTE:
REFER TO FIGURE 2.5-358 FOR LOCATION OF BORING D-31.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-368

UPHOLE (COMPRESSIONAL) VELOCITY SURVEY -
 BORING D-31 SECTION E-E' ALONG NORTH
 FORK OF SALT CREEK




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-369

TYPICAL GEOLOGIC PROFILE SHOWING
GEOPHYSICAL PROPERTIES - STATION SITE

NOTE:
REFER TO LEGEND ON FIGURES 2.5-275 AND 2.5-276 FOR
DETAILED DESCRIPTION OF OVERBURDEN UNITS.




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-370

TYPICAL GEOLOGIC PROFILE SHOWING
GEOPHYSICAL PROPERTIES - DAM SITE

NOTE:
* VALUES ARE ESTIMATED
REFER TO BORING D-11 AND LEGEND ON FIGURE 2.5-277
FOR DETAILED DESCRIPTION OF OVERBURDEN UNITS.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT




FIGURE 2.5-371

TYPICAL GEOLOGIC PROFILE SHOWING
GEOPHYSICAL PROPERTIES - SECTION E-E'
ALONG NORTH FORK OF SALT CREEK

NOTE:

* VALUES ARE ESTIMATED


REFER TO LEGEND ON FIGURE 2.5-278 FOR
DETAILED DESCRIPTION OF OVERBURDEN UNITS.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-372

GEOLOGIC SECTIONS H-H' AND I-I' -
STATION SITE




NOTE:
 REFER TO FIGURES 2.5-19 THROUGH 2.5-65,
 2.5-190 AND 2.5-192 FOR LOG OF BORINGS.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-373


BORING LOCATION PLAN



LOADING AREA	STATIC FND. LOADING KSF.
SERVICE BUILDING	1.5
FUEL BUILDING	6.5
CONTAINMENT BLDG.	6.5
AUXILIARY BLDG.	6.5
TURBINE BLDG.	5.7
DIESEL GEN. & H.V.A.C. BLDG.	4.7
CONTROL BLDG.	4.7
RADWASTE BLDG.	4.8
MACHINE SHOP	4.8
OFF-GAS BLDG.	4.8

NOTE:
1. REFER TO FIGURE 2.5-372 FOR SUBSURFACE SECTIONS.


LEGEND:
--- INDICATES SUBSURFACE SECTION LOCATION.




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-374

STATION PLOT PLAN - FOUNDATION LOADING



LEGEND

-  AREAS OF FLYASH MIXTURE PLACEMENT
- 1+00N MAIN PLANT COORDINATES

NOTES


1. DRAWING PRODUCED FROM BALDWIN ASSOCIATES QUALITY CONTROL RECORDS FOR FLYASH MIXTURE PLACEMENT.
2. FLYASH MIXTURE, CONSISTING OF SAND, CEMENT AND FLYASH, PREPARED AND PLACED IN ACCORDANCE WITH S & L SPECIFICATION K-2942.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-375

LOCATION OF FLY ASH MIXTURE IN
MAIN PLANT SUBGRADE





NOTE
 AREAS OF BASH PLACEMENT
 DETERMINED FROM BALDWIN
 ASSOCIATES CONSTRUCTION
 TRAVELERS.

FIGURE 4 OF QUESTION 241.8

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-376

AREAS WHERE FLY ASH MIXTURE IS USED
 AS FILL AND BACKFILL IN THE MAIN
 PLANT AND SCREEN HOUSE AREAS





NOTES

1. Relative density test-data based on ASTM D2049.
2. Number of occurrences based on average of two pounds per cubic foot range.

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-377
 POWER BLOCK RELATIVE DENSITY
 TEST SUMMARY



NOTE

See Figure 2.5-379 for section through screen house.


LEGEND



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-378

EXCAVATION PLAN FOR CIRCULATING
WATER SCREEN HOUSE




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-379

SECTION THROUGH CIRCULATING WATER SCREEN
 HOUSE SHOWING EXCAVATION LINE

FIGURE 2.5-380
HAS BEEN DELETED




LEGEND

Borings

NOTE



1. The soil profile shows the projection of Borings P-12, H-30 and P-13 along the center line of the outlet structure.



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-381

EXCAVATION PLAN AND SECTION FOR
 OUTLET STRUCTURE



0 25 50 75 100



Scale in Feet



NOTE

1. (C) CI SETTLEMENT MONUMENT LOCATION.

<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>FIGURE 2.5-382</p> <p>LOCATIONS OF SETTLEMENT MONUMENTS - MAIN PLANT</p>

CPS/USAR

Figure 2.5-383
Deleted



LEGEND

- SECTIONS
- BORROW AREA


NOTE

1. FOR SECTIONS SEE
FIGURE 2.5-385.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE 2.5-384

ULTIMATE HEAT SINK



FOR LOCATION OF SECTIONS,
SEE FIGURE 2.5-384.


NOTE:
HORIZONTAL AND VERTICAL SCALES
ARE DISTORTED




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-385

SECTIONS - ULTIMATE HEAT SINK



PLAN




NORTH ABUTMENT



SOUTH ABUTMENT



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-386
PLAN AND SECTIONS FOR SUBMERGED EARTH
FILL AND BAFFLE DIKE




LEGEND





CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-387

SOIL PROFILE - ULTIMATE HEAT SINK
 SECTION P-P





LEGEND






CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-388

SOIL PROFILE - ULTIMATE HEAT SINK
 SECTION Q-Q






CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT
 FIGURE 2.5-389
 SOIL PROFILE - ULTIMATE HEAT SINK
 SECTION X-X



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-390




SOIL PROFILE - ULTIMATE
 HEAT SINK SECTION Y-Y



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-391

SOIL PROFILE - ULTIMATE HEAT SINK
 SECTION R-R




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-392

SOIL PROFILE - ULTIMATE HEAT SINK
 SECTION S-S

#	DESCRIPTION	SOIL DATA		
		DENSITY (PCF)	C' (PSF)	ϕ'
1	COMPACTED WISCONSINAN TILL	130	1300*	0*
2	SALT CREEK ALLUVIUM	120	400	0
3	SAND DRAINAGE BLANKET	125	0	30
4	SALT CREEK ALLUVIUM (SAND)	125	0	33
5	ILLINOIAN TILL	140	4000	0
6	DUMMY LAYER	0	0	0
7	DUMMY LAYER	0	0	0

* THESE VALUES ARE TOTAL STRENGTH PARAMETERS




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-393

STABILITY ANALYSIS - END OF CONSTRUCTION
 CONDITION - MAIN DAM

#	DESCRIPTION	SOIL DATA		
		DENSITY (PCF)	C' (PSF)	ϕ'
1	COMPACTED WISCONSINAN TILL	130	200	33
2	SALT CREEK ALLUVIUM	120	400	0
3	SAND DRAINAGE BLANKET	125	0	30
4	SALT CREEK ALLUVIUM (SAND)	125	0	33
5	ILLINOIAN TILL	140	4000	0
6	DUMMY LAYER	0	0	0
7	WATER	62.4	0	0




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-394

STABILITY ANALYSIS - NORMAL POOL
 CONDITION - MAIN DAM

#	DESCRIPTION	SOIL DATA		
		DENSITY (PCF)	C' (PSF)	ϕ'
1	COMPACTED WISCONSINAN TILL	130	200	33
2	SALT CREEK ALLUVIUM	120	400	0
3	SAND DRAINAGE BLANKET	125	0	30
4	SALT CREEK ALLUVIUM (SAND)	125	0	33
5	ILLINOIAN TILL	140	4000	0
6	DUMMY LAYER	0	0	0
7	WATER	62.4	0	0




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-395

STABILITY ANALYSIS - NORMAL POOL WITH
 0.1g EARTHQUAKE LOADING CONDITION -
 MAIN DAM

#	DESCRIPTION	SOIL DATA		
		DENSITY (PCF)	C' (PSF)	ϕ'
1	COMPACTED WISCONSINAN TILL	130	200	33
2	SALT CREEK ALLUVIUM	120	400	0
3	SAND DRAINAGE BLANKET	125	0	30
4	SALT CREEK ALLUVIUM (SAND)	125	0	33
5	ILLINOIAN TILL	140	4000	0
6	WATER	62.4	0	0
7	WATER	62.4	0	0




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-396

STABILITY ANALYSIS - MAXIMUM POOL
 CONDITION - MAIN DAM


#	DESCRIPTION	SOIL DATA		
		DENSITY (PCF)	C' (PSF)	ϕ'
1	COMPACTED WISCONSINAN TILL	130	200	33
2	SALT CREEK ALLUVIUM	120	400	0
3	SAND DRAINAGE BLANKET	125	0	30
4	SALT CREEK ALLUVIUM (SAND)	125	0	33
5	ILLINOIAN TILL	140	4000	0
6	DUMMY LAYER	0	0	0
7	DUMMY LAYER	0	0	0



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-397

STABILITY ANALYSIS - RAPID DRAWDOWN
 CONDITION - MAIN DAM




#	DESCRIPTION	SOIL DATA		
		J(PCF)	C'(PSF)	ϕ'
1	LOESS	120.0	0	20
2	WISCONSIN TILL	137.0	600	30
3	INTERGLACIAL	131.0	600	30
4	SAND	125.0	0	38
5	ILLINOIAN TILL	150.0	0	47

- (1) F.S: 1.24 (PSEUDO)
- (2) F.S: 2.60 (STATIC)

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-398

STABILITY ANALYSIS - END OF CONSTRUCTION
 CONDITION - SECTION X-X,
 ULTIMATE HEAT SINK



#	DESCRIPTION	SOIL DATA		
		J (PCF)	C' (PSF)	ϕ'
1	LOESS	120.0	0	20
2	WISCONSIN TILL	137.0	600	30
3	INTERGLACIAL	131.0	600	30
4	SAND	125.0	0	38
5	ILLINOIAN TILL	150.0	0	47


- ① F.S: 1.07 (PSEUDO)
- ② F.S: 2.33 (STATIC)

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-399


STABILITY ANALYSIS - FULL COOLING
 LAKE CONDITION - SECTION X-X,
 ULTIMATE HEAT SINK

#	DESCRIPTION	SOIL DATA		
		DENSITY (PCF)	C' (PSF)	ϕ'
1	COMPACTED WISCONSINAN TILL (FILL)	135	400	29
2	SAND AND GRAVEL	120	0	38
3	WISCONSINAN TILL	139	600	30
4	WATER	62.4	0	0



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT
 FIGURE 2.5-400
 STABILITY ANALYSIS - FULL COOLING
 LAKE CONDITION - SECTION H-H',
 ULTIMATE HEAT SINK


#	DESCRIPTION	SOIL DATA		
		DENSITY (PCF)	C' (PSF)	ϕ'
1	COMPACTED WISCONSINAN TILL (FILL)	135	400	29
2	SAND AND GRAVEL	120	0	38
3	WISCONSINAN TILL	139	600	30
4	WATER	62.4	0	0



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-401

STABILITY ANALYSIS - FULL COOLING LAKE
 WITH 0.25g EARTHQUAKE LOADING CONDITION -
 SECTION H-H, ULTIMATE HEAT SINK




NOTE

SEE FIGURE 2.5-398
FOR SOIL DATA

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-402

STABILITY ANALYSIS - EMPTY COOLING
LAKE CONDITION SECTION X-X,
ULTIMATE HEAT SINK




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-403

STABILITY ANALYSIS - EMPTY COOLING
 LAKE CONDITION SECTION H-H,
 ULTIMATE HEAT SINK

TRIAXIAL COMPRESSION TESTS
 CONSOLIDATED UNDRAINED WITH PORE PRESSURE MEASUREMENTS

KEY	BORING	ELEVATION	SOIL TYPE	BLOW COUNTS/FT.	DRY DENSITY IN PCF
1	H-20	721.8	SP	85	130.3
2	H-38	712.9	ML	20	123.5
3	D-48	709.3	CL	9	123.0
4	H-23	707.3	ML	14	121.4
5	D-48	704.3	CL	21	123.8
6	D-48	689.3	CL	17	108.8




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-404

MOHR CIRCLES - WISCONSINAN
 GLACIAL TILL

TRIAXIAL COMPRESSION TESTS
 CONSOLIDATED-UNDRAINED WITH PORE PRESSURE MEASUREMENTS

TEST NO.	BORING NO.	ELEVATION	SOIL TYPE	BLOW COUNT/FT.	DRY DENSITY IN PCF
7	H-23	692.3	ML	15	103
8	H-38	687.9	ML	8	—




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-405

MOHR CIRCLES - INTERGLACIAL TILL

TRIAxIAL COMPRESSION TESTS
 CONSOLIDATED - UNDRAINED WITH PORE PRESSURE MEASUREMENTS




KEY	BORING	ELEVATION	SOIL TYPE	BLOW COUNTS/FT	DRY DENSITY IN PCF
9	H-38	673.4	ML	154/11"	123.5
10	P-38	648.5	ML	100/6"	138
11	H-3	645.1	ML	60	139
12	H-25	633.7	ML	100/4"	146
13	D-8	631.7	ML	94	135.2
14	D-8	591.7	ML	83	132
15	H-6	504.3	ML	31	109

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT
 FIGURE 2.5-406
 MOHR CIRCLES - ILLINOIAN GLACIAL TILL

TRIAxIAL COMPRESSION TEST
 CONSOLIDATED-UNDRAINED WITH PORE PRESSURE MEASUREMENTS

KEY	BORING	ELEVATION	SOIL TYPE	BLOW COUNTS/FT.	DRY DENSITY IN PCF
16	P-38	572.9	ML	48	125.9




CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-407

MOHR CIRCLE - LACUSTRINE DEPOSITS

TRIAxIAL COMPRESSION TESTS
 CONSOLIDATED-UNDRAINED WITH PORE PRESSURE MEASUREMENTS


KEY	BORING	ELEVATION	SOIL TYPE	BLOW COUNT/FT.	DRY DENSITY IN PCF
17	H-25	674.7	ML	3	-
18	H-13	673.6	ML	6	102
19	H-24	670.7	SM	2	-



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-408


MOHR CIRCLES - SALT CREEK ALLUVIUM



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-409


ARTIFICIAL ACCELEROGRAM FOR
HORIZONTAL GROUND MOTION



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-410


ARTIFICIAL ACCELEROGRAM FOR
VERTICAL GROUND MOTION



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-411


DYNAMIC SHEAR STRESS VS. NUMBER OF
 CYCLES TO CAUSE 5% STRAIN - $K_c = 1.0$



**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-412



DYNAMIC SHEAR STRESS VS. NUMBER OF
 CYCLES TO CAUSE 5% STRAIN - $K_c = 1.5$



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-413



DYNAMIC SHEAR STRESS TO MINOR PRINCIPAL
STRESS RATIO VS. NUMBER OF CYCLES TO
CAUSE 5% STRAIN



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-414


SUBMERGED DIKE - CROSS SECTION ANALYZED
 FOR SEISMIC STABILITY



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-415



NATURAL SLOPE - CROSS SECTION ANALYZED
 FOR SEISMIC STABILITY



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-416

SHEAR LAYER MODEL FOR THE SUBMERGED
 DIKE FOUNDATION




SCALE = 1. / 66.667

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-417


FINITE ELEMENT MODEL FOR THE DIKE



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-418


TYPICAL SHEAR STRESS TIME HISTORY



**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-419


SHEAR LAYER MODEL FOR NATURAL
 SLOPE FOUNDATION



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-420

FINITE ELEMENT MODEL USED FOR NATURAL
SLOPE STABILITY ANALYSIS




NOTE:
 The gradational range for the embankment materials is based on a composite of grain size analyses performed.

**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-421

GRADATION OF EMBANKMENT MATERIALS -
 MAIN DAM




NOTES

1. Moisture density relationships based on standard Proctor test ASTM D698.
2. Data based on field laboratory testing of type A material used as fill for Main Dam.
3. D-192, D-105, D-808, D-89 and D-750 denote field sample numbers.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-422

TYPICAL MOISTURE - DENSITY
RELATIONSHIP - MAIN DAM




NOTES

1. Moisture density relationships based on modified Proctor Test ASTM D1557.
2. Data based on field laboratory testing type A material used as fill for ultimate heat sink dam and baffel dike.
3. H-234, H-220, H-184, H-137 and H-136 denote field sample numbers.

**CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT**

FIGURE 2.5-423

TYPICAL MOISTURE-DENSITY RELATIONSHIPS -
ULTIMATE HEAT SINK






NOTE:
 The gradational range for the embankment materials is based on a composite of grain size analyses performed.

CLINTON POWER STATION
 FINAL SAFETY ANALYSIS REPORT

FIGURE 2.5-424
 GRADATION OF EMBANKMENT MATERIALS -
 ULTIMATE HEAT SINK

NORTH


SOUTH




- NOTE:
1. * NOT PROVIDED IN AVAILABLE LOG
 2. COMPILED FROM DATA TABULATED IN: ILLINOIS GEOLOGICAL SURVEY CIRCULAR 377.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-425
 REGIONAL CORRELATION BETWEEN
 DEEP BORINGS



LEGEND:



NOTE:


FROM TECTONIC MAP OF THE UNITED STATES, UNITED STATES GEOLOGICAL SURVEY AND AMERICAN ASSOCIATION OF PETROLEUM GEOLOGISTS, 1962.

EARTHQUAKE DATA COMPILED FROM COFFMAN, J.L. AND VONHAKE, C.A. (1973) EARTHQUAKE HISTORY OF THE UNITED STATES, U.S. DEPT. COMMERCE, NOAA, PUBLICATION 41-1 AND FROM OTHER SOURCES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-426

EARTHQUAKE EPICENTER MAP - BELOW 37°




(CM/SEC²) ACCELERATION AT THE SITE
 CLINTON SEISMIC RISK ANALYSIS

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-427
 SEISMIC RISK CURVE

DISTRIBUTION OF RELATIVE DENSITY




CLINTON STA. COMPACTION TESTS
ALL PASSING DATA
ELEVATIONS 671.00 TO 703.00

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-428

TYPE B GRANULAR FILL DISTRIBUTION
OF RELATIVE DENSITY

DISTRIBUTION OF DRY DENSITY




CLINTON STA. COMPACTION TESTS
 ALL PASSING DATA
 ELEVATIONS 671.00 TO 703.00

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-429

TYPE B GRANULAR FILL DISTRIBUTION
 OF DRY DENSITY

DISTRIBUTION OF MOISTURE CONTENT




CLINTON STA. COMPACTION TESTS
ALL PASSING DATA
ELEVATIONS 671.00 TO 703.00

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-430


TYPE B GRANULAR FILL DISTRIBUTION
OF MOISTURE CONTENT



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-432

POWER BLOCK GRID SYSTEM




NOTE

1. Units of settlements are inches



CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-433 CONTOURS OF COMPUTED FINAL SETTLEMENT FOR THE MAIN PLANT




NOTES

1. THIS MONUMENT WAS REPLACED BY C-4A AFTER SEPTEMBER 1982.
2. UNIT 2 HAS BEEN CANCELLED.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-434

COMPARISON OF PREDICTED AND MEASURED
 SETTLEMENT TIME HISTORIES AT
 SETTLEMENT MONUMENT C4
 (CONTAINMENT BUILDING)




NOTES

1. UNIT 2 HAS BEEN CANCELLED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-435
 COMPARISON OF PREDICTED AND MEASURED
 SETTLEMENT TIME HISTORIES AT
 SETTLEMENT MONUMENT T1
 (TURBINE BUILDING)



NOTES
1. UNIT 2 HAS BEEN CANCELLED.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-436
COMPARISON OF PREDICTED AND MEASURED
SETTLEMENT TIME HISTORIES AT
SETTLEMENT MONUMENT D3
(DIESEL GENERATOR BUILDING)




NOTES
 1. UNIT 2 HAS BEEN CANCELLED.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-437

COMPARISON OF PREDICTED AND MEASURED
 SETTLEMENT TIME HISTORIES AT
 SETTLEMENT MONUMENT R3
 (RADWASTE BUILDING)


C-1



C-2



C-3



NOTE:

1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-438


MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 1 OF 20)

NO READING TAKEN JAN. 84, POINT
C1A TEMPORARILY INACCESSIBLE

C-1A




C-2



NO READING TAKEN JAN 84, POINT
C3 TEMPORARILY INACCESSIBLE

C-3



SETTLEMENT
MONUMENT
NUMBER

ELEVATION
IN FEET

DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC																							
1983												1984												1985												1986												1987											


NOTE :
I. SEE FIGURE 2.5-382 FOR
LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-438


MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 2 OF 20)

C-4




REPLACED BY C-4A

C-5



CONTINUED ON SHEET 4 OF 20

C-7



CONTINUED ON SHEET 4 OF 20

SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC

1978 1979 1980 1981 1982


NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-438


MAIN PLANT
 SETTLEMENT MEASUREMENTS
 (SHEET 3 OF 20)

C-4A




NO READING TAKEN MAY 86, SEP. 86 OR JAN. 87, POINT C-5 INACCESSIBLE

C-5



C-7




SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC																							
1983												1984												1985												1986												1987											


NOTE:
I. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

C-8



CONTINUED ON SHEET 6 OF 20


C-9



CONTINUED ON SHEET 6 OF 20

REPLACED BY C-9A

C-10




CONTINUED ON SHEET 6 OF 20

NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-438
MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 5 OF 20)


NO READING TAKEN JAN. 85, MAY 87, AUG. 87
POINT C-8A INACCESSIBLE

C-8A




NO READINGS TAKEN MAY 84, MAY 85, MAY 86
POINT C-9A INACCESSIBLE THESE DATES

C-9A



NO READINGS TAKEN MAY 87, AUG. 87
POINT C-10 INACCESSIBLE

C-10




SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC											
1983												1984												1985												1986												1987											


NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-438
MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 6 OF 20)




CONTINUED ON SHEET 8 OF 20

REPLACED BY C-11A



REPLACED BY T-1A

CONTINUED ON SHEET 8 OF 20



CONTINUED ON SHEET 8 OF 20


SETTLEMENT MONUMENT NUMBER
ELEVATION IN FEET

1978 1979 1980 1981 1982

NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-438
MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 7 OF 20)


C-11A



NO READING TAKEN MAY 84 POINT T-1A TEMPORARILY INACCESSIBLE


NO READING TAKEN MAY 84, SEPT 85 OR JAN 86 POINT C-11A TEMP INACCESSIBLE

T-1A



NO READINGS TAKEN MAY 84, SEPT 84 POINT T-2 TEMP INACCESSIBLE

T-2



SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC																							
1983												1984												1985												1986												1987											


NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-438

MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 8 OF 20)


T-3



711.74
711.72
711.70
711.68
711.66


CONTINUED ON SHEET 11 OF 20

T-4



REPLACED BY T-4A

T-4A



CONTINUED ON SHEET 11 OF 20




SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC																							
1978												1979												1980												1981												1982											

NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-438
MAIN PLANT SETTLEMENT MEASUREMENTS (SHEET 9 OF 20)



CONTINUED ON SHEET 11 OF 20

SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

1978 1979 1980 1981 1982


NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-438

MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 10 OF 20)


T-3A



T-4A




D-1B




NOTE:
1. SEE FIGURE 2.5-382 FOR
LOCATION OF MONUMENTS

D-2




CONTINUED ON SHEET 13 OF 20

D-3



CONTINUED ON SHEET 13 OF 20

D-4



REPLACED BY D-4A

CONTINUED ON SHEET 13 OF 20

SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC

1978 1979 1980 1981 1982


NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-438


MAIN PLANT
 SETTLEMENT MEASUREMENTS
 (SHEET 12 OF 20)

D-2




NO READINGS TAKEN JAN 85 OR SEPT. 85
POINT D-3 TEMPORARILY INACCESSIBLE

D-3



D-4A



SETTLEMENT MONUMENT NUMBER


ELEVATION IN FEET

DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC																							
1983												1984												1985												1986												1987											

NOTE:
 I. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS


CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT
 FIGURE 2.5-438
 MAIN PLANT SETTLEMENT MEASUREMENTS
 (SHEET 13 OF 20)

D-5




CONTINUED ON SHEET 15 OF 20

D-6



CONTINUED ON SHEET 15 OF 20

D-7



CONTINUED ON SHEET 15 OF 20

SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET


DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC											
1978												1979												1980												1981												1982											

NOTE:
 1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS


CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-438


MAIN PLANT
 SETTLEMENT MEASUREMENTS
 (SHEET 14 OF 20)



NO READINGS TAKEN AT POINT D-6 SEP. 83, JAN 84, MAY 84
 JAN. 85, MAY 85 TEMPORARILY INACCESSIBLE.





NO READINGS TAKEN AT POINT D-7 MAY 86, SEP 86, JAN. 87, MAY 87
 AUG. 87 TEMPORARILY INACCESSIBLE.



SETTLEMENT MONUMENT NUMBER	ELEVATION IN FEET	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
		1983					1984					1985					1986					1987																

NOTE:
 I. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS




SETTLEMENT MONUMENT NUMBER	ELEVATION IN FEET	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
		1978					1979					1980					1981					1982																												

NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS


CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-438
MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 16 OF 20)

R-3




CONTINUED ON SHEET 18 OF 20

R-4



REPLACED BY R-4A ON SHEET 19 OF 20

R-5



R-5A

CONTINUED ON SHEET 18 OF 20

SETTLEMENT MONUMENT NUMBER
ELEVATION IN FEET

DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC																							
1978												1979												1980												1981												1982											


NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-438

MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 17 OF 20)


R-3



R-5A




SETTLEMENT MONUMENT NUMBER



NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS


CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT
 FIGURE 2.5-438
 MAIN PLANT
 SETTLEMENT MEASUREMENTS
 (SHEET 18 OF 20)

R-2B




CONTINUED ON SHEET 20 OF 20

R-1A




CONTINUED ON SHEET 20 OF 20

R-4A



CONTINUED ON SHEET 20 OF 20


SETTLEMENT MONUMENT NUMBER




NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-438
MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 19 OF 20)

R-2B




R-1A



NO READING TAKEN SEPT. 85
POINT R-4A INACCESSIBLE

R-4A



SETTLEMENT MONUMENT NUMBER

ELEVATION IN FEET

DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC JAN FEB MAR APR MAY JUN JUL AUG SEP OCT NOV DEC


1983 1984 1985 1986 1987

NOTE:
1. SEE FIGURE 2.5-382 FOR LOCATION OF MONUMENTS

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-438

MAIN PLANT
SETTLEMENT MEASUREMENTS
(SHEET 20 OF 20)




LOGGED BY: SARGENT & LUNDY
DRILLED BY: RAYMOND INTERNATIONAL

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-439

LOG OF BORING OW-18



LOGGED BY: SARGENT & LUNDY
DRILLED BY: RAYMOND INTERNATIONAL


<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>FIGURE 2.5-440</p>
<p>LOG OF BORING OW-19</p>

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			MOISTURE CONTENT, %	DRY DENSITY PCF	PERCENT FLUIDITY
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLAS- TICITY INDEX %			
		C_u psi	C_s psi	I_p psi						
0										
5										
10										
15										
20										
25	GSD						141	0.39		
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING OW-20
SURFACE ELEVATION 658.4

ELEVATION
(FEET)




LOGGED BY: SARGENT & LUNDY
DRILLED BY: RAYMOND INTERNATIONAL
TESTED BY: SOIL TESTING SERVICES

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-441


LOG OF BORING OW-20



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-442

LOG OF BORING OW-21



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-444

LOG OF BORING OW-23


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FIELD CONTINUM TESTS %	WATER CONTENT %	FLUIDITY INDEX %	DRY DENSITY PCF	WATER CONTENT PCF	WATER CONTENT SD VALUE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLAS- TICITY INDEX %	FLUIDITY INDEX %						
		σ_1 psf	σ_3 psf	σ_1 psf										
0														
5				1500*										
10				2750*										
15				1000*										
20				4500*										
25														
30														
35														
40														
45														
50														
55														
60														
65														
70														
75														

PIEZOMETER INSTALLED ON 10/11/79. A 2 INCH PVC PIPE WITH THE LOWER 13.5 FEET PERFORATED AND THE LOWER END PLUGGED WAS PLACED AT ELEVATION 620.9; GRANULAR FILL WAS PLACED FROM ELEVATION 620.9 TO 649.9; BENTONITE SEAL FROM ELEVATION 649.9 TO 651.9; AND GROUT FROM ELEVATION 651.9 TO 654.9.

BORING OW-24
SURFACE ELEVATION 654.9

BLOW COUNT
SAMPLES

ELEVATION
(FEET)




BORING COMPLETED AT 34.5 FEET ON 10/11/79.

WATER LEVEL ENCOUNTERED AT 20.5 FEET. WATER LEVEL AT 2.4 FEET AFTER APPROXIMATELY 30 MINUTES AND AT 3.2 FEET ABOVE GROUND SURFACE AFTER APPROXIMATELY 4.5 HOURS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-445

LOG OF BORING OW-24




PIEZOMETER INSTALLED ON 10/2/79. A 2 INCH PVC PIPE WITH A 4 FOOT WIRE-WOUND SCREENED SECTION ATTACHED 10 FEET ABOVE THE BOTTOM AND THE LOWER END OF THE PIPE PLUGGED WAS PLACED AT ELEVATION 614.7; GRANULAR BACK-FILL WAS PLACED FROM ELEVATION 614.7 TO 655.2; BENTONITE SEAL FROM ELEVATION 655.2 TO 657.2; AND GROUT FROM ELEVATION 657.2 TO 658.2.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-446

LOG OF BORING RW-1




PIEZOMETER INSTALLED ON 10/2/79. A 2 INCH PVC PIPE WITH A 4 FOOT WIRE-WOUND SCREENED SECTION ATTACHED 10 FEET ABOVE THE BOTTOM AND THE LOWER END OF THE PIPE PLUGGED AT ELEVATION 613.4; GRANULAR BACKFILL WAS PLACED FROM ELEVATION 613.4 TO 653.9; BENTONITE SEAL FROM ELEVATION 653.9 TO 655.9; AND GROUT FROM ELEVATION 655.9 TO 656.9.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-447

LOG OF BORING RW-2




PIEZOMETER INSTALLED ON 10/3/79. A 2 INCH PVC PIPE WITH A 4 FOOT WIRE-WOUND SCREENED SECTION ATTACHED 10 FEET ABOVE THE BOTTOM AND THE LOWER END OF THE PIPE PLUGGED WAS PLACED AT ELEVATION 612.3.; GRANULAR BACKFILL WAS PLACED FROM ELEVATION 612.3 TO 652.8; BENTONITE SEAL FROM ELEVATION 652.8 TO 654.8; AND GROUT FROM ELEVATION 654.8 TO 655.8.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-448

LOG OF BORING RW-3




BIEZOMETER INSTALLED ON 10/4/79. A 2 INCH PVC PIPE WITH A 4 FOOT WIRE-WOUND SCREENED SECTION ATTACHED 10 FEET ABOVE THE BOTTOM AND THE LOWER END OF THE PIPE PLUGGED WAS PLACED AT ELEVATION 616.4; GRANULAR BACK-FILL WAS PLACED FROM ELEVATION 616.4 TO 656.9; BENTONITE SEAL FROM ELEVATION 658.9 TO 658.9; AND GROUT FROM ELEVATION 658.9 TO 659.9.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-449

LOG OF BORING RW-4




PIEZOMETER INSTALLED ON 10/5/79. A 2 INCH PVC PIPE WITH A 4 FOOT WIRE-WOUND SCREENED SECTION ATTACHED 10 FEET ABOVE THE BOTTOM AND THE LOWER END OF THE PIPE PLUGGED WAS PLACED AT ELEVATION 619.3; GRANULAR BACK-FILL WAS PLACED FROM ELEVATION 619.3 TO 659.8; BENTONITE SEAL FROM ELEVATION 659.8 TO 661.8; AND GROUT FROM ELEVATION 661.8 TO 662.8.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-450

LOG OF BORING RW-5




CLINTON STATION IN-PLACE TEST
 SUBMERGED DAM
 ELEVATION FROM 645.0 TO 673.99

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-451

UHS DAM TYPE A COHESIVE FILL
 DISTRIBUTION OF DRY DENSITY




CLINTON STATION IN-PLACE TEST
SUBMERGED DAM
ELEVATION FROM 645.0 TO 673.99

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-452

UHS DAM TYPE A COHESIVE FILL
DISTRIBUTION OF MOISTURE CONTENT




CLINTON STATION IN-PLACE TEST
SUBMERGED DAM
ELEVATION FROM 645.0 TO 673.99

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-453

UHS DAM TYPE A COHESIVE FILL
DISTRIBUTION OF PERCENT COMPACTION




CLINTON STATION IN-PLACE TEST
 BAFFLE DIKE
 ELEVATION FROM 649.0 TO 699.99

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-454

UHS BAFFLE DIKE TYPE A COHESIVE
 FILL DISTRIBUTION OF DRY DENSITY




CLINTON STATION IN-PLACE TEST
 BAFFLE DIKE
 ELEVATION FROM 649.0 TO 699.99

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-455

UHS BAFFLE DIKE TYPE A
 COHESIVE FILL DISTRIBUTION
 OF MOISTURE CONTENT




CLINTON STATION IN-PLACE TEST
 BAFFLE DIKE
 ELEVATION FROM 649.0 TO 699.99

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-456

UHS BAFFLE DIKE TYPE A
 COHESIVE FILL DISTRIBUTION
 OF PERCENT COMPACTION




CLINTON STATION IN-PLACE TEST
 BAFFLE DIKE - SOIL CEMENT
 ELEVATION FROM 673.0 TO 676.99

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-457

UHS BAFFLE DIKE SOIL CEMENT
 SLOPE PROTECTION DISTRIBUTION
 OF DRY DENSITY




CLINTON STATION IN-PLACE TEST
 BAFFLE DIKE - SOIL CEMENT
 ELEVATION FROM 673.0 TO 676.99

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-458

UHS BAFFLE DIKE SOIL CEMENT
 SLOPE PROTECTION DISTRIBUTION
 OF MOISTURE CONTENT




CLINTON STATION IN-PLACE TEST
 BAFFLE DIKE - SOIL CEMENT
 ELEVATION FROM 673.0 TO 676.99

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-459

UHS BAFFLE DIKE SOIL CEMENT
 SLOPE PROTECTION DISTRIBUTION
 OF PERCENT COMPACTION



CLINTON STATION IN-PLACE TEST
 SOUTH DAM USDSCR-SOIL CEMENT
 ELEVATION FROM 649.0 TO 697.99


NOTE:

ONLY TESTS FOR THE UPSTREAM FACE,
 CREST AND DOWNSTREAM SLOPE ARE
 INCLUDED IN THIS ANALYSIS.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-460


UHS DAM SOIL CEMENT SLOPE
 PROTECTION DISTRIBUTION
 OF DRY DENSITY



CLINTON STATION IN-PLACE TEST
 SOUTH DAM USDSCR-SOIL CEMENT
 ELEVATION FROM 649.0 TO 697.99

NOTE:
 ONLY TESTS FOR THE UPSTREAM FACE,
 CREST AND DOWNSTREAM SLOPE ARE
 INCLUDED IN THIS ANALYSIS.

<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>FIGURE 2.5-461</p>
<p>UHS DAM SOIL CEMENT SLOPE PROTECTION DISTRIBUTION OF MOISTURE CONTENT</p>



CLINTON STATION IN-PLACE TEST
SOUTH DAM USDSCR-SOIL CEMENT
ELEVATION FROM 649.0 TO 697.99


NOTE:

ONLY TESTS FOR THE UPSTREAM FACE,
CREST AND DOWNSTREAM SLOPE ARE
INCLUDED IN THIS ANALYSIS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-462

UHS DAM SOIL CEMENT SLOPE
PROTECTION DISTRIBUTION
OF PERCENT COMPACTION




CLINTON STATION IN-PLACE TEST
SOUTH DAM - SOIL CEMENT
ELEVATION FROM 649.0 TO 697.99

NOTE:

TESTS FOR ALL AREAS, INCLUDING THE
ABUTMENTS AND DOWNSTREAM FLAT AREA,
ARE INCLUDED IN THIS ANALYSIS.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-463
UHS DAM SOIL CEMENT SLOPE PROTECTION DISTRIBUTION OF DRY DENSITY



CLINTON STATION IN-PLACE TEST
SOUTH DAM - SOIL CEMENT
ELEVATION FROM 649.0 TO 697.99


NOTE:

TESTS FOR ALL AREAS, INCLUDING THE
ABUTMENTS AND DOWNSTREAM FLAT AREA,
ARE INCLUDED IN THIS ANALYSIS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-464

UHS DAM SOIL CEMENT SLOPE
PROTECTION DISTRIBUTION
OF MOISTURE CONTENT




CLINTON STATION IN-PLACE TEST
SOUTH DAM - SOIL CEMENT
ELEVATION FROM 649.0 TO 697.99

NOTE:

Tests for all areas, including the abutments and the downstream flat area are included in this analysis.

<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>FIGURE 2.5-465</p>
<p>UHS DAM SOIL CEMENT SLOPE PROTECTION DISTRIBUTION OF PERCENT COMPACTION</p>




CLINTON POWER STATION
ALL DATA
OUTLET - P & R SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-466

SSWS OUTLET STRUCTURE
GRANULAR FILL - DISTRIBUTION OF
DRY DENSITY




CLINTON POWER STATION
 ALL DATA
 OUTLET - P & R SERIES

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-467

SSWS OUTLET STRUCTURE
 GRANULAR FILL - DISTRIBUTION OF
 RELATIVE DENSITY




CLINTON POWER STATION
ALL DATA
PIPELINE - PB SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-468

SSWS OUTLET STRUCTURE
COHESIVE BACKFILL - DISTRIBUTION OF
DRY DENSITY




CLINTON POWER STATION
ALL DATA
PIPELINE - PB SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-469

SSWS OUTLET STRUCTURE
COHESIVE BACKFILL - DISTRIBUTION OF
MOISTURE CONTENT




CLINTON POWER STATION
 ALL DATA
 PIPELINE - PB SERIES

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-470

SSWS OUTLET STRUCTURE
 COHESIVE BACKFILL - DISTRIBUTION OF
 PERCENT COMPACTION




CLINTON POWER STATION
 ALL DATA
 PIPELINE - P SERIES

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-471

SSWS PIPELINE GRANULAR FILL
 DISTRIBUTION OF DRY DENSITY




CLINTON POWER STATION
ALL DATA
PIPELINE - P-SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-472

SSWS PIPELINE GRANULAR FILL -
DISTRIBUTION OF RELATIVE DENSITY




CLINTON POWER STATION
ALL DATA
PIPELINE - PB SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-473

SSWS PIPELINE COHESIVE FILL -
DISTRIBUTION OF DRY DENSITY




CLINTON POWER STATION
ALL DATA
PIPELINE - PB SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-474

SSWS PIPELINE COHESIVE FILL -
DISTRIBUTION OF MOISTURE CONTENT




CLINTON POWER STATION
 ALL DATA
 PIPELINE - PB SERIES

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-475

SSWS PIPELINE COHESIVE FILL -
 DISTRIBUTION OF PERCENT COMPACTION




CLINTON POWER STATION
 ALL DATA
 SCREEN HOUSE

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-476

SCREEN HOUSE COHESIVE BACKFILL -
 DISTRIBUTION OF DRY DENSITY




CLINTON POWER STATION
ALL DATA
SCREEN HOUSE

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-477

SCREEN HOUSE COHESIVE BACKFILL -
DISTRIBUTION OF MOISTURE CONTENT




CLINTON POWER STATION
 ALL DATA
 SCREEN HOUSE

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-478

SCREEN HOUSE COHESIVE BACKFILL -
 DISTRIBUTION OF PERCENT COMPACTION




CLINTON POWER STATION
ALL DATA
POWER - PBT SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-479

MAIN PLANT COHESIVE BACKFILL -
DISTRIBUTION OF DRY DENSITY




CLINTON POWER STATION
ALL DATA
POWER - PBT SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-480

MAIN PLANT COHESIVE BACKFILL -
DISTRIBUTION OF MOISTURE CONTENT




CLINTON POWER STATION
 ALL DATA
 POWER - PBT SERIES

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-481

MAIN PLANT COHESIVE BACKFILL -
 DISTRIBUTION OF PERCENT COMPACTION




CLINTON POWER STATION
 ALL DATA
 POWER-P SERIES

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-482

MAIN PLANT GRANULAR BACKFILL -
 DISTRIBUTION OF DRY DENSITY



















CLINTON POWER STATION
ALL DATA
POWER-P SERIES

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-483

MAIN PLANT GRANULAR BACKFILL -
DISTRIBUTION OF RELATIVE DENSITY

FIGURE 2.5-484
HAS BEEN DELETED



CATEGORY I AS NOTED

NOTES

1. THE RUNOFF PROTECTION BERM SHALL HAVE 4" OF TOPSOIL PLACED ON IT AND SEEDED.
2. THE BERM SHALL CONSIST OF TYPE A COHESIVE MATERIAL COMPACTED TO 90% OF THE MAXIMUM DRY DENSITY AS DETERMINED BY ASTM D-1557.
3. SLOPE GRADES SHOWN ARE APPROXIMATE.
4. THE INSTALLATION OF THE CONCRETE REVETMENT ON SLOPES G-S AND H-H SHALL BE PER MANUFACTURER'S INSTRUCTIONS.
5. WATERPROOF CAULKING SHALL BE USED WHERE CMP PENETRATES CONCRETE.
6. WHEN THE UNIT'S BACKFILL OR THE BACKFILL OF THE UNIT'S EXCAVATION BEGINS, THE MATERIAL PLACED ON THE SLOPES ADJACENT TO THE BUILDING (REPRESENTED BY SECTIONS G-K AND H-H) SHALL BE REMOVED TO EXPOSE MATERIAL MEETING THE FILL PLACEMENT REQUIREMENTS AS STATED ON S&L DRAWING 502-1140. ALL BACKFILL PLACED AFTER THIS VERIFICATION SHALL MEET THE REQUIREMENTS OF 502-1140.
7. AS AVAILABLE FROM FIBERESH COMPANY, CHICKAMAUGA, GA, RATE OF 1.5 YD³ OF CONCRETE.
8. REFER TO RECO DRAWING RE-14963, SHEETS 1-5 FOR MSE WALL DETAILS.

REFERENCE DRAWINGS


- 502-1192 MANHOLES AND PIPES SCHEDULE.
- 502-1140 SAFETY RELATED DRAWING.
- C100 SITE DEMO PLAN (BY ARCHITECTURAL EXPRESSIONS, LLP)
- C101 DRAINAGE PLAN (BY ARCHITECTURAL EXPRESSIONS, LLP)
- C102 DRAINAGE DETAILS (BY ARCHITECTURAL EXPRESSIONS, LLP)

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-484A
MAIN PLANT EXCAVATION FINAL
GRADING AND SECTIONS FOR UNIT 2 AREA

REV 21

REVISION 13
JANUARY 2009



IDRT STANDARDS LIST

602306	INLET, TYPE B
602401	MANHOLE, TYPE A
604001-02	FRAME AND LID, TYPE 1
604036-01	GRATE, TYPE B

4' DIA MANHOLE,
TYPE A
STA 5+29
O/S 35' RT
RIM EL 721.00
GRATE TYPE B
S INV 702.5

INLET TYPE B
STA 5+36
O/S 37' RT
RIM EL 719.90
GRATE TYPE B
E INV 716.46

INLET TYPE B
STA 5+44
O/S 247' RT
RIM EL 717.90
GRATE TYPE B
N INV 714.75
W INV 714.75

INLET TYPE B
STA 5+90
O/S 232' RT
RIM EL 717.90
GRATE TYPE B
N INV 715.00
W INV 714.99

DRAINAGE STRUCTURE FOR
ELECTRICAL VAULT
(FIELD VERIFY DRAINAGE
CONNECTION)

PIPE CULVERTS, CLASS A,
TYPE 4 21" x 15"
USFL 702.50 STA 5+29
O/S 35' RT
DSFL 702.00 STA 5+14
O/S 32' RT

PIPE CULVERTS, CLASS A,
TYPE 4 21" x 30"
USFL 721.00 STA 4+93
O/S 249' RT
DSFL 721.00 STA 4+62
O/S 249' RT

NEW ADMINISTRATION BUILDING
FF ELEV 702.00
(SEE ARCHITECTURAL DWGS)

INLET TYPE B
STA 4+14
O/S 247' RT
RIM EL 717.80
GRATE TYPE B
N INV 714.00
W INV 714.00

4' DIA MANHOLE,
TYPE A
STA 5+29
O/S 135' RT
RIM EL 701.70
TYPE 1 FRAME & LID
S INV 695.0

4' DIA MANHOLE,
TYPE A
STA 3+57
O/S 122' RT
RIM EL 700.50
TYPE 1 FRAM & LID
S INV 695.7

INLET TYPE B
STA 3+26
O/S 196' RT
RIM EL 698.00
GRATE TYPE B
E INV 695.90
W INV 695.85

EXISTING
MANHOLE



EXIST CATCH BASIN
STA 2+48
O/S 150' RT
E INV 695.4

NOTE:
BASELINE IS ESTABLISHED
STARTING AT THE SE CORNER
OF EXIST BUILDING STA 0+00



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-484B
MAIN PLANT EXCAVATION FINAL
GRADING AND SECTIONS FOR UNIT 2 AREA



LEGEND

▲ PERMANENT HORIZONTAL CONTROL MONUMENT

X CROSS-SECTION TO BE TAKEN EACH SURVEY


— LOCATION OF ORIGINAL CROSS-SECTION

— ALTERNATE SURVEY CROSS-SECTION

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT


FIGURE 2.5-485

SCHEME FOR CPS-UHS SUBMERGED
 DAM MONITORING SYSTEM




NOTES

1. REFER TO FSAR FIGURE 2.5-372 FOR GEOLOGIC SECTION BELOW ELEVATION 620 FEET.
2. SEE FIGURE C2.5-23 FOR PLAN VIEW OF ECCS PIPELINE EXCAVATION.
3. SECTIONS SHOWN ON FIGURE 2.5-488.



CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-486
GEOLOGIC PROFILE ALONG PIPELINE - SCREENHOUSE TO MAIN PLANT




SEE NOTES ON FIGURE 2.5-486 FOR REFERENCE FIGURES.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-487


GEOLOGIC PROFILE ALONG SSWS PIPELINE - OUTLET STRUCTURE TO MAIN PLANT



NOTES:

1. SECTIONS GIVEN ARE HALF SECTIONS AND ARE SYMMETRICAL ABOUT THE CENTERLINE.
2. SECTION C-C IS TYPICAL FOR ALL BEND LOCATIONS ALONG PIPELINE.
3. SECTION F-F IS FOR AREA IMMEDIATELY ADJACENT TO MAIN PLANT STRUCTURE ONLY.
4. LOCATION OF SECTIONS SHOWN ON FIGURES 2.5-486 AND 2.5-487.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE 2.5-488 TYPICAL CROSS SECTIONS SWS PIPELINE




#	DESCRIPTION	SOIL DATA		
		γ (PCF)	C' (PSF)	ϕ
1	LOESS	120.0	0	20
2	SAND	125.0	0	38
3	WISCONSIN TILL	137.0	600	30
4	INTERGLACIAL	131.0	600	30
5	ILLINOIAN TILL	150.0	0	47
6	ALLUVIUM	120.0	120	38

- ① F.S : 1.21 (PSEUDO)
- ② F.S : 2.42 (STATIC)

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-489

STABILITY ANALYSIS - END OF CONSTRUCTION
 CONDITION - SECTION Y-Y,
 ULTIMATE HEAT SINK




#	DESCRIPTION	SOIL DATA		
		γ (PCF)	C' (PSF)	φ
1	LOESS	120.0	0	20
2	SAND	125.0	0	38
3	WISCONSIN TILL	137.0	600	30
4	INTERGLACIAL	131.0	600	30
5	ILLINOIAN TILL	150.0	0	47
6	ALLUVIUM	120.0	120	38

- ① F.S. : 1.03 (PSEUDO)
- ② F.S. : 2.15 (STATIC)

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE 2.5-490

STABILITY ANALYSIS - FULL COOLING LAKE
CONDITION - SECTION Y-Y,
ULTIMATE HEAT SINK




#	DESCRIPTION	SOIL DATA		
		γ (PCF)	C' (PSF)	ϕ
1	LOESS	120.0	0	20
2	SAND	125.0	0	38
3	WISCONSIN TILL	137.0	600	30
4	INTERGLACIAL	131.0	600	30
5	ILLINOIAN TILL	150.0	0	47
6	ALLUVIUM	120.0	120	38

⓪ F.S : 2.09 (STATIC)

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE 2.5-491

STABILITY ANALYSIS - EMPTY COOLING LAKE
 CONDITION - SECTION Y-Y,
 ULTIMATE HEAT SINK




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure 2.5-492
 (Q & R 241.7)

LATERAL SOIL PRESSURES

CPS/USAR


Figures 2.5-493 through 2.5-495
Deleted



NOTE

SEE FIGURE 2.5-376 FOR KEY.


<p>CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT</p>
<p>Figure 2.5-496 (O & R 241.8) FLY ASH MIXTURE AS FILL AND BACKFILL FOR THE SSWS DISCHARGE PIPELINE</p>



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-1

ULTIMATE HEAT SINK SALT CREEK ALLUVIUM



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-2

**ULTIMATE HEAT SINK - BORING LOCATION
PLAN AND SECTIONS**

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	FLUIDITY INDEX %	UNCONFINE D COMPRESSION			
		σ_1 psf	σ_3 psf	q_u psf						
0										
5	MA			1500*			194 205			
10								130	29.8	
15	MA						100 73	127 137	56.3	
20							80	131		
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING BH-1
SURFACE ELEVATION 690.3 ft.

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS
6 SS	SM TOP OF OUTWASH Brown, sandy silt, some fine gravel -large boulder noticed at 4.0'
44 SS	
17 SS	
30 SS	-some thin sand seams
27 SS	-mottled
100	TOP OF ILLINOIAN TILL
5"SS	ML Gray, silt, some fine sand, trace fine gravel
52 SS	
94 SS	Gray, silt, trace fine to coarse sand, trace fine gravel

676.3

Boring completed at 20. feet
on 4-1-75
Water level not recorded.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-3

LOG OF BORING BH-1

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FINER #200 SIEVE
		TRIAxIAL COMPRESSION		UNCONF. HED CONING STAGE	PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %	PLAS- TICITY INDEX %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf								
0											
5											
10											
15											
20											
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BORING BH-2

SURFACE ELEVATION 689.9 Ft.

ELEVATION
(FEET)

BLOW COUNTS
SAMPLES

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
11 SS	CL	Orange-brown to light brown, silty clay, some organics, trace fine sand.	
11 SS	SM	Medium brown, silty fine to medium sand, some coarse sand, trace fine gravel	
4 SS			
20 SS	SW	TOP OF OUTWASH	679.9
35 SS	SM	Medium brown, silty, fine to coarse sand, trace fine gravel.	
27 SS			
23 SS			
24 SS		TOP OF ILLINOIAN TILL	668.9
25 SS	CL-ML	Mottled orange-brown, fine sandy clayey silt, trace medium to coarse sand, trace fine gravel.	
37 SS	ML	Medium gray, fine sandy silt, trace organics.	
38 SS	CL ML	Medium gray, fine sandy clayey silt, trace medium to coarse sand, trace gravel seams .1 feet thick of silty fine sand.	
	ML	Medium gray, fine sandy clayey silt, trace medium to coarse sand, trace fine gravel.	

Boring completed at 27.5 feet
on 3-26-75.
Water level at 17. feet.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-4

LOG OF BORING BH-2


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf	σ_1 psf						
0				2000*	192	287	242			
5				1100*			284	94		
10	MA			3000*			170	373		
15	MA			2200*	133	107	305 145	156 123		
20	MA			6370			116 145	127 113		
25				1700*			141 102	128		
30	MA						176	253		
35										
40										
45	SA						193	97		
50							206			
55				11930			78 139			
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING BH-3

SURFACE ELEVATION 700.6 Ft.


ELEVATION
(FEET)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-5

LOG OF BORING BH-3



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-6

LOG OF BORING BH-4


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FLUIDITY INDEX %	MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FLUIDITY
		TRIAxIAL COMPRESSION		UNCONF. COMP. INDEX	PLASTIC LIMIT %	LIQUID LIMIT %	SHRINKAGE INDEX %				
		$\sigma_1 - \sigma_3$ psf	σ_3 psf								
0				2330	196	279	241	102			
5	MA						76		178		
	SA						207		119		
10	MA							274	103	260	
15	MA							234	107	483	
20	SA						146		76		
25	SA							165		59	
30	SA							142		56	
35	SA							156		69	
40											
45				4500*	106	100	95				
				4500*			102	136			
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING BH-5

SURFACE ELEVATION 691.8

ELEVATION
(FEET)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-7

LOG OF BORING BH-5

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAXIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
		σ_{1-3} psf	σ_{1-2} psf	σ_{1-1} psf						
0										
5				1000*	205	151	287	100		
				660			235	105		
10				1410	157	307	316	98		
				300*			357			
15	SA						238	96		
20				4790			90	139		
							88			
25							93	137		
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING BH-6

SURFACE ELEVATION 685.0 Ft.

ELEVATION
(FEET)

SYMBOLS

DESCRIPTIONS


5 SS	CL	TOP OF SALT CREEK ALLUVIUM Grayish brown to brown mottled, silty clay, trace fine sand.	
4 SS			
9 SS		Light grayish brown mottled, silty clay.	
7 SS			
3 SS			
8 SS	GC	TOP OF OUTWASH Gray, clayey gravel, some silt.	671.0
28 SS	GM		
41 SS	ML	TOP OF ILLINOIAN TILL Gray, silt, trace fine to coarse sand, trace fine gravel.	669.0
53 SS			
116 SS			

Boring completed at 25 feet
on 4-1-75.
Water level at 6.5 feet.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-8

LOG OF BORING BH-6



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-9
LOG OF BORING BH-7

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		$\frac{C_1+C_2}{2}$ psf	σ_3 psf	$\frac{D_L}{2}$ psf					
0									
5			500*	176	228	274	106		
10				152	95	281			
15	MA					126	9.7		
20			4000*			114	141		
25						106	136		
30						118	137		
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING BH-8

SURFACE ELEVATION 681.7 Ft.

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	TOP OF SALT CREEK ALLUVIUM Mottled grayish black to brown, silty clay, trace fine sand.	
8 SS		
3 SS		
2 SS	ML Brown, silt, trace fine sand. TOP OF 'OUTWASH	673.7
4 SS	SP SM Brown, fine sand, some silt. Brown, fine to coarse sand, some gravel, trace silt.	
19 SS		
30 SS	GP Brown, fine to medium gravel.	
23 SS	ML TOP OF ILLINOIAN TILL Gray silt, trace fine to coarse sand, trace fine gravel.	663.7
33 SS		
123 SS		
100 SS		
2"		

Boring completed at 25. feet
on 3-31-75.
Water level at 3. feet.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-10

LOG OF BORING BH-8

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	STANDARD PENETRATION TEST PASSING 200 SIEVE
		TRIAXIAL COMPRESSION		UNCONSOLIDATED COMPRESSION	PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf							
0										
5				1000*			235			
10	MA						239	644		
15	SA						104	96		
20					105	93	110	142		
25							100			
							133	132		

BORING BH-9

SURFACE ELEVATION 682.1 Ft.

ELEVATION
(FEET)

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
5 SS	CL	TOP OF SALT CREEK ALLUVIUM	
5 SS	ML	Blackish-to-brownish gray, silty clay, trace organics.	
2 SS			
2 SS	ML	Brown, silt, some fine sand, trace clay.	
2 SS			
21 SS	GP	TOP OF OUTWASH Brownish gray, fine to coarse gravel, some fine to coarse sand.	668.1
49 SS		TOP OF ILLINOIAN TILL	665.6
52 SS	ML	Gray, clayey silt, trace fine to coarse sand, trace fine gravel.	
154 SS			
133 SS			

Boring completed at 25. feet
on 3-31-75.
Water level at 4. feet.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-11

LOG OF BORING BH-9

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				
		TRIAxIAL COMPRESSION			PLASTIC LIMIT%	FLAS- TICITY INDEX%	FIELD MOISTURE CONTENT%	DRY DENSITY PCF	PERCENT PASSING 200-SIEVE
		Q ₁ +Q ₂ psf	Q ₃ psf	Q _u psf					
0									
5				16.5	23.3	25.4	106		
10						24.7			
12	SA					22.6	349		
15									
16						10.6	134		
20									
22.5						11.3	138		
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BORING BH-10

SURFACE ELEVATION 680.9 Ft.

ELEVATION
(FEET)

BLOW COUNTS
SAMPLES

SYMBOLS	DESCRIPTIONS
9 SS	TOP OF SALT CREEK ALLUVIUM Blackish-to-brownish gray, CL silty clay, trace fine sand.
3 SS	
2 SS	
2 SS	ML Gray, silt, some fine sand.
4 SS	SM Gray, silty fine sand.
16 SS	ML TOP OF ILLINOIAN TILL Gray, sandy silt, some fine gravel.
32 SS	
34 SS	
70 SS	

666.9

Boring completed at 22.5 feet
on 3-31-75.

Water level at 3.5 feet.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-12

LOG OF BORING BH-10

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAxIAL COMPRESSION		c _v or c _u psf	PLASTIC LIMIT %	FLUIDITY INDEX %	LIQUID LIMIT %			
		σ ₁ +σ ₃ 2 psf	σ ₃ psf							
0										
5					14.4	192	192	115		
10								225		
15					15.2	176	266			
				500*				226	114	
20								143		
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BORING BH-11
SURFACE ELEVATION 685.5 Ft.

ELEVATION
(FEET)

BLOW COUNTS
SAMPLES

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
	TOP OF SALT CREEK ALLUVIUM	
7 SS	CL Grayish brown to brown, silty clay, trace fine sand, trace organics.	
6 SS		
4 SS	CL Brown, silty clay, some fine to medium sand, trace fine to medium gravel.	
4 SS	ML	
4 SS		
4 SS		
4 SS	TOP OF OUTWASH	670.5
22 SS	SP Gray, fine to coarse sand, little silt, trace fine to medium gravel.	
43 SS	SM	
99 SS	ML TOP OF ILLINOIAN TILL	668.5
57 SS	Gray, clayey silt, trace fine to coarse sand, trace fine gravel.	
119 SS		

Boring completed at 27.5 feet on 3-26-75.
Water level not recorded.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-13

LOG OF BORING BH-11

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf							
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING BH-12
SURFACE ELEVATION 681.0 Ft.

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
7 SS	CL ML	TOP OF SALT CREEK ALLUVIUM Grayish black to brownish gray, silty clay, trace fine sand.	
9 SS			
2 SS	SM	TOP OF OUTWASH Reddish brown, silty fine sand, trace clay.	675.0
2 SS			
21 SS	GP	Reddish brown to dark brown, silty fine gravel, trace fine to coarse sand.	
23 SS			
41 SS	ML	TOP OF ILLINOIAN TILL Gray, clayey silt, some fine to coarse sand, trace fine gravel.	664.0
37 SS			
237 SS			
150/2'SS			

Boring completed at 24. feet
on 3-26-75.
Water level at 6.5 feet.

**CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT**

FIGURE A2.5-14

LOG OF BORING BH-12

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF	PERCENT FLUIDITY
		TRIAxIAL COMPRESSION			PLASTIC LIMIT%	FLUIDITY INDEX%	LIQUID LIMIT%	MOISTURE CONTENT%		
		σ_1 psf	σ_3 psf	σ_{1-3} psf						
0				2000*						
5					185	254	259	101		
10	MA						162		134	
15	SA						46		104	
20				4500*			120			
				4500*			116	133		
25							186			
	SA						144		92	
30							309			
35							179			
				8250			100	141		
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING BH-13

SURFACE ELEVATION 695.3 Ft.

ELEVATION
(FEET)

BLOW COUNTS SAMPLES	SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
10 SS	CL ML	Mottled medium brown to dark brown, silty clay, trace fine sand.	
13 SS			
9 SS	SP	TOP OF OUTWASH Reddish-brown, medium sand, trace silt, some medium to coarse sand.	689.3
7 SS			
39 SS	SW	Medium brown, fine to coarse sand, some fine gravel, trace silt.	
53 SS			
34 SS			
63 SS	ML	Medium brown, silt, some clay, little fine to coarse sand, trace fine gravel.	
116 SS			
31 SS	SW	Medium brown, fine to coarse sand, trace fine gravel, trace silt.	
80 SS			
142 SS	ML	Laminated brown to gray, silt, trace fine sand.	
127 SS	SM	Medium brown, silty fine to coarse sand.	
91 SS	ML	Laminated black to gray, silt, trace fine sand.	
115 SS		TOP OF ILLINOIAN TILL	659.3
133 SS	ML	Medium gray, silt, some clay, some fine to coarse sand, trace gravel.	

Boring completed at 40. feet on 4-3-75.

Water level not recorded.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-15

LOG OF BORING BH-13

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAXIAL COMPRESSION		UNCOMFINED COMPRESSION	PLASTIC LIMIT %	FLUIDITY INDEX %	LIQUID LIMIT %	PLASTICITY INDEX %			
		σ_1 psf	σ_3 psf								
0				2300				260	101		
5	MA				171	202	262	180	189		
10	SA							56	104		
15								45			
20	SA							82	108		
25								174			
30								286			
35				6480				138			
								103	135		
								83			
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING BH-14
SURFACE ELEVATION 694.1 Ft.

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	Mottled medium to dark brown, silty clay, trace fine sand, trace organics.	
10 SS		
8 SS		
7 SS	TOP OF OUTWASH	688.1
SM	Reddish-brown, silty, fine to coarse sand, trace fine to medium gravel.	
14 SS		
SW	Medium brown, fine to coarse sand, some fine to medium gravel, trace silt.	
64 SS		
77 SS		
47 SS		
48 SS		
25 SS	GP Medium brown, fine to medium gravel, some fine to coarse sand, trace silt.	
18 SS		
57 SS	SP Medium gray, fine to coarse sand, some fine gravel.	
23 SS	ML Mottled medium to dark gray, silt.	
28 SS	TOP OF ILLINOIAN TILL	665.1
75 SS	ML Medium gray, silt, some fine to coarse sand, trace fine gravel.	
168 SS		

Boring completed at 37.5 feet
on 4-4-75.
Water level at 22.0 feet.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-16

LOG OF BORING BH-14


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200-SIEVE
		COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	UNCONSOLIDATED COARSE SAND			
		$\frac{\sigma_1 + \sigma_3}{2}$	σ_3	$\frac{\sigma_1}{\sigma_3}$						
		psf	psf	psf						
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING PH-1

SURFACE ELEVATION 689.2 Ft.

ELEVATION
(FEET)



**CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT**

FIGURE A2.5-17

LOG OF BORING PH-1

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF	PERCENT PASSING #200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	LIQUID LIMIT %	PLASTICITY INDEX %	MOISTURE CONTENT %		
		σ_1 psi	σ_3 psi	UNCONF. COMP. INDEX						
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING PH-2

SURFACE ELEVATION 687.7 Ft.


ELEVATION
(FEET)

SYMBOLS		DESCRIPTIONS	ELEVATION (FEET)
AG	CL ML	Brown mottled, silty clay.	
	SC SM	TOP OF OUTWASH Brown, clayey, fine to coarse sand, some silt, little fine gravel.	683.2
BG	SP SM	Brown, silty, fine to coarse sand, some fine gravel.	
	ML	Gray, silt, some fine to medium sand, trace fine gravel.	
	ML	Gray, silt, trace organics.	
	ML	TOP OF ILLINOIAN TILL Gray, clayey, silt, trace fine to coarse sand, trace fine gravel.	664.2
<p>Boring completed at 35. feet on 3-25-75. Water level at 16.5 feet.</p>			

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-18

LOG OF BORING PH-2



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-19

LOG OF BORING PH-3

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				DRY DENSITY PCF	PERCENT PASSING NO. 200
		TRIAxIAL COMPRESSION			PLASTIC LIMIT%	FLUIDITY INDEX%	MOISTURE CONTENT%	LIQUID LIMIT%		
		σ_1 psf	σ_3 psf	σ_{1-3} psf						
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING PH-4

SURFACE ELEVATION 694.5 Ft.

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
AG	Orange-brown, mottled, silty, clay.	
CL ML		
SP SM	TOP OF OUTWASH Brown, silty fine to coarse sand, trace fine gravel.	689.5
SW	-silt and gravel grade out.	
ML	TOP OF ILLINOIAN TILL Gray, silt, trace clay, trace fine to coarse sand, trace gravel.	677.5

Boring completed at 25. feet
on 3-24-75.
Water level not recorded.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-20

LOG OF BORING PH-4

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			PLASTIC LIMIT %	FLAS- TICITY INDEX %	MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200-SIEVE
		TRIAxIAL COMPRESSION			UNCONFINE D COMPRESSION	LIQUID LIMIT %	PLASTIC LIMIT %					
		$\sigma_1 + \sigma_3$ pcf	σ_3 pcf	$\sigma_1 - \sigma_3$ pcf								
0												
5												
10												
15												
20												
25												
30												
35												
40												
45												
50												
55												
60												
65												
70												
75												

BLOW COUNTS
SAMPLES

BORING PH-5

SURFACE ELEVATION 722.6 Ft.

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL ML	TOP OF WISCONSINAN TILL Medium brown, silty clay, some fine sand.	
ML CL	Mottled brown to orange brown, clayey silt, some fine sand, trace fine gravel.	
	-grades dark brown.	
ML	TOP OF INTERGLACIAL ZONE Mottled green-to-blueish gray, clayey silt, some fine sand.	695.6
ML	TOP OF ILLINOIAN TILL Medium gray, clayey silt, some fine sand, trace fine gravel.	691.6
	Boring completed at 37. feet on 3-25-75.	
	Water level at 35.5 feet.	

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-21

LOG OF BORING PH-5


DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH				ATTERBERG LIMITS				PLASTIC LIMIT %	FLAS- TICITY INDEX %	FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT 200-SIEVE
		TRIAxIAL COMPRESSION		UNCONSOLIDATED COMPRESSION		LL	PL	U _c	U _s					
		Q ₁ psi	Q ₂ psi	Q ₃ psi	Q ₄ psi									
0														
5														
10														
15														
20														
25														
30														
35														
40														
45														
50														
55														
60														
65														
70														
75														

BLOW COUNTS
SAMPLES

BORING PH-6

SURFACE ELEVATION 713.0 Ft.

ELEVATION
(FEET)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-22

LOG OF BORING PH-6

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200 SIEVE
		TRIAxIAL COMPRESSION		UNCONFINE D COMPRESSION	PLASTIC LIMIT %	FLUIDITY INDEX %	LIQUID LIMIT %	PLASTICITY INDEX %			
		σ_1	σ_3								
0											
5											
10											
15											
20											
25											
30											
35											
40											
45											
50											
55											
60											
65											
70											
75											

BLOW COUNTS
SAMPLES

BORING PH-7

SURFACE ELEVATION 699.6 Ft.

ELEVATION
(FEET)

SYMBOLS DESCRIPTIONS

AG	CL ML	Brown, mottled, silty clay.	
	SC	TOP OF OUTWASH Brown, clayey, fine to medium sand.	693.6
	CL ML	Brownish-gray to brown, silty clay, trace fine to coarse sand, trace fine gravel.	
	ML CL	TOP OF ILLINOIAN TILL Gray, clayey silt, trace fine sand, trace fine gravel.	677.1
Boring completed at 25. feet on 3-24-75.			
Water level at 16. feet.			

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-23

LOG OF BORING PH-7

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT FINER NO. 200 SIEVE
		TRIAxIAL COMPRESSION		UNCONF. END CORRECTED	PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
		σ_1 psf	σ_3 psf							
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING PH-8

SURFACE ELEVATION 682.3 Ft.

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
AG	TOP OF SALT CREEK ALLUVIUM Blackish gray, clayey silt, trace fine sand.	
ML CL		
SC SM	TOP OF OUTWASH Brown, silty fine sand, some clay. -sand grades more coarse.	675.3
ML CL	Gray, clayey silt, trace fine to coarse sand, trace fine gravel.	
ML	Gray silt, trace organics.	
ML	TOP OF ILLINOIAN TILL	666.3
ML	Gray, clayey silt, trace fine to coarse sand, trace fine gravel.	

Boring completed at 20. feet
on 3-25-75.
Water level at 8. feet.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-24

LOG OF BORING PH-8

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	PERCENT PASSING 200-SIEVE
		TRIAxIAL COMPRESSION		UNCORRECTED OR CORRECTED	PLASTIC LIMIT %	FLAS- TICITY INDEX %	LIQUID LIMIT %			
		$\sigma_1 + \sigma_3$ psf	σ_3 psf							
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING PH-9
SURFACE ELEVATION 691.0 Ft.

ELEVATION
(FEET)

	SYMBOLS	DESCRIPTIONS	
	ML	Dark brownish-black, clayey silt.	
AG	ML	TOP OF OUTWASH	
	ML	Medium dark brown, silt, some fine to coarse sand.	687.0
	GM SM	-grades with fine to medium gravel silt grades out.	
	SM	-gravel grades out.	
BC	SM	TOP OF ILLINOIAN TILL	677.0
	ML	Medium gray, silt, some fine to coarse sand, trace fine to medium gravel.	
		Boring completed at 18.5 feet on 4-2-75.	
		Water level 8. feet.	

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-25

LOG OF BORING PH-9

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS				
		TRIAxIAL COMPRESSION			UNCONSOLIDATED COMPACTION	PLASTIC LIMIT %	PLAS- TICITY INDEX %	FLUID MOLE- CULAR CONTENT %	DRY DENSITY PCF
		σ_1 psf	σ_3 psf	Q_u psf					
0									
5									
10									
15									
20									
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BORING PH-10

SURFACE ELEVATION 697.5

ELEVATION
(FEET)

BLOW COUNTS
SAMPLES

SYMBOLS		DESCRIPTIONS	ELEVATION (FEET)
AG	ML	TOP OF SALT CREEK ALLUVIUM	
	CL	Light to medium brown, silty clay, trace medium to coarse sand, trace fine gravel.	
		TOP OF OUTWASH	885.5
	ML	Light, orangish-brown, silt, some clay, trace fine to medium gravel, some fine to medium sand.	
BG	SW	Medium brown, fine to coarse sand, some fine gravel, trace silt.	
	SP		
	SM	Medium brown, silty, fine to medium sand.	
		TOP OF ILLINOIAN TILL	651.5
	ML	Medium gray, silt, trace medium to coarse sand, trace fine to medium gravel.	
		Boring completed at 50.0 feet on 4-8-75. Water level at 15.0 feet.	

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-26


LOG OF BORING PH-10

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF	FIELD RELATIVE DENSITY PASSING 200 SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %	LIQUID LIMIT %			
		σ_1 psf	σ_3 psf	σ_3 psf						
		σ_1 psi	σ_3 psi	σ_3 psi	PL	PI	LL			
0										
5										
10										
15										
20										
25										
30										
35										
40										
45										
50										
55										
60										
65										
70										
75										

BLOW COUNTS
SAMPLES

BORING PH-II
SURFACE ELEVATION 679.2

ELEVATION
(FEET)



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-27

LOG OF BORING PH-11

DEPTH (FEET)	TESTS REPORTED ELSEWHERE	SHEAR STRENGTH			ATTERBERG LIMITS			FIELD MOISTURE CONTENT %	DRY DENSITY PCF PASSING 200-SIEVE
		TRIAxIAL COMPRESSION			PLASTIC LIMIT %	PLAS- TICITY INDEX %			
		$\frac{C_1 + C_2}{2}$ psf	σ_3 psf	Q_u psf					
		UNCONFINED COMPRESSION							
0									
5									
10									
15									
20									
25									
30									
35									
40									
45									
50									
55									
60									
65									
70									
75									

BLOW COUNTS
SAMPLES

BORING PH-12

SURFACE ELEVATION 690.3

ELEVATION
(FEET)

SYMBOLS	DESCRIPTIONS	ELEVATION (FEET)
CL	TOP OF SALT CREEK ALLUVIUM	
ML	Dark brown silty clay, trace fine to coarse sand, trace fine gravel.	
GM	TOP OF OUTWASH Brown, silty, fine to medium gravel, some fine to medium sand.	680.3
ML	TOP OF ILLINOIAN TILL	678.3
CL	Gray, clayey silt, trace fine to medium gravel, some fine to medium sand.	

Boring completed at 19.5 feet on 4-11-75.
Water level not recorded.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-28

LOG OF BORING PH-12

Key to Boring Logs

Samples

23	Indicates Standard Penetration Test Value
SS	Indicates Sample Obtained Using a Standard Split Spoon
ST	Indicates Shelby Tube Sample Obtained Using a 3.0 inch diameter Shelby Tube
PR	Indicates Sample Obtained Using a Pitcher Sampler (3.0 inch outer diameter)
CR	Indicates Sample Obtained with 4.0 inch outer diameter Core Sampler
OB	Indicates Sample Obtained Using an Osterberg Sampler (3.0 inch sample diameter)
AG	Indicates Auger Boring; No Standard Penetration Values or Samples Obtained Unless Specially Noted
BG	Indicates Bag Sample Obtained
HR	Indicates Sample Obtained with High Recovery Barrel

Test Data

Qu/2	Indicates ½ Unconfined Compressive Strength (Equal to Shear Strength) in P.S.F.
0.50	Value with no Asterisk is Obtained From RIMAC Test
0.50*	Value with Asterisk is Obtained from Pocket Penetrometer

Test Reported Elsewhere


C	Consolidation Test
COMP	Bulk Compaction Test
MA	Mechanical Particle Size Analysis (Sieve and Hydrometer)
PERM	Laboratory Permeability Test
SA	Sieve Analysis
TX/CU/PP	Consolidate-Undrained Triaxial Compression Test with Pore Pressure Measurement
TX/UU/R	Unconsolidated-Undrained Triaxial Compression Test on Remolded Samples
DR	Relative Density Test
UC/R	Remolded Samples

All Elevations Refer to Feet Above Mean Sea Level (MSL)

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure A2.5-29

KEY TO BORING LOGS



NOTES


1. Section 10-10: no slide postulated due to quarry beyond the excavated slope.
2. Section 11-11: Salt Creek alluvium excavated due to construction of submerged dike.

All elevations refer to feet above MSL.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE A2.5-30



SECTIONS 10-10 AND 11-11



CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE A2.5-31

SECTIONS 7-7, 8-8 AND 9-9



NOTE:
1. REFER TO FIGURES 2.5-19 THROUGH
2.5-65, 2.5-190 AND 2.5-192 FOR
LOGS OF BORINGS.

LEGEND:
 + BORING LOCATION
 --- TOPOGRAPHIC CONTOURS


FEET
 50 0 50 100 150

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT







FIGURE B2.5-1

FOUNDATION EXCAVATION PLAN

BORINGS



LEGEND

-  Lens 1
-  Lens 2
-  Lens 3
-  Lens 4
-  Lens 5
-  Lens 6


29 Standard split spoon sampler.

*29 Dames and Moore "U" type sampler.

CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT

FIGURE B2.5-2

SUMMARY OF BORING LOGS




LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH					MOISTURE CONTENT %	DRY DENSITY pcf
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			$\frac{q_1 - q_3}{2}$	q_3	q_u	q_p			
1	2	3	4	5	6	7	8	9	
740									
730									
720									
710									
700									
690									
680									
670									
660									
650									
640									

ELEVATION IN FEET

BORING P-50
SURFACE ELEVATION 734.8

BLOW COUNTS
SAMPLES




BORING COMPLETED AT 86.0 FEET ON 8-7-75.
CASING USED TO A DEPTH OF 4.0 FEET.
NO GROUNDWATER LEVEL RECORDED

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE B2.5-4

LOG OF BORING P-50

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.



LABORATORY TEST DATA									
TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf	
	PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAxIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER			
			σ_1 / pcf	σ_3 / pcf	q_u / pcf	q_p / pcf			
740									
730									
720									
710									
700									
690									
680									
670									
660									
650									
640									

BORING P-51

SURFACE ELEVATION 735.1

BLOW COUNTS
SAMPLES

SYMBOLS DESCRIPTIONS

100	█								
37	█								
50	█								
31	█								
22	█								
82	█								
185/9"	█								
175/11"	█								

NO SAMPLES TAKEN ABOVE ELEVATION 680 FEET

GRAY CLAYEY SILT WITH SOME SAND AND TRACE FINE GRAVEL (HARD)

GRADES WITH 1 INCH SILTY SAND SEAM AT 60.1 FEET
GRADES WITH MORE SAND
GRADES WITH THIN SILTY SAND SEAMS AT 66.5 FEET

GRAY SILTY FINE TO COARSE SAND AND SANDY SILT (DENSE)

GRAY SILT WITH SOME SAND AND TRACE FINE GRAVEL (HARD)
GRADES HARDER


BORING COMPLETED AT 85.9 FEET ON 8-9-75. CASING USED TO A DEPTH OF 5.0 FEET. WATER LEVEL NOT RECORDED.


NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE B2.5-5

LOG OF BORING P-51





NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR EXPLANATION OF SYMBOLS USED ON BORING LOGS.

LABORATORY TEST DATA

ELEVATION IN FEET	TESTS REPORTED ELSEWHERE	ATTERBERG LIMITS		SHEAR STRENGTH				MOISTURE CONTENT %	DRY DENSITY pcf
		PLASTIC LIMIT %	PLASTICITY INDEX %	TRIAKIAL COMPRESSION		UNCONFINED COMPRESSION	POCKET PENETROMETER		
				σ_1 pcf	σ_3 pcf				
740									
730									
720									
710									
700									
690									
680									
670									
660									

BORING P-55

SURFACE ELEVATION 739.0

BLOW COUNTS
SAMPLES

SYMBOLS

DESCRIPTIONS

NO SAMPLES TAKEN ABOVE
ELEVATION 679 FEET

P	ML	GRAY SANDY SILT WITH TRACE OF FINE TO COARSE GRAVEL (DENSE)
P	SM	GRAY SILTY SAND WITH TRACE OF GRAVEL (DENSE)
P	ML	GRAY SANDY SILT WITH TRACE FINE GRAVEL (DENSE)
P	SM	GRAY SILTY FINE TO COARSE SAND WITH TRACE FINE GRAVEL (DENSE)
P	ML	GRAY CLAYEY SILT WITH SOME SAND AND TRACE FINE TO MEDIUM GRAVEL (HARD)




BORING COMPLETED AT 79.0 FEET ON 8-8-75.
CASING USED TO A DEPTH OF 5.0 FEET.
GROUNDWATER LEVEL NOT RECORDED.

NOTE:
SEE FIGURE 2.5-298 AND FIGURE 2.5-355 FOR
EXPLANATION OF SYMBOLS USED ON BORING LOGS.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE B2.5-9




LOG OF BORING P-55



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE B2.5-10




PARTICLE SIZE ANALYSES (BORING P-33A)



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE B2.5-11




PARTICLE SIZE ANALYSES (BORING P-52)



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE B2.5-12




PARTICLE SIZE ANALYSES (BORING P-52)



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE B2.5-13




PARTICLE SIZE ANALYSES (BORING P-52)



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE B2.5-14


PARTICLE SIZE ANALYSES
(BORINGS P-52 AND P-54)



**CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT**

FIGURE B2.5-15

PARTICLE SIZE ANALYSES (BORING P-54)



**CLINTON POWER STATION
 UPDATED SAFETY ANALYSIS REPORT**

FIGURE B2.5-16
 PARTICLE SIZE ANALYSES (BORING P-38)

Site Stratigraphic Column

TIME STRATIGRAPHY		STRATIGRAPHIC UNITS	
		UPLAND	VALLEY
Holocene Stage			Cahokia Peyton Colluvium Alluvium
Mississippian Stage	Valderian Substage	Richland Loess	Henry Formation
	Two creek Substage		
	Woodfordian Substage	Vedron Formation	
	Farmdelian Substage	Robein Silt	
	Altonian Substage		
Sangamonian Stage			
Illinoian Stage		weathered Glasford Formation	unaltered Glasford Formation

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

Figure C2.5-1
Page 1 of 2

SITE STRATIGRAPHIC COLUMN

Site Stratigraphic Column

Stratigraphic Description		
Stratigraphic Unit	Approximate Thickness	General Description
Cahokia Alluvium	0-35 feet	Alluvium: Poorly sorted silt, clay, and silty sand with lenses of sand and gravel. (CL to SM)
Peyton Colluvium	0-10 feet	Colluvium: Brown clayey silt with minor amounts of gravel. (ML to CL)
Richland Loess	0-10 feet	Loess: Brown clayey silt, trace fine sand. (ML to CL)
Henry Formation	0-33 feet	Glacial outwash: Yellow-brown fine to coarse sand and gravel, with pockets of gray-brown silt, sandy silt, and silty clay. A lag gravel is often present at the base. (SM, SW, SP, SM-SW, SP-SW)
Wedron Formation	20-55 feet	Till: Brown silty clay to clayey silt, some interspersed fine to coarse sand, trace fine to coarse gravel, with pockets of brown fine sand, sometimes silty, trace fine gravel. Grades to gray clayey silt, some fine to coarse sand, trace fine gravel with pockets of fine to coarse gray sand, trace fine gravel. (ML to CL)
Robein Silt	0-2 feet	Loess (deposited in water): Dark brown organic silt, trace clay, trace fine sand. Locally consists of peat. (ML to CL)
Weathered Glasford Formation	10-15 feet	Till: Gray silt grading to clayey silt, trace fine sand. Grades to gray-green silty clay or clayey silt, some fine to coarse sand, trace fine to coarse gravel. More sand and gravel with depth. Slightly to highly calcareous. (ML to CL)
Unaltered Glasford Formation	90-140+ feet	Till: Dark gray clayey silt, some interspersed fine to coarse sand, highly calcareous, trace fine to coarse gravel with pockets of gray sand, fine to coarse. (ML-CL to SM)

Notes

1. Vertical scale does not represent either relative thickness or stratigraphic units or relative duration of time interval.
2. Excavations for the Clinton Power Station did not extend below the unaltered Glasford Formation.
3. Illinoian-age till of the Glasford Formation was subjected to a significant period of weathering during the Sangamonian Stage and Altonian Substage.
4. Deposits of Cahokia Alluvium and Henry Formation were not differentiated; reported approximate thicknesses of each unit represents a combined thickness for both deposits.
5. The Holocene Stage is represented by a significant period of weathering and development of agricultural soil profiles.
6. The Cahokia Alluvium and Henry Formation were mapped as a single unit. The Cahokia Alluvium is Holocene and, quite possibly, in part Valderan/Two creek in age; the Henry Formation is Woodfordian (probably early) in age. The Wedron Formation is probably early Woodfordian.
7. Locally, the Peyton Colluvium rests directly on the Glasford Formation.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
Figure C2.5-1 Page 2 of 2
SITE STRATIGRAPHIC COLUMN


Comparison of Terminology Used For The FSAR and PSAR

Time Stratigraphy		Stratigraphic Units		
		FSAR		PSAR
Holocene Stage		Cahokia Alluvium	Peyton Colluvium	Salt Creek Alluvium or Flood Plain Alluvium and Recent Channel Deposits
Wisconsinan Stage	Valderan Substage	Richland Loess	Henry Formation	Loess
	Twocreekan Substage			
	Woodfordian Substage	Wedron Formation	Wisconsinan Till or Wisconsinan Glacial Till	
	Farmdalian Substage	Robein Silt		
	Altonian Substage	Weathered Glasford Formation		Interglacial Zone or Sangamon Interglacial Zone or Sangamon Soil Interval
Sangamonian Stage				
Illinoian Stage		Unaltered Glasford Formation	Illinoian Till or Illinoian Glacial Till	

Notes

1. The Cahokia Alluvium, Peyton Colluvium, and Henry Formation consist of alluvial and outwash deposits and are confined to the valley of the North Fork of Salt Creek.
2. Vertical scale does not represent either relative thickness of stratigraphic units or relative duration of time interval.


CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
Figure C2.5-2 COMPARISON OF TERMINOLOGY USED FOR THE FSAR AND PSAR



**CLINTON POWER STATION
FINAL SAFETY ANALYSIS REPORT**

FIGURE C2.5-3



GENERAL LOCATION MAP



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE C2.5-4

EXCAVATION PLAN OF THE POWER BLOCK AND
LOCATIONS OF GEOLOGIC SECTIONS





NOTE

See Figures C2.5-11, C2.5-12, C2.5-14 and C2.5-15 for geologic sections.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**


FIGURE C2.5-5
EXCAVATION PLAN FOR THE CIRCULATING
WATER SCREEN HOUSE




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE C2.5-6

PLAN VIEW OF THE ULTIMATE HEAT SINK



NORTH WALL



LEGEND

STRATIGRAPHIC CONTACTS


- Contacts between formations
- Outline of sand deposit

REFERENCE POINTS

- ⊙ Wedron Fm./Robein Silt contact
- ⊠ Robein Silt/Weath. Glasford Fm. contact
- △ Weath. Glasford Fm./Unalt. Glasford Fm. contact
- × Sand location

NOTES


1. Location of this figure is shown in Figure C2.5-4, see also Figure No. C2.5-3.
2. Descriptions and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. Due to radial photography from center of excavation, photo mosaic is not to scale.
5. Contacts between stratigraphic units and limits of sand deposits are approximated between control points.
6. The Robein Silt is a generally 2 to 4 foot thick layer of organic silt between the tills of the Wedron and Glasford Formations.




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-7

GEOLOGIC SECTION AND PHOTO MOSAIC OF THE
NORTH WALL OF THE POWER BLOCK EXCAVATION



EAST WALL



LEGEND

STRATIGRAPHIC CONTACTS


- Contacts between formations
- Outline of sand deposit

REFERENCE POINTS

- Wedron Fm./Robein Silt. contact
- Robein Silt/ Weath. Glasford Fm contact.
- △ Weath. Glasford Fm./Unalt. Glasford Fm. contact.
- X Sand location

NOTES


1. Location of this figure is shown in Figure C2.5-4, see also Figure No. C2.5-3.
2. Descriptions and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. Due to radial photography from center of excavation, photo mosaic is not to scale.
5. Contacts between stratigraphic units and limits of sand deposits are approximated between control points.
6. The Robein Silt is a generally 2 to 4 foot thick layer of organic silt between the tills of the Wedron and Glasford Formations.




**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE C2.5-8

GEOLOGIC SECTION AND PHOTO MOSAIC OF THE
EAST WALL OF THE POWER BLOCK EXCAVATION



SOUTH WALL



LEGEND

STRATIGRAPHIC CONTACTS


- Contacts between formations
- Outline of sand deposit

REFERENCE POINTS

- ⊙ Wedron Fm./Robein Silt contact
- Robein Silt/Weath. Glasford Fm. contact.
- △ Weath. Glasford Fm./Unalt. Glasford Fm. contact
- × Sand location

NOTES


1. Location of excavation shown in Figure C2.5-4, see also Figure No. C2.5-3.
2. Descriptions and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. Due to radial photography from center of excavation, photo mosaic is not to scale.
5. Contacts between stratigraphic units and outlines of sand deposits are approximated between control points.
6. The Robein Silt is a generally 2 to 4 foot thick layer of organic silt between the tills of the Wedron and Glasford Formations.




CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-9

GEOLOGIC SECTION AND PHOTO MOSAIC OF THE SOUTH WALL OF THE POWER BLOCK EXCAVATION



WEST WALL



LEGEND

STRATIGRAPHIC CONTACTS


- Contacts between formations
- - - Outline of sand deposit

REFERENCE POINTS

- ⊙ Wedron Fm./Robein Silt contact
- Robein Silt/Weath. Glasford Fm. contact,
- ⊙ Wedron Fm./Weath. Glasford Fm. contact.
- △ Weath. Glasford Fm./Unalt. Glasford Fm. contact.

NOTES


1. Location of excavation shown in Figure C2.5-4, see also Figure No. C2.5-3.
2. Descriptions and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. Due to radial photography from center of excavation, photo mosaic is not to scale.
5. Contacts between stratigraphic units and outlines of sand deposits are approximated between control points.
6. The Robein Silt is a generally 2 to 4 foot thick layer of organic silt between tills of the Wedron and Glasford Formations.
7. The Robein Silt has been locally removed by erosion between approximately 220N to 300N.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-10

GEOLOGIC SECTION AND PHOTO MOSAIC OF THE WEST WALL OF THE POWER BLOCK EXCAVATION



LEGEND

- Contact between stratigraphic units.
- - - Inferred contact between stratigraphic units.
- Contact between sand or silt deposits.
- X Survey point

NOTES


1. Location of this geologic section is shown in Figure C2.5-5, see also Figure No. C2.5-3.
2. Description and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. Some ramps and cuts in the excavation have been omitted for clarity.
5. View is to plant north.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-11

GEOLOGIC SECTION OF THE NORTH WALL OF THE
SCREEN HOUSE EXCAVATION



LEGEND

- Contact between stratigraphic units
- - - Inferred contact between stratigraphic unit.
- Contact between sand or silt deposits.
- X Survey point

NOTES


1. Location of this geologic section is shown in Figure C2.5-5, see also Figure No. C2.5-3.
2. Description and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. Some ramps and cuts in the excavation have been omitted for clarity.
5. View is to plant east.

0 50
 Scale in feet
 Vertical Exaggeration=2X

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-12

GEOLOGIC SECTION OF THE EAST WALL OF THE
 SCREEN HOUSE EXCAVATION




NOTES

1. REFER TO FIGURE C2.5-2 AND C2.5-1 FOR DESCRIPTIONS AND AGES OF STRATIGRAPHIC UNITS.
2. REFER TO FIGURES C2.5-3, C2.5-6 AND C2.5-19 FOR LOCATION OF GEOLOGIC SECTION.



CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE C2.5-13 GEOLOGIC SECTION OF THE SOUTH ABUTMENT OF THE ULTIMATE HEAT SINK DAM EXCAVATION




(DISTANCE WEST OF NORTH-SOUTH BASE LINE)
SEE FIGURE No C2.5-5

LEGEND

- Contact between stratigraphic units.
- - - Inferred contact between stratigraphic units.
- Contact between sand or silt deposits.

NOTES


1. Location of this geologic section is shown in Figure C2.5-5, see also Figure No. C2.5-3.
2. Description and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. View is to plant south.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-14

GEOLOGIC SECTION OF THE SOUTH WALL
OF THE SCREEN HOUSE EXCAVATION



LEGEND

— — — Inferred contact between stratigraphic units.

NOTES



1. Location of this geologic section is shown in Figure C2.5-5, see also Figure No. C2.5-3.
2. Description and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in geologic section are approximations.
4. View is to plant west



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-15

GEOLOGIC SECTION OF THE WEST WALL
OF THE SCREEN HOUSE EXCAVATION




LEGEND

- + POINTS TAKEN FROM SUBGRADE PROFILES
- ⊕ POINTS FROM GEOLOGIC MAPPING
- ⊕ — SUBGRADE EXCAVATION LINE
- 2+00 STATIONING ALONG CENTER LINE OF DAM

NOTES




1. Descriptions and ages of stratigraphic units are presented in Figure C2.5-1.
2. See Figure Nos. C2.5-3 and C2.5-6 for location.



CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-16

GEOLOGIC SECTIONS AND PLAN VIEW OF
 THE ULTIMATE HEAT SINK DAM EXCAVATION




NOTES

1. Baffle dike as located by plant coordinates.
2. Descriptions and ages of stratigraphic units are presented in Figure C2.5-1.
3. See Figure Nos. C2.5-3 and C2.5-6 for locations.
4. 2900W Plant coordinates (feet).

LEGEND



+ Subgrade location.



**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE C2.5-17

GEOLOGIC SECTIONS AND PLAN VIEW OF THE
ULTIMATE HEAT SINK BAFFLE DIKE EXCAVATION



0 50
SCALE IN FEET



NOTE

See figure numbers C2.5-3 and C2.5-6 for location.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-18

EXCAVATION PLAN OF THE NORTH ABUTMENT
OF THE ULTIMATE HEAT SINK DAM




NOTE

See figure numbers
C2.5-3 and C2.5-6
for location.

**CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT**

FIGURE C2.5-19

EXCAVATION PLAN OF THE SOUTH ABUTMENT
OF THE ULTIMATE HEAT SINK DAM




HORIZONTAL SCALE IN FEET
 VERTICAL EXAGGERATION = 3X

NOTES

1. REFER TO FIGURE C2.5-1 FOR DESCRIPTIONS AND AGES OF STRATIGRAPHIC UNITS.
2. REFER TO FIGURES C2.5-3, C2.5-6 AND C2.5-18 FOR LOCATION OF GEOLOGIC SECTION.

CLINTON POWER STATION UPDATED SAFETY ANALYSIS REPORT
FIGURE C2.5-20 GEOLOGIC SECTION OF THE NORTH ABUTMENT OF THE ULTIMATE HEAT SINK DAM EXCAVATION



LEGEND


- Inferred contact between stratigraphic units.
- Contact between sand or silt units.
- X Survey point

NOTES

1. Location of this geologic section is shown in Figure C2.5-6, see also Figure No. C2.5-3.
2. Description and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in this geologic section are approximations.
4. View is to plant west.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

 FIGURE C2.5-21
 GEOLOGIC SECTION OF THE BAFFLE
 DIKE ABUTMENT EXCAVATION



LEGEND

- - - Inferred contact between stratigraphic units
- Contact between silt units
- X Survey point

NOTES


1. Location of this geologic section is shown in Figure C2.5-6, see also Figure No. C2.5-7
2. Description and ages of stratigraphic units are presented in Figure C2.5-1.
3. Limits of excavation and slopes shown in this geologic section are approximations.
4. View is to true east.






CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT

FIGURE C2.5-22

GEOLOGIC SECTION OF THE SSWS
 OUTLET STRUCTURE EXCAVATION



LEGEND

-  Sand deposits - Wedron Formation
-  Robein Silt
-  Approximate contact of Robein Silt

NOTES

1. Sand deposits exposed in SSWS piping excavation are discontinuous.
2. SSWS piping subgrade consists of Wisconsin-age fill of the Wedron Formation.
3. See figure No. C2.5-3 for location.

CLINTON POWER STATION
UPDATED SAFETY ANALYSIS REPORT
 FIGURE C2.5-23
EXCAVATION PLAN FOR THE SSWS
BUILDING