



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-5-010
(412) 787-5141
(412) 923-1960

Telecopy (412) 787-2629
January 25, 1985

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

ATTENTION: Mr. Richard W. Starostecki
Division of Project and Resident Programs

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
USNRC IE Inspection Report No. 50-412/84-12

Gentlemen:

This is in response to the Item of Noncompliance cited in Inspection No. 50-412/84-12 and listed in Appendix A (Notice of Violation) attached to your letter to Mr. E. J. Woolever, dated November 9, 1984. On December 10, 1984, Duquesne Light Company provided a partial response to the violation via letter 2NRC-4-204 and committed to address the second half of the violation by January 15, 1985. Since that time, Mr. C. E. Ewing, Manager of Quality Assurance, has requested and was granted an extension until January 22, 1985, from the Sr. Resident Inspector, Mr. G. Walton. On January 22, 1985, DLC submitted 2NRC-4-009, however, this letter is being issued to amend that response.

Response

In order to ensure that QC inspection of the system or subsystem involved is performed on a formal basis with personnel certified for the actual attributes being inspected, our procedures will be revised to include an independent QC inspection. This inspection will be performed by QC personnel on the completion status of the systems or subsystems by Construction prior to the Start-Up Group's (SUG) walkdown to conditionally accept the system for initial testing. The subsequent SUG walkdown will include a QC representative to ensure that the results and condition existing at the time of the QC inspection have not been invalidated.

The revised program will be implemented by March 1, 1985.

SUBSCRIBED AND SWORN TO BEFORE ME THIS

25th DAY OF January, 1985.

Anita Elaine Reiter

Notary Public
ANITA ELAINE REITER, NOTARY PUBLIC
ROBINSON TOWNSHIP, ALLEGHENY COUNTY
MY COMMISSION EXPIRES OCTOBER 20, 1986

JS/wjs

cc: Mr. R. DeYoung, Director (3)
Mr. B. K. Singh, Project Manager
Mr. G. Walton, NRC Resident Inspector
INPO Records Center
NRC Document Control Desk

DUQUESNE LIGHT COMPANY

By E. J. Woolever
E. J. Woolever
Vice President

8502040401 850125
PDR ADOCK 05000412
G PDR

IEOI

