

100

SEP 10 1992

Docket No. 50-282
Docket No. 50-306

Northern States Power Company
ATTN: Mr. L. R. Eliason
Vice President, Nuclear
Generation
414 Nicollet Mall
Minneapolis, MN 55401

Dear Mr. Eliason:

This is to acknowledge receipt of Revision 13 of the Prairie Island Nuclear Generating Plant Emergency Plan via letter dated June 10, 1992. We have reviewed Revision 13 with the exception of additions to Section 4, Table 1 "Summary of Emergency Action Levels". Condition 18, ISFSI Events. The emergency action levels (EALs) relevant to the independent spent fuel storage installation (ISFSI) have been forwarded to our headquarters Office of Nuclear Reactor Regulation (NRR) for their review. The results of NRR's review will be transmitted to you via a separate letter at a future date. From our review, we have determined that the remaining areas of Revision 13 do not decrease the effectiveness of your emergency planning for the Prairie Island Station.

The revision submitted included the following administrative and additional changes. The staffing goal of the Emergency Operations Facility was reduced from two to one hour to reflect the staffing of the facility by onsite personnel. The EALs defining a loss of any function needed for plant shutdown were revised to better define the inoperability of the residual heat removal system.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter will be placed in the NRC's Public Document Room.

If you have any questions, please have your staff contact Mr. Steven Orth of my staff at (708) 790-5171.

Sincerely,

J. W. McCormick-Barger, Chief
Emergency Preparedness and Non-
Power Reactor Section

See Attached Distribution:

Y
RIII
SMO
Orth/jp
9/10/92

RIII
Jorgensen
9/10/92

RIII
gms
McCormick-Barger
9/10/92

9209180029 920910
PDR ADOCK 05000282
F PDR

IE 35
1/0

Distribution

cc: E. L. Watzl, Site Manager,
Prairie Island Site
M. Sellman, Plant Manager
DCD/DCB (RIDS)
OC/LFDCB
Resident Inspector, RIII Prairie
Island
Resident Inspector, RIII Monticello
John W. Ferman, Ph.D.,
Nuclear Engineer, MPCA
State Liaison Officer, State
of Minnesota
Prairie Island, LPM, NRR
Robert M. Thompson, Administrator
Wisconsin Division of Emergency
Government