



Carolina Power & Light Company

Brunswick Nuclear Project  
P. O. Box 10429  
Southport, N.C. 28461-0429

SEP 14 REC'D

FILE: B09-13510C  
SERIAL: BSEP-92-0010

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555


BRUNSWICK STEAM ELECTRIC PLANT UNIT 1  
DOCKET NO. 50-325  
LICENSE NO. DPR-71  
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8A AND  
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-92-005)

Gentlemen:

The following is a summary of fire protection Limiting Condition for Operation (LCO) A1-92-F0542. The LCO is the result of a major outage modification being performed on the common Control Building.

At 0730 on August 10, 1992, the fire barrier between the Unit 1 Control Building stairwell and the 23' elevation cable spread room was declared inoperable. This was done in support of Plant Modification (PM) 91-011, which would require drilling bolt holes in the stairwell's South wall as part of adding new wall supports. With the fire detectors operable on at least one side of the fire barrier, an hourly fire watch was stationed and remains in place pending restoration of the fire barrier. As of August 17, 1992, the PM had taken longer than the 7 days specified by the Technical Specification LCO and required this Special Report. The PM will allow the restoration of the fire barrier prior to the Startup of either Unit.

Very truly yours,

  
J. W. Spencer, General Manager  
Brunswick Nuclear Project

cc: Mr. S. D. Ebnetter  
Mr. R. H. Lo  
BSEP NRC Resident Office

9209180261 920914  
PDR ADOCK 05000325  
S PDR

JE22/0