



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(416) 259-5737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Michael D. Lyster
VICE PRESIDENT - NUCLEAR

September 15, 1992
PY-CEI/NRR-1545 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Monthly Operating Report

Gentlemen:

Attached is the August 1992 Monthly Operating Report for Perry Unit 1. This report is submitted in accordance with Technical Specification 6.9.1.8.

If there are any questions, please feel free to call.

Sincerely,

Michael D. Lyster

MDL:DWC:ss

Attachment

cc: NRR Project Manager
USNRC Senior Resident Inspector - Perry
USNRC, Region III
Director, Office of Resource Management
Ohio EPA

9209180336 920831
PDR ADDOCK 05000440
R PDR
210020
Companies
Cleveland Electric Illuminating
Toledo Edison

JE24

CLEVELAND ELECTRIC ILLUMINATING COMPANY

FERRY NUCLEAR POWER PLANT

August 1, 1992 - August 31, 1992

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPP-58

Table of Contents

Average Daily Unit Power Level	1
Operating Data Report	2
Unit Shutdowns and Power Reductions	3

Average Daily Unit Power Level

DOCKET NO. 50-440
UNIT Perry-1
DATE 09/15/92
Contact H. L. Hegat
Telephone (216)259-3737

MONTH August 1992

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	1177	17	1180
2	1068	18	1178
3	1145	19	1182
4	1178	20	1184
5	1180	21	1184
6	1179	22	1121
7	1170	23	1059
8	1163	24	1166
9	1170	25	1165
10	1165	26	1164
11	1177	27	1169
12	1183	28	1173
13	1182	29	940
14	1182	30	917
15	1182	31	1115
16	1180		

Operating Data Report

UNIT: PERRY-1
 DATE: 09/15/92

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: August 1992
3. Utility Contact: H. L. Hegrat (216) 259-3737
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1150
6. Design Electrical Rating (Net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1166
9. If changes occur in capacity ratings (Item Numbers 4 through 8) since last report, give reasons:
None
10. Power Level to Which Restricted, If Any (Net MWe): 100%
11. Reasons for Restrictions, If Any: Operating License Limit

	This Month	Yr-to-Date	Cumulative
12. Hours In Reporting Period	744.0	5,855.0	41,963.0
13. Hours Reactor Was Critical	744.0	3,892.5	30,575.1
14. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
15. Hours Generator On-Line	744.0	3,723.1	29,617.0
16. Unit Reserve Shutdown Hours	0.0	0.0	0.0
17. Gross Thermal Energy (MWh)	2,602,799	12,653,621	101,286,510
18. Gross Electrical Energy (MWh)	892,583	4,336,074	34,830,876
19. Net Electrical Energy (MWh)	853,856	4,127,175	33,078,329
20. Unit Service Factor	100.0%	63.6%	70.6%
21. Unit Availability Factor	100.0%	63.6%	70.6%
22. Unit Capacity Factor (Using MDC Net)	98.4%	60.5%	68.6%
23. Unit Capacity Factor (Using DER Net)	96.4%	59.2%	66.2%
24. Unit Forced Outage Rate	0.0%	6.1%	7.9%
25. Forced Outage Hours	0.0	240.9	2,524.2
26. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): <u>None</u>			
27. If Shut Down at end of Report Period, Estimated Date of Startup: <u>N/A</u>			

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH August 1992

DUCKET NO. 50-440
 UNIT NAME Perry - 1
 DATE 09/15/92
 CONTACT H. L. Hegrat
 TELEPHONE (216)239-3737

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
92-05	08/29/92	S	0	H	5	N/A	N/A	N/A	Request E, system dispatcher to reduce power due to load requirements.

SUMMARY: During August, 1992, Perry-1 began the month at full power. On August 29, 1992, reactor power was reduced as requested by the system dispatcher. Perry-1 ended the month at full power.

- ¹ F: Forced
 S: Scheduled
- ² Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

- ³ Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued
 5-Reduced Load
 9-Other

- ⁴ Exhibit G-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG1022)
- ⁵ Exhibit I-Same Source