



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JAN 20 1983

MEMORANDUM FOR: Gus C. Lainas, Assistant Director for Operating Reactors, Division of Licensing

FROM: Walter R. Butler, Acting Assistant Director for Reactor Safety, Division of Systems Integration

SUBJECT: HATCH UNIT-2 TECHNICAL SPECIFICATION CHANGE

Plant Name: Hatch Unit 2
Docket Number: 50-366
Responsible Branch: Operating Reactor Branch #4
Project Manager: G. Rivenbark
DSI Branch Involved: RSB
TACs: 49054

Enclosed is the Reactor Systems Branch safety evaluation report on the Georgia Power Company's request to modify the operating limit minimum critical power ratio for Hatch Unit 2. The proposal is acceptable on the condition that technical specifications also be included for the high water level trip and the turbine bypass system.

Walter R. Butler
Walter R. Butler, Acting Assistant
Director for Reactor Safety
Division of Systems Integration

cc: R. Mattson
J. Stolz
~~G. Rivenbark~~
Section B Members, RSB
RSB Section Leaders

CONTACT: T. Collins
X29403

8301260591 XA