

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: July 1992

DOCKET NO: 50-362

UNIT NAME: SONGS - 3

DATE: 9-15-92

COMPLETED BY: J. L. Darling

TELEPHONE: (714) 368-6223

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	LER No.	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
67 *	920703	S	NA	B	5	NA	KE	COND	Reduced reactor power to 75% to perform circulating water system heat treatment and condenser water box cleaning.

* Data corrected since previous submittal.

¹F-Forced
S-Scheduled

²Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Continuation from Previous Month
5-Reduction in the Average Daily Power Level of more than 20% from the previous day
6-Other (Explain)

⁴IEEE Std 805-1984

⁵IEEE Std 803A-1983

mor.aug/19

9209210271 920915
PDR ADDCK 05000361
PDR