NOTE TO: J. Scinto

SUBJECT: SUSQUEHANNA 1 - MAIN STEAM LINE RADIATION SETPOINT

In reference to your note of August 18, 1983, the SER to be written on the main steam line radiation setpoint will address the potential existence of resin fines and, if they exist, the safety implications of condensate demineralizer resin fines blowing into the core.

T. Novak