

November 9, 1983

Note to D. Vassallo

SUBJECT: BROWNS FERRY 1 SURVEILLANCE REQUIREMENTS ON CONTROL ROOM  
EMERGENCY VENTILATION SYSTEM (OELD # 839 072)

This package is not too bad; however, on its face, it raises the question of what have we been doing for the last seven years. It says that the dampers were removed seven years ago - and now we're getting around to changing the specification on surveillance of the dampers? What have we been surveilling for the last seven years?

Joe Scinto

8502090281 840518  
PDR FOIA  
ADAT084-166 PDR