Date: September 15, 1992 PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PN39246

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility:	Licensee Emergency Classification	
Wisconsin Public Service	General Emergency	
Kewaunee Kewaunee, WI	Site Area Emergency 62	
Docket No. 50-305	Unusual Event _XN/A	

Subject: FIRE IN MAIN GENERATOR OUTPUT BREAKER

At 2:43 a.m. (CDT) on September 15, 1992, the reactor tripped following the failure of a bushing in the main generator output breaker in the 345-kilovolt section of the switchyard. The bushing failure caused a fire at the breaker, and the breaker tripped open. This lead to a turbine trip and reactor trip and to the loss of all 345-kilovolt power supplies to the plant. The 138-kilovolt power to the plant was not affected.

The City of Kewaunee fire department was summoned to the plant and extinguished the fire at 3:55 a.m. The licensee plans to repair the circuit breaker and return the plant to operation in the next few days.

The State of Wisconsin will be informed. The information in this preliminary notification has been reviewed with licensee management.

The licensee notified the NRC Operations Center of this event at 4:48 a.m. on September 15, 1992. This information is current as of 11 a.m. on September 15, 1992.

CONTACT: R. Hague

Edul 77 / June 7 R. Hague 7 F 708/790-5546 7

Eath -)An R. Greger 708/790-5644

DISTRIBUTION:

HEALQUARTERS OFFICES NMSS Comm. Rogers OSP Comm. Curtiss AQO Comm. Remick OCA. Comm. de Planque EDO Gen. Counsel 0CAA NRR Research AEOD IRM Enforcement ACRS 016 LSSA

REGIONS Region I Region II Region IV Region V Region V

we want the second seco	FAA IU:		
The Chairman 2	5-	INPO	2:00
and the second s	C 3:0		- Stand
LI			2.56
			2:56
PDR (8/634-3343)	2:53	OIG -	2:50
HQ Public Affairs			
A. Byrdsorg, NRR	essand : "	¢	
Region V			

IE 39