

February 13, 1984

Note to G. Requa

SUBJECT: ROBINSON 2 - AUXILIARY FEEDWATER INITIATION (OELD # 842 135)

This basis for the no significant hazards consideration conclusion is not sufficient. All you simply say is that the reason for the changes is to make the tech spec consistent. That's dandy but there is no justification for asserting that the correct consistency is to raise the 200° temperature to 350°. Its not clear that the correct way to do this isn't to reduce the 350° to 200°. You have to give more description. Consistency is not sufficient. You also have to describe ... not only is it consistent but its the right way to be consistent. You have to have some discussion to indicate that this is the right direction for this change to be made in, that there isn't any problem with making the change in this direction.

*AmB*  
*for* Joe Scinto

cc: M. Karman

8502090358 840518  
PDR FOIA  
ADAT084-166 PDR

181