

February 27, 1984

Note to Ralph Birkel

SUBJECT: McGUIRE 1 - MODES 5&6, COLD SHUTDOWN & REFUELING (OELD # 842 202)

We need at least some indication that we've done an evaluation to reach the conclusion that its safe to allow them to make this tech spec change. This package doesn't seem to be anything but a lot of words. What evaluation, what thought process, did this Agency go through to reach the conclusion that its okay to switch from one mode to another without having control room ventilation?

amb
for Joe Scinto

8502090484 840518
PDR FOIA
ADAT084-166 PDR

200